

6. Project Implementation Programme

The study result shows following implementation programme in order to start DeSOx system commercial operation on the first of January 1998.

(1)	Completion of the Feasibility Study	End of Dec. 1991
(2)	Preparation of Financial Source	End of Jan. 1993
(3)	Selection of Consultant	End of Apr. 1993
(4)	Detailed Design and Preparation of Tender Documents	End of Nov. 1993
(5)	Completion of Tender Evaluation	End of May 1994
(6)	Contract Award	End of May 1994
(7)	Commencement of Civil Work	Beginning of Oct. 1994
(8)	Erection Start	Beginning of Jun. 1995
(9)	Trial Operation Start	Beginning of Sep. 1996
(10)	Taking Over	End of Oct. 1997
(11)	Commercial Operation Start	1st of Jan. 1998

In Table 6-1, 6-2 (1) and (2), implementation schedule and construction schedule are shown.

Table 6-1 KOZIENICE POWER PLANT FGD SYSTEM IMPLEMENTATION SCHEDULE

Year	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000
Basic Schedule		Completion of Feasibility Study (F/S)		Decision of Implementation	Contract Award	Commencement of Erection		Taking Over	New Regulation Come in Force		
1. F/S Finish		→									
2. Preparation of Financial Source		○	○								
3. Decision of Implementation			▼								
4. Selection of Consultants			○	○							
5. Defenit Design (D/D)				○	○						
6. Preparation of Tender Specification				○	○						
7. Bidding				○	○						
8. Bid Evaluation					○	○					
9. Contract Award					▼						
10. Engineering & Design					○	○					
11. Procurement					○	○					
12. Transportation						○	○				
13. Civil Work (Incl. Drilling)					○	○					
14. Erection						○	○				
15. Test & Commissioning								○	○	○	○

No. 1 No. 2 No. 3

7. Construction Cost and Operation and Maintenance Cost

Construction cost for 3 units of 500 MW class FGD system with 89% DeSOx efficiency are estimated at 185,404,000 U\$.

This is equivalent to 123.6 U\$ per kW.

Costs are estimated as of March 1st 1991.

In Fig. 7-1, scope of the following cost estimation is shown.




Fig. 7-1 Supply Limit of One 500 MW FGD Plant

(1) Estimated Construction Cost

	<u>x 10⁶ ZL</u>	<u>x 10³ US\$</u>
a. DeSOx System and Associated Equipment	1,130,833	119,035
b. Transportation	43,890	4,620
c. Construction	92,369	9,723
d. Civil Work	112,575	11,850
e. Modification of Existing Facilities	12,350	1,300
f. Spare Parts	22,686	2,388
g. Start-up and Commissioning	22,686	2,388
h. Import Tax	94,212	9,917
[Direct Construction Cost] a ~ h	[1,531,601]	[161,221]
i. Engineering Fee [5% of Direct Const. Cost]	76,580	8,061
j. Contingency [5% of Direct Const. Cost]	76,580	8,061
k. Administration fee [5% of Direct Const. Cost]	76,580	8,061
[Total Construction Cost] a ~ k	[1,761,341]	[185,404]
[Construction Cost per kW]	[1,174 x 10 ³ ZL/kW]	[123.6 US\$/kW]

(2) Annual O&M Cost

	<u>x 10³ ZL</u>	<u>US\$</u>
a. Utilities Cost	40,220,680	4,233,756
b. Labor Cost	1,111,824	117,034
c. Maintenance Cost	76,579,975	8,061,050
[Total]	[117,912,479]	[12,411,840]

8. Operation and Maintenance

(1) Methods of Operation

The FGD Units are started and stopped linked usually with start and stop of power generation plants.

The FGD Units are started in the sequence of the absorbing systems, the drafting systems and the gypsum processing systems. The FGD Units are stopped, on the other hand, in the sequence of the drafting systems, absorbing systems and the gypsum processing systems. Fig. 8-1 shows starting and stopping timings of the unit-to-unit FGD Unit.

As for stopping, regulations on volume of emission applies to the Kozienice Power Plant but no regulation on concentration applies. Thus, it is possible, at the Kozienice Power Plant, to stop FGD Units during low load operations.

The FGD Units are started remotely from the Control Room. The FGD Units are started system by system sequentially by operating on the CRT of the Control Desk. The starting flow chart is shown in Fig. 8-2.

The FGD Units are stopped system by system, from the Control Room, sequentially by operating on the CRT as in the case of starting. A stop mode is either a short-term stop mode or a long-term stop mode.

A flow chart of the short-term stop mode is shown in Fig. 8-3.

(2) Performance Management

It is desirable to practice performance management in routine operations. One way to do so is to prepare and keep operation log sheet having items necessary for judging operating conditions including performance items.




Fig. 8-1 FGD UNIT START UP SHUT DOWN TIMING CHART

Fig. 8-2 FLOW CHART OF START UP PROCEDURE (1/2)




Fig. 8-2 FLOW CHART OF START UP PROCEDURE (2/2)





Fig. 8-3 FLOW CHART OF SHUT DOWN PROCEDURE
(SHORT TERM STOP MODE)



(3) Maintenance Procedures

In addition to keeping monitoring the operating condition in the Control Room, it is desirable to patrol, at each shift, the field to check for equipment troubles. For patrolling, it is desirable to prepare a check sheet considering the route of equipment inspection, inspection frequency, points of inspection, points of special observation, etc., and patrol the field according to the check sheet.

The FGD must be stopped once a year for scheduled inspection. In the FGD, especially, gypsum sedimentation and clogging possibly occur in the tower, tanks, pumps and pipings, and it is necessary to remove and clear such sedimentation and clogging in addition to overhauling of each equipment.

9. Analysis and Evaluation on Socioeconomic Impact

9.1 Analysis on Socioeconomic Impact

- (1) Annual cost in each year was calculated from the total construction cost including interest during construction based on the construction cost in Chapter 7.

Total construction cost is shown in Table 9-1. In addition total construction cost of which financing for local portion is partly covered with foreign loan is shown in Table 9-2.

Tariff is calculated based on the annual cost. As a result of this calculation, 33 to 41ZL/kWh (0.35¢ to 0.43 ¢/kWh) additional burden in tariff is estimated. Increase in tariff enabling to recover this burden is strongly recommended. Tariff trend in each year are shown in Table 9-3 and 9-4. (With 1991 February cost ... Inflation is disregarded)

- (2) For the economic evaluation, reconstruction of boilers into natural gas firing which has the same reduction of SO₂ effect as this project was chosen.

Flow of benefit and cost of the evaluation is shown in Table 9-5 EIRR. Excess benefit (B-C) and Benefit-Cost ratio (B/C) are as follows.

EIRR	37.69%
B-C	3,560.3 x 10 ⁹ ZL
B/C	2.832

Judging from the study results of the above, this project is much superior to the partial reconstruction of the boilers into natural gas firing which has the same SO₂ reduction effect in terms of cost.

This superiority is maintained until social discount rate which reflects opportunity cost of capital reaches 37.69%.

Table 9-1 Total Construction Cost

(1,000 US\$)

Interest for Foreign Loan	3.5%			5%			8.5%			
	Local Portion	Foreign Portion	Total	Local Portion	Foreign Portion	Total	Local Portion	Foreign Portion	Total	
10%	C.C.	109,621	75,783	185,404	109,621	75,783	185,404	109,621	75,783	185,404
	I.D.C.	29,784.03	12,551.36	42,335.39	29,784.03	18,226.14	48,010.17	29,784.03	32,205.47	61,989.5
	Total	139,405.03	88,334.36	227,739.39	139,405.03	94,009.14	233,414.17	139,405.03	107,988.47	247,393.5
15%	C.C.	109,621	75,783	185,404	109,621	75,783	185,404	109,621	75,783	185,404
	I.D.C.	45,662.63	12,551.36	58,213.99	45,662.63	18,226.14	63,888.77	45,662.63	32,205.47	77,868
	Total	155,283.63	88,334.36	243,617.99	155,283.63	94,009.14	249,292.77	155,283.63	107,988.47	263,272.1

Note: C.C.: Construction Cost
I.D.C.: Interest during Construction

Table 9-2 Total Construction Cost

(1,000 US\$)

Interest for Foreign Loan	3.5%			5%			8.5%			
	Local Portion	Foreign Portion	Total	Local Portion	Foreign Portion	Total	Local Portion	Foreign Portion	Total	
10%	C.C.	74,162	111,242	185,404	74,162	111,242	185,404	74,162	111,242	185,404
	I.D.C.	20,149.82	15,828.39	35,978.21	20,149.82	22,938.64	43,088.46	20,149.82	40,340.89	60,490.71
	Total	94,311.82	127,070.39	221,382.21	94,311.82	134,180.64	228,492.46	94,311.82	151,582.89	245,894.71
15%	C.C.	74,162	111,242	185,404	74,162	111,242	185,404	74,162	111,242	185,404
	I.D.C.	30,892.18	15,828.39	46,720.57	30,892.18	22,938.64	53,830.82	30,892.18	40,340.89	71,233.07
	Total	105,054.18	127,070.39	232,124.57	105,054.18	134,180.64	239,234.82	105,054.18	151,582.89	256,637.07

Note: C.C.: Construction Cost
I.D.C.: Interest during Construction

Table 9-3 Calculation of Tariff

Year after Completion	Depreciation	Interest	Utility Cost	Personnel Cost	Repair Cost	(USD 1000) Total	Tariff (Yen/KWh)	Tariff (ZL/KWh)	Tariff (c/KWh)
1	21939.342	20983.290	4233.756	943.341	8081.05	56140.978	0.38	41.03	0.43
2	21939.342	18683.048	4233.756	943.341	8081.05	53811.724	0.36	39.22	0.41
3	21939.342	20689.318	4233.756	943.341	8081.05	58317.007	0.38	40.79	0.43
4	21939.342	22389.628	4233.756	943.341	8081.05	57567.317	0.60	42.07	0.44
5	21939.342	19550.428	4233.756	943.341	8081.05	54728.117	0.37	39.99	0.42
6	21939.342	16711.228	4233.756	943.341	8081.05	51888.917	0.34	37.82	0.40
7	21939.342	13872.028	4233.756	943.341	8081.05	49049.717	0.31	35.84	0.38
8	21939.342	11032.828	4233.756	943.341	8081.05	46210.517	0.48	33.77	0.36
9	21939.342	8193.628	4233.756	943.341	8081.05	43371.317	0.45	31.69	0.33
10	21939.342	5354.428	4233.756	943.341	8081.05	40532.117	0.42	29.62	0.31
11	21939.342	4844.48	4233.756	943.341	8081.05	40022.172	0.41	29.25	0.30
12	21939.342	4079.585	4233.756	943.341	8081.05	39257.283	0.17	12.50	0.13
13	0.000	3314.646	4233.756	943.341	8081.05	16552.593	0.17	11.72	0.12
14	0.000	2804.701	4233.756	943.341	8081.05	16043.048	0.16	11.35	0.12
15	0.000	2294.756	4233.756	943.341	8081.05	15533.102	0.15	10.98	0.11
16	0.000	1784.809	4233.756	943.341	8081.05	15023.156	0.13	10.61	0.11
17	0.000	1274.864	4233.756	943.341	8081.05	14513.211	0.13	10.24	0.11
18	0.000	764.918	4233.756	943.341	8081.05	14003.265	0.14	9.87	0.10
19	0.000	254.973	4233.756	943.341	8081.05	13493.320	0.14	9.50	0.10
20	0.000	0.000	4233.756	943.341	8081.05	12983.374	0.14	9.13	0.10
21	0.000	0.000	4233.756	943.341	8081.05	12473.429	0.14	8.76	0.10
22	0.000	0.000	4233.756	943.341	8081.05	11963.483	0.14	8.39	0.10
23	0.000	0.000	4233.756	943.341	8081.05	11453.538	0.14	8.02	0.10
24	0.000	0.000	4233.756	943.341	8081.05	10943.592	0.14	7.65	0.10
25	0.000	0.000	4233.756	943.341	8081.05	10433.647	0.14	7.28	0.10
26	0.000	0.000	4233.756	943.341	8081.05	9923.701	0.14	6.91	0.10
27	0.000	0.000	4233.756	943.341	8081.05	9413.756	0.14	6.54	0.10
28	0.000	0.000	4233.756	943.341	8081.05	8903.810	0.14	6.17	0.10
29	0.000	0.000	4233.756	943.341	8081.05	8393.865	0.14	5.80	0.10
30	0.000	0.000	4233.756	943.341	8081.05	7883.919	0.14	5.43	0.10

Annual Operation Hour 5000
 Annual Load Factor 37
 Auxiliary Loss 13000000000
 Annual Net Generation(KWh) 13000000000
 Depreciation Straight Method
 Residual Value 0
 Term (Year) 12
 Total Value 283272.100

Amount of Coal in 1990 526.9 Billion Zl
 Construction Cost 161221

Table 9-4 Calculation of Tariff

Year after Completion	Depreciation	Interest	Utility Cost	Personnel Cost	Repair Cost	USD 1000 Total	Tariff (Yen/kWh)	Tariff (Zl/kWh)	Tariff (¢/kWh)
1	18978.283	1256.452	4233.756	943.541	801.05	4376.822	0.45	21.71	0.24
2	18978.283	1152.402	4233.756	943.541	801.05	4269.032	0.42	21.59	0.22
3	18978.283	1118.323	4233.756	943.541	801.05	4241.922	0.42	21.77	0.22
4	18978.283	1198.262	4233.756	943.541	801.05	4181.110	0.42	21.53	0.22
5	18978.283	933.551	4233.756	943.541	801.05	4023.329	0.40	21.22	0.21
6	18978.283	660.528	4233.756	943.541	801.05	3871.776	0.39	21.02	0.20
7	18978.283	435.116	4233.756	943.541	801.05	3715.176	0.37	20.85	0.20
8	18978.283	326.932	4233.756	943.541	801.05	3560.122	0.35	20.72	0.20
9	18978.283	1803.482	4233.756	943.541	801.05	3284.322	0.32	20.52	0.20
10	18978.283	1131.732	4233.756	943.541	801.05	3250.770	0.32	20.43	0.20
11	18978.283	1174.090	4233.756	943.541	801.05	3153.755	0.31	20.32	0.20
12	0.000	844.687	4233.756	943.541	801.05	14011.273	0.11	10.24	0.11
13	0.000	772.925	4233.756	943.541	801.05	13839.511	0.14	10.11	0.11
14	0.000	601.164	4233.756	943.541	801.05	13667.750	0.14	9.86	0.11
15	0.000	429.403	4233.756	943.541	801.05	13495.888	0.14	9.74	0.11
16	0.000	285.881	4233.756	943.541	801.05	13324.228	0.14	9.67	0.11
17	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
18	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
19	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
20	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
21	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
22	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
23	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
24	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
25	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
26	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
27	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
28	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
29	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11
30	0.000	0.000	4233.756	943.541	801.05	13238.347	0.14	9.67	0.11

Annual Operation Hour 5000
 Annual Load Factor 57
 Auxiliary Cost 13000000000
 Annual Net Generation(kWh) 13000000000
 Depreciation Method Straight Method
 Residual Value 0
 Term (Year) 12
 Total Value 227789.380

Amount of Coal in 1990 526.9 Billion Zl
 Construction Cost 161221

Table 9-5 Economic Evaluation

No. Year	Investment		Costs		Total Cost (N.P.V.)	Total Cost	Benefits		Fuel Cost	Total Benefit (N.P.V.)	Benefit-Costs
	Investment	Repair Cost	OM Cost	OM Cost			OM Cost	Total Benefit			
1	32,640	0.000	0.000	0.000	32,640	32,640	0.000	0.000	0.000	0.000	0.000
2	0.000	283.434	0.000	273.053	273.053	328.474	0.000	0.000	0.000	102.389	75.330
3	0.000	286.008	0.000	274.473	274.473	333.903	0.000	0.000	0.000	102.389	77.370
4	0.000	181.717	0.000	176.466	176.466	291.172	0.000	0.000	0.000	102.389	84.911
5	0.000	0.000	60.806	62.466	62.466	121.611	-34.736	514.500	514.500	429.590	102.389
6	0.000	0.000	121.611	58.472	58.472	121.611	-68.472	1029.000	1029.000	447.527	102.389
7	0.000	0.000	121.611	51.752	51.752	121.611	-68.472	1029.000	1029.000	406.934	102.389
8	0.000	0.000	121.611	48.886	48.886	121.611	-68.472	1029.000	1029.000	388.340	102.389
9	0.000	0.000	121.611	42.524	42.524	121.611	-68.472	1029.000	1029.000	369.746	102.389
10	0.000	0.000	121.611	38.725	38.725	121.611	-68.472	1029.000	1029.000	351.151	102.389
11	0.000	0.000	121.611	32.704	32.704	121.611	-68.472	1029.000	1029.000	332.556	102.389
12	0.000	0.000	121.611	28.115	28.115	121.611	-68.472	1029.000	1029.000	313.961	102.389
13	0.000	0.000	121.611	24.050	24.050	121.611	-68.472	1029.000	1029.000	295.366	102.389
14	0.000	0.000	121.611	20.477	20.477	121.611	-68.472	1029.000	1029.000	276.771	102.389
15	0.000	0.000	121.611	18.000	18.000	121.611	-68.472	1029.000	1029.000	258.176	102.389
16	0.000	0.000	121.611	16.433	16.433	121.611	-68.472	1029.000	1029.000	239.581	102.389
17	0.000	0.000	121.611	14.939	14.939	121.611	-68.472	1029.000	1029.000	220.986	102.389
18	0.000	0.000	121.611	13.581	13.581	121.611	-68.472	1029.000	1029.000	202.391	102.389
19	0.000	0.000	121.611	12.344	12.344	121.611	-68.472	1029.000	1029.000	183.796	102.389
20	0.000	0.000	121.611	11.224	11.224	121.611	-68.472	1029.000	1029.000	165.201	102.389
21	0.000	0.000	121.611	10.218	10.218	121.611	-68.472	1029.000	1029.000	146.606	102.389
22	0.000	0.000	121.611	9.323	9.323	121.611	-68.472	1029.000	1029.000	128.011	102.389
23	0.000	0.000	121.611	8.538	8.538	121.611	-68.472	1029.000	1029.000	109.416	102.389
24	0.000	0.000	121.611	7.862	7.862	121.611	-68.472	1029.000	1029.000	90.821	102.389
25	0.000	0.000	121.611	7.295	7.295	121.611	-68.472	1029.000	1029.000	72.226	102.389
26	0.000	0.000	121.611	6.838	6.838	121.611	-68.472	1029.000	1029.000	53.631	102.389
27	0.000	0.000	121.611	6.491	6.491	121.611	-68.472	1029.000	1029.000	35.036	102.389
28	0.000	0.000	121.611	6.254	6.254	121.611	-68.472	1029.000	1029.000	16.441	102.389
29	0.000	0.000	121.611	6.128	6.128	121.611	-68.472	1029.000	1029.000	-2.154	102.389
30	0.000	0.000	121.611	6.113	6.113	121.611	-68.472	1029.000	1029.000	-10.759	102.389
Total	1812.808	0.000	2979.471	4882.280	1842.820	4882.280	-1702.024	25210.500	24050.458	5503.288	1938.156

Discount Rate 10.00%
 O&M Cost(USD) 3085929
 Repair Cost(MTY) 1088.24
 Benefit 542
 EDR B/C(Discout Rate=10%) 542
 B/C(Discout Rate=10%) 542

9.2 Evaluation on Socio-economic Impact

- (1) During reconstruction of Japanese economy after World War II, investment for environmental protection accounted for 3% of total investment of private companies. At that time the position of environmental protection was not clearly specified in the legislation for environmental protection and no governmental agency in charge of environmental issue did not exist.

In the prime of economic high rate growth, around 1970, environmental issue became the national-wide problem. Many environmental acts were enacted and the Environmental Agency was established in 1971. Environmental administration was strengthened in this way.

As in the field of electric utility legislations were systematized, technology on flue gas treatment was introduced. Flue gas desulphuriser for coal fired thermal power stations was started at the Takasago Thermal Power Station as a pioneer and at the almost all coal fired thermal power stations and high sulphur oil fired thermal power stations, total 68 units 23,450 kW so far, flue gas desulphuriser were installed.

- (2) Macro economic method for socio-economical evaluation on introduction of environmental protection has not been fully developed. However,

- 1) At the Tokyo Conference of Roma Club in 1982, Prof. Dr. Yoichi Kaya, University of Tokyo, presented a estimation, based on rough assumptions, that damage amounted to $6,000 \times 10^9$ Yen (45×10^9 US dollars) in comparison with that the cost for SO_x removal amounted 480×10^9 Yen (3.7×10^9 Milliard US dollars) and
- 2) Environmental white paper for FY 1977 stipulated that there was hardly no adversal effect on macro economies although countermeasures for environmental protection were carried out from 1965 to 1975.

Those had affirmative effect that real rate of economic growth was raised by 0.9%.

(3) Following are analysis on introduction of DeSOx equipment in Polish power stations based on above analyses.

- 1) Economic extension and increase in employment attributable to increase in investment.
- 2) Absorbable effect on energy tariff
- 3) Increase in export

Poland is already industrialized. In this project, local procurement shall be extended as much as possible so that technology can be absorbed aggressively. As a consequence, Poland will be able to export DeSOx equipments to neighbor countries by taking advantage of its comparatively cheap labor cost and such technology.

10. Recommendation for the Implementation of the Project

- (1) Arrangement of Scheme for Local Portion Investment : Improvement of Domestic Financial Market etc.

It has been studied that the Project be implemented as much as possible inside Poland for the least cost and giving good influence on Polish economy as well as taking into account current level of Polish technology. Consequently, although our Study has satisfied this requirement, there remains some problems in connection with the financing on the local portion of the Project.

As the present scheme loans on the basis of the Official Development Assistance in every countries as well as loans from organization for international aid such as the World Bank have limitation for credit line for local portion of projects. Therefore, a certain part of investment for local portion shall be funded from domestic financial market. However, since Polish private financial market is still unmaturred, it is difficult to fund from the market at this stage. Therefore, the following schemes for financing on the local portion will be thought necessary to make the Project implement as scheduled.

- a. Application of the Polish Environmental Fund
- b. Application of a governmental financing entity

If expansion of the activity of private banking system, which is operated on the basis of saving of the national, will not be expected soon, application of a governmental financing entity (if no such an organization, urgent establishment is necessary) shall be studied. Since environmental project is expected to generate effective demand of Polish national economy, application of the governmental financing entity will be thought very useful.

c. Application of Debt for Nature Swap

To a certain extent, Debt for Nature Swap will be applicable to the implementation of the Project, upon agreement with a private bank which has credit to Polish government. (This scheme was materialized in Philippine.)

(2) Arrangement of the Electricity Tariff System

Unless credit incurred from this Project is duly borne by consumers in electricity tariff, it will increase national financial deficit and make inflation worse. Rise of electricity tariff by the implementation of the Project will be estimated at about 20 percent point (40ZL) on the basis of wholesaling price from the Koziénice Power Plant even in the first year from the completion of FGD Units. This will be equivalent to only 4ZL/kWh rise if the cost increase caused from the FGD Units installation of Koziénice Power Plant can be distributed in total electricity consumption all over the country.

Therefore, it shall be materialized that environmental cost including the investment cost be duly included in a new electricity tariff system, revision of which is under way from the basis of the subsidized by the government to the basis of actual cost.

(3) Consideration to High Chlorine Content of Coals

Coals used at the Koziénice Power Plant are high in chlorine content. At present, there is no commercially proven technology to lower chlorine content of waste water from the wet limestone-gypsum DeSOx system to a level at which the waste water can be discharged to river water.

In this Feasibility Study, it is planned that the waste water and gypsum from FGD system are to be mixed with flyash and are to be discarded to a disposal area to be built adjacent to the ash disposal area.

High chlorine content in coal affects to a design of FGD system to a great extent, therefore a study to lower chlorine content as much as possible is necessary.

At a detailed design stage, it is preferable to make a study to reduce chlorine content in coal by purchasing low chlorine coal and/or making optimum blending of coals, etc.

