

6-1 上エジプト地域の気象状況

	1989年
1) 気温	
最高気温	50°C
最低気温	2°C
最暑月の日平均最高気温	42°C
最寒月の日平均最低気温	9°C
2) 降雨	
降雨は殆どなく、たまに冬期に見られる。	
年最高雨量	8mm
年平均雨量	3mm
3) 雪、みぞれ	
今までに記録がない。	
4) 気圧	
高気圧発生月の平均	1,017mb
低気圧発生月の平均	1,005mb
年平均	1,011mb
最高気圧	1,027mb
最低気圧	999mb
5) 相対湿度	
最湿潤月の平均湿度	45%
最乾月の平均湿度	25%
年間平均湿度	34%
湿度はしばしば4%以下になることがあり、たまに0のことも起こる。	
6) 風速、嵐	
最高風速は120km/h. 風向は一定でない。砂嵐は月1回の割でおこる。	
雷は過去14年間記録がなかった。	

6.2 ナイル川の月別放出水量及び各地水位(1987年)

1/6

月	最大放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)	最小放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)
Jan.	120	83.09	81.60	80	<u>82.20</u>	<u>81.00</u>
Feb.	145	83.60	82.40	120	83.09	81.70
Mar.	135	83.40	82.20	120	83.09	81.81
Apr.	135	83.40	82.25	135	83.40	81.80
May	—	84.26	82.25	—	83.50	82.10
Jun.	—	—	—	—	—	—
Jul.	230	<u>85.11</u>	<u>83.60</u>	215	84.87	83.30
Aug.	215	84.87	83.50	170	84.08	82.60
Sep.	170	84.08	82.80	135	83.40	82.20
Oct.	135	83.40	82.20	110	82.89	81.30
Nov.	110	82.89	81.70	105	82.78	81.50
Dec.	115	83.00	81.70	95	82.55	81.40

* アスワン水位の最大水位差: $2.91M = 85.11M - 82.20M$

* エルガーフラ水位の最大水位差: $2.60M = 83.60M - 81.00M$

- 注記: 1. アスワン水位はアスワンハイダムより6.5KM下流の水位。
 2. エルガーフラ水位はアスワンハイダムより34KM下流の水位。
 3. —印は資料無しを示す。

出所: Irrigation Department at Aswan, MPWWR

ナイル川の月別放出水量及び各地水位 (1988年)

2/6

月	最大放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)	最小放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)
Jan.	110	82.89	81.50	75	<u>82.07</u>	81.40
Feb.	120	83.10	81.95	115	83.00	81.50
Mar.	130	83.30	82.30	110	82.89	81.70
Apr.	135	83.40	82.20	130	83.30	81.95
May	190	84.26	82.80	140	83.50	82.20
Jun.	225	<u>85.03</u>	<u>83.70</u>	205	84.71	83.35
Jul.	225	<u>85.03</u>	<u>83.70</u>	210	84.79	83.40
Aug.	205	84.71	83.40	165	83.99	82.60
Sep.	165	83.99	82.70	125	83.20	82.10
Oct.	125	83.20	82.10	110	82.89	81.70
Nov.	110	82.89	81.85	100	82.67	81.60
Dec.	115	83.00	81.80	90	82.43	<u>81.30</u>

* アスワン水位の最大水位差： $2.96M = 85.03M - 82.07M$

* エルガーフラ水位の最大水位差： $2.40M = 83.70M - 81.30M$

- 注記： 1. アスワン水位はアスワンハイダムより6.5KM下流の水位。
 2. エルガーフラ水位はアスワンハイダムより34KM下流の水位。
 3. —印は資料無しを示す。

出所： Irrigation Department at Aswan, MPWWR

ナイル川の月別放出水量及び各地水位(1989年)

3/6

月	最大放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)	最小放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)
Jan.	115	83.00	81.80	75	<u>82.07</u>	81.35
Feb.	115	83.00	81.90	115	83.00	81.75
Mar.	130	83.30	82.15	120	83.10	81.85
Apr.	140	83.50	82.25	130	83.30	82.10
May	200	84.63	83.10	145	83.60	82.25
Jun.	245	<u>85.39</u>	<u>84.00</u>	210	84.87	83.20
Jul.	240	85.27	83.95	215	84.87	83.55
Aug.	210	84.79	83.60	170	84.08	82.65
Sep.	170	84.08	82.65	115	83.00	81.70
Oct.	115	83.00	81.75	105	82.78	81.40
Nov.	110	82.89	81.75	100	82.67	81.50
Dec.	110	82.89	81.75	90	82.43	<u>81.30</u>

* アスワン水位の最大水位差: $3.32M = 85.39M - 82.07M$

* エルガーフラ水位の最大水位差: $2.70M = 84.00M - 81.30M$

- 注記: 1. アスワン水位はアスワンハイダムより6.5KM下流の水位。
 2. エルガーフラ水位はアスワンハイダムより34KM下流の水位。
 3. -印は資料無しを示す。

出所: Irrigation Department at Aswan, MPWWR

ナイル川の月別放出水量及び各地水位 (1990年)

4/6

月	最大放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)	最小放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)
Jan.	110	83.00	81.70	75	<u>82.07</u>	<u>80.90</u>
Feb.	145	83.60	82.15	115	83.00	81.70
Mar.	140	83.50	82.25	125	83.20	81.75
Apr.	140	83.50	82.35	140	83.50	82.25
May	230	85.11	83.70	145	83.60	82.30
Jun.	240	<u>85.27</u>	<u>83.90</u>	235	85.19	83.70
Jul.	235	85.19	83.80	210	84.79	83.40
Aug.	210	84.79	83.45	170	84.08	82.75
Sep.	170	84.08	82.85	105	82.78	81.80
Oct.	115	83.00	81.85	105	82.78	81.60
Nov.	115	83.00	81.85	95	82.55	81.35
Dec.	110	82.89	81.45	80	82.19	81.20

* アスワン水位の最大水位差： $3.20\text{M} = 85.27\text{M} - 82.07\text{M}$

* エルガーフラ水位の最大水位差： $3.00\text{M} = 83.90\text{M} - 80.90\text{M}$

- 注記： 1. アスワン水位はアスワンハイダムより6.5KM下流の水位。
 2. エルガーフラ水位はアスワンハイダムより34KM下流の水位。
 3. -印は資料無しを示す。

出所： Irrigation Department at Aswan, MPWWR

ナイル川の月別放出水量及び各地水位 (1991年)

5/6

月	最大放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)	最小放出量 (百万M3/日)	アスワン 水位 (M)	エルガーフラ 水位 (M)
Jan.	115	83.00	81.45	65	<u>81.84</u>	<u>80.60</u>
Feb.	150	83.70	82.45	115	83.00	81.75
Mar.	140	83.50	82.45	120	83.10	82.00
Apr.	145	83.60	82.40	135	83.40	82.20
May	230	<u>85.11</u>	83.80	145	83.60	82.35
Jun.	245	82.35	<u>84.00</u>	235	85.19	83.85
Jul.	235	85.19	83.95	210	84.79	83.50
Aug.	215	84.87	83.55	170	84.08	82.70
Sep.	170	84.08	82.70	105	82.78	81.65
Oct.	135	83.40	81.90	105	82.78	81.30
Nov.	125	83.20	81.80	95	82.55	81.55
Dec.	-	-	-	-	-	-

* アスワン水位の最大水位差: $3.27\text{M} = 85.11\text{M} - 81.84\text{M}$

* エルガーフラ水位の最大水位差: $3.40\text{M} = 84.00\text{M} - 80.60\text{M}$

注記: 1. アスワン水位はアスワンハイダムより6.5KM下流の水位。

2. エルガーフラ水位はアスワンハイダムより34KM下流の水位。

3. -印は資料無しを示す。

出所: Irrigation Department at Aswan, MPWWR

1987年から1991年11月までの5年間の最大水位差

6/6

* アスワン水位の最大水位差 : $3.55\text{MM} = 85.39\text{M} - 81.84\text{M}$

* エルガーフラ水位の最大水位差 : $3.40\text{M} = 84.00\text{M} - 80.60\text{M}$

6.3(1) 上エジプト地域における作物別単位用水量

(単位: m³/フェダン^②)

Crop	①												Total
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.	
Wheat	453	453	430	-	-	-	-	-	-	-	249	520	2,105
Beans	367	528	92	-	-	-	-	-	-	-	-	618	1,605
Barley	418	320	-	-	-	-	-	-	-	-	468	493	1,699
Fodder (summer)	-	-	-	825	1,111	1,393	696	-	-	-	-	-	4,025
Fodder (Nile)	-	-	-	-	-	-	1,409	1,813	1,711	-	-	-	4,933
Fodder (winter)	891	880	981	282	-	-	-	-	-	-	155	332	3,521
Onion	551	568	515	-	-	-	-	-	-	-	373	426	2,433
Garlic	388	413	364	-	-	-	-	-	655	874	995	995	3,689
Vegetable (W)	726	108	-	-	-	-	-	-	358	390	493	493	3,689
Vegetable (S)	556	1,090	1,186	1,345	1,122	203	-	-	-	-	-	-	5,502
Vegetable (N)	-	-	-	-	-	-	1,429	1,836	1,720	-	-	-	4,985
cone	-	-	-	686	904	1,154	565	-	-	-	-	-	3,309
Sugarcane	647	623	818	913	972	1,245	1,488	1,604	1,317	1,221	1,150	1,150	11,998
Maize	-	-	-	-	420	800	749	859	459	-	-	-	3,287
Fruits	220	225	308	376	497	484	469	440	425	308	303	303	4,055

① January: Water closure ③ -印は用水不足を示す。

② 17エダン=0.42ha.

6.3(2) 計画地の作付実績

(1) 夏作

(単位:フェダン)

ポンプ場	作物		トウモロコシ	野菜	ヘルシーム	その他	サトウキビ	果樹	計
	年								
No.1 El Sheikh Fadi	1989		45	5	16	109	21	16	212
	1990		45	5	16	109	21	16	212
	1991		45	5	16	110	20	16	212
No.9 Gezirat Fares	1991		317	100	-	5	200	-	622

(1) 冬作

(単位:フェダン)

ポンプ場	作物		小麦	豆類	野菜	その他	サトウキビ	果樹	計
	年								
No.1 El Sheikh Fadi	1989		55	6	12	110	21	16	212
	1990		60	22	7	86	21	16	212
	1991		80	4	8	84	20	16	212
No.9 Gezirat Fares	1991		160	2	300	409	27	120	1,018

GENERAL INFORMATION OF EXISTING PUMP STATION

PS No. : 1 PS Name : _____ 2/2

<p>15. The Discharge Tower (1) Nominal Bore (2) Material (3) Present Workability</p>	<p><u>1000</u> <u>500</u> mm dia Iron X</p>
<p>16. The Discharge Pipe Line (1) Nominal Bore (2) Material (3) Berried or not (4) Present Workability</p>	<p><u>700/500</u> mm dia Iron X</p>
<p>17. Water Level (1) Max (2) Min (3) Ave</p>	<p>_____ m _____ m _____ m</p>
<p>18. Water Velocity (1) Max (2) Min (3) Ave</p>	<p><u>very slow</u> _____ m/s _____ m/s _____ m/s</p>
<p>19. Wind (1) Spring a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (2) Summer a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (3) Fall a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (4) Winter a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity :</p>	<p>_____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s</p>

Kamel

Tilal

KM 38.250

STATION NAME: EL SHEIKH FADI
 NR. OF UNITS: 1

DISCHARGE: 500 lit/sec H 10m

R.R.M: 9.60

TRANSFORMER: روسي الصناعات

1000/400

250 KVA

13.15 / 3.61.2 A


1989	1990	1991	
HVL	83.83	83.73	83.82
LWL	81.18	80.73	80.43
	2.15	3.0	3.4

Electric Equipment:-

motor power: 66 kw 975 r.p.m

motor rated voltage: 380/220v 120/206 A

motor size:



- D1 = 50 cm
- D2 = 50 cm
- D3 = 100 cm
- D4 = 70 cm
- HVL = 83.80
- LWL = 80.78
- L = 45 m
- L1 =
- L2 = 88.60
- WL = 90.10

BADE KONCAR YUGOSLAVIA

معمل بحوث مياه

Dec. 04, 1991

CHECK LIST

Page 1/3

(Equipment & Facilities for each existing Pump Station)

ASWAN - DRAW - BENBAN - EL. Sheikh Fadl

Legend

- O : There is no trouble nor problem. Equipment can be used normally.
- Δ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
- X : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 1

PS Name: _____

I. PUMP	Appearance of casing	Finished coat	O
		Rust	Δ
	Appearance of installation	Bolts tightness	Δ
		Vibration	Δ
	Bearing	Noise	X (from cavitation phenomena)
	Vibration	X	
	Temperature	Δ	
	Oil leak	O	
Coupling	Bolt tightness	Δ	
	Eccentricity	Δ	
	Wear	Δ	
Others	Rust	Δ	
	Oil leak	Δ	
	Water leak	Δ	
	Wear	Δ	

Kamel

[Signature]

PS No.: 1

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	Δ
		Rust	Δ
	Bearing	Noise	\times
		Vibration	\times
Temperature		\times	
Oil leak		Δ	
Rotor & Fan	Noise	Δ	
	Vibration	Δ	
	Wind pressure	o	
Others	Rust	o	
	Oil leak	o	
	Wear	Δ	
III. VALVE	Appearance	Water leak	o
		Rust	o
Wear		o	
Operation	Smooth	o	
IV. PIPE & HOSE	Appearance	Water leak	\times
		Rust	\times
		Wear	\times
		Fitness	\times
V. (1) SWITCH BOARD	appearance of outside	Rust	o
		Wear	o
		Noise	o
		Vibration	o
		Tightness	o
	Appearance of interior	Lighting	Δ
		Rust	o
Meter	Zero setting	o	
	Workability	o	

Kamel*[Signature]*

PS No.: 1

PS Name: _____

Page 3/3

V. (2) SWITCH BOARD	Breaker	Point pressure	△
		Rust	○
		Wear	○
		Covering	○
VI. POWER CABLE	Appearance	Damage	△
		Wear	△
		Covering	△
		Connection	△
		Insulation	○
VII. BARGE	Appearance of outside	Damage	△
		Rust	△
		Wear	△
		Vibration	△
	Appearance of interior	Damage	△
		Rust	△
Wear		△	
Winch & Anchor	Tightness	△	
	Rust	△	
	Wear	△	
	Operation smooth	△	
	Lockability	△	
VIII. DIS- CHARGE POND	Appearance	Damage	△
		Wear	△

Kamel*[Signature]*

STATION NAME: SAHEL EL HAMMAM

NO. OF UNITS: 1

DISCHARGE: 500 lt/sec

R.P.M: 750

TRANSFORMER: 15000 VA

11550/433 V

300 K.V.A

15.75/433 A


طلمبات رائد / ١٦/٧

منارة مركز

منارة مركز

منارة مركز

منارة مركز



- D₁ = 50 cm
- D₂ = 50 cm
- D₃ = 100 cm
- D₄ = 70
- H.W.L = 82.13
- L.W.L = 79.11
- L = 70 mt
- L₁ =
- L₂ =
- W.L = 86.80

H.W.L	1989	1990	1991	
L.W.L	82.16	82.06	82.16	
M.W.L	79.51	79.06	78.78	
Difference	3.65	3.0	3.4	

Electric Equipment:-
 motor power : 100 kw
 motor rated voltage : 380 V
 motor type : A0 102 = 8T C.C.C.T.P

Dec. 05. 1991

CHECK LIST
(Equipment & Facilities for each existing Pump Station)

Legend

- : There is no trouble nor problem. Equipment can be used normally.
- △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
- x : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 2

PS Name: _____

I. PUMP	Appearance of casing	Finished coat	X	_____
		Rust	△	_____
	Appearance of installation	Bolts tightness	△	_____
		Vibration	△	_____
	Bearing	Noise	△	_____
	Vibration	△	_____	
	Temperature	△	_____	
	Oil leak	△	<i>drip down on floor</i>	
Coupling	Bolt tightness	△	_____	
	Eccentricity	○	_____	
	Wear	△	_____	
Others	Rust	△	_____	
	Oil leak	△	_____	
	Water leak	△	_____	
	Wear	△	<i>padding</i>	

Kamel *M. Sade*

PS No.: 2

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	△
		Rust	△
	Bearing	Noise	△
		Vibration	△
Temperature		△	
Oil leak		⊘	
Rotor & Fan	Noise	△	
	Vibration	△	
	Wind pressure	△	
Others	Rust	△	
	Oil leak	⊘	
	Wear	△ <i>Inside is very dirty</i>	
III. VALVE	Appearance	Water leak	△ <i>leakage from shaft and flange</i>
		Rust	△
Wear		△ <i>shaft</i>	
Operation	Smooth	△	
IV. PIPE & HOSE	Appearance	Water leak	△
		Rust	△
		Wear	△
		Fitness	△ <i>leaky from rubber and coupling</i>
V. (1) SWITCH BORAD	appearance of outside	Rust	⊘
		Wear	⊘
		Noise	⊘
		Vibration	⊘
		Tightness	⊘ <i>There is no cover</i>
	Appearance of interior	Lighting	<i>No lights</i>
Rust		△ <i>lamps are good</i>	
Meter	Zero setting	⊘	
	Workability	⊘	

Kamel

[Signature]

PS No.: 2

PS Name: _____

Page 3/3

V. (2) SWITCH BOARD	Breaker	Point pressure	0
		Rust	0
		Wear	0
		Covering	X No cover
VI. POWER CABLE	Appearance	Damage	Δ Connection point damaged to structure
		Wear	Δ
		Covering	Δ Not enough cover
		Connection	Δ
		Insulation	Δ Some parts are fair
VII. BARGE	Appearance of outside	Damage	Δ Roof is damaged
		Rust	Δ
		Wear	0
		Vibration	Δ Barge is lean
	Appearance of interior	Damage	Δ floor
		Rust	Δ Pump & Motor Base
		Wear	Δ
	Winch & Anchor	Tightness	Δ front wind only
		Rust	Δ
		Wear	Δ
		Operation smooth	Δ
		Lockability	X 4 edges locked Barge is lean
VIII. DIS- CHARGE POND	Appearance	Damage	No pond
		Wear	Direct to canal

Crane rail on ceiling is short. (Not extended to outside.)

Kamel

Almado

Dec. 03, 1991

GENERAL INFORMATION OF EXISTING PUMP STATION

EDFO - EL-FOWZA

PS No. : 3 PS Name : [One pump] 1/2

1. Commencing Year of the Pump Operation	<u>1952</u> <u>1958</u>
2. Manufacturers Name of the Pump	<u>SULZER (switzerland)</u>
3. Does it exist still now?	<u>YES</u>
4. Presumable Percentage of the Pump Discharge Capacity Comparing with the Initial Design Capacity	<u>50</u> %
5. The pump performance Curve obtained or not?	<u>No</u>
6. Actual Head between the River Water Level and the Discharge Water Level	<u>7.43</u> <u>(8)</u> m
7. Expectable Length of the Pump Discharge Pipe Line up to the Reservoir	<u>28.8</u> m
8. Acrage of the Irrigated Field at Present	<u>33 f25T</u> <u>(300 Feddan)</u>
9. Acrage of the Irrigable Field at Initial Design Stage	<u>N.A</u>
10. Acrage of the Irrigable Field to be Extended on This Project	<u>No</u>
11. The Electric Motor (1) Out put (2) Voltage (3) No. of Poles (4) Frequency (5) Year of Manufacturing (6) Present Workability	<u>135</u> HP <u>380</u> V <u>4</u> poles <u>50</u> Hz <u>1988</u> installed <u>0</u>
12. The Pump (1) Discharge Capacity (2) Total Head (3) Revolutional Speed (4) Present Workability	<u>1958</u> Manufactured <u>500 L/s</u> <u>10 m</u> <u>(724HP) 960</u> rpm <u>X</u>
13. The Transformer (1) Capacity (2) Primary Voltage (3) Secondary Voltage (4) Year of Manufacturing (5) Present Workability	<u>200</u> KVA <u>11000</u> V <u>380</u> V <u>1985</u> <u>0 (OK)</u>
14. The Reservoir (1) Dimensions Length <u> </u> m x width <u> </u> m x width (2) Effective Volume (3) Material (4) Present Workability	<u>No reservoir</u> <u>Direct to canal</u> <u>concrete made</u> <u> </u> m x width <u> </u> <u> </u>

Kamel

1/2/91

STATION NAME: EL FAWAZA EL BAHARIA KM 113.00

NO. OF UNITS: 1 SULZER

DISCHARGE: 500 lit/sec H: 10 mt

R.P.M.: 960

TRANSFORMER: منطقة المحرك

11550/4000 V

200 K.V.A

1135/303 A


1989	1990	1991
80.84	80.74	80.84
78.19	77.74	77.44
205 3.0 314		

Electric Equipment:-

motor power: 100 kw 985 r.p.m

motor rated voltage: 380 V 185 A

motor type: RELIANCE U.S.A



- D₁ = 50 cm
- D₂ =
- D₃ =
- D₄ = 50
- H.W.L = 80.81
- L.W.L = 77.79
- L = 222 mt
- L₁ =
- L₂ = 83.45
- WL = 84.50

Dec. 03, 1991

CHECK LIST
(Equipment & Facilities for each existing Pump Station)

Page 1/3

Legend

- : There is no trouble nor problem. Equipment can be used normally.
- △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
- × : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 3

PS Name: _____

I. PUMP	Appearance of casing	Finished coat : <u>△ It needs Coating</u> Rust : <u>△ not clean</u>
	Appearance of installation	Bolts tightness : <u>△ It needs instrument check</u> Vibration : <u>△ comes from the shaft</u>
	Bearing	Noise : <u>△ It needs instrument check</u> Vibration : <u>△ ~ ~ ~ ~</u> Temperature : <u>△</u> Oil leak : <u>△</u>
	Coupling	Bolt tightness : <u>△</u> Eccentricity : <u>△</u> Wear : <u>△</u>
	Others	Rust : <u>○</u> Oil leak : <u>○</u> Water leak : <u>△</u> Wear : _____

Kamal

[Signature]

PS No.: 3

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	Δ	It needs Coating
		Rust	Δ	It needs cleaning
	Bearing	Noise	Δ	high
		Vibration	X	very high
Temperature		Δ	It rises during the day	
Oil leak		○		
Rotor & Fan	Noise	X		
	Vibration	X		
	Wind pressure	Δ		
Others	Rust	Δ		
	Oil leak	○		
	Wear	○		
III. VALVE	Appearance	Water leak	○	No water Leaks
		Rust	Δ	Not clean
Wear		Δ	It needs gaskets between Flanges	
	Operation	Smooth	Δ	It works in good conditions but need control for on/off
IV. PIPE & HOSE	Appearance	Water leak	X	} In very bad condition
		Rust	X	
		Wear	X	
		Fitness	X	
V. (1) SWITCH BORAD	appearance of outside	Rust	Δ	
		Wear	○	N.A
		Noise	○	No
		Vibration	○	No
		Tightness	Δ	It needs some bolts
	Appearance of interior	Lighting	Δ	
Rust		Δ		
Meter	Zero setting	X	It is not working	
	Workability	X	It doesn't work	

Kamel

A. Hala

PS No.: 3

PS Name: _____

Page 3/3

V. (2) SWITCH BOARD	Breaker	Point pressure Rust Wear Covering	o o o o
VI. POWER CABLE	Appearance	Damage Wear Covering Connection Insulation	 o o o o o
VII. BARGE	Appearance of outside	Damage Rust Wear Vibration	 Δ ^{at floor} need some repairs. Δ - cleaning Δ Some wear in parts in winch Δ Some vibration happens during operation
	Appearance of interior	Damage Rust Wear	Δ It needs some repairs Δ Not clean (the wall & roof) o
	Winch & Anchor	Tightness Rust Wear Operation smooth Lockability	 } The winch in one side only } Not working } In very bad condition
VIII. DIS- CHARGE POND	Appearance	Damage Wear	 No Reserve X } In very bad condition ↑ Coul. (Covered with concrete)

Reservoir

Kamal

Mohd

GENERAL INFORMATION OF EXISTING PUMP STATION

Dec. 04, 1991

ASWAN - SAHEL EL-KOBBANIA

PS No. : 4

PS Name : _____

[One pump] 1/2

1. Commencing Year of the Pump Operation	1933
2. Manufacturers Name of the Pump	WONDER (Made in EGYPT)
3. Does it exist still now?	YES
4. Presumable Percentage of the Pump Discharge Capacity Comparing with the Initial Design Capacity	<u>50</u> %
5. The pump performance Curve obtained or not?	No
6. Actual Head between the River Water Level and the Discharge Water Level	<u>7.96</u> (9) m
7. Expectable Length of the Pump Discharge Pipe Line up to the Reservoir	<u>59.29</u> m
8. Acreage of the Irrigated Field at Present	By rest, (800 Feddan)
9. Acreage of the Irrigable Field at Initial Design Stage	N.A
10. Acreage of the Irrigable Field to be Extended on This Project	YES
11. The Electric Motor (1) Out put (2) Voltage (3) No. of Poles (4) Frequency (5) Year of Manufacturing (6) Present Workability	(USSR) <u>100</u> kW <u>380</u> V <u>4</u> poles <u>50</u> Hz <u>1969</u> Δ
12. The Pump (1) Discharge Capacity (2) Total Head (3) Revolutional Speed (4) Present Workability	<u>500</u> L/s <u>10</u> <u>750</u> rpm Δ
13. The Transformer (1) Capacity (2) Primary Voltage (3) Secondary Voltage (4) Year of Manufacturing (5) Present Workability	<u>300</u> KVA <u>11000</u> V <u>380</u> V 0
14. The Reservoir (1) Dimensions Length <u> </u> m x width <u> </u> m x width (2) Effective Volume (3) Material (4) Present Workability	<u> </u> m x width <u> </u> m <u> </u> m ³

Kamel[Signature]

STATION NAME: SABEL EL KOBBANIA KWA 25.500

NO. OF UNITS 13/14

DISCHARGE 500 lit/sec H 10 mt

R.P.M. 750

TRANSFORMER منارة شركة ايجيه

1000/380 300 KVA

15/442 A mp.

	1989	1990	1991
H.W.L	84.34	84.24	84.34
L.W.L	81.69	81.69	80.94

	∇ UWL	∇ HVL
Difference	2.67	3.4


Electric Equipment:-

motor power : 100 kw

motor rated voltage : 380 v

motor fig. : AD 102 = 8T

C.C.C.P



- D₁ = 50 cm
- D₂ = 50 cm
- D₃ = 100 cm
- D₄ = 60 cm
- HVL = 84.31
- LWL = 81.44
- L = 2.8 mt
- L₁ =
- L₂ = 89.50
- WL = 90.45

Dec. 04, 1991

CHECK LIST

Page 1/3

(Equipment & Facilities for each existing Pump Station)

ASWAN - EL KOBBANIA

Legend

- : There is no trouble nor problem. Equipment can be used normally.
 △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
 × : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 4

PS Name: _____

I. PUMP	Appearance of casing	Finished coat	△
		Rust	△
	Appearance of installation	Bolts tightness	△
		Vibration	△
	Bearing	Noise	△
	Vibration	△	
	Temperature	○	
	Oil leak	○ ×	
Coupling	Bolt tightness	△	
	Eccentricity	△	
	Wear	△	
Others	Rust	△	
	Oil leak	○	
	Water leak	○	
	Wear	△	

Kamel

N. K. K.

PS No.: 4

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	△
		Rust	△
	Bearing	Noise	△
		Vibration	△
Temperature		○	
Oil leak		○	
Rotor & Fan	Noise	△	
	Vibration	△	
	Wind pressure	○	
Others	Rust	△	
	Oil leak	○	
	Wear	○	
III. VALVE	Appearance	Water leak	△
		Rust	△
Wear		△	
Operation	Smooth	△	
IV. PIPE & HOSE	Appearance	Water leak	△
		Rust	△
		Wear	X
		Fitness	△
V. (I) SWITCH BORAD	appearance of outside	Rust	△
		Wear	△
		Noise	○
		Vibration	▽
		Tightness	△
	Appearance of interior	Lighting	△
		Rust	△
	Meter	Zero setting	X
		Workability	X

KamelJ. S. S.

PS No.: 4

PS Name: _____

Page 3/3

V. (2) SWITCH BOARD	Breaker	Point pressure <u>△</u> Rust <u>△</u> Wear <u>△</u> Covering <u>○</u>
VI. POWER CABLE	Appearance	Damage <u>△</u> Wear <u>X</u> Covering <u>X</u> Connection <u>○</u> Insulation <u>△</u>
VII. BARGE	Appearance of outside	Damage <u>△</u> Rust <u>△</u> Wear <u>△</u> Vibration <u>○</u>
	Appearance of interior	Damage <u>△</u> Rust <u>△</u> Wear <u>X</u>
	Winch & Anchor	Tightness <u>△</u> Rust <u>△</u> Wear <u>△</u> Operation smooth <u>△</u> Lockability <u>△</u> <i>No winch & Anchor</i>
VIII. DIS- CHARGE POND	Appearance	Damage <u>△</u> Wear <u>△</u>

Kamel

[Signature]

KM 71.00

STATION NAME: SAHEL EARIS

NO OF UNITS: 2 ANDRITZ

DISCHARGE: 750 lit/sec H = 10 mt

R.P.M: 600

TRANSFORMER: 500 K.V.A

11550 / 393 V

26.3 / 735 A.Amp

1989	1990	1991	
82.52	82.42	82.52	H.W.L
79.87	79.42	79.12	L.W.L
2.65	3.0	3.4	


Electric Equipment:-

motor power: 110 kw

meter rated voltage: 380 V

motor type:

LSP 355 MG LEROY SOMER - FRANCE



- D1 = 50 cm
- D2 = 50 cm
- D3 = 100 cm
- D4 = 70 cm
- H.W.L = 82.49
- L.W.L = 79.47
- L = 42 mt.
- L1 =
- L2 =
- WL = 87.00

Dec. 05. 1991

CHECK LIST

(Equipment & Facilities for each existing Pump Station)

Legend

- O : There is no trouble nor problem. Equipment can be used normally.
- △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
- X : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 5 PS Name: _____

I. PUMP	Appearance of casing	Finished coat	△
		Rust	△
	Appearance of installation	Bolts tightness	△
		Vibration	△
	Bearing	Noise	△
		Vibration	△
		Temperature	△
		Oil leak	X <i>leak from bearing</i>
	Coupling	Bolt tightness	△
		Eccentricity	△
		Wear	△
	Others	Rust	△
		Oil leak	△
		Water leak	△
		Wear	△

Kamal *[Signature]*

PS No.: 5

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	Δ
		Rust	Δ
	Bearing	Noise	Δ
		Vibration	Δ
Temperature		Δ	
Oil leak		X	
Rotor & Fan	Noise	Δ	
	Vibration	Δ	
	Wind pressure	0	
Others	Rust	Δ	
	Oil leak	0	
	Wear	Δ Fan cover	
III. VALVE	Appearance	Water leak	0
		Rust	Δ
Wear		Δ peeling	
Operation	Smooth	Δ	
IV. PIPE & HOSE	Appearance	Water leak	0
		Rust	Δ
		Wear	X rubber hose
		Fitness	Δ water leakage from Towers mouth
V. (1) SWITCH BORAD	appearance of outside	Rust	Δ
		Wear	Δ Bed-Dose mesh broken
		Noise	0
		Vibration	0
		Tightness	Δ Front door not fixed
	Appearance of interior	Lighting	No lighting
Rust		Some wall broken Δ	
Meter	Zero setting	Δ One meter not working	
	Workability	Δ	

KamelM. Sado

PS No.: 5

PS Name: _____

Page 3/3

V. (2) SWITCH BOARD	Breaker	Point pressure	○
		Rust	△
		Wear	○
		Covering	X No cover,
VI. POWER CABLE	Appearance	Damage	○
		Wear	○
		Covering	No cover
		Connection	○
		Insulation	△ No cover of joints
VII. BARGE	Appearance of outside	Damage	△
		Rust	△
		Wear	△
		Vibration	△ little leaning
	Appearance of interior	Damage	△ ^{part of} some wall is broken
		Rust	△ floor
		Wear	△ floor
	Winch & Anchor	Tightness	front portion only not working
		Rust	△
		Wear	△
		Operation smooth	— N.D.
		Lockability	N.A. 4 edges — anchoring
VIII. DIS- CHARGE POND	Appearance	Damage	△ Mad of blocks
		Wear	△ Surface broken.

KamalM. K. S.

GENERAL INFORMATION OF EXISTING PUMP STATION

PS No. : 6

PS Name : _____

2/2


<p>15. The Discharge Tower</p> <p>(1) Nominal Bore</p> <p>(2) Material</p> <p>(3) Present Workability</p>	<p><u>700</u> mm dia</p> <p>Iron</p> <p>Δ</p>	<p>700</p> <p>Iron</p> <p>Δ</p>
<p>16. The Discharge Pipe Line</p> <p>(1) Nominal Bore</p> <p>(2) Material</p> <p>(3) Berried or not</p> <p>(4) Present Workability</p>	<p><u>1000</u> 4000 mm dia</p> <p>Iron</p> <p>Berried</p> <p>X</p>	<p>1000</p> <p>Iron</p> <p>Berried</p> <p>X</p>
<p>17. Water Level</p> <p>(1) Max</p> <p>(2) Min</p> <p>(3) Ave</p>	<p>_____ m</p> <p>_____ m</p> <p>_____ m</p>	
<p>18. Water Velocity</p> <p>(1) Max</p> <p>(2) Min</p> <p>(3) Ave</p>	<p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p>	
<p>19. Wind</p> <p>(1) Spring</p> <p> a) Direction :</p> <p> b) Ave velocity :</p> <p> c) Max velocity :</p> <p> d) Min velocity :</p> <p>(2) Summer</p> <p> a) Direction :</p> <p> b) Ave velocity :</p> <p> c) Max velocity :</p> <p> d) Min velocity :</p> <p>(3) Fall</p> <p> a) Direction :</p> <p> b) Ave velocity :</p> <p> c) Max velocity :</p> <p> d) Min velocity :</p> <p>(4) Winter</p> <p> a) Direction :</p> <p> b) Ave velocity :</p> <p> c) Max velocity :</p> <p> d) Min velocity :</p>	<p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p> <p>_____ m/s</p>	

M. S. S.

Kamal

PS No. 6 PS Name _____

GENERAL LAYOUT PLAN FOR EXISTING FLOATING PUMP STATION



D1 : 700 mm
 D2 : 700 mm
 D3 : 1000 mm
 D4 : 700 mm
 LE : 1000 M
 L1 : 71.20 M
 L2 : 90 M
 HWL: _____ M
 LWL: _____ M
 WL : _____ M

D1 : Diameter of existing floating pump station output pipe
 D2 : Diameter of existing land based tower's mouth of water income from floating pump station
 D3 : Diameter of existing land based tower's horizontal section
 D4 : Diameter of existing pipe line from tower to discharge pond
 LE : Length of existing pipe line from tower to discharge pond
 L1 : Land level of the base of tower
 L2 : Land level of discharge pond
 HWL: Water level of the highest
 LWL: Water level of the lowest
 WL : Discharge water level of discharge pond

[Handwritten signature]

Dec. 11, 1991

CHECK LIST Page 1/3
 (Equipment & Facilities for each existing Pump Station)

Legend

- : There is no trouble nor problem. Equipment can be used normally.
- △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
- × : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 6

PS Name: _____

I. PUMP	Appearance of casing	Finished coat	○	X
		Rust	○	X
	Appearance of installation	Bolts tightness	○	○
		Vibration	△	△
	Bearing	Noise	X	△
		Vibration	△	△
		Temperature	X	△
		Oil leak	○	○
	Coupling	Bolt tightness	○	○
		Eccentricity	○	○
		Wear	△	△
	Others	Rust	○	△
		Oil leak	△	○
		Water leak	○	△
		Wear	△	△

[Signature]

Kamel

PS No.: 6

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	o	_____	o
		Rust	o	_____	o
	Bearing	Noise	X	_____	△
		Vibration	o	_____	o
Temperature		o	_____	o	
Oil leak		o	_____	o	
Rotor & Fan	Noise	X	_____	o	
	Vibration	△	_____	o	
	Wind pressure	o	_____	o	
Others	Rust	o	_____	o	
	Oil leak	o	_____	△	
	Wear	o	_____	△	
III. VALVE	Appearance	Water leak	o	_____	△
		Rust	△	_____	△
Wear		△	_____	△	
	Operation	Smooth	△	_____	△
IV. PIPE & HOSE	Appearance	Water leak	X	_____	X
		Rust	△	_____	△
		Wear	△	_____	X
		Fitness	△	_____	△
V. (1) SWITCH BORAD	appearance of outside	Rust	△	_____	△
		Wear	o	_____	△
		Noise	o	_____	o
		Vibration	o	_____	o
		Tightness	o	_____	△
	Appearance of interior	Lighting	o	_____	△
		Rust	o	_____	△
	Meter	Zero setting	o	_____	o
		Workability	o	_____	o

Kamel *M. H. H.*

PS No.: 6

PS Name: _____

Page 3/3

V. (2) SWITCH BOARD	Breaker	Point pressure	o _____	o
		Rust	o _____	o
		Wear	o _____	o
		Covering	o _____	o
VI. POWER CABLE	Appearance	Damage	Δ _____	o
		Wear	Δ _____	o
		Covering	o _____	o
		Connection	o _____	o
		Insulation	o _____	o
VII. BARGE	Appearance of outside	Damage	Δ _____	X
		Rust	Δ _____	Δ
		Wear	Δ _____	Δ
		Vibration	Δ _____	Δ
	Appearance of interior	Damage	o _____	X
		Rust	o _____	Δ
		Wear	Δ _____	Δ
	Winch & Anchor	Tightness	Δ _____	X
		Rust	Δ _____	X
		Wear	Δ _____	X
		Operation smooth	Δ _____	X
		Lockability	Δ _____	X
VIII. DIS- CHARGE POND	Appearance	Damage	Δ _____	Δ
		Wear	Δ _____	Δ

M. H. H.

Kamel

Water Quality { Temperature 20°C
 7.19 pH
 2.6 x 100 µs/cm

37/60

Dec. 04, 1991

GENERAL INFORMATION OF EXISTING PUMP STATION

~~FROM~~ HONOMO - GEZIERT EL. HARBIAB

PS No. : 7 PS Name : _____ [Two pumps] 1/2

1. Commencing Year of the Pump Operation	1932
2. Manufacturers Name of the Pump	K.S.B (W.E)
3. Does it exist still now?	YES
4. Presumable Percentage of the Pump Discharge Capacity Comparing with the Initial Design Capacity	60 %
5. The pump performance Curve obtained or not?	NO
6. Actual Head between the River Water Level and the Discharge Water Level	8.53 (13) m
7. Expectable Length of the Pump Discharge Pipe Line up to the Reservoir	30.10 m
8. Acreage of the Irrigated Field at Present	BY REST (800 Feddan)
9. Acreage of the Irrigable Field at Initial Design Stage	N.A
10. Acreage of the Irrigable Field to be Extended on This Project	NO
11. The Electric Motor (1) Out put (2) Voltage (3) No. of Poles (4) Frequency (5) Year of Manufacturing (6) Present Workability	(USSR) 12/75A. 40 kw 220 ⁺ /380 V 4 poles 50 Hz 1965 / 1969 X
12. The Pump (1) Discharge Capacity (2) Total Head (3) Revoluntional Speed (4) Present Workability	Manufactured 1951 250 L/s 13 m 800 rpm X
13. The Transformer (1) Capacity (2) Primary Voltage (3) Secondary Voltage (4) Year of Manufacturing (5) Present Workability	100 KVA 11000 V 380 V 0
14. The Reservoir (1) Dimensions Length _____ m x width _____ m x width (2) Effective Volume _____ m ³ (3) Material _____ m ³ (4) Present Workability	

Kamal

El-ender

GENERAL INFORMATION OF EXISTING PUMP STATIONPS No. : 7

PS Name : _____

2/2

15. The Discharge Tower (1) Nominal Bore (2) Material (3) Present Workability	1000 500 mm dia Iron X
16. The Discharge Pipe Line (1) Nominal Bore (2) Material (3) Berried or not (4) Present Workability	500 mm dia Iron Δ
17. Water Level (1) Max (2) Min (3) Ave	_____ m _____ m _____ m
18. Water Velocity (1) Max (2) Min (3) Ave	_____ m/s _____ m/s _____ m/s
19. Wind (1) Spring a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (2) Summer a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (3) Fall a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (4) Winter a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity :	_____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s


Kamel

[Signature]

PS No. 7

PS Name _____

GENERAL LAYOUT PLAN FOR EXISTING FLOATING PUMP STATION



$D_0 = 1260/3.14 = 401.3$

D1 : _____ mm

D1 : Diameter of existing floating pump station output pipe

D2 : $1870/3.14 = 595.8$ mm

D2 : Diameter of existing land based tower's mouth of water income from floating pump station

D3 : 1000 mm

D3 : Diameter of existing land based tower's horizontal section

D4 : 500 mm

D4 : Diameter of existing pipe line from tower to discharge pond

LE : _____ M

LE : Length of existing pipe line from tower to discharge pond

L1 : _____ M

L1 : Land level of the base of tower

L2 : _____ M

L2 : Land level of discharge pond

HWL : _____ M

HWL : Water level of the highest

LWL : _____ M

LWL : Water level of the lowest

WL : _____ M

WL : Discharge water level of discharge pond

Dec 04, 1991

CHECK LIST

(Equipment & Facilities for each existing Pump Station)

Legend

- : There is no trouble nor problem. Equipment can be used normally.
- △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
- × : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 7

PS Name: _____

I. PUMP	Appearance of casing	Finished coat	△
		Rust	△
	Appearance of installation	Bolts tightness	△
		Vibration	△
	Bearing	Noise	△
	Vibration	△	
	Temperature	○	
	Oil leak	○	
Coupling	Bolt tightness	△	
	Eccentricity	△	
	Wear	△	
Others	Rust	△	
	Oil leak	○	
	Water leak	△	
	Wear	△	

Kamel

[Signature]

PS No.: 7

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	Δ
		Rust	Δ
	Bearing	Noise	X
		Vibration	Δ
Temperature		X	
Oil leak		o	
Rotor & Fan	Noise	Δ	
	Vibration	Δ	
	Wind pressure	o	
Others	Rust	Δ	
	Oil leak	o	
	Wear	Δ	
III. VALVE	Appearance	Water leak	o
		Rust	o
Wear		Δ	
Operation	Smooth	o	
IV. PIPE & HOSE	Appearance	Water leak	o
		Rust	Δ
		Wear	X
		Fitness	Δ
V. (1) SWITCH BORAD	appearance of outside	Rust	Δ
		Wear	Δ
		Noise	o
		Vibration	o
		Tightness	Δ
	Appearance of interior	Lighting	X
		Rust	Δ
	Meter	Zero setting	X
		Workability	X

KandDelgado

PS No.: 7

PS Name: _____

Page 3/3

V. (2) SWTICH BOARD	Breaker	Point pressure <u>△</u> Rust <u>△</u> Wear <u>△</u> Covering <u>X</u>
VI. POWER CABLE	Appearance	Damage <u>△</u> Wear <u>△</u> Covering <u>△</u> Connection <u>△</u> Insulation <u>o</u>
VII. BARGE	Appearance of outside	Damage <u>△</u> Rust <u>X</u> Wear <u>X</u> Vibration <u>△</u>
	Appearance of interior	Damage <u>△</u> Rust <u>△</u> Wear <u>△</u>
	Winch & Anchor	Tightness <u>△</u> Rust <u>△</u> Wear <u>△</u> Operation smooth <u>△</u> Lockability <u>△</u>
VIII. DIS- CHARGE POND	Appearance	Damage _____ Wear _____

Kand

Wash

Dec. 01. 1991

GENERAL INFORMATION OF EXISTING PUMP STATION

GHARB ASWAN BAHARY

PS No. : 8 PS Name : GHARB ASWAN BAHARY [Two pumps] 1/2

1. Commencing Year of the Pump Operation	1933
2. Manufacturers Name of the Pump	Wander
3. Does it exist still now?	YES
4. Presumable Percentage of the Pump Discharge Capacity Comparing with the Initial Design Capacity	65 %
5. The pump performance Curve obtained or not?	No
6. Actual Head between the River Water Level and the Discharge Water Level	8.14 (10) m
7. Expectable Length of the Pump Discharge Pipe Line up to the Reservoir	61.16 (12) m
8. Acreage of the Irrigated Field at Present	by rest 600 Feddan Field
9. Acreage of the Irrigable Field at Initial Design Stage	No
10. Acreage of the Irrigable Field to be Extended on This Project	No
11. The Electric Motor (1) Out put (2) Voltage (3) No. of Poles (4) Frequency (5) Year of Manufacturing (6) Present Workability	(France) 110 kw 380 V 6 poles 50 Hz 1983 Δ
12. The Pump (1) Discharge Capacity (2) Total Head (3) Revolutional Speed (4) Present Workability	500 L/s 10 m 600 rpm (82.84P) Δ
13. The Transformer (1) Capacity (2) Primary Voltage (3) Secondary Voltage (4) Year of Manufacturing (5) Present Workability	500 KVA 11000 V 380 V 1984 0
14. The Reservoir (1) Dimensions Length (2) Effective Volume (3) Material (4) Present Workability	No (Direct to the canal) 5.19 mxwidth mxwidth Concrete 0

Kamal

M. M. M.

GENERAL INFORMATION OF EXISTING PUMP STATION

PS No. : 8

PS Name : _____

2/2

<p>15. The Discharge Tower (1) Nominal Bore (2) Material (3) Present Workability</p>	<p>$\phi 1000$ L 3240 mm dia Cast Iron X Leakage water</p>
<p>16. The Discharge Pipe Line (1) Nominal Bore (2) Material (3) Berried or not (4) Present Workability</p>	<p>$\phi 700$ L 2250 mm dia $\phi = 700$ Cast Iron NOT X Leakage water</p>
<p>17. Water Level (1) Max (2) Min (3) Ave</p>	<p>_____ m _____ m _____ m</p>
<p>18. Water Velocity (1) Max (2) Min (3) Ave</p>	<p>Very slow _____ m/s _____ m/s _____ m/s</p>
<p>19. Wind (1) Spring a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (2) Summer a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (3) Fall a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (4) Winter a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity :</p>	<p>_____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s</p>

Kamel

[Signature]

STATION NAME: GHARB ASWAN ELBAHARIA KWA 12.700

NO OF UNITS: 2


DISCHARGE: 0.5 m³/sec H = 10. mt

R.P.M: 800

TRANSFORMER: 500 K.V.A

7.5 / 735 Amp. Floating P.S.

1989	1990	1991
85.14	85.02	85.10
81.82	81.82	81.59
L.W.L		
H.W.L		
Difference		
3.32	3.20	3.51



- D1 = 50 cm
- D2 = 50 cm
- D3 = 100 cm
- D4 = 70 cm
- H.W.L = 85.09
- L.W.L = 81.74
- L = 20 mt.
- L1 =
- L2 = 90.50
- WL = 91.40

Electric Equipment:-

- motor power : 110 kw . 590 r.p.m
- motor rated voltage : 380 v 234 A
- motor type : LSP 355 MG LEROY SOMER FRANCE.

Dec. 01, 1991

CHECK LIST Page 1/3
 (Equipment & Facilities for each existing Pump Station)

Legend

- : There is no trouble nor problem. Equipment can be used normally.
- △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
- × : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 3

PS Name: _____

I. PUMP	Appearance of casing	Finished coat △	_____ / _____
		Rust △	_____
	Appearance of installation	Bolts tightness ○	_____
		Vibration	_____
	Bearing	Noise ○	_____
		Vibration ○	_____
		Temperature ○	_____
		Oil leak ○	_____
Coupling	Bolt tightness ○	_____	
	Eccentricity △	_____	
	Wear △	_____	
Others	Rust △	_____	
	Oil leak ○	_____	
	Water leak ○	_____	
	Wear ○	_____	

Kamel

[Signature]

PS No.: 8

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	Δ
		Rust	Δ
	Bearing	Noise	\circ
		Vibration	\circ
Temperature		\circ	
Oil leak		\circ	
Rotor & Fan	Noise	Δ	
	Vibration	\circ	
	Wind pressure	Δ	
Others	Rust	Δ	
	Oil leak	\circ	
	Wear	Δ	
III. VALVE	Appearance	Water leak	Δ <i>water leak</i>
		Rust	Δ
Wear		Δ	
	Operation	Smooth	Δ
IV. PIPE & HOSE	Appearance	Water leak	\times
		Rust	\times
		Wear	Δ
		Fitness	
V. (1) SWITCH BORAD	appearance of outside	Rust	Δ
		Wear	Δ
		Noise	\circ
		Vibration	\circ
		Tightness	Δ
	Appearance of interior	Lighting	Δ
		Rust	Δ
	Meter	Zero setting	Δ
		Workability	Δ

KamalT. N. S.

PS No.: 8

PS Name: _____

Page 3/3

V. (2) SWITCH BOARD	Breaker	Point pressure	Δ
		Rust	Δ
		Wear	\circ
		Covering	Δ
VI. POWER CABLE	Appearance	Damage	\circ
		Wear	\circ
		Covering	\circ
		Connection	\circ
		Insulation	\circ
VII. BARGE	Appearance of outside	Damage	X
		Rust	X
		Wear	X
		Vibration	Δ
	Appearance of interior	Damage	X
		Rust	X
Wear		X	
Winch & Anchor	Tightness	Δ	
	Rust	Δ	
	Wear	Δ	
	Operation smooth	Δ	
	Lockability	Δ	
VIII. DIS- CHARGE POND	Appearance	Damage	\circ
		Wear	\circ

KamelM. M. M.

KM 67-800

STATION NAME: GAZIRAT FARIS

NO. OF UNITS: 2 منهات بوموت

DISCHARGE: 350 / 500 lit/sec H 13/10 mt

R.P.M.

TRANSFORMER: منهات شجرة الجمل

11000 / 380 300 K.V.A

227 / 393 Amp

1989	1990	1991
82.65	82.55	82.65
80.0	79.55	79.25
H.W.L		
L.W.L		

Difference
2.65
3.10


Electric Equipment:-

motor power : 110 kw

motor rated voltage : 380 v 234 Amp

motor type

L.S.P. 355-MG LEROY SOMER - FRANCE



- D₁ = 50 cm
- D₂ = 50 cm
- D₃ = 100 cm
- D₄ = 50 cm
- H.W.L = 82.62
- L.W.L = 79.60
- L = 33 mt
- L₁ =
- L₂ =
- WL = 86.80

Dec. 03, 1991

CHECK LIST

Page 1/3

(Equipment & Facilities for each existing Pump Station)

KOMOMBO - EKLEET - GEERT FARS

Legend

- O : There is no trouble nor problem. Equipment can be used normally.
- △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
- X : Equipment has a heavy problem. It is necessary to replace it.

Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 9

PS Name: _____

I. PUMP	Appearance of casing	Finished coat	△
		Rust	△
	Appearance of installation	Bolts tightness	△
		Vibration	
	Bearing	Noise	△
	Vibration	△	
	Temperature	o	
	Oil leak	o	
Coupling	Bolt tightness	o	
	Eccentricity	△	
	Wear	△	
Others	Rust	△	
	Oil leak	o	
	Water leak	△	
	Wear	△	

Kamel

[Signature]

PS No.: 9

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	X
		Rust	△
	Bearing	Noise	△
		Vibration	△
Temperature		△	
Oil leak		o	
Rotor & Fan	Noise	△	
	Vibration	△	
	Wind pressure	o	
Others	Rust	△	
	Oil leak	o	
	Wear	△	
III. VALVE	Appearance	Water leak	△
		Rust	△
Wear		△	
Operation	Smooth	o	
IV. PIPE & HOSE	Appearance	Water leak	X
		Rust	X
		Wear	△
		Fitness	△
V. (1) SWITCH BOARD	appearance of outside	Rust	△
		Wear	△
		Noise	X
		Vibration	X
		Tightness	X
	Appearance of interior	Lighting	X
		Rust	X
	Meter	Zero setting	X
		Workability	X

Kamel

[Handwritten signature]

PS No.: 9

PS Name: _____

Page 3/3

V. (2) SWITCH BOARD	Breaker	Point pressure	X
		Rust	X
		Wear	X
		Covering	△
VI. POWER CABLE	Appearance	Damage	o
		Wear	o
		Covering	o
		Connection	o
		Insulation	o
VII. BARGE	Appearance of outside	Damage	△
		Rust	△
		Wear	△
		Vibration	o
	Appearance of interior	Damage	△
		Rust	△
Wear		△	
Winch & Anchor	Tightness	△	
	Rust	△	
	Wear	△	
	Operation smooth	△	
	Lockability	△	
VIII. DIS- CHARGE POND	Appearance	Damage	△
		Wear	△

Kassel*N. N. N.*

Water Quality {
 • Temperature 21 °C
 • 7.60 pH
 • 2.4 x 100 µs/cm 55/60

Dec. 04. 1991

GENERAL INFORMATION OF EXISTING PUMP STATION

ASWAN-GEEIERT BANARIF

PS No. : 10 PS Name : [100 pumps] 1/2

1. Commencing Year of the Pump Operation	1952
2. Manufacturers Name of the Pump	ANDRIDIES ANDRIDIES (W.G)
3. Does it exist still now?	YES
4. Presumable Percentage of the Pump Discharge Capacity Comparing with the Initial Design Capacity	60 %
5. The pump performance Curve obtained or not?	No
6. Actual Head between the River Water Level and the Discharge Water Level	8.97 (9.5) m
7. Expectable Length of the Pump Discharge Pipe Line up to the Reservoir	64.38 m
8. Acreage of the Irrigated Field at Present	By rest 800 FEDDAN
9. Acreage of the Irrigable Field at Initial Design Stage	N.A
10. Acreage of the Irrigable Field to be Extended on This Project	No
11. The Electric Motor (1) Out put (2) Voltage (3) No. of Poles (4) Frequency (5) Year of Manufacturing (6) Present Workability	110 kw 380 V 4 poles 50 Hz 1985 installed Δ
12. The Pump (1) Discharge Capacity (2) Total Head (3) Revolutional Speed (4) Present Workability	Manufactured 1957 750 L/S 10 m (600rpm) 800 rpm (120PH) Δ
13. The Transformer (1) Capacity (2) Primary Voltage (3) Secondary Voltage (4) Year of Manufacturing (5) Present Workability	500 KVA 11000 V 380 V o
14. The Reservoir (1) Dimensions Length <u> </u> m x width <u> </u> m x width (2) Effective Volume (3) Material (4) Present Workability	<u> </u> m x width <u> </u> m <u> </u> m

Kamal

[Signature]

GENERAL INFORMATION OF EXISTING PUMP STATION

PS No. : 10

PS Name : _____

2/2

15. The Discharge Tower (1) Nominal Bore (2) Material (3) Present Workability	1000 500 mm dia Iron X
16. The Discharge Pipe Line (1) Nominal Bore (2) Material (3) Berried or not (4) Present Workability	600 500 mm dia Iron Half berried Δ
17. Water Level (1) Max (2) Min (3) Ave	_____ m _____ m _____ m
18. Water Velocity (1) Max (2) Min (3) Ave	_____ m/s _____ m/s 0.22 m/s
19. Wind (1) Spring a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (2) Summer a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (3) Fall a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity : (4) Winter a) Direction : b) Ave velocity : c) Max velocity : d) Min velocity :	_____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s _____ m/s

KamelE. Kato

STATION NAME: GAZIRAT BAHAREIF

NO. OF UNITS: 2 15/50 ANDRITZ 800 15/50

KM 15.600

DISCHARGE: 750 lit/sec H: 10 mt.

R.P.M: 600

TRANSFORMER: 11000/400

500 K.V.A

28.3 / 722 Amp

1985 H.W.L 1990 1991

L.W.L 85.03 84.91


Diff 3.32 3.2 3.51

Electric Equipment:-

motor power: 110 kw 590 R.P.M

motor rated voltage: 380 V 234 A

motor type: 1 SP 355 MFC LEROY SOMER - FRANCE



- D1 = 50 cm
- D2 = 50 cm
- D3 = 100 cm
- D4 = 70 cm
- H.W.L = 84.98
- L.W.L = 81.63
- L1 = 52 mt
- L2 = 90.00
- WL = 91.00

Dec. 04, 1991

CHECK LIST

Page 1/3

(Equipment & Facilities for each existing Pump Station)

ASWAN - ABO EL RISH - GEIERT BAHARIF

Legend

- : There is no trouble nor problem. Equipment can be used normally.
 △ : Equipment has a little problem. It is better to change some parts of equipment or to maintain properly.
 X : Equipment has a heavy problem. It is necessary to replace it.


Remarks: Noise : by a sense of hearing
 Vibration : by a sense of touch
 Temperature : by a sense of touch
 Oil leak : by a sense of sight
 Wear, Rust : by a sense of sight and touch
 Tightness : by a sense of sight and touch

PS No.: 12

PS Name: _____

I. PUMP	Appearance of casing	Finished coat	○
		Rust	○
	Appearance of installation	Bolts tightness	○
		Vibration	△
	Bearing	Noise	△
	Vibration	△	
	Temperature	○	
	Oil leak	○	
Coupling	Bolt tightness	○	
	Eccentricity	○	
	Wear	○	
Others	Rust	○	
	Oil leak	○	
	Water leak	○	
	Wear	○	

Kamel



PS No.: 10

PS Name: _____

Page 2/3

II. MOTOR	Appearance	Finished coat	o
		Rust	o
	Bearing	Noise	△
		Vibration	△
Temperature		△	
Oil leak		o	
Rotor & Fan	Noise	△	
	Vibration	△	
	Wind pressure	o	
Others	Rust	o	
	Oil leak	o	
	Wear	o	
III. VALVE	Appearance	Water leak	△
		Rust	o
		Wear	△
	Operation	Smooth	△
IV. PIPE & HOSE	Appearance	Water leak	X
		Rust	△
		Wear	X
		Fitness	X
V. (1) SWITCH BORAD	appearance of outside	Rust	△
		Wear	△
		Noise	o
		Vibration	o
		Tightness	△
	Appearance of interior	Lighting	△
		Rust	△
	Meter	Zero setting	△
		Workability	△

Kamel*S. K. K.*

PS No.: 10

PS Name: _____

Page 3/3

V. (2) SWTICH BOARD	Breaker	Point pressure	△
		Rust	△
		Wear	○
		Covering	△
VI. POWER CABLE	Appearance	Damage	△
		Wear	△
		Covering	△
		Connection	○
		Insulation	○
VII. BARGE	Appearance of outside	Damage	△
		Rust	△
		Wear	△
		Vibration	△
	Appearance of interior	Damage	△
		Rust	○
		Wear	△
	Winch & Anchor	Tightness	△
		Rust	○
		Wear	△
		Operation smooth	△
		Lockability	△
VIII. DIS- CHARGE POND	Appearance	Damage	△
		Wear	△

Kamel*N. Kamil*

6.5 10ヶ所のプロペラングポンプの年間管理記録

1/4
(1987)

Site No.	Station Name	No. of operating hours	Discharge in cu.m (year)	Cost of Maintenance (L.E)	Cost of consumption of electric power and fuel	Wages & salary (L.E)	Cost of oils & grease (L.E)	Inspection and Repairing cost	Total cost (L.E)	Cost of irrigation per feddan (L.E)	Area served
1	El Sheikh Fadl	2,397	4,314,600	55.00	6,800,830	9,148,500	44,880	11,667	27,716,210	86,634	320
2	Sahel El Hamam	2,185	3,988,800	34,900	4,600,002	7,263,852	264,440	7,292	19,455,194	97,275	200
3	El Fosa El Baharia	930	1,674,000	22,400	825,730	5,008,000	248,380	5,469	11,573,000	77,175	150
4	Sahel El Kobania	1,947	3,504,600	20,890	1,558,750	7,164,679	13,520	10,937	19,695,839	65,650	300
5	Sahel Fares	6,198	1,673,460	62,000	1,910,110	11,075,760	59,760	40,524	53,632,000	83,800	640
7	El Twise	3,011	2,210,605	30,000	5,303,353	8,715,252	52,320	10,573	24,673,925	84,100	290
8	Gharb Aswan Baharia	6,237	11,226,000	110,380	5,982,000	16,360,719	34,180	9,115	31,602,017	126,400	250
9	Gezirat Fares	2,477	4,458,600	73,000	6,301,000	6,022,260	37,440	7,292	19,725,481	98,630	200
10	Gezirat Behrif	4,821	8,781,000	83,120	8,419,000	18,508,054	28,560	10,938	37,976,566	126,300	300

2/4
(1988)

Site No.	Station Name	No. of operating hours	Discharge in cu.m (year)	Cost of Maintenance (L.E)	Cost of consumption of electric power and fuel	Wages & salary (L.E)	Cost of oils & grease (L.E.)	Inspection and Repairing cost	Total cost (L.E.)	Cost of irrigation per feddan (L.E.)	Area served
1	El Sheikh Fadl	2,718	4,910,400	71.00	1,700.000	9,380.000	44.880	16,960	28,155.88	87.987	320
2	Sahel El Hamam	2,506	4,510,800	36.640	6,300.200	11,129.000	44.880	10,600	28,110.144	140.550	200
3	El Fosa El Baharia	1,274	2,293,200	211.175	1,623.080	4,762.320	258.510	7,950	14,805.085	98.700	150
4	Sahel El Kobania	2,166	3,898,000	11.420	2,299.752	6,426.223	13.640	15,900	24,651.035	82.170116	300
5	Sahel Fares	6,210	1,723,280	85.0	31,000.430	4,843.000	59.760	23,920	59,908.19	107.21	640
7	El Twise	2,816	1,798,925	12.610	6,000.000	11,805.000	52.320	15,370	33,237.581	114.612	290
8	Gharb Aswan Baharia	6,188	11,138,400	263.500	23,608.9.9	16,717.257	27.280	13,250	53,867.946	222.667	250
9	Gezirat Fares	2,570	4,626,000	46.00	8,500.898	14,004.000	37.440	10,600	33,188.338	165.941	200
10	Gezirat Behrif	4,462	8,924,000	97.420	13,999.152	20,783.292	17.980	15,900	50,797.844	169.32614	300


3/4
(1989)

Site No.	Station Name	No. of operating hours	Discharge in cu.m (year)	Cost of Maintenance (L.E)	Cost of consumption of electric power and fuel	Wages & salary (L.E)	Cost of oils & grease (L.E.)	Inspection and Repairing cost	Total cost (L.E.)	Cost of irrigation per feddan (L.E.)	Area served
1	El Sheikh Fadl	2,812	5,066,600	722.00	14,000.52	9,180.00	20.54	13,705	37,651.00	117.60	320
2	Sahel El Hamam	2,297	4,134,600	327.00	8,000.37	10,500.00	39.92	8,568	27,435.29	137.10	200
3	El Fosa El Baharia	1,479	2,662,200	7.44	19.80	4,823.06	38.44	6,426	11,314.74	75.43	150
4	Sahel El Kobania	2,048	3,686,000	193.47	3,146.84	15,761.70	32.40	12,852	31,986.40	106.60	300
5	Sahel Fares	6,041	1,673,460	300.00	32,313.28	15,210.66	26.74	27,417	75,287.60	117.60	640
7	El Twise	2,902	2,535,250	340.00	8,000.07	12,120.00	41.78	12,423	32,924.80	113.50	290
8	Gharb Aswan Baharia	5,647	1,016,500	210.50	20,123.53	28,408.15	33.20	10,710	59,494.38	237.90	250
9	Gezirat Fares	2,435	4,383,900	527.160	11,000.70	82,170.24	43.54	8,568	101,256.30	506.25	200
10	Gezirat Behrif	3,250	8,700,000	205.64	16,165.56	31,368.54	36.12	12,852	60,627.30	202.00	300

4/4
(1990)

Site No.	Station Name	No. of operating hours	Discharge in cu.m (year)	cost of Maintenance (L.E)	Cost of consumption of electric power and fuel	Wages & salary (L.E)	Cost of oils & grease (L.E.)	Inspection and Repairing cost	Total cost (L.E.)	Cost of irrigation per feddan (L.E.)	Area served
1	El Sheikh Fadi	3,210	5,778,000	110	19,533.46	9,863.16	34.96	18,816	48,357.58	151.117	320
2	Sahel El Hamam	2,487	4,476,600	200	13,504.651	9,767.76	36.82	11,760	35,269.231	176.346	200
3	El Fosa El Baharia	1,489	2,680,200	25.325	1,098.276	5,795.235	140.625	8,820	24,879.461	165.863	150
4	Sahel El Kobania	2,119	388,900	128.310	4,163.856	10,428.195	16.120	176,400	191,136.48	637.121	300
5	Sahel Fares	6,595	17,806,500	258	31,000.765	1,596.600	31.005	37,632	70,531	110.204	640
7	El Twise	2,984	2,232,450	120	12,220.818	12,497.88	38.680	17,052	41,929.378	144.584	290
8	Gharb Aswan Baharia	6,472	11,764,800	522.160	42,046.194	25,680.548	31.400	14,700	82,980.302	331.921	250
9	Gezirat Fares	2,670	4,806,900	68	13,060.235	8,424.480	34.34	11,760	33,287.055	166.435	200
10	Gezirat Behrif	4,844	9,515,600	254.560	22,414.292	24,095.661	32.240	17,640	64,436.753	214.789	300
6	El Biadica El Ollia	10,395	68,085,000	4,439.0	489,657.0	104,674.0	2,766	10,566	612,098.0	161.0	3,800


1) 現状配置図



2) 現状揚程

(1) 実揚程	21.0 M
(2) ポンプ回り損失水頭	1.0 M
(3) タワー損失水頭	0.5 M
(4) 手前旧パイプ損失水頭 (Dia 700 mm x 150 M)	10.7 M
(5) 中間旧パイプ損失水頭 (下段水路まで) (Dia 1000 mm x 800 M)	21.2 M
(6) 先端旧パイプ損失水頭 (上段水路まで) (Dia 1000 mm x 200 M)	1.5 M
(7) 先端速度損失水頭	0.32 M
全揚程 (必要動力)	56.22 M 950 KW

3) 適性水路に更新後の配置図



4) 適性水路に更新後の揚程

(1) 実揚程	21.0 M
(2) ポンプ回り損失水頭	1.0 M
(3) タワー損失水頭	0.5 M
(4) 手前更新パイプ損失水頭 (Dia 1200 mm x 200 M, 2本)	0.87 M
(5) 中間変更パイプ損失水頭 (下段水路まで) (Dia 1200 mm x 800 M, 1本)	3.47 M
(6) 先端変更パイプ損失水頭 (上段水路まで) (Dia 1200 mm x 200 M, 1本)	0.87 M
(7) 先端速度損失水頭	0.27 M
全揚程	27.97 M
(必要動力)	460 kW

6.7 ポンプ場維持管理運営体制及び人員配置

組 織	責 任 者 名	人 員
General Directorate Upper Egypt	Dir. Eng Wahbu Sabet Lauka	1 技師 75 職員
A South Upper Egypt General Directorate	Dir. Mohamed Abd Al Rahaman	4 技師 650 職員
1: Directorate of Aswan		4 技師 66 職員
a) Khafar Handasa		1 技師 112 職員
b) Draw Handasa		2 技師 173 職員
c) Edfu Handasa		2 技師 159 職員
B Middle East General Directorate (Naga Hamady)	Dir. Abd Rawof Marhaly	8 技師 1,100 職員
2: Directorate of Luxsor	Eng. Sabry Maghazy	3 技師 53 職員
a) El Hebeit Handasa		1 技師 82 職員
b) GL Gherea Handasa		113 (技師、職員)
c) Shanhour Handasa		100 (技師、職員)

6.8 年間維持管理費算出根拠

(1)	維持費	7,000 LE
	1990年の実績 6,125LEより	
(2)	電力費	960,000 LE
	1m ³ 当り電力単価 = 647,895/127,600,000 = 0.0051LE/m ³	
	年間ポンプ送水量 = 188,375,000m ³	
	(付属資料6.4より)	
	電力費 = 0.0051 * 188,375,000m ³ = 960,700LE	
(3)	人件費	264,000 LE
	技師 = 6,000LE * 1人 * ハンダーサ = 24,000LE	
	職員 = 2,400LE * 10人 * 10カ所 = 240,000LE	
(4)	潤滑油・グリース費	4,000 LE
	1990年実績3,162LEより推定	
(5)	点検、修理費	100,000 LE
	1987、88、90年実績より。(付属資料4.4参照)	
		合計 <u>1,335,000 LE</u>

