



Fig. 5-26 Temperature vs Depth Diagram of Exploratory Wells




Fig. 5-27 Pressure and Temperature Profiles for COP-1

LEGEND

- April 1981 (Sonic) Orifice } (Mean : - - - - -)
- ▣ " " (Subsonic) Orifice } (Mean : - - - - -)
- Feb. 19~26, 1982 Stable flow rate (— · — · — · —)
- " " Unstable flow rate (— · — · — · —)
- x Feb. 27~May 7, 1982 Flow rate after shut in test
- △ Sep. 9, 1982~Aug. 2, 1984
- ▲ Jan. 21, 1987~Apr. 1, 1987
- ◇ Nov. 14, 1987~Dec. 8, 1987

from COPADE (1981); (1982) and CREGEN data




Fig. 5-28 COP-1 Well Characteristic Curve




Fig. 5-29 COP-1 Production History




Fig. 5-30 COP-1 Schematic Production Curve




Fig. 5-31 Integrated Columnar Section of COP-2




Fig. 5-32 Pressure and Temperature Profiles for COP-2




Fig. 5-33 Horner Buildup Graph for COP-2




Fig. 5-34 COP-2 Well Characteristic Curve




Fig. 5-35 COP-2 Production History





Fig. 5-36 COP-2 Schematic Production Curve

Depth(m)	Drilling	Casing
0		
100	<p>21.00m</p> <p>12¹/₄" Tricone bit (311.2mm)</p>	<p>20.00m</p> <p>9⁵/₈" API N-80 (400ϕ) (OD:244.5mm, ID:226.6mm) Full hole cementing</p>
200	<p>8⁵/₈" Tricone bit (219.1mm)</p>	<p>7" API N-80 (290ϕ) (OD:177.8mm, ID:157.1mm) Full hole cementing</p>
300	<p>301.00m</p>	<p>300.00m</p>
400		
500	<p>6" Tricone bit (151.1mm)</p>	<p>5" API N-80 (180ϕ) (OD:127.0mm, ID:112.0mm) Full hole cementing</p>
600		
700		
800	<p>782.00m</p>	<p>779.00m</p>
900	<p>4¹/₈" Tricone bit (104.8mm) (782.00~882.90m :NQ-WL Coring)</p>	<p>92mm NX-NU R-70 Full hole cementing</p>
1,000	<p>1,000.00m</p>	<p>957.25m 986.13m</p>
1,100	<p>NQ-WL (78.2mm) Coring 1,065.00m</p>	<p>2" ASTM Sch-40 (OD:60.3mm, ID:52.5mm) (786.93~1,053.17m :Strainer)</p>

Fig. 5-37 Casing Program of COP-3



- ① Measurement Date : May 15, 1991 (ST. 8hr)
Water Level : 900m
Max Temp : 240°C (1.002m)
- ② Measurement Date : May 16, 1991 (ST. 24hr)
Water Level : 887m
Max Temp : 241°C (1.002m)
- ③ Measurement Date : May 17, 1991 (ST. 48hr)
Water Level : 875m
Max Temp : 242°C (1.002m)
- ④ Measurement Date : May 9, 1991 (ST. 96hr)
Water Level : 870m
Max Temp : 242°C (1.002m)
- ⑤ Measurement Date : May 31, 1991 (ST. 390hr 50m)
Water Level : about 1.010m
Max Temp : 236.9°C (1.000m)
- ⑥ Equilibrium Temperature Calculated by
①, ②, and ③ (1.000m ~ 1.065m)

Fig. 5-38 Columnar Section of COP-3




Fig. 5-39 Distribution of Alteration Minerals from COP-3, Detected by X-ray Diffractometer





Fig. 5-40 Homogenization Temperature of Fluid Inclusion of COP-3



○ : STATIC TEMPERATURE	} 1991. 5. 31 15:50 (ST = 390h50m ; 900~1049m)	
□ : STATIC PRESSURE		19:00 (ST = 394h ; 500 ~ 800m and 1015m)
	} 1991. 6. 1 10:00 (ST = 409h ; 0 ~ 400m)	
◆ : FLOWING TEMPERATURE	} 1991.6.12 Steam Flowrate 7.9t/h (0 ~ 900m)	
▲ : FLOWING PRESSURE		5.4 " (1000~1046m)
		6.13 —" —" 5.7 "
	6.15 —" —" 6.9 "	

Fig. 5-41 Pressure and Temperature Profiles for COP-3

(May 7, 1991)
Depth of AMERADA gauge : 986.m





Fig. 5-42 Pressure Transient during Injection on COP-3



$$\textcircled{1} \text{ I. I. } = \frac{24.5 \text{ t/h}}{(38.867 - 38.108) \text{ kg/cm}^2 \text{ G}} = 32 \text{ t/hr/kg/cm}^2$$

$$\textcircled{2} \text{ I. I. } = \frac{45.3 \text{ t/h}}{(39.415 - 38.108) \text{ kg/cm}^2 \text{ G}} = 35 \text{ t/hr/kg/cm}^2$$

$$\textcircled{3} \text{ I. I. } = \frac{74.5 \text{ t/h}}{(39.638 - 38.108) \text{ kg/cm}^2 \text{ G}} = 49 \text{ t/hr/kg/cm}^2$$

Ave. 38 t/hr/kg/cm²

Fig. 5-43 Injectivity of COP-3




Fig. 5-44 Horner Buildup Graph for COP-3




Fig. 5-45 COP-3 Production History







Fig. 5-46 COP-3 Well Characteristic Curve




- LEGEND**
- [Geology]**
- Copahue Volcanic Rocks
 - A° Trolope Igneous Rocks
 - Las Mellizas Formation
 - Caviahue Conglomerate Member
 - Hualcupen Formation
- [Structural Features]**
- Fault
 - Fault (Assumed)
 - Fumaroles and Hydrothermal Alteration Zone
 - Crater
- [Gravity Prospecting]**
- Iso-Gravity Contour (mgal) ($\rho=2.23g/cm^3$)
 - High Anomaly
 - Low Anomaly
 - Gravimetric Anticline
 - Gravimetric Syncline
 - Gravimetric Lineament
 - Exploratory well



CENTRO REGIONAL DE ENERGIA GEOTERMICA DEL NEUQUEN
 REPUBLICA ARGENTINA
 FEASIBILITY STUDY OF COPAHUE GEOTHERMAL DEVELOPMENT PROJECT
 COMPOSITE MAP OF GEOLOGY AND BOUGUER ANOMALY
 JAPAN INTERNATIONAL COOPERATION AGENCY
 DATE: _____



- LEGEND**
- [Geology]**
- Cov Copahue Volcanic Rocks
 - Tr.v A° Trolope Volcanic Rocks
 - Me.v Las Mellizas Formation
 - Me.s Cavihue Conglomerate Member
 - Hu.F Hualcupen Formation
 - Fault
 - Fault (Assumed)
 - Fumaroles and Hydrothermal Alteration Zone
 - Crater
- [Gravity Prospecting]**
- Iso-Gravity Contour(mgal) ($\rho=2.23g/cm^3$)
 - H High Anomaly
 - L Low Anomaly
 - Gravimetric Anticline
 - Gravimetric Syncline
 - Gravimetric Lineament
 - Exploratory well



CENTRO REGIONAL DE ENERGIA GEOTERMICA
 DEL NEUQUEN
 REPUBLICA ARGENTINA


FEASIBILITY STUDY
 OF
 COPAHUE GEOTHERMAL DEVELOPMENT PROJECT

COMPOSITE MAP
 OF
 GEOLOGY AND BOUGUER ANOMALY

JAPAN INTERNATIONAL COOPERATION AGENCY

DATE: _____ Fig. 5-47



Profile A - A'




LEGEND

- Ta Talus
- Co.v Copahue Volcanic Rocks
- Tr.v A° Trolope Volcanic Rocks
- Me.v Las Mellizas Formation
- Me.s Caviahue Conglomerate Member
- R.B.p Riscos Bayos Pyroclastic Flow Deposits
- Hu.F Hualcupen Formation
- Geologic Boundary
- Fault
- Fault (Assumed)
- Fumarole and Hot Spring
- Base of Shallow Low Resistivity Layer
- Top of Deep Low Resistivity Layer
- Upheaval Zone of High Resistivity Basement

Profile B - B'



CENTRO REGIONAL DE ENERGIA GEOTERMICA
DEL NEUQUEN
REPUBLICA ARGENTINA
FEASIBILITY STUDY
OF
COPAHUE GEOTHERMAL DEVELOPMENT PROJECT
GEOLOGY AND RESISTIVITY PROFILE
JAPAN INTERNATIONAL COOPERATION AGENCY
DATE: Fig. 5-48



LEGEND

[Geology]


- Copahue Volcanic Rocks
- Hualcupen Formation
- Fault
- Fault (Assumed)
- Fumaroles and Hydrothermal Alteration
- Crater

[Gravity Survey]


- Iso-Gravity Contour (m gal, $\rho = 2.23g/cm^3$)
- High Anomaly
- Low Anomaly

[Resistivity Survey]


- Apparent Resistivity Contour ($\Omega \cdot m$, AB/2 Resistivity ($\Omega \cdot m$))
- < 10
- 10~15
- 15~20
- 20~30
- Top of Deep Low Resistivity Zone (EL. 800)
- Upheaval Zone of High Resistivity Base
- Exploratory well



CENTRO REGIONAL DE ENERGIA GEOTERMAL DEL NEUQUEN
 REPUBLICA ARGENTINA
 FEASIBILITY STUDY OF COPAHUE GEOTHERMAL DEVELOPMENT PROJECT
 COMPOSITE MAP OF BOUGUER ANOMALY, RESISTIVITY AND FAULTS
 JAPAN INTERNATIONAL COOPERATION AGENCY
 DATE: _____



- LEGEND**
- [Geology]**
- Co.v Copahue Volcanic Rocks
 - Hu.F Hualcupen Formation
 - Fault
 - Fault (Assumed)
 - Fumaroles and Hydrothermal Alteration Zone
 - Crater
- [Gravity Survey]**
- Iso-Gravity Contour (m gal, $\rho = 2.23 \text{ g/cm}^3$)
 - H** High Anomaly
 - L** Low Anomaly
- [Resistivity Survey]**
- Apparent Resistivity Contour ($\Omega\text{-m}$, $AB/2 = 500\text{m}$)
 - Resistivity ($\Omega\text{-m}$)
 - < 10
 - 10~15
 - 15~20
 - 20~30
 - Top of Deep Low Resistivity Zone (El. m)
 - Upheaval Zone of High Resistivity Basin
 - Exploratory well




CENTRO REGIONAL DE ENERGIA GEOTERMICA
DEL NEUQUEN
REPUBLICA ARGENTINA

FEASIBILITY STUDY
OF
COPAHUE GEOTHERMAL DEVELOPMENT PROJECT

**COMPOSITE MAP OF BOUGUER
ANOMALY, RESISTIVITY AND FAULTS**

JAPAN INTERNATIONAL COOPERATION AGENCY

DATE: _____ Fig. 5-49




5816
5814
5812
5810
5808
5806
5805

1572 1574 1576 1578 1580 1582 1584 1596

LEGEN


- Fault s
- Fault (A
- Strike a
- Strike a
- Lineame
- Hydroth
- Crater
- Fumarol
- Contour Resistiv
- Contour Resistiv
- Isotherm
- Anomar
- Thermal
- Explora
- Alternat
- Upheav Resistiv
- Locatio

CENTRO REGION
COPAHUE GEOTH
RESULT
JAPAN INTER



LEGEND


- Fault sh: Shear Zone(m)
- Fault ct: Fault Clay(m)
- Fault (Assumed)
- Strike and Dip of Normal Fault
- Strike and Dip of Reverse Fault
- Lineament (from Aerial Photographs)
- Hydrothermal Alteration Zone
- Crater
- Fumaroles
- Contour of Top of Intermediate Depth High Resistivity Layer (EL. m)
- Contour of Detected Depth of Deep Low Resistivity Layer (EL. m)
- Isotherm (°C) of 50m Depth
- Anomaly of soil Mercury(ppb)
- Thermal Gradient Hole
- Exploratory well
- Alternative Location of COP-3
- Upheaval Zone of High Resistivity Basement
- Location of Section




CENTRO REGIONAL DE ENERGIA GEOTERMICA DEL NEUQUEN REPUBLICA ARGENTINA	
FEASIBILITY STUDY OF COPAHUE GEOTHERMAL DEVELOPMENT PROJECT	
COMPILED MAP SHOWING RESULT OF EACH SURVEY	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DATE :	Fig. 5-50

1574 1576 1578 1580 1582 1584 1596

Profile A - A'




Profile B - B'



LEGEND

- T_o Talus
Gravel, Sand and Mud
- Co.v Copahue Volcanic Rocks
Pyroxene Olivine Basalt, Liparite and
Pyroclastic Rocks
- Tr.v A° Trolope Volcanic Rocks
Pyroxene-bearing Plagioclase Andesite
- Me.v } Olivine Pyroxene Basaltic Andesite,
Pyroxene Andesite and Agglomerate etc.
- Me.s } Las Mellizas
Formation
Lake Sediments and Glacial Deposits
Conglomerate, Sandstone and Mudstone
- R.B.p Riscos Bayos Pyroclastic Flow Deposits
- Hu.F Hualcupen Formation
Fine Pyroxene Andesite, Agglomerate,
Tuff Breccia, Tuff etc.
- Geologic Boundary
- Fault
- Fault (Assumed)
- Fumarole and Hot Spring
- Isotherms
- Heat Conduction
- Meteoric Water Flow
- Hydrothermal Fluid Flow
- Volcanic Gas
- Vapor dominated Reservoir
- Hot Water Reservoir
- Alteration Zone
- Production Zone
- Alternative Location of COP-3

Fig. 2-1



CENTRO REGIONAL DE ENERGIA GEOTERMICA DEL NEUQUEN REPUBLICA ARGENTINA	
FEASIBILITY STUDY OF COPAHUE GEOTHERMAL DEVELOPMENT PROJECT	
MODEL OF GEOTHERMAL SYSTEM	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DATE :	Fig. 5-51




Fig. 5-52 Conceptual flow of resource assessment in Copahue Study

Profile A - A'




Fig. 5-53 Simulation Model

LEGEND

Talus	Hydrothermal Fluid Flow
Gravel, Sand and Mud	Volcanic Gas
Copahue Volcanic Rocks	Vapor dominated Reservoir
Pyroxene Olivine Basalt, Lignite and Pyroclastic Rocks	Hot Water Reservoir
A ⁰ Trolope Volcanic Rocks	Alteration Zone
Pyroxene-bearing Plagioclase Andesite	Production Zone
Olivine Pyroxene Basaltic Andesite, Pyroxene Andesite and Agglomerate etc.	
Lake Sediments and Glacial Deposits	
Conglomerate, Sandstone and Mudstone	
Riscos Bayos Pyroclastic Flow Deposits	
Hualcopen Formation	
Fine Pyroxene Andesite, Agglomerate, Tuff Breccia, Tuff etc.	
Geologic Boundary	
Fault	
Fault (Assumed)	
Fumarole and Hot Spring	
Isotherms	
Heat Conduction	
Meteoritic Water Flow	




Fig. 5-54 Computed Temperature Distribution




Fig. 5-55 Computed Pressure Distribution




Fig. 5-56 Computed Steam Saturation Distribution




Fig. 5-57 Computed Mass Flux Distribution

Z = 6	0.1	5.0	1.0	1.0	0.001	0.001	0.5	0.001	0.1	0.1
5	0.1	5.0	1.0	0.001	50.0	50.0	50.0	0.001	0.1	0.1
4	0.1	5.0	0.1	0.001	50.0	50.0	50.0	0.001	0.1	0.1
3	0.1	5.0	0.1	0.001	50.0	50.0	50.0	0.001	0.1	0.1
2	0.1	5.0	0.1	0.001	50.0	50.0	0.001	0.1	0.1	0.1
1	0.1	5.0	0.1	0.01	50.0	50.0	0.001	0.1	0.1	0.1
X = 1		2	3	4	5	6	7	8	9	10

permeability (10^{-15} m^2)

Fig. 5-58 Permeability Distribution




Fig. 5-59 Schematic Representation of the Monte Carlo Simulation Process




Fig. 5-60 Map of confirmed and whole areas




Fig. 5-61 Histogram of MW Capacity, Confirmed Area




Fig. 5-62 Mean of MW Capacity vs. No. of Trials, Confirmed Area




Fig. 5-63 Cumulative Probability of MW Capacity, Confirmed Area




Fig. 5-64 Histogram of MW per Square Kilometer, Confirmed Area




Fig. 5-65 Cumulative Probability of MW per Square Kilometer, Confirmed Area




Fig. 5-66 Histogram of MW Capacity, Whole Area




Fig. 5-67 Mean of MW Capacity vs. No. of Trials, Whole Area




Fig. 5-68 Cumulative Probability of MW Capacity, Whole Area





Fig. 5-69 Histogram of MW per Square Kilometer, Whole Area



MW Capacity per sq. km [MW/KM2]

6.15

Fig. 5-70 Cumulative Probability of MW per Square Kilometer, Whole Area




Fig. 5-71 Evaluation Curve of Plant Capacity

Table 5-1 List of Geothermal Investigation Works in Copahue Area

Investigation Works	Year	Admini- stra- tion *1	Exe- cutor	Scope of Investigation Works	No. of Data *2
Geological survey	1974	CNEG	YPF	regional survey	-
	1980	COPADE	L-ELC	detailed survey	C1, 13
	1987		A. H. Pesce	volcano-tectonics	C6
Geophysical prospecting					
Gravity prospecting	1975	CNEG	YPF	180 km ² , 285 points	C26-27
Electrical prospecting	1980	COPADE	L-ELC	AB/2=2000m, 56 points 69 lines	C1
	1981	"	"	AB/2=5000m, 7 points 15 lines	C3
	1987	CREGEN	CREGEN	AB/2=1500m, 11 points	
Geochemical survey					
Soil geochemistry	1974	CNEG	YPF		-
	1986	CREGEN	CREGEN	Hg, CO ₂ , 1m depth temperature 10km ² , 70 points + 8 km ² , 50 points	C7
Fluid geochemistry	1980-87	COPADE CREGEN	L-ELC CREGEN	surface water, fluids of fumarole, well fluid, analysis of chemical composition and isotope	C1,18-23
Well survey					
Thermal gradient hole	1975-76	CNEG	YPF	11-200m, 17 wells	C28,29
Exploratory well COP-1	1976	CNEG	YPF	954m, logging	C2,4,31,
"	1981	COPADE	YPF	deepen to 1414m	32,34
Exploratory well COP-2	1986	CREGEN	CREGEN	1241m, logging	C5,33, 34,35
Well test (COP-1, 2)	1981-87	COPADE CREGEN	L-ELC CREGEN	production test, hole temperature. pressure	C2,4,5, 31,36,37 38

*1 Administration

CNEG : Comision Nacional de Estudios Geotermicos
 COPADE: Consejo de Planificacion para el Desarrollo
 CREGEN: Centro Regional de Energia Geotermica del Neuquen
 L-ELC : Latinoconsult/ELC-Electroconsult

*2 List of Collected Dates

Table 5-2 Stratigraphic Correlation between this Report and Other Reports

Age	LATINOCONSULT/ELC-Electroconsult (1980)	Pesce (1987)	This report
Holocene	Productos del Volcan Copahue	Centro Efusivo Copahue	Copahue Volcanic Rocks
Pleistocene	Formación Palao-Co	Efusiones de Fondo de Valle	A° Trolope Volcanic Rocks
Quaternary		Centro Efusivo Las Mellizas	Las Mellizas Formation Caviáhue Conglomerate Member
Tertiary		Depositos Fondo de Caldera	Riscos Bayos Pyroclastic Flow Deposits
		Formación Huaiquipen	Huaiquipen Formation
Miocene	Sedimentos de la Cuenca Neuquina	Formación Trapa Trapa Formación Epulaufquén	?
Pre-Tertiary		?	

Table 5-3 Chemical Composition of Ground Surface Water and Hot Spring Water

No.	Sample No.	Date	Temp. °C	pH	Conductivity μS/cm	Na	K	Ca	Mg	NH ₄	HCO ₃	SO ₄	Cl	SiO ₂	No. of colle. data
						mg/l meq/l						mg/l meq/l			
1	Agrio 1	7.'80	12.3	5.25	260	6.7	0.8	9.2	1.5		20.0	60.0	20.0	3.0	C.1
2	Agrio 2	"	10.4	4.97	1,520	0.29	0.02	0.46	0.12		0.33	1.25	0.56		
3	Agrio 3	"	11.2	4.48	4,400	48.9	17.4	113.6	186.0		20.0	690.0	190.0	4.0	"
4	CAV 1	"	13.5	1.80	11,500	2.13	0.45	5.67	15.31		0.33	14.35	5.36		
5	CAV 2	"	14.6	2.60	1,520	141.0	36.5	393.0	765.0		0	2,360.0	5,040.0	27.0	"
6	CAV 5	"	12.6	5.42	260	6.13	0.93	19.61	62.96		0	49.09	142.13		
7	CAV 6	"	11.0	5.52	260	25.2	14.9	7.8	45.0		0	2,100.0	520.0	12.0	"
8	CAV 7	"	11.1	6.98	350	1.10	0.38	0.39	3.70		0	43.68	14.66		
9	ARA 2	"	12.1	7.25	24	7.4	1.2	2.8	12.5		0	250.0	50.0	4.0	"
10	ARA 4	"	9.0	6.00	390	0.32	0.03	0.14	1.04		0	5.20	1.41		
11	ARA 6	"	14.0	0.75	20,000	8.9	1.2	21.1	15.0		30.0	90.0	20.0	10.0	"
12	HU 5	"		6.36	18	0.39	0.03	1.05	1.23		0.49	1.87	0.56		
13	HAC 3	"	10.1	6.30	250	9.6	2.3	11.4	16.0		0	100.0	50.0	6.0	"
14	IT	"	12.3	6.75	20	0.42	0.06	0.57	1.32		0	2.08	1.41		
15	3T	"	12.4	6.47	28	7.4	0.3	18.5	21.0		30.0	80.0	20.0	7.0	"
16	CO 1	"	7.6	6.05	20	0.32	0.02	0.92	1.73		0.49	1.66	0.56		
17	CO 2	"	8.0	6.10	3	2.8	0.3	1.4	1.2		40.0	10.0	10.0	8.0	"
18	CO 4	"	8.9	6.35	12	0.12	0.02	0.07	0.10		0.66	0.21	0.28		
19	CO 5	"	12.0	6.20	8	11.9	1.2	12.8	33.0		30.0	120.0	20.0	12.0	"
20	CO 7	"	10.1	6.31	16	0.52	0.03	0.64	2.72		0.49	2.50	0.56		
21	CO 8	"	9.5	6.20	9	95.0	99.6	14.2	87.0		0	9,140.0	4,870.0	38.0	"
22	CO 10	"	10.2	6.35	116	4.20	25.5	0.71	7.16		0	190.11	137.33		
23	CO 11	"	11.2	6.10	114	0.6	0.4	1.1	0.9		40.0	10.0	10.0	3.0	"
24	CO 12	"	10.5	5.04	230	0.03	0.01	0.05	0.07		0.66	0.21	0.28		
25	CO 15	"	10.4	4.20	26	8.9	1.2	11.1	15.0		20.0	30.0	20.0	5.0	"
26	RHCP 3	"	12.1	6.55	34	0.39	0.03	0.55	1.23		0.33	1.66	0.56		
27	HA 3	"	11.2	7.48	55	0.7	0.4	0.7	0.9		50.0	10.0	10.0	12.0	"
28	MA 2	"	84.6	5.82	1,720	0.03	0.01	0.03	0.07		0.82	0.21	0.28		
29	MA 3	"	91.2	6.55	1,980	0.7	0.4	0.7	0.9		30.0	10.0	4.6	6.0	"
30	MA 5	"	17.4	4.24	68	0.03	0.01	0.03	0.07		0.49	0.21	0.13		
31	MA 7	"	84.0	4.32	1,640	0.7	0.4	0.7	0.3		30.0	10.0	10.0	12.0	"
32	MA 9	"	91.8	6.95	380	0.03	0.01	0.03	0.02		0.49	0.21	0.28		
33	MAT 4	"	80.5	4.01	2,800	0.5	0.4	0.7	0.3		0	170.0	20.0	8.0	"
34	MAT 6	"	87.0	2.45	4,220	0.02	0.01	0.03	0.02		0	3.54	0.56		
35	ANF 3	"	82.6	5.72	1,480	0.4	0.4	0.7	0.3		30.0	10.0	10.0	9.0	"
36	ANF 5	"	36.4	6.30	660	0.02	0.01	0.03	0.02		0	0.42	0.56		
37	ANF 6	"	11.2	5.36	31	0.4	0.4	0.7	0.3		0	20.0	20.0	8.0	"
38	COPA 5	2.'85	61	6.6	53	0.02	0.01	0.03	0.02		0	0.42	0.56		
39	COPA 6	"	51.5	5.9	38	0.02	0.01	0.03	0.02		0	0.42	0.56		
40	COPA 7	"	34	5.9	19	0.7	0.4	0.7	0.3		30.0	10.0	10.0	12.0	"
						0.83	0.16	3.05	0.79		4.78	0.25	0.06		
						2.30	0.59	2.55	2.50		7.90	0.27	0.06	90	C.18
						1.65	0.49	1.95	1.08		4.70	0.48	0.03	100	"
						19	6.2	61	9.5		287	12	2	80	"

Note: No. 1 - No. 27: Ground surface water
No. 28 - No. 40: Hot spring water

Table 5-4 Gas Composition and Geochemical Temperature

Sample No.	Date	Gas Composition (Vol %)					Geochemical Temperature			No. of Collected data
		CO ₂	H ₂ S	H ₂	N ₂	CH ₄	α	β	T (°C)	
Chancho C6	'77	66.93	16.75	16.22		0.06	-0.60	-7	(598)*	C.20
"	"	75.69	10.75	13.25		0.31	2.31	0	(373)*	"
Anfiteatro	'77	95.04	0.32	2.06		2.65	14.72	0	215*	C.20
"	7.'80	93.14	n.d.	3.72	0.50	2.62	12.69	0	235	C.1
"	"	"	"	1.31	"	"	15.37	0	209	"
" 2	6.'82	95.36	0.1	1.34	0.51	2.68	17.00	0	194	C.4
Rio Blanco	11.'86	92.66	0.52	1.86	2.55	2.41	13.77	0	224*	C.22
"	"	92.24	0.41	1.91	2.85	2.62	14.07	0	221*	"
B° de Copahue	'77	96.30	0.003	2.29		1.41	19.59	0	172*	C.20
"	"	95.59	0.04	2.45		1.93	16.29	0	200*	"
"	"	96.55	0.46	1.14		1.85	15.10	0	211*	"
"	"	96.34	0.26	2.10		1.26	13.91	0	223*	"
Termas de Copahue 2	7.'80	89.63	n.d.	5.89	2.19	2.32	12.78	0	234	C.1
" 2	"	"	"	3.24	"	"	14.34	0	218	"
" 6	"	93.81	n.d.	4.59	tr	1.61	13.25	0	229	"
" 6	"	"	"	2.25	"	"	15.11	0	211	"
Copahue (COT 6)	6.'82	95.94	0.1	2.30	tr	1.64	15.13	0	211	C.4
" (COT 2)	"	91.94	0.1	3.32	2.24	2.37	14.36	0	218	"
Termas de Copahue	11.'86	94.56	0.62	1.62	2.15	1.02	13.18	0	230*	C.22
"	"	94.19	0.56	1.57	2.57	1.11	13.49	0	227*	"
Aqua de Lemon	11.'86	91.73	0.64	1.54	4.92	1.17	13.33	0	229*	"
Las Maquinitas	'77	96.13	0.50	1.74		1.63	13.76	0	224	C.1
"	"	94.69	0.17	2.60		2.74	14.53	0	217	"
" 1	7.'80	94.80	n.d.	3.50	0.23	1.42	13.88	0	223	"
" 1	"	"	"	1.85	"	"	15.53	0	207	"
"	'81	94.8	n.d.	1.8	0.2	1.4	15.60	0	206	C.2
" 1	6.'82	96.39	0.1	1.83	0.23	1.44	15.63	0	206	C.4
"	11.'86	95.4	0.53	1.45	1.32	1.3	13.94	0	222*	C.22
"	"	95.6	0.44	1.7	1.96	1.3	13.74	0	224*	"
Las Maquinas	'77	93.46	0.15	2.7		3.65	14.50	0	217	C.1
"	"	93.95	0.65	2.34		3.05	13.12	0	230	"
" 1	7.'80	92.68	n.d.	2.57	3.08	2.45	15.09	0	211	"
" 1	"	"	"	2.08	"	"	15.04	0	206	"
" 4	"	91.85	n.d.	3.00	2.57	2.77	14.75	0	214	"
" 4	"	"	"	2.35	"	"	15.39	0	208	"
"	'81	92.7	n.d.	2.1	3.1	2.5	15.63	0	206	C.2
" 1	6.'82	92.68	0.1	2.08	3.08	2.45	15.63	0	206	C.4
" 4	"	91.87	0.1	2.35	2.57	2.77	15.39	0	208	"
"	11.'86	93.29	0.62	1.68	2.23	2.18	13.74	0	224*	C.22
COP-I	'81	94.0	0.3	2.0	1.2	2.5	14.37	0	218	C.2
" (No. 1)	6.'82	94.02	0.24	1.89	1.03	2.53	14.81	0	214	C.4
" (No. 2)	"	93.62	0.15	1.92	1.53	2.43	15.34	0	209	"
" (No. 3)	"	93.35	0.17	1.87	1.30	3.01	15.42	0	208	"
" (No. 4)	"	93.72	0.16	2.01	0.9	2.96	15.31	0	209	"
" (No. 5)	"	92.31	0.15	1.89	2.5	2.76	15.45	0	208	"
" (No. 6)	"	91.97	0.14	1.92	2.81	2.55	15.42	0	208	"
" (No. 7)	"	93.63	0.28	2.62	1.81	1.63	13.37	0	228	"
Pozo Copahue 1	11.'86	93.7	0.51	1.6	2.45	1.7	13.92	0	223*	C.22
" 2	"	94.2	0.80	1.2	2.6	1.2	13.79	0	224*	C.22
COP-I steam	6.'91	90.49	0.76	2.98	2.44	3.27	12.24	0	240*	JICA
COP-3 steam	"	95.79	0.39	0.93	2.35	0.52	14.72	0	215*	JICA
"	"	"	0.45	"	"	"	"	"	"	CREGEN

* : Calculated by JICA

Table 5-5 Isotope Analysis of Meteoric Water and Geothermal Fluid

No.	Sample No.	Date	Temp °C	Type of Sample	EL. of Sampling Point m	$\delta^{18}\text{O}$ ‰	δD ‰	^3H TU	No. of Collected Data
I-1	COP-I	2.82		Vapor (COP-I)	2,000	-10.5	-84.0		C 18
I-2	COPA-2	2.85	242	"	"	-9.6	-82.7	0.6 ± 0.7	"
I-3	COP-I	11.86		"	"	-8.2	-74 -76		"
I-4	COP-II	2.85		Vapor (COP-II)		-10.8	-85		
I-5	COP-II	11.86		"		-7.7	-80 -83		
I-6	COPA-1	2.85	130	Vapor (MAT)		-10.8	-84.2	0.8 ± 0.7	C 18
I-7	COPA-3	"	85	Vapor (MA)		-10.6	-85.1	0.0 ± 0.6	"
I-8	COPA-20	"		Vapor (COP)	2,010	-12.8	-90.2		"
I-9	COPA-5	"	61	Hot spring	2,020	-11.9	-84.2	2.5 ± 0.7	"
I-10	COPA-6	"	51.5	"	2,020	-11.9	-84.3		"
I-11	COPA-4	"	51	"	2,020	-11.9	-84.7	1.7 ± 0.7	"
I-12	COPA-7	"	34	"	2,010	-12.0	-84.3	3.3 ± 0.7	"
I-13	COPA-9	"	26	"		-12.2	-83.3		"
I-14	CAVI-4	"	12	River	1,670	-11.3	-81.9	3.6 ± 0.5	"
I-15	COPA-8	"		"	2,040	-11.8	-84.3	2.4 ± 0.7	"
I-16	COPA-12	"		Spring	2,310	-11.9	-84.6	3.6 ± 0.7	"
I-17	CAVI-1	"	13	Spring water for drinking		-11.5	-81.7	3.9 ± 0.4	"
I-18	VAF-1	4.85	8	Spring	2,050	-12.5	-90.1	4.8 ± 0.7	"
I-19	CAVI-3	2.85	10	River	1,420	-12.9	-92.5	4.5 ± 0.4	"
I-20	VAF-2	4.85	7	Spring	1,820	-13.5	-97.2	1.8 ± 0.4	"
I-21	CAVI-2	2.85	10	"	1,660	-12.9	-93.5	3.2 ± 0.7	"
I-22	VAF-3	4.85	11	"	1,674	-13.6	-94.6	1.8 ± 0.7	"
I-23		6.91		Vapor (COP-1)	2,000	-11.5	-100.1		JICA
I-24		6.91		Vapor (COP-3)	2,011	-9.4	-85.3	< 0.3	"
I-25		6.91		Hot water (")	2,011	-4.3	-62.4		"

Table 5-6 Quantity of Geochemical Survey in Wells

Well name	Analysis Item	Sampling Date
COP-1	Gas Vapor Ratio	13 JUNE 1991
	Chemical Composition of Gas	13 JUNE 1991
	Chemical Composition of Condensate Water	13 JUNE 1991
COP-3	Gas Vapor Ratio	11 & 15 JUNE 1991
	Chemical Composition of Gas	11 JUNE 1991
	Chemical Composition of Condensate	9-14 JUNE 1991
	Chemical Composition of Hot Water	15 JUNE 1991

Table 5-7 Chemical Analysis of Geothermal Fluid from COP-1 and COP-3 Wells

Well	Sampling Date	Gas Vapor Ratio (Volume%)	Chemical Composition			
			Gas (Volume%)		Vapor (mg/l)	
COP-1	June 1991	Gas 5.28	Gas 91.25	CO ₂	90.49	
				H ₂ S	0.76	
		Residual Gas 8.75	Ar	0.05 *		
			CH ₄	3.27		
			H ₂	2.98		
			He	0.00		
			N ₂	2.44		
		Vapor 94.72	pH	5.6		
			EC	470 (μs/cm)		
			TSM	24 (mg/l)		
			Na ⁺	0.23	Cl ⁻	11
			K ⁺	0.1	SO ₄ ²⁻	13
			Ca ²⁺	0.58	HCO ₃ ³⁻	90
			Mg ²⁺	0.05	CO ₃ ²⁻	0
			B	<0.1		
			NH ₄ ⁺	<0.1		
COP-3	June 1991	Gas 5.0 **	Gas 96.18	CO ₂	95.79	
				H ₂ S	0.39 ***	
		Residual Gas 3.82	Ar	0.02		
			CH ₄	0.52		
			H ₂	0.93		
			He	0.00		
			N ₂	2.35		
		Vapor 95.0 **	pH	5.8		
			EC	830 (μs/cm)		
			TSM	17 (mg/l)		
			Na ⁺	0.31	Cl ⁻	18
			K ⁺	0.1	SO ₄ ²⁻	11
			Ca ²⁺	0.21	HCO ₃ ³⁻	83
			Mg ²⁺	0.01	CO ₃ ²⁻	0
			B	1		
			NH ₄ ⁺	21		

* Air contamination is high percentage.

** Average of 10times mesuring.

*** CRBGEN's value is 0.45%.

Table 5-8 Chemical Analysis of Hot Water from COP-3 Well

Sampling Date	Chemical Composition (mg/l)					
June, 1991	pH	7.7				
	EC	300 ($\mu\text{S}/\text{cm}$)				
	TSM	150 (mg/ℓ)				
	Na ⁺	3.1	T-Fe	0.81	F ⁻	1.0
	K ⁺	0.9			T-Hg	0.02
	Ca ²⁺	2.1	Cl ⁻	2.2	H ₂ S	<1
	Mg ²⁺	0.16	SO ₄ ²⁻	11	As ³⁺	0.15
	B	40	HCO ₃ ³⁻	178		
	NH ₄ ⁺	<0.8	CO ₃ ²⁻	0.5		
	Mn ²⁺	<0.2	Br ⁻	<0.5		
Li	<0.1	I ⁻	<0.1			

Table 5-9 Isotope Analysis of Geothermal Fluid from COP-1 and COP-3

Loc.		δD (‰)	$\delta^{18}O$ in H ₂ O (‰)	$^{13}C/^{12}C$ in CO ₂ (‰)	$^{34}S/^{32}S$ (‰)	3H (TU)
COP-1	Condensate	-100.1	-11.5	-8.9	+ 3.6	-
COP-3	Condensate	- 85.3	- 9.4	-9.3	- 3.6	<0.3
COP-3	Hot Water	- 62.4	- 4.3 *	-14.1	+12.3	-

* $\delta^{18}O$ value in SO₄ is not measured for it's low content

Table 5-10 Results of X-ray Analysis on COP-1 and -2

Well No.	Depth	Lm	Wa	Mo	Ch/Mo	Se/Mo	Ch	Se	Ka	Cc	Qz	Pl	K-f	Pr	Ep	Hem	Remarks	
COP-1	130m			1								3	1			1	Cuttings	
	230m			1								3				1	"	
	360m			1						1		3					"	
	458-463m			1	1	1	1			1	3	3				1	Core	
	541m			1	1		1					3	3			1	Cuttings	
	630-631m	1			1	1				1	2	3				1	Core	
	720m			1	1							1	3				Cuttings	
	801m		?	1			1	1		1	3	3						"
	930m		?				1			1	1	3	2	1				Core
COP-2	415m			1	1		2			1	3	3						Cuttings
	602m			1	1		1			1	3	3						"
	643m		2	1			1	1	1		3	3		1	1			"
	844m						2				3	3		?	1			"
	883m						2				3	3		?	1			"
	970m						1				3	3			3			"
	1030m						2				3	3		2	2			"
	1160m			1			2			?	3	3			1			"
	1205m			1			1				3	3		?	1			"

Abbreviation Lm: Laumontite, Wa: Wairakite, Mo: Montmorillonite
 Ch/Mo: Chlorite/Montmorillonite mixed-layer mineral, Se/Mo:
 Sericite/Montmorillonite mixed-layer mineral, Ch: Chlorite, Se:
 Sericite, Ka: Kaorinite, Cc: Calcite, Qz: Quartz, Pl: Plagioclase,
 K-f: K-feldspar, Pr: Prehnite, Ep: Epidote, Hem: Hematite

Number in this table means a relative intensity of detected minerals (3 > 2 > 1).

Specimens of COP-2 between 844 m and 1205 m were not able to be analyzed by the oriented X-ray analysis because of the scarcity of specimens.

Table 5-11 Characteristics of Alternative Location of COP-3

Item	Site	A	B	C
1. Geology	<ul style="list-style-type: none"> ◦ Structure ◦ Formation ◦ Fault and Lineament 	<p>Graben/Horst Las Mellizas F./Hualcupen F. WNW-ESE; Predominant continuous fault NW-SE ; Lineament</p>	<p>Horst Las Mellizas F./Hualcupen F. NW-SE ; Reverse fault ENE-WSW; Lineament</p>	<p>Horst Las Mellizas F./Hualcupen F. NE-SW; Concentrated Parallel fault system</p>
2. Gravity Prospecting	<ul style="list-style-type: none"> ◦ Bouguer Anomaly ◦ Depth of Gravity Basement 	<p>High anomaly area About 1,600 m</p>	<p>High anomaly area About 1,600 m</p>	<p>High anomaly area About 1,600 m</p>
3. Temperature Gradient of Shallow Zone	<ul style="list-style-type: none"> ◦ Temperature Gradient of Shallow Zone 	<p>High</p>	<p>High</p>	<p>High</p>
4. Electrical Prospecting	<ul style="list-style-type: none"> ◦ Depth to Top of High Resistivity Basement ◦ Deep Low Resistivity Layer and Depth ◦ Electrical Fault 	<p>About 650 m</p> <p>Detect (Measurement Point D-I) About 1,800 m Between No. 65/66 and No. 39 (concordant with geology)</p>	<p>About 750 m</p> <p>Detect (Measurement Point D-II) About 1,800 m None</p>	<p>About 400 m</p> <p>No detect (Measurement Point D-14) None</p>
5. Geochemical Survey	<ul style="list-style-type: none"> ◦ Temperature from Geothermometer 	<p>205 - 230°C</p>	<p>205 - 230°C</p>	<p>205 - 230°C</p>
6. Topography	<ul style="list-style-type: none"> ◦ Accessibility ◦ Altitude 	<p>Good About 2,010 m</p>	<p>Good About 2,040 m</p>	<p>Bad About 2,090 m</p>
7. Distance from the Site to Manifestation	<ul style="list-style-type: none"> ◦ Distance from the Site to Manifestation 	<p>2.2 km (to Copahue) 2.2 km (to Maquinas)</p>	<p>0.6 km (to Maquinas) 1.8 km (to Copahue)</p>	<p>1.2 km (to Copahue)</p>

Table 5-12 Result of Microscopic Observation for COP-3

(Observation : Lic. Ana María Casé)

PROF. No	GRADO DE ALTER.	ROCA	TEXTURA	MINERALES FORMADORES DE ROCA						MINERALES DE ALTERACION															
				Qz	Pl	Bi	Au	Hy	Ho	Qz	M	Ch	Se	Ch/M	Ka	Cc	Ep	Pr	Ap	Ga	Ze	Wa	Ac	Le	Py
* 10 ^m	2	LAVA ANDESITICA			4		1	1			1		1						1		1			2	1
* 50	3	LAVA ANDESITICA			4		1	1			1		1		3		1		1						2
* 80	4	TOBA ANDESITICA		1	4						1		4		1	1								2	
* 110	4	LAVA BRECHADA			3								4			1	1					1		2	1
* 160	4	TOBA		2	3						1		3		1		1		1				3	1	
* 210	3	ANDESITA		1	3		1						2		2		2		1					2	
* 290	3	ANDESITA			3		2						3	1		1	2							2	2
293.3	5	LAVA BRECHADA	IRRECONOCIBLE								3		2		1-2		2		1				3	1	
* 350	1	ANDESITA			3	1	2						1			1			1					1	
* 430	1 - 2	ANDESITA			3		2				1				1										
* 490	4	TOBA										4	2		2	2	2							2	
* 528	1	BASALTO			3	1		2									1							1	
* 560	2	ANDESITA			3		1	1	2		1	1	2	2	2	1			1				1	1	
* 670	4	TOBA		2	2								2	1		3	2	1						2	
* 710	3	ANDESITA			3						1		3				2							2	2
* 740	4	TOBA ANDESITICA		1	3								3				2	2						2	2
801.7	3	ANDESITA			3						1		3				1	2	1					2	1
* 811	3	ANDESITA			3						2		3			2		2	2					2	1
* 819	4	ANDESITA			3						2		3				2	2	1			1		2	
824.7	3	LAVA ANDESITICA		3	3								3				2							2	
* 838	4	ANDESITA									2	3	3				2	1					1	2	1
862.2	4	ANDESITA			4								2				2	3	1				1	3	2
882.1	3	ANDESITA			4						1		2		3		2	1						3	
956.8	3	ANDESITA	PORF. PASTA: INTERSERTAL		4						1		2				2							2	
1002.9	3	BRECHA		4	1						3		1				2	1				2	3	2	
1015.0	3	ANDESITA	PORFIRICA		4						1		3		1		2	2				1		1	
1022.2	3	AND. QZOSA	PORF. PASTA: HIPIDIOM GRANU	1	4						1		2				2	1		?			1	2	
1035.0	2	AND. QZOSA	INTERSERTAL	1	4	1	1						2				2						1	1	
1045.86	2 - 3	AND. QZOSA	INTERSERTAL	1	4		1						2				1			1			1	1	
1055.35	1 - 2	AND. QZOSA	INTERSERTAL	1	4	1	1						2				2							1	
1064.26	2 - 3	AND. QZOSA	INTERSERTAL	1	4		1						2				2							1	

* : CUTTING

Table 5-12 Result of Microscopic Observation for COP-3 (continued)

(Observation : JICA)

PROF. No	GRADO DE ALTER.	ROCA	TEXTURA	MINERALES FORMADORES DE ROCA							MINERALES DE ALTERACION													
				Qz	Pl	Bi	Au	Ol	Ho	Op	Qz	M	Ch	Ch/M	Se/M	Ka	Cc	Ep	Pr	Ga	Wa	Ac	Le	Py
293.2 ^m	4	TOBA	CLASTICO	4	?						1	2	3		2	2	3							1
528.8	2	BASALTO	PORFIRITICA		4/4	1	?/4			1/2	1		1				3/2							
783.0	2	OLIVINA BASALTO	PORFIRITICA		4/4		?/2	4/?		1/3	1	4/4												
1005.9	3-4	ANDESITA ALTERADA	PORFIRITICA		3/3		?		?	?	2		2/3					1/1			1		2	
1020.6	3-4	ANDESITA ALTERADA	PORFIRITICA		3/3		?		?	(1)/(1)	3		2/2					2/1	2				1/1	
1027.7	3	ANDESITA ALTERADA	PORFIRITICA		4/3		?		?	?	2		3				1	1/1	1/1				1	
1030.6	3	PORFIDO ALTERADA	HOLOCRI TALINO	1	4		2		?	(1)			3	2			1	1	1				1	1
1040.5	3	PORFIDO ALTERADA	HOLOCRI TALINO	1	4		2		?	1			2	2				1		1			1	1
1053.1	3	PORFIDO ALTERADA	HOLOCRI TALINO	1	4		2		?	1			1	3				1		1			2	1
1064.3	3	PORFIDO ALTERADA	HOLOCRI TALINO	1	4		2		?	1			2	2			1	1		1			1	1

GRADO DE ALTERACION

1 : FRESCO

1

5 : FUERTE

CANTIDAD DE MINERALES

1 : POCO

1

5 : MUCHO

PORFIDOBLASTO/PASTA

2/

3

MINERALES FORMADORES DE ROCA

Qz : CUARZO

Pl : PLAGIOCLSA

Bi : BIOTITA

Au : AUGITA

Hy : HIPERSTENO

Ol : OLIVINA

Ho : HORNBLENDA

Op : OPACO

MINERALES DE ALTERACION

Qz : CUARZO

M : MONTMORILLONITA

Ch : CLORITA

Se : SERICITA

Ch/M : CLORITA/MONTMORILLONITA

Se/M : SERICITA/MONTMORILLONITA

Ka : CAOLINITA

Ap : APATITA

Cc : CALCITA

Ep : EPIDOTO

Pr : PREHNITA

Ga : GRANATE

Ze : CEOLITA

Wa : WAIKAKITA

Ac : ACTINOLITA

Le : LEUCOXINO

Py : PIRITA

Table 5-13 Result of X-ray Analysis of COP-3

Depth	Sample	Sillbite	Laumontite	Wairakite	Montmorillonite	Chlorite/Mont	Chlorite	Sericite/Mont	Sericite	Kaolinite	Pyrophyllite	Calcite	Quartz	Plagioclase	K-feldspar	Prehnite	Epidote	Garnet	Pyrite	Pyroxene	Amphibole
20 m	BULK	2?			4	2						9	18	4	3		2?		3		
	ORIENT	?			○							⊙	⊙	⊙	•				○		
	E. G.	?			○																
	HCL																				
50 m	BULK				2							3	15	21	3		3?		3		
	ORIENT				•							○	⊙	⊙	○		•				
	E. G.				•																
	HCL				•																
80 m	BULK				4	4						5	14	18			3?				
	ORIENT				•	•						○	⊙	⊙							
	E. G.				•	•															
	HCL				•	•															
120 m	BULK				3	3						6	21	7	3						
	ORIENT				•	•						○	⊙	○	•						
	E. G.				•	•															
	HCL				•	•															
170 m	BULK				2	3						5	23	22	3				2		
	ORIENT				•	•						○	⊙	⊙	•				•		
	E. G.				•	•															
	HCL				•	•															
200 m	BULK				3	3				3?		6	18	15							
	ORIENT				•	•						○	○	⊙							
	E. G.				•	•															
	HCL				•	•															
250 m	BULK					3	3			3?		5	12	10			2?				
	ORIENT					○	○					○	⊙	⊙							
	E. G.				•	•															
	HCL																				
280 m	BULK				3	○	3			3		10	13	5					2		
	ORIENT				○	○				•		⊙	⊙	○					•		
	E. G.				○		•			•											
	HCL				○		•			•											
294.2 m	BULK						3			4		5	10	9			•				
	ORIENT						○			○		○	⊙	⊙							
	E. G.						○	•		○											
	HCL						•			○											

Figure of Bulk : Quartz Index

- ⊙ : Large Volume
- : Medium Volume
- : Small Volume

Analyzed by Dra. Graciela Mas

Table 5-13 Result of X-ray Analysis of COP-3 (continued)

Depth	Sample	Stibite	Lamontite	Wairakite	Monmorillonite	Chlorite/Mont	Chlorite	Sericite/Mont	Sericite	Kaolinite	Pyrophyllite	Calcite	Quartz	Plagioclase	K-feldspar	Prehnite	Epidote	Carnat	Pyrite	Pyroxene	Amphibole
320 m	BULK					3				3		5	9	12			2?				
	ORIENT					.				.		○	⊙	⊙							
	E. G.				.	.				.											
	HCL									.											
350 m	BULK											4	3	15			.				
	ORIENT												○	⊙			○				
	E. G.																				
	HCL																				
400 m	BULK					3	3			?		8	12	6							
	ORIENT					○	○					⊙	⊙	⊙							
	E. G.														
	HCL														
420 m	BULK					3	3			?		4	9	11			2?				
	ORIENT					○	⊙							
	E. G.														
	HCL														
450 m	BULK					3		2		3		10	20	4						2	
	ORIENT					.		.		.		○	⊙	.					.		
	E. G.														
	HCL														
480 m	BULK					3		2		3		10	25	9	3						
	ORIENT					.		.		.		○	⊙	○							
	E. G.					.		.		○											
	HCL					.		.		○											
528 m	BULK				3	?		2		3		30	10	2						4	
	ORIENT					⊙	○	.					.		
	E. G.														
	HCL														
560 m	BULK				3			2		3		3	6	17						2	
	ORIENT				○	⊙					.		
	E. G.				.			.		.											
	HCL				.			.		.											
600 m	BULK				3					2		6	8	12						2	
	ORIENT				.			.		.		○	○	⊙					.		
	E. G.				.			.		.											
	HCL				.			.		.											

Figure of Bulk : Quartz Index

- ⊙ : Large Volume
- : Medium Volume
- : Small Volume

Analyzed by Dra. Graciela Mas

Table 5-13 Result of X-ray Analysis of COP-3 (continued)

Depth	Sample	Stibite	Laumontite	Wairakite	Montmorillonite	Chlorite/Mont	Chlorite	Sericite/Mont	Sericite	Kaolinite	Pyrophyllite	Calcite	Quartz	Plagioclase	K-feldspar	Prehnite	Epidote	Garnet	Pyrite	Pyroxene	Amphibole
620 m	BULK					3		2	4			9	13	8					2		
	ORIENT					.			○			⊙	⊙						.		
	E.G.				.	.			.												
	HCL				.	?			.												
660 m	BULK			2?		2	2	4	9			12	7			2					
	ORIENT			?		.	.	○	⊙			⊙	○			.					
	E.G.					.	.	○													
	HCL					?		○													
720 m	BULK					4		3	6			9	10	3		2					
	ORIENT					○		○	⊙			⊙	⊙								
	E.G.					○		○													
	HCL					.		○													
760 m	BULK					3	2	4	9			10	9			3					
	ORIENT					.		○	⊙			⊙	⊙			.					
	E.G.					.		○													
	HCL					.		○													
785 m	BULK				3	3							22	8	3		3	3	3		2
	ORIENT				.	.							⊙	○
	E.G.				.	.															
	HCL				.																
789.4 m	BULK				4	3			3			11	8			3	3	3			2
	ORIENT				○	.			.			○	⊙			
	E.G.				○	.															
	HCL				.																
812 m	BULK					3		5	15			4	20			3					
	ORIENT					.		.	○			.	⊙			.					
	E.G.					.		.													
	HCL					.		.													
819.8 m	BULK					6		5				10	7	4	3	3					
	ORIENT					○		.				⊙	○	.		.					
	E.G.					○		.													
	HCL					.		.													
822 m	BULK					5		?				7	3		5	4					
	ORIENT					⊙						⊙	.		⊙	○					
	E.G.					⊙															
	HCL					○															

Figure of Bulk : Quartz Index

- ⊙ : Large Volume
- : Medium Volume
- : Small Volume

Analyzed by Dra. Graciela Mas

Table 5-13 Result of X-ray Analysis of COP-3 (continued)

Depth	Sample	Sillbite	Laumontite	Wairakite	Montmorillonite	Chlorite/Mont	Chlorite	Sericite/Mont	Sericite	Kaolinite	Pyrophyllite	Calcite	Quartz	Plagioclase	K-feldspar	Prehnite	Epidote	Garnet	Pyrite	Pyroxene	Amphibole	
m 827.8	BULK					4				?		11	5	13		2	3					
	ORIENT											⊙	○	⊙		•						
	E.G.																					
	HCL																					
m 854.5	BULK					4				3			26	12	3	2	2					
	ORIENT					○				•			⊙	⊙		•						
	E.G.					○				•												
	HCL					?				•												
m 866	BULK					5				4?		3	14	3	3	3	5					
	ORIENT					•						•	⊙	•	○							
	E.G.					•																
	HCL					•																
m 882	BULK					8							6	10	4		5					5
	ORIENT					○							○	⊙	•	•						•
	E.G.					○																
	HCL																					
m 966	BULK		2			4		1					5	8	3	2	3					1
	ORIENT					○							○	⊙	○	○	○					
	E.G.					○																
	HCL																					
m 1002	BULK		2			2		1					12	6	3	2	2					
	ORIENT		•			•							⊙	○	○	•	•					
	E.G.					•																
	HCL																					
m 1015	BULK					2		1					9	7		3	8					1
	ORIENT					○							⊙	⊙		○						•
	E.G.					○																
	HCL																					
m 1022	BULK		2			4				2?			3	6	2	3	4					
	ORIENT		○			○				?			○	⊙	○	○	○					
	E.G.					○																
	HCL									?												
m 1034	BULK	1			2	2		2		2?		2	5	9	2	2	2					2
	ORIENT				•	•						•	○	⊙	•	•						•
	E.G.				•	•																
	HCL																					

Figure of Bulk : Quartz Index

- ⊙ : Large Volume
- : Medium Volume
- : Small Volume

Analyzed by Dra. Graciela Mas

Table 5-13 Result of X-ray Analysis of COP-3 (continued)

Depth	Sample	Stibite	Laumontite	Wairakite	Montmorillonite	Chlorite/Mont	Chlorite	Sericite/Mont	Sericite	Kaolinite	Pyrophyllite	Calcite	Quartz	Plagioclase	K-feldspar	Prehnite	Epidote	Garnet	Pyrite	Pyroxene	Amphibole
1045	BULK		2			2	2	1			1?	2	7	14	4		3				2
	ORIENT					.	.					.	○	○			.				.
	E.G.					.	.														
	HCL																				
1055	BULK					2	2					2	7	11		2	2				1
	ORIENT					.	.					.	○	○							.
	E.G.					.	.														
	HCL																				
1064	BULK					2	2	1				2	5	12	4	2	2				2
	ORIENT					.	.					.	○	○		.					.
	E.G.					○	.														
	HCL																				
	BULK																				
	ORIENT																				
	E.G.																				
	HCL																				
	BULK																				
	ORIENT																				
	E.G.																				
	HCL																				
	BULK																				
	ORIENT																				
	E.G.																				
	HCL																				
	BULK																				
	ORIENT																				
	E.G.																				
	HCL																				

Figure of Bulk : Quartz Index

- ◎ : Large Volume
- : Medium volume
- : Small Volume

Analyzed by Dra. Graciela Mas

Table 5-13 Result of X-ray Analysis of COP-3 (continued)

Depth	Sample	Stibite	Lamprophile	Wairakite	Montmorillonite	Chlorite/Mont	Chlorite	Sericite/Mont	Sericite	Kaolinite	Pyrophyllite	Calcite	Quartz	Plagioclase	K-feldspar	Prehnite	Epidote	Garnet	Pyrite	Pyroxene	Amphibole	
293.2	BULK				2	4	?			2		22	27	4						1		
	ORIENT				⊙	⊙	•			⊙		•	•	•								
	E. G.				○	○	•			○												
	HCL				⊙		•			○												
529.2	BULK					?	8					3	25	10					<1	1?		
	ORIENT					•	⊙					•	•	•								
	E. G.					•	○															
	HCL																					
866.0	BULK				?	?	9						11			3	1		<1	?	?	
	ORIENT				•	•	⊙														?	?
	E. G.				•	•	⊙														?	
	HCL				•																?	
1005.9	BULK			<1			1						8	8					<1			<1
	ORIENT						○						•	•								
	E. G.						○															
	HCL																					
1020.6	BULK						<1						12	8	3	1			<1		?	
	ORIENT						○						•	•	•						•	
	E. G.						•														•	
	HCL																				•	
1027.7	BULK						2						7	9	2				<1		?	1
	ORIENT						○						•	•							•	
	E. G.						○														•	
	HCL																				•	
1030.6	BULK					1	2						8	15					<1		1	<1
	ORIENT					•	⊙						•	•							•	
	E. G.					•	○														•	
	HCL																				•	
1040.5	BULK												5	14					<1		1	<1
	ORIENT					○	○						•	•							•	
	E. G.					•	•														•	
	HCL																				•	
1053.1	BULK					<1	<1						5	15					<1		1	<1
	ORIENT					○	•						•	•							•	
	E. G.					•	•														•	
	HCL																				•	

Figure of Bulk : Quartz Index

- ⊙ : Large Volume
- : Medium volume
- : Small Volume

Analyzed by JICA

Table 5-13 Result of X-ray Analysis of COP-3 (continued)

Depth	Sample	Stibite	Lamontite	Wairakite	Montmorillonite	Chlorite/Mont	Chlorite	Sericite/Mont	Sericite	Kaolinite	Pyrophyllite	Calcite	Quartz	Plagioclase	K-feldspar	Premite	Epidote	Garnet	Pyrite	Pyroxene	Amphibole	
																						1
1064.3	BULK												5	14					<1		1	<1
	ORIENT					⊙	○						•	•								•
	E.G.					○	•															•
	HCL																					•
	BULK																					
	ORIENT																					
	E.G.																					
	HCL																					
	BULK																					
	ORIENT																					
	E.G.																					
	HCL																					
	BULK																					
	ORIENT																					
	E.G.																					
	HCL																					
	BULK																					
	ORIENT																					
	E.G.																					
	HCL																					
	BULK																					
	ORIENT																					
	E.G.																					
	HCL																					
	BULK																					
	ORIENT																					
	E.G.																					
	HCL																					

Figure of Bulk : Quartz Index

- ⊙ : Large Volume
- : Medium volume
- : Small Volume

Analyzed by JICA

Table 5-14 Physical Properties of Cores of COP-3

Depth	γ_s	γ_d	Gs	ϕ	Rock Type
293.1m	2.40	2.237	2.674	16.35%	Altered Lapilli Tuff
293.2m	2.387	2.212	2.608	17.46%	Altered Lapilli Tuff
528.7m	2.778	2.772	2.788	0.60%	Basaltic Andesite
528.8m	2.770	2.746	2.813	2.40%	Basaltic Andesite
794.4m	2.735	2.697	2.803	3.76%	Basaltic Andesite
810.6m	1.976	1.815	2.164	16.11%	Basaltic Andesite (Fractured Zone)
821.7m	2.701	2.653	2.786	4.76%	Altered Lava
848.7m	2.521	2.425	2.684	9.66%	Altered Tuff Breccir
848.8m	2.524	2.387	2.766	13.69%	Altered Tuff Breccir
882.0m	2.525	2.446	2.655	7.85%	Altered Lava
1011.6m	2.68	2.64	2.76	4.3 %	Andesite Lava
1059.8m	3.50	3.45	3.62	4.8 %	Porphyrite

- γ_s : Bulk specific gravity (saturated-surface-dry) = $B/(B-C)$
 γ_d : Bulk specific gravity (Dry) = $A/(B-C)$
 Gs: Apparent specific gravity (Particle density) = $A/(A-C)$
 ϕ : Effective porosity = $(B-A)/(B-C) \times 100$

Here A: Weight of oven-dry sample in air (g)
 B: Weight of saturated-surface-dry sample in air (g)
 C: Weight of saturated sample in water (g)

Table 5-15 Homogenization Temperature of Fluid Inclusion of COP-3

Depth	Homogenization Temperature (°C) by Dra. G. MAS							
180 ^m Quartz	251.6P	282.5P	311.5P	369.9P	367.8P	328.5P	303.0P	382.5G
	213.9S	229.1S	207.0S	320.3P	209.0S	217.4S	223.2S	216.8S
	237.4S	238.8S	238.0S	272.7P	225.3S	226.7S		
210 Quartz	226.6S	216.7S	212.1S	224.7S	287.9P	247.4P	210.7S	212.5S
	216.7S	283.9P	282.3P	228.6S	271.6P	212.8S	207.1S	209.3S
	208.5S	239.3S	230.5S	260.7P	219.3S	218.9S	213.0S	210.6S
	220.8S	230.0S	280.7P	216.7S	213.2S	215.4S	209.5S	211.8S
320 Quartz	265.7P	222.9S	237.5S	233.4S	253.4S	254.1S	252.4S	236.6S
	317.5P	228.7S	246.6S	318.3P	315.2P	339.2P	325.1P	326.0P
	259.4S	238.4S	244.3S	221.6S	245.0S	242.1S	220.7S	227.0S
	238.4S	239.3S	238.2S					
528 Calcite	209.1S	192.4S	216.8S	212.5S	219.0S	209.6S	227.3S	201.4S
	215.6S	178.2S	192.4S	187.7S	181.3S	196.4S	223.6S	213.8S
	246.3S	162.6S						
801 Quartz	257.0S	276.9S	278.9S	280.4S	294.5C	274.4C	276.0C	303.0P
	264.0S	261.2S	265.1S	266.7S	264.9S	291.4S	287.0S	277.3S
	301.5P	285.7P	260.1S	261.5S	265.4S	245.4S	252.9S	260.5S
	308.5P	301.9P	296.9S					
806 * Quartz	252.9S	285.9P	289.1P	251.3S	251.5S	246.3S	248.4S	252.1C
	260.8C	254.1C	274.9P	287.1P	241.8S	252.3S	259.9S	260.9S
854.2 Quartz	307.1P	245.6S	238.5S	242.4S	245.3S	273.6C	263.5C	259.5C
	260.8C	279.8P	258.9C	261.3C	263.4C	262.2C	303.4P	261.0S
	258.8S	257.6S	287.2C	271.5P	251.8C	260.7C	258.4C	261.1C
882 Calcite	269.0T	275.4T	264.9T	270.9T	268.4T	269.6T	274.5T	269.1T
	283.1T	259.6T	268.9T	263.8T	260.2T	262.0T	260.4T	265.9T
	265.3T	266.1T	282.3T	262.1T	269.6T	259.7T	268.3T	265.4T

P : Primary Inclusion C : Cluster
S : Secondary Inclusion T : Trail or Cluster
G : Gaseous Inclusion
* : Gaseous inclusions in the sample are available.

Table 5-15 Homogenization Temperature of Fluid Inclusion of COP-3 (continued)

Depth	Homogenization Temperature (°C) by Dra. G. MAS							
1009 m Quartz	258.9	268.5	248.0	266.7	270.7	286.2	278.1	258.4
	266.4	257.8	254.1	262.0	268.8	271.3	253.0	268.3
	287.3	285.6	279.5	297.7	299.5	248.9	253.5	256.8
1013 * m Quartz	251.3	252.4	256.5	261.3	257.1	259.5	255.1	252.3
	260.2	254.5	255.7	248.5	254.1	262.3	256.4	251.6
	256.5	262.5						
Depth	Homogenization Temperature (°C) by JICA							
801.8 m Quartz	283.0	281.0	243.0	270.0	243.0	244.0	304.0	275.0
	311.0	329.0	339.0	304.0	296.0	342.0	343.0	344.0
	349.0	330.0	263.0	251.0	281.0	283.0	259.0	276.0
	309.0	312.0	282.0	309.0	257.0	293.0		
813.0 m Quartz	243.0	243.0	242.0	265.0	252.0	252.0	262.0	237.0
	273.0	279.0	240.0	239.0	246.0	242.0	238.0	241.0
	242.0	239.0	243.0	273.0	266.0	272.0	243.0	274.0
	243.0	281.0	281.0	244.0	280.0			

All inclusions in the samples of 1,009 and 1,013 m are primary or pseudosecondary.

* : Gaseous inclusions in the sample are available.

Table 5-16 Pressure and Temperature Values Measured at Feed Zone for COP-3

Depth of Feed Zone	Pressure (Measured Depth)	Temperature	Remarks
1010m	kg/cm ² G		Measured Date
	38.13 (at 1000m)	236.9°C (at 1000m)	31/05/91 (ST=391hr)
		241.7°C (at 1000m)	12/06/91 (flowing temp.)
	38.156* (at 1010m)		31/05/91 (ST=391hr)

*: Estimated pressure calculated by pressure gradient between 900m and 1000m

Table 5-17 Parameters in calculation of reserve for confirmed area

<u>Parameter</u>	<u>Unit</u>	<u>Type of Probability (or fixed)</u>	<u>Minimum Value</u>	<u>Maximum Value</u>	<u>Most Likely Value</u>
areal extent	km ²	fixed	—	—	4
thickness	m	triangular	6 0 0	1 2 0 0	9 0 0
temperature	°C	triangular	2 3 0	2 5 0	2 4 0
porosity		uniform	0 . 0 4	0 . 1	—
water saturation		uniform	0 . 3	0 . 5	—
recovery factor		uniform	0 . 0 4	0 . 1 5	—
volumetric specific heat of rock	kJ/m ³ °C	fixed	—	—	2 3 6 0
rejection temperature	°C	fixed	—	—	1 0
utilization factor		fixed	—	—	0 . 6
power plant load factor		fixed	—	—	0 . 8 5
power plant life	years	fixed	—	—	3 0

Table 5-18 Parameters in calculation of reserve for whole area

<u>Parameter</u>	<u>Unit</u>	<u>Type of Probability (or fixed)</u>	<u>Minimum Value</u>	<u>Maximum Value</u>	<u>Most Likely Value</u>
areal extent	km ²	uniform	1 1	1 3	—
thickness	m	triangular	6 0 0	1 2 0 0	9 0 0
temperature	°C	uniform	2 3 0	2 5 0	—
porosity		uniform	0 . 0 4	0 . 1	—
water saturation		uniform	0 . 3	0 . 5	—
recovery factor		uniform	0 . 0 4	0 . 1 5	—
volumetric specific heat of rock	KJ/m ³ °C	fixed	—	—	2 3 6 0
rejection temperature	°C	fixed	—	—	1 0
utilization factor		fixed	—	—	0 . 6
power plant load factor		fixed	—	—	0 . 8 5
power plant life	years	fixed	—	—	3 0

CHAPTER 6 PRELIMINARY DESIGN OF POWER PLANT

Chapter 6 PRELIMINARY DESIGN OF POWER PLANT

Contents

	<u>Page</u>
6.1 Design Conditions	6 - 1
6.1.1 Site Conditions	6 - 1
6.1.2 Selection of the Plant Site	6 - 1
6.1.3 Design Conditions and Fundamental Characteristics	6 - 2
6.1.4 Operating Conditions of Power Plant	6 - 2
6.1.5 Fundamental Characteristics of Power Plant	6 - 7
6.2 Preliminary Design of Power Plant	6 - 8
6.2.1 Basic Layout	6 - 8
6.2.2 Access Road and Land Reclamation	6 - 8
6.2.3 Production Well Drilling	6 - 9
6.2.4 Freshwater Intake Facilities	6 - 9
6.2.5 Steam Pipeline and Related Facilities	6 - 9
6.2.6 Turbine and Related Facilities	6 - 12
6.2.7 Electrical Equipment	6 - 15
6.2.8 Powerhouse and Related Buildings	6 - 16

List of Table

Table 6-1 Comparison Study of Power Plant Site

List of Figures

Fig. 6-1 Site Selection of Power Plant
Fig. 6-2 Well Characteristic
Fig. 6-3 Location Map of Power Plant
Fig. 6-4 (1) Plot Plan of Power Plant
Fig. 6-4 (2) Cross Section of Powerhouse
Fig. 6-4 (3) General Arrangement of 1st Floor
Fig. 6-4 (4) General Arrangement of 2nd Floor
Fig. 6-4 (5) General Arrangement of 3rd Floor
Fig. 6-5 Heat Balance

Chapter 6 PRELIMINARY DESIGN OF POWER PLANT

6.1 Design Conditions

6.1.1 Site Conditions

The Project site is located at an altitude of nearly 2,000 m in the Andes in the west of the Province of Neuquén close to the Argentine-Chilean border. It lies on a gently sloping mountainside where there is no inhabitation and no vegetation. The community nearest to the site is Copahue located about 2 km north. It is a summer resort and is almost abandoned during the winter months. Caviahue, located some 5 km southeast of the site, is the nearest community which is inhabited at all times.

The temperature is 20°C during the summer and -10°C during the winter and averages 7°C annually. Meteorologically, the site is characterized by strong west direction winds of 20 to 30 m/sec in speed which blow throughout the year. There lies a lake near the site and it is easy to obtain water from the lake. The annual rainfall is approximately 1,200 mm and there is snowfall of 3 to 4 m during the winter.

6.1.2 Selection of the Plant Site

The plant site needs to be selected by taking into account the following requirements.

- (1) It is favorable to select a plant site in a flat land to minimize excavation required for site reclamation, because there are many outcrops of rocks in the Project site.
- (2) The power plant is better to be located as close as possible to bases "A" and "B" of production wells to minimize the length of the pipeline.
- (3) The power plant is necessary to be in proximity to Lago Las Mellizas (2) from which water will be obtained, with the least practicable pumping head.

As shown in Fig. 6-1, three alternative sites are selected in the course of the field survey. The result of comparison is shown in Table 6-1. Overall evaluation taking into account the above requirements and other factors indicates that Alternative III is the most suitable site, followed by Alternatives II and I.

6.1.3 Design Conditions and Fundamental Characteristics

Output	:	30 MW x 1 unit
Production Well	:	1,200 m x 7 (directional drilling; well length 1,340 m)
No. of Well Bases	:	2
Well End Spacing	:	500 m or more
Well Diameter	:	Final diameter 8 in. Well head 12 in.
Properties of Steam	:	Steam-dominated type (saturated steam)
Gas Content of Steam	:	6% by weight (as CO ₂)
Well Characteristics	:	Fig. 6-2
Well Damping Factor	:	First 2 years 15% 3 - 5 years 8% 6 years and more 3%

6.1.4 Operating Conditions of Power Plant

The geothermal power plant is to be operated at a base load with a 85% utilization factor. The plant service ratio is estimated to be 6%. Therefore, the annual generated energy is to be 2.1×10^8 kWh. The plant operation is to be monitored constantly from the central control room. The operators are planned to be working on three shifts of 2 persons x 4 turns. Two operators are needed to be on duty at all times, but they will be assisted by day service personnel during plant startup and shutdown. The total plant staff is estimated to be 20 persons consisting of 8 operators and 12 maintenance/repair and control personnel.




Table 6-1 Comparison Study of Power Plant Site

Category	Alternative I	Alternative II	Alternative III
Location	East side of production well drilling base "A" (Site C)	Northeast side of production well drilling base "A" (Site B)	Southwest side of production well drilling base "B" (Site A)
Access Road	Passing the south side of Lago Mellizas (2) and approaching from the south side of the site.	Passing the south side of Lago Mellizas (2) and approaching from the south side of the site.	Approaching from the south side of the site through a road to Copahue village.
Transmission Line	Extended from the south side	Extended from the north side	Extended from the south side
Location of receiver	West side of the main building	West side of the main building	West side of the main building
Main building and cooling tower	Main building south side and cooling tower north side	Main building north side and cooling tower south side	Main building south side and cooling tower north side
Advantages	<ul style="list-style-type: none"> Plant water can be obtained from nearby Lago Mellizas (2) with little difference in level 	<ul style="list-style-type: none"> Plant water can be obtained from nearby Lago Mellizas (2) with little difference in level. 	<ul style="list-style-type: none"> Access road is shortest compared to other alternatives. Transmission line is shortest compared to other alternatives. Steam pipelines from bases "A" and "B" do not cross the access road.
Disadvantages	<ul style="list-style-type: none"> Located at the foot of the south slope to have snowdrift. Located in the path of west wind, subject to strong wind. Flood protection is required for a small river between Lagos Mellizas (1) and (2). Access road is relatively long, crossing a small river between Lagos Mellizas. 	<ul style="list-style-type: none"> Located at the foot of the south slope to have snowdrift. Located in the path of west wind, subject to strong wind. Access road is relatively long, crossing a small river between Lagos Mellizas (1) and (2). 	<ul style="list-style-type: none"> The maximum allowable load is needed to be checked for existing bridges to Copahue. The water intake point is relatively far from Lago Mellizas (2), requiring the pumping up of around 50 m.

Characteristics of Well

$P_r = 35 \text{ ata}$

$J = 3 \frac{1}{h} / \text{kg/cm}^2$




Fig. 6-2 Well Characteristics

6.1.5 Fundamental Characteristics of Power Plant

The geothermal power plant is planned to directly use saturated steam from steam dominated geothermal wells for operation of a condensing steam turbine.

The steam condenser is of direct contact type and uses a circulated mixture of condensed water cooled by a cooling tower as well as cooling water for cooling purposes. Surplus water in the cooling water system is to be returned to soil layers through reinjection wells.

Noncondensing gases (mostly CO₂) from the condenser is extracted from it by means of a vacuum pump and then released into the air from the cooling tower fan stack for diffusion. The generated power is boosted to 132 kV and then supplied to the EPEN power system.

6.2 Preliminary Design of Power Plant

6.2.1 Basic Layout

The power plant consists of the main building, cooling tower, switchyard, steam pipeline connecting production wells "A" and "B" with the power plant, and the freshwater intake and supply facilities. The layout is illustrated in Fig. 6-3. The power plant location and layout of the structures and equipment within the power plant yard have been determined with due consideration given to the topography and climatic conditions of the project area.

The power plant yard is 120 m long by 80 m wide. The layout of the major facilities in the power plant yard is as illustrated in Fig. 6-4. The main building is located in the center of the power plant yard and the cooling tower is installed parallel to the north side of the main building in consideration of the predominant wind direction. On the south of the main building is located a switchyard which transmits geothermal power to the Loncopue substation through a 132 kV transmission line. A parking house and a warehouse are also provided in the power plant yard.

6.2.2 Access Road and Land Reclamation

The power plant is to be located adjacent to the north side of the provincial road. The access road connects the provincial road with the power plant. For the construction of the power plant, an existing road leading to a point near production well site "A" is to be improved and used. A new access road to well site "B" is to be branched off from the power plant yard. It is planned to construct a new road about 4 m wide along the steam pipeline for the purpose of inspection and maintenance.

The plant site is located in flatland scattered with stones and the site reclamation is consisted mainly of excavation works for the purpose of securing adequate bearing capacity of the foundations for structures and equipment. The yard is to be reclaimed in such a way as to achieve the maximum possible balance between excavations and fills.

6.2.3 Production Well Drilling

Drilling of the steam production wells is to be undertaken in accordance with drilling plan including the location, depth, inclination and direction of the wells and the casing program, which is to be based on the results of exploratory works described in Chapter 11.

Drilling is to be carried out on a base system and seven wells are estimated to be necessary to be drilled in Bases "A" and "B". The average drilling depth is 1,200 m; average drilling length 1,340 m; maximum deviation distance 500 m; and well end spacing, 500 m or more.

6.2.4 Freshwater Intake Facilities

The pump is installed on the north shore of Lago Mellizas (2) to intake the water which is conveyed to the power plant through a pipeline. The water thus obtained is to be used primarily for cooling purposes and partly for drinking and other purposes.

Since a maximum snowfall of 4 m is anticipated at the Project site during the winter, the power plant building, switchyard, parking house, access road and other major facilities of the plant are planned to be provided with sprinklers for melting snow.

6.2.5 Steam Pipeline and Related Facilities

Two production well drilling bases are assumed. One base located at some 1,200 m southwest from the power plant is called Base "A", and the other at some 400 m east-northeast from the power plant is called Base "B". Four wells are planned to be drilled at Base "A" and three wells at Base "B". The minimum steam flow of each well averages 30 t/h and the maximum steam flow is 1.2 times larger (36 t/h).

Two pipelines each from the four wells at Base "A" are unified into two pipelines. Three wells at Base "B" are unified into one pipeline. The capacity of each pipeline is 60 to 72 t/h for Line "A" and 92 to 110 t/h for Line "B".

The well head pressure capable of providing the maximum output is nearly 9 ata when estimated from the well characteristics. Therefore, the preliminary plant design is based on a well head pressure around 9 ata. Assuming a pipeline diameter of 400 mm for all pipelines, the velocity is to be 32 to 38 m/sec for Line "A" and 50 to 60 m/sec for Line "B" and the pressure loss is calculated to be 1 to 1.4 kg/cm² for Line "A" and 0.9 to 1.2 kg/cm² for Line "B". Therefore, if the turbine inlet pressure is 8 ata, then the well head pressure is to be 8.9 to 9.4 ata.

An optimization check has been undertaken in respect of the pipeline diameter with the steam cost assumed to be 50,000 US\$/t/h. The check has revealed the following:

- If the pipeline diameter is 450 mm, pressure loss decreases with a resulting increase in the amount of steam obtainable, but this advantage is outweighed by an increase in the pipeline construction cost.
- If the pipeline diameter is 350 mm, the pipeline construction cost decrease, but this advantage is offset by increased pressure loss and a consequential reduction in the amount of steam generated.

The optimization study has revealed that the optimum pipeline diameter is 400 mm.

A line (1.200 m)						
D m	Cost 1 1,000\$	P.loss kg/cm ²	W.H.P. ata	Product t/h	Cost 2 1,000\$	Total 1,000\$
350	-59	2.1	10.1	61.0	+75	+16
400	Base	1.1	9.1	62.5	Base	Base
450	+61	0.7	8.7	62.8	-15	+46
B line (400 m)						
350	-20	1.7	9.7	90.6	+70	+50
400	Base	0.9	8.9	92.0	Base	Base
450	+20	0.6	8.6	92.3	-15	+5

A cyclone type separator is installed at each well head to prevent the intrusion of water and the eruption of rock powder and other solids. The maximum working pressure and the maximum working temperature are set at 12 kg/cm²g and 190°C, respectively, with a certain allowance.

Before the junction of main steam lines of each well a flowmeter and two selector valves are installed to permit changeover of main steam lines and air release pipes. A simple silencer is installed as necessary in the air release pipes to lower the noise level during the release of steam into the air.

The principal specifications of the steam pipelines and related equipment are as indicated below:

Route	Base "A" - P/S	Base "B" - P/S	Total
No. of Wells	4	3	7
No. of Trains	2	1	3
Capacity (t/h)	60-72 (x2)	92-110	220-260
Velocity (m/s)	32-38	54-64	-
Pressure Loss (kg/cm ²)	1-1.4	0.9-1.2	-
Well Head Pressure (ata)	9.0-9.4	8.9-9.2	-
Pipe Diameter (mm)	400	400	-
Pipe Length (m)	1,200 x 2	400	2,800
Separator (unit)	4	3	7
Silencer (unit)	4	3	7
Approx. Weight (t)	302	63	365

6.2.6 Turbine and Related Facilities

Basic Design

The optimum position for installing a turbine is selected on the basis of the data available and with some design changes predicted for the future.

Turbine Inlet Steam Pressure

On the basis of the characteristics of COP-3, a simulation study has been carried out in which the well diameter is changed to the diameter of a production well, a 10% reduction is assumed in the reservoir pressure, and a productivity index of 1/2 is assumed. Under these conditions, the maximum output point is found in the vicinity of the well head pressure of 9 ata. Accordingly, the value of 8 ata has been taken for the turbine inlet pressure with a pressure loss in the pipeline assumed to be 1 kg/cm².

Turbine Outlet Steam Pressure

From COP-1 and COP-2, it is assumed that the gas content of steam is 6% by weight. The maximum exhaust pressure is calculated as approximately 0.1 ata.

As a result, the value of 0.1 ata is taken for the turbine outlet steam pressure.

Attempts have been made to work out a minimum cost assuming a gross turbine output of 30,000 kW, taking the required amount of steam, vacuum pump installation cost and plant power requirement as variable factors, and with the exchange rates for construction cost assumed to be 50,000US\$/t/h, 500US\$/kW and 1,500US\$/kW, respectively, for these factors.

An economic efficiency analysis made in respect to the back-pressure turbine has shown that only if the gas content is estimated to be 13% or more, the type of turbine has been concluded economically more advantageous than the condensing type turbine.

Condenser type

The possibility is considered of using the water of a lake located near the site by means of a surface condenser. It is found, however, that the surface condenser is more expensive than the direct contact type of condenser because of the higher costs of the pump power, cooling water pipes and condenser tube. The surface condenser has a technical problem with cleaning the tube surfaces of scales.

Design Atmospheric Temperature for Cooling Tower

The average annual temperature is 7°C, but it rises to 20°C during the summer months of January and February. The design temperature of 10°C is taken to keep an output drop during the summer at a level lower than 5%.

Cooling Tower Type

Considering that the cooling tower is exposed to a high wind speed, the mechanical draught counterflow type has been selected for the cooling tower.

The number of cells has been fixed at four to facilitate adjustment of the fan operation to cope with temperature fluctuation.

Gas Extractor Type

For the gas extractor, an electric vacuum pump has been selected in preference to a steam ejector which is lower in operating efficiency and requires a larger quantity of steam. The number of gas extractors to be installed has been set at three to facilitate adjustments to changes in the amount of gas required.

The following are the principal specifications considered on the basis of the foregoing analyses for the turbine and associated equipment.

(1) Turbine

Model:	Single-flow condensing steam turbine
Rated output:	30,000 kW
No. of unit:	One
Inlet steam pressure:	8 ata
Inlet steam temperature:	Saturated
Outlet steam pressure:	0.1 ata
Rate of steam flow:	214.3 t/h

(2) Condenser

Model:	Direct contact low level type
No. of unit:	One
Internal pressure:	0.1 ata
Cooling water temperature (inlet/outlet):	16°C/42.9°C
Amount of cooling water:	3,916 t/h
Amount of exchange heat:	1,055 x 10 ⁸ kcal/h

(3) Cooling Tower

Model:	Suction/induction ventilating counterflow type
No. of cell:	4
Fan:	85 kW x 4

Approx. dimensions: 11 m x 44 m x 10 m H
Amount of cooling water: 4,000 tons/hr
Inlet water temperature: 42.9°C
Outlet water temperature: 16°C
Design atmospheric temperature: 10°Cwb

(4) Gas Extractor

Model: Electric vacuum pump
No. of units: 3
Capacity: 73 kg/min
Electric motor: 340 kW

(5) Circulating Water Pump

Model: Vertical single-stage centrifugal pump
No. of units: 2
Capacity: 2,000 t/h
Lift: 35 m
Electric motor: 250 kW

6.2.7 Electrical Equipment

Principal specifications of the electrical equipment are as follows:

(1) Generator

Model: Horizontal shaft revolving-field 3-phase
AC air-cooled type
Capacity: 33,400 kVA
Power factor: 90%
Voltage: 11 kV
No. of unit: One

(2) Main Transformer

Model:	Outdoor oil-immersed air-cooled type
No. of unit:	One
Capacity:	33,400 kVA

6.2.8 Powerhouse and Related Buildings

It is planned that the powerhouse consists of a three-story building measuring 20.8 m wide, 32.4 m long and 21.5 m high. The first floor consists of pump rooms (vacuum pump and cooling water circulating pump), a tank room, a reserved power room, etc. A battery room, a relay room and an office are arranged on the second floor. The third floor is the main floor where a turbine generator room and a central control room are located.

The entrance for delivered equipment is located at the southwest corner of the main building and an air well is provided from the first to the third floor.

The powerhouse is designed to be of steel frame structure combined with steel sheet walls in consideration of long beams required and large design wind and snow loads. The related buildings in the power plant yard, including a parking house and warehouse, are also designed to be of steel frame and steel sheet wall.

