


9-7-90
No. 96
Analamary
EL=544m




Hydrogeological Section of Analamary Area (96)

22-11.1989

No. 97


Antanimora

EL=500m



Hydrogeological Section of Antanimora Area (97)

22-11, 1989
 Bereketa
 No. 98
 EL=352m




Hydrogeological Section of Bereketa Area (98)

12-11-1989

No. 99


Ankilimitraloka

EL=317m




Hydrogeological Section of Ankilimitraloka Area (99)

The Locations of Investigation & The Topographical Feature











25-10.1989
Andranahinaly



Hydrogeological Section of Andranahinaly Area

The Locations of Investigation & The Topographical Feature

Candidate Village	No.	EL.	m
Name ANTANAMEBA (army bace)			
 Settlement	 Electric Vertical Sounding		
 Magneto-telluric Sounding Point			
 Well	 Spring	 Test Drilling Point	
 Candidate Drilling Point			





10-11.1989

Antanimieva

EL=150m








Borehole for oil exploration
(126m:400m/H from limestone)




Lithological Prospecting of Existing Borehole in Antanimieva

The Locations of Investigation & The Topographical Feature

Candidate Village	No.	EL.	m	
	Name <u>Betsioky-Nard</u>			

	Settlement		Electric Vertical Sounding
	Magneto-telluric Sounding Point		
	Well		Spring
			Test Drilling Point
	Candidate Drilling Point		



The diagram illustrates the locations of investigation relative to a fault. A vertical line on the right represents the fault, with surveyed lines parallel to it. Four points are marked along this line: (1) at the top, (2) in the middle, and (3) at the bottom. A fourth point, (4), is located to the left of the fault, connected to point (2) by a line labeled 300m. A tree is shown near point (4). Houses are depicted near points (1), (2), and (3). Distances of 150m are indicated between points (1) and (2), and between points (2) and (3). A dashed line at the bottom right indicates the surveyed lines are parallel to the fault.

11-11.1989
 Betsioky-Avaratra
 EL=219m





Fig. 4-2-5 Hydrogeological Section of Betsioky Area

3. RESULTS OF WATER QUALITY ANALYSIS

Fig. Distribution map of TDS, hardness, and chlorine.



No Villages	15 Tafatavalo	U. Fiv. ANKAZOABO ATM	48 Ilemby	80 Ambondro	78 Befoly	92 Mahaboboka
I. Fiv. MOROMBE	16 Ambiky	32 Batursaty	W. Fiv. BEROROKA	61 Beroroka	79 Ankeroroka	93 Mahasoa
	17 Marovalo	33 Andranomantisy		62 Antsowarify	80 Ambobiasavelona	94 Andawasy-Vineta
1 Ankazomanga	18 Andranoboka	34 Tanandro	49 Tanandava-Antaifasy	63 Manombo-Atm	81 Manoroka	95 Tranokaky
2 Beadabo	19 Satsrebondro	35 Asprandantsotaky	50 Anjanikiltra	64 Antandroka	101 Ankililalinka	96 Analaazary
3 Befasy	20 Mahavozokely	36 Andranomafana	51 Anavilary	65 Ankarabato		97 Antanimora
4 Ankililolo(I)	21 Antranosatra	37 Manakila		66 Andoharano		98 Bereheta
5 Ambalamos	22 Manory	38 Berenty-Ankilinasy	IV. Fiv. TOLIARA I/U	67 Tsefanoka		99 Ankilimitraloka
6 Tejanthy	23 Aspoza	39 Botelnefo		68 Benetsy		100 Ankilivalo
7 Namatoa	24 Ankililolo(2)	40 Tanandava	52 Soahazo	69 Androvo		
8 Mangolovolo	25 Silhanaka	41 Aspoza	53 Analamisaupy	70 Anjanala	82 Iaborana	
9 Ankida	26 Besoka	42 Ipétes Atm	54 Bolitsaka	71 Amphalia	83 Andranolava	
10 Vorisy	27 Basibasy	43 Mandabe Atm	55 Ampasikibo	72 Behompny	84 Lambomakandro	
11 Andranomantisy	28 Analatelo	44 Soatanimbary	56 Mamaboha	73 Ambolonkira	85 Besakoa(1)	
12 Berantala	29 Mangotroka	45 Sabanory Atm	57 Antseva	74 niary	86 Besakoa(2)	
13 Tanandava	30 Kosy-Ambositra	46 Berenty-Betsileo	58 Ankililavotoka	75 Befanany	87 Ampendry	
14 Antsakosbe	31 Tsiarimploka	47 Ankililavotoky	59 Amphany	76 Tsiwonobe	88 Maninday	
				77 Andranovory	89 Bevoalavo	
					90 Tanambao	
					91 Anabihaintsy	

Table F-1 Results of water quality analysis for drinking water

RESULTATS DE L'ANALYSE DE LA QUALITE D'EAU

No. Village	1	2	3	4	5	6	7
Nom Village	ANKAZOMANGA	BEADABO	BEFASY	ANKILIFOLO (1)	AMBALAMOA	TSIANIHY	NAMATOA
Rubrique Test							
1 Water temp. °C	32.0	33.0	35.0	32.5	29.0	29.5	29.0
2 PH (25C)	7.8	8.1	7.5	7.4	7.4	7.5	6.8
3 Hard.	296	250	32	288	240	162	142
4 Ca	64.0	58.0	4.8	67.0	64.0	40.0	33.0
5 Mg	33.0	25.0	4.8	29.0	19.0	15.0	15.0
6 Cl	156	144	30	606	58	58	17
7 SO4	200	185	17	17	58	23	14
8 Fe	0.11	0.10	1.08	0.46	0.06	0.02	0.31
9 TDS (25C)	624.0	555.0	93.8	1240.0	343.0	293.0	174.0
10 EC (25C)	1250	1110	187	2490	687	586	348
11 Acidity	30	32	18	92	39	34	48
12 Alkalinity	196	178	58	398	304	226	171
13 PO4	0.45	0.45	0.17	0.39	0.77	0.51	0.33
14 NH3-N	0.17	0.20	0.16	1.67	0.06	0.05	0.24
15 NO2-N	0.006	0.003	0.008	0.028	0.000	0.003	0.005
16 NO3-N	0.3	0.7	0.4	0.0	0.2	1.8	0.3
17 F	0.05	0.47	0.00	0.43	0.52	0.56	0.19
18 Mn	0.2	0.3	0.2	0.2	0.1	0.3	0.3
19 E.coli	+	+	-	+	+	+	+
20 TURB & COLOR	YEL. TURB	YEL. TURB	RED TURB	YEL. TURB	YEL. TURB	RED	RED
NOTE:	11/7 Riv.	11/7 Riv.	11/7 S.W.	11/7 S.W.	11/9 O.W.	11/9 S.W.	11/8 O.W.

Cont.

No. Village	8	9	10	11	12	13	14
Non Village	MANGOLOVOLO	ANKIDA	VORISY	ANDRONOMANI- TSY	BERANALA	TANANDAVA	ANTSAKOABE
1 Water temp. °C	30.0	29.0 NO VIL.	30.0	30.0	30.0	31.5	28.5
2 PH (25C)	6.4	5.8	7.5	7.5	7.3	7.8	7.9
3 Hard.	16	12	286	286	232	204	60
4 Ca	2.4	1.6	95.0	95.0	34.0	57.0	21.0
5 Mg	2.4	1.9	12.0	12.0	36.0	15.0	1.9
6 Cl	16	13	52	52	30	52	16
7 SO4	5	5	36	36	9	55	26
8 Fe	2.10	0.67	0.00	0.00	0.44	0.00	0.26
9 TDS (25C)	37.1	20.7	348.0	348.0	125.0	293.0	97.9
10 EC (25C)	74	41	697	697	251	585	195
11 Acidity	16	12	26	26	21	27	28
12 Alkalinity	17	16	239	239	104	176	74
13 PO4	0.00	0.02	0.84	0.84	0.73	0.22	0.23
14 NH3-N	0.46	0.20	0.14	0.14	0.40	0.00	0.34
15 NO2-N	0.008	0.004	0.239	0.239	0.000	0.000	0.016
16 NO3-N	0.7	0.5	5.7	5.7	0.1	1.8	1.4
17 F	0.00	0.02	0.59	0.59	0.73	0.54	0.00
18 Mn	0.3	0.2	0.0	0.0	1.3	0.0	0.4
19 E.coli	+	-	+	+	+	+	+
20 TURB & COLOR	BROWN TURB	YEL. TURB	YEL.	YEL.	+	WHITE TURB	+
NOTE:	11/8 Riv.	11/8 S.W. spring	11/9 S.W.	11/9 D.W.	11/9 B.F.W.	11/11 canal	

Cont.

No. Village	15	16	17	18	19	20	21
Nom Village	TANTALAVALO	AMBIKY.	MAROVATO	ANDRANOBOKA	SATRAMBONDRO	MOHAVOZOKELY	ANTRANOSATRA

Rubrique Test							

1 Water temp. °C	27.5	28.0	28.0	28.0	33.5	NOT	28.0
2 pH (25C)	7.9	7.8	7.7	7.7	7.3	ACCESSIBLE	8.0
3 Hard.	82	96	278	278	152		172
4 Ca	22.0	22.0	85.0	85.0	54.0		64.0
5 Mg	6.8	9.7	16.0	16.0	4.3		2.9
6 Cl	17	15	48	48	14		24
7 SO4	26	32	38	38	6		22
8 Fe	0.35	0.32	0.09	0.09	0.14		1.70
9 TDS (25C)	101.0	128.0	341.0	341.0	174.0		241.0
10 EC (25C) µS/cm	202	257	682	682	348		482
11 Acidity	18	20	60	60	46		110
12 Alkalinity	80	90	292	292	170		254
13 PO4	0.17	0.39	0.37	0.37	1.22		0.70
14 NH3-N	0.22	0.26	0.17	0.17	0.81		3.20
15 NO2-N	0.007	0.010	0.000	0.000	0.014		0.054
16 NO3-N	1.0	1.0	0.0	0.0	0.3		1.0
17 F	0.51	0.12	0.72	0.72	0.33		0.24
18 Mn	0.5	0.5	0.0	0.0	0.2		0.3
19 E.coli	+	+	-	-	+		+
20 TURB & COLOR	WHITE TURB	YEL. TURB	YEL.	YEL.	BROWN TURB		

NOTE:	11/11 canal	11/11 Riv.	11/11 S.W.	11/11 S.W.	11/11 S.W.		11/10 S.W.
			springs				

Cont.

No. Village	22	23	24	25	26	27	28
Na. Village	MANOY	AMPOZA	ANKILIFOLO (2)	SIHANAKA	BEOKA	BASIBASY	ANALATELO
Rubrique Test							
1 Water temp. °C	28.0	28.0	28.0	27.5	28.0 NOT	27.0	27.0
2 pH (25C)	7.5	7.6	7.6	7.7	7.6 ACCESSIBLE	8.0	7.4
3 Hard.	460	182	182	434	154	234	448
4 Ca	142.0	68.0	68.0	168.0	56.0	67.0	154.0
5 Mg	25.0	2.9	2.9	3.4	3.4	16.0	15.0
6 Cl	164	20	20	108	10	48	52
7 SO4	270	18	18	14	10	42	148
8 Fe	0.00	0.02	0.02	0.00	0.84	0.07	0.05
9 TDS (25C)	985.0	314.0	314.0	489.0	166.0	312.0	466.0
10 EC (25C)	1970	628	628	977	333	623	932
11 Acidity	148	100	100	114	62	38	66
12 Alkalinity	462	318	318	252	176	268	308
13 PO4	0.75	0.62	0.62	0.81	0.57	0.29	0.06
14 NH3-N	0.39	0.15	0.15	1.31	0.44	0.17	0.05
15 NO2-N	0.005	0.009	0.009	0.058	0.026	0.008	0.000
16 NO3-N	2.0	0.0	0.0	10.6	0.7	0.0	0.0
17 F	0.64	0.46	0.46	0.32	0.00	0.28	0.12
18 Mn	0.1	0.1	0.1	0.0	0.8	0.1	0.0
19 E.coli	+	+	+	+	+	+	+
20 TURB & COLOR	+	+	+	+	+	+	+
NOTE:							
11/10 D.W. 11/10 S.W. 11/10 S.W. 11/10 S.W. 11/10 S.W. 11/12 canal 11/15 S.W.							

Cont.

No. Village	29	30	31	32	33	34	35
Na Village	MANGOTROKA	NOSY-AMBOISITRA	TSIARPIOKE	BETARATSY	ANDRANOMANIN-TANDRANO TSY	AMPANDRAMI-TSETAKY	
Rubrique Test							
1 Water temp. °C	28.5	NOT	NOT	NOT	32.5	27.0	25.5
2 pH (25°C)	5.8	ACCESSIBLE	ACCESSIBLE	ACCESSIBLE	6.1	6.0	6.6
3 Hard.	120				5	8	44
4 Ca mg/l as CaCO3	28.0				0.8	2.4	10.0
5 Mg mg/l	12.0				0.7	0.5	4.4
6 Cl mg/l	42				5	1	5
7 SO4 mg/l	3				15	9	8
8 Fe mg/l	0.03				0.45	0.33	0.54
9 TDS (25°C) mg/l	167.0				12.7	23.4	68.0
10 EC (25°C) µS/cm	334				25	47	136
11 Acidity mg/l as CaCO3	14				10	16	20
12 Alkalinity mg/l as CaCO3	8				10	22	72
13 PO4 mg/l	0.17				0.03	0.02	0.01
14 NH3-N mg/l	0.18				0.08	0.00	0.00
15 NO2-N mg/l	0.036				0.021	0.008	0.000
16 NO3-N mg/l	11.9				0.5	0.4	0.4
17 F mg/l	0.22				0.04	0.21	0.22
18 Mn mg/l	0.0				0.2	0.1	0.1
19 E. coli +/-	+				+	+	+
20 TURB & COLOR							
					WHITE TURB	WHITE TURB	
					10/31 S.W.	10/31 S.W.	10/31 S.W.
NOTE:							
	11/11 S.W.						

Cont.

No. Village	36	37	38	39	40	41	42
Nm Village	ANDRANOMA- FANA	MAMAKIALA	BERENTY- ANKILIMASY	BETSINEFO	TANANDAVA	AMPOZA	IPETSA ATM
Rubricque Test:							
1 Water temp. °C	NOT ACCESSIBLE	NOT ACCESSIBLE	NOT ACCESSIBLE	23.0	7.4	23.5	25.5
2 pH (25°C)				8.3	150	8.3	7.8
3 Hard.				304	36.0	166	116
4 Ca				98.0	15.0	50.0	32.0
5 Mg				15.0	22	9.7	8.7
6 Cl				30	39	6	6
7 SO4				215	0.59	2	8
8 Fe				0.82	213.0	0.13	0.13
9 TDS (25°C)				446.0	425	166.0	137.0
10 EC (25°C)				891	102	333	275
11 Acidity				60	146	82	66
12 Alkalinity				148	0.16	162	128
13 PO4				0.08	0.34	0.03	0.11
14 NH3-N				0.22	0.003	0.00	0.08
15 NO2-N				0.012	0.003	0.00	0.002
16 NO3-N				1.5	1.2	1.0	0.7
17 F				0.52	0.59	0.00	0.42
18 Mn				0.8	0.1	0.0	0.0
19 E.coli				+	+	+	+
20 TURB & COLOR				WHITE TURB	YEL		
NOTE:							
				11/1 Riv.	11/1 S.W.	11/1 Riv.	11/1 S.W.

Cont.

No. Village		43	44	45	46	47	48	49
Nm Village		MONDABE	SOATANIMBARY	SAHANORY	BERENTY-	ANKILIVALO-	ILEMBY	TANANDAVA-
		ATM	ATN	ATN	BETSILEO	KELY		ANTAIFASY
Rubric Test								
1	Water temp: °C	25.0	28.0	30.5	32.5	30.0 NOT	30.0 NOT	27.0
2	pH (25°C)	7.4	7.3	6.4	8.3	8.2 ACCESSIBLE	8.2 ACCESSIBLE	8.0
3	Hard.	314	171	23	97	186	186	242
4	Ca	81.0	55.0	5.6	28.0	45.0	45.0	68.0
5	Mg	27.0	8.0	2.2	6.8	18.0	18.0	17.0
6	Cl	32	29	5	15	10	10	74
7	SO4	72	4	6	8	26	26	27
8	Fe	0.01	0.09	0.88	0.67	0.30	0.30	0.24
9	TDS (25°C)	394.0	265.0	40.5	119.0	197.0	197.0	542.0
10	EC (25°C)	788	530	81	238	394	394	1080
11	Acidity	74	89	18	50	63	63	108
12	Alkalinity	245	178	38	99	172	172	404
13	PO4	0.36	0.44	0.18	0.36	0.20	0.20	0.21
14	NH3-N	0.05	0.06	0.08	0.19	0.10	0.10	0.63
15	NO2-N	0.004	0.002	0.000	0.004	0.003	0.003	0.008
16	NO3-N	0.1	0.0	1.5	0.0	0.0	0.0	0.9
17	F	0.71	0.19	0.00	0.24	0.32	0.32	0.65
18	Mn	0.0	0.0	0.2	0.1	0.0	0.0	0.1
19	Zinc	+	+	+	+	+	+	+
20	TURB & COLOR	+	+	+	+	+	+	+

NOTE: 11/2 S.W. 11/2 S.W. 11/2 S.W. 11/2 Riv. 11/2 Riv. 11/1 Riv.

Cont.

No. Village	50 ANJAMITIKI- TRA	51 ANAVIAVY	52 SOHAZO	53 ANALAMISAMPY	54 BELITSAKA	55 AMPASIKIBO	56 NAMABOHA
Subsique Test	NO VIL.	NOT ACCESSIBLE					
1 Water temp. °C	26.0	28.0	27.5	28.0	27.0	28.0	27.0
2 pH (25°C)	7.6	7.4	7.4	7.4	7.3	6.8	7.3
3 Hard.	110	210	452	210	428	652	428
4 Ca	32.0	70.0	159.0	70.0	142.0	243.0	142.0
5 Mg	7.3	10.0	13.0	10.0	17.0	11.0	17.0
6 Cl	16	60	130	60	14	115	14
7 SO4	4	12	110	12	88	57	57
8 Fe	0.16	0.14	0.08	0.14	0.15	0.15	2.18
9 TDS (25°C)	141.0	348.0	557.0	348.0	414.0	780.0	414.0
10 EC (25°C)	282	696	1110	696	827	1560	827
11 Acidity	36	64	66	64	112	136	112
12 Alkalinity	144	300	286	300	395	375	395
13 PO4	0.26	0.10	0.20	0.10	0.25	0.33	0.25
14 NH3-N	0.36	0.13	0.30	0.13	4.36	0.019	4.36
15 NO3-N	0.011	0.000	0.000	0.000	0.021	0.01	0.021
16 NO3-N	0.4	0.8	0.9	0.8	1.0	0.1	1.0
17 F	0.24	0.25	0.00	0.25	0.12	0.09	0.12
18 Mn	0.2	0.1	0.1	0.1	2.4	0.1	2.4
19 E.coli	+	+	+	+	+	+	+
20 TURB & COLOR							
NOTE:	11/15 S.W.	11/15 D.W.	11/15 D.W.	11/15 D.W.	11/15 D.W.	11/15 S.W.	11/15 S.W.
		handpump	handpump	handpump	handpump		
						YEL. TURB	

Cont.

No. Village	57	58	59	60	61	62	63
Nam Village	ANTSEVA	ANKATRAKATRA	AMPIHAMY	AMBONDRO	BEROROHA	ANTSOMARIFY	MANOMBO
							ATM
Rubrique Test							
1 Water temp. °C		27.0	27.5	NOT	NOT	NOT	28.0
2 pH (25°C)		6.9	7.4	ACCESSIBLE	ACCESSIBLE	ACCESSIBLE	7.4
3 Hard.	ms/l as CaCO3	42	302				438
4 Ca	ms/l	132.0	98.0				125.0
5 Mg	ms/l	51.0	14.0				30.0
6 Cl	ms/l	125	84				94
7 SO4	ms/l	175	145				145
8 Fe	ms/l	0.01	0.04				0.02
9 TDS (25°C)	ms/l	733.0	592.0				623.0
10 EC (25°C)	µS/cm	1470	1180				1250
11 Acidity	ms/l as CaCO3	89	70				62
12 Alkalinity	ms/l as CaCO3	472	350				274
13 PO4	ms/l	0.33	0.20				0.13
14 NH3-N	ms/l	0.08	0.24				0.13
15 NO2-N	ms/l	0.002	0.006				0.030
16 NO3-N	ms/l	0.2	0.5				6.2
17 F	ms/l	0.39	0.24				0.44
18 Mn	ms/l	0.0	0.0				0.0
19 E.coli	+/ -	+	+				+
20 TURB & COLOR		YEL. TURB					

NOTE:

10/25 D.W. 11/15 S.W. 11/15 S.W.

11/17 D.W.

Cont.

No. Village	64	65	66	67	68	69	70
Nom Village	ANTANDROKA	ANKARAOBATO	ANDOHARANO	TSEFANOXA	BENETSY	ANDREVO BAS	ANJAMALA
----- Rubrique Test -----							
1 Water temp. °C	29.0		NOT ACCESSIBLE	25.0	28.0	27.0	NOT ACCESSIBLE
2 pH (25C)	7.4		8.1	8.0	7.5	7.6	
3 Hard.	332		220	178	208	336	
4 Ca	118.0		63.0	67.0	66.0	102.0	
5 Mg	8.7		15.0	2.4	10.0	20.0	
6 Cl	42		10	20	16	290	
7 SO4	100		28	70	110	60	
8 Fe	0.02		0.19	0.11	0.19	0.02	
9 TDS (25C)	371.0		216.0	196.0	238.0	754.0	
10 EC (25C) µS/cm	742		432	392	476	1510	
11 Acidity	44		34	40	28	58	
12 Alkalinity	178		108	124	94	232	
13 PO4	0.02		0.23	0.25	0.39	0.14	
14 NH3-N	0.05		0.00	0.13	0.21	0.07	
15 NO2-N	0.025		0.000	0.011	0.006	0.069	
16 NO3-N	4.6		0.1	0.1	0.0	1.3	
17 F	0.43		0.00	0.29	0.51	0.33	
18 Mn	0.0		0.1	0.2	0.1	0.0	
19 E.coli +/-	+		+	+	+	-	
20 TURB & COLOR		WHITE TURB		YEL.			
----- NOTE: -----							
	11/17 D.W.	10/25 Riv.		11/24 canal	11/16 canal	11/17 S.W. Spring	

Cont.

No. Village	71	72	73	74	75	76	77
Nom Village	AMPIHALIA	BEHOMPY	AMBOLONKIRA	MIARY	BEFANAMY	TSIVONAOBE	ANDRANOVOVY
Rubrique Test							
1 Water temp. °C	30.0	30.0	30.0	28.0	29.0	28.0	28.0
2 PH (25C)	8.3	8.3	8.3	7.6	7.9	7.4	7.4
3 Hard.	169	168	168	211	215	384	384
4 Ca	46.0	45.0	45.0	65.0	67.0	98.0	98.0
5 Mg	13.0	14.0	14.0	11.0	12.0	34.0	34.0
6 Cl	25	26	26	44	46	330	330
7 SO4	49	50	50	47	49	92	92
8 Fe	1.85	2.13	2.13	0.26	0.01	0.00	0.00
9 TDS (25C)	176.0	175.0	175.0	259.0	257.0	839.0	839.0
10 EC (25C)	352	350	350	518	514	1680	1680
11 Acidity	20	20	20	32	24	70	70
12 Alkalinity	152	154	154	170	171	264	264
13 PO4	0.12	0.15	0.15	0.12	0.19	0.11	0.11
14 NH3-N	0.04	0.04	0.04	0.07	0.02	0.44	0.44
15 NO2-N	0.002	0.002	0.002	0.000	0.000	0.024	0.024
16 NO3-N	0.2	0.1	0.1	0.4	0.0	1.2	1.2
17 F	0.10	0.08	0.08	0.41	0.25	0.13	0.13
18 Mn	0.7	0.8	0.8	0.2	0.0	0.0	0.0
19 E.coli	+	+	+	-	-	+	+
20 TURB & COLOR	RED TURB	RED TURB	RED TURB	RED TURB	RED TURB	RED TURB	RED TURB
NOTE:							
11/23 Riv. 11/23 Riv. 11/23 Riv. 11/23 P.F. 11/23 P.F. 11/16 S.W.							

Cont.

No. Village	78	79	80	81	82	83	84
Nom Village	BEFOLY	ANKOROROKA	AMBOHIMAHAY- VELONA	MANOROKA	LABORANA	ANDRANOLAVA	LAMEOMAKAND- RO
WATER VENDER WATER VENDER							
Rubrique Test							
1 Water temp. °C	27.0	27.0	27.0	27.0	27.0	27.0	27.0
2 pH (25C)	7.6	7.6	7.6	7.6	7.6	7.6	7.6
3 Hard.	192	192	192	192	192	192	192
4 Ca	56.0	56.0	56.0	56.0	56.0	56.0	56.0
5 Mg	13.0	13.0	13.0	13.0	13.0	13.0	13.0
6 Cl	28	28	28	28	28	28	28
7 SO4	59	59	59	59	59	59	59
8 Fe	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9 TDS (25C)	224.0	224.0	224.0	224.0	224.0	224.0	224.0
10 EC (25C)	447	447	447	447	447	447	447
11 Acidity	20	20	20	20	20	20	20
12 Alkalinity	152	152	152	152	152	152	152
13 PO4	0.22	0.22	0.22	0.22	0.22	0.22	0.22
14 NH3-N	0.05	0.05	0.05	0.05	0.05	0.05	0.05
15 NO2-N	0.002	0.002	0.002	0.002	0.002	0.002	0.002
16 NO3-N	0.2	0.2	0.2	0.2	0.2	0.2	0.2
17 F	0.37	0.37	0.37	0.37	0.37	0.37	0.37
18 Mn	0.0	0.0	0.0	0.0	0.0	0.0	0.0
19 E.coli	+	+	+	+	+	+	+
20 TURB & COLOR	YEL. TURB	YEL. TURB	YEL. TURB	YEL. TURB	YEL. TURB	YEL. TURB	YEL. TURB
NOTE:	11/22 Riv.	11/23 S.W.(1)	11/3 S.W.	11/3 Riv.	11/3 Riv.	11/3 Riv.	11/3 Riv.

Cont.

No. Village	85	86	87	88	89	90	91
Nom Village	BESAKOA (1)	BESAKOA (2)	AMPANDRA	MANINDAY	BEVOALAVO	TANAMBAO	AMBAHIMALI- TSY
Rubrique Test							
1 Water temp. °C			NO VIL.		26.0 NOT		27.0
2 PH (25°C)	NOT ACCESSIBLE				6.6 ACCESSIBLE		7.1
3 Hard.	mg/l as CaCO3	6.2			5		232
4 Ca	mg/l	0.4			0.4		48
5 Mg	mg/l	0.2			1.0		67.0
6 Cl	mg/l	4			7		15.0
7 SO4	mg/l	4			8		66
8 Fe	mg/l	0.35			0.80		136
9 TDS (25°C)	mg/l	15.5			18.5		0.06
10 EC (25°C)	µS/cm	31			37		430.0
11 Acidity	mg/l as CaCO3	15			11		859
12 Alkalinity	mg/l as CaCO3	18			15		44
13 PO4	mg/l	0.17			0.05		196
14 NH3-N	mg/l	0.00			0.16		0.27
15 NO2-N	mg/l	0.003			0.006		0.07
16 NO3-N	mg/l	0.1			0.7		0.017
17 F	mg/l	0.12			0.00		1.5
18 Mn	mg/l	0.2			0.6		0.57
19 E.coli	+/ -	+			+		0.2
20 TURB & COLOR							+
NOTE:							
	10/26 S.W.		11/20 Riv.		11/20 S.W.		YEL. TURB
							11/3 Riv.

Cont.

No. Village	92	93	94	95	96	97	98
Nam Village	MOHABOBOKA	MAHASOA	ANDAMASINY- VINETA	TRANOKAKY	ANALAMARY	ANTANIMORA	BEREKETA
Rubrique Test							
1 Water temp. °C	28.0	29.0	26.0	25.5	26.0	26.0	39.0
2 pH (25°C)	8.0	7.3	8.2	5.8	6.8	6.8	8.5
3 Hard. mg/l as CaCO3	96	338	266	6	26	26	182
4 Ca mg/l	29.0	116.0	74.0	0.4	9.6	9.6	50.0
5 Mg mg/l	5.6	12.0	20.0	1.2	0.5	0.5	14.0
6 Cl mg/l	17	56	46	20	12	12	26
7 SO4 mg/l	24	26	55	21	10	10	34
8 Fe mg/l	5.10	0.11	0.10	2.42	2.68	2.68	0.32
9 TDS (25°C) mg/l	124.0	394.0	317.0	29.1	50.0	50.0	217.0
10 EC (25°C) µS/cm	247	788	634	58	100	100	435
11 Acidity mg/l as CaCO3	16	48	30	34	14	14	8
12 Alkalinity mg/l as CaCO3	80	390	258	18	67	67	184
13 PO4 mg/l	0.09	0.09	0.32	0.41	0.33	0.33	0.38
14 NH3-N mg/l	0.10	0.10	0.10	0.63	0.44	0.44	0.13
15 NO2-N mg/l	0.000	0.001	0.003	0.031	0.007	0.007	0.008
16 NO3-N mg/l	0.0	0.0	0.0	1.9	0.9	0.9	0.7
17 F mg/l	0.00	0.43	0.51	0.00	0.00	0.00	0.22
18 Mn mg/l	0.4	0.0	0.2	1.6	1.1	1.1	0.5
19 E.coli +/-	+	+	+	+	+	+	+
20 TURB & COLOR	RED TURB			YEL. TURB	YEL. TURB	WHITE TURB	
NOTE:	11/21 Riv.	11/21 Riv.	11/21 Riv.	11/20 S.W.	11/20 S.W.	11/22 Riv.	
				spring			

Cont.

No. Village	99	100	WHO
Nom. Village	ANKILIMI- TRALOKA	ANKILIVALO	STANDARD VALUES
Rubrique Test			
1 Water temp. °C	34.0		6.5/8.5
2 pH (25C)	8.4		500
3 Hard.	337		75.0
4 Ca	92.0	6.2	30.0
5 Mg	26.0	3.2	250
6 Cl	40	0.5	400
7 SO4	195	4	0.3
8 Fe	0.34	4.22	1000
9 TDS (25C)	389.0	24.5	-
10 EC (25C)	778	49	-
11 Acidity	10	14	-
12 Alkalinity	192	20	-
13 PO4	0.81	0.11	0.50
14 NH3-N	0.18		-
15 NO2-N	0.014	0.004	10.0
16 NO3-N	1.0	0.2	1.50
17 F	0.41	0.00	0.1
18 Mn	0.6	0.5	-
19 E.coli	+	+	-
20 TURB & COLOR	WHITE TURB	RED TURB	
	11/22 Riv.	10/27 S.W.	

LEGEND
=====

Dug Well
Shallow Well
Bore Hole
Borne Fountain Well
Public Fountain
Water Supply

Table F-2 Results of water quality analysis for salty water and reference water

RESULTATS DE L'ANALYSE DE LA QUALITE D'EAU

No. Village	16	27	52	65	68
Nom Village	AMBIKY	BASIBASY	ANKAZOABO	ANKARAOBATO	BENETSY
Rubrique Test					
1 Water temp. °C	29.0	28.0	30.5	27.0	27.0
2 pH (25C)	7.5	7.5	7.7	7.4	7.3
3 Hard.	378	740	172	1120	270
4 Ca	104.0	210.0	52.0	132.0	55.0
5 Mg	29.0	52.0	10.0	163.0	176.0
6 Cl	142	492	14	172.0	32.0
7 SO4	102	2	8	920	15
8 Fe	0.00	0.18	0.00	775	90
9 TDS (25C)	611.0	1160.0	176.0	0.11	0.03
10 EC (25C)	1220	2330	352	2530.0	421.0
11 Acidity	70	115	54	5070	842
12 Alkalinity	355	500	206	123	100
13 PO4	0.80	1.76	0.04	490	354
14 NH3-N	0.22	15.40	0.00	0.19	0.51
15 NO2-N	0.002	0.004	0.00	0.79	0.06
16 NO3-N	0.0	0.5	0.007	0.032	0.008
17 F	1.22	0.16	0.1	1.7	0.2
18 Mn	0.0	1.4	0.15	0.61	0.65
19 E.coli	+	+	0.1	0.1	0.1
20 TURB & COLOR	-	+	+	+	+
NOTE:	11/11 D.W. private	11/15 D.W. private	11/7 B.H.W. springs	11/15 O.W. handpump Hospital	10/25 D.W. Hospital 11/16 D.W.(1)

Cont.

No. Village	68	69	69	77	81	84	95
Nom Village	BENETSY	ANDREVO HAUT	ANDREVO HAUT	ANDRANOVOVY	MANOROKA	VINETA	ANDAMASINY- TRANOKAKY

Rubrique Test							
1 Water temp. °C	28.0	29.0	28.0	28.0	27.0	27.0	27.5
2 pH (25°C)	7.3	7.9	7.7	7.7	7.5	7.5	7.6
3 Hard.	760	214	1380	235	216	216	140
4 Ca	216.0	72.0	222.0	92.0	60.0	60.0	54.0
5 Mg	53.0	8.2	199.0	1.2	16.0	16.0	1.5
6 Cl	610	14	1800	8	24	24	7
7 SO4	1600	105	1800	3	17	17	5
8 Fe	0.06	0.19	0.15	0.05	0.27	0.27	0.13
9 TDS (25°C)	3280.0	229.0	4680.0	242.0	233.0	233.0	146.0
10 EC (25°C)	6560	458	9370	483	466	466	292
11 Acidity	90	22	112	83	34	34	25
12 Alkalinity	530	102	532	239	238	238	160
13 PO4	0.75	0.74	1.90	0.35	0.72	0.72	0.19
14 NH3-N	0.63	0.35	1.70	0.00	0.26	0.26	0.10
15 NO2-N	0.146	0.015	0.008	0.006	0.002	0.002	0.001
16 NO3-N	4.6	0.5	0.0	0.1	0.1	0.1	0.004
17 F	0.79	0.44	0.63	0.20	0.44	0.44	1.0
18 Mn	0.0	0.4	0.2	0.1	0.7	0.7	0.14
19 E.coli	+	+	+	+	+	+	0.4
20 TURB & COLOR	+	+	+	+	+	+	+

NOTE:	11/16 D.W.(2)11/17 canal	11/17 D.W.	10/26 S.W.	11/23 D.W.(2)	11/21 S.W.	11/3 D.W.	Handpump

Cont.

WHO
STANDARD VALUES

TOLIARA

No. Village
Nom. Village

Rubrique Test		WHO STANDARD VALUES	
1	Water temp. °C	29.0	6.5/8.5
2	pH (25C)	7.3	
3	Hard.	288	500
4	Ca	66.0	75.0
5	Mg	30.0	30.0
6	Cl	155	250
7	SO4	98	400
8	Fe	0.20	0.30
9	TDS (25C)	543.0	1000.0
10	EC (25C) µS/cm	1085	
11	Acidity	58	
12	Alkalinity	256	
13	PO4	0.41	
14	NH3-N	0.03	0.50
15	NO2-N	0.001	
16	NO3-N	0.6	10.0
17	F	0.43	1.50
18	Mn	0.1	0.1
19	E.coli	-	-
20	TURB & COLOR	-	-

11/27 U.S.

NOTE:

LEGEND
=====

D.W.
S.W.
B.H.
B.F.W.
P.F.
W.S.

:Dug Well
:Shallow Well
:Bore Hole
:Bore Fountain Well
:Public Fountain
:Water Supply

Table RESULTS OF WATER QUALITY ANALYSIS

NO.	LOCATION	DATE	Temp	pH	Hard.	Ca	Mg	Na	K	Cl	SO4	Fe	TDS	EC	Acid. Alkali	PO4	NH3-N	NO2-N	NO3-N	F	Mn	E.coli	NOTE	
1	ANKAZORANGA	89/11/07	32.0	7.8	296	54.0	33.0	160.0	5.7	156	200	0.11	624.0	1250	30	196	0.45	0.17	0.006	0.3	0.05	0.2	+	Riv.
2	BEADABO	89/11/07	33.0	8.1	250	58.0	25.0	149.0	6.0	144	135	0.10	555.0	1110	32	178	0.45	0.20	0.003	0.7	0.67	0.3	+	Riv.
3	BEASAY	89/11/07	35.0	7.5	32	4.0	4.8	25.0	2.0	33	17	1.00	93.0	157	18	58	0.17	0.16	0.002	0.4	0.00	0.2	-	S.W.
4	ANKILIFOLO(1)	89/11/07	32.5	7.4	288	67.0	29.0	482.0	34.0	666	17	0.46	1240.0	2490	92	398	0.39	1.67	0.028	0.0	0.43	0.2	+	S.W.
5	ANGALANGA	89/11/09	29.0	7.4	240	64.0	19.0	64.0	4.3	58	58	0.06	343.0	687	39	250	0.77	0.06	0.000	0.2	0.52	0.1	+	D.W.
6	TSIANIHY	89/11/09	29.5	7.5	162	40.0	15.0	34.0	80.0	58	23	0.02	293.0	586	34	226	0.51	0.05	0.003	1.8	0.56	0.3	+	S.W.
7	NARATOA	89/11/08	29.0	6.8	142	33.0	15.0	18.0	7.5	17	14	0.31	174.0	348	48	171	0.33	0.24	0.005	0.3	0.19	0.3	+	D.W.
8	MANGOLOULO	89/11/08	30.0	6.4	16	2.4	2.4	8.0	1.0	16	5	2.10	37.1	74	16	12	0.00	0.46	0.008	0.7	0.00	0.3	+	Riv.
9	ANKIDA	89/11/08	29.0	5.3	12	1.6	1.3	4.7	0.5	7	5	0.67	20.7	41	12	8	0.02	0.20	0.004	0.5	0.02	0.2	-	S.W. Spring
10	UORISY	NO U/L																						
11	ANDRONOMANITSY	89/11/09	30.0	7.5	286	95.0	12.0	27.0	20.0	52	36	0.00	348.0	697	26	238	0.84	0.14	0.239	5.7	0.59	0.0	+	S.W.
12	BERANALA	89/11/09	30.0	7.3	134	34.0	12.0	11.0	2.0	38	9	0.44	125.0	251	21	104	0.73	0.40	0.000	0.1	0.73	1.3	+	D.W.
13	TANANDAVA	89/11/09	31.5	7.8	204	57.0	15.0	48.0	5.4	52	55	0.00	293.0	595	27	176	0.22	0.00	0.000	1.8	0.54	0.0	+	B.F.W.
14	ANTSAROA	89/11/11	28.5	7.9	60	21.0	1.9	11.0	3.5	16	26	0.26	97.9	195	28	74	0.23	0.34	0.016	1.4	0.00	0.4	+	canal
15	TANTALAVALO	89/11/11	27.5	7.9	82	22.0	6.8	11.0	3.6	17	26	0.35	101.9	202	18	80	0.17	0.22	0.007	1.0	0.51	0.5	+	canal
16	AMBIKY	89/11/11	28.0	7.8	96	22.0	9.7	14.0	3.5	15	32	0.32	128.0	257	20	98	0.39	0.26	0.010	1.0	0.12	0.5	+	Riv.
17	MAROUATO	89/11/11	28.0	7.7	278	85.0	16.0	49.0	1.8	48	38	0.09	341.0	682	60	292	0.37	0.17	0.000	0.0	0.72	0.0	-	S.W. Spring
18	ANDRANOBOKA	89/11/11	33.5	7.3	152	54.0	4.3	2.0	22.0	14	6	0.14	174.0	348	46	170	1.22	0.01	0.014	0.3	0.33	0.2	+	S.W.
19	SATRAMBONDO	NOT ACCESSIBLE																						
20	MOHAUZOZOKELY	NOT ACCESSIBLE																						
21	ANTRANOSATRA	89/11/10	28.0	8.0	172	64.0	2.9	26.0	31.0	24	22	1.70	241.0	482	110	254	0.70	3.20	0.054	1.0	0.24	0.2	+	S.W.
22	HANDY	89/11/10	28.0	7.5	450	142.0	25.0	296.0	7.6	164	270	0.00	995.0	1970	148	462	0.75	0.39	0.005	2.0	0.64	0.1	+	D.W.
23	AMPOZA	89/11/10	28.0	7.6	182	68.0	2.9	65.0	7.3	20	18	0.02	314.0	628	100	318	0.62	0.15	0.009	0.0	0.46	0.1	+	S.W.
24	ANKILIFOLO(2)	89/11/10	27.5	7.7	434	168.0	3.4	8.0	6.8	108	14	0.00	499.0	977	114	252	0.81	1.31	0.058	10.6	0.32	0.0	+	S.W.
25	SIHANAKA	89/11/10	28.0	7.5	154	56.0	3.4	22.0	4.3	10	10	0.84	166.0	333	62	176	0.57	0.44	0.026	0.7	0.00	0.8	+	S.W.
26	BEROKA	NOT ACCESSIBLE																						
27	BASIBASY	89/11/12	27.0	8.0	236	67.0	16.0	45.0	5.9	48	42	0.07	312.0	623	38	268	0.29	0.17	0.008	0.0	0.28	0.1	+	canal
28	ANALATILO	89/11/15	27.0	7.4	448	154.0	15.0	37.0	3.0	52	148	0.05	466.0	932	66	380	0.06	0.05	0.000	0.0	0.12	0.0	+	S.W.
29	MANGOTROKA	89/11/11	28.5	5.8	120	28.0	12.0	5.5	6.8	42	3	0.03	107.0	334	14	100	0.17	0.18	0.036	11.9	0.22	0.0	+	S.W.
30	MOSTAROBOSITRA	NOT ACCESSIBLE																						

Temp.: °C
Hard. Acid. Alkali.: mg/l as CaCO₃
EC : μS/cm
Other items : mg/l

Table RESULTS OF WATER QUALITY ANALYSIS

NO.	LOCATION	DATE	Temp	pH	Hard.	Ca	Mg	Na	K	Cl	SO4	Fe	TDS	EC	Acid, Alkali	PO4	MH3-N	NO2-N	NO3-N	F	Mr	E. coli	NOTE	
31	TSIRAMPLOKE	NOT ACCESSIBLE																						
32	BETARATSY	NOT ACCESSIBLE																						
33	ANDRANOMANINTSY	89/10/31 32.5	6.1	5	5	0.8	0.7	3.3	4.8	5	2	0.45	12.7	25	10	10	0.03	0.021	0.5	0.04	0.2	+	S.W.	
34	TANDRANG	89/10/31 27.0	6.0	8	8	2.4	0.5	6.0	5.1	1	9	0.33	23.4	47	16	22	0.02	0.008	0.4	0.21	0.1	+	S.W.	
35	AMPANDRAMITSETAKY	89/10/31 25.5	6.6	44	44	10.0	4.4	8.3	11.0	5	8	0.54	68.0	136	20	72	0.01	0.000	0.4	0.22	0.1	+	S.W.	
36	ANDRANOMAFANA	NOT ACCESSIBLE																						
37	MANAKIALA	NOT ACCESSIBLE																						
38	BERENTYANKILIMASY	NOT ACCESSIBLE																						
39	BEZISINEFO	89/11/01 23.0	8.3	384	384	98.8	15.0	42.0	15.0	30	215	0.82	446.0	891	80	148	0.08	0.22	0.012	1.5	0.52	0.8	+	Riv.
40	TANANDRAU	89/11/01	7.4	150	150	36.8	15.0	29.0	16.0	22	39	0.59	213.0	425	182	146	0.16	0.34	0.003	1.2	0.59	0.1	+	S.W.
41	AMPOZA	89/11/01 23.5	8.3	166	166	50.0	8.7	5.3	5.2	6	2	0.13	166.0	333	82	162	0.03	0.00	0.000	1.0	0.00	0.0	+	Riv.
42	IPETSA ATM	89/11/01 25.5	7.8	116	116	32.0	8.7	17.0	1.0	6	8	0.13	137.0	275	66	128	0.11	0.08	0.002	0.7	0.42	0.0	+	S.W.
43	MONDARE ATM	89/11/02 25.0	7.4	314	314	81.8	27.0	60.0	10.0	32	72	0.81	394.0	788	74	245	0.30	0.05	0.004	0.1	0.71	0.0	+	S.W.
44	SOATANIMBARAY	89/11/02 28.0	7.3	171	171	55.0	8.0	56.0	4.7	29	4	0.09	265.0	530	89	178	0.44	0.06	0.002	0.3	0.19	0.0	+	S.W.
45	SAHANORY ATM	89/11/02 30.5	6.4	23	23	5.6	2.2	4.3	6.3	5	6	0.38	40.5	81	18	38	0.18	0.08	0.000	1.5	0.08	0.2	+	S.W.
46	BERENTYBETSILO	89/11/02 32.5	8.3	97	97	28.0	6.8	11.0	5.7	15	8	0.07	119.0	238	50	99	0.36	0.19	0.004	9.0	0.24	0.1	+	Riv.
47	ANKILJALOKELY	89/11/02 30.0	8.2	186	186	45.0	18.0	12.0	6.7	10	26	0.30	197.0	394	63	172	0.20	0.10	0.003	0.0	0.32	0.0	+	Riv.
48	ILERBY	NOT ACCESSIBLE																						
49	TANANDRAUANTAFISY	89/11/01 27.0	8.0	242	242	68.0	17.0	133.0	7.0	74	27	0.24	542.0	1080	108	404	0.21	0.63	0.008	0.9	0.65	0.1	+	Riv.
50	ANJANITIKITRA	NO U/L.																						
51	ANAUATAY	NOT ACCESSIBLE																						
52	SOAHARO	89/11/15 28.0	7.6	110	110	32.3	7.3	18.0	0.6	16	4	0.16	141.0	282	36	144	0.26	0.36	0.011	0.4	0.24	0.2	+	S.W.
53	ANALAHITSARPY	89/11/15 28.0	7.4	218	218	70.0	10.0	65.0	6.5	60	12	0.14	248.0	606	64	300	0.10	0.13	0.000	0.8	0.25	0.1	-	D.W. handpump
54	BELITSAKA	89/11/15 27.5	7.4	452	452	159.0	13.0	61.0	3.6	130	110	0.08	557.0	1110	66	286	0.20	0.30	0.000	0.9	0.00	0.1	+	D.W.
55	AMPASIKIBO	89/11/15 28.0	6.8	652	652	243.0	11.0	56.0	8.7	115	88	0.15	780.0	1560	136	375	0.33	0.09	0.019	0.1	0.09	0.1	+	D.W. handpump
56	NAMABOHA	89/11/15 27.0	7.3	420	420	142.0	17.0	11.0	16.0	14	57	2.18	414.0	827	112	395	0.25	4.36	0.021	1.0	0.12	2.4	+	S.W.
57	ANTSEVA	89/10/25	7.1	540	540	132.0	51.0	132.0	5.1	125	175	0.01	733.0	1470	89	472	0.33	0.08	0.002	0.2	0.38	0.0	+	D.W.
58	ANKATRAKATRA	89/11/15 27.0	6.9	42	42	11.0	3.4	8.3	11.0	12	12	2.21	76.0	152	44	56	0.31	1.72	0.028	1.0	0.00	0.1	+	S.W.
59	AMPHIANY	89/11/15 27.5	7.4	302	302	98.0	14.0	143.0	11.0	84	145	0.04	592.0	1180	70	350	0.20	0.24	0.006	0.5	0.24	0.0	+	S.W.
60	AMBONDRO	NOT ACCESSIBLE																						
TEMP.: °C																								

Temp.: °C
Hard, Acid, Alkali.: mg/l as CaCO₃

EC : µS/cm

Other items : mg/l

Table RESULTS OF WATER QUALITY ANALYSIS

NO.	LOCATION	DATE	Temp	pH	Hard.	Ca	Mg	Na	K	Cl	SO4	Fe	TDS	EC	Acid. Alkali	PO4	MH3-N	NO2-N	NO3-N	F	Mn	E. coli	NOTE
61	BEROROKA	NOT ACCESSIBLE																					
62	ANTOMARIFY	NOT ACCESSIBLE																					
63	MANORBO ATH	89/11/17 28.0	7.4	438	125.0	30.0	52.0	5.8	94	145	0.02	0.02	623.0	1250	62	274	0.13	0.13	0.030	6.2	0.44	0.0	D.W.
64	ANTANDROKA	89/11/17 29.0	7.4	332	118.0	8.7	18.0	3.9	42	100	0.02	0.02	371.0	742	44	178	0.02	0.05	0.025	4.6	0.43	0.0	D.W.
65	ANKARABATO	89/10/25	8.1	228	63.0	15.0	12.0	2.0	10	26	0.19	0.19	216.0	432	34	108	0.23	0.00	0.000	0.1	0.00	0.1	Riv.
66	ANDOHARANO	NOT ACCESSIBLE																					
67	TSEFANOKA	89/11/24 25.0	8.0	178	67.0	2.4	6.7	2.7	20	70	0.11	0.11	186.0	392	40	124	0.25	0.13	0.011	0.1	0.29	0.2	canal
68	BENETSY	89/11/16 28.0	7.5	288	60.0	10.0	13.0	6.9	16	110	0.19	0.19	238.0	476	28	94	0.39	0.21	0.036	0.0	0.51	0.1	canal
69	ANDREUBAS	89/11/17 27.0	7.0	336	102.0	20.0	172.0	16.0	230	60	0.02	0.02	754.0	1510	58	232	0.14	0.07	0.069	1.3	3.33	0.0	S.W. Spring
70	ANJANALA	NOT ACCESSIBLE																					
71	AMPITALIA	NOT ACCESSIBLE																					
72	SEHORPY	89/11/23 30.0	8.3	169	46.0	13.0	13.0	4.4	25	49	1.85	1.85	176.0	352	20	152	0.12	0.04	0.002	0.2	0.10	0.7	Riv.
73	AMBOKONKIRA	89/11/23 30.0	8.3	168	45.0	14.0	12.0	5.7	26	50	2.13	2.13	175.0	350	20	154	0.15	0.04	0.002	0.1	0.08	0.8	Riv.
74	MIARY	89/11/23 28.0	7.8	211	66.0	11.0	30.0	3.9	44	47	0.20	0.20	259.0	518	32	170	0.12	0.07	0.000	0.4	0.41	0.2	P.F.
75	BEFANARY	89/11/23 29.0	7.9	215	67.0	12.0	30.0	4.6	46	49	0.01	0.01	257.0	514	24	171	0.19	0.02	0.000	0.0	0.25	0.0	P.F.
76	TSIVONABE	89/11/16 28.0	7.4	384	88.0	34.0	135.0	22.0	330	92	0.00	0.00	839.0	1680	70	264	0.11	0.44	0.024	1.2	0.13	0.0	S.W.
77	ANDRANOORY	WATER VENDER																					
78	BEFOLY	WATER VENDER																					
79	ANKOROKOKA	WATER VENDER																					
80	ANBOHITAHAELONA	89/11/22 27.0	7.6	192	56.0	13.0	18.0	5.8	28	59	0.01	0.01	224.0	447	20	152	0.22	0.05	0.002	0.2	0.37	0.0	Riv.
81	MANOROKA	89/11/23 27.0	7.6	280	64.0	29.0	53.0	8.6	24	37	0.28	0.28	336.0	673	30	347	0.32	0.59	0.004	0.5	0.45	0.0	S.W. (1)
82	LABORANA	89/11/03	5.9	24	4.8	2.9	4.4	3.1	7	8	0.97	0.97	25.7	51	10	21	0.06	0.09	0.005	2.0	0.00	0.1	S.W. (1)
83	ANDRANOLAVA	89/11/03	7.8	181	54.0	11.0	9.9	6.5	12	18	0.03	0.03	186.0	373	32	154	0.13	0.24	0.008	0.0	0.29	0.0	Riv.
84	LANDONAKANDRO	89/11/03	8.3	108	36.0	2.4	9.5	7.9	10	1	3.83	3.83	113.0	226	45	108	0.10	0.17	0.000	0.0	0.30	0.3	Riv.
85	BESAKOA(1)	NOT ACCESSIBLE																					
86	BESAKOA(2)	89/10/26	6.2	2	0.4	0.2	1.9	4.0	4	4	0.35	0.35	15.5	31	15	5	0.17	0.00	0.003	0.1	0.12	0.2	S.W.
87	AMPANDRA	NO U/L																					
88	MANINDAY	89/11/20 26.0	6.6	5	0.4	1.0	2.4	4.1	7	8	0.80	0.80	18.5	37	11	5	0.85	0.10	0.006	0.7	0.00	0.6	Riv.
89	BEVOLAUO	NOT ACCESSIBLE																					
90	TANAHARO	89/11/20 27.0	7.1	232	67.0	15.0	47.0	74.0	66	136	0.06	0.06	430.0	859	44	198	0.27	0.07	0.017	1.5	0.57	0.2	S.W.

Temp.: °C

Temp.: °C

Hard. Acid. Alkali.: mg/l as CaCO3

EC : $\mu S/cm$

Other items : mg/l

Table RESULTS OF WATER QUALITY ANALYSIS

NO.	LOCATION	DATE	Temp	pH	Hard.	Ca	Mg	Na	K ₂	Cl	SO ₄	Fe	TDS	EC	Acid Alkali	PO ₄	MH ₃ -N	MH ₂ -N	MH ₃ -N	F	Mn	E. coli	NOTE	
91	ANBAHIMALITSY	89/11/03	33.5	7.8	48	14.0	3.4	5.2	6.4	15	9	1.58	62.7	125	20	45	0.10	0.005	0.0	0.00	0.2	+	Riv.	
92	MOHABOBOKA	89/11/21	28.0	8.0	96	29.0	5.6	8.7	6.9	17	24	5.10	124.0	247	16	80	0.09	0.000	0.0	0.00	0.4	+	Riv.	
93	MAHASOA	89/11/21	28.0	7.3	338	116.0	12.0	35.0	2.8	56	26	0.11	394.0	723	42	380	0.09	0.10	0.001	0.6	0.43	0.0	+	Riv.
94	ANDAMASINY-VINETA	89/11/21	26.0	8.2	206	74.0	20.0	33.0	3.3	46	55	0.10	317.0	634	30	258	0.32	0.10	0.003	0.0	0.51	0.2	+	Riv.
95	TRANOKAKY	WATER UNDER																						
96	ANALANDRY	89/11/20	25.5	5.8	6	0.4	1.2	0.1	4.9	7	3	2.42	29.1	58	34	9	0.41	0.63	0.031	1.9	0.00	1.8	+	S.W. Spring
97	ANTANIMORA	89/11/20	26.0	6.0	26	9.6	0.5	10.0	4.3	12	10	2.08	50.0	100	14	30	0.33	0.44	0.007	0.9	0.00	1.1	+	S.W.
98	BEREKETA	89/11/22	39.0	8.5	182	50.0	14.0	22.0	6.8	26	34	0.32	217.0	435	3	184	0.38	0.13	0.088	0.7	0.22	0.5	+	Riv.
99	ANKILIKITRLOKA	89/11/22	34.0	8.4	337	92.0	20.0	43.0	7.6	40	196	0.34	389.0	778	10	192	0.81	0.18	0.014	1.0	0.41	0.5	+	Riv.
100	ANKILIVALO	89/10/27		6.2	10	3.2	0.5	3.1	4.4	5	4	4.22	24.5	49	14	15	0.11	0.024	0.2	0.00	0.5	+	Riv.	
101	16 ANBIKY	89/11/11	29.0	7.5	378	164.0	29.0	100.0	37.0	142	102	0.00	611.0	1220	70	355	0.80	0.22	0.002	0.0	1.22	0.8	+	S.W.
102	27 BASIBASY	89/11/15	28.0	7.5	740	218.0	52.0	164.0	45.0	492	2	0.18	1160.0	2330	115	500	1.76	15.40	0.004	0.5	0.16	1.4	+	D.H. Private
103	ANTANIMIEVA	89/11/07	30.5	7.7	172	52.0	18.0	7.4	2.8	14	8	0.08	176.0	352	54	150	0.04	0.00	0.007	0.1	0.15	0.1	+	D.H. Spring
104	ANKAZOABO	89/11/01	27.0	7.4	340	132.0	4.4	54.0	15.0	88	37	0.00	572.0	1140	124	342	0.00	0.38	0.006	12.6	0.48	0.9	+	D.H. Private
105	52 SOAHZO	89/11/15		7.4	1120	103.0	172.0	601.0	13.0	928	775	0.11	2530.0	5070	123	490	0.19	0.79	0.032	1.7	0.61	0.1	+	D.H. Private
106	65 ANKARABATO	89/10/25		7.3	270	55.0	32.0	113.0	10.0	15	30	0.01	421.0	842	100	354	0.51	0.06	0.008	0.2	0.65	0.0	+	D.H. Hosp. HP
107	68 BENETSY	89/11/16	27.0	7.3	596	176.0	38.0	101.0	6.8	742	575	0.03	2440.0	4800	60	438	0.10	0.30	1.140	0.3	0.65	0.1	+	D.H. Hosp. HP
108	68 BENETSY	89/11/10	26.0	7.3	700	216.0	53.0	127.0	5.9	610	1680	0.06	3280.0	6500	90	530	0.75	0.63	0.146	4.6	0.79	0.0	+	D.H. (1) Hosp.
109	69 ANDREVOHAUT	89/11/17	29.0	7.8	214	72.0	8.2	8.3	4.5	14	105	0.18	229.0	458	22	102	0.74	0.35	0.015	0.5	0.44	0.4	+	D.H. (2)
110	69 ANDREVOHAUT	89/11/17	28.0	7.7	1380	222.0	199.0	194.0	48.0	1900	1800	0.15	4680.0	9370	112	532	1.90	1.70	0.008	0.0	0.63	0.2	+	Canal
111	77 ANDRANOVO	89/10/26		7.2	235	92.0	1.2	13.0	4.3	8	3	0.05	242.0	483	83	239	0.35	0.60	0.006	0.1	0.20	0.1	+	D.H.
112	81 MANOROKA	89/11/23	27.0	7.5	216	60.0	16.0	31.0	5.2	24	17	0.27	233.0	466	34	238	0.72	0.26	0.002	0.1	0.44	0.7	+	S.W.
113	94 ANDAMASINY-VINETA	89/11/21	27.5	7.6	140	54.0	1.5	3.1	5.4	7	5	0.13	146.0	292	25	180	0.19	0.10	0.001	1.0	0.14	0.4	+	D.H. (2)
114	95 TRANOKAKY	89/11/03	27.0	7.1	220	82.0	3.6	54.0	3.5	32	7	0.47	317.0	633	52	254	0.01	0.06	0.004	0.1	0.10	0.1	+	S.W.
115	TOLINARA	89/11/27	29.0	7.3	209	66.0	30.0	133.0	8.5	155	98	0.20	543.0	1085	58	250	0.41	0.03	0.001	0.6	0.43	0.1	+	D.H. Handpump
116																								
117																								
118																								
119																								
120																								

Temp.: °C

Temp.: °C
Hard. Acid. Alkali.: mg/l as CaCO₃
EC : μ S/cm
Other items : mg/l













Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (1)













Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (2)













Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (3)













Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (4)













Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (5)













Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (6)













Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (7)













Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (8)












Fig. HEXADIAGRAMS OF SHALLOW GROUNDWATER (9)

4. BRIEF REVIEW OF THE SOLAR PUMP SYSTEM

SOLAR PUMP SYSTEM

Harnessing solar energy is expected to be fully operational in the next century. High expectations of the early stages of research on the practical application of solar energy were dampened by the low price of fossil fuel in recent years. However, research has continued, seeking to reduce the cost of the initial investment, that is, the cost of photovoltaic cells. Solar energy has the following characteristics.

- (a) Independent and decentralized system
- (b) Fuel free
- (c) Simple operation and maintenance
- (d) Clean energy

Given these advantages, solar energy is considered to be practically usable in local water supply projects. Solar powered pump is one of the ideas of the practical utilization of this energy, as was already carried out in Mali by a JICA project. The objective of construction of a solar powered pilot facilities in this Project is to further examine the possibility of using solar power in rural water supply systems.

1. Climatic Condition in the Study Area

(1) Sunshine energy

The Madagascar government conducted a study on the potential of new energy sources as reported in "GISEMENTS SOLAIRE ET EOLIEN A MADAGASCAR", published in 1987. This report shows the statistics of sunshine and wind observations.

The following tables show sunshine hour, percentage of sunshine and solar radiation energy in Ranohira and Toliara stations.

(a) Sunshine hour

Year:1960-1984

unit:hours/day

		JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Ranohira	Mean	7.8	7.8	8.2	8.7	8.8	8.6	8.4	9.2	9.6	9.4	8.8	7.3
	Med.	8.5	8.4	8.9	9.2	9.4	9.2	9.2	10	10.2	10.3	9.4	7.7
	Min	0	0	0	0	0	0	0	0	0	0	0	0
	Max	12.8	12.5	11.8	11.1	10.8	10.5	10.8	11.1	11.3	12.2	12.7	12.5
Toliara	Mean	10.0	9.5	9.6	9.6	9.5	9.4	9.5	10.1	10.1	10.3	10.5	9.6
	Med.	11.3	11.0	10.8	10.5	10.2	10.0	10.1	10.6	10.6	11.0	11.6	11.1
	Min	0	0	0	0	0	0	0	0	0	0	0	0
	max	13.3	12.8	11.9	11.3	11.2	10.6	10.9	11.2	11.4	12.5	13.0	13.2

(b) Percentage of sunshine

Year:1960-1984

unit:%

		JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Ranohira	Mean	59.1	61.6	67.9	76.0	81.1	81.1	77.9	81.7	80.5	75.4	67.6	54.6
	Med.	64.6	66.2	74.1	80.9	86.3	86.6	85.7	89.1	86.3	82.1	71.1	57.6
Toliara	Mean	75.3	74.4	79.9	84.1	87.4	88.7	88.2	90.3	85.4	82.0	79.8	71.6
	Med.	85.6	86.7	89.6	91.7	94.4	94.6	94.4	94.3	89.3	88.1	88.4	82.7

(c) Solar radiation (global)

Year:1960-1984

unit:Wh/m2

		JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Ranohira	Mean	6354	6853	5851	5567	4903	4591	4712	5136	5662	5996	6403	6265
	Med.	6311	6515	5972	5750	4685	4506	4693	5319	5704	6304	6430	6187
	Min	2064	1439	930	2695	2845	2370	2117	2211	1278	899	2765	1959
	Max	9807	9773	8744	7372	8515	6135	6344	6384	7694	7868	6805	8942
Toliara	Mean	7184	8722	6178	5313	4477	4073	4261	5251	5803	6165	6851	6962
	Med.	7421	6965	6465	5525	4607	4120	4263	5319	6017	6267	7173	7430
	Min	2771	1645	404	2302	2097	2443	2160	2224	1114	2053	1274	1540
	Max	9244	8636	8174	7035	5902	5132	5452	6444	7376	8431	8953	8693

From the results of monthly radiation contour map for Madagascar was prepared as shown in Fig.A. According to this map, the southwestern region has the highest potentiality in Madagascar.

Since the Study Area is located on the tropic of Capricorn, radiation is low in July, and high in January. Maximum daily sunshine hours is highest in January, 12.8 and 13.3 hours/day being recorded at Ranohira and Toliara stations, respectively. Maximum daily sunshine hours is lowest in June, 10.5 hours/day in Ranohira and 10.6 hours/day in Toliara.

However, when these values are averaged, December shows the lowest value in Ranohira station. In the Ranohira station, only 50-60 % of original day light is available because of the frequency of rainy days during December-February.

In the end, monthly mean of solar radiation varied from 4000-4500 Wh/m² in June to 6400-7200 wh/m² in January in the Ranohira and Toliara stations, respectively. These values are quite enough to implement solar powered pump stations.

(2) Rainy days

Rainy days with more than 1mm, 5mm and 10mm, obtained from daily rainfall records in Toliara and Ankarabato stations, are examined as follows.

(a) Toliara station, 1979-1988

unit: No. of rainy days

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
R>1mm	4.9	5.5	3.2	2.1	0.8	2.0	0.7	0.7	0.8	1.4	2.1	4.2
R>5mm	2.7	3.4	1.8	1.2	0.4	0.5	0.3	0.3	0.4	0.5	1.2	2.4
R>10mm	2.1	2.5	1.4	0.8	0.3	0.1	0.1	0.2	0.3	0.2	0.9	1.9

(b) Ankaraobato station, 1972-1981

unit: No. of rainy days

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
R>1mm	9.1	8.9	5.3	2.7	1.9	2.6	1.1	0.9	1.6	1.9	3.9	10.2
R>5mm	7.2	6.4	3.3	1.8	0.9	0.9	0.5	0.3	0.9	0.9	2.6	8.3
R>10mm	5.5	5.2	2.4	1.4	0.3	0.3	0.2	0.1	0.5	0.6	2.0	6.1

These tables show 2-3 days in Toliara and 7-8 days in Ankaraobato with more than 5mm of rain as average. According to the field experience, rainfall is concentrated in a very short span in the afternoon or at night. Therefore, some sunshine hours can be expected even in these rainy days.

However, it is required an extra pumping system or a water storing facility for the days with insufficient solar energy and other emergencies.

2. Solar System for the Project

2.1 General

Climatic data from Antananarive station were used. Design of the facility was based on the following conditions.

- (a) Purpose: test facility for potable water
- (b) Water demand: 10 m³/day
- (c) Total head: 34 m
- (d) Climatic condition and pumping capacity

Item	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Total
Rad. (30°)	5.67	5.86	5.83	5.78	5.28	5.02	5.04	5.94	6.77	7.17	6.96	6.24	5.96
Tem.	27.2	27.1	26.4	24.7	22.3	20.3	19.8	20.5	22.1	23.7	25.2	26.5	23.8
Power Ratio	.518	.528	.527	.527	.483	.469	.472	.555	.627	.658	.633	.564	.546
Water Capa. (m3/day)	9.9	10.2	10.2	10.2	9.3	9.1	9.1	10.7	12.1	12.7	12.2	10.9	10.6

(e) Specification

Detailed specification is attached in Annex 1.

3. Results of Monitoring

In order to measure actual solar and pumping capacity, monitoring equipments were set in the solar pump system. However, mechanical troubles occurred in the system, thereby precluding start of detailed monitoring until March 1991.

As a way to overcome deficient monitoring equipments, pumping discharge was measured by reading the storage tank water level in November and December of 1990, as shown below.

Water level of the tank

unit:l

Time	Nov./18	Nov./22	Dec./19
8:00-9:00	484	581	-
-10:00	1210	1355	397
-11:00	1403	1592	580
-12:00	1452	1646	1468
-13:00	1113	1791	2129
-14:00	242	(1600)	1791
-15:00	-	(1500)	1113
-16:00	-	(1000)	871
-17:00	-	-	678
-18:00	-	-	-
	5904	11065	9027

However, these results are influenced by rain, cloudy sky, and "tank capacity". Pumping was once stopped before full tank, and water was supplied to the villagers. Therefore, the data of November/22 between 13:00 and 16:00 hours are estimated. The measurements of Nov./18 and Dec./19 were interrupted by rainfall.

From March 1991, monitoring equipment worked well and the following results were obtained.

Flow meter

unit: l

Time	Mar./20	Mar./21	Mar./22
8:00-9:00	-	-	-
-10:00	-	117	437
-11:00	-	595	974
-12:00	1065	1350	1325
-13:00	1227	1477	1305
-14:00	1313	1478	1317
-15:00	690	1241	1050
-16:00	-	141	256
-17:00	-	-	-
-18:00	-	-	-
Total	4295	6399	6664

During the rainy season, village people use other water sources, such as water stored in their own drum or dug-wells. Therefore, daily water consumption was smaller than in the dry season. As a result, care takers stopped the solar pump when the tank was full, without using up the full solar capacity.

The daily distribution of the radiation is presented in Fig.B. This figure showing the result of Mar.22 gives a relatively complete picture of this season. The pump was operated between 9:00-16:00 hours.

Maximum radiation is almost 6.0 mV equipment to 0.8 kW/m², and 4.5 mV equipment to 0.6 kW/m². Accumulated radiation during this period is calculated as follows.

$$(0.8+0.6)/2 \times 3 \text{ hrs} + 0.8 \times 2 \text{ hrs} + (0.8+0.6) \times 2 \text{ hrs} \\ = 5.1 \text{ kWh/day}$$

Actual inclined radiation on solar panel should be smaller than this amount, with an estimated discharge capacity of 6.7 m³/day.

Considering the above records, the following comparison can be made.

Month	Q Max. (l/min)	Q Daily (m3)	Time Design (hrs)	Q (m3)	Remarks
November	30	11.1	8	12.2	
December	35	(9.0)	8	10.9	with rainfall
March	22	6.7	7	10.2	

Even in March, daily capacity is different from designed capacity because of the difference in radiation value. Daily radiation is lower from November to March, and, the lower peak occurs in June (both in monthly average and monthly maximum). Therefore, in order to consider the design-base, this system must be maintained at least up to next March 1992.

Operation and maintenance of the solar system is quite simple when the line from converter/solar battery is directly connected to the submersible pump. This connection is possible when the motor and pump are under water during operation. No special knowledge is required for the care-takers. Only the surface of solar panels have to be kept clean because dirt lowers the energy efficiency. Also since the solar panel is easily breakable, a caretaker or guardsman should be watching night and day against vandals.

4. Evaluation and recommendation

(1) Cost of operation

(a) Model village

- (i) Population: 1000
- (ii) Unit water consumption: 20 l/person/day
- (iii) Total head of the well: 25m
- (iii) Revenue from village

1 household = 7 persons
 1000 people = 143 households
 1 household pays 200 FMG/month

Total revenue from the model village will be
 $143 \times 200 \times 12 = 343,200 \text{ FMG /year}$

(b) Investment

For the solar pump operation, components include solar system, submersible motor pump, portable generator, head tank, pipeline and public hydrant. As alternative, pumping system with diesel generator and handpump system is discussed. Most of equipment cost is adopted from the pilot facility constructed during the Study.

(i) Solar pump system

Item	Unit cost	Quantity	Cost	Remarks
Solar system	3,800,000	1set	3,800,000	Incl. spare parts
Submersible motor pump	400,000	1set	400,000	Incl. spare parts
Portable generator (gasoline)	150,000	1set	150,000	Incl. spare parts
S-Total			4,350,000 yen	
Shipment etc. (25 %)			1,087,500 yen	
Foreign Total /10.5			5,437,500 yen 57,000,000 FMG	
Civil Works				
Head tank				
Pipeline				
Public hydrant				
S-Total			40,000,000 FMG	
Total			97,000,000 FMG	

(ii) Generator and pump system

In place of the portable generator, diesel generator is used for this system, including construction of a generator house.

unit:yen

Item	Unit cost	Quantity	Cost	Remarks
Generator (diesel)	950,000	1set	950,000	Incl. spare parts
Civil Works				
Generator house			400,000	FMG

(c) Pump Operation Schedule

Basically, solar system will be backed up by gasoline generator for rainy days or cases of machinery trouble.

In order to estimate annual operating time of gasoline generator, average rainy days at Ankaraobato station is used as shown below.

Daily Rainfall (mm/day)	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
1<R<10	3.6	3.7	2.9	1.3	1.6	2.3	0.9	0.8	1.1	1.3	1.9	4.1
10<R	5.5	5.2	2.4	1.4	0.3	0.3	0.2	0.1	0.5	0.6	2.0	6.1

When daily rainfall is more than 10 mm/day, operating time of generator is assumed to be full day, while if daily rainfall is between 1 and 10 mm/day, operating time is assumed to be a half day. In the end, annual operating time is calculated as follows.

$$25.5 \times 0.5 + 24.6 \times 1.0 = 37.35 \text{ days}$$

Total head of the well is assumed as 25 m. From the capacity of submersible pump, 75 l/min is expected by generator(full capacity). When solar pump system is used, full capacity is not expected because of the variation of the radiation. Therefore, average capacity is assumed as 80%, or 60 l/min.

Water demand: 20 m3/day

Item	Generator system	Solar system
Pump capacity	75 l/min	60 l/min(average)
Pumping time	4.5 hr/day	5.6 hr/day
Annual operation time of generator (hrs.)	1643 hr (365 day)	213 hr (38 day)

(d) Unit cost

--- Fuel

Item	Unit cost	Remarks
Diesel	422 FMG/l	
Gasoline	840 FMG/l	

--- Efficiency of the generator

Item	Generator Capacity(kVA)	Output (PS)	Fuel (l/h)
Diesel	5.5	10	0.6
Gasoline	1.3	2.2	1.1

Fuel consumption is calculated
for diesel

Fuel consumption = Output x Consumption rate (0.117) x 0.5

for gasoline

Fuel consumption = Output x Consumption rate (0.5)

(e) Replacement, operation and maintenance costs

(i) Other items (spare parts, etc.)

Solar system --- 100,000 FMG/year

Generator system --- 50,000 FMG/year

(ii) Wages for care-taker

60,000 FMG/year

(iii) Dues for the central organization

30,000 FMG/year (periodic patrol)

(iv) Replacement

- Solar panel

50 % of replacement in 15 years

- Generator

Replacement in 8 years for diesel

Replacement in 5 years for gasoline

- Submersible Pump

- Other small equipments

Cash flow of this model is shown in Table 1 and 2.

In this table, calculation is performed by " ".

From this flow, following results can be considered;

(a) Investment and replacement costs of both systems are not so different for the estimated 30 years useful life.

(b) In the case of the solar system, O&M and fuel cost is well balanced with the revenue from the village.

(2) Recommendation

From these cash flows, a solar pump is considered a viable system for rural communities like the Study Area, if investment and replacement costs are neglected.


It is still difficult to expect rural people pay all of investment cost for a mechanical pumping system, or even for the replacement.

However, they are able to cover operation and maintenance cost, including fuel cost. From this point of view, the O&M cost of the solar system is cheaper than the cost of the generator system.

It should be pointed out that no reliable climatic data for solar systems are available in the Study Area. Therefore, the pilot solar pump station of the Study is expected to provide the necessary data of the actual condition in a few years. When these data become available, complete reviews should be made on the practical use of solar energy for pumping water supply systems in southern Madagascar, as well as on the economic condition of villages.

Fig.

MAYENNE ANNUELLE DEL I'IRRADIATION SOLAIRE GLOBALE
(en kWh/m²/jour)



SOURCE: GISEMENTS
SOILAIRE ET EOLIEN
A MADAGASCAR, 1987

Distribution of Daily Radiation

by Solar Meter (7mV/kW/m²)





Fig.B DIALY DISTRIBUTION OF RARIATION

1. GENERAL


This technical specification describes the photovoltaic equipment for water pumping and measuring installed in Madagascar as a test facility.

2. SYSTEM DIAGRAM

(1) Water pumping system



(2) Measuring system



3. DESIGN CRITERIA

- 1) Location : Madagascar / south-west area
- 2) Total head : 34 m
 - : (Static water level 10m)
 - : (Dynamic water level 30m)
 - : (Water tank height 4m)
- 3) Water demand : 10 m³/day
- 4) Water source : Deep well
- 5) Water quality : Potable water
- 6) Well diameter : 100 mm
- 7) Purpose : Test facility

4. CLIMATIC DATA

- 1) Irradiation data : Monthly mean daily global horizontal solar radiation at Tananarive
(lat. 18 54' S, long. 47 32' E, elv. 1310m)
- 2) Temperature data : Monthly mean atmospheric temperature at Toliara
(lat.23 24'S,long.43 44'E,elv.9m)

5. RESULT OF CALCULATION

1) Climatic data for simulation

ITEM	J	F	M	A	M	J	J	A	S	O	N	D	Yr.
IRRADIATION (KWh/m ² /day)	5.98	5.95	5.70	5.42	4.72	4.24	4.43	5.49	6.53	7.20	7.26	6.74	4.99
TEMPERATURE (°C)	27.2	27.1	26.4	24.7	22.3	20.3	19.8	20.5	22.1	23.7	25.2	26.5	23.8

2) Simulated pumping capacity

ITEM	J	F	M	A	M	J	J	A	S	O	N	D	Yr.
IRRADIATION at 30 deg.	5.67	5.86	5.83	5.78	5.28	5.02	5.04	5.94	6.77	7.17	6.96	6.24	5.96
POWER RATIO	.518	.528	.527	.527	.483	.469	.472	.555	.627	.658	.633	.564	.546
WATER CAP. (m ³)	9.9	10.2	10.2	10.2	9.3	9.1	9.1	10.7	12.1	12.7	12.2	10.9	10.6

6. SPECIFICATION

(1) Pumping system

1) Module

Item	Specification
Model	LA361J48
Type	Multi crystal silicone
Cell size	100x100 mm
Nos. of cell	36 pcs.
Frame material	Aluminum
Weight	5.9 kg

2) Array

Item	Specification
Model	SAG-486
Construction	Module 6 pcs.
Tilt angle	25 deg.
Frame material	Aluminum
Wind Velocity	Up to 40 m per sec.

ITEM	CLASS	MODULE		SOLAR ARRAY		TOTAL	
Type		LA361J48		SAG-456			
Nos of module/or array		Module 1 pc.		Module 6 pcs.			
System voltage		12 V				270 V	
		typical	minimum	typical	minimum	typical	minimum
Maximum output power (Pm)		48.0 W	45.6 W	288.0 W	273.6 W	864 W	820.8 W
Optimum voltage (Vm)		16.7 V	16.7 V	100.2 V	100.2 V	300.6 V	300.6 V
Optimum current (Im)		2.88 A	2.73 A	2.88 A	2.73 A	2.88 A	2.73 A
Open circuit voltage (Voc)		20.7 V	18.6 V	124.2 V	111.6 V	372.6 V	334.8 V
Short circuit current (Isc)		3.10 A	2.79 A	3.10 A	2.79 A	3.10 A	2.79 A

Conditions

1. Irradiation
2. Cell temperature

100mW/cm² AM 1.5

25°C

3) Photovoltaic Inverter

Model	SPI-1
Series connection of photovoltaic modules	LA361J48 type module x 18 series
Rated input (photovoltaic)	Max. 864 Wp
Rated input voltage Rated input current	270VDC \pm 5% (Max. 372.6VDC) Max. 6.2 ADC
Rated output	
Rated output voltage Output frequency	* Max. 200 VAC Max. 60 Hz * 3-phase variable voltage matched with the voltage requirements of the pumps.
Function	(1) Input voltage regulation circuit (2) Over-voltage protection circuit (3) Over-heat protection circuit
Switch	ON-OFF switch to connect (or disconnect) the solar array to the main circuit
Insulation resistance	More than 10M Ω (DC500V megger)
Dielectric strength	DC500V one minute
Operating temperature	-10°C - +45°C
Dimension	Refer to DWG. No. MDS-511

4) Submersible motor / pump

Item	Specification
Model	SA2A-13
Type	Submersible motor pump
Rated output	0.55 kW
Frequency	50 Hz
Phase x Volt	3 x 200 V
Amperage	3.9 A
Poles	2
Revolution	3000 r.p.m.
Discharge size	25 A
Material	Stainless steel

Cash flow
(1) Solar pump system

Unit:1000 FMG

Year	Investment & Replace	O&M	Revenue
1	97000	357	343
2	-	357	343
3	-	357	343
4	-	357	343
5	-	357	343
6	2000	357	343
7	-	357	343
8	5250	357	343
9	-	357	343
10	-	357	343
11	2000	357	343
12	-	357	343
13	-	357	343
14	-	357	343
15	-	357	343
16	35190	357	343
17	-	357	343
18	-	357	343
19	-	357	343
21	2000	357	343
22	-	357	343
23	-	357	343
24	5250	357	343
25	-	357	343
26	2000	357	343
27	-	357	343
28	-	357	343
29	-	357	343
30	-	357	343

(2) Generator pump system

Unit:1000 FMG

Year	Investment & Replace	O&M	Revenue
1	111600	606	343
2	-	606	343
3	-	606	343
4	-	606	343
5	-	606	343
6	-	606	343
7	-	606	343
8	17800	606	343
9	-	606	343
10	-	606	343
11	-	606	343
12	-	606	343
13	-	606	343
14	-	606	343
15	-	606	343
16	17800	606	343
17	-	606	343
18	-	606	343
19	-	606	343
20	-	606	343
21	-	606	343
22	-	606	343
23	-	606	343
24	17800	606	343
25	-	606	343
26	-	606	343
27	-	606	343
28	-	606	343
29	-	606	343
30	-	606	343

5. SELECTION OF THE PUMP SYTEM

Selection of the Pump System

It is important to select more advantageous lifting system for implementation plan of water supply facility.

The final comparison is performed in 4 villages, Manoy, Antseva, Ankatrakatra and Ambondra, expected promising aquifer with shallow groundwater level.

Basically, it is necessary to consider many factors in order to decide which system is suitable for candidate village. Village's individual conditions of economy and living standard are background to make final decision of the system selection. And, required service level must be considered by the hard and soft viewpoints, such as investment cost, operation and maintenance cost and facility/organization management capability.

However, in order to simplify this argument, only investment cost is used for this comparison in this time.

At least concerning investment, cost of three handpumps is equal to mechanized pump systems. Therefore, handpump system is selected for these villages.

Comparison of Handpump and Mechanized pump

unit:US\$

Village	No.	Population	G.W.C.	Motor Pump	Handpump	
					(3)	(4)
Manoy	22	707	21	57570	37046	49395
Antseva	57	1048	21	73928	56816	75755
Ankatrakatra	58	603	19	58410	56816	75755
Ambondro	60	1310	26	63480	43636	58181

G.W.C. --- Gross Water Consumption (m3/day)

pump discharge rate:

motorized pump --- 6 hours a day

handpump --- 4-7 m3/day

1. Manoy

No; 22

Population in 2000; 707

Gross Water Consumption; 21 m3/day

Type; WHP-CT

Handpump

ITEM	SPECIFICATION	QUANTITY	COST(US\$)
Well construction	ø4" x 40.0 m	3	26,360
Pumping Test		3	5,242
Handpump	20 l/sec x 10 m	3	3,478
Concrete Base		3	1,966
Total			37,046

Motor pump

ITEM	SPECIFICATION	QUANTITY	COST(US\$)
Well construction	ø4" x 40.0 m	1	8,787
Pumping Test		1	5,242
Motor pump	21.0l/sec x 20 m		19,943
Generator	10 KVA	1	10,650
Pump House	3 m x 4 m	1	5,286
Tank	10 m3	1	17,620
Pipe line	3"	250 m	1,941
Joint			582
Standpost		2	1,607
Total			57,570

2. Village; Antseva

No; 57

Population in 2000; 1048

Gross Water Consumption; 23 m3/day

Type; WHP

Handpump

ITEM	SPECIFICATION	QUANTITY	COST(US\$)
Well construction	ø4" x 70.0 m	3	46,129
Pumping Test		3	5,242
Handpump	20 l/sec x 20 m	3	3,478
Concrete Base		3	1,966
Total			56,816

Motor pump

ITEM	SPECIFICATION	QUANTITY	COST(US\$)
Well construction	ø4" x 70.0 m	1	15,376
Pumping Test		1	1,747
Motor pump	21.0l/sec x 26 m		19,943
Generator	10 KVA	1	10,650
Pump House	3 m x 4 m	1	5,286
Tank	10 m3	1	17,620
Pipe line	3"	250 m	7,762
Joint			2,329
Standpost		4	3,214
Total			57,570

3. Village; Ankatrakatra

No;58

Population in 2000; 603

Gross Water Consumption; 19 m3/day

Type; WHP-CT

Handpump

ITEM	SPECIFICATION	QUANTITY	COST(US\$)
Well construction	ø4" x 70.0 m	3	46,129
Pumping Test		3	5,242
Handpump	20 l/sec	3	3,478
Concrete Base		3	1,966
Total			56,816

Motor pump

ITEM	SPECIFICATION	QUANTITY	COST(US\$)
Well construction	ø4" x 70.0 m	1	15,376
Pumping Test		1	1,747
Motor pump	20 l/sec x 20 m		19,943
Generator	10 KVA	1	3,804
Pump House	3 m x 4 m	1	5,286
Tank	10 m3	1	17,620
Pipe line	3"	300 m	2,329
Joint			699
Standpost		2	1,607
Total			58,410

4. Ambondro

No; 60

Population in 2000; 1,310

Gross Water Consumption; 26 m3/day

Type; WMP

Handpump

ITEM	SPECIFICATION	QUANTITY	COST(US\$)
Well construction	ø4" x 50.0 m	3	32,950
Pumping Test		3	5,242
Handpump	20 l/sec	3	3,478
Concrete Base		3	1,966
Total			43,636

Motor pump

ITEM	SPECIFICATION	QUANTITY	COST(US\$)
Well construction	ø4" x 50.0 m	1	10,983
Pumping Test		1	1,747
Motor pump	26.0l/sec x 21 m		19,943
Generator	10 KVA	1	10,650
Pump House	3 m x 4 m	1	5,286
Tank	10 m3	1	17,620
Pipe line	3"	400 m	3,105
Joint			931
Standpost		4	3,214
Total			63,480

APPENDIX (1)

LIST OF COLLECTED DATA

BIBLIOGRAPHIE

01. Patrick RAJOELINA & Alain RAMELET, "MADAGASCAR, la Grande Ile", Editions l'Harmattan, 1989
02. Hubert DESCHAMPS, "Madagascar", Collection QUE SAIS-JE?, No.529
03. "Bulletin semestriel de Statistiques Sanitaires", Ministère de la Santé, Direction des Services Sanitaires et Médicaux, 1987
04. "Cahiers démographiques des Fokontany, les résultats obtenus en 1987 et 1988", Ministère de la Santé, Direction des services sanitaires et médicaux, 1989
05. "Etude des Ressources en Eaux Souterraines à Madagascar, Annexe I - Planches", ONU, 1966
06. "Etude des Ressources en Eaux Souterraines à Madagascar, Annexe II - Equipement et essais de pompage dans les forages S12 et S12bis", ONU, 1966
07. "Etude des Ressources en Eaux Souterraines à Madagascar, Annexe III - Notices explicatives et Carte phréatique entre Fiherenana et Manogoky", ONU, 1966
08. "Etude des Ressources en Eaux Souterraines à Madagascar, Annexe IV - Hydrochimie", ONU, 1966
09. "Etude des Ressources en Eaux Souterraines à Madagascar, Annexe V - Implantations précises recommandées pour les forages artésiens dans le cadre d'un premier projet de mise en valeur de la plaine de Befandriana", ONU, 1966
10. "Etude des Ressources en Eaux Souterraines à Madagascar, Annexe VI - Etudes complémentaires relatives à la nappe captive de Befandriana", ONU, 1966
11. "Etude des Ressources en Eaux Souterraines à Madagascar, Annexe VII - Coupes de forages", ONU, 1966
12. "Etude des Ressources en Eaux Souterraines de la Plaine de Morondava, Annexe I - Forages et essais de pompage", PNUD, 1970
13. "Etude des Ressources en Eaux Souterraines de la Plaine de Morondava, Annexe II - Chimie des eaux", ONU, 1970
14. "Etude des Ressources en Eaux Souterraines de la Plaine de Morondava, Annexe III - Fluctuations des nappes", ONU, 1970
15. "Etude des Ressources en Eaux Souterraines de la Plaine de Morondava, Annexe IV - Hydrogéologie de la ville de MORONDAVA", ONU, 1970
16. "EAU POTABLE PUBLIQUE, Production par unité productrice, zones desservies"
17. "Note technique concernant le Projet d'Exploitation d'Eaux Souterraines de la Région comprise entre l'Onilahy et Morondava", Ministère de l'Industrie, de l'Energie et des Mines, sept.1987
18. "Approvisionnement en Eau et Assainissement de Tananarive, Tome VII - Programmation nationale pour l'Approvisionnement en eau et l'Assainissement à Madagascar", OMS, juin 1975
19. "Programme d'Investissement Public 1989-91, 1990-92, 1991-93"
20. "Répartition des Formations sanitaires - 1988"
21. "Barèmes tarifaires eau - janvier 1990", JIRAMA, janv.1990
22. "Bilan des Travaux exécutés par l'AID dans la province de Tuléar de novembre 1963 au 15 août 1965", Ministère de l'Industrie, de l'Energie et des Mines, sept.1965
23. "Planning d'exécution des Travaux de 22 forages dans la Région Nord-Ouest de Madagascar", Ministère de l'Industrie, de l'Energie et des Mines, mai 1989
24. "Ressources en Eaux Souterraines de la Région de Tuléar, Résumé des Connaissances acquises - Note sommaire sur les études complémentaires à entreprendre", Ministère de l'Industrie, de l'Energie et des Mines, mars 1967
25. Henri BESAIRIE, "Géologie de Madagascar, I - Les terrains sédimentaires", Annales géologiques de Madagascar, Fascicule XXXV, 1972

26. "Rapport d'exécution de deux forages pour l'Alimentation en eau du poste sanitaire d'Ankilizato et du centre médical de Mandabe", Ministère de l'Industrie, de l'Energie et des Mines
27. "Approvisionnement en eau potable et Assainissement en milieu rural", OMS & Banque Mondiale, nov.1982
28. "Guide des Affaires à Madagascar", édition 1986/87
29. Pakotondrainibe Jean HERIVÉLO, "Les eaux souterraines de Madagascar", avril 1983
30. "Rapport Economique et Financière, année 1989", Ministère de l'Economie et du Plan
31. "Rapport sur la situation actuelle, secteur Eau et Assainissement", PNUD & Banque Mondiale, oct.1989
32. "Plan 1986-90", Journal officiel No.1755, juillet 1986
33. "Programme d'études et de travaux d'AEP", Ministère de l'Industrie, de l'Energie et des Mines
34. L. Andriamihaja, "L'organisation financière de Madagascar"
35. "Bulletin mensuel de Statistique (Edition spéciale)", No.372-83, Direction générale de la Banque des données de l'Etat, mars 1987
36. "Situation économique au 1er janvier 1988", Direction générale de la Banque des données de l'Etat
37. "Inventaire socio-économique, Tomes 1 et 2", Direction générale de la Banque des données de l'Etat, fév.1988
38. "Investir à Madagascar", Ministère de l'Industrie, de l'Energie et des Mines, 1990
39. Jean-Michel HOERNER, "Géographie régionale du Sud-Ouest de Madagascar", Association des Géographes de Madagascar, 1986

APPENDIX (2)

WELL INVENTORY SHEET

DEMOCRATIC REPUBLIC OF MADAGASCAR
MINISTRY OF INDUSTRIES, ENERGY AND MINES
DIRECTORATE OF ENERGY AND WATER
SERVICE OF WATER AND HYDROGEOLOGY

BOREHOLE LOCATION


1	PRESENT OWNER:	3	REGION:
	PREF., TOWN, VILLAGE:	4	NWRC WELL NO.
2	ORIGINAL WELL NO.:	5	MAP NO. SCALE:

DATA	TRANSFERRED FROM WELL LOG	ON SITE GATHERED DATA
6 DRILLING COMPLETION DATE/BY:	a	b
7 CASING DIAMETER	a	b
8 DRILLING DEPTH	a B.G.R.	b
9 WATER LEVEL DEPTH	a B.G.R.	b
10 DISCHARGE	a	b
11 DRAWDOWN	a	b
12 TYPE OF SCREEN AND PERFORATION	a	b
13 INFORMATION WRITTEN BY:	14 TYPE/HP. OF PUMP:	
23 REMARKS:	15 WATER ANALYSES: PCB	
	16 USE:	
	17 INFORMATION GIVEN BY:	
18 MEASURING WATER LEVEL POSSIBLE? Yes No		
19 GROUND ELEVATION: M ^A M ^B M.S.L.		
20 WATER LEVEL DEPTH: M ^A M ^B		
21 WATER LEVEL ELEVATION: M ^A M ^B M.S.L.		
22 VERTICAL SKETCH OF WELL		

24 SKETCH OF WELL SITE

MAP NO.
SCALE
DISTANCES FROM THE EDGES OF THE MAP IN MILLIMETERS

N



S

W

E

25	LOCATED ON:	26	BASIN'S NO. & NAME:
	BY:	27	COORDINATES:
			LAT. LONG.

DEMOCRATIC REPUBLIC OF MADAGASCAR MINISTRY OF INDUSTRIES, ENERGY AND MINES DIRECTORATE OF ENERGY AND WATER SERVICE OF WATER AND HYDROGEOLOGY												WELL LOG RECORD SHEET		
1	PRESENT OWNER: REGION:			WELL NO.: 3.			25	26	27	SHORT DESCRIPTION OF PENETRATED DATA				
2	LOCALITY			ORIGINAL WELL NO.										
2a	BASIN NO.:			BASIN NAME:										
3	MAP NO./SCALE:			4	COORDINATES:									
5	COMPLETION DATE:			6			ELEVATION OF GROUND:							
7	CASING DIAMETER:			8	CASING BELOW GROUND:									
9	DIAMETER			FROM			TO							
SCREEN			1.											
			2.											
			3.											
			4.											
10	TYPE OF SCREEN & PERFORATION													
11	BELOW GROUND			DATE			ELEVATION							
STATIC WATER LEVEL			1.											
			2.											
			3.											
			4.											
12	LATER. MEAS. OF W.L.:													
13	M ³ /H/M:						14			IN MIN:				
14	PUMP TEST PERFORMED			Yes	No	16	STORAGE COEFF.			17	TM ² /hr.:			
18	WATER RIGHT DATE:						19			WATER RIGHT QUANTITY: M ³ /HR				
20	WATER ANALYSES:			21			SIEVE TEST ANALYSES:			22	DESCRIPTION OF SAMPLES:			
23	SAMPLE BOX NOS.:													
24	DATE AND WRITTEN BY:													
28	REMARKS:													