

Benefit Cost Ratio Calculation : Naradaw P= 1.600 kW
 In Case of Carabau 2 x 1000 kW

Input Data : Naradaw P= 1.500 kW
 Year of Start (n=0) 1997

Year	n	I/I-1 n	Cost Stream		Benefit Stream			
			Naradaw		Alternative (Diesel)			
			Invest.	C Value	Invest.	Fuel	Total	B Value
1997	0	1.000	1.150	1.150	0	0	0	0
1998	1	0.909	6.900	6.273	488	0	488	444
1999	2	0.826	3.450	2.851	488	0	488	403
2000	3	0.751	173	130	49	841	890	669
2001	4	0.683	173	118	49	953	1.002	684
2002	5	0.621	173	107	49	1.070	1.119	595
2003	6	0.564	173	98	49	1.190	1.239	700
2004	7	0.513	173	89	49	1.301	1.350	693
2005	8	0.467	173	81	49	1.408	1.457	680
2006	9	0.424	173	73	49	1.476	1.525	647
2007	10	0.386	173	67	49	1.528	1.577	608
2008	11	0.350	173	61	49	1.569	1.618	567
2009	12	0.319	173	55	49	1.602	1.651	526
2010	13	0.290	173	50	49	1.634	1.683	487
2011	14	0.263	173	46	49	1.649	1.698	447
2012	15	0.239	173	41	49	1.661	1.710	409
2013	16	0.218	173	38	537	1.672	2.209	481
2014	17	0.198	173	34	537	1.681	2.218	439
2015	18	0.180	173	31	49	1.689	1.738	313
2016	19	0.164	173	28	49	1.696	1.745	285
2017	20	0.149	173	26	49	1.696	1.745	259
2018	21	0.135	173	23	49	1.696	1.745	236
2019	22	0.123	173	21	49	1.696	1.745	214
2020	23	0.112	173	19	49	1.696	1.745	195
2021	24	0.102	173	18	49	1.696	1.745	177
2022	25	0.092	173	16	49	1.696	1.745	161
2023	26	0.084	173	15	49	1.696	1.745	146
2024	27	0.076	173	13	49	1.696	1.745	133
Total			11.572					11.699

Year	n	Naradaw		Year
		Invest.	Diesel Invest. kWh	
1997	0	1.150	0	1997
1998	1	6.900	488	1998
1999	2	3.450	488	1999
2000	3	173	49	2000
2001	4		5.446	2001
2002	5		6.117	2002
2003	6		6.802	2003
2004	7		7.437	2004
2005	8		8.044	2005
2006	9		8.437	2006
2007	10		8.733	2007
2008	11		8.968	2008
2009	12		9.157	2009
2010	13		9.337	2010
2011	14		9.420	2011
2012	15		9.491	2012
2013	16		9.555	2013
2014	17		9.608	2014
2015	18		9.649	2015
2016	19		9.691	2016
2017	20		9.691	2017
2018	21		9.691	2018
2019	22		9.691	2019
2020	23		9.691	2020
2021	24		9.691	2021
2022	25		9.691	2022
2023	26		9.691	2023
2024	27	173	49	2024

B/C 1.01
 B-C 128

Input Data : Naradaw P= 1.600 kW
 Year of Start (n=0) 1993

Year	n	Naradaw		Year
		Invest.	Diesel Invest. kWh	
Const.	0	1.150	0	1993
Const.	1	6.900	488	1994
Const.	2	3.450	488	1995
Opera.	3	173	49	1996
Opera.	4		4.628	1997
Opera.	5		5.507	1998
Opera.	6		6.390	1999
Opera.	7		7.351	2000
Opera.	8		7.999	2001
Opera.	9		8.471	2002
Opera.	10		8.796	2003
Opera.	11		9.044	2004
Opera.	12		9.256	2005
Opera.	13		9.407	2006
Opera.	14		9.532	2007
Opera.	15		9.631	2008
Re-Const	16		488+49	2009
Re-Const	17		488+49	2010
Opera.	18		49	2011
Opera.	19		9.691	2012
Opera.	20		9.691	2013
Opera.	21		9.691	2014
Opera.	22		9.691	2015
Opera.	23		9.691	2016
Opera.	24		9.691	2017
Opera.	25		9.691	2018
Opera.	26		9.691	2019
Opera.	27	173	49	2020

Benefit Cost Ratio Calculation : Naradaw P= 1.600 kW
 In case of Carabau 1 x 1000 kW

Year	n	1/1.1 n	Cost Stream		Benefit Stream		
			Naradaw		Alternative (Diesel)		
			Invest.	C Value	Invest.	Fuel	Total
1993	0	1.000	1.150	1.150	0	0	0
1994	1	0.909	6.900	6.273	488	0	488
1995	2	0.826	3.450	2.851	488	0	488
1996	3	0.751	173	130	49	562	711
1997	4	0.683	173	118	49	810	859
1998	5	0.621	173	107	49	964	1.013
1999	6	0.564	173	98	49	1.118	1.157
2000	7	0.513	173	89	49	1.286	1.335
2001	8	0.467	173	81	49	1.400	1.449
2002	9	0.424	173	73	49	1.482	1.531
2003	10	0.386	173	67	49	1.539	1.588
2004	11	0.350	173	61	49	1.583	1.632
2005	12	0.319	173	55	49	1.620	1.669
2006	13	0.290	173	50	49	1.646	1.695
2007	14	0.263	173	46	49	1.668	1.717
2008	15	0.239	173	41	49	1.685	1.734
2009	16	0.218	173	38	537	1.696	2.233
2010	17	0.198	173	34	537	1.696	2.233
2011	18	0.180	173	31	49	1.696	1.745
2012	19	0.164	173	28	49	1.696	1.745
2013	20	0.149	173	26	49	1.696	1.745
2014	21	0.135	173	23	49	1.696	1.745
2015	22	0.123	173	21	49	1.696	1.745
2016	23	0.112	173	19	49	1.696	1.745
2017	24	0.102	173	18	49	1.696	1.745
2018	25	0.092	173	16	49	1.696	1.745
2019	26	0.084	173	15	49	1.696	1.745
2020	27	0.076	173	13	49	1.696	1.745
Total			11.572				11.590

B/C 0.98

B-C -182

Benefit Cost Ratio Calculation : Naradaw P= 1.600 kW

In case of Carabau 1 x 1000 kW

Input Data : Naradaw P= 1.600 kW

1994

Year of Start (n=0)

Year	n	Naradaw Invest.		Diesel kwh	Year
		Invest.	Invest.		
Const.	0	1.150	0	0	1994
Const.	1	6.900	488		1995
Const.	2	3.450	488		1996
Opera.	3	173	49	4.628	1997
Opera.	4			5.507	1998
Opera.	5			6.390	1999
Opera.	6			7.351	2000
Opera.	7			7.999	2001
Opera.	8			8.471	2002
Opera.	9			8.796	2003
Opera.	10			9.044	2004
Opera.	11			9.256	2005
Opera.	12			9.407	2006
Opera.	13			9.532	2007
Opera.	14			9.631	2008
Opera.	15			9.691	2009
Re-Const	16		488 + 49	9.691	2010
Re-Const	17		488 + 49	9.691	2011
Opera.	18			9.691	2012
Opera.	19			9.691	2013
Opera.	20			9.691	2014
Opera.	21			9.691	2015
Opera.	22			9.691	2016
Opera.	23			9.691	2017
Opera.	24			9.691	2018
Opera.	25			9.691	2019
Opera.	26			9.691	2020
Opera.	27	173	49	9.691	2021

Year	n	1/1.1 ⁿ	Cost Stream		Benefit Stream		
			Naradaw		Alternative (Diesel)		
			Invest.	C Value	Invest.	Fuel	Total
1994	0	1.000	1.150	1.150	0	0	0
1995	1	0.909	6.900	6.273	488	0	488
1996	2	0.826	3.450	2.851	488	0	488
1997	3	0.751	173	130	49	810	859
1998	4	0.683	173	118	49	964	992
1999	5	0.621	173	107	49	1.118	1.167
2000	6	0.564	173	98	49	1.286	1.335
2001	7	0.513	173	89	49	1.400	1.449
2002	8	0.467	173	81	49	1.482	1.531
2003	9	0.424	173	73	49	1.539	1.588
2004	10	0.386	173	67	49	1.583	1.632
2005	11	0.350	173	61	49	1.620	1.669
2006	12	0.319	173	55	49	1.646	1.695
2007	13	0.290	173	50	49	1.668	1.717
2008	14	0.263	173	46	49	1.685	1.734
2009	15	0.239	173	41	49	1.696	1.745
2010	16	0.218	173	38	537	1.696	2.233
2011	17	0.198	173	34	537	1.696	2.233
2012	18	0.180	173	31	49	1.696	1.745
2013	19	0.164	173	28	49	1.696	1.745
2014	20	0.149	173	26	49	1.696	1.745
2015	21	0.135	173	23	49	1.696	1.745
2016	22	0.123	173	21	49	1.696	1.745
2017	23	0.112	173	19	49	1.696	1.745
2018	24	0.102	173	18	49	1.696	1.745
2019	25	0.092	173	16	49	1.696	1.745
2020	26	0.084	173	15	49	1.696	1.745
2021	27	0.076	173	13	49	1.696	1.745
Total		Total	11.572				11.969

B/C

1.03

B-C

397

Input Data : Naradaw P= 1.600 kW
 Benefit Cost Ratio Calculation : Naradaw P= 1.600 kW

Year of Start (n=0) 1997
 In case of Carabau 1 x 1000 KW

Year	n	Naradaw		Year
		Invest.	Diesel	
Const.	0	1.150	0	1997
Const.	1	6.900	488	1998
Const.	2	3.450	488	1999
Opera.	3	173	49	2000
Opera.	4		7.999	2001
Opera.	5		8.471	2002
Opera.	6		8.796	2003
Opera.	7		9.044	2004
Opera.	8		9.256	2005
Opera.	9		9.407	2006
Opera.	10		9.532	2007
Opera.	11		9.631	2008
Opera.	12		9.691	2009
Opera.	13		9.691	2010
Opera.	14		9.691	2011
Opera.	15		9.691	2012
Re-Const	16		488 + 49	2013
Re-Const	17		488 + 49	2014
Opera.	18		49	2015
Opera.	19		9.691	2016
Opera.	20		9.691	2017
Opera.	21		9.691	2018
Opera.	22		9.691	2019
Opera.	23		9.691	2020
Opera.	24		9.691	2021
Opera.	25		9.691	2022
Opera.	26		9.691	2023
Opera.	27	173	49	2024

Year	n	Cost Stream		Benefit Stream		
		Naradaw		Alternative (Diesel)		
		Invest.	C Value	Invest.	Fuel	Total B Value
1997	0	1.150	1.150	0	0	0
1998	1	6.900	6.273	488	0	488
1999	2	3.450	2.851	488	0	488
2000	3	173	130	49	1.286	1.335
2001	4	173	118	49	1.400	1.449
2002	5	173	107	49	1.482	1.531
2003	6	173	98	49	1.539	1.588
2004	7	173	89	49	1.583	1.632
2005	8	173	81	49	1.620	1.669
2006	9	173	73	49	1.646	1.695
2007	10	173	67	49	1.668	1.717
2008	11	173	61	49	1.685	1.734
2009	12	173	55	49	1.696	1.745
2010	13	173	50	49	1.696	1.745
2011	14	173	46	49	1.696	1.745
2012	15	173	41	49	1.696	1.745
2013	16	173	38	537	1.696	2.233
2014	17	173	34	537	1.696	2.233
2015	18	173	31	49	1.696	1.745
2016	19	173	28	49	1.696	1.745
2017	20	173	26	49	1.696	1.745
2018	21	173	23	49	1.696	1.745
2019	22	173	21	49	1.696	1.745
2020	23	173	19	49	1.696	1.745
2021	24	173	18	49	1.696	1.745
2022	25	173	16	49	1.696	1.745
2023	26	173	15	49	1.696	1.745
2024	27	173	13	49	1.696	1.745
Total			11.572			13.280

B/C 1.15

B-C 1.708

**Appendix 5 PERMISSIBLE TRANSMISSION CAPACITY
FOR 11 KV EXISTING INTERCONNECTION LINE
RANAU-KUNDASANG GRID**

Appendix 5

PERMISSIBLE TRANSMISSION CAPACITY FOR 11 KV EXISTING
INTERCONNECTION LINE RANAU-KUNDASANG GRID

CONTENTS

	<u>Page</u>
1. Permissible Transmission Capacity for 11 kV Existing Interconnection Line Ranau-Kundasang Grid	AP5-1

**Permissible Transmission Capacity
for 11 kV Existing Interconnection Line Ranau-Kundasang Grid**

It is to consider a three-phase overhead line 6 miles long, from proposed mini hydro P.P (Naradaw P.P) to Ranau, supplying energy at 11,000 volts with a frequency of 50 Hz.

The conductors consist of No. 0000 B&S., stranded Aluminum, spaced in a horizontal plane with a separation of 2.0 ft. between the center wire and each of the outer wires.

It is desired to calculate the maximum load in kilowatts with the power factor 0.8 which can be transmitted by this line and given that the inherent regulation (or percentage voltage drop) must not exceed 10 percent when the temperature of the wire at circumstances in 90°F.

The calculation was made based on the following conditions:

Voltage between lines at receiving end,

$$E = 11,000 \text{ volts}$$

$$\text{Frequency, } f = 50 \text{ Hz}$$

$$\text{Power factor of load, } \cos \phi = 0.8$$

$$\text{Length of line, } L = 6 \text{ miles}$$

Diameter of No. 0000 stranded conductor

$$2r = 0.522 \text{ in}$$

$$\text{Area of cross-section of wire} = 0.1662 \text{ sq. in}$$

Resistance, ohms per mile, at 20°C (68°F) = 0.430 Ω

The resistance per mile at 90°C

$$R_{90} = R_{20} (1 + at) \dots\dots\dots (1)$$

Where R_{90} = resistance at 90°C

t = temperature rise above initial temperature (20°C)

R_{20} = resistance at the initial temperature (20°C)

$$R_{90} = 0.430 \frac{(390+167)}{(390+68)} = 0.523 \text{ ohm}$$

The increase of resistance due to skin effect need not be taken into account because the product area x frequency is $0.1662 \times 50 = 8$ (approximately), it is seen that the skin-effect multiplier is so small as to be negligible.

The spacing between wires, in inches are:

$a = 24$, $b = 24$, $c = 48$, and the equivalent spacing is

$$d = \sqrt[3]{24 \times 24 \times 48} = 30.2 \text{ in.}$$

Using this value in formula (1), or for d in formula (2),

$$(IX) = 0.0046 fI \log_e \frac{\sqrt[3]{abc}}{r} + 0.000506 fI \dots\dots\dots (1)$$

Reactive voltage drop (IX) per mile of single conductor

$$= 0.00466 fI \log (1.285 \frac{d}{r}) \dots\dots\dots (2)$$

$$\frac{d}{r} = \frac{30.2}{0.261} = 116 \text{ which may be used in the formula (3)}$$

$$x = 0.00466 \times f \times \log (1.285 \times 116) \dots\dots\dots (3)$$

The result is reactance per mile of single conductor, $X = 0.506$ ohm
 The required regulation of percentage voltage drop is

$$100 \times \frac{V - E}{E} \dots\dots (4)$$

Where V stands for the voltage between conductors at the sending end of the line. The value $(V - E)$ is equal to $\sqrt{3} (V_n - E_n)$ where V_n and E_n are star voltages (conductor to neutral) at the sending and receiving ends, respectively.

If the simplified formula (5) is used,

$$V_n = E_n + IR \cos \theta + IX \sin \theta \dots\dots (5)$$

giving the voltage drop per conductor, the loss of voltage as measured between conductor is

$$(V - E) = \sqrt{3} IL (R \cos \theta + X \sin \theta)$$

Accordingly, the following formula (6) and (7) are obtained based on

$$I = \frac{W}{\sqrt{3} E \cos \theta}$$

$$(V - E) = \frac{WL (R \cos \theta + X \sin \theta)}{E \cos \theta} \text{ volts } \dots\dots (6) \text{ (approximately)}$$

$$(V - E) + \frac{WL (R + X \tan \theta)}{E} \text{ volts } \dots\dots (7) \text{ (approximately)}$$

On the other hand, the percentage voltage drop is as shown below.

$$\frac{100 (V - E)}{E} = \frac{100 WL (R + X \tan \theta)}{E^2} \dots\dots (8)$$

Values for $\tan \theta$ corresponding to any given power factor ($\cos \theta$) may be obtained from trigonometric tables, or following formula

$$\tan \theta = \frac{\sqrt{1 - \cos \theta}}{\cos \theta}$$

Applying formula (8) to the solution this particular problem,

$$W = \frac{\text{percent voltage drop} \times E^2}{100L (R + X \tan \theta)} \dots\dots\dots (9)$$

$$= \frac{10 \times (11,000)^2}{100 \times 6 (0.523 + 0.506 \times 0.75)}$$

$$= \underline{\underline{2,200 \text{ kW}}}$$

The required answer is that the permissible maximum load at the receiving end is 2,200 kW. A load in excess of this would cause the inherent regulation to be greater than 10 percent.

Appendix 6 PRELIMINARY DESIGN

Appendix 6

PRELIMINARY DESIGN

CONTENTS

	<u>Page</u>
1. Stability Analysis of Dam	AP6-1
2. Optimum Diameter of Pipeline	AP6-4
3. Water Hammer Calculation	AP6-8

6.1 Stability Analysis of Dam

The dam bodies must be checked by making stability computation so that following requirements at any horizontal section and contact face between dambody and bedrock are satisfied against external forces and weight of the dam.

- (1) No tensile stress must be produced along the upstream face (The action line of resultant force must pass through the middle third of bottom).
- (2) No sliding must be ensured against shear friction force.
- (3) Compressive stress at the bottom must not exceed it's allowable limit of the ground. (No settlement)

Above requirements are satisfied with following formula. Typical section of Liwagu dam is studied.

■ No tensile

$$C = \left| \frac{\sum M}{\sum V} - \frac{B}{2} \right| = \left| \frac{78.57}{23.38} - \frac{7.0}{2} \right| = 0.14 \leq \frac{B}{6} = \frac{7.0}{6} = 1.17 \quad \therefore \text{OK}$$

■ No sliding

when no earthquake

$$\frac{f \cdot \sum V}{\sum H} = \frac{0.75 \times 23.38}{12.75} = \frac{17.54}{12.75} = 1.37 \geq 1.2 \quad \therefore \text{OK}$$

when earthquake

$$\frac{f \cdot \sum V}{\sum H} = \frac{0.75 \times 23.38}{16.69} = \frac{17.54}{16.69} = 1.05 \geq 1.0 \quad \therefore \text{OK}$$


■ No settlement

$$\frac{\sum V}{B} \left(1 + \frac{6e}{B} \right) = \frac{23.38}{7.0} \left(1 + \frac{6 \times 0.14}{7.0} \right) = 3.74 \leq 9a = 50 \text{ ton/m}^2 \quad \therefore \text{OK}$$

Calculation Sheet

Item	External Force (ton)	Arm Length (m)	Moment (t.m)
Self Weight	$13.68 \text{ m}^2 \times 2.4 = 32.83$	2.153	70.68
Seismic Force	$32.83 \times 0.12 = 3.94$	2.183	8.60
Hydrostatic Pressure	$\frac{1}{2} \times 4.5 \times 4.5 = 10.12$	$\frac{1}{3} \times 4.5 = 1.5$	15.18
	$-\frac{1}{2} \times 2.25 \times 4.5 = -1.62$	$\frac{1}{3} \times 1.8 = 0.6$	-0.97
Gravel Force	$\frac{1}{2} \times 2.25 \times 4.5 = 5.06$	1.5	7.59
	$-\frac{1}{2} \times 0.9 \times 1.8 = -0.81$	0.6	-0.49
Uplift	$P_1 = \frac{1}{3} \times 2.7 + 1.8 = 2.7 \text{ m}$	$\frac{1}{3} \times 7.0 = 2.33$	-22.02
	$P_2 = 0 \text{ m}$ $-\frac{1}{2} \times 2.7 \times 7.0 = -9.45$		
Σ Vertical Force	$32.83 - 9.45 = 23.38$	$\chi = \frac{78.57}{23.38} = 3.36$	78.57
Σ Horizontal Force with Earthquake	$3.94 + 10.12 - 1.62 + 5.06 - 0.81 = 16.69$	--	--
Σ Horizontal F. without Earthquake	$16.69 - 3.94 = 12.75$	--	--

SECTION



6-2 Optimum Diameter of Pipeline

Optimum Diameter of Pipeline at Liwagu Site

ITEM	D1	D2	D3	D4	D5	D6
Head Loss	0.5	0.55	0.6	0.65	0.7	0.75
ΔH (m)	0.03438	0.02068	0.013	0.00849	0.00571	0.00396
Output for Head Loss	0.2005	0.1206	0.0758	0.0495	0.0333	0.0231
ΔP (kw)						
Energy for Head Loss	1170.6	704.1	442.6	289.1	194.4	134.8
ΔE (kwh)						
Benefit for Firm Peak Power: B kw (MS)	47.52	28.58	17.96	11.73	7.89	5.47
Benefit for Energy: B kwh (MS)	200.17	120.4	75.68	49.44	33.24	23.05
Total Benefit B (MS)	247.69	148.98	93.64	61.17	41.13	28.52
Construction Cost C con (MS)	370	420	460	580	710	860
Annual Cost C (MS)	42.55	48.3	52.9	66.7	81.65	98.9
Total B + C (MS)	290.24	197.28	146.54	127.87	122.78	127.42

$$Q(m^3) = 0.7$$

$$\eta = 0.013$$

$$\Delta H(m) = 10.298 * \eta^2 * Q^2 / D^5 (16/3)$$

$$\Delta P(kw) = 9.8 * \eta * Q * h$$

$$\Delta E(kwh) = E * (Q/Q_{max}) * (H_{loss}/H_e) = 9.7 * 10^{-6} * (Q/1.18) * (\Delta H/169)$$

$$B_{kw}(MS) = \Delta P * \text{Unit kw benefit} = 240 MS/kw * \Delta P$$

$$B_{kwh}(MS) = \Delta E * \text{Unit kwh benefit} = 0.18 MS/kwh * \Delta E$$

$$C(MS) = \text{Annual cost factor} * C_{con} = 0.115 * C_{con}$$

Optimum Diameter of Pipeline at Mesilau Site

	ITEM	D1	D2	D3	D4	D5	D6
Head Loss	$\Delta H(m)$	0.5	0.55	0.6	0.65	0.7	0.75
Output for Head Loss	$\Delta P(kw)$	0.01617	0.00972	0.00611	0.00399	0.00269	0.00186
Energy for Head Loss	$\Delta E(kwh)$	377.5	226.9	142.7	93.2	62.8	43.4
Benefit for Firm Peak Power:	B kw (MS)	15.33	9.22	5.78	3.79	2.56	1.75
Benefit for Energy	B kwh (MS)	64.55	38.8	24.4	15.94	10.74	7.42
Total Benefit	B (MS)	79.88	48.02	30.18	19.73	13.3	9.17
Equalized Annual Cost	C con (MS)	370	420	460	580	710	860
Annual Cost	C (MS)	42.55	48.3	52.9	66.7	81.65	98.9
Total B + C	B + C (MS)	122.43	96.32	83.08	86.43	94.95	108.07

$Q(m^3) = 0.48$

$n = 0.013$

$\Delta H(m) = 10.298 * n^2 * Q^2 / D^5 (16/3)$

$\Delta P(kw) = 9.8 * n * Q * h$

$\Delta E(kwh) = E * (Q/Q_{max}) * (H_{loss}/H_e) = 9.7 * 10^6 * (Q/1.18) * (\Delta H/169)$

$B_{kw}(MS) = \Delta P * \text{Unit kw benefit} = 240MS/kw * \Delta P$

$B_{kwh}(MS) = \Delta E * \text{Unit kwh benefit} = 0.18MS/kwh * \Delta E$

$C(MS) = \text{Annual cost factor} * C_{con} = 0.115 * C_{con}$

Calculation of Benefit in terms of Firm Peak Power and Energy (1/1)

No.	Item	Unit	Calculation	
(1)	Firm peak power of Naradaw	MW	560 kW	
(2)	Dependable capacity of Naradaw	MW	$(1) \times (1-H_1) \times (1-H_2) \times (1-H_3)$ $= 560(1-0.01) \times (1-0.06) (1-0.10)$ $= 560 \times 0.8375 = 469 \text{ kW}$	
(3)	Dependable capacity of Alternative thermal	MW	Same as the value given in (2)	
(4)	Rated capacity of Alternative thermal	MW	$(3) \div \{(1-T_1) \times (1-T_2) \times (1-T_3)\}$ $= 469 \div (1-0.04) \times (1-0.13) \times (1-0.20)$ $= 469 \div 0.6682 \approx 700 \text{ kW}$	
(5)	Annual energy production of Naradaw	10^6 kWh	$9.7 \times 10^6 \text{ kWh}$	
(6)	Available Energy of Naradaw	10^6 kWh	$(5) \times (1-H_1) = 9.7 \times (1-0.01)$ $= 9.6 \times 10^6 \text{ kWh}$	
(7)	Available Energy of Alternative thermal	10^6 kWh	Same as the value given in (6)	
(8)	Annual energy production of Alternative thermal	10^6 kWh	$(7) \div (1-T_1)$ $= 9.6 \times 10^6 \div (1-0.04)$ $= 10.0 \times 10^6 \text{ kWh}$	
	Loss Rates of Hydro and Thermal		Hydro Power	Thermal Power
	Station Service Rate	%	$H_1 = 1\%$	$T_1 = 4\%$
	Outage Rate	%	$H_2 = 6\%$	$T_2 = 13\%$
	Capacity Derated Rate	%	$H_3 = 10\%$	$T_3 = 20\%$

Calculation of Benefit in terms of Firm Peak Power and Energy (1/2)

(9)	Fuel Consumption per kWh		0.354 l/kWh	
(10)	Fuel Cost per Liter		0.50 M\$/l	
(11)	Construction Cost per kW	\$/kW	1,395 M\$/kW	
(12)	Construction Cost	10 ⁶ \$	1,395 × 700 = 976 × 10 ³ M\$	
(13)	Service Life	year	n = 15 years	
(14)	Annual Interest Rate	%	i = 10%	
(15)	Capital Recovery Factor		$\frac{i(1+i)^n}{(1+i)^n - 1}$ = $\frac{0.1(1+0.1)^{15}}{(1+0.1)^{15} - 1}$ = 0.13	
(16)	Rate of O&M Cost to Construction Cost	%	5%	
			Fixed Cost	Variable cost
(17)	Interest & Depreciation		(12) × (15) = 127 × 10 ³ M\$	--
(18)	O&M Cost		(12) × (16) × 0.8 = 39 × 10 ³ M\$	(12) × (16) × 0.2 = 10 × 10 ³ M\$
(19)	Fuel Cost		--	(8) × (9) × (10) = 1.698 × 10 ³ M\$
(20)	Total of Fixed Cost		(17) + (18) = 166 × 10 ³ M\$	--
(21)	Total of variable Cost		--	(18) + (19) = 1.708 × 10 ³ M\$
(22)	Benefit Corresponding to Firm Peak Power	\$/kW	(20) ÷ (4) = 237 = 240 M\$/kW	--
(23)	Benefit Corresponding to Energy	\$/kW	--	(21) ÷ (8) = 0.171 = 0.18 M\$/kWh

6-3 Water Hammer Calculation

WATER HAMMER

Gross head 195
 Discharge 0.7
 Liwagu

1. PRESSURE WAVE VELOCITY

$$a = 1/(w/g*(1/K+D/E/t))^{0.5}$$

Where,

- a : Pressure wave velocity (m/sec)
- w : Unit weight of water (1.0 tonf/m³)
- g : Accelation of gravity (9.8 m/sec²)
- K : Bulk modulus of compressibility of water (2.07 x 10⁵ tonf/m²)
- E : Young's modulus of elasticity for pipe material (for steel pipe = 2.1 x 10⁷ tonf/m²)
- D : Diameter of pipe (m)
- t : Pipe wall thickness (m)

	D (m)	t (m)	a (m/sec)	Length (m)
Liwagu pipeline	0.7	0.006	971.4	2680.0
Penstock	0.8	0.006	936.2	456.3
- do -	0.8	0.007	976.7	120.4
- do -	0.8	0.008	1010.7	90.3
- do -	0.8	0.009	1039.8	98.1
- do -	0.5	0.006	1055.3	15.0
				3460.1

$$a = L/(L1/a1+L2/a2 \dots \dots Ln/an)$$

$$= 969.877 \text{ m/sec}$$

2. Water Hammer caused by the rapid closing of valve (in the case T < 2*L/a = 7.14 sec)

$$H-Ho = - a/g*(V-Vo)$$

- Where, Ho : Water head in constant flowing situation (m)
- Vo : Flow velocity in constant flowing situation (m)
- H : Water head at a given time after the valve is operated (m)
- V : Flow velocity at a given time after the valve is operated (m)

When valve is fully closed and V = 0, H-Ho = a*Vo/g is maximum additional head caused by water hammering.

In case of

Discharge in the pipeline : 0.70 m³/sec,
Mean velocity in the pipeline : 1.724 m/sec

Maximum additional head by water hammer is

$$H - H_0 = 170.619 \text{ m}$$

3. Simplified method of calculations for water hammer caused by slowly closing a valve
(in the case $T > 2L/a = 7.16 \text{ sec}$)

This formula is based on the assumption that from the time the first reflective returns to the valve until it is fully closed, the pressure remains unchanged and that the effective opening area of the valve is changed rectilinearly.

$$H/H_0 = 1 + n/2 * (n + -(n^2 + 4)^{0.5})$$

In this formula, + causes rise of the pressure at the time of closing the valve, whereas, - causes drop at the time of opening.

$$n = L * V_0 / (T * g * H_0)$$

Where, T : Time of valve closing (sec)
L : Length of pipeline : 3460.1 (m)
H₀ : 195 (m)
V₀ : 1.724 (m/sec)

Time (sec)	n	H (m) (closing)	H (m) (opening)
10	0.31215	266.11	142.89
12	0.26013	252.75	150.45
15	0.20810	240.02	158.42
18	0.17342	231.88	163.99
22	0.14189	224.70	169.23
26	0.12006	219.86	172.95
30	0.10405	216.37	175.74
35	0.08919	213.18	178.37
40	0.07804	210.82	180.36
50	0.06243	207.56	183.20
60	0.05203	205.41	185.12
80	0.03902	202.76	187.54
100	0.03122	201.18	189.01
120	0.02601	200.14	189.99
150	0.02081	199.10	190.98
200	0.01561	198.07	191.98

WATER HAMMER

CASE - II

Gross head 184
 Discharge 1.2
 Mesilau

1. PRESSURE WAVE VELOCITY

$$a = 1/(w/g*(1/K+D/E/t))^{0.5}$$

Where,

- a : Pressure wave velocity (m/sec)
- w : Unit weight of water (1.0 tonf/m³)
- g : Accelation of gravity (9.8 m/sec²)
- K : Bulk modulus of compressibility of water (2.07 x 10⁵ tonf/m²)
- E : Young's modulus of elasticity for pipe material (for steel pipe = 2.1 x 10⁷ tonf/m²)
- D : Diameter of pipe (m)
- t : Pipe wall thickness (m)

	D (m)	t (m)	a (m/sec)	Length (m)
Mesilau pipeline	0.6	0.006	1010.7	990.0
Penstock	0.8	0.006	936.2	456.3
- do -	0.8	0.007	976.7	120.4
- do -	0.8	0.008	1010.7	90.3
- do -	0.8	0.009	1039.8	98.1
- do -	0.5	0.006	1055.3	15.0
				1770.1

$$a = L/(L1/a1+L2/a2 \dots Ln/an)$$

$$= 989.978 \text{ m/sec}$$

2. Water Hammer caused by the rapid closing of valve
 (in the case T < 2*L/a = 3.58 sec)

$$H-Ho = - a/g*(V-Vo)$$

- Where, Ho : Water head in constant flowing situation (m)
- Vo : Flow velocity in constant flowing situation (m)
- H : Water head at a given time after the valve is operated (m)
- V : Flow velocity at a given time after the valve is operated (m)

When valve is fully closed and V = 0, H-Ho = a*Vo/g is maximum additional head caused by water hammering.

In case of

Discharge in the pipeline : 1.20 m³/sec,
Mean velocity in the pipeline : 2.046 m/sec

Maximum additional head by water hammer is

$$H - H_0 = 206.683 \text{ m}$$

3. Simplified method of calculations for water hammer caused by slowly closing a valve
(in the case $T > 2L/a = 3.58 \text{ sec}$)

This formula is based on the assumption that from the time the first reflective returns to the valve until it is fully closed, the pressure remains unchanged and that the effective opening area of the valve is changed rectilinearly.

$$H/H_0 = 1 + n/2 * (n + (n^2 + 4)^{0.5})$$

In this formula, + causes rise of the pressure at the time of closing the valve, whereas, - causes drop at the time of opening.

$$n = L * V_0 / (T * g * H_0)$$

Where, T : Time of valve closing (sec)
L : Length of pipeline : 1770.1 (m)
H₀ : 184 (m)
V₀ : 2.047 (m/sec)

Time (sec)	n	H (m) (closing)	H (m) (opening)
10	0.20093	224.87	150.56
12	0.16744	217.50	155.66
15	0.13395	210.35	160.95
18	0.11163	205.72	164.58
22	0.09133	201.59	167.95
26	0.07728	198.78	170.32
30	0.06698	196.74	172.08
35	0.05741	194.87	173.74
40	0.05023	193.48	174.99
50	0.04019	191.54	176.75
60	0.03349	190.27	177.94
80	0.02512	188.68	179.44
100	0.02009	187.73	180.34
120	0.01674	187.11	180.94
150	0.01340	186.48	181.55
200	0.01005	185.86	182.16

6-4 Wall Thickness of Penstock

WALL THICKNESS (from Liwagu Intake)

No.	L (m)	TL (m)	EL (m)	H (m)	P (kg/cm ²)	Ph (kg/cm ²)	Pd (kg/cm ²)	t (cm)	at (cm)	w (kg/m)	W (kg)	Wt (kg)
Liwagu headpond	0	0	1043.0	5.0	0.5	0.0	0.5	0.0299	0.6	103.58	0	0
	2680.0	2680.0	1025.0	23.0	2.3	2.3	4.6	0.1510	0.6	103.58	277,594	277,594
Penstock	0	2680.0	1025.0	23.0	2.3	2.3	4.6	0.1704	0.6	118.38	0	0
1	15.0	2695.0	1024.0	24.0	2.4	2.3	4.7	0.1743	0.6	118.38	1,780	1,780
2	42.0	2737.0	1024.0	24.0	2.4	2.3	4.7	0.1755	0.6	118.38	4,972	6,752
3	34.0	2771.0	1016.0	32.0	3.2	2.3	5.5	0.2037	0.6	118.38	4,020	10,771
4	11.0	2782.0	1015.0	33.0	3.3	2.4	5.7	0.2074	0.6	118.38	1,308	12,079
5	19.0	2801.0	1015.0	33.0	3.3	2.4	5.7	0.2079	0.6	118.38	2,249	14,328
6	26.0	2827.0	1015.0	33.0	3.3	2.4	5.7	0.2087	0.6	118.38	3,078	17,406
7	64.3	2891.3	1009.0	39.0	3.9	2.4	6.3	0.2310	0.6	118.38	7,610	25,015
8	41.2	2932.5	989.0	59.0	5.9	2.5	8.4	0.3002	0.6	118.38	4,875	29,891
9	21.0	2953.5	980.0	68.0	6.8	2.5	9.3	0.3315	0.6	118.38	2,489	32,379
10	24.7	2978.2	971.0	77.0	7.7	2.5	10.2	0.3628	0.6	118.38	2,924	35,303
11	12.4	2990.6	968.0	80.0	8.0	2.5	10.5	0.3734	0.6	118.38	1,464	36,768
12	11.2	3001.8	963.0	85.0	8.5	2.5	11.0	0.3907	0.6	118.38	1,324	38,091
13	13.0	3014.8	963.0	85.0	8.5	2.5	11.0	0.3911	0.6	118.38	1,539	39,630
14	40.5	3055.3	952.0	96.0	9.6	2.6	12.2	0.4297	0.6	118.38	4,797	44,427
15	23.4	3078.7	944.0	104.0	10.4	2.6	13.0	0.4576	0.6	118.38	2,771	47,198
16	57.6	3136.3	927.0	121.0	12.1	2.7	14.8	0.5172	0.6	118.38	6,815	54,013
	0.0	3136.3	927.0	121.0	12.1	2.7	14.8	0.5172	0.7	138.10	0	54,013
17	42.4	3178.6	913.0	135.0	13.5	2.7	16.2	0.5661	0.7	138.10	5,853	59,866
18	20.4	3199.0	909.0	139.0	13.9	2.7	16.6	0.5803	0.7	138.10	2,817	62,682
19	30.7	3229.7	899.0	149.0	14.9	2.7	17.6	0.6152	0.7	138.10	4,236	66,919
20	26.9	3256.6	889.0	159.0	15.9	2.8	18.7	0.6500	0.7	138.10	3,718	70,637
	0.0	3256.6	889.0	159.0	15.9	2.8	18.7	0.6500	0.8	157.83	0	70,637
21	59.1	3315.7	861.0	187.0	18.7	2.8	21.5	0.7470	0.8	157.83	9,321	79,958
22	31.2	3346.9	857.4	190.6	19.1	2.8	21.9	0.7602	0.8	157.83	4,926	84,884
	0.0	3346.9	857.4	190.6	19.1	2.8	21.9	0.7602	0.9	177.56	0	84,884
23	4.0	3350.9	857.4	190.6	19.1	2.8	21.9	0.7603	0.9	177.56	714	85,598
24	32.1	3383.0	855.0	193.0	19.3	2.9	22.2	0.7694	0.9	177.56	5,693	91,291
25	33.0	3416.0	854.0	194.0	19.4	2.9	22.3	0.7737	0.9	177.56	5,862	97,153
26	16.0	3432.0	853.0	195.0	19.5	2.9	22.4	0.7776	0.9	177.56	2,847	99,999
27	13.0	3445.0	853.0	195.0	19.5	2.9	22.4	0.7780	0.9	177.56	2,308	102,308
28	0.0	3445.0	853.0	195.0	19.5	2.9	22.4	0.4919	0.6	73.98	0	102,308
29	15.0	3460.0	853.0	195.0	19.5	2.9	22.4	0.4921	0.6	73.98	2,219	104,527

Notes : TL : Length of pipeline
 EL : Elevation of center of pipe
 H : Static head
 P : Static pressure
 Ph : Water hammer pressure
 Pd : Design pressure
 t : Calculated thickness
 at : Adopted thickness
 W : Weight of pipe

WEIGHT OF PIPELINES AND PENSTOCK

Pipeline	t (mm)	Length (m)	Weight (ton)
Liwagu Pipeline D = 700	6	2680.0	277.6
Mesilau Pipeline	6	990.0	87.9
Connecting pipe D = 600	6	90.0	8.0
Penstock			
D = 800	6	456.3	54.0
	7	120.4	16.6
	8	90.3	14.2
	9	98.1	17.4
D = 500	6	30.0	2.2
Penstock		795.0	104.5

Appendix 7 CONSTRUCTION COSTS

Appendix 7

CONSTRUCTION COSTS

CONTENTS

	<u>Page</u>
1. Breakdown of Construction Cost	AP7-1

Summary of Construction Cost

Description	Amount (M\$)
1. Civil Engineering Works	6,099,000
1.1 Preliminaries	200,000
1.2 Liwagu Intake Facilities	509,000
1.3 Mesilau Intake Facilities	647,000
1.4 Liwagu Pipeline	2,284,000
1.5 Mesilau Pipeline	543,000
1.6 Penstock	813,000
1.7 Powerhouse	175,000
1.8 Access Road	928,000
2. Electrical and Mechanical Works	3,150,000
3. Transmission Line	140,000
4. Project Land Cost and Compensations	250,000
5. Engineering and Management (10% of above total)	965,000
6. Contingencies	896,000
10% of Civil Engineerings Works	610,000
5% of Electrical and Mechanical Works	158,000
5% of Transmission Lines	7,000
10% of Project Land Cost and Compensations	25,000
10% of Engineering, Management and Commissioning	96,000
Grand Total	11,500,000

Construction Cost No.1

1.2 Liwagu Intake Facilities

1.2.1 Intake Dam and Desilting Basin

Description	Unit	Q'ty	Unit Price (MS)	Amount (MS)
Site clearance & Setting out	L.S	1	7,000	7,000
Temporary river diversion works	L.S	1	75,000	75,000
Excavation in soft material	m ³	100	7	700
Excavation in river gravel	m ³	800	10	8,000
Excavation in rock	m ³	40	60	2,400
Mass concrete (1:3:6)	m ³	410	220	90,200
Structural concrete (1:2:4)	m ³	240	300	72,000
Reinforcement	t	14	1,850	25,900
Embankment	m ³	70	10	700
Gabion (1.5×1.0×0.5m)	Set	60	80	4,800
Scouring gate (0.7×0.9m)	Set	2	8,000	16,000
Miscellaneous (5%)	L.S.	1		15,300
Total				318,000

Construction Cost No. 2

1. 2. 2 Headpond

Description	Unit	Q'ty	Unit Price (M\$)	Amount (M\$)
Site clearance & Setting out	L. S	1	5,000	5,000
Excavation in soft material	m ³	100	7	700
Excavation in river gravel	m ³	250	10	2,500
Excavation in rock	m ³	50	60	3,000
Embankment	m ³	960	10	9,600
Facing concrete (1;2;4)	m ³	180	300	54,000
Structure concrete (1;2;4)	m ³	200	300	60,000
Reinforcement	t	12	1,850	22,200
PVC Waterstop	m	200	20	4,000
Gravel	m ³	135	46	6,210
Scouring gate (0.7×0.9m)	Set	1	8,000	8,000
Stop gate (0.7×0.7m)	Set	1	7,000	7,000
Miscellaneous (5%)	L. S			8,790
Total				191,000

Construction Cost No. 3

1.3 Mesilau Intake Facilities

1.3.1 Intake Dam and Desilting Basin

Description	Unit	Q'ty	Unit Price (M\$)	Amount (M\$)
Site clearance & Setting out	L.S	1	7,000	7,000
Temporary river diversion work	L.S	1	75,000	75,000
Excavation in soft material	m ³	180	7	1,260
Excavation in river gravel	m ³	180	10	1,800
Excavation in rock	m ³	90	60	5,400
Embankment	m ³	600	10	6,000
Mass concrete (1;3;6)	m ³	440	220	96,800
Structure concrete (1;2;4)	m ³	300	300	90,000
Reinforcement	t	11	1,850	20,350
Gabion (1.5×1.0×0.5m)	Set	60	80	4,800
Scouring gate (0.6×0.7m)	Set	1	6,000	6,000
Scouring gate (1.4×1.2m)	Set	1	12,000	12,000
Stop gate (0.9×0.9m)	Set	1	10,000	10,000
Miscellaneous (5%)	L.S	1		16,590
Total				353,000

Construction Cost No. 4

1.3.2 Headpond

Description	Unit	Q'ty	Unit Price (M\$)	Amount (M\$)
Site clearance & Setting out	L.S	1	5,000	5,000
Excavation in soft material	m ³	3,000	7	21,000
Excavation in rock	m ³	500	60	30,000
Embankment	m ³	1,200	10	12,000
Facing concrete (1;2;4)	m ³	200	300	60,000
Structure concrete (1;2;4)	m ³	100	300	30,000
Reinforcement	t	7	1,850	12,950
PVC Waterstop	m	250	20	5,000
Gravel	m ³	150	46	6,900
Masonry	m ³	25	50	1,250
Supply & inst. of connecting pipe (D=600mm)	m	90	450	40,500
Supply & inst. of scouring pipe (D=700mm)	m	36	700	25,200
Scouring valve (D=700mm)	Set	1	30,000	30,000
Stop valve (D=600mm)	Set	1	22,000	22,000
Miscellaneous (5%)	L.S	1		14,200
Total				294,000

Construction Cost No. 5

1.4 Liwagu Pipeline

Description	Unit	Q'ty	Unit Price (M\$)	Amount (M\$)
Site clearance & Setting out	L. S	1	38,000	38,000
Excavation in soft material	m ³	940	7	6,580
Excavation in rock	m ³	0	60	0
Supply & inst. of steel pipe (D=700mm, t=6mm)	m	2,680	700	1,876,000
Saddle concrete (1;2;4)	m ³	300	300	90,000
Anchor block & pier concrete (1;2;4)	m ³	130	220	28,600
Reinforcement	t	14	1,850	25,900
Steel bridge for pipeline :l=30m	Set	1	35,000	35,000
Steel bridge for pipeline :l=20m	Set	2	20,000	40,000
Gravell	m ³	120	46	5,520
Stope valve (D=700mm)	Set	1	30,000	30,000
Miscellaneous (5%)	L. S	1		108,400
Total				2,284,000

Construction Cost No. 6

1.5 Mesilau Pipeline

Description	Unit	Q'ty	Unit Price (M\$)	Amount (M\$)
Site clearance & Setting out	L.S	1	20,000	20,000
Excavation in soft material	m ³	160	7	1,120
Excavation in rock	m ³	0	60	0
Supply & inst. of steel pipe (D=600mm, t=6mm)	m	990	450	445,500
Saddle concrete (1;2;4)	m ³	60	300	18,000
Anchor block concrete (1;2;4)	m ³	20	220	4,400
Reinforcement	t	3	1,850	5,550
Gravell	m ³	9	46	414
Stop valve (D=600mm)	Set	1	22,000	22,000
Miscellaneous (5%)	L.S	1		26,016
Total				543,000

Construction Cost No. 7

1.6 Penstock

Description	Unit	Q'ty	Unit Price (M\$)	Amount (M\$)
Site clearance & Setting out	L. S.	1	44,000	44,000
Excavation in soft material	m ³	2,900	7	20,300
Rock excavation	m ³	720	60	43,200
Sand foundation for penstock	m ³	620	40	24,800
Backfill for penstock	m ³	1,600	10	16,000
Supply & inst. of steel pipe (D=700&600mm, t=6mm)	m	473	1,150	543,950
Supply & inst. of steel pipe (D=700&600mm, t=7mm)	m	120	1,270	152,400
Supply & inst. of steel pipe (D=700&600mm, t=8mm)	m	90	1,350	121,500
Supply & inst. of steel pipe (D=700&600mm, t=9mm)	m	85	1,400	119,000
Supply & inst. of steel pipe (D=500mm, t=6mm)	m	32	380	12,160
Anchor block concrete (1:2:4)	m ³	140	220	30,800
Reinforcement	ton	3	1,850	5,550
Slope protection (Seeding)	m ²	3,200	2	6,400
Concrete pile (D=300mm, l=1.5m)	p. c	50	45	2,250
Miscellaneous (5%)	L. S.	1		54,940
Total				1,151,000

Construction Cost No. 8

1.7 Powerhouse

Description	Unit	Q'ty	Unit Price (M\$)	Amount (M\$)
Site clearance & Setting out	L.S	1	7,000	7,000
Excavation in soft material	m ³	2,700	7	18,900
Excavation in rock	m ³	300	60	18,000
Embankment	m ³	0	5	0
Base concrete (1;2;4)	m ³	0	220	0
Structure concrete (1;2;4)	m ³	130	300	39,000
Reinforcement	t	4	1,850	7,400
Slope protection (Seeding)	m ²	340	2	680
Gravel	m ³	170	46	7,820
Precast concrete gutter (30×30m)	m	50	22	1,100
Superstructure	L.S	1	50,000	50,000
Hoist with girder	L.S	1	16,800	16,800
Miscellaneous (5%)	L.S.	1		8,300
Total				175,000

Construction Cost No. 9

1.8 Access Road

Description	Unit	Q'ty	Unit Price (MS)	Amount (MS)
Type A	m	2,980	206	613,880
Type B	m	2,480	109	270,320
Miscellaneous	L.S.	1		43,800
Total				928,000

Type A Site clearance	m	1	5	5
Slope protection (Seeding)	m	6	2	12
Excavation	m ³	18	4	70
Gravel	m ³	1	46	28
Precast concrete gutter (30×30cm)	m	1	22	22
Concrete wall	m ³	0	300	60
Hume concrete pipe	m	0	230	9
Total				206
Type B Site clearance	m	1	5	5
Slope protection (Seeding)	m	2	2	4
Excavation	m ³	9	4	35
Gravel	m ³	1	46	28
Concrete wall	m ³	0	300	30
Hume concrete pipe	m	0	230	7
Total				109

Construction Cost No. 10

2. Electrical and Mechanical Works

Description	Unit	Q'ty	Unit Price	Amount
Turbine and Generator	L. S.	1		2,012,000
Transformer	L. S.	1		214,000
Telecommunication	L. S.	1		198,000
Transportation	L. S.	1		242,000
Installation (including miscellaneous materials)	L. S.	1		484,000
Total				3,150,000

Appendix 8 ENVIRONMENTAL IMPACT STUDY

Appendix 8

ENVIRONMENTAL IMPACT STUDY

CONTENTS

	<u>Page</u>
1. Environmental Impact Assessment Report (Executive Summary)	AP8-1

**Lembaga Letrik Sabah
Kota Kinabalu**

**SMALL SCALE HYDROELECTRIC POWER
DEVELOPMENT PROJECT AT UPPER LIWAGU RIVER
BASIN IN SABAH**

ENVIRONMENTAL IMPACT ASSESSMENT

Final Report

May 1992

**Biro Penyelidikan dan Perundingan
Universiti Kebangsaan Malaysia**

EXECUTIVE SUMMARY

BACKGROUND

Sabah Electricity Board (SEB) proposes to install a small hydro-electric power generation facilities in the vicinity of Kg. Naradaw, Kundasang, Sabah to cater for the growing power demand of the population and development activities along the Kundasang - Ranau grid.

The proposed Naradaw scheme is a run of river type, comprising two intake weirs: one will be on Sg. Liwagu proper and the second on Sg. Mesilau. Water extracted from these two intake weirs will be piped to a head pond before being surged down to a power house located near the confluence of the two rivers. The Naradaw site has a total catchment area of 59.2 km², enabling a design maximum discharge of 1.18 m³/s. With a net head of 169 m, the installed capacity of the hydroplant is estimated at 1.6 MW.

The aim of the present study is to investigate and describe the existing status of the physicochemical, biological and human components of the environment within and in the vicinity of the project area, and thereon predict the potential impacts of the activities related to the proposed hydroelectric installation as well as suggesting appropriate mitigation and abatement measures for incorporation into the project plan.

EXISTING ENVIRONMENT

CLIMATE: The areas along the upper reaches of the Liwagu River are influenced by the southwest monsoon with rainy seasons between May - October, and dry seasons between February - April. Kundasang has one of the lowest recorded average annual rainfalls in Sabah i.e. 2,313 mm presumably due to the rainshadow effect. On the average about 1001 mm per year of rainfall is available for runoff and infiltration into the ground. There is little seasonal variation of temperature in Kundasang; the hottest month, May, has a monthly mean daily maximum of 25.7°, the coolest being January, at 22.5°.

TOPOGRAPHY: Slopes in the Study Area are generally steep. The Naradaw site has a mountainland of elevations from 840 to 1,040 m, through which the Liwagu River and the Mesilau River meander from west-northwest to east-southeast. The gradient of the Liwagu river is approximately 1/19, while that

of the Mesilau River is approximately 1/15. Slopes generally inclined 20 to 45 degrees, and parts of the slopes show old or new signs of landslides.

GEOLOGY: The project area is underlain by sedimentary rocks of Crocker Formation consisting of sandstone with minor shale/mudstone and siltstone alternations. Unconformably overlying the Crocker is the Pinosuk Gravel and recent riverine alluvium. The Crocker Formation has been extensively faulted with no preferred orientation of fault lines.

Weathered to freshly fractured sandstone boulders of the Crocker Formation are found at the intake site of the Liwagu River. At the Mesilau intake, strongly brecciated sandstone of the Crocker Formation were found at the depth of about 6 metres below the river bed.

The main soil associations found in the Study Area are those of Pinosuk, Trusmadi and Crocker Associations. The soil is suitable for the cultivation of vegetables, but because of the steepness of the terrain, there is a strong erosion risk.

From seismological data, recorded earthquakes west of Ranau have had magnitude ranging from 4 - 5.9 on the Richter scale, and are of shallow depth (less than 70 km). The most recent earthquake in this part of Sabah measuring 5 on the Richter Scale occurred on 27 May 1991, followed by series of aftershocks during the following weeks.

DRAINAGE: The project area lies within the catchment area of the Sg. Liwagu, which flows generally eastwards, eventually emerging in Labuk Bay on the Sulu Sea. Its source is in the Kinabalu Park, and it is this river which provides water for consumption in the Ranau District. The main tributaries upstream of the project area is Sg. Mesilau East and West and Sg. Silau Silau. The catchment areas for the Mesilau rivers upstream of the proposed intake point is estimated to be about 28 km² and that for Sg. Liwagu proper is 31 km².

LAND USE: Agricultural sector represents the main production base for the economy of the project area. The swidden agriculture appears to have given way to a more settled farming method. Their effort is being facilitated by Government agencies such as the Koperasi Pembangunan Desa (KPD) which provides water supply and sprinkler system. Most holdings appear to range from 0.6 - 0.8 ha. in size. The total area of cultivated land in Kundasang in 1984 was estimated about 750 ha. The crops most commonly grown on the holdings are mixed, non-tree crop horticulture some of which are indigenous to temperate climates. In addition to growing vegetables, many local residents keep some form of livestock.

WATER USE: The water use in the upstream area of the project site are in three main areas viz. Bundu Tuhan, Kundasang, and Pinosuk Plateau. The estimated water demand for various uses (domestic, agriculture, commercial

other municipal uses) in the three areas for 1990 is estimated at nearly 22 (equivalent to 1.16 cumecs).

WATER QUALITY: Field observation indicates that the Liwagu and Mesilau rivers are being directly affected by the agricultural, urbanisation, mining and recreational activities in the Upper Liwagu basin although the DOE data show that the water quality at Ranau still belongs to Class I water. Water quality examination within the project area shows relatively high loading of dissolved solids, organics and phosphates although the dissolved oxygen level in some cases are near saturation point. Available data indicate that none of the common organochlorine pesticides occur at detectable concentration in water although low quantities of these pesticides have been detected in sediment samples.

VEGETATION: The vegetation of this area is essentially that of a lower montane rain forest which is characterised by two floristic zones, namely the upper dipterocarp forest (roughly at 750 - 900 m altitude) and oak-laurel forest (900 - 1800 m). Although the original hillslope vegetation has mostly been cleared and replaced with commercial vegetable plot, there are still a few remnant primary species along the Liwagu and Mesilau river valleys; these include *Podocarpus* sp., *Aglaia* sp., *Shorea* sp., *Eleocarpus* sp. and *Diospyros* sp. Areas that have been severely affected by shifting cultivation (slash and burnt) are now dominated by the secondary species which include *Melochia umbellata*, *Coccoloba gigantea*, *Brookea dasyntha*, *Trema* sp. and others. The above ground biomass at the proposed powerhouse site was found to be only about 16 tonne/ha. No unique floral species of special conservation or scientific interests have been found here.

WILDLIFE: Fauna representing the original community was found only within the remnants of the riverine reserves. The presence of *Amolops headi* and *Ansonia longidigita* in the Mesilau river implies the existence originally of a larger amphibian community typical of hill forest. Nevertheless, substantial presence of *Bufo juxtasper* in the Mesilau river indicates a trend towards the simplification of the amphibian community caused by deforestation. Modification of the Mesilau-Liwagu valleys is also evidenced by the high relative abundance of introduced and colonising bird species (bulbuls, prinias, munias) typical of the disturbed habitats of the lowlands. Few mammals were caught or sighted, again species typical of disturbed lowland/hill forest. No rare or endangered species were recorded.

AQUATIC LIFE: Of the 11 species of fish caught at the proposed intake point on the Mesilau, eight belong to the family Gastromyzontidae. At the Liwagu intake point, 15 species of fish have been sampled, 12 were found to belong to the family Gastromyzontidae, two species from the family Anguillidae and only one species from the family Cyprinidae. Of the 12 species caught from the Liwagu-Mesilau confluence, 10 belong to the family Gastromyzontidae and 2 species from the family Anguillidae. Thus, at the range of altitude where the hydro scheme is to be located, the dominant fish family found in the streams were Gastromyzontidae.

HUMAN ENVIRONMENT: The proposed project will acquire about 10 ha. of land for laying the pipe, power house and the pond. Most of these lands are private lands. About five houses have to be relocated as they are located very close to the pipeline and the power house. All households in the study area belong to the lower income group of less than \$400 per month.

The survey reveals that about 76 percent of respondents agreed the project to be built in the proposed site, 16 percent disagreed and the rest had no opinion. Those who disagreed feel that the area is not suitable for the hydro-electric project in view of constant water shortages.

POTENTIAL IMPACTS

INVESTIGATION STAGE: The potential impacts of the site surveying, engineering and geophysical investigations are expected to be of low magnitude. Nevertheless, the entry of the investigation team should be made known to the kampung head.

CONSTRUCTION AND DEVELOPMENT STAGE: Earth work and excessive use of the existing Kauluan gravel road can cause among others, (i) damage to the road, (ii) soil erosion and slope failure, (iii) increase in suspended sediment in stream waters, (iv) increase of airborne particulates during dry periods, (v) noise from the machineries deployed, and (vi) inherent risks to human safety both of onsite workers and the surrounding neighbourhood. The construction of intake weirs can result in immediate siltation of downstream water if the flow is not properly diverted. Indiscriminate disposal of wastes into the surrounding water bodies can seriously affect the aquatic ecosystem and downstream water use. Appropriate mitigation measures must therefore be taken during the civil works.

OPERATION AND MAINTENANCE: Major environmental issues that can be associated with the operation and maintenance of the proposed small scale upper Liwagu HEP project are (i) the power generation activities, particularly with regard to water extraction, and (ii) waste disposal.

Water quantity for the Liwagu and Mesilau rivers upstream of the intake points, and also the Liwagu river downstream of the power house will not be affected, as what comes into the HEP plant system will go out.

However, for the stretch between the intake points and the power house, there will be some reduction in flow. The reduction in river water quantity between the intake points and the powerhouse may lead to a number of adverse implications, the most critical being possible loss of habitat for aquatic life. Another potential negative impact will be creation of sites for mosquito breeding as low flows will lead to formation of small water pools in the rocky bed.

The ponding of water is not expected to affect the downstream water quality as the retention time in the pond is only about 2 hours.

Solid wastes, particularly the silt/sludge from the headpond and used lubrication oil from the power plant maintenance must be properly managed to avoid pollution of downstream water.

RECOMMENDATIONS

Based on the information gathered of the existing environment and the proposed development and operational plans, major recommendations with regard to environmental preservations are as follows:

- 1) In view of the pressing demand for water resource by the various users within the upper Liwagu catchment area, an accurate water auditing must be worked out to verify the feasibility of the proposed HEP project and avoid adverse environmental implications associated with water quantity.
- 2) During low flows, priority must be given to allocating sufficient quantity of flow for river maintenance purposes (for the intake - powerhouse stretch); the minimum flow recommended is 0.05 cumecs for Sg. Mesilau and 0.10 cumecs for Sg. Liwagu.
- 3) Affected villagers must be appropriately compensated for losses due to displacement or acquisition of land, prior to commencement of construction work.
- 4) As the area is still tectonically active, structures must be firmly anchored to the bedrocks; all installations must incorporate adequate safety features to minimise impact in case of foundation failure.
- 5) All engineering works must incorporate strict erosion control measures to minimise siltation problem of surface waters during the construction stage.

Table 1.0 summarises the potential impacts and recommended mitigation and abatement measures for the proposed upper Liwagu HEP project.

TABLE 1.0. SUMMARY OF POTENTIAL IMPACTS AND MITIGATING MEASURES OF THE PROPOSED UPPER LIWAGU SMALL-SCALE HYDROPOWER PROJECT

ITEM	PROJECT ACTIVITIES AND SOURCES OF POLLUTANTS	POTENTIAL IMPACTS	NATURE S (short-term) L (long-term) P (permanent)	PROPOSED MITIGATION MEASURES	RESIDUAL IMPACTS
A. INVESTIGATION STAGE					
	Site surveying and engineering/geotechnical investigation.	Minimal in terms of traffic related impacts (airborne dust, road safety, noise) May cause anxiety among population. Minimal impacts on biological components.	S S	First inform the village head. Ensure minimal cutting of terraces/riparian vegetation.	
Note: No new access road required.					
B. CONSTRUCTION AND DEVELOPMENT					
1.	Access road Note: Existing roads are unsurfaced and on hillslopes.	Reduction in surface water quality. Reduction in air quality. Increase in noise. Degradation of roads due to overloading.	S S S S	Make use of existing roads rather than cutting new roads. Road surface to be improved (gravelled and compacted to appropriate specification). Proper drainage should be provided for newly built stretch. Water to be lightly sprayed on access roads when dust is excessive. Working hours limited to daytime only. Close supervision by Site Engineer	
		Some loss in agriculture land	P	Affected land owners to be compensated for new road stretch that cut across vegetable farms.	

TABLE 1.0. SUMMARY OF POTENTIAL IMPACTS AND MITIGATING MEASURES OF THE PROPOSED UPPER LWAGU SMALL-SCALE HYDROPOWER PROJECT - cont'd

ITEM	PROJECT ACTIVITIES AND SOURCES OF POLLUTANTS	POTENTIAL IMPACTS	NATURE S (short-term) L (long-term) P (permanent)	PROPOSED MITIGATION MEASURES	RESIDUAL IMPACTS
2	Site clearing	Increased suspended solids in surface water due to surface erosion.	S	Attempt should be made at synchronising site clearing with dry periods.	
	Note: o The area is generally devoid of primary vegetation (replaced with vegetable farms). o There are no endangered and rare plant and wildlife species in the area.			Minimal cutting of riparian vegetation; replanting cleared strips. Provision of temporary drain and silt trap around headpond and powerhouse areas. Exposed steep slopes to be protected with plastic sheeting. Use excess earth for road grading and bunds. Working hours near settlement areas to be limited to daytime.	
		increase in noise level.	S	Water to be sprinkled during dry periods.	
		increase in suspended particulates in the air.	S	Plant debris must not be burnt on-site but properly stacked along the riparian or hill slopes to act as silt-screen.	
		Displacement of houses (Note: Land acquisition not extensive)	P	Affected population should be adequately compensated. Resettlement of affected household to be completed first prior to site clearing.	Displacement of about five households.
3	Earthworks	Increase in suspended particulates in air prior to stabilisation.	S	Spray water when dust is excessive.	
		Increase in suspended solids due to erosion by runoff.	S	Construct temporary drains which lead to a silt trap or settling pond.	

TABLE 1.0. SUMMARY OF POTENTIAL IMPACTS AND MITIGATING MEASURES OF THE PROPOSED UPPER LWAGU SMALL-SCALE HYDROPOWER PROJECT - cont'd

ITEM	PROJECT ACTIVITIES AND SOURCES OF POLLUTANTS	POTENTIAL IMPACTS	NATURE S (short-term) L (long-term) P (permanent)	PROPOSED MITIGATION MEASURES	RESIDUAL IMPACTS
				<p>Earthwork is best confined to periods of expected low precipitation.</p> <p>Excess earth to be stockpiled on levelled ground and compacted, or used for road grading or bunding.</p> <p>Earthwork should be phased so as not to allow too much area being exposed to erosion at any one time. Exposed areas to be revegetated/turfed immediately upon completion of earthwork.</p> <p>Proper diversion of stream flow.</p>	
		Siltation of streams during construction of intake weirs.	S	Minimal cutting of slope. Slope to be cut or cleared of vegetation only when the site is ready to be worked on. Work first from higher ground.	
		Slope failure.	S	Working time near settlement areas to be limited to day time only.	
		Increase in noise due to earthwork machinery.	S	Good landscaping work, particularly around headpond and powerhouse.	
		Reduction of aesthetics.			
4	Transportation	Increase in suspended particulates in air.	S	Lorry loads must be covered to avoid spillage.	
		Decrease in tranquility.	S	Sprinkling of road and tracks when dust is excessive. Transportation movement to be restricted to daytime.	

TABLE 1.0. SUMMARY OF POTENTIAL IMPACTS AND MITIGATING MEASURES OF THE PROPOSED UPPER LWAGU SMALL-SCALE HYDROPOWER PROJECT - cont'd

ITEM	PROJECT ACTIVITIES AND SOURCES OF POLLUTANTS	POTENTIAL IMPACTS	NATURE S (short-term) L (long-term) P (permanent)	PROPOSED MITIGATION MEASURES	RESIDUAL IMPACTS
		Safety hazards.	S	Safety regulation and normal construction supervision to be enforced.	
5	Material and equipment	Increase in noise.	S	Minimise number of trips by proper planning. Working hours in Kg. Naradaw is limited to daytime only.	
		Safety hazard in storage area	S	Machines, pipes etc. to be stored away from the public right of way and guarded.	
		Risk of accident at construction site.	S	Safety regulation and normal construction supervision to be enforced.	
6	Waste disposal	Deterioration of water quality.	S	Proper management of wastes (e.g. use of covered containers/pit) Excess earth to be reused or properly stocked. Other construction wastes to be disposed off at approved waste dump site. No open burning on-site.	
		Water contamination by sewage.	S	No full scale maintenance work on machineries/vehicles be allowed in the project area.	
7	Base camp	Indiscriminate dumping of wastes lead to ground and water pollutions - potential health hazard.	S	Provision of temporary septic tank to worker quarters. Proper management of wastes (see Waste Disposal).	
8	Labour force	Employment opportunities (+ve impact)	S	(Job priority given to locals).	

TABLE 1.0. SUMMARY OF POTENTIAL IMPACTS AND MITIGATING MEASURES OF THE PROPOSED UPPER LIWAGU SMALL-SCALE HYDROPOWER PROJECT - cont'd

ITEM	PROJECT ACTIVITIES AND SOURCES OF POLLUTANTS	POTENTIAL IMPACTS	NATURE S (short-term) L (long-term) P (permanent)	PROPOSED MITIGATION MEASURES	RESIDUAL IMPACTS
9	Scenic modification	Loss of natural scenery particularly at headpond - powerhouse area.	P	Replace with good landscape, and revegetated.	Man-made structure.
		Obstruction to human and animal passage	P	Minimise by bunding the blocking segment. Good landscaping.	
10	Abandonment	Safety: abandoned structures and machineries could be hazardous.	S	Dangerous machineries to be stored/parked in a guarded premise.	
C. OPERATION AND MAINTENANCE STAGE					
11	Power generation	Reduced flow between intake and powerhouse during low flows:	P		
		a. impacting aquatic life (loss of habitat)		Ensure a minimum of 0.05 and 0.10 cumecs of flow for Mesilau and Liwagu, respectively, for river maintenance (minimum 6' depth).	
		b. affecting direct water use		Possibly compensate by distributing a fraction of ponded water to nearby population.	
		c. possible mosquito breeding		Alternate day flushing during dry periods.	
		d. temporal reduction in water quantity for downstream users due to flow regulation.		Headpond storage must not exceed 2000 m ³ .	
		Noise	P	Proper installation of pipeline and genset to minimise vibration.	
		Risk of headpond and pipeline collapse/rupture		Installation of fail-safe system (including control valves and bundwalls at strategic points; consider alarm system. Structures (including pipeline support) must be anchored firmly on bedrocks.	

TABLE 1.0. SUMMARY OF POTENTIAL IMPACTS AND MITIGATING MEASURES OF THE PROPOSED UPPER LWAGU SMALL-SCALE HYDROPOWER PROJECT - cont'd

ITEM	PROJECT ACTIVITIES AND SOURCES OF POLLUTANTS	POTENTIAL IMPACTS	NATURE S (short-term) L (long-term) P (permanent)	PROPOSED MITIGATION MEASURES	RESIDUAL IMPACTS
12	Infrastructure and Utility				
	a) Road	Deterioration of water quality on impact	L	Installation of impact buffering structure (impact of this slight turbulence is counterbalanced by the SS removal in the headpond).	
	b) Water Supply	Anticipated improved road pavement upon completion of project (a positive impact)	L	See item 11(b).	
	c) Power Supply	Improved power supply along the Kundasang - Ranau grid (a positive impact)	L		
13	Waste disposal	Headpond sludge - potential contamination of river water by nutrients and pesticides.	L	Silt/sludge to be stockpiled on the levelled ground adjacent to the headpond. Encourage reuse for agricultural soil conditioning.	
		Oil wastes from genset maintenance - water contamination.	L	Collected (oil sump, drums), carefully stored and returned to supplier.	

Appendix 9 TECHNICAL SPECIFICATIONS

Appendix 9

TECHNICAL SPECIFICATIONS FOR FIELD INVESTIGATIONS

CONTENTS

	<u>Page</u>
1. Topographic Survey	AP9-1
2. Geological Investigation	AP9-15
3. Hydrological Survey	AP9-75
4. Environmental Impact Assessment	AP9-79
5. Documents Regarding Seismic Survey and Hydrological Survey	AP9-109

MALAYSIA

FEASIBILITY STUDY
ON
SMALL SCALE HYDROELECTRIC POWER DEVELOPMENT PROJECT
AT UPPER LIWAGU RIVER BASIN IN SABAH

TECHNICAL SPECIFICATIONS
FOR
FIELD INVESTIGATIONS

SEPTEMBER, 1991

JAPAN INTERNATIONAL COOPERATION AGENCY

CONTENTS

	<u>Page</u>
I. Topographic Survey	I.1
II. Geological Investigation	II.1
II.1 Core Drilling with Permeability Test and Standard Penetration Test (SPT)	II.1.1
II.2 Seismic Prospecting Survey	II.2.1
II.3 Geologic Mapping	II.3.1
III. Hydrological Survey	III.1
IV. Environmental Impact Assessment	IV.1

Appendix of Geologic Mapping

The Rule for Geologic Drawing

I. TOPOGRAPHIC SURVEY

1. General

The Specification shall be applicable to the topographic survey to be performed in order to obtain data necessary for the preliminary design of the Feasibility Study of the Small Scale Hydroelectric Power Development Project at Upper Liwagu River Basin in Sabah, Malaysia.

2. Scope of Work

The detailed work plan and quantities shall be fixed later. However, the work quantities are as follows:

1/500 scale topographic survey are :	0.098 Km ²
- Intake dam at Liwagu river	: 0.012 Km ²
- Intake dam at Mesilau river	: 0.017 Km ²
- Penstock and powerhouse	: 0.069 Km ²

The location of the Work is shown in Fig. I.1 and has been prepared based on the existing topographic map at a scale of 1/5,000.

3. Work Plan

The work plans are attached in Fig. I.2 - I.4, and has been prepared based on the existing topographic map at a scale of 1/2,500.

4. Work Period

The topographic survey shall be completed by 31 January 1992.

5. Technical Specifications

All measurement shall be expressed in the metric system and the language shall be English.

5.1 1/500 Scale Topographic Survey

The topographic maps at a scale of 1/500 shall be prepared for proposed areas and their surroundings, which include the planned intake dam, headrace route, head tank, penstock route, power house to be selected at best suitable sites. One (1) bench mark shall be monumented for each selected site based on the following item 5.2 Monumentation.

1/500 scale topographic survey is required to connect at least two existing control points, which were already established by the Government of Malaysia to serve as the origin for horizontal coordinates. Traversing and levelling for 1/500 scale topographic survey should follow the Specifications as described under 5.3 Traversing and 5.4 Levelling.

Topographical features, vegetation limits, and all the changes of the ground condition (knick points) necessary for 1/500 scale topographic mapping shall be observed by such a method as the Total Station Method. In case the boulders larger than 3 m in diameter be found in the river bed, their locations, features and elevation of top surface should be shown on 1/500 scale planimetric maps separated the topographic maps. Sufficient information shall be observed to enable 1 metre contours to be plotted on the map. Results of these field surveys shall be plotted. And the plotting accuracy shall be 0.3 mm on the map. The topographic maps shall be prepared at 1/500 scale with the standard contour line interval of 1 metre. The format of the manuscript sheet is 80 x 60 centimetres.

5.2 Monumentation

Monuments of bench marks shall be established at places suitable for maintenance and future use, and monumentation is to be carried out before traversing survey in conformity with Malaysian specifications (monument type, size, materials, and other detailed specifications).

5.3 Traversing

Traversing is required to originate at one of the existing control points which were already established by the Government of Malaysia (Land & Survey Kota Kinabalu) to serve as the origins for horizontal coordinates for traversing and closed to another one.

(1) Point Selection

Point selection shall be done as follows:

- (a) Turning points shall be installed so that their intervals are as equal in distance as possible.
- (b) Reference piles shall be installed for each bench mark considering possible damage to be done to the point.

(2) Horizontal Angle Observation

Horizontal angles shall be observed as follows:

- (a) The direction method shall be adopted unless specified otherwise by Engineer.
- (b) A pair (one set) of observation consists of two readings by telescope in the direct and in the reverse positions.
- (c) Two sets of observation at 0 degree and 90 degree positions shall be carried out for each point.
- (d) Allowances are as follows:

	Allowance of double angle differences	Allowance of difference of observation
Horizontal angle	30"	20"

(3) Vertical Angle Observation

One set of vertical angle observation consisting of reading by telescope in the direct and in the reverse shall be carried out for each sideline.

(a) Allowances are as follows:

Allowance of constant of elevation	30"
------------------------------------	-----

(4) Re-measurement

In case that any of horizontal observation results exceeds the allowances as specified in the above table, all observations involved at that particular position shall be redone.

(5) Measurement of Distance

Distance shall be measured as follows:

(a) In case of using electro-optical instrument, one set of observations consists of four readings for the direct reading instrument (digital count), and for the indirect reading instrument, one set consists of readings with all modulated frequencies.

(b) Required number of sets and allowance of difference of observation are shown in the following table.

Number of sets	1
Allowance of difference of observation	4 centimetres

Results of surveying and records, and sketches including distances from more than two distinct ground features are filled in the description form with two snap-photos of the bench mark. One is close-up and the other is a distance view.

(6) Computation and Data Sorting

(a) Coordinates computation for traversing shall be carried out in accordance with the local coordinate system (Rectified Skew Orthomorphic) and the Everest Spheroid, and the forms of point descriptions shall be provided by Engineer.

(b) Calculation at Field

Allowance of closure and closure ratio of the obtained results at field are shown in the following table. If any of the results exceed the allowance, re-observation shall be conducted after re-checking the results.

Closure of bearing	Closure rate of coordinate	Closure rate of height	Remarks
20 sqr. N	1/4,000	12 cm sigma S / sqr.L	

S: Length of each leg in Km N: Numbers of angle measurement
L: Number of legs

(c) The results of surveying and records are to be bound in the order of working steps. Index maps shall be prepared on the existing topographic map at a scale of 1/2,500.

5.4 Levelling

(1) This specification of levelling should be for determination of the elevations of bench marks by using levels and staves (direct levelling), and levelling is required to originate at more than two existing control points and checked both at the start and the end of each levelling route.

(a) The lines of sights shall not exceed 70 metres. Backsight and foresight shall be balanced at each instrument set up in order to cancel the residual instrument collimation errors.

- (b) The observer shall take readings disregarding 10 centimetres at both ends of the staves.
- (c) Levelling routes shall be in closed loops or an open levelling by duplicate measurements may be recommended.
- (d) Temporary bench marks shall be established approximately at 4 kilometres interval on the levelling routes. They are selected and painted at suitable places such as bridges, buildings, revetments, weirs, rocks or so on, that are easy to support.

(2) Calculation

Accuracy of observation

Closure of loop $5 \text{ cm} \times \text{sq. root } S$
 S : length of single run in km

- (3) Index maps of bench marks and levelling routes shall be prepared on the existing topographic map at a scale of 1/2,500.

6. Items not Specified in this Specifications

The items not specified in this Specifications shall be instructed by the Engineer as a variation order.


7. Final Products to be Delivered:

- (1) One (1) set of result of 1/500 scale topographic survey
 - (a) Observation notes
 - (b) Computation sheets
 - (c) 1/500 scale manuscript sheets
- (2) One (1) set of result of traversing
 - (a) Observation notes


- (b) Computation sheets
- (c) Final computation result
- (d) Descriptions of traversing point
- (e) An traversing point index map

(3) One (1) set of result of levelling survey

- (a) Observation notes
- (b) Computation sheets
- (c) Description of bench marks
- (d) A levelling route index map



Intake Dam at Liwagu R.




Intake Dam at Mesilau R.

Sungai Mesilau

Penstock & Powerhouse

Fig. I-1 LOCATION MAP




Intake Dam at Mesilau R.

Penstock & Powerhuose

300m
1:5000

Fig. I-2 INTAKE DAM at LIWAGU RIVER



Oleh Jabatan Tanah dan Ukur, Sabah, Feb., 1988

652

766 250 T

AP9 - 11

Fig. 1-3 INTAKE DAM at MESILAU RIVER

