

**JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
ELECTRICITY GENERATING AUTHORITY OF THAILAND (EGAT)
THE KINGDOM OF THAILAND**

**FEASIBILITY STUDY
ON
BULK POWER SUPPLY PROJECT
FOR
THE GREATER BANGKOK AREA**

FINAL REPORT

SUMMARY

AUGUST 1993

ELECTRIC POWER DEVELOPMENT CO., LTD.

M	P	N
J	R	
93 - 115		


JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

**ELECTRICITY GENERATING AUTHORITY OF THAILAND (EGAT)
THE KINGDOM OF THAILAND**

**FEASIBILITY STUDY
ON
BULK POWER SUPPLY PROJECT
FOR
THE GREATER BANGKOK AREA**

FINAL REPORT

SUMMARY




AUGUST 1993

ELECTRIC POWER DEVELOPMENT CO., LTD.

国際協力事業団

25649



MAP OF EGAT ELECTRIC POWER SYSTEM

EXISTING	UNDER CONSTRUCTION	FUTURE PROJECT
—	—	—
—	—	—
—	—	—
—	—	—
●	○	○
■	□	□
△	△	△
△	△	△
⊛	⊛	⊛
⊛	⊛	⊛

- 500 KV TRANSMISSION LINE
- 230 KV TRANSMISSION LINE
- 115 KV TRANSMISSION LINE
- 66 KV TRANSMISSION LINE
- 500 KV SUBSTATION
- 230 KV SUBSTATION
- 115 KV SUBSTATION
- 66 KV SUBSTATION
- THERMAL POWER PLANT
- HYDRO POWER PLANT

100 KILOMETER

CONTENTS

	<u>Page</u>
Conclusion and Recommendation	1
Chapter 1 Introduction	
1.1 Background of the Project	5
1.2 Objective and Scope of the Study	6
1.3 Activities of the Team in Thailand	7
1.4 Member of JICA Study Team	7
1.5 Provision of Equipment	8
1.6 Technology Transfer to the Counterparts	8
Chapter 2 Electric Power Demand Forecast	
2.1 Current Status of Electric Power Demand in the Kingdom of Thailand	9
2.2 Power Demand Forecast Made by JICA Team	9
Chapter 3 Power System Planning of the Greater Bangkok Area for a Long Future	
3.1 The Power System of Thailand - Present Situation	18
3.2 Approach to The Future Power Systems of The Greater Bangkok Area	20
3.3 Criteria for The Transmission System Planning	22
3.4 Measures to Cope with Requirements	22
3.5 Main Points for Planning Horizon Year Transmission Systems	24
Chapter 4 Power System Configuration of Planned Years	
4.1 Present	40
4.2 Up to 1997	41
4.3 Up to 2001	42
4.4 Up to 2006	43
4.5 Up to 2011	44

Chapter 5	Cost Estimation and Construction Scheduling	
5.1	Cost Estimation	45
5.2	Construction Scheduling	45
Chapter 6	Environmental Impact Study	
6.1	General	49
6.2	Recent EGAT Experience with Re-built 230 kV Multiple Circuit on Single Right of Way	49
6.3	Environmental Problem: Superimpose 500 kV Line on Existing 230 kV Line Right of Way	50
6.4	Static Induction under Extra-High Voltage Overhead Transmission Line	50
Chapter 7	Economic and Financial Analyses	
7.1	Economic Analysis	51
7.2	Financial Analysis	53
Chapter 8	Future Studies	73
Chapter 9	Technology Transfer	74

LIST OF TABLES

Table 2-1	ENERGY AND POWER GENERATION IN THAILAND (1981-1992)
Table 2-2	REQUIREMENT OF POWER AND ENERGY FROM EGAT BY UTILITIES
Table 2-3	POWER DEMAND FORECAST IN THAILAND (1/2, 2/2)
Table 2-4	POWER DEMAND FORECAST FOR MEA, PEA & EGAT'S DIRECT CUSTOMERS
Table 3-1	POWER DEVELOPMENT PLAN AND TRANSITION OF POWER SUPPLY CAPABILITY OF THAILAND
Table 3-2	COMPARISON OF THREE-PHASE SHORT CIRCUIT CURRENTS OF 2011 YEAR SYSTEMS REGARDING POWER PLANT CONFIGURATION
Table 3-3	REINFORCEMENT OF TRANSMISSION LINES IN THE GREATER BANGKOK AREA
Table 3-4	CONSTRUCTION PLAN OF SUBSTATIONS FOR POWER SYSTEM REINFORCEMENT IN THE GREATER BANGKOK AREA
Table 5-1	CONSTRUCTION AND EXPANSION SCHEDULE OF THE TRANSMISSION LINES IN THE GREATER BANGKOK AREA
Table 7-1	Construction Cost for Economic Analysis
Table 7-2	Operation and Maintenance Cost
Table 7-3	Benefit Flow and Cost Flow of the Project
Table 7-4	Calculation of EIRR
Table 7-5	Construction Cost for Financial Analysis
Table 7-6	Calculation of FIRR
Table 7-7	Construction Cost divided into Foreign and Local Currency Portion
Table 7-8	Calculation of Interest during Construction
Table 7-9	Financing for Construction
Table 7-10	Repayment Schedule of Debt (loan supplied 1994-1997)
Table 7-11	Repayment Schedule of Debt (loan supplied 1998-2001)
Table 7-12	Repayment Schedule of Debt (loan supplied 2002-2006)

Table 7-13	Repayment Schedule of Debt (loan supplied 2007-2011)
Table 7-14	Statement of Profit and Loss
Table 7-15	Cash Flow
Table 7-16	Calculation of Debt Service Ratio

LIST OF FIGURES

- Fig. 2-1 Method of Predicting Future Power and Energy Demand
- Fig. 2-2 Energy Demand at Generating End
- Fig. 2-3 Maximum Power Demand at Generating End
- Fig. 2-4 Energy Demand of MEA
- Fig. 2-5 Maximum Power Demand of MEA
- Fig. 3-1 ELECTRIC POWER SYSTEM OF THAILAND
- Fig. 3-2 ESTIMATED POWER TRANSMISSION AMONG REGIONS IN 2006
- Fig. 3-3 APPROACH TO FUTURE POWER SYSTEMS
- Fig. 3-4 Power Flow Diagram for Fiscal 2011 (Case 1)
- Fig. 3-5 Power Flow Diagram for Fiscal 2011 (Case 2)
- Fig. 3-6 TRANSMISSION SYSTEM OF THE GREATER BANGKOK AREA AFTER 2011
- Fig. 3-7 TRANSMISSION SYSTEMS OF THE GREATER BANGKOK AREA AT PRESENT AND IN FUTURE
- Fig. 4-1 EXISTING POWER SYSTEM AS OF EARLY 1993
- Fig. 4-2 POWER SYSTEM IN 1997
- Fig. 4-3 POWER SYSTEM IN 2001
- Fig. 4-4 POWER SYSTEM IN 2006
- Fig. 4-5 POWER SYSTEM IN 2011

CONCLUSION AND RECOMMENDATION

CONCLUSIONS

1. Power Demand in Greater Bangkok Area

In Thailand, the power generation is done by Electricity Generating Authority of Thailand (EGAT) and the maximum power generation and annual energy production in 1992 were recorded at 8,877 MW and 56,021 GWh, respectively. The power supply to the customers in the greater Bangkok area is made by Metropolitan Electricity Authority (MEA) and the maximum demands in the future are as follows:

Year	Max. Demand
1992	3,890 MW
1997	6,089 MW
2001	7,952 MW
2006	10,264 MW
2011	13,569 MW

2. Present Situations and Problems of Power Supply Facilities

In the Greater Bangkok area, there are two thermal power plants, say North Bangkok Thermal Power Plant (237.5 MW) and South Bangkok Thermal Power Plant (1,339 MW). The power supply to the demand in the Greater Bangkok Area is from the above two power plants and from power plants outside the area by 500 kV and/or 230 kV transmission lines from north, west and southeast.

The power supply facilities such as transmission lines and substations are expanded according to the demand increasing. However, it is difficult to expand the necessary power facilities following to the demand by EGAT itself since the power demand increase is extraordinary high pitch due to rapid development of the city areas and arising the many problems such as land acquisition for substations and transmission lines as well as environmental issues for installing new power facilities.

Under these circumstances, EGAT has realized the needs of the feasibility study on the power supply project for the Greater Bangkok Area based on the long range vision and requested the study to the Japanese government through Thai government, and the study has been done by this Japan International Cooperation Agency (JICA) Study Team.

3. Basic Assumptions of the Feasibility Study

This feasibility study has been made based on the following assumptions:

- (1) Economy
Growing up steady as same as that at the present.
- (2) Power Demand
The power is to be supplied without load control.
- (3) Budget for the Project
The planning of the Project is based on the technical requirement, say there is no power supply interruption after clearing fault when a transmission line or a transformer damaged. Therefore, the planning has not been reduced in the scale due to any budgetary restriction.
- (4) Right of Way of Transmission Line
The present right of way is available in the future.
- (5) Environmental Issues
Only predicted issues are considered within the present environmental restricts.
- (6) Power System Design
In principle, the planning is based on the single contingency criteria used by EGAT.
- (7) Implementation of the Project
The planning of transmission lines is mainly by overhead transmission lines taking economy into consideration, only the route where overhead transmission line could not be built by physical restrictions or by aviation regulations.
The planning is without considerable power supply interruption during implementation of the Project.
- (8) Level of Technology
The planning is made by using the proven technology. (Unproven new technology was not considered.)

4. Major Features of Bulk Power Supply Project

- (1) Outline
 - 500 kV Overhead Transmission Line (new) : 226 circuit-km
 - 230 kV Overhead Transmission Line (new) : 146 circuit-km
 - 230 kV Overhead Transmission Line (Renov.) : 472 circuit-km
 - 230 kV Underground Transmission Line (new) : 242 circuit-km

- 500 kV Substations : 6 substations (5 new, 1 expansion)
- 230 kV Substations : 18 substations (10 new, 8 expansion)

(2) Project Cost (including both of EGAT's and MEA's portions and estimated in 1992 price level)

- Stage 1 (to be completed by 1997) : US\$696,285,000.-
 - Stage 2 (to be completed by 2001) : US\$470,739,000.-
 - Stage 3 (to be completed by 2006) : US\$365,768,000.-
 - Stage 4 (to be completed by 2011) : US\$421,288,000.-
- Total : US\$1,954,080,000.-

Note: The cost of foundation of the transmission lines is different by the foundation soil, the most of the transmission lines tower foundation is constructed at the poor soil area. The above cost is based on the assumption that all the foundations are in the poor soil.

5. Economic Justification

In the study, the cost of the Project was estimated for the poor soil tower foundation case. In the study of the economic evaluation of the Project, the Project is considered economically to be justified.

6. Financial Analysis

In the financial analysis of the Project, the flow of cost and flow of the benefit are considered as follows:

- (1) Cost flow consists of the construction cost and the operation and maintenance cost of the power facilities, and:
- (2) Benefit flow consists of increased electricity sales due to the Project.

As the result of the financial analysis, the Project is considered also financially to be sound.

RECOMMENDATIONS

- (1) This study is made globally taking long range view of bulk power supply for the Greater Bangkok Area into consideration. Therefore, in advance to the actual implementation of the Project, it is necessary to study the Project further in detail. During the study, when the better alternatives be found, the revision of the plan will be preferable taking the long range view into consideration.
- (2) In the study, the 500 kV transmission lines to supply the power to the Greater Bangkok Area Project has been designed based on the present Power Development Plan (PDP) by EGAT. Therefore, if there is any change in the 500 kV transmission line system, the transmission system has to be reviewed accordingly.
- (3) Since the preparation of the required budget, the field survey, the detailed design and negotiation of the land acquisition will take for long time, the preparatory works should be started few years before the construction work start.
- (4) This is the first feasibility study on the Bulk Power Supply for the Greater Bangkok Area, therefore, the basic drawing for the Project is in the report taking the present situation of the power supply for the area into consideration. The study of the Project has to be reviewed time to time when the circumstances be changed.
- (5) Consequence to this study, the feasibility study on the expansion and renovation of the transmission line and distribution network system with the voltages 230 kV and below in the Greater Bangkok Area is necessary.

CHAPTER 1 INTRODUCTION

1.1 Background of the Project

In Thailand, due to increase of population and vivid commercial and industrial activities as well as grading-up of living standard, the electric energy consumption is heavily increasing in these years. In Greater Bangkok area which electricity is supplied by Metropolitan Electricity Authority (MEA), the average annual growth rate of power demand in these five years is 12.35%. It is noted that this growth rate is tremendously high comparing to 6.3% in Japan. The maximum power demand of the Greater Bangkok area in 1992 was recorded at 3,890 MW, and according to the Working Group for Load Forecast which members compose of staff of Electricity Generating Authority of Thailand (EGAT) and MEA, the expected maximum power demand will be:

6,089 MW	in 1997
7,952 MW	in 2001
10,264 MW	in 2006

To meet the power demand of MEA, EGAT has expanded power facilities in accordance with the short and long term plans. However, due to rapid development in the Greater Bangkok area, it is very difficult to obtain spaces for substations and new right of ways for transmission lines. In long term view, it is jeopardized to expand the power facilities in accordance with the long term plan if the demand is increased steadily.

To solve these problems, EGAT took up "Bulk Power Supply Project for the Greater Bangkok Area" as an emergency issue, which is a long term power facilities expansion plan in the Greater Bangkok Area up to the year of 2011 including 500kV and 230kV transmission lines and substations.

The Government of Thailand therefore requested technical assistant for "the feasibility study on Bulk Power Supply Project for the Greater Bangkok Area" to the Government of Japan in May 1991.

In response to this request, the Government of Japan had the Japan International Cooperation Agency (JICA) dispatched the Preliminary Study Mission to Thailand in November 1991, and the Mission surveyed the background of the request, performed site surveys, collected information and data, and made a preliminary study in the future policies and other relevant matters.

On November 8, 1991, the Preliminary Study Team of JICA and EGAT reached an agreement on "the Scope of Work for Feasibility Study on Bulk Power Supply Project for the Greater Bangkok Area".

Based on the Agreement, the Government of Japan decided to conduct a feasibility Study on the Project, and assigned this work to JICA.

1.2 Objective and Scope of the Study

1.2.1 Objective of the Study

The objective of this study is;

- To estimate the power demand growth in the Greater Bangkok Area of the Kingdom of Thailand, and
- To formulate the optimal transmission line and substation facility expansion plan which is designated to meet this power demand growth up to the year of 2011.

In formulating this plan,

- all factors affecting the future electric power supply potentials, including the current status of power supply facilities as identified by available data,
- constraints on power supplies including site problems and technical problems,
- as well as environmental issues that may affect social reactions,

shall be thoroughly addressed and evaluated.

1.2.2 Scope of the Study

This study is a feasibility study, the objective area of which consists of the Greater Bangkok Area and the Central Area which are respectively defined as below.

Greater Bangkok Area

The 230 kV transmission lines and 500 kV transmission lines, plus substations related to these transmission lines (including the 230 kV facilities of MEA)

Central Area

500 kV transmission lines and substations related to these transmission lines

1.2.3 Study Items

Study items in this feasibility study consists of;

- a) Collection and evaluation of existing data and information
- b) Field investigation
- c) Power survey

- d) Environmental studies
- e) Optimal power system plan
- f) Basic Design
- g) Economic and financial Analyses
- h) Cost estimation and construction scheduling

1.3 Activities of the Team in Thailand

During the period from July 1992 to August 1993, the JICA study team performed following activities in Thailand.

1st: July 1 to 30, 1992

Presentation of the methodology and the schedule of the study based on the Inception Report(Draft), the field survey for the related areas, collection of the study data and discussion on the Inception Report(Draft).

2nd: October 7 to 21, 1992

Presentation of the progress and achievement of the study. Discussion on updated EGAT PDP, progress of environmental survey and basic approach to economic analysis.

3rd: February 16 to March 2, 1993

Presentation of the Interim Report. Discussion on power system planning, power system analysis and change of transmission line route by proposed new airport area. Site survey to proposed new substation.

4th: June 20 to July 4, 1993

Presentation of the Draft Final Report by personnel each other. Discussion on economic evaluation financial analyses, construction schedule and future study.

Meeting of training schedule and item of technical transfer.

1.4 Member of JICA Study Team

Mr. Takuya Takaoka	Team Leader
Mr. Mitsuru Omori	Power System Planning
Mr. Masao Koike	Transmission Line Planning
Mr. Shigekatsu Soejima	Substation Planning
Mr. Vichien Virapanish	Environmental Study
Mr. Hiroto Inabe	Power System Analysis

Mr. Takashi Masuo

Economic Analysis

Mr. Hideaki Morishita

Secretary

1.5 Provision of Equipment

To promote the power system analyses using computer in this study, the following equipment was provided by JICA to EGAT.

Item	Q'ty	Unit	Type
Computer	1	set	ACER Frame 1000,1750
Laser Printer	1	set	HP Laser Jet III
X-Y Plotter	1	set	Roland DXY-1300
Power Stabilizer	1	set	

1.6 Technology Transfer to the Counterparts

The technology transfer to the counterparts from EGAT was performed in Japan during this study period as follows:

(1) Transmission Line and Substation Design

a) Counterpart : Mr. Kijja Snipatthamkura

b) Schedule : November 29 to December 23, 1992
(25 days)

(2) Power System Analysis

a) Counterpart : Mr. Kittipon Chuanagaroon

b) Schedule : July 13 to August 7, 1993 (26 days)

CHAPTER 2 ELECTRIC POWER DEMAND FORECAST

2.1 Current Status of Electric Power Demand in the Kingdom of Thailand

The electric power demand in Thailand has been increasing substantially due to her recent favorable economic growth and incoming rush of enterprises and factories.

Transition of power and energy generated in Thailand for the past ten years is shown in Table 2-1. Yearly average growth rates of power and energy generation during the last ten years are 12.07% and 12.74% respectively. The annual load factor at generating end, which once showed a tendency to decrease at a rate of about 0.4% per year from about 70% in 1981 reaching the lowest 66.77% in 1989, has begun to increase and recovered to the level of about 70%.

Transition of power and energy requirement from EGAT's customers, i.e. the Metropolitan Electricity Authority (MEA), the Provincial Electricity Authority (PEA) and other direct customers, is shown in Table 2-2.

MEA is an organization to distribute electric energy in the Greater Bangkok Area, Nonthaburi and Samut Prakan Provinces, whereas PEA is one to distribute in all the provinces except the MEA's area.

The actual result of 1992 shows ratios of the three parties' energy consumption as MEA 45.2% PEA 51.5%, and the other direct customers 3.3%.

In respect of the maximum power demand, ratios of the three parties were as MEA 43.2%, PEA 53.6% and the other direct customers 3.2%.

Most part of the PEA demand comes from local cities, towns, and fishing and agrarian villages, and the demand is particularly high at the lighting peak time.

The load factor of PEA demand is about 0.57 ~ 0.60, which is considerably low in comparison with MEA's 0.68 or so.

2.2 Power Demand Forecast Made by JICA Team

Fig. 2-1 shows the method of predicting future power and energy demand.

Power demand of Thailand in future forecasted by the JICA Team is shown in Table 2-2 and 2-3, and Fig. 2-2, 2-3, 2-4 and 2-5.

Table 2-1 ENERGY AND POWER GENERATION IN THAILAND (1981 -1992)

Fiscal Year	Energy			Power			Load Factor (%)
	Generation (GWh)	Growth (%)		Generation (MW)	Growth (%)		
		(GWh)	(%)		(MW)	(%)	
1981	15,960	1,206	8.2	2,589	171	7.1	70.4
1982	16,882	922	5.8	2,838	249	9.6	67.9
1983	19,066	2,184	12.9	3,204	366	12.9	67.9
1984	21,066	2,000	10.5	3,547	343	10.7	67.8
1985	23,357	2,290	10.9	3,878	331	9.3	68.8
1986	24,780	1,423	6.1	4,181	303	7.8	67.7
1987	28,193	3,414	13.8	4,734	553	13.2	68.0
1988	31,997	3,804	13.5	5,444	710	15.0	67.1
1989	36,457	4,460	13.9	6,233	789	14.5	66.8
1990	43,189	6,732	18.5	7,094	861	13.8	69.5
1991	49,225	6,036	14.0	8,045	951	13.4	69.8
1992	56,006	6,781	13.8	8,877	832	10.3	72.0
Average Growth	-	-	-	-	-	-	-
1982 - 1986	-	1,764	9.2	-	318	10.1	-
1987 - 1992	-	5,205	14.6	-	783	13.4	-

Table 2-2 REQUIREMENT OF POWER AND ENERGY FROM EGAT BY UTILITIES

Fiscal Year	Power & Energy Generated by EGAT			Requirement by MEA			Requirement by PEA			Requirement by Direct Customers		
	Power (MW)	Energy (GWh)	Load Factor (%)	Power (MW)	Energy (GWh)	Load Factor (%)	Power (MW)	Energy (GWh)	Load Factor (%)	Power (MW)	Energy (GWh)	Load Factor (%)
1981	2,589	15,960	70.4	1,388	8,496	69.9	1,115	5,569	57.0	100	505	57.6
1982	2,838	16,882	67.9	1,499	8,719	66.4	1,264	6,190	55.9	102	494	55.3
1983	3,204	19,066	67.9	1,631	9,666	67.7	1,493	7,287	55.7	125	637	58.2
1984	3,547	21,066	67.8	1,776	10,498	67.5	1,675	8,174	55.7	129	710	62.8
1985	3,878	23,357	68.7	1,823	10,910	68.3	1,918	9,391	55.9	162	963	67.9
1986	4,181	24,780	67.7	1,983	11,391	65.6	2,078	10,190	56.0	170	1,037	69.6
1987	4,734	28,193	68.0	2,178	12,930	67.8	2,375	11,792	56.7	167	1,123	76.8
1988	5,444	31,997	67.1	2,432	14,564	68.4	2,745	13,737	57.1	175	1,192	77.8
1989	6,233	36,457	66.8	2,715	16,144	67.9	3,239	16,130	56.8	206	1,337	74.1
1990	7,094	43,189	69.5	3,124	18,623	68.1	3,737	19,318	59.0	214	1,428	76.2
1991	8,045	49,225	69.8	3,519	20,777	67.4	4,252	22,493	60.4	229	1,504	74.9
1992	8,877	56,006	72.0	3,993	22,946	65.6	4,956	26,132	60.2	295	1,693	65.6
Average Annual Growth Rate (%) (1983 - 1992)	12.1	12.7	-	10.3	10.2	-	14.7	15.5	-	11.2	13.1	-

Table 2-3 POWER DEMAND FORECAST IN THAILAND (1/2)

Year	Generating End				Sending End			
	Generated Energy (GWh)	kWh Station Losses (%)	Maximum Power (MW)	kWh Station Losses (MW)	Load Factor (%)	Energy (GWh)	Maximum Power (MW)	Load Factor (%)
1980	14,753.73	4.00	2,417.40	87	69.7	14163.28	2,330.37	69.38
1981	15,959.97	3.84	2,588.70	89	70.4	15,347.68	2,499	70.1
1982	16,881.95	3.57	2,838.00	91	67.9	16,279.46	2,747	67.7
1983	19,066.30	3.45	3,204.30	100	67.9	18,408.30	3,105	67.7
1984	21,066.44	3.94	3,547.30	126	67.8	20,236.34	3,422	67.5
1985	23,356.57	4.38	3,878.40	153	68.7	22,333.76	3,726	68.4
1986	24,779.53	4.09	4,180.90	154	67.7	23,765.90	4,027	67.4
1987	28,193.16	4.22	4,793.90	180	68.0	27,003.86	4,554	67.7
1988	31,996.94	4.40	5,444.00	215	67.1	30,590.45	5,229	66.8
1989	36,457.09	4.20	6,232.70	236	66.8	34,924.84	5,997	66.5
1990	43,188.79	4.95	7,093.70	316	69.5	41,049.79	6,778	69.1
1991	49,225.03	4.83	8,045.00	350	69.8	46,845.11	7,695	69.5
1992	56,006.44	4.86	8,876.90	388	72.0	53,285.44	8,489	71.7
1993	61,919	4.92	10,103	447	70.0	58,874	9,656	69.6
1994	68,744	4.97	11,217	501	70.0	65,329	10,715	69.6
1995	75,860	5.00	12,359	556	70.1	72,067	11,803	69.7
1996	83,576	5.00	13,616	613	70.1	79,397	13,004	69.7
1997	91,271	5.00	14,849	668	70.2	86,707	14,181	69.8
1998	99,333	5.00	16,160	727	70.2	94,366	15,433	69.8
1999	108,047	5.00	17,553	790	70.3	102,645	16,763	69.9
2000	117,093	5.00	18,995	855	70.4	111,238	18,141	70.0
2001	126,883	5.00	20,584	926	70.4	120,539	19,657	70.0
2002	135,895	5.00	22,046	992	70.4	129,100	21,053	70.0
2003	145,508	5.00	23,605	1062	70.4	138,232	22,543	70.0
2004	155,302	5.00	25,194	1134	70.4	147,537	24,060	70.0
2005	165,292	5.00	26,815	1207	70.4	157,028	25,608	70.0
2006	175,755	5.00	28,512	1283	70.4	166,967	27,229	70.0
2007	186,437	5.00	30,245	1361	70.4	177,115	28,884	70.0
2008	196,738	5.00	31,916	1436	70.4	186,901	30,480	70.0
2009	206,872	5.00	33,560	1510	70.4	196,528	32,050	70.0
2010	216,868	5.00	35,181	1583	70.4	206,025	33,598	70.0
2011	226,672	5.00	36,772	1655	70.4	215,339	35,117	70.0

Table 2-3 POWER DEMAND FORECAST IN THAILAND (2/2)

Transmission & Distribution Losses (GWh)	Transmission & Distribution Losses (%)	Energy Consumption		GDP in 1972 price		Elasticity of GWh per GDP	Energy Consumption per GDP (Wh/Baht)	Population (Thousand)	kWh per Capita		Year
		(GWh)	(%)	(M Baht)	(%)				(kWh)	(%)	
1,156.31	8.16	13006.97		299,472		0.44	43.43	46,961	277		1980
1,978.23	12.9	13,369.45	2.8	318,440	6.3	2.67	41.98	47,875	279	0.82	1981
1,461.30	9.0	14,818.16	10.8	331,379	4.1	1.15	44.72	48,847	303	8.63	1982
2,355.61	12.8	16,052.69	8.3	355,411	7.3	1.35	45.17	49,515	324	6.87	1983
2,633.92	13.0	17,602.42	9.7	380,739	7.1	3.33	46.23	50,583	348	7.34	1984
2,674.14	12.0	19,659.62	11.7	394,113	3.5	1.58	49.88	51,796	380	9.07	1985
2,710.65	11.4	21,055.25	7.1	411,813	4.5	1.80	51.13	52,969	398	4.73	1986
2,768.53	10.3	24,235.33	15.1	446,361	8.4	1.25	54.30	53,973	449	12.96	1987
3,025.65	9.9	27,564.80	13.7	495,378	11.0	0.90	55.64	54,961	502	11.69	1988
3,410.53	9.8	31,514.31	14.3	574,355	15.9	1.72	54.87	55,448	568	13.32	1989
3,964.75	9.7	37,085.03	17.7	633,395	10.3	1.55	58.55	56,340	658	15.81	1990
4,820.04	10.3	42,559.03	14.8	693,559	9.5	1.30	61.36	57,199	744	13.04	1991
5,681	10.7	47,604	11.9	756,806	9.1	1.30	62.9	58,041	820	10.2	1992
5,812	9.9	53,062	11.5	823,547	8.8	1.30	64.4	58,876	901	9.9	1993
6,385	9.8	58,945	11.1	893,781	8.5	1.25	65.9	59,693	987	9.6	1994
6,973	9.7	65,095	10.4	968,380	8.3	1.25	67.2	60,508	1076	8.9	1995
7,605	9.6	71,792	10.3	1,048,089	8.2	1.20	68.5	61,311	1171	8.8	1996
8,222	9.5	78,485	9.3	1,129,518	7.8	1.20	69.5	62,100	1264	7.9	1997
8,859	9.4	85,508	8.9	1,213,735	7.5	1.20	70.4	62,879	1360	7.6	1998
9,540	9.3	93,105	8.9	1,303,605	7.4	1.15	71.4	63,640	1463	7.6	1999
10,235	9.2	101,003	8.5	1,399,768	7.4	1.15	72.2	64,390	1569	7.2	2000
10,980	9.1	109,559	8.5	1,502,868	7.4	1.15	72.9	65,182	1681	7.2	2001
11,642	9.0	117,458	7.2	1,601,374	6.6	1.10	73.3	66,012	1779	5.9	2002
12,341	8.9	125,891	7.2	1,705,899	6.5	1.10	73.8	66,803	1885	5.9	2003
13,040	8.8	134,497	6.8	1,811,911	6.2	1.10	74.2	67,594	1990	5.6	2004
13,740	8.7	143,288	6.5	1,921,565	6.1	1.08	74.6	68,385	2095	5.3	2005
14,464	8.7	152,504	6.4	2,036,000	6.0	1.08	74.9	69,176	2205	5.2	2006
15,189	8.6	161,926	6.2								2007
15,868	8.5	171,033	5.6								2008
16,519	8.4	180,009	5.2								2009
17,144	8.3	188,881	4.9								2010
17,739	8.2	197,599	4.6								2011

Table 2-4 POWER DEMAND FORECAST FOR MEA, PEA & EGATS DIRECT CUSTOMERS

Year	EGAT			MEA			PEA			EGAT's Direct Customers		
	Generated Energy (GWh)	Maximum Power (MW)	Load Factor (%)	Received Energy (GWh)	Maximum Power (MW)	Load Factor (%)	Received Energy (GWh)	Maximum Power (MW)	Load Factor (%)	Received Energy (GWh)	Maximum Power (MW)	Load Factor (%)
1980	14,754	2,417	69.7	8,286	1,392	68.0	4,966	974	58.2	446	86	
1981	15,960	2,589	70.4	8,496	1,388	69.9	5,569	1,115	57.0	505	100	
1982	16,882	2,638	67.9	8,719	1,499	66.4	6,190	1,264	55.9	494	102	
1983	19,066	3,204	67.9	9,666	1,631	67.7	7,287	1,493	55.7	637	125	
1984	21,066	3,547	67.8	10,498	1,776	67.5	8,174	1,675	55.7	710	129	
1985	23,357	3,878	68.7	10,910	1,823	68.3	9,391	1,918	55.9	963	162	
1986	24,780	4,181	67.7	11,391	1,983	65.6	10,190	2,078	56.0	1,037	170	
1987	28,193	4,734	68.0	12,930	2,178	67.8	11,792	2,375	56.7	1,123	167	
1988	31,997	5,444	67.1	14,564	2,432	68.4	13,737	2,745	57.1	1,192	175	
1989	36,457	6,233	66.8	16,144	2,715	67.9	16,130	3,239	56.8	1,337	206	
1990	43,189	7,094	69.5	18,623	3,124	68.1	19,318	3,737	59.0	1,428	214	
1991	49,225	8,045	69.8	20,777	3,519	67.4	22,493	4,252	60.4	1,504	229	
1992	56,006	8,877	72.0	22,946	3,993	65.6	26,132	4,956	60.2	1,693	295	
1993	61,919	10,103	70.0	26,230	4,403	68.0	29,201	5,377	62.0	1,717	280	
1994	68,744	11,217	70.0	28,849	4,843	68.0	32,820	5,854	64.0	1,820	297	
1995	75,860	12,359	70.1	31,549	5,295	68.0	36,653	6,538	64.0	1,929	315	
1996	83,576	13,616	70.1	34,460	5,785	68.0	40,872	7,290	64.0	2,045	333	
1997	91,271	14,849	70.2	37,292	6,260	68.0	45,142	8,052	64.0	2,147	350	
1998	99,333	16,160	70.2	40,214	6,751	68.0	49,661	8,858	64.0	2,254	368	
1999	108,047	17,553	70.3	43,345	7,277	68.0	54,594	9,738	64.0	2,367	386	
2000	117,093	18,995	70.4	46,560	7,816	68.0	59,789	10,500	65.0	2,485	405	
2001	126,883	20,584	70.4	50,003	8,394	68.0	65,451	11,495	65.0	2,610	426	
2002	135,895	22,046	70.4	53,041	8,904	68.0	70,746	12,425	65.0	2,714	443	
2003	145,508	23,605	70.4	56,261	9,445	68.0	76,452	13,427	65.0	2,823	460	
2004	155,302	25,194	70.4	59,484	9,986	68.0	82,328	14,459	65.0	2,936	479	
2005	165,292	26,815	70.4	62,713	10,528	68.0	88,380	15,522	65.0	3,053	498	
2006	175,755	28,512	70.4	66,051	11,088	68.0	94,765	16,643	65.0	3,175	518	
2007	185,437	30,245	70.4	69,304	11,634	68.0	101,471	17,821	65.0	3,270	533	
2008	196,798	31,916	70.4	72,396	12,153	68.0	107,975	18,963	65.0	3,368	549	
2009	206,872	33,560	70.4	75,345	12,648	68.0	114,461	20,102	65.0	3,469	566	
2010	216,868	35,181	70.4	78,161	13,121	68.0	120,942	21,240	65.0	3,574	583	
2011	226,672	36,772	70.4	80,825	13,569	68.0	127,385	22,372	65.0	3,681	600	

Fig. 2-1 Method of Predicting Future Power and Energy Demand




Fig. 2-2 Energy Demand at Generating End




Fig. 2-3 Maximum Power Demand at Generating End




Fig. 2-4 Energy Demand by MEA





Fig. 2-5 Maximum Power Demand by MEA



CHAPTER 3 POWER SYSTEM PLANNING OF THE GREATER BANGKOK AREA FOR A LONG FUTURE

3.1 The Power System of Thailand - Present Situation

Fig. 3-1 shows the outline of the power system of Thailand. Voltages of the transmission lines forming the power system of Thailand are 500 kV, 230 kV, 115 kV and 69 kV. The frequency of electricity is 50 Hz.

The power system is divided into the following four regions.

- Region 1 : Metropolitan Area and its Surrounding Part of Thailand
- Region 2 : Northeastern Part of Thailand
- Region 3 : Southern Part of Thailand
- Region 4 : Northern and Central Part of Thailand

Each region is connected by transmission lines of 500 kV, 230 kV and 115 kV.

The total capacity of power generating facilities is 11,033 MW as of September 1992. It consists of hydro-electric power 2,429.2 MW (accounting for 22.0% of the total), oil/gas and lignite fired thermal 5,506.5 MW (49.9%), combined cycle 2,859.6 MW (25.9%) and gas turbine 238.0 MW (2.2%).

3.1.1 Power Supply Capability And Electric Energy Demand of Each Region

Below is the feature of each region in respect of power supply and demand as of September 1992.

- (1) In Region 1, there are thermal power stations and combined cycle plants of large scale such as SOUTH BANGKOK (1,330.0 MW), BANG PAKONG (3,074.6 MW), RAYON (1,130.0 MW), etc., and also reservoir type hydro-electric power stations of large scale such as SRINAGARIND (720.0 MW), KHAO LAEM (300.0 MW), etc. A total capacity of these facilities is 6,973.3 MW, accounting for about 63.2% of the total installed capacity of power sources in this country.

This region has a great demand for electric energy which accounts for about 75% of the total electric energy demand in the country.

- (2) In Region 2, there are hydro-electric power stations of medium scale such as CHULABHORN (40.0 MW), SIRINDHORN (36.0 MW), a combined cycle power plant at NAM PONG (355.0 MW) and some gas turbines.

A total capacity of these facilities is 491.3 MW, accounting for 4.5% of the total installed capacity in the country.

These power sources are capable of load-frequency control and used effectively in an ordinal operation especially at the peaking time.

The power supplied for the base load is transmitted mainly from Region 4 through the 230 kV transmission lines and also from Region 1 through the 115 kV transmission lines.

Some of the power required in this region is supplied from Lao PDR, a neighboring country, based on a contract to purchase surplus energy (power) generated by the Nam Ngum hydro-electric power station (150 MW) which belongs to this country.

Demand for electric energy in this region accounts for nine to ten percent of the total demand of the country.

- (3) In Region 3, there are thermal power stations such as KHANOM (150.0 MW), KRABI (34.0 MW), SURATANI (72.0 MW), etc. and also hydro-electric such as RAJJAPRABHA (240.0 MW), BANG LANG (72.0 MW), etc.

A total capacity of these facilities including the gas turbine (42.0 MW) at Hat Yai is 611.3 MW which accounts for 5.5% of the total installed capacity in the country.

Power for base load of this region is supplied from the Khanom and Krabi thermal and from Region 1 as well through the Second Central - Southern Tie line, a 230 kV double-circuit between PRACHUAP KHIRI KHAN and SURAT THANI.

This region and a neighboring country, Malaysia, are mutually exchanging electric power by means of the 115/132 kV power system interconnection which has been in operation between two countries since February 1981.

Demand for electric energy in this region accounts for six to seven percent of the total demand of the country.

- (4) Power stations installed in Region 4 are the Mae Moh thermal power plant with the output of 2,025.0 MW, and hydro-electric of large scale such as BHUMIBOL (535.0 MW), SIRIKIT (375.0 MW), etc.

A total output of these facilities is 3,070.0 MW, which is about 28% of the total installed capacity of power sources of this country.

Demand for electric energy in this region accounts for eight to nine percent of the total demand of the country.

3.1.2 The Power Transmission among The Regions

Even though Region 1 has a very large supply capability of power, it cannot meet independently its great demand for power which accounts for approximately 75% of the total demand of the country.

A main load center of the region is the Greater Bangkok Area, namely Bangkok and its surroundings.

Table 3-1 shows the transition of power supply capability in Thailand which is estimated according to EGAT's power development plan, PDP 92-01(1). The sites of power development in near future are centered on

the Mae Moh area in the northern district of Region 4 and the eastern seaboard area of Region 1.

The JICA team has estimated power transmission among the regions in 2006. Fig. 3-2 shows an example of this.

3.2 Approach to The Future Power Systems of The Greater Bangkok Area

3.2.1 Present Situation of The Transmission System

In the Greater Bangkok Area, there are two thermal power plants at present, namely NORTH BANGKOK (237.5 MW) and SOUTH BANGKOK (1,330 MW). They are connected to the 230 kV transmission lines which encircle the metropolitan area forming three loops.

Power to serve the Greater Bangkok Area is supplied from these two power plants and from this ring of 230 kV transmission lines.

To this ring of 230 kV transmission lines, electric power is sent not only from the above power plants but also from the power plants located in Region 1, such as BANG PAKONG (2,276.6 MW), SRINAGARIND (720 MW), KHAO LAEM (300 MW) and so forth by means of 230 kV transmission lines.

Further more, some of electric power generated at the power plants located in Region 3, namely MAE MOH (2,025 MW), BHUMIBOL (535 MW) and SIRIKIT (375 MW), is sent to the Greater Bangkok Area by means of 500 kV and 230 kV transmission lines.

Substations connected with the 230 kV transmission lines of the Greater Bangkok Area, such as SAI NOI, NORTH BANGKOK, BANG KAPI, BANGKOK NOI, SOUTH BANGKOK, BANG PHLI and RANGSIT, play currently a very important role to collect electric power from the above power plants and send it to the other substations to distribute in the area.

The transmission system composed of these substations and the 230 kV transmission lines can fulfill its function at the present time and will work for several years to come by adopting measures to increase the capacity of the existing facilities, such as the use of twin conductors on the transmission lines and installation of additional transformer banks in the substations.

3.2.2 The Power Demand of The Project Area

Below is the forecast of future power demand of the MEA service area which covers most part of the Greater Bangkok Area.

Fiscal Year	Maximum Power Demand (MW)
1992	3,993 (actual)
1997	6,089 (forecast by the Thai Organization)
2001	7,952 (forecast by the Thai Organization)
2006	10,264 (forecast by the Thai Organization)
2011	13,569 (forecast by the JICA team)

Such a high growth of power demand of the project area needs to construct new substations and transmission lines, but in recent years there are problems to be encountered due to difficulties in the acquisition of land for substations and rights-of-way for transmission lines to be constructed.

There is another problem that some of the substation buses will encounter excessive fault levels for the interrupting capacity (50 kA) of circuit breakers in the not long distant future.

3.2.3 Requirements for The Future Transmission System

The power system must be kept in adequate condition to generate the energy, convey it to the load areas and deliver it to the customers.

Therefore, as long as loads continue to increase, the power system must also continue to grow providing sufficient capacity of power generation, transmission and distribution for the increasing load.

3.2.4 Approach to The Transmission Expansion Planning

The expansion plan of the transmission system in the Greater Bangkok Area has been made based on the load forecasts predicted by the Thai organization and JICA team and the power development plan of EGAT.

Planning of future power systems has been implemented by the procedure shown in Fig. 3-2. The approach to be taken to transmission expansion planning begins by stepping from the present power system to the horizon year conditions, say about 20 year ahead.

The horizon year expansion plan of the transmission system of the Greater Bangkok Area has been implemented taking the matters of importance into account, namely conditions of the area for installation of facilities, criteria for power system planning, and problems and requirements to cope with. The matters will be described in the following sections in detail.

The basic designs of transmission lines and substations have been developed for each year of 1997, 2001, 2006 and 2011.

Power flow analyses, short circuit current calculation and stability analyses have been carried out for the power systems covering the whole country in order to define the needs of transmission network expansions and reinforcements of the Greater Bangkok Area.

3.3 Criteria for The Transmission System Planning

Power system facilities are planned against a wide range of potential contingencies, in terms of both their steady state and transient state behavior. The planning criteria are comprised in assumptions of such contingencies and their consequences.

Below are the criteria adopted for the transmission system planning in this study:

- (1) The voltage variation in the transmission system should be within 98% -105% of the nominal voltage under normal condition and 92% - 108% under contingency (emergency) condition.
- (2) The transmission system should be planned on the basis of a single contingency (n-1) criterion which is widely used in many developed countries, i.e. each system element such as one circuit of a line or one transformer bank can fail separately without causing loss of load and excessive overloads on the remaining equipment.
- (3) The bulk power system should be maintained stable under the condition of a permanent three phase fault on any generator or transmission circuit, with normal fault clearing and without reclosing.

The fault clearing times to be used are as follows:

4 cycles	for 500 kV system
5 cycles	for 230 kV system

- (4) Fault levels should be below 50 kA at any bus bar both in the 500 kV and in the 230 kV transmission system.

3.4 Measures to Cope with Requirements

The power demand in the Greater Bangkok Area is anticipated to become more than doubled within the next ten years. Due to such a high growth of demand and resulting heavy load flows on the lines, the existing transmission system will not be able to meet the requirements in near future.

Reinforcements of the power system should be urgently implemented to increase the power supply capability, to maintain the system reliability, to improve voltage conditions, and to reduce system losses.

However, EGAT has encountered severe problems on the acquisition of land for substations and new rights-of-way for transmission lines needed to increase supply capability as well as some technical problems

concerning excessive fault level and heavy loaded situation on the parallel 230 kV lines.

The measures, to cope with such problems, are envisaged as below.

(1) To increase transmission capacity

Transmission system of higher voltage, say 500 kV, should be introduced into the urban area. It implies installation of 500 kV transmission lines and substations in this area.

(2) To secure spaces for facilities

To obtain rights-of-way and land for 500 kV facilities, the existing transmission lines and substations should be replaced.

A space on the existing right-of-way should be examined to use for a new substation.

It should be examined to install compact substations, or underground or building substations. It is recommendable to adopt GIS equipment to make a substation's space smaller.

Equipment adopted should have larger capacity than the existing one to use the space effectively.

Compact 230 kV lines of large capacity should be constructed adopting multi-conductors and multi-circuits in a narrow right-of-way as well.

Underground transmission should be considered if necessary.

(3) To solve excessive short circuit levels

Circuit breakers with a larger interrupting current, say 50 kA, will have to be installed. At the least, at substations where fault levels are predicted to exceed the interrupting current rating, the existing circuit breakers should be replaced by breakers with a higher rating.

Operation with the system split is very effective in reducing short-circuit current, so bus sections will be separated by normally open circuit breakers at a few substations.

The system will be divided into two or three load areas which are bounded by circuit breakers and each of which has sufficient load-carrying capability to supply its load.

Introduction of a higher voltage level (500 kV) should be examined in place of the present voltage level (230 kV).

Adoption of high impedance transformers or current limiting reactors is also conceivable.

3.5 Main Points for Planning Horizon Year Transmission Systems

3.5.1 Expansion of the 500 kV System

The followings are the matters that JICA team has especially paid attention to the planning of the future transmission system in the Greater Bangkok Area.

- (1) To make a great increase of power supply capability especially to the center of the city.
- (2) Only the existing rights-of-way will be available for strengthening the transmission system, because it is extremely difficult or impossible to obtain new rights-of-way, especially inside the existing 230 kV ring.
- (3) To control a fault level below 50 kA without losing merits of interconnection between substations as much as possible.

3.5.2 Main Points of the Planned Horizon Year Transmission System

The main points of the planned horizon year transmission system are as follows.

- (1) Introduction of 500 kV system into the Bangkok Noi substation

It is desirable to increase supply capability from the west side of the Greater Bangkok Area. For this purpose the voltage of 500 kV should be introduced into the Bangkok Noi substation.

To introduce 500 kV into the Bangkok Noi substation, the existing 230 kV SAI NOI - BANGKOK NOI line should be replaced by a 500 kV double-circuit line because it is extremely difficult or rather impossible to obtain a new route for the 500 kV line. The conductor of the line should be ACSR 1272 MCM x 4.

When the 500 kV line is completed, the 500 kV system in the Greater Bangkok Area will be formed linking the Nong Chok, Wang Noi, Sai Noi and Bangkok Noi substations.

- (2) Introduction of 500 kV system into the North Bangkok substation

500 kV should be introduced into the North Bangkok substation in order to increase power supply capability for the area which is to be supplied by the North Bangkok, Lat Phrao and Ratchada Phisek substations.

A 500 kV double-circuit line should be installed using the right-of-way of the existing 230 kV SAI NOI - RANGSIT - NORTH BANGKOK line for this purpose.

The 500 kV line will connect the two substations, SAI NOI and NORTH BANGKOK, directly, because the Rangsit substation is not large enough to install necessary 500 kV equipment to connect with the 500 kV system.

In the section between Rangsit and North Bangkok, the structures of the line should be equipped with four circuits, a 500 kV double-circuit and 230 kV double-circuit, except for a restricted area on the height of structures between the Rangsit substation and Chaeng Wattana substation in the vicinity of the Don Muang airport.

In this area, the structures are restricted below 45 meters in height and so should be equipped with a 500 kV double-circuit only. Therefore, for the 230 kV line, underground cables will have to be used.

The 230 kV double-circuit placed in juxtaposition with the 500 kV double-circuit should be connected with the Rangsit substation, Chaeng Wattana substation in the course of construction, a proposed substation " A ", and the North Bangkok substation.

Conductors ACSR 1272 MCM x 4 should be used for the 500 kV line and also for the 230 kV line in the section of overhead transmission. For the section of underground transmission, cross linked polyethylene cables with load carrying capability of about 600 MW per circuit will be used as the initial scale. In future, however, additional cables should be laid in accordance with the increase of power demand at the Chaeng Wattana substation.

It is desirable that the present 230 kV single-circuit line between BANGKOK NOI and NORTH BANGKOK is replaced by a 500 kV line regarding reliability of the system and flexibility of system operation.

The 230 kV double-circuit should be placed in juxtaposition with the 500 kV double-circuit between the North Bangkok substation and the substation " F " (TALINGCHAN) which will be installed in around 2010.

(3) Installation of a new 230 kV substation " A "

A new substation " A " will be installed at the spot where the 230 kV line to the Lat Phrao substation is branched by 1 pi (π) connection from the RANGSIT - NORTH BANGKOK line at present.

The 230 kV transmission lines should connect this substation with the Chaeng Wattana, North Bangkok and Lat Phrao substations. That will balance power flow of each circuit and increase loading capability of the lines especially to the Chaeng Wattana and Lat Phrao substations.

In addition, the installation of the A substation will make it easier to develop routes of transmission lines to send power to the substations which will be built in a populated area in future.

(4) Reinforcement of the NONG CHOK - ON NUCH line

In order to increase power supply capability of the Nong Chok substation, the present line between the Nong Chok and On Nuch substations should be reinforced with the four-circuit line, the conductor of which is ACSR 1272 MCM x 2.

- (5) Installation of a new substation " C ", and reinforcement of the BANG PAKONG - NONG CHOK and BANG PAKONG - ON NUCH Lines

In addition to reinforcement of the NONG CHOK - ON NUCH line, a new 500 kV substation " C " should be installed at the crossing where the BANG PAKONG - NONG CHOK line and the BANG PAKONG 2 - ON NUCH line meet, and the existing 230 kV lines should be reinforced in the sections between C and the On Nuch substation and between C and the Nong Chok substation.

This will increase capability and reliability of power supply to the eastern area of Bangkok, which is to be supplied from ON NUCH, BANG KAPI, CHIDLOM and new substations, H and B, which will be installed in future.

One of the 230 kV transmission line (double-circuit) which run from Bang Pakong power station to the Nong Chok substation should be replaced in the section of NONG CHOK - site of C by a 230 kV four-circuit line which will be connected to the existing lines coming from the Bang Pakong power station.

The other 230 kV transmission line constructed between Bang Pakong power station and Nong Chok substation should be replaced in the section of NONG CHOK - C by a 500 kV-designed transmission line and should be pulled into the C substation.

The present 230 kV BANG PAKONG - ON NUCH line should be pulled into the C station as well to form a pass of power flow from NONG CHOK to ON NUCH together with the above 500 kV-designed transmission line by way of the C station. 500 kV will be introduced into the C substation in around 2010.

The 230 kV double-circuit transmission line between the On Nuch and C substations should be replaced with four circuits using conductor ACSR 1272 MCM x 2.

The present right-of-way of this line is so adjacent to the proposed site of a new international airport that the line route will have to be moved to avoid the area controlled by the regulation concerning height restriction of structures built around an airport.

Otherwise it will be necessary to lay underground cables instead of an overhead line near the site of the airport. In this case, cross linked polyethylene cables with load carrying capability of about 600 MW per circuit will be laid as the initial scale and an additional cable will be laid in accordance with the increase of power flow of the line.

- (6) Power supply to the Rangsit area and its vicinity

In order to increase capability of power supply to the Rangsit area, one more substation, e.g. Rangsit 2, will be necessary. Installation of the new substation should be examined concerning 115 kV and 69 kV transmission system, i.e. capacity of the present lines, possibility of their reinforcement, acquisition of rights-of-way of new lines from the existing substation to the distribution substations.

230 kV four circuits using ACSR 1272 MCM x 2 should be installed between WANG NOI and RANGSIT. These circuits will assure power supply with high reliability together with the other 230 kV NONG CHOK - RANGSIT line.

(7) Installation of substations in the populated areas

In order to increase power supply capability for densely populated areas, new 230 kV substations G, H, J and F should be installed.

The final scale of the transformer banks which supply power to the secondary voltage 115 kV or 69 kV of these substations should be 300 MVA x 3 or 4 banks.

Power will be supplied to these substations from the key stations such as North Bangkok, A, BANG KAPI, SOUTH THONBURI and BANGKOK NOI by 230 kV underground cables.

The transmission system should adopt unit system in which the above substations are not equipped with circuit breakers and bus bars at the side of 230 kV transmission lines so as to be simply and compactly designed.

The capacity of 230 kV cable used should correspond to the capacity of transformer bank.

(8) Replacement of the 230 kV BAN PONG 2 - SAI NOI Line by a 500 kV Double-circuit Transmission Line

A 500 kV transmission system will have to be constructed to send power from the power plants located in the western seaboard and/or southern seaboard to Sai Noi substation. To secure a right-of-way for the transmission system, the existing 230 kV BAN PONG 2 - SAI NOI line should be replaced by a 500 kV transmission line.

That is also effective to control an increasing fault level at the 230 kV bus of the Sai Noi substation.

(9) Reinforcement of the 230 kV BANGKOK NOI - SAM PHRAN 1 - SOUTH THONBURI line

The above transmission line will be heavily loaded as demand for power increases in the areas situated to the southwest of the Greater Bangkok Area. Reinforcement of this line will be necessary about the middle of 2000s.

The single circuit between BANGKOK NOI and SAM PHRAN 1 and also the one between SAM PHRAN 1 and SOUTH THONBURI should be strengthened with two circuits of 230 kV lines using a conductor ACSR 1272MCM x 4.

In the section between SAM PHRAN 1 and the present right-of-way of the BANGKOK NOI - SOUTH THONBURI line, structures of the line will have to be equipped with four circuits because of only one right-of-way available.

It is recommended the line which links directly between BANGKOK NOI and SOUTH THONBURI is reinforced with a conductor ACSR 1272MCM x 4.

3.5.3 Description of the Study Cases of a Horizon Year Transmission System

For the study on a 2011 year (a horizon year) transmission system of the Greater Bangkok Area, the JICA team has supposed several cases with regard to power sources and connection of transmission lines.

Figs. 3-4 and 3-5 are typical power flow diagrams obtained as a result of the study on a horizon year power system.

In Case 1, power sources are developed mainly in the western seaboard and southern seaboard, while in Case 2, power sources are developed in the eastern seaboard and western seaboard almost equally. In either case there will be many rights-of-way necessary for the 500 kV lines to send power from the sources to the Greater Bangkok Area.

Table 3-2 shows the study results of fault levels at the 230 kV bus of each substation in the Greater Bangkok Area.

The transmission system shown as Fig. 3-6 will be fundamentally adaptable to the future requirements of power supply, reliability and fault levels, irrespective of configuration of power sources developed in future.

In case most of the power sources are developed in the western and/or southern areas, the 500 kV transmission system between SAI NOI and WANG NOI will need three circuits due to the heavy load flow.

Tables 3-3 and 3-4 show transmission lines and transformer banks and line equipment of the substations respectively which are proposed to be installed or reinforced to form the 2011 year transmission system of the Greater Bangkok Area.

Fig. 3-7 shows the transmission systems of the Greater Bangkok Area at present and in a horizon year.

Table 3-1 POWER DEVELOPMENT PLAN AND TRANSITION OF POWER SUPPLY CAPABILITY OF THAILAND

As per EGAT's power development plan, PDP 92-01(1)

Fiscal Year	Developed Power Plant	Fuel Type	Rated Capacity (MW)	Accumulated Installed Capacity					Peak Generation (MW)
				Whole Country (MW)	Region1 (MW)	Region2 (MW)	Region3 (MW)	Region4 (MW)	
1991	Existing			9,610.3	5,550.3	378.3	611.3	3,070.4	8,045
1992	Rayong cc Block 1(ST) Unit 1	Gas	102	9,712.3	5,652.3				
	Bang Pakong Unit 3	Oil/Gas	600	10,312.3	6,252.3				
	Bang Pakong cc Block 3 (ST) Unit 1	Gas	99	10,411.3	6,351.3				
	Rayong cc Block 2 (ST) Unit 1	Gas	102	10,513.3	6,453.3				
	Bang Pakong cc Block 4 (ST) Unit 1	Gas	99	10,612.3	6,552.3				
	Rayong cc Block 3 (ST) Unit 1	Gas	102	10,714.3	6,654.3				
	Nam Phong cc Block1(ST) Unit 1	Gas	113	10,827.3		491.3			
Rayong cc Block 4 (GT) Unit 1-2	Gas	206	11,033.3	6,860.3				9,000	
1993	Bang Pakong Unit 4	Oil/Gas	600	11,633.3	7,460.3				
	Nam Phong cc Block2 (GT) Unit 1-2	Gas	242	11,875.3		733.3			
	South Bangkok cc Block1(GT) Unit 1-2	Gas	220	12,095.3	7,680.3				
	Rayong cc Block 4 (ST) Unit 1	Gas	102	12,197.3	7,782.3				9,924
1994	R2 Gas Turbine Retired	Gas	-28	12,169.3		705.3			
	Khanom cc Block 1(GT) Unit 1-4	Gas	448	12,617.3			1,059.3		
	Nam Phong cc Block2 (ST) Unit 1	Gas	113	12,730.3		818.3			
	Pak Mun Unit 1-2	Hydro	68	12,798.3		886.3			
	South Bangkok cc Block1(ST) Unit 1	Gas	115	12,913.3	7,897.3				
	Khanom cc Block 1(ST) Unit 1	Gas	226	13,139.3			1,285.3		10,892
1995	Pak Mun Unit 3-4	Hydro	68	13,207.3		954.3			
	Sirikit Unit 4	Hydro	125	13,332.3				3,195.4	
	South Bangkok cc Block1(GT) Unit 1-2	Gas	400	13,732.3	8,297.3				
	Mae Moh Unit 12	Lignite	300	14,032.3				3,495.4	11,946
1996	R3 Gas Turbine Retired	Gas	-70	13,962.3			1,215.3		
	Krabt Retired	Lignite	-34	13,928.3			1,181.3		
	Mae Moh Unit 13	Lignite	300	14,228.3				3,795.4	
	Bhumibol Unit 8	Hydro	175	14,403.3				3,970.4	
	Wang Noi Gas Turbine	Oil/Gas	600	15,003.3	8,897.3				13,075
1997	Mae Kham FBC Unit 1	Lignite	150	15,153.3				4,120.4	
	Kaeng Krung Unit 1-2	Hydro	80	15,233.3			1,261.3		
	Lower Central cc Block1	Gas	600	15,833.3	9,497.3				
	South Bangkok cc Block2(ST) Unit 1	Gas	200	16,033.3	9,697.3				
	Mae Kham FBC Unit 2	Lignite	150	16,183.3				4,270.4	
Lower Central cc Block2	Gas	600	16,783.3	10,297.3				14,205	
1998	Lam Takhong Unit 1-2	Hydro	500	17,283.3		1,454.3			
	Lower Central cc Block3	Gas	600	17,883.3	10,897.3				15,354
1999	Ao Phai Unit 1	Oil/Coal	700	18,583.3	11,597.3				
	Surat Thani Unit1 Retired	Oil	-30	18,553.3			1,231.3		
	Mae Lama Luang Unit 1-2	Hydro	160	18,713.3				4,430.4	
	Ao Phai Unit 2	Oil/Coal	700	19,413.3	12,297.3				16,531
2000	Ao Phai Unit 3	Oil/Coal	700	20,113.3	12,997.3				
	New Thermal Unit 1	Oil/Coal	1000	21,113.3	13,997.3				17,765
2001	Region 3 cc Block1	Gas	300	21,413.3			1,531.3		
	Mae Taeng Unit 1-2	Hydro	26	21,439.3				4,456.4	
	New Thermal Unit 2	Oil/Coal	1000	22,439.3	14,997.3				19,000
2002	Lampang Unit 1	Lignite	300	22,739.3				4,756.4	
	Lam Takhong Unit 3-4	Hydro	500	23,239.3		1,954.3			
	Lampang Unit 2	Lignite	300	23,539.3				5,056.4	
	Lampang Unit 3	Lignite	300	23,839.3				5,356.4	20,219
2003	Bang Pakong cc Block 1 Retired	Gas	-380.3	23,459.0	14,617.0				
	Lan Krabu Gas Turbine Retired	Gas	-140	23,319.0				5,216.4	
	Lampang Unit 4	Lignite	300	23,619.0				5,516.4	
	Region 3 cc Block2	Gas	300	23,919.0			1,831.3		
	New Thermal Unit 3	Oil/Coal	1000	24,919.0	15,617.0				
	Lampang Unit 5	Lignite	300	25,219.0				5,816.4	
	Nam Khok Pumped-Storage Unit 1-2	Hydro	300	25,519.0				6,116.4	
Lampang Unit 6	Lignite	300	25,819.0				6,416.4	21,482	
2004	North Bangkok Unit 1-3 Retired	Oil	-237.5	25,581.5	15,379.5				
	Bang Pakong cc Block 2 Retired	Gas	-380.3	25,201.2	14,999.2				
	Mae Moh Unit 1-2 Retired	Lignite	-150	25,051.2				6,266.4	
	New Thermal Unit 4	Oil/Coal	1000	26,051.2	15,999.2				
2005	New Thermal Unit 5	Oil/Coal	1000	27,051.2	16,999.2				22,795
	New Thermal Unit 6	Oil/Coal	1000	28,051.2	17,999.2				
	Lampang Unit 7	Lignite	300	28,351.2				6,566.4	
2006	Lampang Unit 8	Lignite	300	28,651.2				6,866.4	24,150
	Nuclear Unit 1	Nuclear	1000	29,651.2			2,831.3		
	Nuclear Unit 2	Nuclear	1000	30,651.2			3,831.3		25,515
Total Installed Capacity As Of 2006					17,999.2	1,954.3	3,831.3	6,866.4	

Table 3-2 COMPARISON OF THREE-PHASE SHORT CIRCUIT CURRENTS OF THE 2011 YEAR SYSTEMS REGARDING POWER PLANT CONFIGURATION

230kV bus	Case 1	Case 2
	kA	kA
SAI NOI	24.9	25.4
WANG NOI	44.9	47.2
BANGKOK NOI	44.6	44.3
NONG CHOK (bus A)	44.7	48.8
NONG CHOK (bus B)	22.8	23.3
NORTH BANGKOK	30.1	30.6
C	40.5	42.9
A	26.9	27.2
RANGSIT	26.6	27.3
LAT PHRAO	25.2	25.6
RATCHADA PHISEK	29.3	30.7
BANG KAPI	36.6	38.9
ON NUCH	41.7	44.6
BANG PHLI	32.0	33.6
SOUTH TONBURI	37.9	37.8
SOUTH BANGKOK	35.2	35.1

Note The 230 kV system is split at CHAENG WATTANA, RATCHADA PHISEK, KHLONG MAI, BANG PHLI and NONG CHOK as shown on Fig.s 5-9 and 5-10.

Case 1 : Power sources are developed mainly in the western seaboard and southern seaboard areas.

Case 2 : Power sources are developed in the eastern seaboard and western seaboard areas almost equally.


Table 3-3 REINFORCEMENT OF TRANSMISSION LINES IN THE GREATER BANGKOK AREA

No.	Transmission lines		1982 year system		1981 year system		1980 year system		Remarks	
	From	To	Length (km)	Voltage (kV)	No. of Circuits	Conductor n x MCM	Length (km)	Voltage (kV)		No. of Circuits
29	WANG NOI	NONG CHOK	-	-	-	-	64	500	2	4 x 795
28	SAI NOI	WANG NOI	-	-	-	-	56	500	2	4 x 795
26	BANG PHU	BANG PAKONG	44.1	230	2	2 x 1272	-	-	-	-
26	D (BANG BOR)	BANG PAKONG	-	-	-	-	17.5	230	2	2 x 1272
26	D (BANG BOR)	BANG PAKONG	-	-	-	-	27.5	230	2	2 x 1272
22	ONMUCH	BANG PHU	10.5	230	2	1 x 1272	10.5	230	2	2 x 1272
15	ONMUCH	BANG KAPI	10	230	2	2 x 1272	10	230	4	2 x 1272
15	ONMUCH	BANG KAPI	10	230	2	2 x 1272	10	230	2	2 x 1272
18	B (PATANAKARN)	BANG KAPI	-	-	-	-	5	230	2	2 x 1272
	LAT PHRAO	BANG KAPI	10.4	230	2	2 x 1272	-	-	-	-
	RATCHADA PHISEK	BANG KAPI	-	-	-	-	4.5	230	2	2 x 1272
	RATCHADA PHISEK	BANG KAPI	-	-	-	-	6.5	230	2	2 x 1272
27	SOUTH BANGKOK	BANG PHU	15.9	230	2	2 x 1272	11.5	230	2	2 x 1272
27	E (TEPARAK)	BANG PHU	-	-	-	-	5.5	230	2	2 x 1272
23,24	NONG CHOK	BANG PAKONG 2	42.3	230	2	2 x 1272	43	230	2	2 x 1272
23,25	NONG CHOK	BANG PAKONG 2	-	-	-	-	5.5	230	2	2 x 1272
18	NONG CHOK	KHLONG MAI	34.3	230	2	2 x 1272	19	500	2	4 x 1272
19,20,21	ON-NUCH	KHLONG MAI	56	230	2	2 x 1272	15.5	230	2	2 x 1272
	ON-NUCH	BANG PAKONG 2	-	-	-	-	22	230	4	2 x 1272/cable
	KHLONG MAI	BANG PAKONG	8	230	2	2 x 1272	8	230	2	2 x 1272
	SAI NOI	RANGSIT	24.5	230	2	2 x 1272	-	-	-	-
	RANGSIT	NORTH BANGKOK	19.4	230	1	1 x 1272	-	-	-	-
	RANGSIT	LAT PHRAO	17.7	230	1	1 x 1272	-	-	-	-
3,13,5,6	NORTH BANGKOK	NORTH BANGKOK	7	230	1	1 x 1272	44	500	2	4 x 1272
13	SAI NOI	CHAENG WATTANA	-	-	-	-	10	230	2	4 x 1272/cable
	RANGSIT	CHAENG WATTANA	-	-	-	-	7.1	230	2	4 x 1272
5	CHAENG WATTANA	A	-	-	-	-	4.4	230	2	4 x 1272
6	A	NORTH BANGKOK	-	-	-	-	2.7	230	2	4 x 1272
7	A	LAT PHRAO	-	-	-	-	2.7	230	2	4 x 1272
14	NONG CHOK	ON-NUCH	16.8	230	2	2 x 1272	16.8	230	4	2 x 1272
26	BAN-PONG	SAI NOI	53.6	230	2	2 x 1272	53.6	500	2	4 x 1272
2	SAI NOI	BANGKOK NOI	29.6	230	2	2 x 1272	29.6	500	2	4 x 1272
1,4	NORTH BANGKOK	NORTH BANGKOK	18.4	230	1	1 x 1272	18.4	500	2	4 x 1272
	F (TALINGCHAN)	RANGSIT/RANGSIT 2	-	-	-	-	9.2	230	2	2 x 1272
12	WANG NOI	RANGSIT	-	-	-	-	50	230	4	2 x 1272
8,9	BANGKOK NOI	SAM PHRAN 1	12	230	1	2 x 1272	12	230	2	4 x 1272
9,10	SAM PHRAN 1	SOUTH THONBURI	19.8	230	1	2 x 1272	19.8	230	2	4 x 1272
11	BANGKOK NOI	SOUTH THONBURI	8.1	230	2	1 x 1272	8.1	230	1	4 x 1272
	A	G (SANAMPAO)	-	-	-	-	9	230	6	Cable
	SOUTH THONBURI	I (THANONTOK)	-	-	-	-	10	230	4	Cable
	BANGKOK NOI	J (THONBURI)	-	-	-	-	11	230	3	Cable
	BANG KAPI	H (KLONG TOEY)	-	-	-	-	8	230	6	Cable

Table 3-4 CONSTRUCTION PLAN OF SUBSTATIONS FOR POWER SYSTEM REINFORCEMENT IN THE GREATER BANGKOK AREA

Substation	1992 year system				2011 year system				Ind. peak load (MVA)
	Line equipment		Transformer		Line equipment		Transformer		
	Voltage (kV)	No. of Circuits	Voltage (kV)	Capacity (MVA)	Voltage (kV)	No. of Circuits	Voltage (kV)	Capacity (MVA)	
NONG CHOK	500	1	500/230	2x600	760	8	500/230	2x600 + 2x750	2270
	230	2	230/121	1 x 200	200	10	230/115	3x300	720
WANG NOI	-	-	-	-	-	12	500/230	4 x 750	2580
	-	-	-	-	-	4	230	-	-
SAI NOI	-	-	-	-	-	14 - 16	500/230	4 x 750	2580
	230	-	-	-	-	2	230/115	4 x 200	690
BANGKOK NOI	230	6	230/69	2x200 + 2x100	480	4	500/230	5x750	3370
	-	-	230/115	2 x 200	250	6	230/69	3x200 + 2x100	690
NORTH BANGKOK	230	3	230/72.5	1 x 200 + 1 x 100	135	4	230/115	3 x 200	480
	-	-	-	-	-	2	500/230	4 x 750	2580
C	-	-	-	-	-	5	230/72.5	3x200+1x300	720
	-	-	-	-	-	2	500/230	4 x 750	2580
BANG KAPI	230	8	230/69	3 x 200	480	18	230/69	6 x 200	1100
	230	6	230/69	2 x 200	250	6	230/69	3 x 200	480
BANG PHLI	230	6	230/115	2 x 200	250	2	230/115	2 x 250	320
	230	2	230/66	2 x 250	320	4	230/115	4 x 300	1040
CHIDLOM	230	4	230/69	3 x 200	480	16	230/115	4 x 300	1040
	-	-	-	-	-	12	230	-	-
CHAENG WATTANA	230	8	230/72.5	3x200	480	8	230/72.5	5 x 300	1350
	230	8	230/115	1 x 200 + 1 x 100	135	8	230/115	5 x 300	1350
LAT PHRAO	230	4	230/69	-	-	4	230/69	3 x 300	720
	-	-	-	-	-	2	230/66	2 x 200	480
ON - NUCH	230	4	230/69	3 x 200	480	4	230/69	4 x 300 *1	1040
	-	-	-	-	-	16	230/115	4 x 300	1040
A	-	-	-	-	-	12	230	-	-
	-	-	-	-	-	12	230	-	-
RANGSIT *3	230	8	230/72.5	3x200	480	8	230/72.5	5 x 300	1350
	230	8	230/115	1 x 200 + 1 x 100	135	8	230/115	5 x 300	1350
RATCHADA PHISEK	230	-	-	-	-	4	230/69	3 x 300	720
	230	-	-	-	-	4	230/115	3 x 200	480
SOUTH BANGKOK	230	5	230/72.5	4 x 200	690	5	230/72.5	5 x 200	900
	230	6	230/115	1 x 200	200	10	230/115	3 x 200	480
SOUTH TONBURI	230	6	-	-	-	10	230/72.5	4 x 200	690
	-	-	-	-	-	4	230/66	3 x 300	720
B (PATANAKARN)	-	-	-	-	-	4	230/115	2 x 300	380
	-	-	-	-	-	4	230/115	3 x 300	720
D (BANG BORI)	-	-	-	-	-	4	230/66	3 x 300	720
	-	-	-	-	-	6	230/66	3 x 300	720
H (KHLONG TOEY)	-	-	-	-	-	2	230/115	3 x 300	720
	-	-	-	-	-	4	230/66	3 x 300	720
F (TALINGCHAN)	-	-	-	-	-	2	230/115	3 x 300	720
	-	-	-	-	-	4	230/66	3 x 300	720
E (TEPARAK)	-	-	-	-	-	4	230/115	3 x 300	720
	-	-	-	-	-	4	230/66	3 x 300	720
I (THANONTOK)	-	-	-	-	-	4	230/66	4 x 300	1040
	-	-	-	-	-	3	230/66	3 x 300	720
J (THONBURI)	-	-	-	-	-	6	230/66	3 x 300	720
	-	-	-	-	-	6	230/115	3 x 300	720
G (SANAMIPAO)	-	-	-	-	-	6	230/115	3 x 300	720
	-	-	-	-	-	5	230/115	5 x 200	900
SAM PHRAN 1	230	2	-	-	-	6	230/115	5 x 200	900
	-	-	-	-	-	5	230/115	5 x 200	900

*1 The transformer banks should be replaced by larger ones.
 *2 Two circuits of eight are for the power source developed following the Ao Phai project.
 *3 It is required that the substation load which includes PEAS load is divided into two or three, and new substations are constructed in future.
 *4 Number of circuits depends on the development of the power sources in the west and south.
 *5 Two circuits of six are for a future-built substation, e.g. SAMUT SAKHON 3.



MAP OF EOAT ELECTRIC POWER SYSTEM

- | EXISTING | UNDER CONSTRUCTION | FUTURE PROJECT |
|--------------------------|--------------------|----------------|
| 300 KV TRANSMISSION LINE | --- | --- |
| 230 KV TRANSMISSION LINE | --- | --- |
| 115 KV TRANSMISSION LINE | --- | --- |
| 69 KV TRANSMISSION LINE | --- | --- |
| 300 KV SUBSTATION | ○ | ○ |
| 230 KV SUBSTATION | □ | □ |
| 115 KV SUBSTATION | △ | △ |
| 69 KV SUBSTATION | ▽ | ▽ |
| THERMAL POWER PLANT | ⊞ | ⊞ |
| HYDRO POWER PLANT | ⊞ | ⊞ |

Fig. 3-1 ELECTRIC POWER SYSTEM OF THAILAND

SYSTEM PLANNING DEPARTMENT
1 SEPTEMBER 1973





Fig. 3-2 ESTIMATED POWER TRANSMISSION AMONG REGIONS IN 2006

Fig. 3-3 APPROACH TO FUTURE POWER SYSTEMS



Factors for future power system planning

- 1 Power demand forecast
- 2 Power development plan
- 3 Capacity of equipment
- 4 Short circuit current
- 5 Power system stability
- 6 Reliability of power supply
- 7 Environmental restrictions

Fig. 3-4 Power Flow Diagram for Fiscal 2011

Case 1





Fig. 3-5 Power Flow Diagram for Fiscal 2011

Case 2






Fig. 3-6 TRANSMISSION SYSTEM OF THE GREATER BANGKOK AREA AFTER 2011





Fig. 3-7 TRANSMISSION SYSTEMS OF THE GREATER BANGKOK AREA AT PRESENT AND IN FUTURE


CHAPTER 4 POWER SYSTEM CONFIGURATION OF PLANNED YEARS

4.1 Present

Existing power system as of early 1993 is as shown below (Fig.4-1).

The outline of power system configurations of planned years are as follows:


Fig.4-1



4.2 Up to 1997

- a) New 500 kV double lines between SAI NOI and NONG CHOK via WANG NOI (1995).
- b) New 500 kV double lines to SAI NOI from lower central seaboard via BAN PONG 2.
- c) New 500 kV double lines to SAI NOI from western seaboard.
- d) 230 kV double lines replaced by 500/230 kV 4 lines between RANGSIT and CHAENG WATTHANA and operated at 230 kV (1997).
- e) Tap to TEPARAK of existing 230 kV double lines (SOUTH BANGKOK-BANG PHLI- 1996).
- f) New 230 kV double lines with four circuit tower between RANGSIT and WANG NOI (1995).
- g) New 230 kV triple lines (Underground Cable) from BANG KAPI to KHRONG TOEY (1996).
- h) New 230 kV triple lines (Underground Cable) from SOUTH THONBURI to SATU PRADIT by 1996.
- i) New 230 kV single line from SOUTH BANGKOK to SOUTH THONBURI by 1997.
- j) Tap to RAICHADAPISEK of existing 230 kV double lines (LATPRO-BANG KAPI, 1994)
- k) New substations; 230 kV WANG NOI, CHAENG WATHANA (1997), TEPARAK (1997).


Fig.4-2



4.3 Up to 2001

- a) New 500 kV double lines to NONG CHOK from AO PHAI.
- b) 230 kV double lines replaced by 500 kV double lines between SAI NOI and BANGKOK NOI and operated at 230 kV (2000).
- c) 230 kV single line replaced by 500 kV double lines between NORTH BANGKOK and BANGKOK NOI and operated at 230 kV (2000).
- d) 230 kV double lines replaced by 500/230 kV 4 lines between <A> and NORTH BANGKOK and between <A> and CHAENG WATTHANA (2002).
- e) 230 kV double lines replaced by 4 conductor double lines between <A> and LAT PHRAO (2002).
- f) 230 kV double lines replaced by 230 kV 4 lines between NONG CHOK and ON NUCH (1998).
- g) Lay additional 230 kV double lines (Underground Cable) from BANG KAPI to KHRONG TOEY (2000).
- h) New 230 kV five lines (Underground Cable) from <A> to SANANPAO (2000).
- i) New substation; <A> (2001).


Fig.4-3



4.4 Up to 2006

- a) Operate SAI NOI-BANGKOK NOI lines at 500 kV (2002).
- b) 230 kV double lines replaced by 500 kV double lines between SAI NOI and RANGSIT site (2004).
- c) Operate SAI NOI-NORTH BANGKOK lines via RANGSIT site and NORTH BANGKOK-BANGKOK NOI lines at 500 kV (2005).
- d) String additional 230 kV double lines between RANGSIT and WANG NOI (2003).
- e) 230 kV triple lines replaced by 230 kV 4 conductor triple lines between BANGKOK NOI and tap point to SAM PHRAN 1, two of which tap to SAM PHRAN 1 (2003).
- f) 230 kV triple line replaced by 230 kV 4 conductor triple lines between SOUTH THONBURI and tap point to SAM PHRAN 1, two of which tap to SAM PHRAN 1 and the other to BANGKOK NOI line (2004).
- g) Existing 230 kV lines replaced by 230 kV 4 lines between ON NUCH and BANG KAPI (2005).
- h) New 230 kV double lines from BANGKOK NOI to THONBURI (2005).
- i) New 230 kV double lines between ON NUCH and BANG PHLI (2005).

Fig.4-4




4.5 Up to 2011

- a) New 500 kV double lines to NONG CHOK from AO PHAI.
- b) Tap to <C> of existing 230 kV lines (NONG CHOK - BANG PAKONG, ON NUCH - BANG PAKONG, 2009).
- c) 230 kV double overhead lines replaced by 230 kV 4 lines (underground cable crossing airport area and overhead line in the other area) between <C> and ON NUCH (2007).
- d) Existing 230 kV lines replaced by 230 kV 4 lines between <C> and NONG CHOK (2009).
- e) New 500 kV double lines between <C> and NONG CHOK (2010).
- f) Tap to TALINGCHAN just below the line (500/230 kV line from NORTH BANGKOK, 2009)
- g) Lay additional 230 kV single line (Underground Cable) from BANGKOK NOI to THONBURI (2011)
- h) Lay additional 230 kV single line (Underground Cable) from BANG KAPI to KHRONG TOEY (2010).
- i) Lay additional 230 kV single line (Underground Cable) from SOUTH THONBURI to SATU PRADIT (2010)
- j) Lay additional 230 kV single line (Underground Cable) from <a> to SANAMPAO
- k) 230 kV double lines replaced by 230 kV 4 lines between BANG KAPI and tap point to PATANAKAN, 2 of which tap to PATANAKAN (2010).
- l) Tap to KHLONG MAI of existing 230 kV double lines (<C> - BANG PAKONG, 2009)
- m) New substation; <C> (2008).

Fig.4-5

POWER SYSTEM IN 2011



CHAPTER 5 COST ESTIMATION AND CONSTRUCTION SCHEDULING

5.1 Cost Estimation

The construction cost is tabulated in the following page, expressed in the price level in 1993.

Much importance was placed on the use the existing right of way in planning transmission line routes on account of difficulties in acquiring new right of way in the Greater Bangkok Area and together with the expectation to minimize the construction cost.

Eventhough overhead line is preferable to underground cable from economical point of view, some sections which are not wide enough to reconstruct new lines required or deemed to obstruct aviation or others, are planned by underground cables as listed below.

- RANGSIT to CHAENG WATTHANA (EGAT)
- SOUTH THONBURI to THANONTOK (MEA)
- BANG KAPI to KHLONG TOEY (MEA)
- <A> S.S. to SANAMPAO (MEA)
- BANGKOK NOI to THONBURI (MEA)
- ON NUCH to <C> S.S. (EGAT)

The construction cost of transmission line much differs depending on the cost for tower footing for overhead line or that for tunnel excavation for underground cable owing to the nature of soil (poor or fair) of the route.

As it is considered that the poor soil covers most of the Greater Bangkok Area, the estimation in case of poor soil will give a rather realistic value for the construction cost of transmission line.

As for substation, pad or pile type foundation will be adopted depending on the nature of soil for bus support, steel structure or equipment such as transformer, circuit breaker, disconnecting switch and others, but it has less affect on the total construction cost of substations, of which the foundation cost occupies small part.

5.2 Construction Scheduling

In accordance with optimal power system plan of each planned year (1997, 2001, 2006 and 2011) described in Chapter 3, the construction schedule is planned as indicated in the attached bar charts.

In planning, in addition to the result of power system analysis (i.e., the time when the short circuit current or power flow exceeds the existing equipment ratings), the following items are taken into consideration to determine the critical path for construction scheduling.

- (1) To make a small roop of 500 kV system via SAI NOI, RANGSIT, NORTH BANGKOK and BANGKOK NOI by 2006 without reduce or cutting power supply to the central consumers area during

construction, the loop is to be reconstructed and completed in four time-related divisions, the first of which is the portion between Rangsit and Chaeng Watthana.

This first portion (between Rangsit and Chaeng Watthana) is estimated to be overloaded with the existing lines and to be reinforced (replaced by 500/230 kV 4 lines and operated at 230 kV tentatively) by 1997, and in addition, power transmission to central consumers area will be secured by this route during the construction period of the other part of the loop, in the case this portion is reconstructed prior to start reconstruction of the other part of the loop.

Followed by this, replacement of line between North Bangkok and Bangkok Noi (by 500 kV double lines), which portion has less capability of power transmission than the other part in the loop as it is a single line, and replacement of lines between Sai Noi and Bangkok Noi (by 500 kV double lines) are to be performed and completed by 2000.

Replacement of lines between North Bangkok and Chaeng Watthana by 500/230 kV 4 lines together with construction of 230 kV new substation <A> at junction point of lines among Rangsit, North Bangkok and Lat Phrao will be completed by 2002, and Sai Noi-Bangkok Noi line start operation at 500 kV by 2002.

The remaining part of the loop between Sai Noi and Rangsit site is to be completed by 2004 replacing the existing line by 500 kV double lines, and the small 500 kV loop start 500 kV operation by 2005.

- (2) To increase the transmission capability to central consumers area through On Nuch, <C> substation is to be constructed by 2008 and number of lines will be tapped to <C> substation.

The construction of <C> substation will be followed by :

- Tap to <C> of existing 230 kV lines (Nong Chok-Bang Pakong, On Nuch-Bang Pakong -2008)
- 230 kV double overhead lines replaced by 230 kV 4 lines (underground cable crossing airport area and overhead line in the other area) between <C> and On Nuch (2008)
- New 230 kV 4 lines between <C> and Nong Chok (2009)
- New 500 kV double lines between <C> and Nong Chok (2011)

- (3) The other lines are to be reinforced depending on the capability of power transmission corresponding the growth of power demand in each consumers area.

Table 5-1 CONSTRUCTION AND EXPANSION SCHEDULE OF THE TRANSMISSION LINES IN THE GREATER BANGKOK AREA

No	Transmission Lines			Scale in 1992			1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	Scale in 2011			
	From	To	Length (km)	Construction length (km)	Voltage (kV)	No. of Circuits	Conductor n x MCM																				Voltage (kV)	No. of Circuits	Conductor n x MCM
29	WANG NOI	NONG CHOK	64	64				***	*****																	500	2	4 x 795	
28	SAI NOI	WANG NOI	56	56				***	*****																	500	2	4 x 795	
26	BANG PHLI	BANG PAKONG	44.1		230	2	2 x 1272																			230	2	2 x 1272	
26	BANG PHLI D (BANG BOR)	BANG PAKONG	17.5	1.0										***												230	2	2 x 1272	
22	ON NUCH	BANG PHLI	10.5	10.5	230	2	1 x 1272												*****							230	2	2 x 1272	
15	ON NUCH	BANG KAPI	10	10	230	2	2 x 1272												*****							230	4	2 x 1272	
16	ON NUCH B (PATANAKARN)	BANG KAPI	10 5	10 5.0	230	2	2 x 1272																	*****		230	2	2 x 1272	
	LAT PHTAO	BANG KAPI	10.4		230	2	2 x 1272																			230	2	2 x 1272	
	LAT PHTAO	RATCHADA PHISEK	4.5	0.5				****																		230	2	2 x 1272	
	RATCHADA PHISEK	BANG KAPI	6.5	0.5				****																		230	2	2 x 1272	
27	SOUTH BANGKOK	BANG PHLI	15.9		230	2	2 x 1272																			230	2	2 x 1272	
27	SOUTH BANGKOK E (TEPARAK)	BANG PHLI	11.5	2.0						*****																230	2	2 x 1272	
27	E (TEPARAK)	BANG PHLI	5.5	2.0						*****																230	2	2 x 1272	
23	NONG CHOK	BANG PAKONG 2 Site C	42.3 19	19	230	2	2 x 1272																	*****		230	4	2 x 1272	
24	NONG CHOK Site C	BANG PAKONG 2	24	2.0																					***	230	2	2 x 1272	
19,21	ON NUCH	BANG PAKONG 2 C	56 22	22	230	2	2 x 1272																			230	4	2 x 1272	
20	ON NUCH	BANG PAKONG 2 C	Overhead 12 Cable 10	Overhead 12 Cable 10																	***	*****				230	4	2 x 1272 cable	
25	Site C	BANG PAKONG 2	36	2.0	230	2	2 x 1272																	***		230	2	2 x 1272	
18	NONG CHOK NONG CHOK C	KHLONG MAI C KHLONG MAI	34.3 19 15.5	19 2.0	230	2	2 x 1272																			500	2	4 x 1272	
	KHLONG MAI	BANG PAKONG	8		230	2	2 x 1272																			230	2	2 x 1272	
2	SAI NOI	BANGKOK NOI	29.6	29.6	230	2	2 x 1272								*****											500	2	4 x 1272	
1	BANGKOK NOI	NORTH BANGKOK	18.4		230	1	1 x 1272																						
4	BANGKOK NOI Site F (TALINGCHAN)	Site F (TALINGCHAN)	9.2	9.2										***												500	2	4 x 1272	
4	Site F (TALINGCHAN)	NORTH BANGKOK	9.2	9.2										***												500	2	4 x 1272	
4	F (TALINGCHAN)	NORTH BANGKOK	9.2	9.2																				***		230	2	2 x 1272	
3	SAI NOI	RANGSIT	24.5	24.5	230	2	2 x 1272												*****							500	2	4 x 1272	
	SAI NOI	Site RANGSIT	24.5	24.5																									
3	RANGSIT	NORTH BANGKOK	19.4		230	1 / 2	1 x 1272																						
13	RANGSIT	LAT PHTAO	17.7		230	1 / 2	1 x 1272																						
	RANGSIT	CHAENG WATTANA	10	1.0	230	2	1 x 1272			***																			
	Site RANGSIT	Site CHAENG WATTANA	10	10																							500	2	4 x 1272
	RANGSIT	CHAENG WATTANA	10	10																							230	2	4 x 1272
		CHAENG WATTANA	Overhead 5 Cable 5	Overhead 5 Cable 5																							230	2	4 x 1272 cable
	CHAENG WATTANA	NORTH BANGKOK	11.4	1.0	230	1 / 2	1 x 1272			***																			
	CHAENG WATTANA	LAT PHTAO	9.7	1.0	230	1 / 2	1 x 1272			***																			
	NORTH BANGKOK	LAT PHTAO	7		230	1 / 2	1 x 1272																						
5	Site CHAENG WATTANA	Site A	7.1	7.1											*****											500	2	4 x 1272	
5	CHAENG WATTANA	A	7.1	7.1											*****											230	2	2 x 1272	
6	Site A	NORTH BANGKOK	4.4	4.4											*****											500	2	4 x 1272	
6	A	NORTH BANGKOK	4.4	4.4											*****											230	2	4 x 1272	
7	A	LAT PHTAO	2.7	2.7											*****											230	2	4 x 1272	
14	NONG CHOK	ON - NUCH	16.8	16.8	230	2	2 x 1272								*****											230	4	2 x 1272	
12	WANG NOI	RANGSIT	50	50	230	2	1 x 1272								*****											500	2	4 x 1272	
12	WANG NOI	RANGSIT (or RANGSIT 2)	50	50																						230	2	2 x 1272	
	RANGSIT	RANGSIT 2	4.0	4.0																						230	2	2 x 1272	
8	BANGKOK NOI	SAM PHRAN 1	12		230	1	2 x 1272																						
9	BANGKOK NOI Junction near BANGKOK NOI	Junction near BANGKOK NOI	0.3	0.3	230	1	2 x 1272																				230	2	4 x 1272
10	Junction near BANGKOK NOI	SAM PHRAN 1	11.7	11.7	230	2	2 x 1272																				230	4	4 x 1272
11	Junction near BANGKOK NOI	SOUTH THONBURI	8.1	8.1	230	1	2 x 1272																				230	2	4 x 1272
30	BANGKOK NOI	SOUTH THONBURI	8.1	8.1	230	2	2 x 1272																				230	1	4 x 1272
32	A	G (SANAPPAO)	9	9																						230	6	Cable	
33	SOUTH THONBURI	I (THANONTOK)	10	10																						230	4	Cable	
31	BANGKOK NOI	J (THONBURI)	11	11																						230	3	Cable	
	BANG KAPI	H (KLONG TOEY)	8	8																						230	6	Cable	

Note : (1) **** shows a period of construction work.

(2) [shaded box] shows recomended reinforcement, though outside the Greater Bangkok Area.

CHAPTER 6 ENVIRONMENTAL IMPACT STUDY

6.1 General

The ultimate plan for horizon year transmission system covers introduction of 500 kV system into Bangkok Noi and North Bangkok substations, with replacement of existing 230 kV loop lines, Sai Noi - Bangkok Noi - North Bangkok - Rangsit - Sai Noi with 500 kV transmission lines. Since it is extremely difficult or rather impossible to obtain a new line-route, therefore existing 230 kV right of way of 40 m. will be rather restricted for the 500 kV line construction.

The objective of the study includes environmental problem, protective measure and compensation cost to build 500 kV transmission line on the existing 230 kV line right of way around the Bangkok Metropolitan Area.

6.2 Recent EGAT Experience with Re-built 230 kV Multiple Circuit on Single Right of Way

6.2.1 Transmission Lines

The principal problem and its solution are briefly summarized as follows:

(1) Design Stage

- a) Due consideration has to be made prior to the bids as the condition that either the construction can be carried out with the existing line shut-off during off-peak period (e.g. during 8-16 hours daily) only, or that line section can be taken out of service for 2-3 months for the purpose of erection of tower and/or stringing of conductor.
- b) Locate the new tower on the spot closed to former site so that middle span reinforced tower can be set up in the middle of the span.
- c) Problem of conflict with new infrastructure, e.g. the crossing of new expressway, or the new elevated railroad etc. can be easily solved during the design stage.

(2) Construction Stage

- a) During construction period, two options are available, i.e. the temporary detour line or the planned permanent additional line - to be built on the edge of the Right of Way, for instance.
- b) Transportation of major equipment or supplies - e.g. long concrete piles - can pose as one of major problem to deal with very narrow Right of Way.

6.2.2 Substation

- (1) In general, the existing substation occupy rather small area. It is therefore necessary to modify the substation layout, either by replacing the equipment with higher capacity rating, or
- (2) Re-build the substation with Gas Insulated Switchgear (GIS) equipment, which occupy small space than the conventional type.

Attention is drawn here concerning the construction of the new 500 kV lines and substations as part of the Bulk Power Supply in the Greater Bangkok Area will pose similar and/or rather more difficult problems to the above-mentioned project.

6.3 Environmental Problem : Superimpose 500 kV Line on Existing 230 kV Line Right of Way

Mae-Moh-Tha Tako-Nong chok 500 kV line was built in most of the rural area, i.e. running through the forest, rice field etc. In another word, it occupies the area of rural environment. The proposed lines of the Bulk Power Supply Project, Sai Noi-Bangkok Noi-North Bangkok-Rangsit-Sai Noi loop line would be built on the existing 230 kV Right of Way, which lie within the sub-urban as well as the urban one. This loop line will go through very-densely populated community, commercial center and all kinds of social infrastructure. In another words, it will occupy the area in sub-urban and urban environment.

6.4 Static Induction under Extra-High Voltage Overhead Transmission Line

The study of the static induction under transmission lines has been started as a part of the research program for clarification of technical problems introduction by the 500 kV transmission lines.

When a man carrying an umbrella passes beneath a 500 kV transmission line, a part of his body, such as his cheek may touch the metallic part of the umbrella stem to sense the static induction, or a man touching metallic part of a car, building, fence, etc. may sense the static induction. Concerning these circumstances, the following subjects were studied.

- * Effect on human body and the strength of the sensing.
- * The relation between the strength of electric field under the transmission line and the strength of the sensing.
- * Measurement method and prediction method of electric field strength.
- * Target of reduction and measures for reduction.

CHAPTER 7 ECONOMIC AND FINANCIAL ANALYSES

7.1 Economic Analysis

7.1.1 Outline

In the economic evaluation of this bulk power supply project, the economic internal rate of return (EIRR) by which the total benefit [B] and the total cost [C] become equal has been calculated, and at the same time the surplus benefit (B-C) and the benefit to cost ratio (B/C) have also been calculated as the bases of overall judgment.

The following benefits and costs are considered:

- Benefit:
- 1) The incremental electric energy which is made available to the customers by this Project.
 - 2) The reduction in the electric energy lost by power supply failures which is expected to be brought about by this Project.
 - 3) The reduction of operating/maintenance costs which is expected to be brought about by this Project.
- Cost :
- 1) Total project investment
 - 2) Operation and maintenance costs of completed facilities.

7.1.2 Basic Assumptions/Conditions

The calculations in the economic evaluation were performed based on the following assumptions and conditions.

(1) The Electricity Tariff Rate

The average selling price of EGAT based on the current tariff structure was used in the study. This average selling price is the tariff rate at transmission level and based on the investment and expense of EGAT on generation and transmission system. The transmission costs have been considered to include only EGAT investment and expenses. (Transmission or sub-transmission costs by MEA and PEA are assumed to be part of distribution.)

(2) Total Project Investment

It has been agreed in principle that any transmission or sub-transmission line that should be constructed along the public right-of-way will be implemented by MEA or PEA. Therefore, some part of the works recommended in the project will be implemented by MEA. Corresponding to the current tariff structure which based on the investment of each power utility, the investment costs on the MEA's portions were taken out and not included in the study.

The total project investment (only EGAT's investment) was calculated as the construction cost of the Project excluding the interests during construction, import duties, VAT (Value Added Tax) and escalation. The total construction cost has been added up on the 1992 price base.

(3) Foreign Currency Exchange Rate

It was assumed that 1 US\$ = 25 Bahts

(4) Operation and Maintenance Cost

In line with the economic analysis standard of EGAT, the annual operation and maintenance cost was assumed to be 1.0% of the construction cost (without import duty and VAT) for transmission and distribution lines and 2.0% of the same for substation equipment respectively.

(5) Period of Calculation

The amortization period of the related facilities is set forth by the economic analysis standard of EGAT as follows:

Transmission and Distribution lines:	40 years
Substation equipment	: 25 years

The amortization period for this Project was calculated by averaging the above figures using weighing factors for transmission and substation facilities which are proportional to the relative weight of each sector in the total investment. The calculated amortization period was 32 years.

Considering that the facilities to be constructed under this Project will be completed one by one from 1994 to 2011, the period of calculation for the economic evaluation was set from the middle point of the construction period (from 1994 to 2011), that is, 2002, until 32 years later, that is 2034.

(6) Discount Rate

The discount rate was selected at 10% per annum based on the discussion with EGAT.

(7) Generation Cost

In line with the economic analysis standard of EGAT and taking transmission loss into account, the energy cost was assumed to be 0.6998 Baht/kWh and the capacity cost was assumed to be 4,409.16 Baht/kW (per annum).

7.1.3 Result of Economic Evaluation

The flow of benefit and cost of this Project is shown in Table 7-3 and calculation of EIRR is shown in Table 7-4.

The Economic Internal Rate of Return (EIRR), the excess Benefit (B-C) and the Benefit to Cost ratio (B/C) as obtained by these benefit and cost are as below.

EIRR: 17.54% (Table 7-4)

B-C : 668,715 Thousand US\$ (Table 7-3, discount rate 10% p.a.)

B/C : 2.18 (Table 7-3, discount rate 10% p.a.)

In judging the economic soundness of this Project, the JICA Study Team rates that all of EIRR, B-C and B/C values are good, and this Project is economically feasible.

7.2 Financial Analysis

7.2.1 Outline

The following values shall be calculated based on the value of incremental electric energy (sales revenue) and the total cost of this Project in terms of domestic price in the Kingdom of Thailand.

- <1> Financial internal rate of return (FIRR)
- <2> Development of disbursement schedule table
- <3> Production of profit and loss statement
- <4> Cash flow
- <5> Calculation of Debt Service Ratio

7.2.2 Analytical Methodology

(1) Calculation of Financial Internal Rate of Return (FIRR)

The financial internal rate of return, by which the yearly sums of costs and revenues are equal (the financial internal rate of return), has been calculated, and this value has been compared with the opportunity cost of capital. The cost applicable to this evaluation will include the total investment (construction cost with import duty) without consideration of the financing conditions, such as interest, interest during construction, repayment of principal, repayment period, etc., and the operation and maintenance cost.

In this evaluation, the profitability of the investment for the project will be judged regardless of financial conditions.

(2) Calculation of Debt Service Ratio

Debt Service Ratio is the ratio of the corporate internal financing, which is business profit plus depreciation, to the reimbursement plus interest of borrowed money.

To calculate this value, the following three works were required.

- 1) Development of reimbursement plan
- 2) Development of profit and loss statement
- 3) Cash flow analysis

The costs that are applicable to this evaluation consist of the operation and maintenance cost and depreciation cost. The depreciation cost will be calculated based on the total construction cost including import duties, interest during construction and escalation.

7.2.3 Basic Conditions

This financial analysis has been conducted by the following basic conditions.

(1) Financial Internal Rate of Return (FIRR)

1) Electricity Sales Revenue

The benefit value of this Project calculated in the Economic Evaluation (7.1) is used.

2) Construction Cost

Same as in Economic Evaluation, only EGAT's portion of the construction cost was considered and the construction cost including import duties, which was excluded in the Economic Evaluation, is used.

However, VAT, interest and interest during construction are excluded.

VAT is excluded since VAT will be refunded to EGAT as a governmental body.

3) Operation & Maintenance Cost

The cost calculated in 7.1 (Economic Evaluation) is used.

4) Escalation

Not considered.

(2) Debt Service Ratio

1) Electricity Sales Revenue

Same as in the calculation of FIRR, but escalation is considered.

2) Construction Cost

The construction cost including import duties, interest during construction and escalation.

3) Operation & Maintenance Cost

Same as FIRR, but escalation is considered.

4) Escalation

Escalation of 5% per annum is considered.

5) Capital Procurement Condition

(a) Foreign Currency

An interest rate of 8% per annum. The principal and interest to be uniformly reimbursed for 20 years.

Amount borrowed from year 1994 to 1997 will be reimbursed from year 1998.

In the same manner, amount borrowed, from 1998 to 2001, amount borrowed from 2002 to 2006 and amount borrowed from 2007 to 2011 will be reimbursed from 2002, 2007 and 2012 respectively.

(b) Local Currency

An interest rate of 10% per annum on 50% of the construction cost to be provided by local currency.

The principal and interest to be uniformly reimbursed for 10 years in the same manner as Foreign Currency amount.

6) Depreciation

As mentioned in Economic Evaluation, the economic life of facilities is assumed to be 32 years. The depreciation has been calculated on the straight line method with no residual value.

7.2.4 Financial Internal Rate of Return (FIRR)

(1) Construction Cost

The construction cost for calculation of FIRR is shown in Table 7-5.

(2) FIRR

The flows of expenditures and revenues of this Project based on the construction cost above-mentioned and other assumptions is as presented in Table 7-6, and the FIRR is estimated 17.10%.

Based on this estimation, it can be concluded that this project is financially sound.

7.2.5 Debt Service Ratio

(1) Reimbursement Plan

The reimbursement plan based on the conditions of capital procurement shown in Paragraph 7.2.3 (2) is presented in Table 7-9 to 7-13.

It has been assumed that the interest during construction and escalation are included in the construction cost (Shown in Table 7-7 and 7-8) which is the basis of calculation of the borrowed money, and these accounts are recovered as a part of depreciation.

(2) Profit and Loss Statement and Cash Flow

The profit and loss statement and the cash flow are presented in Table 7-14 and 7-15 respectively.

(3) Debt Service Ratio

The calculated debt service ratio is presented in Table 7-16.

The debt service ratio up to year 2020 is 6.85, which shows this Project is sound also in the aspect of profitability.

Table 7-1 Construction Cost for Economic Analysis

(1,000 US\$)

Year	Total Construction Cost for Transmission Line	Value Added Tax	Import Duty	Construction Cost (Transmission Line) for Analysis	Total Construction Cost for Substation Equipment	Value Added Tax	Import Duty	Construction Cost (Substation) for Analysis	Total Construction Cost for Analysis
	A	B	C	D=A-(B+C)	E	F	G	H=E-(F+G)	D+H
1994	300	16	10	274					274
1995	161,280	6,692	3,950	150,638					150,638
1996									0
1997	81,410	650	298	80,462	206,995	11,358	14,337	181,300	261,762
1998	14,850	764	322	13,764					13,764
1999									0
2000	45,370	2,347	1,318	41,705					41,705
2001					193,909	10,660	12,506	170,743	170,743
2002	23,000	1,215	490	21,295					21,295
2003	15,080	791	445	13,844					13,844
2004	25,930	1,307	927	23,696					23,696
2005	12,510	4,718	298	7,494					7,494
2006					171,788	9,435	9,748	152,605	152,605
2007	175,180	555	250	174,375					174,375
2008									0
2009	18,190	8,701	405	9,084					9,084
2010	13,750	700	474	12,576					12,576
2011					112,518	6,184	7,314	99,020	99,020
2012				0				0	0
2034									
Total	586,850	28,456	9,187	549,207	685,210	37,637	43,905	603,668	1,152,875

Table 7-2 Operation and Maintenance Cost

(1.000 US\$)

Year	Construction Cost (Transmission Line) without VAT and Import Duty	Operation and Maintenance Cost for Transmission Line	Construction Cost (Substation) without VAT and Import Duty	Operation and Maintenance Cost for Substation Equipment	Total Operation and Maintenance Cost
1994	274		0		
1995	150,638		0		
1996	0		0		
1997	80,462		181,300		
1998	13,764	2,314	0	3,626	5,940
1999	0	2,314	0	3,626	5,940
2000	41,705	2,314	0	3,626	5,940
2001	0	2,314	170,743	3,626	5,940
2002	21,295	2,868	0	7,041	9,909
2003	13,844	2,868	0	7,041	9,909
2004	23,696	2,868	0	7,041	9,909
2005	7,494	2,868	0	7,041	9,909
2006	0	2,868	152,605	7,041	9,909
2007	174,375	3,532	0	10,093	13,625
2008	0	3,532	0	10,093	13,625
2009	9,084	3,532	0	10,093	13,625
2010	12,576	3,532	0	10,093	13,625
2011	0	3,532	99,020	10,093	13,625
2012		5,492		12,073	17,565
2034					
Total	549,207	167,573	603,668	377,860	545,434

Table 7-3 Benefit Flow and Cost Flow of the Project

(1,000 US\$)

Discount Rate	Year	Cost			Benefit		NPV		
		Costruction	O&M	Total	PV	Total		PV	
10.00 % pa	1	1994	274		274	226		-226	
	2	1995	150,638		150,638	113,177		-113,177	
	3	1996	0		0	0		0	
	4	1997	261,762		261,762	162,534		-162,534	
	5	1998	13,764	5,940	19,704	11,122	982	554	-10,568
	6	1999	0	5,940	5,940	3,048	12,564	6,447	3,399
	7	2000	41,705	5,940	47,645	22,227	17,553	8,189	-14,038
	8	2001	170,743	5,940	176,683	74,931	50,317	21,339	-53,592
	9	2002	21,295	9,909	31,204	12,030	72,051	27,779	15,748
	10	2003	13,844	9,909	23,753	8,325	98,470	34,513	26,188
	11	2004	23,696	9,909	33,605	10,708	129,166	41,156	30,449
	12	2005	7,494	9,909	17,403	5,041	164,153	47,549	42,508
	13	2006	152,605	9,909	162,514	42,795	204,188	53,769	10,974
	14	2007	174,375	13,625	188,000	45,006	248,047	59,380	14,375
	15	2008	0	13,625	13,625	2,965	294,906	64,180	61,215
	16	2009	9,084	13,625	22,709	4,493	344,805	68,218	63,725
	17	2010	12,576	13,625	26,201	4,712	397,573	71,507	66,795
	18	2011	99,020	13,625	112,645	18,418	452,606	74,005	55,586
	19	2012		17,565	17,565	2,611	452,606	67,277	64,666
	20	2013		17,565	17,565	2,374	452,606	61,161	58,787
	21	2014		17,565	17,565	2,158	452,606	55,601	53,443
	22	2015		17,565	17,565	1,962	452,606	50,546	48,585
	23	2016		17,565	17,565	1,783	452,606	45,951	44,168
	24	2017		17,565	17,565	1,621	452,606	41,774	40,153
	25	2018		17,565	17,565	1,474	452,606	37,976	36,502
	26	2019		17,565	17,565	1,340	452,606	34,524	33,184
	27	2020		17,565	17,565	1,218	452,606	31,385	30,167
	28	2021		17,565	17,565	1,107	452,606	28,532	27,425
	29	2022		17,565	17,565	1,007	452,606	25,938	24,932
	30	2023		17,565	17,565	915	452,606	23,580	22,665
	31	2024		17,565	17,565	832	452,606	21,437	20,605
	32	2025		17,565	17,565	756	452,606	19,488	18,731
	33	2026		17,565	17,565	688	452,606	17,716	17,029
	34	2027		17,565	17,565	625	452,606	16,106	15,481
	35	2028		17,565	17,565	568	452,606	14,641	14,073
	36	2029		17,565	17,565	517	452,606	13,310	12,794
	37	2030		17,565	17,565	470	452,606	12,100	11,631
	38	2031		17,565	17,565	427	452,606	11,000	10,573
	39	2032		17,565	17,565	388	452,606	10,000	9,612
	40	2033		17,565	17,565	353	452,606	9,091	8,738
	41	2034		17,565	17,565	321	452,606	8,265	7,944
	Total		1,152,875	545,425	1,698,300	567,272	12,897,319	1,235,986	668,715

B-C 668,715

B/C 2.1788264

Table 7-4 Calculation of EIRR

(1,000 US\$)

Discount Rate 17.53573 % pa	Year	Cost			Benefit		NPV		
		Costruction	O&M	Total	PV	Total		PV	
	1	1994	274		274	198		-198	
	2	1995	150,638		150,638	92,774		-92,774	
	3	1996	0		0	0		0	
	4	1997	261,762		261,762	116,696		-116,696	
	5	1998	13,764	5,940	19,704	7,474	982	372	-7,101
	6	1999	0	5,940	5,940	1,917	12,564	4,055	2,138
	7	2000	41,705	5,940	47,645	13,082	17,553	4,819	-8,262
	8	2001	170,743	5,940	176,683	41,273	50,317	11,754	-29,519
	9	2002	21,295	9,909	31,204	6,202	72,051	14,320	8,118
	10	2003	13,844	9,909	23,753	4,017	98,470	16,651	12,634
	11	2004	23,696	9,909	33,605	4,835	129,166	18,583	13,748
	12	2005	7,494	9,909	17,403	2,130	164,153	20,093	17,963
	13	2006	152,605	9,909	162,514	16,924	204,188	21,264	4,340
	14	2007	174,375	13,625	188,000	16,657	248,047	21,978	5,320
	15	2008	0	13,625	13,625	1,027	294,906	22,231	21,204
	16	2009	9,084	13,625	22,709	1,456	344,805	22,115	20,658
	17	2010	12,576	13,625	26,201	1,430	397,573	21,695	20,265
	18	2011	99,020	13,625	112,645	5,230	452,606	21,013	15,783
	19	2012		17,565	17,565	694	452,606	17,878	17,184
	20	2013		17,565	17,565	590	452,606	15,211	14,620
	21	2014		17,565	17,565	502	452,606	12,941	12,439
	22	2015		17,565	17,565	427	452,606	11,011	10,583
	23	2016		17,565	17,565	364	452,606	9,368	9,004
	24	2017		17,565	17,565	309	452,606	7,970	7,661
	25	2018		17,565	17,565	263	452,606	6,781	6,518
	26	2019		17,565	17,565	224	452,606	5,769	5,546
	27	2020		17,565	17,565	190	452,606	4,909	4,718
	28	2021		17,565	17,565	162	452,606	4,176	4,014
	29	2022		17,565	17,565	138	452,606	3,553	3,415
	30	2023		17,565	17,565	117	452,606	3,023	2,906
	31	2024		17,565	17,565	100	452,606	2,572	2,472
	32	2025		17,565	17,565	85	452,606	2,188	2,103
	33	2026		17,565	17,565	72	452,606	1,862	1,790
	34	2027		17,565	17,565	61	452,606	1,584	1,523
	35	2028		17,565	17,565	52	452,606	1,348	1,295
	36	2029		17,565	17,565	45	452,606	1,147	1,102
	37	2030		17,565	17,565	38	452,606	976	938
	38	2031		17,565	17,565	32	452,606	830	798
	39	2032		17,565	17,565	27	452,606	706	679
	40	2033		17,565	17,565	23	452,606	601	578
	41	2034		17,565	17,565	20	452,606	511	491
	Total		1,152,875	545,425	1,698,300	337,859	12,897,319	337,859	0

B-C 0
B/C 1.0000000

Table 7-5 Construction Cost for Financial Analysis

(1,000 US\$)

Year	Total Construction Cost for Transmission Line	Value Added Tax	Construction Cost (Transmission Line) for Analysis	Total Construction Cost for Substation Equipment	Value Added Tax	Construction Cost (Substation) for Analysis	Total Construction Cost for Analysis
	A	B	C=A-B	D	E	F=D-E	C+F
1994	300	16	284				284
1995	161,280	6,692	154,588				154,588
1996							0
1997	81,410	650	80,760	206,995	11,358	195,637	276,397
1998	14,850	764	14,086				14,086
1999							0
2000	45,370	2,347	43,023				43,023
2001				193,909	10,660	183,249	183,249
2002	23,000	1,215	21,785				21,785
2003	15,080	791	14,289				14,289
2004	25,930	1,307	24,623				24,623
2005	12,510	4,718	7,792				7,792
2006				171,788	9,435	162,353	162,353
2007	175,180	555	174,625				174,625
2008							0
2009	18,190	8,701	9,489				9,489
2010	13,750	700	13,050				13,050
2011				112,518	6,184	106,334	106,334
2012							0
-			0				0
2034							0
Total	586,850	28,456	558,394	685,210	37,637	647,573	1,205,967

Table 7-6 Calculation of FIRR

(1.000 US\$)

Discount Rate	Year	Cost			Revenue		NPV		
		Costruction	O&M	Total	PV	Total		PV	
17.10040 % pa	1	1994	284		284	207		-207	
	2	1995	154,588		154,588	96,272		-96,272	
	3	1996	0		0	0		0	
	4	1997	276,397		276,397	125,528		-125,528	
	5	1998	14,086	5,940	20,026	7,767	982	381	-7,386
	6	1999	0	5,940	5,940	1,967	12,564	4,161	2,194
	7	2000	43,023	5,940	48,963	13,848	17,553	4,965	-8,884
	8	2001	183,249	5,940	189,189	45,695	50,317	12,153	-33,542
	9	2002	21,785	9,909	31,694	6,537	72,051	14,861	8,324
	10	2003	14,289	9,909	24,198	4,262	98,470	17,345	13,082
	11	2004	24,623	9,909	34,532	5,194	129,166	19,429	14,235
	12	2005	7,792	9,909	17,701	2,274	164,153	21,086	18,812
	13	2006	162,353	9,909	172,262	18,896	204,188	22,398	3,502
	14	2007	174,625	13,625	188,250	17,634	248,047	23,236	5,601
	15	2008	0	13,625	13,625	1,090	294,906	23,591	22,501
	16	2009	9,489	13,625	23,114	1,579	344,805	23,555	21,976
	17	2010	13,050	13,625	26,675	1,556	397,573	23,193	21,637
	18	2011	106,334	13,625	119,959	5,976	452,606	22,548	16,572
	19	2012		17,565	17,565	747	452,606	19,255	18,508
	20	2013		17,565	17,565	638	452,606	16,444	15,805
	21	2014		17,565	17,565	545	452,606	14,042	13,497
	22	2015		17,565	17,565	465	452,606	11,992	11,526
	23	2016		17,565	17,565	397	452,606	10,240	9,843
	24	2017		17,565	17,565	339	452,606	8,745	8,406
	25	2018		17,565	17,565	290	452,606	7,468	7,178
	26	2019		17,565	17,565	247	452,606	6,377	6,130
	27	2020		17,565	17,565	211	452,606	5,446	5,235
	28	2021		17,565	17,565	180	452,606	4,651	4,470
	29	2022		17,565	17,565	154	452,606	3,972	3,817
	30	2023		17,565	17,565	132	452,606	3,392	3,260
	31	2024		17,565	17,565	112	452,606	2,896	2,784
	32	2025		17,565	17,565	96	452,606	2,473	2,377
	33	2026		17,565	17,565	82	452,606	2,112	2,030
	34	2027		17,565	17,565	70	452,606	1,804	1,734
	35	2028		17,565	17,565	60	452,606	1,540	1,481
	36	2029		17,565	17,565	51	452,606	1,315	1,264
	37	2030		17,565	17,565	44	452,606	1,123	1,080
	38	2031		17,565	17,565	37	452,606	959	922
	39	2032		17,565	17,565	32	452,606	819	787
	40	2033		17,565	17,565	27	452,606	700	672
	41	2034		17,565	17,565	23	452,606	597	574
	Total		1,205,967	545,425	1,751,392	361,266	12,897,319	361,266	0

B-C 0
B/C 1.000000

Table 7-7 Construction Cost divided into Foreign and Local Currency Portion
(1,000 US\$)

Year	Construction Cost for Transmission Line				Construction Cost for Substation Equipment				Total Const. Cost (a) + (b) + (d) + (e)
	Total (a) + (b)	Foreign (a)	Local (b)	(Local) (VAT) (c)	Total (d) + (e)	Foreign (d)	Local (e)	(Local) (VAT) (f)	
1994	300	20	280	16	0				300
1995	161,280	11,280	150,000	6,692	0				161,280
1996	0	0	0	0	0				0
1997	81,410	24,160	57,250	650	206,996	138,528	68,468	11,358	288,406
	242,990				206,996				449,986
1998	14,850	920	13,930	764	0				14,850
1999	0	0	0	0	0				0
2000	45,370	3,770	41,600	2,347	0				45,370
2001	0	0	0	0	193,906	136,943	56,963	10,660	193,906
	60,220				193,906				254,126
2002	23,000	1,400	21,600	1,215	0				23,000
2003	15,080	1,270	13,810	791	0				15,080
2004	25,930	2,650	23,280	1,307	0				25,930
2005	12,510	850	11,660	4,718	0				12,510
2006	0	0	0	0	171,786	124,385	47,401	9,435	171,786
	76,520				171,786				248,306
2007	175,180	59,700	115,480	555	0				175,180
2008	0	0	0	0	0				0
2009	18,190	1,160	17,030	8,701	0				18,190
2010	13,750	1,350	12,400	700	0				13,750
2011	0	0	0	0	112,519	77,580	34,939	6,184	112,519
	207,120				112,519				319,639
Total	586,850	108,530	478,320	28,456	685,207	477,436	207,771	37,637	1,272,057

Table 7-8 Calculation of Interest during Construction

(1,000 US\$)

Year	Construction cost without VAT before escalation			Construction cost without VAT after escalation			Interest during Construction			Total		
	Foreign (a)+(d)	Local (b)-(c)+(e)-(f) - Total		Foreign	Local	Total	Foreign	Local	Total	Foreign	Local	Grand total
		20	284									
1994	11,280	143,308	0	13,058	165,897	178,955	524	4,162	4,686	13,582	170,059	183,641
1995	162,688	113,710	0	207,636	145,126	352,762	9,352	11,938	21,289	216,988	157,064	374,051
1996	13,166	14,086	0	1,233	17,644	18,877	49	441	490	1,282	18,085	19,367
1997	3,770	39,253	0	5,570	57,995	63,565	321	2,332	2,653	5,891	60,327	66,218
1998	136,943	46,303	0	212,444	71,831	284,275	9,042	5,578	14,620	221,486	77,409	298,894
1999	1,400	20,385	0	2,280	33,205	35,485	91	830	921	2,372	34,035	36,407
2000	1,270	13,019	0	2,172	22,267	24,439	269	2,217	2,486	2,441	24,484	26,925
2001	2,650	21,973	0	4,759	39,460	44,219	547	3,760	4,307	5,306	43,220	48,526
2002	850	6,942	0	1,603	13,090	14,693	801	5,074	5,875	2,404	18,164	20,568
2003	124,385	37,966	0	246,274	75,170	321,444	10,716	7,280	17,996	256,990	82,450	339,440
2004	59,700	114,925	0	124,112	238,921	363,033	4,964	5,973	10,938	129,076	244,894	373,970
2005	0	0	0	0	0	0	9,929	11,946	21,875	9,929	11,946	21,875
2006	1,160	8,329	0	2,659	19,090	21,749	10,035	12,423	22,459	12,694	31,514	44,208
2007	1,350	11,700	0	3,249	28,157	31,406	10,272	13,604	23,876	13,521	41,762	55,282
2008	77,580	28,755	0	196,041	72,662	268,703	18,243	16,125	34,368	214,284	88,787	303,071
2009	585,966	619,998	0	1,023,111	1,000,807	2,023,918	86,302	112,882	199,185	1,109,413	1,113,689	2,223,103
2010												
2011												
Total												

Table 7-9

Financing for Construction

(1,000 US\$)

Year	Construction cost after escalation		Interest during Construction		Financing for Construction		
	Foreign	Local	Foreign	Local	Foreign	Local	Total
1994	22	291	1	7	23	153	176
1995	13,058	165,897	524	4,162	13,582	87,110	100,693
1996	0	0	1,046	8,309	1,046	8,309	9,356
1997	207,636	145,126	9,352	11,938	216,988	84,501	301,488
					231,639	180,073	411,712
1998	1,233	17,644	49	441	1,282	9,263	10,545
1999	0	0	99	882	99	882	981
2000	5,570	57,995	321	2,332	5,891	31,330	37,221
2001	212,444	71,831	9,042	5,578	221,486	41,493	262,979
					228,758	82,968	311,727
2002	2,280	33,205	91	830	2,371	17,433	19,804
2003	2,172	22,267	269	2,217	2,441	13,350	15,792
2004	4,759	39,460	547	3,760	5,306	23,490	28,796
2005	1,603	13,090	801	5,074	2,404	11,619	14,023
2006	246,274	75,170	10,716	7,280	256,990	44,865	301,855
					269,512	110,757	380,269
2007	124,112	238,921	4,964	5,973	129,076	125,434	254,510
2008	0	0	9,929	11,946	9,929	11,946	21,875
2009	2,659	19,090	10,035	12,423	12,694	21,968	34,663
2010	3,249	28,157	10,272	13,604	13,521	27,683	41,204
2011	196,041	72,662	18,243	16,125	214,284	52,456	266,740
					379,505	239,487	618,991
Total	1,023,111	1,000,807	86,302	112,882	1,109,413	613,285	1,722,698

Table 7-10 Repayment Schedule of Debt (loan supplied 1994-1997)

(1,000 US\$)

No.	Year	Financing for Construction			Repayment of foreign Currency			Repayment of local Currency													
		Foreign	Local	Total	Interest	Principal	Total	Interest	Principal	Total											
	1994	23	153	176																	
	1995	13,582	87,110	100,693																	
	1996	1,046	8,308	9,356																	
	1997	216,988	84,501	301,488																	
1	1998				18,531	5,062	23,593	18,007	11,299	29,306	180,073										
2	1999				18,126	5,467	23,593	16,877	12,429	29,306	156,346										
3	2000				17,689	5,904	23,593	15,635	13,671	29,306	142,674										
4	2001				17,217	6,376	23,593	14,267	15,039	29,306	127,635										
5	2002				16,706	6,887	23,593	12,764	16,543	29,306	111,093										
6	2003				16,155	7,437	23,593	11,109	18,197	29,306	92,896										
7	2004				15,560	8,032	23,593	9,290	20,016	29,306	72,880										
8	2005				14,918	8,675	23,593	7,288	22,018	29,306	50,862										
9	2006				14,224	9,369	23,593	5,086	24,220	29,306	26,642										
10	2007				13,474	10,119	23,593	2,664	26,642	29,306	0										
11	2008				12,665	10,928	23,593														
12	2009				11,791	11,802	23,593														
13	2010				10,846	12,747	23,593														
14	2011				9,827	13,766	23,593														
15	2012				8,725	14,868	23,593														
16	2013				7,536	16,057	23,593														
17	2014				6,251	17,342	23,593														
18	2015				4,864	18,729	23,593														
19	2016				3,366	20,227	23,593														
20	2017				1,748	21,845	23,593														
	Total	231,639	180,073	411,713	240,220	231,639	471,859	112,988	180,073	293,061											

Table 7-11 Repayment Schedule of Debt (loan supplid 1998-2001)
(1,000 US\$)

No.	Year	Financing for Construction		Repayment of foreign Currency		Repayment of local Currency				
		Foreign	Local	Interest	Principal Total	Balance	Interest	Principal Total	Balance	
	1994									
	1995									
	1996									
	1997									
	1998	1,282	9,263		10,545					
	1999	99	882		981					
	2000	5,891	31,330		37,221					
	2001	221,486	41,493		262,979					82,968
1	2002			18,301		4,999	23,300	223,758	8,297	13,503
2	2003			17,901		5,399	23,300	218,360	7,776	13,503
3	2004			17,469		5,831	23,300	212,530	7,204	13,503
4	2005			17,002		6,297	23,300	206,233	6,574	13,503
5	2006			16,499		6,801	23,300	199,432	5,881	13,503
6	2007			15,955		7,345	23,300	192,087	5,119	13,503
7	2008			15,367		7,933	23,300	184,154	4,280	13,503
8	2009			14,732		8,567	23,300	175,587	3,358	13,503
9	2010			14,047		9,253	23,300	166,334	2,343	13,503
10	2011			13,307		9,993	23,300	156,342	1,228	13,503
11	2012			12,507		10,792	23,300	145,549		
12	2013			11,644		11,656	23,300	133,894		
13	2014			10,712		12,588	23,300	121,306		
14	2015			9,704		13,595	23,300	107,711		
15	2016			8,617		14,683	23,300	93,028		
16	2017			7,442		15,857	23,300	77,171		
17	2018			6,174		17,126	23,300	60,045		
18	2019			4,804		18,496	23,300	41,549		
19	2020			3,324		19,976	23,300	21,574		
20	2021			1,726		21,574	23,300	0		
	Total	228,758	82,968	311,726	237,232	228,758	465,990		52,059	82,968
										135,927

Table 7-12 Repayment Schedule of Debt (loan supplied 2002-2006)

(1,000 US\$)

No.	Year	Financing for Construction		Repayment of foreign Currency		Repayment of local Currency	
		Foreign	Local	Interest	Principal Total	Interest	Principal Total
	1994						
	1995						
	1996						
	1997						
	1998						
	1999						
	2000						
	2001						
	2002	2,371	17,433				
	2003	2,441	13,350				
	2004	5,306	23,490				
	2005	2,404	11,619				
	2006	256,990	44,865				
	2007					269,512	110,757
1	2007			21,561	5,889	27,450	6,949
2	2008			21,090	6,361	27,450	7,644
3	2009			20,581	6,869	27,450	8,409
4	2010			20,031	7,419	27,450	9,258
5	2011			19,438	8,013	27,450	10,175
6	2012			18,797	8,654	27,450	11,192
7	2013			18,105	9,345	27,450	12,311
8	2014			17,357	10,093	27,450	13,543
9	2015			16,549	10,901	27,450	14,897
10	2016			15,677	11,773	27,450	16,387
11	2017			14,736	12,715	27,450	18,025
12	2018			13,718	13,732	27,450	18,025
13	2019			12,620	14,831	27,450	18,025
14	2020			11,433	16,017	27,450	18,025
15	2021			10,152	17,298	27,450	18,025
16	2022			8,768	18,682	27,450	18,025
17	2023			7,274	20,177	27,450	18,025
18	2024			5,659	21,791	27,450	18,025
19	2025			3,916	23,534	27,450	18,025
20	2026			2,033	25,417	27,450	18,025
	Total	269,512	110,757	279,496	269,512	549,008	180,252

Table 7-13 Repayment Schedule of Debt (loan supplied 2007-2011) (1,000 US\$)

No.	Year	Financing for Construction		Repayment of foreign Currency			Repayment of local Currency								
		Foreign	Local	Total	Interest	Principal	Total	Interest	Principal	Total	Balance				
	1994														
	1995														
	1996														
	1997														
	1998														
	1999														
	2000														
	2001														
	2002														
	2003														
	2004														
	2005														
	2006														
	2007	129,076	125,434	254,510											
	2008	9,829	11,946	21,875											
	2009	12,694	21,968	34,663											
	2010	13,521	27,883	41,404											
	2011	214,284	52,456	266,740											
1	2012						30,360	8,293	38,653	371,212	23,949	15,027	38,975	239,487	224,460
2	2013						29,697	8,956	38,653	362,256	22,446	16,529	38,975	207,931	207,931
3	2014						28,980	9,673	38,653	352,583	20,793	18,182	38,975	189,749	189,749
4	2015						28,207	10,447	38,653	342,136	18,975	20,001	38,975	169,748	169,748
5	2016						27,371	11,283	38,653	330,853	16,975	22,001	38,975	147,747	147,747
6	2017						26,488	12,185	38,653	318,668	14,775	24,201	38,975	128,547	128,547
7	2018						25,493	13,160	38,653	305,508	12,355	26,621	38,975	96,926	96,926
8	2019						24,441	14,213	38,653	291,295	9,693	29,283	38,975	67,643	67,643
9	2020						23,304	15,350	38,653	275,945	6,764	32,211	38,975	35,432	35,432
10	2021						22,076	16,578	38,653	259,368	3,543	35,432	38,975	0	0
11	2022						20,749	17,904	38,653	241,464					
12	2023						19,317	19,336	38,653	222,127					
13	2024						17,770	20,883	38,653	201,244					
14	2025						16,100	22,554	38,653	178,690					
15	2026						14,295	24,358	38,653	154,332					
16	2027						12,347	26,307	38,653	128,025					
17	2028						10,242	28,411	38,653	99,614					
18	2029						7,969	30,684	38,653	68,929					
19	2030						5,514	33,139	38,653	35,750					
20	2031						2,863	35,790	38,653	0					
	Total	379,504	239,487	618,992			393,563	379,505	773,068		150,267	239,487	389,754		

Table 7-14 Statement of Profit and Loss

(1,000 US\$)

Year	Revenue	Business Expenses			Business Profit	Financial Cost			Net Profit
		OM cost	Depreciation	Total		Interest Dur. Const.	Interest	Total	
1994						8		8	-8
1995						4,686		4,686	-4,686
1996						9,356		9,356	-9,356
1997						21,289		21,289	-21,289
1998	1,316	7,960	17,730	25,690	-24,374	490	36,538	37,028	-61,402
1999	17,679	8,358	17,730	26,088	-8,409	981	35,003	35,984	-44,393
2000	25,934	8,776	17,730	26,506	-572	2,653	33,324	35,977	-36,549
2001	78,058	9,215	17,730	26,945	51,113	14,620	31,484	46,104	5,009
2002	117,363	16,141	29,776	45,917	71,447	921	56,068	56,989	14,458
2003	168,417	16,948	29,776	46,724	121,693	2,486	52,941	55,427	66,266
2004	231,964	17,795	29,776	47,571	184,392	4,307	49,523	53,830	130,562
2005	309,535	18,685	29,776	48,461	261,074	5,875	45,782	51,657	209,417
2006	404,278	19,619	29,776	49,395	354,883	17,996	41,690	59,686	295,197
2007	515,672	28,325	44,522	72,847	442,825	10,938	69,849	80,787	362,038
2008	643,743	29,742	44,522	74,264	569,479	21,875	63,783	85,658	483,821
2009	790,299	31,229	44,522	75,751	714,549	22,459	60,078	82,537	632,012
2010	956,807	32,790	44,522	77,312	879,495	23,876	56,042	79,918	799,577
2011	1,143,713	34,430	44,522	78,952	1,064,761	34,368	51,650	86,018	978,743
2012	1,200,898	46,605	69,472	116,077	1,084,821		101,171	101,171	983,650
2013	1,260,943	48,935	69,472	118,407	1,142,536		95,142	95,142	1,047,394
2014	1,323,991	51,382	69,472	120,854	1,203,136		88,576	88,576	1,114,560
2015	1,390,190	53,951	69,472	123,423	1,266,767		81,427	81,427	1,185,340
2016	1,459,700	56,649	69,472	126,121	1,333,579		73,645	73,645	1,259,934
2017	1,532,685	59,481	69,472	128,953	1,403,731		65,169	65,169	1,338,562
2018	1,609,319	62,455	69,472	131,927	1,477,391		57,740	57,740	1,419,651
2019	1,689,785	65,578	69,472	135,050	1,554,735		51,558	51,558	1,503,177
2020	1,774,274	68,857	69,472	138,329	1,635,945		44,825	44,825	1,591,120
Total	18,646,562	793,908	1,067,658	1,861,566	16,784,996	199,184	1,343,008	1,542,192	15,242,804

Table 7-15

Cash Flow

(1,000 US\$)

Year	Cash Inflow				Cash Outflow			Balance	
	Financing	Net Profit	Depreciation	Total	Investment	Repayment of princi.	Total	Year	Accumulated
1994	176	-8		168	176		176	-8	-8
1995	100,693	-4,686		96,007	100,693		100,693	-4,686	-4,694
1996	9,356	-9,356		0	9,356		9,356	-9,356	-14,050
1997	301,488	-21,289		280,199	301,488		301,488	-21,289	-35,339
1998	10,545	-61,402	17,730	-33,127	10,545	16,361	26,906	-60,033	-95,372
1999	981	-44,393	17,730	-25,682	981	17,896	18,877	-44,559	-139,932
2000	37,221	-36,549	17,730	18,402	37,221	19,575	56,796	-38,394	-178,326
2001	262,979	5,009	17,730	285,718	262,979	21,415	284,394	1,324	-177,002
2002	19,804	14,458	29,776	64,038	19,804	33,635	53,439	10,599	-166,403
2003	15,792	66,266	29,776	111,834	15,792	36,759	52,551	59,283	-107,119
2004	28,796	130,562	29,776	189,134	28,796	40,178	68,974	120,160	13,041
2005	14,023	209,417	29,776	253,216	14,023	43,919	57,942	195,274	208,315
2006	301,855	295,197	29,776	626,828	301,855	48,012	349,867	276,961	485,276
2007	254,510	362,038	44,522	661,070	254,510	65,328	319,838	341,232	826,508
2008	21,875	483,821	44,522	550,218	21,875	42,088	63,963	486,255	1,312,763
2009	34,663	632,012	44,522	711,197	34,663	45,792	80,455	630,742	1,943,504
2010	41,204	799,577	44,522	885,303	41,204	49,828	91,032	794,271	2,737,775
2011	266,740	978,743	44,522	1,290,005	266,740	54,222	320,962	969,043	3,706,818
2012		983,650	69,472	1,053,122		68,826	68,826	984,296	4,691,115
2013		1,047,394	69,472	1,116,866		74,855	74,855	1,042,011	5,733,125
2014		1,114,560	69,472	1,184,032		81,421	81,421	1,102,611	6,835,737
2015		1,185,340	69,472	1,254,812		88,570	88,570	1,166,242	8,001,979
2016		1,259,934	69,472	1,329,406		96,354	96,354	1,233,052	9,235,030
2017		1,338,562	69,472	1,408,034		86,803	86,803	1,321,231	10,556,262
2018		1,419,651	69,472	1,489,123		70,639	70,639	1,418,484	11,974,746
2019		1,503,177	69,472	1,572,649		76,823	76,823	1,495,826	13,470,572
2020		1,591,120	69,472	1,660,592		83,554	83,554	1,577,038	15,047,609
Total	1,722,701	15,242,804	1,067,658	18,033,163	1,722,701	1,262,853	2,985,554	15,047,609	

Table 7-16

Calculation of Debt Service Ratio

(1,000 US\$)

Year	Internal Fund Procured				Repayment of Debt				Debt Service Ratio
	Business Profit	Depreciation	Total	Accumulated	Interest	Principal	Total	Accumulated	
				(A)				(B)	(A)/(B)
1994									
1995									
1996									
1997									
1998	-24,374	17,730	-6,644	-6,644	36,538	16,361	52,899	52,899	-0.13
1999	-8,409	17,730	9,321	2,676	35,003	17,896	52,899	105,798	0.03
2000	-572	17,730	17,158	19,834	33,324	19,575	52,899	158,697	0.12
2001	51,113	17,730	68,843	88,677	31,484	21,415	52,899	211,596	0.42
2002	71,447	29,776	101,223	189,900	56,068	33,635	89,703	301,299	0.63
2003	121,693	29,776	151,469	341,370	52,941	36,759	89,700	390,999	0.87
2004	184,392	29,776	214,168	555,538	49,523	40,178	89,701	480,700	1.16
2005	261,074	29,776	290,850	846,388	45,782	43,919	89,701	570,401	1.48
2006	354,883	29,776	384,659	1,231,047	41,690	48,012	89,702	660,103	1.86
2007	442,825	44,522	487,347	1,718,394	69,849	65,328	135,177	795,280	2.16
2008	569,479	44,522	614,001	2,332,395	63,783	42,088	105,871	901,151	2.59
2009	714,549	44,522	759,071	3,091,465	60,078	45,792	105,870	1,007,021	3.07
2010	879,495	44,522	924,017	4,015,482	56,042	49,828	105,870	1,112,891	3.61
2011	1,064,761	44,522	1,109,283	5,124,765	51,650	54,222	105,872	1,218,763	4.20
2012	1,084,821	69,472	1,154,293	6,279,059	101,171	68,826	169,997	1,388,760	4.52
2013	1,142,536	69,472	1,212,008	7,491,066	95,142	74,855	169,997	1,558,757	4.81
2014	1,203,136	69,472	1,272,608	8,763,675	88,576	81,421	169,997	1,728,754	5.07
2015	1,266,767	69,472	1,336,239	10,099,914	81,427	88,570	169,997	1,898,751	5.32
2016	1,333,579	69,472	1,403,051	11,502,964	73,645	96,354	169,999	2,068,750	5.56
2017	1,403,731	69,472	1,473,203	12,976,168	65,169	86,803	151,972	2,220,722	5.84
2018	1,477,391	69,472	1,546,863	14,523,031	57,740	70,639	128,379	2,349,101	6.18
2019	1,554,735	69,472	1,624,207	16,147,238	51,558	76,823	128,381	2,477,482	6.52
2020	1,635,945	69,472	1,705,417	17,852,654	44,825	83,554	128,379	2,605,861	6.85
Total	16,784,996	1,067,658	17,852,654		1,343,008	1,262,853	2,605,861		

CHAPTER 8 FUTURE STUDIES

It is necessary to continue the following studies for implementing the project in accordance with the feasibility study on Bulk Power Supply Project for the Greater Bangkok Area:

- (1) Study on the land acquisition for the transmission lines and substations to be installed in accordance with the feasibility study.
- (2) Economic comparison study on the design of substation and transmission line taking environmental aspects into consideration.
- (3) Review on the feasibility study in case that circumstances be changed.
- (4) Study for obtaining governmental authorization of the actual implementation of the Project, such as environmental assessment of the Project.
- (5) Study on the detailed design of the Project, including studies such as optimization of the transmission line design whether the overhead transmission line should be employed or underground cable.
- (6) Study on the detailed implementation schedule.
- (7) Study on the arrangement of the budget.
- (8) Study on the procurement arrangement of the services and materials.

CHAPTER 9 TECHNOLOGY TRANSFER

(1) OJT During Implementation of Field Investigation

At the time of presentation of the Inception Report, discussions shall be held on the features and problems of this Project in sufficient detail. During this process, technology shall be transferred to the counterpart concerning what kind of works are required in solving problems in each area, and what techniques are used in conducting such works.

In the presentation of Interim Report and Draft Final Report, each content of reports shall be presented by the personnel in direct charge of the subject, and technology transfer shall be implemented concerning not only the problems and their solutions related to this Project, but on the general subject of transmission line and substation development plan for the Kingdom of Thailand through exchange of questions and answers between the participants of the presentation meetings.

(2) Training of Counterpart in Japan

In the training in Japan, emphasis shall be placed on the design of transmission line and substation facilities and power system analysis methodologies which are closely related to the content of this Feasibility Study.

The power system analysis computer code possessed by EPDC shall be used in the training of power system analysis.

As EPDC has experiences on projects which are similar to this Study, a comprehensive technology transfer, including on-site training, shall be conducted based on EPDC's experiences on the problems and critical issues in power system planning.

a) Training on Transmission Line and Substation Expansion Plan of Greater Bangkok Area

Training programs shall be formulated and applied on the following subjects.

i) Power System Analysis

- Power flow calculation
- Short circuit capacity calculation
- Power system stability calculation

ii) Transmission Line and Substation Designs

- Design of urban type substations
- Transmission line tower structural calculation
- Insulation coordination and power line design

b) On-Site Training

EPDC has Nishi-Tokyo Substation at Machida City of Tokyo Metropolitan District. This substation is located inside the

metropolitan area. A construction work for expansion of transmission line capacity is under way to convert a section of Tadami Trunk Line, which connects Shin-Nitta Substation of Tokyo Electric Power Company to Kita-Kumagaya Substation of the same company from the existing 275 kV, double circuit design to a line having two, 500 kV circuits and two, 275 kV circuits. This substation facility and the transmission line reinforcement project is similar to the Bulk Power Supply Project for the Greater Bangkok Area.

Therefore, it should be very effective in giving the trainees to grasp a comprehensive picture of the Bulk Power Supply Project for the Greater Bangkok Area if the training is given by pointing out the features and problems of planning, design, construction and expansion of Nishi-Tokyo Substation and the design and construction plan of Tadami Trunk Line Reinforcement Project, and their implication on the Project of Thailand.

As the training will be given not only by class room studies but through on-site observation of technical problems, the time period of training in Japan shall be appropriately planned.

JICA