

Appendix 5.3.3-6

Calculation of Overall Heat Transfer
Coefficient(U) and Fouling Factor(f) in Run 5-2

OPERATION CONDITION

FOR

RUN 5-2

1. Operation Period	24th Oct. to 7th Nov.
2. Operation Time	230 h
3. Scale Control Method	Hybrid
4. Operation Mode	Recirculation
5. Ball Cleaning	at F.F in B.H of $0.34-0.36 \text{ m}^2 \text{K/kW}$
6. Top Brine Temperature	112°C
7. Flow Rate	
-Make Up Seawater	$2.45 \text{ m}^3/\text{h}$
-Recirculation	$6.5 \text{ m}^3/\text{h}$
-Product Water	$0.79 \text{ m}^3/\text{h}$
-Blow Brine	$1.66 \text{ m}^3/\text{h}$
8. Chemical Constituents of Brine	
-pH at 25°C	8.12
-M-Alkalinity as CaCO_3	55 - 60 mg/L
-Chloride ion	32,720 mg/L
-Concentration factor as Cl^-	1.39
9. Dosing Rate of Chemicals	
-Scale Inhibitor = PPN(M)	1 mg/L
-Acid = 98% H_2SO_4	72 mg/L

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 25, 94 Time: 00:00 Total Operation Time: 8.0 Hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	15500	15500		
Specific Heat (kJ/kg/°C)	3.940	3.926	3.912	3.900	3.968	3.965		
Inlet Temp. (deg. C)	76.8	63.3	50.1	37.5	31.9	27		
Outlet Temp. (deg. C)	89.5	76.8	63.3	50.1	37	31.9		
Temp. Rise (deg. C)	12.7	13.5	13.2	12.6	5.1	4.9		
Flashing Temp. (deg. C)	116	82.3	69.8	56.7	41.6	35.7		
Heat Transfer Rate (kJ/s)	160.932	95.690	93.240	88.729	87.122	83.645		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	11.899	10.890	11.905	11.800	6.836	5.916		
U (kW/sq.m/°C)	2.895	4.536	4.044	3.882	2.572	2.853		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.0891	0.0244	0.0512	0.0615	0.1927	0.1544		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 25, 94 Time: 04:00 Total Operation Time: 12.0 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/hr)	6500	6500	6500	6500	15500	15500		
Specific Heat (kJ/kg/°C)	3.940	3.925	3.911	3.899	3.967	3.964		
Inlet Temp. (deg. C)	76.1	62.3	49	36.2	30.8	27		
Outlet Temp. (deg. C)	89	76.1	62.3	49	35	30.8		
Temp. Rise (deg. C)	12.9	13.8	13.3	12.8	4.2	3.8		
Flashing Temp. (deg. C)	91.6	81.3	69.1	55.7	39.8	34.5		
Heat Transfer Rate (kJ/s)	164.495	97.794	93.922	90.113	71.731	64.863		
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	16.396	10.650	12.272	11.982	6.681	5.378		
U (kW/sq.m/°C)	2.147	4.741	3.951	3.883	2.166	2.434		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.2093	0.0149	0.0570	0.0615	0.2655	0.2148		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 25, 94 Time: 8:00 Total Operation Time: 16 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500		
Specific Heat (kJ/kg/°C)	3.940	3.925	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	76.4	62.9	49.4	36.8	31	29		
Outlet Temp. (deg. C)	89	76.4	62.9	49.4	37	31		
Temp. Rise (deg. C)	12.6	13.5	13.5	12.6	6	2		
Flashing Temp. (deg. C)	92.2	82.2	69.9	56.4	40.3	36.4		
Heat Transfer Rate (kJ/s)	164.495	95.680	95.346	88.715	122.327	40.752		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	15.804	11.229	12.564	12.238	5.791	6.348		
U (kW/sq.m/°C)	2.228	4.399	3.918	3.743	4.263	1.296		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
F (sq.m K/kW)	0.1925	0.0312	0.0592	0.0711	0.0385	0.5758		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 25, 94

Time: 12:00

Total Operation Time: 20 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500		
Specific Heat (kJ/kg/K)	3.940	3.925	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	89	63.1	50	37.5	31.4	29		
Outlet Temp. (deg. C)	112	76.5	63.1	50	36	31.4		
Temp. Rise (deg. C)	23	13.4	13.1	12.5	4.6	2.4		
Flashing Temp. (deg. C)	119	82.9	70.2	56.9	41	35.7		
Heat Transfer Rate (kJ/s)	164.495	94.975	92.530	88.024	93.780	48.904		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	15.804	11.865	12.529	12.092	7.052	5.412		
U (kW/sq.m/K)	2.228	4.133	3.813	3.758	2.684	1.824		
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/KW)	0.1925	0.0459	0.0662	0.0700	0.1766	0.3523		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 25, 94

Time: 16:00

Total Operation Time: 24 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.940	3.925	3.912	3.900	3.967	3.965			
Inlet Temp. (deg. C)	89.5	63	50	37.4	31.5	28			
Outlet Temp. (deg. C)	112	76.5	63	50	36	31.5			
Temp. Rise (deg. C)	22.5	13	13.5	12.6	4.5	3.5			
Flashing Temp. (deg. C)	118	83.1	70.1	56.9	40.8	35.5			
Heat Transfer Rate (kJ/s)	160.932	95.682	91.823	88.727	91.742	71.313			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	14.440	12.122	12.492	12.128	6.804	5.568			
U (kW/sq.m/°C)	2.385	4.075	3.795	3.777	2.721	2.585			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.1628	0.0493	0.0675	0.0687	0.1714	0.1908			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 25, 84 Time: 20:00 Total Operation Time: 28 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8	# 9
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.961	3.925	3.912	3.900	3.967	3.965			
Inlet Temp. (deg. C)	89.5	62.9	49.7	37	31.2	28			
Outlet Temp. (deg. C)	112	76.4	62.9	49.7	36	31.2			
Temp. Rise (deg. C)	22.5	13.5	13.2	12.7	4.8	3.2			
Flashing Temp. (deg. C)	118	82.6	70.1	56.6	40.5	35.3			
Heat Transfer Rate (kJ/s)	160.932	95.680	93.231	89.424	97.856	65.199			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	14.440	11.678	12.675	12.165	6.612	5.547			
U (kW/sq.m/°C)	2.385	4.230	3.797	3.795	2.986	2.372			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.1628	0.0403	0.0673	0.0674	0.1388	0.2255			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 26, 94

Time: 00:00

Total Operation Time: 32 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 6	# 6
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500	18500	18500
Specific Heat (KJ/Kg/K)	3.961	3.925	3.912	3.900	3.967	3.965	3.965	3.965
Inlet Temp. (deg. C)	89	62.7	49.6	36.9	31.1	27	27	27
Outlet Temp. (deg. C)	112	76.3	62.7	49.6	35.5	31.1	31.1	31.1
Temp. Rise (deg. C)	23	13.6	13.1	12.7	4.4	4.1	4.1	4.1
Flashing Temp. (deg. C)	117.5	82.5	70	56.6	40.5	35.2	35.2	35.2
Heat Transfer Rate (KJ/S)	164.495	96.385	92.521	89.422	89.697	83.530	83.530	83.530
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	4.9556
L.M.T.D. (deg. K)	13.980	11.713	12.747	12.274	6.970	5.915	5.915	5.915
U (kW/sq.m/K)	2.518	4.248	3.747	3.761	2.597	2.850	2.850	2.850
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.1407	0.0393	0.0708	0.0698	0.1890	0.1548	0.1548	0.1548

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2	Date: October 26, 94		Time: 04:00		Total Operation Time: 36 hr.	
Variables	Brine Heater		Evaporator Stages			
	# 1	# 2	# 3	# 4	# 5	# 6
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500
Specific Heat (KJ/kg/K)	3.961	3.925	3.912	3.900	3.967	3.964
Inlet Temp. (deg. C)	89	62.7	49.6	36.9	31	27
Outlet Temp. (deg. C)	112	76	62.7	49.6	35	31
Temp. Rise (deg. C)	23	13.3	13.1	12.7	4	4
Flashing Temp. (deg. C)	118	82.3	69.9	56.7	40.6	35.2
Heat Transfer Rate (KJ/S)	164.495	94.255	92.521	89.422	81.539	81.492
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556
L.M.T.D. (deg. K)	14.598	11.718	12.638	12.383	7.421	5.979
U (kW/sq.m/K)	2.412	4.153	3.779	3.728	2.217	2.751
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.1582	0.0447	0.0685	0.0722	0.2550	0.1675

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 26, 94

Time: 06:00

Total Operation Time: 40 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000		
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	76.4	63.2	50	37.5	31.3	29.5		
Outlet Temp. (deg. C)	88	76.4	63.2	50	37	31.3		
Temp. Rise (deg. C)	11.6	13.2	13.2	12.5	5.7	1.8		
Flashing Temp. (deg. C)	93.4	82.8	70.4	57.2	41	35.6		
Heat Transfer Rate (kJ/s)	171.620	93.557	93.238	88.024	113.072	35.687		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	16.128	11.794	12.675	12.419	6.435	5.148		
U (kW/sq.m/°C)	2.277	4.095	3.798	3.659	3.546	1.399		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.1827	0.0481	0.0672	0.0772	0.0859	0.5187		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 26, 94

Time: 12:00

Total Operation Time: 44 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000		
Specific Heat (KJ/kg/°C)	3.961	3.925	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	89	62.6	49.9	37.7	31.7	28.5		
Outlet Temp. (deg. C)	112	75.6	62.6	49.9	36.5	31.7		
Temp. Rise (deg. C)	23	13	12.7	12.2	4.8	3.2		
Flashing Temp. (deg. C)	118.5	82.3	69.9	57	41.3	35.9		
Heat Transfer Rate (kJ/s)	164.495	92.123	89.698	85.912	95.218	63.442		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	15.206	12.054	12.601	12.200	6.925	5.650		
U (kW/sq.m/°C)	2.315	3.946	3.675	3.636	2.775	2.266		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.1755	0.0289	0.0760	0.0790	0.1643	0.2452		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2	Date: October 26, 94	Time: 18:00	Total Operation Time: 48 hr.					
Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500	18500	
Specific Heat (kJ/kg/K)	3.939	3.925	3.912	3.900	3.967	3.965	3.965	
Inlet Temp. (deg. C)	88.5	62.6	49.9	37.5	31.5	28	28	
Outlet Temp. (deg. C)	112	75.8	62.6	49.9	36	31.5	31.5	
Temp. Rise (deg. C)	23.5	13.2	12.7	12.4	4.5	3.5	3.5	
Flashing Temp. (deg. C)	120	82.8	70.2	57	40.9	35.8	35.8	
Heat Transfer Rate (kJ/s)	168.058	93.542	89.698	87.319	91.742	71.313	71.313	
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	
L.M.T.D. (deg. K)	17.146	12.456	12.927	12.273	6.907	5.877	5.877	
U (kW/sq.m/K)	2.098	3.877	3.582	3.673	2.680	2.448	2.448	
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	
f (sq.m K/kW)	0.2203	0.0618	0.0831	0.0762	0.1770	0.2123	0.2123	

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 26, 94 Time: 20:00 Total Operation Time: 52 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6480	6480	6480	6480	18500	18500		
Specific Heat (kJ/kg/°C)	3.961	3.925	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	89	62.6	49.9	37.5	31.6	28		
Outlet Temp. (deg. C)	112	75.7	62.6	49.9	36	31.6		
Temp. Rise (deg. C)	23	13.1	12.7	12.4	4.4	3.6		
Flashing Temp. (deg. C)	120	82.4	70	57.1	41	35.9		
Heat Transfer Rate (kJ/s)	163.989	92.547	89.422	87.050	89.704	73.351		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	16.980	12.090	12.710	12.382	6.970	5.919		
U (kW/sq.m/°C)	2.067	3.952	3.632	3.629	2.597	2.501		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.2274	0.0570	0.0792	0.0794	0.1890	0.2038		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 27, 94

Time: 00:00

Total Operation Time: 56 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200		
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	88.5	62.8	50.1	37.9	31.9	28		
Outlet Temp. (deg. C)	112	75.9	62.8	50.1	36	31.9		
Temp. Rise (deg. C)	23.5	13.1	12.7	12.2	4.1	3.9		
Flashing Temp. (deg. C)	121	82.6	70.4	57.5	41.3	36.2		
Heat Transfer Rate (kJ/s)	168.058	92.837	89.703	85.916	82.234	78.177		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	18.302	12.090	12.927	12.525	7.155	6.042		
U (kW/sq.m/°C)	1.965	3.964	3.583	3.541	2.319	2.611		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.2524	0.0562	0.0831	0.0863	0.2351	0.1869		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 27, 84

Time: 04:00

Total Operation Time: 60 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 6	# 6
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500	18500	18500
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.967	3.965	3.965	3.965
Inlet Temp. (deg. C)	88.5	62.8	50	37.7	31.6	28	28	28
Outlet Temp. (deg. C)	112	75.8	62.8	50	36	31.6	31.6	31.6
Temp. Rise (deg. C)	23.5	13	12.8	12.3	4.4	3.6	3.6	3.6
Flashing Temp. (deg. C)	121	82.1	70.1	57.3	41	36	36	36
Heat Transfer Rate (kJ/s)	168.058	92.127	90.408	86.617	89.704	73.351	73.351	73.351
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	4.9556
L.M.T.D. (deg. C)	18.302	11.612	12.638	12.454	6.970	6.022	6.022	6.022
U (kW/sq.m/°C)	1.965	4.096	3.693	3.591	2.597	2.458	2.458	2.458
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.2524	0.0481	0.0747	0.0824	0.1890	0.2107	0.2107	0.2107

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 27, 94

Time: 08:00

Total Operation Time: 64 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 6	# 6
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000	18000	18000
Specific Heat (KJ/kg/°C)	3.939	3.925	3.912	3.900	3.968	3.966	3.966	3.966
Inlet Temp. (deg. C)	88.5	63	50.3	38	31.7	30	30	30
Outlet Temp. (deg. C)	112	76.1	63	50.3	37	31.7	31.7	31.7
Temp. Rise (deg. C)	23.5	13.1	12.7	12.3	5.3	1.7	1.7	1.7
Flashing Temp. (deg. C)	121	82.2	70.5	57.5	41.3	36.2	36.2	36.2
Heat Transfer Rate (kJ/s)	168.058	92.842	89.707	86.623	105.140	33.707	33.707	33.707
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	4.9556
L.M.T.D. (deg. C)	18.302	11.425	12.818	12.345	6.599	5.305	5.305	5.305
U (kW/sq.m/°C)	1.965	4.195	3.613	3.622	3.215	1.282	1.282	1.282
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.2524	0.0423	0.0807	0.0800	0.1150	0.5838	0.5838	0.5838

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2	Date: October 27, 94	Time: 12:00	Total Operation Time: 68 hr.					
Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000	18000	
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.968	3.965	3.965	
Inlet Temp. (deg. C)	88.5	62.8	50.1	37.9	32.6	29	29	
Outlet Temp. (deg. C)	112	75.7	62.8	50.1	37	32.6	32.6	
Temp. Rise (deg. C)	23.5	12.9	12.7	12.2	4.4	3.6	3.6	
Flashing Temp. (deg. C)	121	82.7	70.4	57.5	41.8	36.1	36.1	
Heat Transfer Rate (kJ/s)	168.058	91.418	89.703	85.916	87.292	71.379	71.379	
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	
L.M.T.D. (deg. C)	18.302	12.347	12.927	12.525	6.763	5.090	5.090	
U (kW/sq.m/°C)	1.965	3.822	3.583	3.541	2.605	2.830	2.830	
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	
f (sq.m K/kW)	0.2524	0.0655	0.0831	0.0863	0.1879	0.1573	0.1573	

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 27, 94

Time: 16:00

Total Operation Time: 72 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8
Flowrate (kg/h)	6500	6500	6500	6500	18300	18300		
Specific Heat (kJ/kg/°C)	3.961	3.925	3.912	3.901	3.968	3.965		
Inlet Temp. (deg. C)	88.5	62.9	50.4	38.5	32.5	29		
Outlet Temp. (deg. C)	112	75.8	62.9	50.4	37	32.5		
Temp. Rise (deg. C)	23.5	12.9	12.5	11.9	4.5	3.5		
Flashing Temp. (deg. C)	122	82.8	70.7	57.9	41.8	36.7		
Heat Transfer Rate (kJ/s)	168,058	91,420	88,295	83,812	90,764	70,552		
Heat Transfer Area (sq.m)	4,6723	1,937	1,937	1,937	4,9556	4,9556		
L.M.T.D. (deg. K)	19,438	12,347	13,069	12,521	6,804	5,774		
U (kW/sq.m/°C)	1,850	3,823	3,488	3,456	2,692	2,466		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.2840	0.0655	0.0906	0.0933	0.1754	0.2095		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 27, 94 Time: 20:00 Total Operation Time: 76 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200		
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.901	3.968	3.965		
Inlet Temp. (deg. C)	75.8	62.9	50.4	38.1	32	29		
Outlet Temp. (deg. C)	88.5	75.8	62.9	50.4	37	32		
Temp. Rise (deg. C)	12.7	12.9	12.5	12.3	5	3		
Flashing Temp. (deg. C)	93.4	82.8	70.7	57.9	41.6	36.5		
Heat Transfer Rate (kJ/s)	168.058	91.420	88.295	86.625	100.293	60.141		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	19.438	12.347	13.069	12.670	6.796	5.873		
U (kW/sq.m/°C)	1.850	3.823	3.488	3.530	2.978	2.066		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.2840	0.0655	0.0906	0.0872	0.1397	0.2878		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2	Date: October 28, 94	Time: 00:00	Total Operation Time: 80 hr.					
Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200	18200	
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.967	3.965	3.965	
Inlet Temp. (deg. C)	75.7	62.7	50.1	37.9	31.9	28.5	28.5	
Outlet Temp. (deg. C)	88.5	75.7	62.7	50.1	36	31.9	31.9	
Temp. Rise (deg. C)	12.8	13	12.6	12.2	4.1	3.4	3.4	
Flashing Temp. (deg. C)	93.2	82.7	70.7	57.8	41.4	36.3	36.3	
Heat Transfer Rate (kJ/s)	91.035	92.125	88.995	85.916	82.234	68.157	68.157	
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	
L.M.T.D. (deg. C)	20.000	12.383	13.321	12.849	7.258	5.939	5.939	
U (kW/sq.m/°C)	4.827	3.841	3.449	3.452	2.286	2.316	2.316	
Clean-U Value (kW/sq.m/°C)	6.6	5.1	5.1	5.1	5.1	5.1	5.1	
f (sq.m K/kW)	0.0557	0.0643	0.0939	0.0936	0.2413	0.2357	0.2357	

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2	Date: October 28, 94	Time: 04:00	Total Operation Time: 84 hr.					
Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200	18200	
Specific Heat (kj/kg/°C)	3.961	3.925	3.912	3.900	3.967	3.965	3.965	
Inlet Temp. (deg. C)	88.5	62.8	50.2	37.9	31.8	28	28	
Outlet Temp. (deg. C)	112	75.7	62.8	50.2	36	31.8	31.8	
Temp. Rise (deg. C)	23.5	12.9	12.6	12.3	4.2	3.8	3.8	
Flashing Temp. (deg. C)	124	81.9	70.6	57.7	41.4	36.3	36.3	
Heat Transfer Rate (kJ/s)	168.058	91.418	88.998	86.621	84.239	76.172	76.172	
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	
L.M.T.D. (deg. K)	21.666	11.465	13.106	12.670	7.300	6.207	6.207	
U (kW/sq.m/°C)	1.660	4.116	3.506	3.529	2.329	2.476	2.476	
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	
f (sq.m K/kw)	0.3460	0.0469	0.0892	0.0872	0.2333	0.2078	0.2078	

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 28, 84

Time: 08:00

Total Operation Time: 88 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200		
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.968	3.965		
Inlet Temp. (deg. C)	88	62.5	49.9	37.7	31.7	29.5		
Outlet Temp. (deg. C)	112	75.5	62.5	49.9	37	31.7		
Temp. Rise (deg. C)	24	12.5	12.6	12.2	5.3	2.2		
Flashing Temp. (deg. C)	124	82.1	70.3	57.4	41.2	36		
Heat Transfer Rate (kJ/s)	171.620	92.120	88.991	85.912	106.309	44.104		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	21.846	11.943	13.106	12.633	6.493	5.324		
U (kW/sq.m/°C)	1.681	3.982	3.506	3.511	3.304	1.671		
Clean-U value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3383	0.0551	0.0892	0.0888	0.1066	0.4022		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 28, 94

Time: 12:00

Total Operation Time: 92 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500		
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.968	3.965		
Inlet Temp. (deg. C)	88	62.8	50.4	37.7	32	29		
Outlet Temp. (deg. C)	112	75.6	62.8	50.4	37	32		
Temp. Rise (deg. C)	24	12.8	12.4	12.7	5	3		
Flashing Temp. (deg. C)	124	93.4	70.9	58.1	41.6	36.5		
Heat Transfer Rate (kJ/s)	171.620	90.708	87.587	89.438	101.947	61.132		
Heat Transfer Area (sq. m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	21.846	12.638	13.354	13.035	6.796	5.873		
U (kW/sq.m/°C)	1.681	3.706	3.386	3.542	3.027	2.101		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3383	0.0738	0.0992	0.0862	0.1343	0.2800		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 28, 94 Time: 18:00 Total Operation Time: 96 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 5	# 6
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500	18500	18500
Specific Heat (kJ/kg.°C)	3.960	3.925	3.912	3.901	3.968	3.965	3.965	3.965
Inlet Temp. (deg. C)	88	62.7	50.3	38.1	32.1	29	32.1	29
Outlet Temp. (deg. C)	112	75.5	62.7	50.3	37	32.1	37	32.1
Temp. Rise (deg. C)	24	12.8	12.4	12.2	4.9	3.1	4.9	3.1
Flashing Temp. (deg. C)	124	82.8	70.7	58	41.6	36.6	41.6	36.6
Heat Transfer Rate (kJ/s)	171.620	90.705	87.585	85.920	99.908	63.170	99.908	63.170
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	4.9556
L.M.T.D. (deg. K)	21.846	12.638	13.247	12.849	6.756	5.915	6.756	5.915
U (kW/sq.m/°C)	1.681	3.705	3.413	3.452	2.984	2.155	2.984	2.155
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.3383	0.0738	0.0969	0.0936	0.1390	0.2680	0.1390	0.2680

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 28, 94 Time: 20:00 Total Operation Time: 100 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6350	6350	6350	6350	18300	18300		18300
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.967	3.965		3.965
Inlet Temp. (deg. C)	88	62.6	50.2	38.1	31.9	29		29
Outlet Temp. (deg. C)	112	75.6	62.6	50.2	36.5	31.9		31.9
Temp. Rise (deg. C)	24	13	12.4	12.1	4.6	2.9		2.9
Flashing Temp. (deg. C)	124	82.7	70.6	57.9	41.5	36.4		36.4
Heat Transfer Rate (kJ/s)	167.660	89.997	85.562	83.248	92.773	58.455		58.455
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		4.9556
L.M.T.D. (deg. C)	21.846	12.492	13.247	12.812	7.052	5.830		5.830
U (kW/sq.m/°C)	1.643	3.719	3.335	3.355	2.655	2.023		2.023
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		5.1
f (sq.m K/kW)	0.3524	0.0728	0.1038	0.1020	0.1806	0.2982		0.2982

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 29, 94

Time: 00:00

Total Operation Time: 104 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6350	6350	6350	6350	18200	18200		
Specific Heat (kJ/kg/°C)	3.960	3.925	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	88	62.4	49.9	37.7	31.8	28.5		
Outlet Temp. (deg. C)	112	75.4	62.4	49.9	36	31.8		
Temp. Rise (deg. C)	24	12.6	12.5	12.2	4.2	3.3		
Flashing Temp. (deg. C)	124	92.8	70.4	57.6	41.2	36.1		
Heat Transfer Rate (kJ/s)	167.660	89.992	86.246	83.930	84.239	66.152		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	21.846	12.164	13.284	12.849	7.094	5.794		
U (kW/sq.m/°C)	1.643	3.820	3.352	3.372	2.396	2.304		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m/kW)	0.3524	0.0657	0.1023	0.1005	0.2212	0.2380		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2	Date: October 29, 94	Time: 08:00	Total Operation Time: 112 hr.					
Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6350	6350	6350	6350	18400	18400	18400	
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.968	3.965	3.965	
Inlet Temp. (deg. C)	75.6	62.5	49.9	37.4	32.2	29	29	
Outlet Temp. (deg. C)	88.5	75.6	62.5	49.9	37	32.2	32.2	
Temp. Rise (deg. C)	12.9	13.1	12.6	12.5	4.8	3.2	3.2	
Flashing Temp. (deg. C)	94.2	83.7	71.6	58.7	42.1	36.8	36.8	
Heat Transfer Rate (kJ/s)	89.628	90.688	86.937	85.990	97.341	64.856	64.856	
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	
L.M.T.D. (deg. C)	23.851	13.616	14.499	14.141	7.237	6.060	6.060	
U (kW/sq.m/°C)	4.242	3.439	3.096	3.139	2.714	2.160	2.160	
Clean-U Value (kW/sq.m/°C)	6.6	5.1	5.1	5.1	5.1	5.1	5.1	
f (sq.m K/kW)	0.0842	0.0947	0.1270	0.1225	0.1723	0.2669	0.2669	

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 29, 94

Time: 12:00

Total Operation Time: 116 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18400	18400		
Specific Heat (kJ/kg/°C)	3.961	3.925	3.912	3.901	3.968	3.966		
Inlet Temp. (deg. C)	88.5	62.9	50.4	38.2	32.3	29.5		
Outlet Temp. (deg. C)	112	75.8	62.9	50.4	37	32.3		
Temp. Rise (deg. C)	23.5	12.9	12.5	12.2	4.7	2.8		
Flashing Temp. (deg. C)	125	83.7	71.6	58.7	42.1	36.8		
Heat Transfer Rate (kJ/s)	168.058	91.420	88.295	85.922	95.314	56.751		
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	22.763	13.325	14.034	13.493	7.196	5.788		
U (kW/sq.m/°C)	1.580	3.542	3.248	3.287	2.673	1.979		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3764	0.0863	0.1118	0.1081	0.1781	0.3093		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 28, 94 Time: 16:00 Total Operation Time: 120 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18300	18300		
Specific Heat (kJ/kg/°C)	3.960	3.924	3.912	3.901	3.968	3.965		
Inlet Temp. (deg. C)	88	62.4	50.2	38.3	32.5	28		
Outlet Temp. (deg. C)	112	75.3	62.4	50.2	37	32.5		
Temp. Rise (deg. C)	24	12.9	12.2	11.9	4.5	4.5		
Flashing Temp. (deg. C)	124	83.3	71.1	58.4	42	36.8		
Heat Transfer Rate (kJ/s)	171.620	91.408	86.168	83.808	90.764	90.704		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	21.846	13.433	13.920	13.273	7.011	6.284		
U (kW/sq.m/°C)	1.681	3.513	3.196	3.260	2.612	2.913		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3383	0.0886	0.1168	0.1107	0.1867	0.1472		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 29, 94

Time: 20:00

Total Operation Time: 124 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18400	18400		
Specific Heat (kJ/kg/°C)	3.938	3.924	3.911	3.900	3.968	3.965		
Inlet Temp. (deg. C)	88	62	49.6	37.5	32	28.5		
Outlet Temp. (deg. C)	112	75	62	49.6	37	32		
Temp. Rise (deg. C)	24	13	12.4	12.1	5	3.5		
Flashing Temp. (deg. C)	124	82.5	70.5	57.8	41.5	36.4		
Heat Transfer Rate (kJ/s)	171.620	92.108	87.570	85.203	101.396	70.933		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	21.846	12.929	13.783	13.348	6.692	5.980		
U (kW/sq.m/°C)	1.681	3.678	3.280	3.295	3.058	2.393		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3383	0.0758	0.1088	0.1074	0.1310	0.2217		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 30, 94 Time: 00:00 Total Operation Time: 128 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6400	6400	6400	6400	18400	18400		
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.968	3.965		
Inlet Temp. (deg. C)	88	62.4	49.7	37.5	32.1	28.5		
Outlet Temp. (deg. C)	112	75.6	62.4	49.7	37	32.1		
Temp. Rise (deg. C)	24	13.2	12.7	12.2	4.9	3.6		
Flashing Temp. (deg. C)	125	82.4	70.7	57.8	41.4	36.3		
Heat Transfer Rate (kJ/s)	168.980	86.826	88.314	84.587	99.368	72.960		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	22.945	10.283	13.681	13.279	6.547	5.815		
U (kW/sq.m/°C)	1.576	4.359	3.332	3.289	3.063	2.532		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3780	0.0779	0.1040	0.1080	0.1304	0.1989		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2	Date: October 30, 94	Time: 04:00	Total Operation Time: 132 hr.			
Variables	Brine Heater		Evaporator Stages			
	# 1	# 2	# 3	# 4	# 5	# 6
Flowrate (kg/h)	6400	6400	6400	6400	18400	18400
Specific Heat (kJ/kg/K)	3.938	3.924	3.911	3.900	3.968	3.965
Inlet Temp. (deg. C)	74.8	61.9	49.4	37.4	32.2	28
Outlet Temp. (deg. C)	87	74.8	61.9	49.4	36.5	32.2
Temp. Rise (deg. C)	12.2	12.9	12.5	12	4.3	4.2
Flashing Temp. (deg. C)	92.2	81.5	70	57.6	41.6	36.6
Heat Transfer Rate (kJ/s)	85.403	89.989	86.915	83.196	87.198	85.118
Heat Transfer Area (Sq.m)	1.937	1.937	1.937	1.937	4.9556	4.9556
L.M.T.D. (deg. K)	10.101	12.018	13.392	13.310	7.032	6.267
U (kW/sq.m/K)	4.365	3.866	3.351	3.227	2.502	2.741
Clean-U Value (kW/sq.m/K)	6.6	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.0776	0.0626	0.1024	0.1138	0.2036	0.1688

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 30, 94 Time: 03:00 Total Operation Time: 136 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6400	6400	6400	6400	18400	18400			
Specific Heat (kJ/kg/°C)	3.939	3.924	3.911	3.900	3.968	3.966			
Inlet Temp. (deg. C)	75.4	62.3	49.7	37.3	32	30			
Outlet Temp. (deg. C)	88	75.4	62.3	49.7	37	32			
Temp. Rise (deg. C)	12.6	13.1	12.6	12.4	5	2			
Flashing Temp. (deg. C)	93.2	82.8	71	58	41.4	36.2			
Heat Transfer Rate (kJ/s)	168.980	91.397	87.618	85.971	101.396	40.537			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	24.035	12.856	14.072	13.569	6.587	5.135			
U (kW/sq.m/°C)	1.505	3.670	3.214	3.271	3.106	1.593			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.4082	0.0764	0.1150	0.1086	0.1258	0.4317			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 30, 94

Time: 20:00

Total Operation Time: 148 hr.

Variables	Brine Heater	Evaporator Stages					
		# 1	# 2	# 3	# 4	# 5	# 6
Flowrate (kg/h)	6400	6400	6400	6400	6400	18000	18000
Specific Heat (kJ/kg/°C)	3.961	3.940	3.926	3.912	3.900	3.967	3.965
Inlet Temp. (deg. C)	89.5	77.2	63.6	50.4	37.5	32.1	28.5
Outlet Temp. (deg. C)	112	89.5	77.2	63.6	50.4	36	32.1
Temp. Rise (deg. C)	22.5	12.3	13.6	13.2	12.9	3.9	3.6
Flashing Temp. (deg. C)	114	93.8	82.7	69.9	56.7	41.2	36.4
Heat Transfer Rate (kJ/s)	158.456	86.164	94.925	91.813	89.447	77.364	71.374
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	1.937	4.9556	4.9556
L.M.T.D. (deg. K)	8.980	9.106	10.924	11.683	11.576	6.969	5.919
U (kW/sq.m/°C)	3.777	4.885	4.486	4.057	3.989	2.240	2.433
Clean-U Value (kW/sq.m/°C)	3.9	6.6	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.0084	0.0532	0.0268	0.0504	0.0546	0.2503	0.2149

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 31, 94 Time: 00:00 Total Operation Time: 192 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6400	6400	6400	6400	18000	18000		
Specific Heat (kJ/kg/°C)	3.961	3.926	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	89	63.6	50.2	37.3	31.9	28.5		
Outlet Temp. (deg. C)	112	77.2	63.6	50.2	36	31.9		
Temp. Rise (deg. C)	23	13.6	13.4	12.9	4.1	3.4		
Flashing Temp. (deg. C)	114	82.7	70	56.6	41	36.1		
Heat Transfer Rate (kJ/s)	161.965	94.925	93.201	89.443	81.330	67.408		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	9.106	10.924	11.865	11.687	6.847	5.733		
U (kW/sq.m/°C)	3.807	4.486	4.055	3.951	2.397	2.373		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.0063	0.0268	0.0505	0.0570	0.2211	0.2254		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 31, 94 Time: 04:00 Total Operation Time: 156 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6400	6400	6400	6400	18000	18000		
Specific Heat (kJ/kg/°C)	3.940	3.926	3.912	3.900	3.967	3.965		
Inlet Temp. (deg. C)	77.1	63.5	50.1	37.2	31.8	28.5		
Outlet Temp. (deg. C)	89	77.1	63.5	50.1	36	31.8		
Temp. Rise (deg. C)	11.9	13.6	13.4	12.9	4.2	3.3		
Flashing Temp. (deg. C)	93.3	82.5	70.1	56.5	40.8	36.1		
Heat Transfer Rate (kJ/s)	161.965	94.922	93.199	89.441	83.313	65.425		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	9.106	10.810	12.087	11.687	6.681	5.794		
U (kW/sq.m/°C)	3.807	4.533	3.981	3.951	2.516	2.279		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.0063	0.0245	0.0551	0.0570	0.2013	0.2428		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 31, 94 Time: 08:00 Total Operation Time: 160 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6490	6490	6490	6490	18200	18200		18200
Specific Heat (KJ/kg/K)	3.961	3.926	3.912	3.900	3.967	3.966		3.966
Inlet Temp. (deg. C)	89	63.7	50.3	37.4	31.9	30		30
Outlet Temp. (deg. C)	112	77.1	63.7	50.3	36.5	31.9		31.9
Temp. Rise (deg. C)	23	13.4	13.4	12.9	4.6	1.9		1.9
Flashing Temp. (deg. C)	115.5	82.7	70.2	56.8	41	36.3		36.3
Heat Transfer Rate (KJ/s)	164.242	94.844	94.514	90.703	92.266	38.092		38.092
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		4.9556
L.M.T.D. (deg. K)	11.361	10.969	11.976	11.797	6.532	5.293		5.293
U (kW/sq.m/K)	3.094	4.464	4.074	3.969	2.850	1.452		1.452
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1		5.1
f (sq.m K/kW)	0.0668	0.0279	0.0494	0.0559	0.1548	0.4926		0.4926

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: October 31, 94

Time: 12:00

Total Operation Time: 164 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 6	# 6
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200	18200	18200
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.968	3.968	3.968
Inlet Temp. (deg. C)	89.5	64.1	51	38.4	32.2	32.2	30	30
Outlet Temp. (deg. C)	112	77.3	64.1	51	36.5	36.5	32.2	32.2
Temp. Rise (deg. C)	22.5	13.2	13.1	12.6	4.3	4.3	2.2	2.2
Flashing Temp. (deg. C)	116.5	83.7	71	57.7	41.6	41.6	37	37
Heat Transfer Rate (kJ/s)	160.932	93.580	92.553	88.747	86.250	86.250	44.107	44.107
Heat Transfer Area (sq. m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	4.9556
L.M.T.D. (deg. C)	12.557	11.794	12.310	11.909	7.032	7.032	5.831	5.831
U (kW/sq.m/°C)	2.743	4.096	3.882	3.847	2.475	2.475	1.526	1.526
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	5.1
f (sq. m K/kW)	0.1082	0.0480	0.0615	0.0639	0.2080	0.2080	0.4591	0.4591

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 31, 94 Time: 16:00 Total Operation Time: 168 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000		
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.965		
Inlet Temp. (deg. C)	89.5	63.9	50.9	38.2	32.3	29		
Outlet Temp. (deg. C)	112	77.2	63.9	50.9	37	32.3		
Temp. Rise (deg. C)	22.5	13.3	13	12.7	4.7	3.3		
Flashing Temp. (deg. C)	116	83.1	70.7	57.5	41.6	37		
Heat Transfer Rate (kJ/s)	160.932	94.285	91.843	89.448	93.242	65.429		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	11.899	11.272	12.164	11.836	6.677	6.204		
U (kW/sq.m/°C)	2.895	4.318	3.898	3.902	2.818	2.128		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.0891	0.0355	0.0605	0.0602	0.1588	0.2738		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: October 31, 94 Time: 20:00 Total Operation Time: 172 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000		
Specific Heat (kJ/kg.°C)	3.961	3.926	3.913	3.901	3.967	3.965		
Inlet Temp. (deg. C)	89	63.7	50.6	37.8	32.2	29		
Outlet Temp. (deg. C)	112	77.1	63.7	50.6	36	32.2		
Temp. Rise (deg. C)	23	13.4	13.1	12.8	3.8	3.2		
Flashing Temp. (deg. C)	117	83	70.7	57.3	41.5	36.7		
Heat Transfer Rate (kJ/s)	164.495	94.990	92.544	90.146	75.381	63.446		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	13.351	11.307	12.419	11.982	7.234	5.957		
U (kW/sq.m/°C)	2.637	4.437	3.847	3.884	2.103	2.149		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m /kW)	0.1228	0.0345	0.0639	0.0614	0.2795	0.2692		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 01, 94 Time: 00:00 Total Operation Time: 176 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6400	6400	6400	6400	18000	18000		
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.900	3.968	3.965		
Inlet Temp. (deg. C)	89	63.8	50.5	37.7	32.2	28.5		
Outlet Temp. (deg. C)	112	77.2	63.8	50.5	36.5	32.2		
Temp. Rise (deg. C)	23	13.4	13.3	12.8	4.3	3.7		
Flashing Temp. (deg. C)	117.5	83.1	70.8	57.2	41.3	36.6		
Heat Transfer Rate (kJ/s)	161.965	93.531	92.512	88.757	85.303	73.357		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	13.980	11.307	12.492	11.982	6.722	6.063		
U (kW/sq.m/°C)	2.480	4.271	3.823	3.824	2.561	2.442		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.1469	0.0381	0.0655	0.0654	0.1945	0.2135		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 01, 94 Time: 04:00 Total Operation Time: 180 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6400	6400	6400	6400	18200	18200		
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.900	3.968	3.965		
Inlet Temp. (deg. C)	89	63.7	50.4	37.5	32	28.5		
Outlet Temp. (deg. C)	112	77.1	63.7	50.4	36.5	32		
Temp. Rise (deg. C)	23	13.4	13.3	12.9	4.5	3.5		
Flashing Temp. (deg. C)	118	83.4	70.8	57.1	41.1	36.4		
Heat Transfer Rate (kJ/s)	161.965	93.529	92.509	89.447	90.261	70.162		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	14.598	11.754	12.601	12.018	6.596	5.980		
U (kW/sq.m/°C)	2.375	4.108	3.790	3.843	2.761	2.367		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.1647	0.0473	0.0678	0.0642	0.1661	0.2263		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 01, 94 Time: 08:00 Total Operation Time: 184 hr.

Variables	Evaporator Stages					
	Brine Heater	# 1	# 2	# 3	# 4	# 5
Flowrate (kg/h)	6450	6450	6450	6450	6450	18000
Specific Heat (kJ/kg/°C)	3.961	3.940	3.926	3.913	3.901	3.966
Inlet Temp. (deg. C)	89	77.3	64.1	50.9	38.2	30
Outlet Temp. (deg. C)	112	89	77.3	64.1	50.9	32.4
Temp. Rise (deg. C)	23	11.7	13.2	13.2	12.7	2.4
Flashing Temp. (deg. C)	118.5	94.1	83.4	71	57.7	36.8
Heat Transfer Rate (kJ/s)	163.230	82.597	92.860	92.541	88.760	47.589
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	1.937	4.9556
L.M.T.D. (deg. C)	15.206	9.814	11.460	12.346	12.055	6.076
U (kW/sq.m/°C)	2.298	4.345	4.183	3.870	3.801	1.742
Clean-U Value (kW/sq.m/°C)	3.9	6.6	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.1788	0.0786	0.0430	0.0623	0.0670	0.3780

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 01, 94 Time: 12:00 Total Operation Time: 188 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200		
Specific Heat (kJ/kg/°C)	3.961	3.927	3.913	3.901	3.968	3.966		
Inlet Temp. (deg. C)	89	64.6	51.5	38.8	32.8	30		
Outlet Temp. (deg. C)	112	77.4	64.6	51.5	38	32.8		
Temp. Rise (deg. C)	23	12.8	13.1	12.7	5.2	2.8		
Flashing Temp. (deg. C)	118.5	84.3	72	58.5	42.2	37.1		
Heat Transfer Rate (kJ/s)	164.495	90.752	92.565	89.461	104.320	56.139		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	15.206	12.201	12.856	12.274	6.455	5.583		
U (kW/sq.m/°C)	2.315	3.840	3.717	3.763	3.261	2.029		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.1755	0.0643	0.0730	0.0697	0.1105	0.2968		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 01, 94 Time: 18:00 Total Operation Time: 192 hr.

Variables	Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500
Specific Heat (kJ/kg/°C)	3.940	3.927	3.914	3.902	3.968	3.966
Inlet Temp. (deg. C)	89	64.7	51.8	39.6	32.2	29.5
Outlet Temp. (deg. C)	112	77.5	64.7	51.8	37	32.2
Temp. Rise (deg. C)	23	12.8	12.9	12.2	4.8	2.7
Flashing Temp. (deg. C)	118.5	84.2	71.8	58.8	42.6	39.3
Heat Transfer Rate (kJ/s)	164.495	90.754	91.156	85.950	97.870	55.022
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556
L.M.T.D. (deg. K)	15.206	11.982	12.456	12.091	7.754	8.378
U (kW/sq.m/°C)	2.315	3.910	3.778	3.670	2.547	1.325
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.1755	0.0596	0.0686	0.0764	0.1965	0.5585

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: November 01, 94

Time: 20:00

Total Operation Time: 196 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200		
Specific Heat (kJ/kg/°C)	3.961	3.927	3.914	3.902	3.968	3.965		
Inlet Temp. (deg. C)	89	64.6	51.6	39.2	32	29		
Outlet Temp. (deg. C)	112	77.5	64.6	51.6	37	32		
Temp. Rise (deg. C)	23	11.5	13	12.4	5	3		
Flashing Temp. (deg. C)	120	94.3	71.8	58.5	42.3	38.9		
Heat Transfer Rate (kJ/s)	164.495	91.462	91.860	87.353	100.293	60.141		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	16.980	11.797	12.602	12.055	7.525	8.310		
U (kW/sq.m/°C)	2.073	4.002	3.763	3.741	2.689	1.460		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.2259	0.0538	0.0696	0.0712	0.1757	0.4887		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 3-2 Date: November 02, 94 Time: 00:00 Total Operation Time: 200 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000			
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.902	3.968	3.965			
Inlet Temp. (deg. C)	89	77.2	51.5	39.2	32.3	29			
Outlet Temp. (deg. C)	112	77.2	64.3	51.5	37	32.3			
Temp. Rise (deg. C)	23	12.9	12.8	12.3	4.7	3.3			
Flashing Temp. (deg. C)	120.5	84	71.7	58.6	42.7	38.9			
Heat Transfer Rate (kJ/s)	164.495	91.455	90.442	86.647	93.242	65.429			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. K)	17.558	12.128	12.746	12.237	7.816	8.139			
U (kW/sq.m/°C)	2.005	3.893	3.663	3.656	2.407	1.622			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.2423	0.0608	0.0769	0.0775	0.2193	0.4204			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 02, 94 Time: 04:00 Total Operation Time: 204 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000		
Specific Heat (kJ/kg/°C)	3.961	3.927	3.913	3.901	3.968	3.965		
Inlet Temp. (deg. C)	89	64.5	51.5	39	32.3	29		
Outlet Temp. (deg. C)	112	77.3	64.5	51.5	37	32.3		
Temp. Rise (deg. C)	23	11.7	13	12.5	4.7	3.3		
Flashing Temp. (deg. C)	120.5	83.7	71.9	58.6	42.6	38.5		
Heat Transfer Rate (kJ/s)	164,495	90,749	91,857	88,054	93,242	65,429		
Heat Transfer Area (sq.m)	4,6723	1,937	1,937	1,937	4,9556	4,9556		
L.M.T.D. (deg. C)	17,558	11,651	12,820	12,310	7,713	7,733		
U (kW/sq.m/°C)	2,005	4,021	3,699	3,693	2,440	1,707		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.2423	0.0526	0.0743	0.0747	0.2138	0.3696		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 02, 94 Time: 08:00 Total Operation Time: 208 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000			
Specific Heat (kJ/kg/°C)	3.961	3.927	3.914	3.902	3.968	3.966			
Inlet Temp. (deg. C)	89	64.7	51.7	39.4	32.3	31			
Outlet Temp. (deg. C)	112	77.4	64.7	51.7	38	32.3			
Temp. Rise (deg. C)	23	12.7	13	12.3	5.7	1.3			
Flashing Temp. (deg. C)	120.5	83.7	71.9	58.8	42.8	38.7			
Heat Transfer Rate (kJ/s)	164.495	90.044	91.862	86.651	113.089	25.779			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	17.558	11.505	12.602	12.237	7.282	7.030			
U (kW/sq.m/°C)	2.005	4.041	3.763	3.656	3.134	0.740			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.2423	0.0514	0.0696	0.0775	0.1230	1.1553			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 02, 94 Time: 12:00 Total Operation Time: 212 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18000	18000		
Specific Heat (kJ/kg/°C)	3.940	3.926	3.913	3.902	3.968	3.966		
Inlet Temp. (deg. C)	77	64.2	51.5	39.4	33.2	30.5		
Outlet Temp. (deg. C)	88.5	77	64.2	51.5	38	33.2		
Temp. Rise (deg. C)	11.5	12.8	12.7	12.1	4.8	2.7		
Flashing Temp. (deg. C)	94.9	83.2	72	59	43	38.3		
Heat Transfer Rate (kJ/s)	168.058	90.742	89.734	85.240	95.240	53.542		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	18.302	11.430	13.143	12.596	7.133	6.355		
U (kW/sq.m/°C)	1.965	4.099	3.525	3.494	2.694	1.700		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.2524	0.0479	0.0876	0.0902	0.1751	0.3921		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 3-2	Date: November 02, 94		Time: 16:00		Total Operation Time: 216 hr.					
Variables	Brine Heater		Evaporator Stages							
	# 1	# 2	# 3	# 4	# 5	# 6				
Flowrate (kg/h)	6500	6500	6500	6500	17500	17500	17500			
Specific Heat (kJ/kg/K)	3.961	3.926	3.913	3.901	3.968	3.966	3.966			
inlet Temp. (deg. C)	88.5	64	51.2	38.9	33.3	30	30			
Outlet Temp. (deg. C)	112	76.6	64	51.2	38	33.3	33.3			
Temp. Rise (deg. C)	23.5	12.6	12.8	12.3	4.7	3.3	3.3			
Flashing Temp. (deg. C)	121	83.1	71.9	58.8	43.1	37.6	37.6			
Heat Transfer Rate (KJ/S)	168.058	89.317	90.435	86.641	90.666	63.621	63.621			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556			
L.M.T.D. (deg. K)	18.302	11.690	13.288	12.778	7.196	5.794	5.794			
U (kW/sq.m/K)	1.965	3.945	3.514	3.500	2.542	2.216	2.216			
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.2524	0.0574	0.0885	0.0896	0.1972	0.2552	0.2552			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 02, 94 Time: 20:00 Total Operation Time: 220 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8
Flowrate (kg/h)	6500	6500	6500	6500	17200	17200		17200
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.966		3.966
Inlet Temp. (deg. C)	88.5	63.9	51.1	38.6	33.1	29		33.1
Outlet Temp. (deg. C)	112	76.8	63.9	51.1	38	33.1		4.1
Temp. Rise (deg. C)	23.5	12.9	12.8	12.5	4.9	4.1		37.3
Flashing Temp. (deg. C)	121.5	83.2	71.9	58.7	43			77.682
Heat Transfer Rate (kJ/s)	168.058	91.445	90.433	88.046	92.902	4.9556		6.019
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	2.613	2.604		5.1
L.M.T.D. (deg. C)	18.872	11.687	13.396	12.853	7.173			0.1879
U (kW/sq.m/°C)	1.906	4.040	3.485	3.537	5.1	5.1		0.0867
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		0.0909
f (sq.m K/kW)	0.2683	0.0515	0.0909	0.0867	0.1866			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 03, 94 Time: 00:00 Total Operation Time: 224 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8	# 9
Flowrate (kg/h)	6500	6500	6500	6500	17200	17200			
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.966			
Inlet Temp. (deg. C)	88.5	64.1	51.1	38.6	33.1	29			
Outlet Temp. (deg. C)	112	76.9	64.1	51.1	37.5	33.1			
Temp. Rise (deg. C)	23.5	12.8	13	12.5	4.4	4.1			
Flashing Temp. (deg. C)	121.5	83.4	71.9	58.7	43	37.2			
Heat Transfer Rate (kJ/s)	188.058	90.740	91.848	88.046	83.419	77.682			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. K)	18.872	11.761	13.254	12.853	7.486	5.915			
U (kW/sq.m/K)	1.906	3.983	3.578	3.537	2.249	2.650			
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.2683	0.0550	0.0834	0.0867	0.2486	0.1813			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 03, 94 Time: 04:00 Total Operation Time: 228 hr.

Variables	Brine Heater		Evaporator Stages			
	# 1	# 2	# 3	# 4	# 5	# 6
Flowrate (kg/h)	6500	6500	6500	6500	17200	17200
Specific Heat (kJ/kg/°C)	3.939	3.926	3.913	3.901	3.968	3.966
Inlet Temp. (deg. C)	88.2	63.8	50.8	38.3	33	29
Outlet Temp. (deg. C)	112	76.6	63.8	50.8	37.5	33
Temp. Rise (deg. C)	23.8	12.8	13	12.5	4.5	4
Flashing Temp. (deg. C)	122	83.7	71.4	58.2	42.6	36.9
Heat Transfer Rate (kJ/s)	170.195	90.732	91.841	88.040	85.314	75.787
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556
L.M.T.D. (deg. C)	19.542	12.420	13.037	12.636	7.114	5.667
U (kW/sq.m/°C)	1.864	3.772	3.637	3.597	2.420	2.699
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.2801	0.0691	0.0789	0.0819	0.2172	0.1745

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No: 5-2

Date: November 03, 94

Time: 08:00

Total Operation Time: 252 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17500	17500		
Specific Heat (kJ/kg/°C)	3.939	3.926	3.913	3.901	3.968	3.967		
Inlet Temp. (deg. C)	88	63.8	50.8	38.3	33	33		
Outlet Temp. (deg. C)	112	76.6	63.8	50.8	38	33		
Temp. Rise (deg. C)	24	12.8	13	12.5	5	0		
Flashing Temp. (deg. C)	123	83.4	71.1	58.1	42.6	36.8		
Heat Transfer Rate (kJ/s)	171.620	90.732	91.841	88.040	96.451	0.000		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	20.735	12.091	12.711	12.527	6.796	ERR		
U (kW/sq.m/°C)	1.771	3.874	3.730	3.628	2.864	ERR		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3081	0.0621	0.0720	0.0795	0.1531	ERR		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: November 03, 94

Time: 12:00

Total Operation Time: 236 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17500	17500		
Specific Heat (kJ/kg/°C)	3.939	3.926	3.913	3.901	3.968	3.966		
Inlet Temp. (deg. C)	88	64.2	51.4	39.1	33.4	30		
Outlet Temp. (deg. C)	112	76.9	64.2	51.4	38	33.4		
Temp. Rise (deg. C)	24	12.7	12.8	12.3	4.6	3.4		
Flashing Temp. (deg. C)	123	84.5	72.3	59.2	43.2	37.5		
Heat Transfer Rate (kJ/s)	171.620	90.032	90.440	86.645	88.737	65.549		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	20.735	12.927	13.504	12.994	7.259	5.630		
U (kW/sq.m/°C)	1.771	3.622	3.458	3.442	2.467	2.349		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3081	0.0820	0.0931	0.0944	0.2093	0.2295		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 03, 94 Time: 16:00 Total Operation Time: 240 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17500	17500		
Specific Heat (kJ/kg/°C)	3.939	3.926	3.913	3.901	3.968	3.966		
Inlet Temp. (deg. C)	88	63.7	50.8	38.4	33.1	29		
Outlet Temp. (deg. C)	112	76.5	63.7	50.8	38	33.1		
Temp. Rise (deg. C)	24	12.8	12.9	12.4	4.9	4.1		
Flashing Temp. (deg. C)	123.5	84.3	71.9	58.8	42.8	37.1		
Heat Transfer Rate (kJ/S)	171.620	90.730	91.134	87.336	94.522	79.037		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	21.292	13.180	13.649	13.247	6.965	5.811		
U (kW/sq.m/°C)	1.725	3.554	3.447	3.404	2.739	2.745		
Clean-U value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/KW)	0.3233	0.0853	0.0940	0.0977	0.1691	0.1683		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: November 03, 94

Time: 20:00

Total Operation Time: 244 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17500	17500		
Specific Heat (kJ/kg/K)	3.939	3.926	3.913	3.901	3.968	3.966		
Inlet Temp. (deg. C)	88	63.8	50.9	38.3	33.1	29		
Outlet Temp. (deg. C)	112	76.7	63.8	50.9	38	33.1		
Temp. Rise (deg. C)	24	12.9	12.9	12.6	4.9	4.1		
Flashing Temp. (deg. C)	124	84.4	72	58.9	43	37		
Heat Transfer Rate (kJ/s)	171.620	91.442	91.136	88.745	94.522	79.037		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	21.846	13.109	13.649	13.321	7.173	5.707		
U (kW/sq.m/K)	1.681	3.601	3.447	3.439	2.659	2.795		
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3383	0.0816	0.0940	0.0947	0.1800	0.1617		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 04, 94 Time: 00:00 Total Operation Time: 248 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17200	17200		
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.966		
Inlet Temp. (deg. C)	89	63.8	50.8	38.1	33	29		
Outlet Temp. (deg. C)	112	76.7	63.8	50.8	37.5	33		
Temp. Rise (deg. C)	23	12.9	13	12.7	4.5	4		
Flashing Temp. (deg. C)	123.5	84.3	72	58.8	42.8	36.8		
Heat Transfer Rate (kJ/s)	164.495	91.442	91.841	89.446	85.314	75.787		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	20.936	13.000	13.686	13.359	7.321	5.562		
U (kW/sq.m/°C)	1.682	3.631	3.464	3.457	2.352	2.749		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.3382	0.0793	0.0926	0.0932	0.2292	0.1676		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 04, 94 Time: 04:00 Total Operation Time: 252 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17000	17000		
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.965		
Inlet Temp. (deg. C)	89	63.4	50.7	38.6	32.8	28.5		
Outlet Temp. (deg. C)	112	76.4	63.4	50.7	37	32.8		
Temp. Rise (deg. C)	23	13	12.7	12.1	4.2	4.3		
Flashing Temp. (deg. C)	113.5	83.2	71.4	58.4	42.6	36.6		
Heat Transfer Rate (kJ/s)	164.495	92.142	89.716	85.224	78.697	80.520		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	8.234	12.164	13.359	12.812	7.505	5.681		
U (kW/sq.m/K)	4.276	3.911	3.467	3.434	2.116	2.860		
Clean-U value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	-0.0225	0.0596	0.0923	0.0951	0.2765	0.1536		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 04, 94 Time: 08:00 Total Operation Time: 256 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17100	17100		
Specific Heat (KJ/kg/K)	3.961	3.926	3.913	3.901	3.968	3.966		
Inlet Temp. (deg. C)	89	63.7	51	38.8	32.8	30		
Outlet Temp. (deg. C)	112	76.6	63.7	51	38	32.8		
Temp. Rise (deg. C)	23	12.9	12.7	12.2	5.2	2.8		
Flashing Temp. (deg. C)	113	83.4	71.5	58.7	42.7	36.6		
Heat Transfer Rate (KJ/s)	164.495	91.440	89.723	85.934	98.014	52.746		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. K)	7.237	12.128	13.143	12.849	6.980	5.072		
U (KW/sq.m/K)	4.865	3.893	3.524	3.453	2.834	2.099		
Clean-U Value (KW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/KW)	-0.0508	0.0608	0.0877	0.0935	0.1568	0.2804		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 04, 94 Time: 12:00 Total Operation Time: 260 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17100	17100		
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.902	3.968	3.966		
Inlet Temp. (deg. C)	89	64	51.5	39.4	33.1	30		
Outlet Temp. (deg. C)	112	76.7	64	51.5	38	33.1		
Temp. Rise (deg. C)	23	12.3	12.5	12.1	4.9	3.1		
Flashing Temp. (deg. C)	114	84.1	72	59.2	43.2	37.2		
Heat Transfer Rate (kJ/s)	164.495	90.027	88.319	85.240	92.362	58.398		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	9.106	12.710	13.284	12.812	7.381	5.505		
U (kW/sq.m/°C)	3.866	3.657	3.432	3.435	2.525	2.141		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.0022	0.0774	0.0953	0.0951	0.1999	0.2711		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 04, 94 Time: 16:00 Total Operation Time: 264 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	17100	17100			
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.966			
Inlet Temp. (deg. C)	88.5	63.6	51.1	39.1	33.1	29			
Outlet Temp. (deg. C)	112	76.3	63.6	51.1	38	33.1			
Temp. Rise (deg. C)	23.5	12.7	12.5	12	4.9	4.1			
Flashing Temp. (deg. C)	114	82.9	71.3	58.8	43	37.2			
Heat Transfer Rate (kJ/S)	168.058	90.017	88.310	84.529	92.362	77.231			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	9.232	11.836	12.961	12.774	7.173	5.915			
U (kW/sq.m/°C)	3.896	3.927	3.518	3.416	2.598	2.635			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.0003	0.0586	0.0882	0.0966	0.1888	0.1835			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 04, 94 Time: 20:00 Total Operation Time: 268 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17100	17100		
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.966		
Inlet Temp. (deg. C)	88.5	63.6	51	38.8	32.8	29		
Outlet Temp. (deg. C)	112	76.6	63.6	51	38	32.8		
Temp. Rise (deg. C)	23.5	13	12.6	12.2	5.2	3.8		
Flashing Temp. (deg. C)	114	82.8	71.6	58.5	42.7	36.8		
Heat Transfer Rate (kJ/s)	168.058	92.147	89.015	85.934	98.014	71.578		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	9.332	11.501	13.321	12.633	6.980	5.890		
U (kW/sq.m/°C)	3.896	4.136	3.450	3.512	2.834	2.538		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq. m K/kW)	0.0003	0.0457	0.0938	0.0887	0.1568	0.1979		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 05, 94 Time: 00:00 Total Operation Time: 272 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8	# 9
Flowrate (kg/h)	6500	6500	6500	6500	6500	6500	6500	6500	6500
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.965	3.965	3.965	3.965
Inlet Temp. (deg. C)	89	63.7	50.9	38.6	32.7	28.5	28.5	28.5	28.5
Outlet Temp. (deg. C)	112	76.6	63.7	50.9	37.5	32.7	32.7	32.7	32.7
Temp. Rise (deg. C)	23	12.9	12.8	12.3	4.8	4.2	4.2	4.2	4.2
Flashing Temp. (deg. C)	114.5	82.9	71.5	58.4	42.5	36.6	36.6	36.6	36.6
Heat Transfer Rate (kJ/s)	164.495	91.440	90.428	86.635	90.471	79.109	79.109	79.109	79.109
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	4.9556	4.9556
L.M.T.D. (deg. C)	9.904	11.576	13.180	12.670	7.133	5.746	5.746	5.746	5.746
U (kW/sq.m/°C)	3.555	4.078	3.542	3.530	2.559	2.778	2.778	2.778	2.778
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	5.1	5.1
f (sq.m k/kW)	0.0249	0.0491	0.0862	0.0872	0.1946	0.1639	0.1639	0.1639	0.1639

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2		Date: November 05, 94	Time: 04:00	Total Operation Time: 276 hr.					
Variables	Brine Heater		Evaporator Stages						
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	17100	17100	17100		
Specific Heat (kJ/kg/K)	3.939	3.926	3.913	3.901	3.968	3.965	3.965		
Inlet Temp. (deg. C)	76.5	63.6	50.8	38.5	32.6	28.5	28.5		
Outlet Temp. (deg. C)	88.5	76.5	63.6	50.8	37.5	32.6	32.6		
Temp. Rise (deg. C)	12	12.9	12.8	12.3	4.9	4.1	4.1		
Flashing Temp. (deg. C)	93.5	82.8	71.2	58.2	42.4	36.5	36.5		
Heat Transfer Rate (kJ/s)	85.355	91.437	90.426	86.633	92.355	77.225	77.225		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556		
L.M.T.D. (deg. K)	10.035	11.576	12.964	12.562	7.069	5.707	5.707		
U (kW/sq.m/K)	4.494	4.078	3.601	3.560	2.636	2.731	2.731		
Clean-U Value (kW/sq.m/K)	6.6	5.1	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.0710	0.0491	0.0816	0.0848	0.1832	0.1701	0.1701		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2	Date: November 05, 94	Time: 08:00	Total Operation Time: 280 hr.					
Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 6	
Flowrate (kg/h)	6500	6500	6500	6500	18200	18200	18200	
Specific Heat (kJ/kg/°C)	3.961	3.926	3.913	3.901	3.968	3.968	3.966	
Inlet Temp. (deg. C)	88.5	76.3	51	38.7	32.8	32.8	29.5	
Outlet Temp. (deg. C)	112	76.3	63.6	51	37.5	37.5	32.8	
Temp. Rise (deg. C)	23.5	12.7	12.6	12.3	4.7	4.7	3.3	
Flashing Temp. (deg. C)	114	82.3	71.2	58.1	42.6	42.6	36.8	
Heat Transfer Rate (kJ/s)	168.058	90.017	89.015	86.637	94.285	94.285	66.161	
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	
L.M.T.D. (deg. C)	9.232	11.172	12.890	12.237	7.196	7.196	5.486	
U (kW/sq.m/°C)	3.896	4.160	3.565	3.655	2.644	2.644	2.434	
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	
f (sq.m K/kW)	0.0003	0.0443	0.0844	0.0775	0.1821	0.1821	0.2148	

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: November 06, 94

Time: 20:00

Total Operation Time: 316 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17100	17100		
Specific Heat (kJ/kg/°C)	3.960	3.925	3.912	3.900	3.968	3.966		
Inlet Temp. (deg. C)	88	63.3	50.4	37.7	32.7	29		
Outlet Temp. (deg. C)	112	76.2	63.3	50.4	38	32.7		
Temp. Rise (deg. C)	24	11.8	12.9	12.7	5.3	3.7		
Flashing Temp. (deg. C)	117	93.6	71.6	58.3	42.4	36.1		
Heat Transfer Rate (kJ/s)	171.620	83.923	91.125	89.438	99.899	69.694		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	13.653	12.347	13.756	13.251	6.704	5.025		
U (kW/sq.m/°C)	2.690	4.163	3.420	3.485	3.007	2.799		
Clean-U value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.1153	0.0655	0.0963	0.0909	0.1365	0.1612		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2 Date: November 07, 94 Time: 00:00 Total Operation Time: 320 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17100	17100		17100
Specific Heat (KJ/kg/K)	3.960	3.925	3.912	3.900	3.968	3.965		3.965
Inlet Temp. (deg. C)	88	63.3	50.3	37.7	32.7	28		28
Outlet Temp. (deg. C)	112	76.2	63.3	50.3	38	32.7		32.7
Temp. Rise (deg. C)	24	12.9	13	12.6	5.3	4.7		4.7
Flashing Temp. (deg. C)	117	83.2	71.4	58.1	42.4	36.1		36.1
Heat Transfer Rate (KJ/S)	171.620	91.430	91.830	88.733	99.899	88.524		88.524
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		4.9556
L.M.T.D. (deg. K)	13.653	12.347	13.578	13.106	6.704	5.414		5.414
U (KW/Sq.m/K)	2.690	3.823	3.491	3.495	3.007	3.299		3.299
Clean-U Value (KW/Sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1		5.1
f (sq.m K/KW)	0.1153	0.0655	0.0903	0.0900	0.1365	0.1070		0.1070

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 5-2

Date: November 07, 94


Time: 04:00

Total Operation Time: 324 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	17200	17200		
Specific Heat (kJ/kg/°C)	3.939	3.925	3.912	3.900	3.968	3.965		
Inlet Temp. (deg. C)	76.2	63.3	50.2	37.7	32.4	28		
Outlet Temp. (deg. C)	88	76.2	63.3	50.2	38	32.4		
Temp. Rise (deg. C)	11.8	12.9	13.1	12.5	5.6	4.4		
Flashing Temp. (deg. C)	94.5	83.7	71.7	58.4	42.3	35.9		
Heat Transfer Rate (kJ/s)	83.923	91.430	92.535	88.028	106.168	83.356		
Heat Transfer Area (sq.m)	171.620	4.6723	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	14.289	12.892	13.939	13.499	6.715	5.405		
U (kW/sq.m/°C)	2.571	3.661	3.427	3.367	3.190	3.112		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m K/kW)	0.1326	0.0770	0.0957	0.1010	0.1174	0.1252		

Appendix 5.3.3-7

Calculation of Overall Heat Transfer
Coefficient(U) and Fouling Factor(f) in Run 8



OPERATION CONDITION FOR RUN 8

1. Operation Period	16th Nov. to 6th Dec.
2. Operation Time	472 h
3. Scale Control Method	PPN(M) Dosing
4. Operation Mode	Recirculation
5. Ball Cleaning	at FF in BH of $0.34-0.36 \text{ m}^2 \text{ K/kW}$
6. Top Brine Temperature	112°C
7. Flow Rate	
-Make Up Seawater	2.42 m^3/h
-Recirculation	6.5 m^3/h
-Product Water	0.9 m^3/h
-Blow Brine	1.52 m^3/h
8. Chemical Constituents of Brine	
-pH at 25°C	8.52
-M-Alkalinity as CaCO_3	180 mg/L
-Chloride ion	33,100 mg/L
-Concentration factor as Cl^-	1.40
9. Dosing Rate of Chemicals	
-Scale Inhibitor = PPN(M)	2 mg/L
-Acid = 98% H_2SO_4	--

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8

Date: November 16, 94

Time: 20:00

Total Operation Time: 8 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8	# 9
Flowrate (kg/h)	6500	6500	6500	6500	6500	18500	18500	18500	18500
Specific Heat (kJ/kg.K)	3.962	3.962	3.962	3.962	3.962	3.966	3.966	3.966	3.964
Inlet Temp. (deg. C)	89.8	62	48.2	35	30.2	26.5	26.5	26.5	26.5
Outlet Temp. (deg. C)	112	76.1	62	48.2	34.5	30.2	30.2	30.2	30.2
Temp. Rise (deg. C)	22.2	14.1	13.8	13.2	4.3	3.7	3.7	3.7	3.7
Flashing Temp. (deg. C)	114.5	80.8	67.6	54.1	39.1	33.4	33.4	33.4	33.4
Heat Transfer Rate (kJ/s)	158.794	99.916	97.440	92.908	87.646	75.374	75.374	75.374	75.374
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	4.9556	4.9556
L.M.T.D. (deg. K)	9.692	10.171	11.107	11.257	6.515	4.815	4.815	4.815	4.815
U (kW/sq.m/K)	3.507	5.072	4.529	4.269	2.715	3.159	3.159	3.159	3.159
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.0288	0.0011	0.0247	0.0582	0.1723	0.1205	0.1205	0.1205	0.1205

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8	Date: November 17, 94	Time: 00:00	Total Operation Time: 12 hr.					
Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500	18500	
Specific Heat (kJ/kg/°C)	3.962	3.925	3.911	3.898	3.966	3.964	3.964	
Inlet Temp. (deg. C)	89.9	62	48.1	34.8	30	26	26	
Outlet Temp. (deg. C)	112	76.1	62	48.1	34	30	30	
Temp. Rise (deg. C)	22.1	14.1	13.9	13.3	4	4	4	
Flashing Temp. (deg. C)	114.5	80.9	67.7	54.1	38.9	33.3	33.3	
Heat Transfer Rate (kJ/s)	158.081	99.916	98.145	93.609	81.527	81.481	81.481	
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	
L.M.T.D. (deg. C)	9.666	10.288	11.254	11.384	6.702	5.038	5.038	
U (kW/sq.m/°C)	3.500	5.014	4.502	4.245	2.455	3.264	3.264	
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	
f (sq.m K/kW)	0.0293	0.0034	0.0260	0.0395	0.2113	0.1103	0.1103	

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 3

Date: November 17, 94

Time: 04:00

Total Operation Time: 16 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500		
Specific Heat (kJ/kg/°C)	3.940	3.925	3.911	3.898	3.966	3.964		
Inlet Temp. (deg. C)	76.2	62.1	48.1	35	29.9	26		
Outlet Temp. (deg. C)	89.8	76.2	62.1	48.1	34	29.9		
Temp. Rise (deg. C)	13.6	14.1	14	13.1	4.1	3.9		
Flashing Temp. (deg. C)	92.3	80.8	67.6	54.3	38.9	33.3		
Heat Transfer Rate (kJ/s)	158.794	99.919	98.852	92.203	83.565	79.444		
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		
L.M.T.D. (deg. C)	8.904	10.054	11.061	11.536	6.744	5.104		
U (kW/sq.m/°C)	3.817	5.131	4.614	4.126	2.501	3.141		
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1		
f (sq.m k/kw)	0.0056	-0.0012	0.0207	0.0463	0.2038	0.1223		

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8

Date: November 17, 94

Time: 08:00

Total Operation Time: 20 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.940	3.925	3.911	3.898	3.967	3.964			
Inlet Temp. (deg. C)	89.8	62.2	48.3	35.1	30.2	27			
Outlet Temp. (deg. C)	112	76.2	62.2	48.3	35	30.2			
Temp. Rise (deg. C)	22.2	14	13.9	13.2	4.8	3.2			
Flashing Temp. (deg. C)	115	80.9	67.7	54.4	39.1	33.4			
Heat Transfer Rate (kJ/s)	158.794	99.212	98.150	92.910	97.841	65.190			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	10.431	10.138	11.027	11.460	6.193	4.617			
U (kW/sq.m/°C)	3.258	5.052	4.595	4.185	3.188	2.849			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m /kW)	0.0505	0.0019	0.0215	0.0428	0.1176	0.1549			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8 Date: November 17, 94 Time: 12:00 Total Operation Time: 24 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.962	3.925	3.911	3.899	3.967	3.964			
Inlet Temp. (deg. C)	89.8	62.2	48.5	35.6	30.4	27.5			
Outlet Temp. (deg. C)	112	76.2	62.2	48.5	35	30.4			
Temp. Rise (deg. C)	22.2	14	13.7	12.9	4.6	2.9			
Flashing Temp. (deg. C)	115	80.7	67.6	54.5	39.4	33.8			
Heat Transfer Rate (kJ/s)	158.794	99.212	96.740	90.806	93.766	59.082			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
LM.T.D. (deg. C)	10.431	9.903	10.845	11.243	6.428	4.702			
U (kW/sq.m/°C)	3.258	5.172	4.605	4.170	2.944	2.536			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.0505	-0.0027	0.0211	0.0437	0.1436	0.1983			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8 Date: November 17, 84 Time: 16:00 Total Operation Time: 28 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.962	3.924	3.910	3.898	3.966	3.964			
Inlet Temp. (deg. C)	89.8	61.6	48	34.8	30.1	26			
Outlet Temp. (deg. C)	112	75.5	61.6	48	33.5	30.1			
Temp. Rise (deg. C)	22.2	13.9	13.6	13.2	3.4	4.1			
Flashing Temp. (deg. C)	115.5	80.7	67.6	54.3	39.1	33.4			
Heat Transfer Rate (kJ/s)	158.794	98.486	96.021	92.904	69.296	83.519			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. K)	11.135	10.684	11.489	11.683	7.166	5.077			
U (kW/sq.m/K)	3.052	4.759	4.315	4.105	1.951	3.320			
Clean-U Value (kW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.0712	0.0140	0.0357	0.0475	0.3164	0.1052			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8 Date: November 17, 94 Time: 20:00 Total Operation Time: 32 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.961	3.924	3.910	3.898	3.966	3.964			
Inlet Temp. (deg. C)	89.5	61.5	47.7	34.4	29.6	25.5			
Outlet Temp. (deg. C)	112	75.5	61.5	47.7	33	29.6			
Temp. Rise (deg. C)	22.5	14	13.8	13.3	3.4	4.1			
Flashing Temp. (deg. C)	115.8	81.2	67.7	54.2	38.8	33			
Heat Transfer Rate (kJ/s)	160.932	99.193	97.428	93.600	69.291	83.513			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	11.631	11.289	11.783	11.940	7.370	5.182			
U (kW/sq.m/°C)	2.962	4.536	4.269	4.047	1.897	3.252			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq. m K/kW)	0.0813	0.0244	0.0382	0.0510	0.3310	0.1114			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 3 Date: November 18, 94 Time: 00:00 Total Operation Time: 36 hr.

Variables	Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500
Specific Heat (kJ/kg/°C)	3.939	3.924	3.910	3.898	3.966	3.964
Inlet Temp. (deg. C)	75.5	61.5	47.6	34.4	29.4	25.5
Outlet Temp. (deg. C)	89.5	75.5	61.5	47.6	33	29.4
Temp. Rise (deg. C)	14	14	13.9	13.2	3.6	3.9
Flashing Temp. (deg. C)	92.5	81.3	67.8	54.1	38.7	32.8
Heat Transfer Rate (kJ/s)	99.581	99.193	98.133	92.895	73.366	79.438
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556
L.M.T.D. (deg. C)	11.899	11.402	11.930	11.905	7.354	5.104
U (kW/sq.m/°C)	2.895	4.491	4.247	4.029	2.013	3.141
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1
f (sq.m K/kW)	0.0891	0.0266	0.0394	0.0521	0.3006	0.1223

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8 Date: November 18, 94 Time: 04:00 Total Operation Time: 40 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.939	3.924	3.910	3.898	3.966	3.964			
Inlet Temp. (deg. C)	75.4	61.3	47.4	34.2	29.2	25.5			
Outlet Temp. (deg. C)	89.5	75.4	61.3	47.4	33	29.2			
Temp. Rise (deg. C)	14.1	14.1	13.9	13.2	3.8	3.7			
Flashing Temp. (deg. C)	92.3	81.2	67.7	54	38.5	32.7			
Heat Transfer Rate (kJ/s)	160.932	99.897	98.128	92.891	77.441	75.363			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	11.899	11.437	12.042	12.015	7.234	5.129			
U (kW/sq.m/°C)	2.895	4.509	4.207	3.991	2.160	2.965			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.0891	0.0257	0.0416	0.0545	0.2669	0.1412			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 3 Date: November 18, 94 Time: 08:00 Total Operation Time: 44 hr.

Variables	Brine Heater		Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6		
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500		18500
Specific Heat (KJ/kg/K)	3.961	3.924	3.910	3.898	3.966	3.964		3.964
Inlet Temp. (deg. C)	89.5	61.7	47.7	34.4	29	26		26
Outlet Temp. (deg. C)	112	75.9	61.7	47.7	33.5	29		29
Temp. Rise (deg. C)	22.5	14.2	14	13.3	4.5	3		3
Flashing Temp. (deg. C)	116	81.4	68	54.2	38.6	32.4		32.4
Heat Transfer Rate (KJ/S)	160.932	100.618	98.842	93.600	91.708	61.107		61.107
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556		4.9556
L.M.T.D. (deg. K)	11.899	11.130	11.965	11.940	7.114	4.743		4.743
U (KW/Sq.m/K)	2.895	4.667	4.265	4.047	2.601	2.600		2.600
Clean-U Value (KW/Sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1		5.1
f (sq.m K/KW)	0.0891	0.0182	0.0384	0.0510	0.1884	0.1886		0.1886

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8

Date: November 18, 94

Time: 12:00

Total Operation Time: 48 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.961	3.924	3.910	3.898	3.966	3.964			
Inlet Temp. (deg. C)	89.5	61.5	47.8	34.5	29.2	25.5			
Outlet Temp. (deg. C)	112	75.8	61.5	47.8	33	29.2			
Temp. Rise (deg. C)	22.5	14.3	13.7	13.3	3.8	3.7			
Flashing Temp. (deg. C)	116.5	81.4	68	54.3	38.7	32.7			
Heat Transfer Rate (kJ/s)	160.932	101.323	96.723	93.602	77.441	75.363			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	12.557	11.278	12.082	11.940	7.439	5.129			
U (kW/sq.m/°C)	2.743	4.638	4.133	4.047	2.101	2.965			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.1082	0.0195	0.0459	0.0510	0.2800	0.1412			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8 Date: November 18, 94 Time: 10:00 Total Operation Time: 52 hr.

Variables	Brine Heater			Evaporator Stages					
	#1	#2	#3	#4	#5	#6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.962	3.962	3.962	3.962	3.965	3.963			
Inlet Temp. (deg. C)	89.8	61.2	47.3	34	28.8	25			
Outlet Temp. (deg. C)	112	75.5	61.2	47.3	32.5	28.8			
Temp. Rise (deg. C)	22.2	14.3	13.9	13.3	3.7	3.8			
Flashing Temp. (deg. C)	116.5	81.2	67.6	54	38.4	32.3			
Heat Transfer Rate (kJ/s)	158.794	101.314	98.125	93.592	75.398	77.396			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	12.468	11.392	12.042	12.161	7.600	5.169			
U (kW/sq.m/°C)	2.726	4.591	4.207	3.973	2.002	3.021			
Clean-U value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/kW)	0.1104	0.0217	0.0416	0.0556	0.3035	0.1349			

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8 Date: November 18, 94 Time: 20:00 Total Operation Time: 56 hr.

Variables	Brine Heater					Evaporator Stages				
	# 1	# 2	# 3	# 4	# 5	# 6	# 1	# 2	# 3	# 4
Flowrate (kg/h)	6500	6500	6500	6500	6500	18500	18500	18500	18500	18500
Specific Heat (KJ/kg/K)	3.961	3.924	3.910	3.897	3.865	3.963	3.963	3.963	3.963	3.963
Inlet Temp. (deg. C)	89.5	61	46.9	33.6	28.3	24	24	24	24	24
Outlet Temp. (deg. C)	112	75.4	61	46.9	32	28.3	28.3	28.3	28.3	28.3
Temp. Rise (deg. C)	22.5	14.4	14.1	13.3	3.7	4.3	4.3	4.3	4.3	4.3
Flashing Temp. (deg. C)	116	81.1	67.4	53.6	37.9	31.7	31.7	31.7	31.7	31.7
Heat Transfer Rate (KJ/S)	160.932	102.019	99.530	93.584	75.393	87.570	87.570	87.570	87.570	87.570
Heat Transfer Area (Sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556	4.9556	4.9556	4.9556	4.9556
L.M.T.D. (deg. K)	11.899	11.426	12.112	12.161	7.600	5.260	5.260	5.260	5.260	5.260
U (KW/sq.m/K)	2.895	4.609	4.242	3.973	2.002	3.359	3.359	3.359	3.359	3.359
Clean-U Value (KW/sq.m/K)	3.9	5.1	5.1	5.1	5.1	5.1	5.1	5.1	5.1	5.1
f (sq.m K/KW)	0.0891	0.0209	0.0396	0.0556	0.3035	0.1016	0.1016	0.1016	0.1016	0.1016

CALCULATIONS OF OVERALL HEAT TRANSFER COEFFICIENT AND FOULING FACTOR

Run No. 8 Date: November 19, 94 Time: 00:00 Total Operation Time: 60 hr.

Variables	Brine Heater			Evaporator Stages					
	# 1	# 2	# 3	# 4	# 5	# 6			
Flowrate (kg/h)	6500	6500	6500	6500	18500	18500			
Specific Heat (kJ/kg/°C)	3.939	3.924	3.910	3.897	3.965	3.965			
Inlet Temp. (deg. C)	75.4	61	46.9	33.6	28.2	24			
Outlet Temp. (deg. C)	89	75.4	61	46.9	32.5	28.2			
Temp. Rise (deg. C)	13.6	14.4	14.1	13.3	4.3	4.2			
Flashing Temp. (deg. C)	92	80.8	67.1	53.5	37.7	31.7			
Heat Transfer Rate (kW)	96.727	102.019	99.530	93.584	87.621	85.533			
Heat Transfer Area (sq.m)	4.6723	1.937	1.937	1.937	4.9556	4.9556			
L.M.T.D. (deg. C)	13.351	11.083	11.776	12.051	7.135	5.327			
U (kW/sq.m/°C)	2.637	4.752	4.364	4.009	2.478	3.240			
Clean-U Value (kW/sq.m/°C)	3.9	5.1	5.1	5.1	5.1	5.1			
f (sq.m K/KW)	0.0077	0.0144	0.0331	0.0534	0.2075	0.1125			