


[Appendix 3.8-2] Comparative Study of Facilities

[Appendix 3.8-2-1] Selection of Biological Treatment Process


a) Feature of Treatment Process

Alternative treatment processes can be summarized as follows.



i. Lagoon

In hot climate countries the stabilization lagoon is commonly applied taking advantages of high temperature as well as the attraction of low cost and simple operational needs. However, this process requires quite a wide land space which is not available in the vicinity of the Project Area.




Flow Sheet of Stabilization Pond Process

ii. Conventional Activated Sludge Process (CASP)

The conventional activated sludge process has a long history of experienced and proved to be appropriate for wastewater plants with capacities similar to the one considered here. However, the requirement of rather high level technique for operation and maintenance which is a vital factor that makes the process inappropriate in the lack of experienced and trained necessary manpower. In case of industrial wastewater plants, a considerable high engineering technique is essentially needed and unavoidable.


The CASP is more compactly installed than other alternatives. Thus the CASP will be suitably allocated in the available limited space proposed on the Project Area.



Flow Sheet of CASP

iii. Oxidation Ditch Process

The oxidation ditch process has originally been developed for applying to small size plants. The oxidation ditch is a long continuous channel usually oval in plan and 1.0 - 3.0 m in depth. The wastewater in the ditch is aerated by one or more brush or rotors placed across the channel. Theoretically if the number of ditches is increased the capacity of the plant become larger in proportion. In Japan, the maximum capacity of a single ditch is about 5,000 m³/day.



Flow Sheet of Oxidation Ditch Process

iv. Other Alternatives

Other remaining alternatives seem to be infeasible for the considered treatment plant, since some are suitable only for small size plants and others are too costly. The trickling filter is likely to cause a higher level of odor released from the biofilters. On top of that the microbial film in biofilters becomes a breeding ground of various flies and midges, which can cause severe nuisance especially in hot climates.

b) Comparative Study of Biological Treatment Processes

i. A General Comparison Between Alternatives

Alternative treatment processes are compared on the basis of capital costs, operation and maintenance costs, and required areas. The results of these comparisons are as follows.

• Cost Comparison




Figure 1 Normalized Capital Costs of Alternative Processes




Figure 2 Normalized O & M Costs of Alternative Processes

- Comparison of Required Area




Figure 3 Normalized Area Required for Alternative Processes

ii. Conventional Activated Sludge Process (CASP) Versus Oxidation Ditch Process

Through comparative studies and discussions previously mentioned, the conventional activated sludge process and the oxidation ditch process are considered to be the most suitable for this area. More detailed comparison between these processes is shown in Table 1 and Figure 4. The comparison shows that the conventional activated sludge process (CASP) is most feasible. However, it has to be mentioned that in case of the CASP, the preparation for operation and maintenance of the plant should include a training program for the concerned manpowers.

Table 1 Conventional Activated Sludge Versus Oxidation Ditch

Item	CAS	OD
BOD removal efficiency (%)	80 - 95	80 - 90
Plant Capacity	Economically beneficial for large scale (>20,000 m ³ /d) plant rather than small	Practices for small scale plant (<20,000 m ³ /d) are many, for large scale few
Costs	Capital	100 %
	O & M (30 years)	160 %
Area for treatment plant site	350 m * 150 m = 5.25 ha	400 m * 270 m = 10.8 ha
Additional Works to secure land	-	Relocation of the existing water pipe or the oil pipe
Overall appraisal	⊙	×




Figure 4 Flow Diagram of Industrial Wastewater Treatment Plant

Legend
 N.T. : Neutralization Tank
 P.S. : Primary Sedimentation Tank
 F.S. : Final Sedimentation Tank

c) Conclusion

As the result of comparative study of the above several treatment processes, conventional activated sludge process was selected from view points of economy, required area, and well experienced with similar capacities wastewater treatment plants.

[Appendix 3.8-2-2] Selection of Aeration Method

Method of aeration shall be decided after studies about its cost saving, energy-saving and easiness of maintenance.

C-1

Method of Aeration	Features	Cost-saving	Energy-saving	Maintenance
Circulation aeration by blower, (Air-Blowing Type)	<ul style="list-style-type: none"> This method is popular for standard activated sludge system. This is applicable for rectangular tank of 5 m depth. Big bubble diffusers and fine bubble diffusers can be used. 	Lower price	Low consumption of energy	Low cost maintenance
Total area aeration by blower (Nozzle-jet Type)	<ul style="list-style-type: none"> Recently this system has been developed in combination with Ultra fine bubble diffusers in view of energy saving. This system is very effective on O₂ dispersion and O₂ transfer in the tank and of energy saving type, but this requires an additional facilities to prevent clogging. 	Initial cost is rather high	Lowest consumption of energy	Prevention of clogging is required
Mechanical surface aeration	<ul style="list-style-type: none"> This system is to aerate surface of water mechanically. It is said that this is of energy saving type, but it is constrained by depth of water, structure of pond, numbers of pond, numbers of machines, adjustment of air supply, environmental conditions (generation of noise scattering of water, corrosion of machine, water temp. and ambient temp.) life of machine and maintenance. 	Short life span of machine due to corrosion	Average	<ul style="list-style-type: none"> Low maintenance cost Turbulent flow break flocs

* Conclusion : Circulation aeration system shall be chosen for the Suez waste water treatment plant judging from the tables of C-1 and C-2 and fine bubble type shall be chosen for diffusers.

C-2 Compression Table on Aerators

(1) Table for various aerators


Aerator	Features of Equipment	Merit	Demerit	Application
Big bubble type	<ul style="list-style-type: none"> Bubbles generated are big 	<ul style="list-style-type: none"> Low Cost No cloggings Low maintenance cost Easy maintenance Blower can be installed far away from the aerators (Less pressure loss) 	<ul style="list-style-type: none"> Low efficiency of O₂ transfer (High cost of power) Turbulent flow breaks flocs 	<ul style="list-style-type: none"> Small scale treatment plant (for labour saving)
Fine bubble type	<ul style="list-style-type: none"> Bubbles generated are small 	<ul style="list-style-type: none"> High efficiency of O₂ transfer (Low cost of power) Easy maintenance 	<ul style="list-style-type: none"> Air cleaner may be needed to prevent cloggings on the aerators Turbulent flow breaks flocs 	<ul style="list-style-type: none"> Large scale treatment plant
Ultrafine bubble type	<ul style="list-style-type: none"> Bubbles generated are smaller than that of fine bubble type 	<ul style="list-style-type: none"> Efficiency of O₂ transfer is much better No restriction on the shape of tank Good for flocculation 	<ul style="list-style-type: none"> Air cleaner may be needed to prevent clogging Initial cost is a little high 	<ul style="list-style-type: none"> Treatment plant to reduce energy cost Better treatment Treatment plant that requires high nitrification
Vertical shaft agitator type	<ul style="list-style-type: none"> There are two types of float type and fixed type There are turbine type and propeller type 	<ul style="list-style-type: none"> Low cost High efficiency of O₂ transfer Effective mixing 	<ul style="list-style-type: none"> Maintenance is not easy, if numbers of unit are many Insufficient nitrification Not suited for cold area Turbulent flow breaks flocs Distribution of DO in the tank is not even 	<ul style="list-style-type: none"> Treat plant that does not require nitrification Treatment plant located in hot area Aerating lagoon
Horizontal shaft drive type	<ul style="list-style-type: none"> Waves caused by rotation of aerator transfer O₂ (only for shallow tanks) There are two types of puddle type and rotor type 	<ul style="list-style-type: none"> High efficiency of O₂ transfer Low price Low maintenance cost 	<ul style="list-style-type: none"> Limitation of tank shape Not suited for cold area Insufficient in nitrification Turbulent flow breaks flocs 	<ul style="list-style-type: none"> Oxidation ditch
Combination type	<ul style="list-style-type: none"> Air is injected from spurjaring and simultaneously agitated by turbine propellers equipped in the water 	<ul style="list-style-type: none"> Good mixing Efficiency of O₂ transfer is ordinary Supply of air is largely adjustable 	<ul style="list-style-type: none"> Reducer and air compressor are required High price High maintenance cost Turbulent flow breaks flocs 	<ul style="list-style-type: none"> Treatment plant that requires wide range of air supply Nitrification tank

(2) Comparison Table of O₂ Transfer in Water


Aerator	O ₂ dissolving efficiency in water (%)	Power efficiency when O ₂ transferred in water (kgO ₂ /kwh)	Required Energy (kwh/kgO ₂)
BIG BUBBLE TYPE	10 - 16	1.4 - 1.9	0.51 - 0.71
	10 - 13	1.4 - 1.9	0.62 - 0.71
	8 - 10	1.2 - 1.5	0.60 - 0.71
	15 - 26	1.9 - 3.3	0.31 - 0.55
CIRCULATING TYPE	20 - 32	3.0 - 4.6	0.22 - 0.33
	1.5 - 2.2	0.46 - 0.66	
MECHANICAL AERATION	14 - 18	1.2 - 1.8	0.55 - 1.82
	15 - 26	1.6 - 2.3	0.44 - 0.62
COMBINATION			

* In case of mixed liquid in the aeration tank, it will be doubled.


Figure. Aeration Method



Circulation Aeration by Blower (Air-Blowing Type)





Total Area Aeration by Blower (Nozzle-Jet Type)



Mechanical Surface Aeration

[Appendix 3.8-2-3] Comparison Table for Sludge Collector (1)

TYPE ITEM	TRAVELING MODE TYPE	LINK-BELT TYPE
SKETCH		
MECHANISM	<p>The sludge scraper is hanged on traveling equipment which is provided with rope winding drum for "up" and "down" of scraper.</p> <p>This sludge collector would traveling forward as scraper moves "down" and as scraper "up" for sludge collecting.</p> <p>The scraper would be above the water level when sludge collector is not functioning.</p>	<p>The sludge scraper attached endless chain as bout three (3) meters pitch.</p> <p>This sludge collector is moving in direction of arrow described in the above sketch for sludge collecting.</p>
RECORD OF PERFORMANCE	Slightly Less	Lot

Comparison Table for Sludge Collector (2)

ITEM	TYPE	TRAVELING MODE TYPE	LINK-BELT TYPE
MAINTENANCE	Complicated. Traveling Equipment, Limit Switch etc. require inspection.	Easy Machine Mechanism is simple.	
OPERATION METHOD	Intermittent movement, many limit switches. Operation is complicated	Continuous running. Operation is easy.	
PERFORMANCE	Slightly no-good performance compare with Link-Belt Type.	Good	
MOTOR POWER	Primary Settling Tank : 12.0 kW (3.0 kW/2 tanks) Final Settling Tank : 12.0 kW (3.0 kW/2 tanks)	Primary Settling Tank : 6.0 kW (1.5 kW/2 tanks) Final Settling Tank : 8.8 kW (2.2 kW/2 tanks)	
INITIAL COST	180 %	100 %	
RUNNING COST	250 %	100 %	
SAFETY	Not good Mechanism is complicated and many limiting switches are required. Due to loading of sludge, possibility for wheels of traveling equipment to slip out.	Good Mechanism is simple.	

Comparison Table for Sludge Collector (3)

ITEM TYPE	TRAVELING MODE TYPE	LINK-BELT TYPE
TROUBLE PERCENTAGE	<p>High</p> <p>Many limit switches. Slipping out of wheels of traveling equipment.</p>	<p>Low</p> <p>Mechanism is simple.</p>
EVALUATION	<p>(1) Mechanism is complicate, motor power is big and intermittent operation.</p> <p>(2) Many limiting switches are necessary and maintenance work require a lot of time.</p> <p>(3) Normally, if Link-Belt Type can not be installed, select this type.</p> <p>(4) Possibility for scraper to slip out</p>	<p>(1) This sludge collector can adjust moving speed of scraper so that sludge flotation be prevented.</p> <p>(2) Return scraper can introduce floating scum to scum trough.</p> <p>(3) Lower height of scraper minimizes interference with flow of wastewater..</p>
RESULT	X	O

[Appendix 3.8-2-4] Comparative Study of Industrial Relay Pumping Systems

The maximum excavation depth for setting sewer pipes is limited to 5 m, taking into consideration local practices and experience. As a result it became necessary to inset two relay pumping stations into the sewer network. One is in the Ataqā I.E. Coastal Area which will be developed by coastal reclamation, therefore, the planned elevation is lower than the remaining areas, and flat. Another one is beside the Suez-Ain Sukhuna road which runs through the east rim of Ataqā I.E. East and is, due to topographic conditions, the route of the intercepting sewer for Ataqā I.E. East.

The road is relatively flat and the required excavation depth for the intercepting sewer becomes about 5 m at a point 1.9 km from the northern boundary of the Project Area. The site is about one km away from the coastal area's pumping station, which means it is infeasible to combine the two pumping stations into one.

If the shortest course from each pumping station to the sewers to reach the wastewater treatment plant by gravity is selected, the force main's distance from these two pumping stations is roughly 850 m and 450 m respectively.

There are alternatives, however, by which the two force mains can be combined together or the force main from the coastal area's pumping station can be connected to the nearest sewer flowing down to another pumping station. This is to minimize related costs. A comparative study of the alternatives stated above has been carried out and is summarized below.


Table 8.2.5 Comparative Study of Alternatives

(Unit: Million LE)


Content		Case-1	Case-2	Case-3	Remarks	
Cost	Construction	Pumping station	21.0	21.0	25.0	
		Force main	1.0	1.3	0.9	
		Subtotal	22.0	22.3	25.9	
	Operation	0.3	0.3	0.4		
	Total	22.3	22.6	26.3		
Appraisal		orthodox, simple and least trouble	combined force man is undesirable	too costly than others		

It is concluded from the study mentioned above that Case-1 should be adopted.


CASE - 1



CASE - 2



CASE - 3



Legend

- ← : Gravity Sewer
- ←--- : Force Main
- Ⓟ : Relay Pumping Station
- No. 1 : No. 1 Relay Pumping Station
- No. 2 : No. 2 Relay Pumping Station

Figure - 8.2.1 Alternatives to be Compared

[Appendix 3.8-2-5] COMPARISON TABLE
 OF
 MAIN PUMPS
 FOR
 SEWER RELAY PUMPING STATION

TYPE ITEM	(1) Horizontal shaft type pump	(2) Vertical shaft type pump	(3) Submersible pump
1. Installation method	Pump & motor are installed on the floor.	In case of single floor, pump casing is installed underwater and the motor is installed on the floor.	Pump & motor are installed underwater.
2. Installation space	Large	Smaller than (1)	Small
3. Suction Capability	Cavitation is apt to break out because the impeller is located above water level.	Cavitation is seldom to break out because the impeller is located underwater.	Same as (2).
4. Priming	Required.	Not required.	Not required.
5. Motor start method	Slightly complicated.	Comparatively easy.	Comparatively easy.
6. Inner inspection	Easiest because pump is installed on the floor.	It is necessary for inspection to lift up pump and motor.	Same as (2). But it is comparatively easy to inspect by the installation & removal device. The pump unit can be raised to ground level for maintenance and inspection by chain and can be simply replaced by lowering with the chain. The pump discharge and syphon are jointed automatically.

	Lowest	Higher than (3)	Low
7. Ceiling height			
8. Durability against corrosion	Major portions are located above water level and seldom corrode.	Major portions are located under water and are apt to corrode.	The pump unit is located under water and is apt to corrode.
9. Safety measure	The measure of (3) is not required.	Same as (1).	Counter measure for an electric shock is required.
10. Maintenance	Replacing the bearings and inspecting the parts of gland.	Same as (1).	Replacing the mechanical seal. Exchange the oil and the bearing checking the insulation resistance (once a month).
11. Equipment cost	(3) < (1) < (2)	Most expensive	Cheapest

[Appendix 3.8-3] Caluculations

[Appendix 3.8-3-1] Capacity of the Equipment
of Wastewater Treatment Plant

CONTENTS

1.	Basic Design Condition	3
1.1	Wastewater Characteristics	3
1.2	Quantity and Quality of Industrial Wastewater from Each Industries	4
1.3	System of the Treatment	5
1.4	Remove Ratio	5
2.	Flow Sheet of Wastewater Treatment Processes	6
3.	Design Criteria	7
3.1	Sewer System	7
3.2	Wastewater Treatment Processes	7
4.	Number of Treatment Equipment Line	8
5.	Calculation of Basic Capacity of the Equipment	8
5.1	Main Equipment	
(1)	Screen	8
(2)	Grit Chamber	8
(3)	Stroage Tank	9
(4)	Neutralization Tank	10
(5)	Coagulation Tank	11
(6)	Primary Sedimentation Tank	12
(7)	Aeration Tank	14
(8)	Final Sedimentation Tank	17
(9)	Chlorine Contact Tank	19

(10)	Treated Water Tank	20
(11)	Filtered Tank	20
(12)	Filter Tank (Future Equipment)	21
(13)	Filter (Future Equipment)	22
(14)	Backwashed Tank (Future Equipment)	24
5.2	Sludge Treatment Facility	25
(1)	Influent Flow and Quality	25
(2)	Sludge Thickener	25
(3)	Sludge Basin	27
(4)	Sludge Drying Beck	28
5.3	Bypass Pipe	29
(1)	Setting of Bypass Discharge	29
(2)	Setting of Bypass Weir Height	30

1. Basic Design Condition

1.1 Wastewater Characteristics

(1) Wastewater Quantities

Average Daily = 46,500 m³/d (D ave Q)
Maximum Daily = 55,800 m³/d (D max Q)
Peak Hourly = 3,875 m³/hr (H max Q)

(Notes)

Maximum Daily = Average Daily x 1.2
Peak Hourly = Average Daily x 2.0 x 1/24

(2) Wastewater Qualities

PH (IN) = 6 to 10
BOD (IN) = 330 mg/l
COD (IN) = 280 mg/l
SS (IN) = 380 mg/l

(3) Treated Wastewater Qualities

PH (OUT) = 7 (6 to 9)
BOD (OUT) = less than 20 mg/l
SS (OUT) = less than 30 mg/l (50 mg/l : Criteria)
OIL (Mineral) = less than 5 mg/l
OIL (Animal and Vegetable) = less than 30 mg/l
Coliforms = less than 3,000 MPN/100 ml

1.2 Quantity and Quality of Industrial Wastewater from Each Industries

Industry	Quantity (Avg. Daily)	Quality						
		PH	BOD		COD*		SS	
	m ³ /day	-	mg/l	kg/day	mg/l	kg/day	mg/l	kg/day
1. Ataqa I.E. and Adabiya I.F.Z								
1) Food	2,400	6 to 10	400	960	310	744	340	816
2) Wood Products	2,400	6 to 10	100	240	280	672	120	288
3) Plastic	1,890	6 to 10	390	738	340	643	90	171
4) Paper Products	2,140	6 to 10	400	856	200	428	390	835
5) Spinning & Weaving	5,310	6 to 10	400	2,124	260	1,381	230	1,222
6) Electrical	4,370	6 to 10	240	1,049	170	743	500	2,185
7) Mechanical & Metal ind.	1,630	6 to 10	280	457	280	457	300	489
8) Building Materials	5,060	6 to 10	270	1,367	50	253	500	2,530
9) Chemicals & Pharmaceutio	3,000	6 to 10	400	1,200	400	1,200	500	1,500
10) Others	6,420	6 to 10	400	2,568	480	3,082	500	3,210
Sub-Total	34,620	6 to 10	334	11,559	278	9,603	383	13,246
2. Ataqa I.E. Expansion Area	10,280	6 to 10	334	3,434	278	2,858	383	3,938
3. Ataqa Port	1,400	6 to 10	200	280	180	252	250	350
4. Commercial & Public Use	200	6 to 10	200	40	180	36	250	50
Total	46,500	6 to 10	330	15,313	280	12,749	380	17,584

1.3 System of the Treatment


Coaguration Sedimentation and Standard Activated Sludge Method.

1.4 Remove Ratio

	Qualities (mg/l)		Removal (%)			Note
	Waste-water	Treated Waste-water	P.S.T.	A.T. and F.S.T	Synthe-sis	
B.O.D	330	20	30.0	91.4	94.0	
SS	380	30	40.0	86.8	92.2	

- P.S.T. = Primary Sedimentation Tank
 A.T. = Aearation Tank
 F.S.T. = Final Sedimentation Tank

2. Flow Sheet of Wastewater Treatment Processes



Flow Sheet (Industrial Wastewater Treatment Processes)

3. Design Criteria

3.1 Sewer System

Design Flow : Peak Hourly Flow (H max Q)
Q max /Q ave : 2.0
Values of "N" : VC : 0.012 (Vitrified Clay Pipe)
RC : 0.013 (Reinforced Concrete Pipe)
Minimum Diameter : f 175 mm
Minimum Cover : 1.0 m
Minimum Velocity : 0.6m/S

3.2 Wastewater Treatment Processes

(1) Primary Sedimentation Tank

Over Flow Rate = less than $35 \text{ m}^3/\text{m}^2 \text{ day}$ at D max Q
Retention Time = 2.0 - 4.0 hour at D max Q

(2) Aeration Tank

BOD - SS Load = 0.2 - 0.5 kg/kg . ss. day at D mas Q
MLSS = 1,000 - 3,000 mg/l
Aeration Time = more than 6.0 hour (based on design flow)

(3) Final Sedimentation Tank

Over Flow Rate = less than $25 \text{ m}^3/\text{m}^2 \text{ day}$ at D max Q
Retention Time = 1.8 - 3.0 hour at D max Q

(4) Filter : Future Equipment

Line Velocity = less than 230m/day at D max Q
Bed Depth = 0.6 - 1.0 m
Kind of Media = Anthrasite and Sand

(5) Chlorination Equipment

Chlorine Contact Time = 30 minite at D ave Q
Dosage = 6.0 mg/l at Tertiary Filtration Effluent

(6) Sludge Thickener

Solid Loading = 25 - 29 kg/m².day
Hydraulic Loding = 16 - 32 m³/m².day

(7) Sludge Drying Beds

Retention Time = 5.0 to 7.0 days
Width = 6.0 to 8.0 m
Length = 30.0 to 45.0 m

(8) Stand-by of pumps

40% of Actual Load

4. Number of Treatment Equipment Line

Four (4) Line

Therefore, wastewater per line that have to treatment (Q) is as follow.

D ave Q (Average Daily) = $46,500 \times 1/4 = 11,625 \text{ m}^3/\text{day}$

D max Q (maximum Daily) = $55,800 \times 1/4 = 13,950 \text{ m}^3/\text{day}$

H max Q (Peak Hourly) = $3,875 \times 24 \times 1/4 = 23,250 \text{ m}^3/\text{day}$

5. Calculation of Basic Capacity of the Equipment

5.1 Main Equipment

(1) Screen (Fine)

H max Q = $3,875 \text{ m}^3/\text{hour}$

Minimum Flow Velocity : $0.6 \text{ m}/\text{sec}$

Need Screen Sectional Area :

$$3,875 / (0.6 \times 60 \times 60) = 1.80 \text{ m}^2$$

Screen Max Water Level = 1.2 m

Screen Bar Thickness = 5 mm (Bar Quantity = $2,000 \text{ mm} / 20 \text{ mm} = 100 \text{ pcs}$)

Screen Wide = $2,000 \text{ mm}$ ($100 \text{ pcs} \times 5 \text{ mm} = 500 \text{ mm}$)

Make Good Use of Wide :

$$2,000 - 500 = 1,500 \text{ mm}$$

$$1.2 \text{ m}^h \times 1.5 \text{ m}^w = 1.80 \text{ m}^2 \text{ ----- O.K.}$$

Specification :

Type : Manual Bar Screen

Wide and Pich : $2,000 \text{ mm}$ (Wide), 20 mm (Pich), 5 mm (Thickness)

Setting Angle : 60°

(2) Grit Chamber

H max Q = $93,000 \text{ m}^3/\text{day}$

Over Flow Rate : less than $1,800 \text{ m}^3 / \text{m}^2 \cdot \text{day}$ at H max Q

Surface Area :

$$SA = 93,000 / 1,800 = 52.0 \text{ m}^2$$

Mesurement :

$$3.6 \text{ m}^w \times 15.0 \text{ m}^L \times 1 \text{ pcs}$$

Over Flow Rate (Actual) :

$$\text{OFR} = 93,000 / (3.6 \times 15.0 \times 1) = 1,722 \text{ m}^3 / \text{m}^2 \cdot \text{day} \text{ ----- O.K.}$$

(3) Storage Tank

$D \max Q = 55,800 \text{ m}^3/\text{day}$

Retention Time : $RT = 6.0 \text{ hour}$

Capacity :

$V_1 = 55,800 \times 6/24 = 13,950 \text{ m}^3$

$V_2 = 3,488 \text{ m}^3/\text{each} \times 4 \text{ pcs}$

Depth : $H = 3.5 \text{ m}$

Surface Area :

$SA = 3,488/3.5 = 997 \text{ m}^2/\text{each}$

Measurement :

$10.0 \text{ m}^W \times 50.0 \text{ m}^L \times 3.5 \text{ m}^H \times 8 \text{ set}$

Capacity (Actual) :

$V_1 = 10.0 \times 50.0 \times 3.5 = 1,750 \text{ m}^3/\text{each} \text{ ----- OK}$

$V_2 = 1,750 \times 8 = 14,000 \text{ m}^3 \text{ ----- OK}$

Retention Time (Actual) :


$RT = 14,000/55,800 \times 24 = 6.02 \text{ hour} \text{ ----- OK}$

Peripheral Equipment :

Raw Pump :

$q = 13,950/(24 \times 60) = 9.69 \text{ m}^3/\text{min. each}$

$10.0 \text{ m}^3/\text{min} \times 6(2) \text{ PCS}$



(4) Neutralization Tank

D max Q = 55,800 m³/day

Retention Time : RT = 20 min

Capacity :

$V_1 = 55,800 \times 20 / (24 \times 60) = 775 \text{ m}^3$

$V_2 = 194 \text{ m}^3/\text{each} \times 4 \text{ pcs}$

Depth : H = 4.0 m

Surface Area :

$SA = 194 / 4.0 = 49 \text{ m}^2/\text{each}$

Measurement :

$7.0 \text{ m}^W \times 4.0 \text{ m}^H \times 4 \text{ pcs}$

Capacity (Actual) :

$V_1 = 7.0^2 \times 4.0 = 196 \text{ m}^3/\text{each} \text{ ----- OK}$

$V_2 = 196 \times 4 = 784 \text{ m}^3 \text{ ----- OK}$

Retention Time (Actual) :


$RT = 784 / 55,800 \times 24 \times 60 = 20.2 \text{ min} \text{ ----- OK}$

Air Quantity for Mixing

$q = (7.0)^2 \times 1.0 \text{ m}^3/\text{m}^2.\text{hr} \times 1/60$

$= 0.82 \text{ m}^3/\text{min}.\text{each} \text{ ----- } 1.0 \text{ m}^3/\text{min}.\text{each}$

$1.0 \text{ m}^3/\text{min} \times 6(2) \text{ PCS}$



(5) Coagulation Tank

D max Q = 55,800 m³/day

Retention Time : RT = 20 min

Capacity :

$V_1 = 55,800 \times 20 / (24 \times 60) = 775 \text{ m}^3$

$V_2 = 194 \text{ m}^3/\text{each} \times 4 \text{ pcs}$

Depth : H = 4.0 m

Surface Area :

$SA = 194 / 4.0 = 49 \text{ m}^2/\text{each}$

Measurement :

$7.0 \text{ m}^W \times 4.0 \text{ m}^H \times 4 \text{ pcs}$

Capacity (Actual) :

$V_1 = 7.0^2 \times 4.0 = 196 \text{ m}^3/\text{each} \text{ ---- OK}$

$V_2 = 196 \times 4 = 784 \text{ m}^3 \text{ ---- OK}$


Retention Time (Actual) :

$RT = 784 / 55,800 \times 24 \times 60 = 20.2 \text{ min} \text{ ---- OK}$

Mixer :

Type : Double Paddle x 4 pcs

Material : Stenless Steel



(6) Primary Sedimentation Tank

D max Q = 55,800 m³/day, H max Q = 93,000 m³/day

Over Flow Rate :

$$\text{OFR}_1 = \text{less than } 35 \text{ m}^3/\text{m}^2 \text{ day at D max Q}$$

Retention Time :

$$\text{RT} = 2.0 - 4.0 \text{ hour at D max Q}$$

Surface Area :

$$\text{SA}_1 = 55,800/35 = 1,595 \text{ m}^2 = 399 \text{ m}^2/\text{each}$$

Capacity :

$$V = 55,800 \times 2.0/24 = 4,650 \text{ m}^3 = 1,163 \text{ m}^3/\text{each}$$

Depth :

$$H = 1,163/399 = 2.91 \quad 3.0 \text{ m}$$

Measurement :

$$10.0 \text{ m}^W \times 40.0 \text{ m}^L \times 3.0 \text{ m}^H \times 4 \text{ pcs}$$

Over Flow Rate (Actual) :


$$\text{OFR}_1 = 55,800/(10.0 \times 40.0 \times 4) = 34.9 \text{ m}^3/\text{m}^2 \text{ day}$$

---- OK

Retention Time (Actual) :

$$\text{RT} = (10.0 \times 40.0 \times 3.0 \times 4) / 55,800 \times 24 = 2.06 \text{ hr}$$

---- OK



Sludge Generation :

Sludge Generation Ratio : as 40.0 %

SS Concentrate of Sludge : as 2.0wt %

$$\begin{aligned}\text{Removal SS} &= 55,800 \times 380 \times 0.40 \times 10^{-3} \\ &= 8,481.6 \text{ kg - ss/day} \\ &= 2,120.4 \text{ kg - ss/day. each x 4 line}\end{aligned}$$

Sludge Volume :

$$\begin{aligned}\text{SV} &= 8,481.6/0.02 \times 10^{-3} \\ &= 424.08 \text{ m}^3/\text{day} \\ &= 106.02 \text{ m}^3/\text{day. each x 4 line}\end{aligned}$$

Peripheral Equipment :

Rake : Chain Flight Double Rink Type
(5.0 m^w x 2^{set}) x 4 line

Scum Skimer : 4 pcs

Sludge Pump :

$$\begin{aligned}q &= 424.08/(12 \times 60) \times 1/4 = 0.147 \text{ m}^3/\text{min. each} \\ &0.20 \text{ m}^3/\text{min} \times 6(2) \text{ pcs}\end{aligned}$$

(7) Aeration Tank

$$D \text{ max } Q = 55,800 \text{ m}^3/\text{day}$$

$$\text{BOD - SS Load} = 0.2 - 0.5 \text{ kg/kg.ss.day at } D \text{ max } Q$$

$$\text{MLSS} = 1,000 - 3,000 \text{ mg/l}$$

$$\text{Aeration Time} = \text{more than } 6.0 \text{ hour}$$

Influent Quality :

$$\begin{aligned} \text{BOD (IN)} &= 55,800 \times 330 \times (1 - 0.30) \times 10^{-3} \\ &= 12,889.8 \text{ kg - BOD/day} \end{aligned}$$

$$\begin{aligned} \text{BOD (mg/l)} &= 12,889.8/55,800 \times 10^3 \\ &= 231 \text{ mg/l} \end{aligned}$$

$$\begin{aligned} \text{SS (IN)} &= 55,800 \times 380 \times (1 - 0.40) \times 10^{-3} \\ &= 12,722.4 \text{ kg - ss/day} \end{aligned}$$

$$\begin{aligned} \text{SS (mg/l)} &= 12,722.4/55,800 \times 10^3 \\ &= 228 \text{ mg/l} \end{aligned}$$

Capacity :

$$V_1 = 55,800 \times 6.0/24 = 13,950 \text{ m}^3$$

$$\begin{aligned} V_2 &= 12,889.8/(0.30 \times 2,000) \times 10^{-3} = 21,482 \text{ m}^3 \\ &= 21,483 \text{ m}^3 \end{aligned}$$

$$= 5,371 \text{ m}^3/\text{each} \times 4 \text{ pcs}$$

$$\text{Depth} : H = 5.0 \text{ m}$$

Measurement :

$$15.0 \text{ m}^W \times 72.0 \text{ m}^L \times 5.0 \text{ m}^H \times 4 \text{ pcs}$$

Surface Area (Actual) :

$$\text{SA} = 15.0 \times 72.0 \times 4$$

$$= 4,320 \text{ m}^2$$

$$= 1,080 \text{ m}^2/\text{each} \times 4 \text{ pcs}$$

Capacity (Actual) :

$$V = 15.0 \times 72.0 \times 5.0 \times 4$$

$$= 21,600 \text{ m}^3$$

$$= 5,400 \text{ m}^3/\text{each} \times 4 \text{ pcs}$$

BOD - SS Load (Actual) :

$$L (\text{BOD - SS}) = 12,889.8/(21,600 \times 2,000/10^3)$$

$$= 0.298 \text{ kg - BOD/kg - ss. day ----- OK}$$

Aeration Time (Actual) :
 $T_a = 21,600 / (55,800 / 24) = 9.29$ hour ----- OK

BOD Volume Load (Actual)
 $L \text{ (BOD.V)} = 12,889.8 / 21,600 = 0.579$ kg/m³.day
 ----- OK (= 0.600 kg/m³.day)

Return Sludge Volume :

Return Sludge Rate :
 $R_r = (MLSS - SS[IN]) / (Cr - MLSS) \times 10^2$
 Cr : Return Sludge Generation Ratio
 (= 8,000 mg/l)
 Therefore
 $R_r = (2,000 - 228) / (8,000 - 2,000) \times 10^2$
 = 29.53 % (Maximum = 100 %)

RSV = D max Q x R_r/10²
 = 55,800 x 29.53/10²
 = 16,477.74 m³/day
 = 11.44 m³/min

Aeration Time of Influent Sludge (Actual) :
 $SA = V(AT) \times MLSS / 10^3 / SS(IN)$
 = 21,600 x 2,000 / 10³ / 12,722.4
 = 3.40 day ----- OK (2.0 < SA < 4.0 day)


Sludge Retention Time (Actual) :

$SRT = [V(A.T) \times MLSS + V(F.S.T) \times MLSS] / (Q_w \times Cr + D \text{ max } Q \times S_{So})$

Where

- * V(A.T) = Aeration Tank Capacity = 21,600 m³
- * V(F.S.T.) = Final Sedimentation Tank Capacity
 = 6,975 m³
- * Q_w = Sludge Volume at Final Sedimentation Tank
 = 1,380.38 m³/day
- * Cr = Return Sludge Generation Ratio
 = 8,000 mg/l
- * S_{So} = Treated Wastewater Qualities
 = 30 mg/l

$SRT = (21,600 \times 2,000 + 6,975 \times 2,000) / (1,380.38 \times 8,000 + 55,800 \times 30)$
 = 4.50 day



Aeration :

$$\text{Need Oxygen} = D \max Q \times \text{BOD(IN)} \times (1 - R(P)) \times R(F) \\ \times 10^{-3} \times 35 \text{ m}^3/\text{kg} - \text{BOD}$$

Where,

* R(p) : Removal at Primary Sedimentation Tank
= 30.0 %

* R(f) : Removal at Aeration Tank + Final
Sedimentation Tank
= 91.4 %

$$O(w) = 55,800 \times 330 \times (1 - 0.30) \times 0.914 \times 10^{-3} \times 35 \\ = 412,345 \text{ m}^3/\text{day} \\ = 286.35 \text{ m}^3/\text{min}$$

Blower :

$$q = 286.35/4 = 71.59 \text{ m}^3/\text{min}.\text{each}$$

(8) Final Sedimentation Tank

D max Q = 55,800 m³/day

Over Flow Rate = less than 25 (20) m³/m² day at D max Q
Retention Time = 1.8 - 3.0 hour at D max Q

Surface Area :

SA = 55,800/20 = 2,790 m² = 698 m²/each

Capacity :

V = 55,800 x 3.0/24 = 6,975 m³ = 1,744 m³/each

Depth :

H = 1,744/698 = 2.50 m

Measurement :


5.0 m^W x 70.0 m^L x 2.5 m^H x 8 set (4 pcs)

Over Flow Rate (Actual) :

OFR = 55,800/(10.0 x 70.0 x 4) = 19.9 m³/m².day
---- OK

Retention Time (Actual) :

RT = (10.0 x 70.0 x 2.5 x 4) / 55,800 x 24 = 3.01 hour
---- OK



Return Sludge to Aeration Tank

$$\begin{aligned} \text{Maximum Return Sludge Ratio} &= 100 \% \\ q &= 55,800 \times 100 = 55,800 \text{ m}^3/\text{day} \\ &= 13,950 \text{ m}^3/\text{day. each} \times 4 \text{ pcs} \\ &= 9.69 \text{ m}^3/\text{min. each} \times 4 \text{ pcs} \end{aligned}$$

Sludge Generation :

$$\begin{aligned} \text{Sludge Generation Ratio} &: \\ &\text{as } 40.0 \% \text{ (Primary Sedimentation Tank)} \\ &\text{as } 86.8 \% \text{ (Aeration Tank + Final} \\ &\quad \text{Sedimentation Tank)} \end{aligned}$$

$$\begin{aligned} \text{SS Concentrate of Sludge} &: \text{ as } 0.8^{\text{wt}} \% \\ \text{Removal SS} &= 55,800 \times 380 \times (1 - 0.40) \times 0.868 \times 10^{-3} \\ &= 11,043.0 \text{ kg - SS/day} \\ &= 2,761 \text{ kg - SS/day. each} \times 4 \text{ line} \end{aligned}$$

$$\begin{aligned} \text{Sludge Volume} &: \\ \text{SV} &= 11,043.0 / 0.008 \times 10^{-3} \\ &= 1380.38 \text{ m}^3/\text{day} \\ &= 345.10 \text{ m}^3/\text{day. each} \times 4 \text{ line} \end{aligned}$$

Peripheral Equipment :

$$\begin{aligned} \text{Rake} &: \text{ Chain Flight Double Rink Type,} \\ &\quad (5.0 \text{ m}^{\text{W}} \times 2 \text{ set}) \times 4 \text{ line} \end{aligned}$$

$$\text{Sum Skimer} : 4 \text{ set}$$

$$\text{Return Sludge Pump} : 4.90 \text{ m}^3/\text{min} \times 6(2) \text{ pcs}$$

$$\begin{aligned} \text{Sludge Pump} &: \\ q &= 345.10 / (12 \times 60) \times 1/4 = 0.120 \text{ m}^3/\text{min. each} \\ \text{Therefore} & \\ &0.50 \text{ m}^3/\text{min} \times 6 (2) \text{ pcs} \end{aligned}$$

(9) Chlorine Contact Tank

D ave Q = 46,500 m³/day

Chlorine Contact Time = 30 minite at D ave Q

Capacity :

$$V = 46,500 \times 30 / (24 \times 60) = 967 \text{ m}^3$$

$$V = 967.0 \text{ m}^3 = 121 \text{ m}^3/\text{each} \times 8 \text{ pcs}$$

Measure :


$$2.0 \text{ m}^W \times 25.0 \text{ m}^L \times 2.5 \text{ m}^H \times 8 \text{ pcs}$$

Capacity :

$$V = 2.0 \times 25.0 \times 2.5 \times 8 = 1,000 \text{ m}^3$$

Chlorine Contact Time :

$$CT = 1,000/46,000 \times 24 \times 60 = 31.0 \text{ minute ----- OK}$$



(10) Treated Water Tank

$$D \text{ max } Q = 55,800 \text{ m}^3/\text{day}$$

Retention Time :

$$RT = 5 \text{ minute at } D \text{ max } Q$$

Capacity :

$$V = 55,800 \times 5 / (24 \times 60)$$

$$= 193.8 \text{ --- } 200 \text{ m}^3$$

$$V = 100 \text{ m}^3/\text{each} \times 2 \text{ set}$$

Measurement :

$$5.0 \text{ m}^W \times 8.0 \text{ m}^L \times 2.5 \text{ m}^H \times 2 \text{ set}$$

Retention Time (Actual) :

$$RT = [(5.0 \times 8.0 \times 2.5 \times 2) / 55,800] \times 24 \times 60$$

$$= 5.2 \text{ minute ----- OK}$$

(11) Filtered Tank

Surface Washing :

$$\text{Surface Washing Velocity} = 0.3 \text{ m}^3/\text{m}^2 \cdot \text{min}$$

$$\text{Surface Washing Time} = 5.0 \text{ minute}$$

Surface Washing :

$$q_1 = 0.3 \times 36 \text{ m}^2/\text{each} \times 5.0 = 54 \text{ m}^3/\text{day} \cdot \text{set}$$

Back Washing :

$$LV = 0.7 \text{ m}^3/\text{m}^2 \cdot \text{min}$$

$$\text{Back Washing Time} = 10.0 \text{ minute}$$

Back Washing :

$$q_2 = 0.7 \times 36 \text{ m}^2/\text{each} \times 10.0 = 252 \text{ m}^3/\text{day} \cdot \text{set}$$

Total Washing Water :

$$q = (q_1 + q_2) \times 8 \text{ set} = (54 + 252) \times 8 = 2,448 \text{ m}^3/\text{day}$$

Capacity :

$$V = q_1 + q_2 = 54 + 252 = 306 \text{ m}^3$$

Measurement :

$$8.0 \text{ m}^W \times 16.0 \text{ m}^L \times 2.5 \text{ m}^H \times 1 \text{ set}$$

(12) Filter Tank (Future Equipment)

Influent Flow : D max Q

$$D \text{ max } Q = 55,800 - 1,380,38 = 54,419.6 \text{ m}^3/\text{day}$$

Influent Quality :

$$\Delta S = 55,800 \times 380 \times 10^{-3} \times (1 - 0.922)$$

$$= 1,653.9 \text{ kg-ss/day}$$

$$SS = 1,653.9/54,419.6 \times 10^3 = 30.4 \text{ mg/l}$$

Retention Time :

$$RT = 10.0 \text{ minute at D max } Q$$

Capacity :

$$V = 54,419.6 \times 10.0 / (24 \times 60)$$

$$= 378 \text{ m}^3$$

$$= 95 \text{ m}^3/\text{each} \times 4 \text{ pcs}$$

Measurement :

$$4.0 \text{ m}^W \times 10.0 \text{ m}^L \times 2.5 \text{ m}^H \times 4 \text{ pcs}$$

Capacity (Actual) :

$$V = 4.0 \times 10.0 \times 2.5 \times 4 = 400 \text{ m}^3$$

Retention Time (Actual) :

$$RT = (400/54,419.6) \times 24 \times 60 = 10.6 \text{ minute}$$

----- OK

Filter Pump :

$$q = 54,419.6 / (24 \times 60) \times 1.05$$

$$= 39.7 \text{ m}^3/\text{minute}$$

$$= 10.0 \text{ m}^3/\text{minute, each} \times 6(2) \text{ pcs}$$


(13) Filter (Future Equipment)

Live Velocity :
 $LV = 200 \text{ m/day}$ (Max : 300 m/day)

Filterd Area :
 $S = 54,419.6 \times 1.05/200$
 $= 286 \text{ m}^2$
 $= 36 \text{ m}^2/\text{each} \times 8 \text{ set}$

Measurement and Number :
 $6.0 \text{ m}^W \times 6.0 \text{ m}^L \times 4.6 \text{ m}^H \times 8 \text{ set}$

Filter Unit : (m)



Time of Back Washing : 1 time/day

Anthrasite Volume :

$$AV = \frac{1,653.9 \text{ kg - ss/day}}{15 \text{ kg - ss/m}^3 \text{ Anthrasite}} \times 1/8 = 13.8 \text{ m}^3$$

Depth of Anthrasite :
 $13.8/36 = 0.4 \text{ m}$

Depth of Sand :
 $0.4 \times 0.60 = 0.24 \quad 0.2 \text{ m (less than 60\%)}$
 * Depth (Anthrasite + Sand) = 0.6 - 1.0 m

Q'ty of Washing Water :

(a) Surface washing

Surface Washing Velocity = $0.3 \text{ m}^3/\text{m}^2\cdot\text{minute}$

Surface Washing Time = 5.0 minute

$q_1 = 0.3 \times 36 \text{ m}^2/\text{each} \times 5.0 = 54 \text{ m}^3/\text{day. set}$

(b) Back Washing

LV = $0.7 \text{ m}^3/\text{m}^2\cdot\text{minute}$

Back Washing Time = 10.0 minute

$q_2 = 0.7 \times 36 \text{ m}^2 / \text{each} \times 10.0$

$= 252 \text{ m}^3/\text{day.set}$

(c) Total Washing Water

$q = (q_1 + q_2) \times q_{\text{set}}$

$= (54 + 252) \times 8$

$= 2,448 \text{ m}^3/\text{day}$

Wastewater Quality of Back Washing Water :

SS : Suspended Solid

$$\text{SS} = \frac{54.419 \times (30.4 - 10.0) + 2,448 \times 10.0}{2,448} = 463.5 \text{ mg/l}$$

(14) Backmashed Tank (Future Equipment)

Capacity :

$$V = q^1 + q^2 = 54 + 252 = 306 \text{ m}^3$$

Measurement :

$$8.0 \text{ m}^W \times 16.0 \text{ m}^L \times 2.5 \text{ m}^H \times 1 \text{ set} \quad (V = 320 \text{ m}^3)$$

Transfer Pump

$$q = (306 \text{ m}^3/\text{cycle}) / (2.0 \text{ hr}/\text{cycle} \times 60) \\ = 2.55 \quad 3.0 \text{ m}^3/\text{minute}$$

$$3.0 \text{ m}^3/\text{minute} \times 2(1) \text{ pcs}$$

Air Quantity for Mixing :

$$q = (8.0 \times 16.0) \times 1.0 \text{ m}^3/\text{m}^2 \text{ hr} \times 1/60 \\ = 2.2 \text{ m}^3 / \text{minute}$$

5.2 Sludge Treatment Facility

(1) Influent Flow and Quality

Sources of Sludge Generation	Quantity (m ³ /day)	SS	
		(mg/l)	(kg/day)
Primary Sedimentation Tank	424.08	20,000	8,481.6
Final Sedimentation Tank	1,380.38	8,000	11,043.0
Backwashed Water of Filter	(2,720.00)	(942.6)	(2,564.0)
Separate Water and Washed Water	-	-	-
Total	4,524.46	4,882	22,088.6

(2) Sludge Thickener

Solid Loading = 25 - 59 kg/m². day
 Hydraulic Loading = 16 - 32 m³/m². day

Surface Area :

$$SA = 22,088.6/40 = 553 \text{ m}^2$$

Measurement :

$$D = \frac{553 \times 1/2}{\pi/4} = 18.8 \quad 19.0 \text{ m } \emptyset$$

$$19.0 \text{ m } \emptyset \times 3.0 \text{ m}^H \times 2 \text{ pcs}$$

Surface Area :

$$\begin{aligned} SA &= (\pi \times 19.0^2) / 4 \\ &= 283.5 \text{ m}^2/\text{each} \times 2 \text{ pcs} \\ &= 567 \text{ m}^2 \end{aligned}$$

Capacity :

$$V = 567 \times 3.0 = 1,701 \text{ m}^3$$

Solid Loading (Actual) :

$$SL = 22,088.6/567 = 39.0 \text{ kg/m}^2. \text{ day} \text{ ----- OK}$$

Hydraulic Loading (Actual) :

$$HL = 4,524.46/567 = 8.0 \text{ m}^3/\text{m}^2. \text{ day} \text{ ----- OK}$$

Retention Time (Actual) :
RT = 1,701.4,524.46 x 24 = 9.0 hour

Concentration Sludge Volume :
Sludge Water Rate = 98.0 %
CSV = 22,088.6/(1 - 0.98) x 10⁻³
= 1,104.43 m³/day
= 0.77 m³/min

Effluent Separate Water :
ESW = 4,524.46 - 1,104.43
= 3,420.03 m³/day

Peripheval Equipment :
Rake : 2 set
Scum Box : 2set

(3) Sludge Basin

$$\begin{aligned}\text{Concentration Sludge Volume} &= 1,104.43 \text{ m}^3/\text{day} \\ &= 0.77 \text{ m}^3/\text{min}\end{aligned}$$

Retention Time : RT = more than 12.0 hour

$$\begin{aligned}\text{Capacity :} \\ V &= 1,104.43 \times 12/24 \\ &= 552.2 \text{ m}^3 \\ &= 280 \text{ m}^3/\text{each} \times 2 \text{ pcs}\end{aligned}$$

$$\begin{aligned}\text{Measurement :} \\ 10.0 \text{ m}^{\text{II}} \times 3.0 \text{ m}^{\text{H}} \times 2 \text{ pcs}\end{aligned}$$

$$\begin{aligned}\text{Capacity (Actual) :} \\ V = 10.0^2 \times 3.0 \times 2 = 600 \text{ m}^3 \text{ ----- OK}\end{aligned}$$

$$\begin{aligned}\text{Retention Time (Actual) :} \\ \text{RT} = 600/1,104.43 \times 24 = 13.0 \text{ hour ----- OK}\end{aligned}$$

$$\begin{aligned}\text{Peripheral Equipment :} \\ \text{Diffuser :} \\ \text{Aeration } q &= 600 \times 1.0 \text{ m}^3/\text{m}^3 \cdot \text{hour} \times 1/60 \\ &= 10.00 \text{ m}^3/\text{min} \\ &= 5.0 \text{ m}^3/\text{min. each} \times 2 \text{ pcs}\end{aligned}$$

$$\begin{aligned}\text{Sludge Feed Pump :} \\ q &= 1,104.43 \text{ m}^3/\text{day} \times 1/(12.0 \text{ hour}/\text{day} \times 60) \times 1/4 \text{ pcs} \\ &= 0.38 \text{ m}^3/\text{min} \quad 0.40 \text{ m}^3/\text{min} \\ \text{Therefore} \\ &0.40 \text{ m}^3/\text{min} \times 6(2) \text{ pcs}\end{aligned}$$

(4) Sludge Drying Beds

Sludge Volume :

$$SV = 1,104.43 \text{ m}^3/\text{day} \text{ (Sludge Water Rate} = 98.0 \%)$$

Retention Time : $RT = 5.0$ to 7.0 days

Width = 6.0 to 8.0 m

Length = 30.0 to 45.0 m

Sludge Depth = 10.0 cm

Depth of the Sand = 15.0 to 30.0 cm

* Sand Size = 0.3 to 1.2 mm

Depth of the Gravel = at least 8.0 cm

= 20.0 - 30.0 cm

* Gravel Size = 3.0 - 6.0 mm

Surface Area :

$$SA = SV \times RT / SD$$

Where SV : Sludge Volume (= $1,104.43 \text{ m}^3/\text{day}$)
RT : Retention Time (= 7.0 day)
SD : Sludge Depth (= 0.10 m)

$$SA = 1,104.43 \times 5.0 / 0.10$$

$$= 55,222 \text{ m}^2$$

Measurement :

$$8.0 \text{ m}^W \times 45.0 \text{ m}^L \times 160 \text{ pcs}$$

Surface Area (Actual) :

$$SA = 8.0 \times 45.0 \times 160 = 57,600 \text{ m}^2$$

Retention Time (Actual) :

$$RT = 57,600 \times 0.10 / 1,104.43 = 5.22 \text{ day} \text{ ----- OK}$$

5.3 Bypass Pipe

(1) Setting of Bypass Discharge

Setting is made so as to entirely bypass the influent higher than H max Q. Since there is an allowance of $H = 6,500 - 1,220 (4,720) = 5,280$ m (1,780 m) between HWL of the Bay of Suez and the ultimate level (Chlorine Flocculation Basin Weir Height) of the treatment facilities, there is no danger about back water, and if the effluent pipes are installed higher than back water level (+ 1,220 m) the effluent (treated water and bypass water) is always discharged into the Bay of Suez by gravity with no presence of standing water inside of the effluent pipe.

(2) Setting of Bypass Weir Height

Type of Weir : Lateral overflow weir (bypass weir)

GH = + 7.500 m

Water Level of Suez Bay :

HWL = + 0.763 m

LWL = - 0.737 m

Treated Water Discharge Pipe Loss Head :

Pipe Form : ϕ 1.350 mm x 1.2 0/00 x 1.000 m^L (H.P.)

Loss Head : ΔH (D ave Q) = 0.113 m

ΔH (D max Q) = 0.162 m

ΔH (H max Q) = 0.450 m

ΔH (RH max Q) =

Back Water Level :

D ave WL = + 0.763 + 0.113 + α = + 0.880 m (+ 4.380 m)

D max WL = + 0.763 + 0.162 + α = + 0.930 m (+ 4.430 m)

H max WL = + 0.763 + 0.450 + α = + 1.220 m (+ 4.720 m)

RH max WL =

Chlorine Contact Tank :

Outflow Wier Level = + 6.500 m

Bypass Pipe :

ϕ 1.350 mm x 1.2 0/00 (H. P.)

V full = 1.292 m/sec

Q full = 1.8489 m³/sec

Water Level of Influent Pipe :

$$D \text{ ave } Q/Q \text{ full} = 0.538 / 1.8489 = 0.291 \rightarrow 29.1$$

$$D \text{ max } Q/Q \text{ full} = 0.646 / 1.8489 = 0.349 \rightarrow 34.9$$

$$H \text{ max } Q/Q \text{ full} = 1.076 / 1.8489 = 0.582 \rightarrow 58.2$$

Hydraulic characteristic curve (Manning's Formula)

$$d / D \text{ (D ave Q)} = 0.37$$

$$d / D \text{ (D max Q)} = 0.41$$

$$d / D \text{ (H max Q)} = 0.55$$


According by the water depth of the influent pipe are ;

$$d \text{ (D ave Q)} = 1.350 \times 0.37 = 0.500 \text{ m}$$

$$d \text{ (D max Q)} = 1.350 \times 0.41 = 0.554 \text{ m}$$

$$d \text{ (H max Q)} = 1.350 \times 0.55 = 0.743 \text{ m}$$

Profil of Influent Pipe :



$$\text{(MH1)} = + 3.660 + 1.2 \times 15 \times 10^{-3} = + 3.678 \text{ m}$$

$$\text{(MH2)} = + 3.660 + 1.2 \times (15 + 163) \times 10^{-3} = + 3.874 \text{ m}$$

Bypass Weir Height (Lateral Overflow Weir) :

$$\text{Bypass Wier Level} = + 3.874 + 0.743 + \alpha = + 4.620 \text{ m}$$

Installed at (MH2) Manhle.

[Appendix 3.8-3] Caluculations

[Appendix 3.8-3-2] Capacity of the Machinery
of Wastewater Treatment Plant

I. Basic Design Condition

1 - 1. Waste Water Characteristics

(1) Waste Water Quantities

Average [Daily] = 46,500 m³ /d (Q/d ...ave)

Maximum [Daily] = 55,800 m³ /d (Q/d ...max)

Peak [Hourly] = 3,875 m³ /h (Q/h ...max)

(Note)

Maximum [Daily] = Average Daily × 1.2

Peak [Hourly] = Average Daily × 2.0 × 1/24

(2) Waste Water Quantity

pH (in) = 6 to 10

BOD (in) = 330 mg/l

COD (in) = 280 mg/l

SS (in) = 380 mg/l

(3) Treated Waste Water Quantity

pH (out) = 6 to 8

BOD (out) = Less than 20 mg/l

SS (out) = Less than 30 mg/l (50mg/l ; Criteria)

Oil (Mineral) = Less than 5mg/l

Oil (Animal and Vegetable) = Less than 30mg/l

Coliforms = Less than 3,000 MPN/100ml

1 - 2. Quantity and quality of industrial waste water from each industry

(See table-1)

1 - 3. System of the treatment

Coaguration Sedimentation and Standard Activated Sludge Method

Industry	Quantity (Avg. Daily)	Quality						
		PH	BOD		COD*		SS	
	m ³ /day	-	mg/l	kg/day	mg/l	kg/day	mg/l	kg/day
1. Ataqa I.E. and Adabiya I.F.Z								
1) Food	2,400	6 to 10	400	960	310	744	340	816
2) Wood Products	2,400	6 to 10	100	240	280	672	120	288
3) Plastic	1,890	6 to 10	390	738	340	643	90	171
4) Paper Products	2,140	6 to 10	400	856	200	428	390	835
5) Spinning & Weaving	5,310	6 to 10	400	2,124	260	1,381	230	1,222
6) Electrical	4,370	6 to 10	240	1,049	170	743	500	2,185
7) Mechanical & Metal ind.	1,630	6 to 10	280	457	280	457	300	489
8) Building Materials	5,060	6 to 10	270	1,367	50	253	500	2,530
9) Chemicals & Pharmaceutio	3,000	6 to 10	400	1,200	400	1,200	500	1,500
10) Others	6,420	6 to 10	400	2,568	480	3,082	500	3,210
Sub-Total	34,620	6 to 10	334	11,559	278	9,603	383	13,246
2. Ataqa I.E. Expansion Area	10,280	6 to 10	334	3,434	278	2,858	383	3,938
3. Ataqa Port	1,400	6 to 10	200	280	180	252	250	350
4. Commercial & Public Use	200	6 to 10	200	40	180	36	250	50
Total	46,500	6 to 10	330	15,313	280	12,749	380	17,584

1 - 4. Removal Rate

	Qualities(mg/l)		removal (%)			Note
	Waste Water	Treated Waste Water	P. S. T.	A. T and F. S. T.	Synthesis	
BOD	330ppm	20ppm	30.0	91.4	94.0	
SS	380ppm	30ppm	40.0	86.8	92.2	

(Note) P. S. T. =Primary Sedimentation Tank
A. T. =Aeration Tank
F. S. T. =Final Sedimentation Tank

(6) Sludge Thickner

Solid Loading = 25~59kg/m² . dayHydraulic Loading = 16~32m³/m² . day

(7) Sludge Drying Beds

Retention Time = 5.0 to 7.0 days

Wide = 6.0 to 8.0m

Length = 30.0 to 45.0

(8) Stand-by units of Pumps

40% of Actual Load

4. Number of treatment equipment line

Four(4) Line

Therefore, Wastewater per line to be treated (Q) is as follow;

DaveQ (Average-Daily) = 46,500m³ /d × 1/4 = 11,625m³ /dayDmaxQ (Maximum-Daily) = 55,800m³ /d × 1/4 = 13,950m³ /dayHmaxQ (Peak -Hourly) = 3,875m³ /h × 24 × 1/4 = 23,250m³ /day

5. Calculation of basic capacity of the equipment

5-1. Main equipment

(1) Raw waste water pumping station scope of civil work

Influent Quantity; 46,500m³ /d(aveQ), 55,800m³ /d(maxQ), 3,875m³ /h(Peak Hour)Pit Capacity ; 10 ~ 15min(Peak hour) 3,875m³ /h ÷ 60 = 64.59m³ /min64.59m³ /min × 10 ~ 15min = 645.9 ~ 968.9m³ → 950m³Pump station Dimention; (9.0mW × 23.0mL × 4.8mH) = 993.6m³

a) Influent pipe B.O.P. ; +3,600(GL-3,900) dia. 1,300mm Φ

b) Pump outlet pipe; velocity = 2.0m/sec Φ = 146√(64.6/2) = 830mm → 1000mm Φ

c) Pump quantity ; 6pcs(2pcs spare) 64.6/4 = 16.15m³ /min(each)

d) Pump outlet size; velocity = 3.0m/sec Φ = 146√(16.15/3) = 339mm → 400mm Φ

e) Pump head v(1000) = 64.6m³ / (60 × 3.14/4 × D²) = 1.37m/secv(400) = 16.15m³ / (60 × 3.14/4 × D²) = 2.14m/sec

Influent pump head; Actual head(HI) = (▽+9,120) + (▽-1,700) = 10.82m

piping loss head(HLi)(400) = f1xL/Dx v² / 2g

$$\begin{aligned}
 f1(400) &= 0.02 + 0.0005/D = 0.0213 & f2(1000) &= 0.02 + 0.0005/D = 0.0205 \\
 H2(400) &= C.0213 \times 10.2m / 0.4 \times (2.14)^2 / 19.6 = 0.127m \\
 H3(1000) &= 0.0205 \times 250.0m / 1.0 \times (1.37)^2 / 19.6 = 0.491m \\
 \text{Elbow loss head } H4(400) &= 1pc \times 0.2 \times (2.14)^2 / 19.6 = 0.047m \\
 H5(1000) &= 5pc \times 0.2 \times (1.37)^2 / 19.6 = 0.096m \\
 \text{Checkvaive loss } H6(400) &= 1pc \times 1.8 \times (2.14)^2 / 19.6 = 0.421m \\
 \text{Tee loss } H7(1000) &= 1pc \times 1.2 \times (1.37)^2 / 19.6 = 0.115m \\
 \text{Total head } H &= H1 + H2 + H3 + H4 + H5 + H6 + H7 = 10.82 + 0.127 + 0.491 + 0.047 + 0.096 + 0.421 + 0.115 = 12.117m \\
 &= 13.0m
 \end{aligned}$$

$$f) \text{ Power of motor } PS = 0.163 \times (\gamma \times Q \times H) / \eta \times \alpha$$

PS ; Power of motor	kw
γ ; Gravity of gravity inlet water	1.0
Q ; Flow volume	16.15m ³ /min
H ; Total head	13.0m
η ; Efficiency of pump	72 %
α ; Safety ratio	1.2

$$PS = 0.163 \times (1.0 \times 16.15 \times 13.0) / 0.72 \times 1.2 = 54.8kw \quad \rightarrow 55.6kw$$

① [Sewerage Pump for raw waste water pumping station specification]

..... (Facility NO. 4-5)


Type	; Submersible Waste Water Pump	
Specification	; 400Φ x 16.15m ³ /min x 13.0m x 55kw (380V x 50HZ)	
Quantity	; 6pcs (spare 2 pcs)	
Accessory	; Cable 20m/1 PCS, Chain; 6m/1pcs (Stainless Steel), Guide pipe 1set/1pcs (Stainless Steel), automatic connection 1Set/1pcs	

② Chain hoist ; Hoist 2.8ton x 6m hoist (2.4 x 0.2kw) 1 Set ... (Facility NO. 4-7)

Accessory ; Help plain trolley; 2.8ton x 6.0m 1 Set

(2) Screen

Influent Quantity	= 3,375m ³ /h (Peak hourly)
Minimum flow velocity	= 0.6m/sec
Required Screen Section Area	= 3,375m ³ /h ÷ (0.6m/s x 60 x 60) = 1.8m ²
Screen Max Water Level	= 1.12m
Screen Bar Thickenes s	= 5mm (Bar Quantity 2,000mm ÷ 30mm = 67pcs)
Screen Wide	= 2,000mm 67pc s x 5mm = 335mm
Effective Width	= 2,000mm - 335mm = 1,665mm 1.12m x 1.665m = 1.86m ²



- ③ [Screen Specification]... (Facility NO. K-2)
- Type : Manual operation type
 - Capacity : 3,875m³/hour
 - Width : Width 2,000mm x 1,200mm
 - Pitch and bar : 30mm, Bar Thickness = 8mm
 - Water top level : 1,000mm
 - Setting Angle : 60 °
 - Material : Stainless steel
 - Quantity : 1 pc
 - Accessories : Hand rake tool 1 unit

(3) Grit chamber (Hopper type)

Design Capacity : 60sec (at hourly peak)

$= 3,875m^3/h \div (60sec/min \times 60min/h) \times 60sec = 64.6m^3$

Dimension : 3.8m x 15.0m x 1.0m (hopper type)

Capacity

$$(V) = \{(3.8 \times 15.0) \times 1.0\} + 0.5/6 \{(3.8 \times 15.0) + (15.0 + 10.0)(3.8 + 2.9) + (2.9 \times 10.0)\}$$

$= 78.1m^3 > 64.6m^3 \quad OK$

- (4) Sand pump
- a) Sand pump capacity $q = 0.5m^3/min$
 - b) Pump outlet size
 - Velocity - 3.0m/sec
 - $\Phi = 146 \sqrt{0.5/3} = 59.6mm \rightarrow 80mm$
 - c) Pump head
 - $v(80) = 0.5m^3 / (60 \times 3.14 / 4 \times 80^2)$
 - $= 1.656m/sec$

Actual pump head (H1) = (V+11.200) - (V+2.600) = 8.6m

Pipe loss head (H2) $30mm = f \times l / D \times v^2 / 2g$ $f = 0.02 + 0.0005/D = 0.0263$

$H2(80) = 0.0263 \times 30 / 0.08 \times (1.656)^2 / 19.6 = 1.380m$

Elbow loss head $H3(80) = 8pcs \times 0.2 \times (1.656)^2 / 19.6 = 0.224m$

Cyclone loss head $H4 = 0.7kg/cm^2 = 7.006m$


Total head = H1 + H2 + H3 = 8.6 + 1.38 + 0.224 + 7.0 = 17.204m $\rightarrow 18m$

d) Power of motor (PS) = $0.163 \times (\gamma \times Q \times H) / \eta \times 1.2 = 0.163 \times (1.1 \times 0.5 \times 18) / 0.50 \times 1.2$
 $= 3.88 \text{kw} \longrightarrow 5.5 \text{kw}$

- ④ [Sand Pump] (Facility NO. M-3)
 Type ; Submersible Sand Pump
 Specification; 80mm x 0.5m³/min x 18m x 5.5kw (380V 50HZ)
 Quantity ; 2pcs (1 pcs Stand-By Warehouse)
 Accessory ; Cable 20m/1pcs, Chain 20m/1pcs (Stainless steel)
- ⑤ [Cyclone] (Facility NO. M-8)
 Type ; Vertical Cyclone Type Capacity; 40m³ /hr
 Specification; approx. 230mm dia. x 1270mmh
 Material ; Frame (Aluminum + Inside Rubber Lined) or equivalent.
 Quantity ; 1 pc
- ⑥ [Grit washer] (Facility NO. M-4)
 Type ; Screw conveyor type ... with air bubbling nozzle 2pc
 Specification; approx. 200 Φ x 5.0m L x 1.5kw (380V 50HZ)
 Quantity ; 1 pc
 Accessory ; Sand Container 0.3m³ (0.7x0.8x0.6h stainless steel) 1pc
- ⑦ [Inlet Gate] (Facility NO. M-1)
 Type ; Power operated type
 Dimension ; 1,400 x 1,400 x 4.2m L x 1.5 kw (380V 50HZ)
 Quantity ; 1 pc
- ⑧ [Chain hoist] (Facility NO. M-7)
 Type ; Power operated type
 Specification; 2.8TON x 6m (380V x 2.4kw + 0.2kw 50HZ)
 Quantity ; 1 pc

(4) Storage Tank

DmaxQ = 55,800m³/day
 Retention Time; RT = 6.0 hour
 Capacity ; V1 = 55,800m³/d x 6/24 = 13,950m³
 V2 = 13,950m³ ÷ 4 line = 3,488m³
 Capacity (Actual) V1 = 10.0 x 50.0 x 3.5 = 1,750m³ /each 1 Line = 2 tank
 V2 = 1,750m³ x 8 tank = 14,000m³ > 13,950m³ OK
 Retention time; (Actual)
 RT = 14,000m³ ÷ (55,800m³/24hr) = 6.02hour > 6.0hr OK



$L(300) = 2.0 + 6.0 + 1.0 + 4.0 = 13.0 \text{m}$
 $L(500) = 15.0 + 4.0 + 2.0 + 0.5 = 27.5 \text{m}$

Raw Water Pump

a) Capacity ; 55,800m³/d ÷ 4 line = 13,950m³/d 1 line
 13,950m³/d ÷ 24 hour = 581.25m³/h = 9.69m³/min 10.0m³/min

b) Pump outlet size; velocity = 2.0 ~ 3.0m/sec
 $\Phi 1 = 146 \sqrt{10.0/2.0 \sim 3.0} = 267\text{mm} \sim 326\text{mm}$ 300mm
 pipe line (1 line 2 pump); $\Phi 2 = 146 \sqrt{20.0/2 \sim 3} = 377\text{mm} \sim 462\text{mm}$ 500mm

c) Actual pump Head ; (H1) = 11.0m - 5.0m = 6.0m
 Piping loss head (HL1) = $f_1 \times L / D \times v^2 / 2g$ $f_1(300) = 0.02 + 0.0005/D = 0.0217$
 $f_1(500) = 0.02 + 0.0005/D = 0.021$
 $v_1(300) = 10\text{m}^3 / (60 \times 3.14 / 4 \times D^2) = 2.36$ $v_2(500) = 20\text{m}^3 / (60 \times 3.14 / 4 \times D^2) = 1.70$
 $HL_1(300) = 0.0217 \times 13 / 0.3 \times (2.36)^2 / 19.6 = 0.268\text{m}$
 $HL_1(500) = 0.027 \times 27.5 / 0.5 \times (1.70)^2 / 19.6 = 0.219\text{m}$

Inlet loss head (HL2) = $f \times v^2 / 2g = 1 \text{pc} \times 1.0 \times (2.36)^2 / 19.8 = 0.282\text{m}$ f=1.0

Tee loss head (HL3) = $f \times v^2 / 2g = 2 \text{pc} \times 1.2 \times (2.36)^2 / 19.8 = 0.564\text{m}$ f=1.2

Check valve loss (HL4) = $f \times v^2 / 2g = 1 \text{pc} \times 1.8 \times (2.36)^2 / 19.8 = 0.507\text{m}$ f=1.8

Elbow loss head (HL5) = $f \times v^2 / 2g = 3 \text{pc} \times 0.3 \times (1.70)^2 / 19.8 = 0.132\text{m}$ f=0.3

Total head (H) = 6.0 + 0.268 + 0.219 + 0.282 + 0.564 + 0.507 + 0.132 = 7.972m > 9.0m

d) Power of motor = $0.163 \times (\gamma \times Q \times H) / \eta \times 1.2$
 $= 0.163 \times (1.0 \times 10 \times 9) / 0.65 \times 1.2 = 27.1\text{kw} \rightarrow 30.0\text{kw}$

① [Specification of Raw water pump] (Facility NO. W-12)
 Type ; Horizontal Sewage Pump (Slurry pump)
 Specification ; 300mm x 10.0m³/min x 9.0m x 30kw (380v, 50hz, 6pole)
 V-belt drive, Mechanical seal type
 Quantity ; 6 pcs (2 pcs spare)

② [Inlet gate for storage tank] (Facility NO. W-9)
 Type ; Movable weir type
 Specification ; 1,000mm W x 300ST
 Quantity ; 2 pcs

③ [Mixing blower for storage tank] (Facility NO. W-50)
 Mixing Air ; 0.5m³ / m³ .hr
 $3,500\text{m}^3 \times 2 \text{line} \times 0.5\text{m}^3 / \text{m}^3 \cdot \text{hr} \times 1/60 = 58.4\text{m}^3 / \text{min}$
 Specification ; Type; Roots Blower 250mm x 59m³ / min x 0.4kg/cm² x 55kw
 Quantity ; 3 pcs (1 pc spare)

④ [Separated gate for storage tank] (Facility NO. W-10)
 Type ; Sluice gate type

- Specification ;500mm x 500mm
- Quantity ;4 pcs
- ⑤ [Diffuser for storage tank] (Facility NO. K-11)
 - Type ;Per-forated pipe
 - Quantity ;20set/1 tank (Total 160 pcs)
- ⑥ [Floor drain pump for storage tank pump room] (Facility NO. K-13)
 - Type ;Submersible pump
 - Specification ;50mmx0.1m³/minx10mx0.75kw
 - Quantity ;2pcs (1pc spare)
- ⑦ [Air flow meter for storage tank] (Facility NO. FI-1)
 - Type ;Orifice type
 - Specification ;200mm Connection (500 ~ 2,800Nm³ /H)
 - Quantity ;8 pcs

(5). Neutralization tank

DmaxQ =55,800m³/day
 Retention Time;RT=20min
 Capacity ;V1=55,800m³/d x20min/(24x60)=775m³
 V2=775m³ ÷ 4 line=194m³
 Capacity (Actual) V1=7.0x7.0x4.0=196m³/each > 194m³ OK
 V2=196m³x4=784m³ > 775m³ OK
 Retention time; (Actual) RT=784/(55,800 ÷ 24 ÷ 60)=20.2min > 20min OK
 Required air for Mixing
 ;q=7.0x7.0x1.0m³/m³.hrx1/60=0.32m³/min...1.0 m³/min...each
 mixing air to be supplied from aeration blower

- ① [Distributor gate for neutralization tank] (Facility NO. K-14)
 - Type ;Movable weir type
 - Specification ;1,000mmWx300ST FC20
 - Quantity ;2 pcs
- ② [Inlet gate for neutralization tank] (Facility NO. K-15)
 - Type ;Sluice gate type
 - Specification ;500mm x500mm
 - Quantity ;4 pcs
- ③ [Diffuser for neutralization tank] (Facility NO. K-16)

- Type ; Disc Type
 Quantity ; 8 pcs/1 line (Total 32 pcs)
- ④ [pH Meter] Scope of machinery section ... (Facility NO, PH-1)
 Type ; Soaking or type (Indicator and Control)
 Quantity ; 4 pcs
 Accessory ; pH-holder 1 pcs/1 pcs, others 1 set/1 pcs
- ⑤ [Buffer plate for neutralization tank] (Facility NO, M-71)
 Type ; Plate type
 Specification ; 1000mmx600mmx3000mmh
 Material ; Stainless steel
 Quantity ; 4 pcs
- ⑥ [Air flow meter for neutralization tank] (Facility NO, FI-2)
 Type ; Orifice type (Flange sandwich type)
 Specification ; 50mm connection (Flow rate; 35~175Nm³ /H)
 Quantity ; 4 pc

(6) Coagulation tank

DmaxQ = 55,800m³/day

Retention time; RT=20min

Capacity ; V1=55,800m³/dx20min ÷ (24x60)=775m³

V2=775m³ ÷ 4=194m³/each

Capacity (Actual); V1=7.0x7.0x4.0=196m³/each > 194m³ OK

V2=194x4pc=784m³..... > 775m³ OK

Retention time; (Actual)

RT=784/(55,800 ÷ 24 ÷ 60)=20.2min > 20min OK

- ① [Mixer for coagulation tank] (Facility NO, M-17)
 Type ; Double paddle type
 Specification; Mixing capacity (194m³), Rotating speed(12rpm)x11kw
 Material ; Stainless steel
 Quantity ; 4 pcs
- ② [Buffer plate for coagulant tank] (Facility NO, M-72)
 Type ; Plate type
 Specification; 1000mmx600mmx3000mmh
 Material ; Stainless steel
 Quantity ; 4 pcs

(7) Caustic Soda Feeding System

Caustic Soda to be used ;45% solid

(pH 4.0 -----> PH 7.0)

$$\text{NaOH} = g = (10^{-4} - 10^{-7}) \text{kg-ion} \times 40 / 1 \times 55,800 \text{m}^3 / \text{d} \times 10$$

$$= 4.0 \times 10^{-4} \times 55,800 \text{m}^3 / \text{d} \times 10 = 2,232 \text{kg/d}$$

NaOH Feed = 2,232kg/d x 90/45 x 1/1.49 = 3,329L/d (Solution Gravity=1.49)

Storage period ; More than 7days/1tank
= 3.33m³/d x 7day = 23.31m³/1 tank

① [Caustic Soda tank] (Facility NO. 3-46)

Capacity ; 30m³

Material ; Mild Steel

Dimension ; Approx 3,000mmΦ x 5,000mmH

Quantity ; 1 pc

Accessory ; Level gauge 1/1 unit

② [Caustic Soda Feeding Pump] (Facility NO. M-47)

Dosing volume ; 3.33m³/day ÷ 4 Line ÷ 1,440 = 0.58L/min

Type ; Uniaxial screw pump

Specification ; 20mmΦ x ~ 1000cc/min x 0.4kw (380V x 50HZ)

Quantity ; 6 pcs (2 pcs spare)

Accessory ; Pressure gauge 6pc/6pcs.

③ [Caustic Soda solution tank unit] (Facility No. 3-70)

Capacity ; 4.2m³ (for 45% Solid -----> 45% Liquid)

Material ; Mild Steel


Dimension ; Approx 2.0mW x 2.0mL x 1.7mH (used depth approx 1.2mH)

Quantity ; 1 pc

Accessory ; (A) Mixer ; 2.2kw x 380V x 50HZ x 1 pc

(B) NaOH transfer pump; 50mm x 40mm x 0.2m³/min x 10m x 1.5kw x 2pcs

(C) Manual Chain Hoist; 1.0ton x 4.0m x 1 pc



∇ HWL
∇ LWL
∇ LLWL

HWL ALARM
LWL ALARM
LLWL FEED PUMP OFF

(8) Aluminium Sulfate Feeding system

Aluminium Sulfate to be used; 8% Liquid (as Al_2O_3) (Gravity-1.08)
 Dosing Rate ; max. 100ppm (as Al_2O_3)
 Required Volume ; $55,800m^3/d \times 100ppm \times 10^{-3} = 5,580kg/d$
 Dosing Volume ; $5,580m^3/d \times 100/8 \times 1/1.08 = 64,584L/d$
 Dosing Volume line ; $64,584L/d \div 4 \text{ Line} \div 1,440 = 11.22L/min$

① Aluminium Sulfate tank.....Scope of Civil works


Storage period ; More than 7day
 ; $64,584L/d \times 7day \times 10^{-3} = 452m^3$
 Material ; RC (Inside...Rubber lined or FRP lined)
 Dimension ; 8.0m x 3.0m x 4.0m 2pcs
 Tank Inside ; FRP or Rubber LinedScope of civil works
 Capacity ; 8.0m x 3.0m x 4.0m x 2pcs = 512m³ > 452m³ OK

② [Aluminium Sulfate Feeding pump].....(Facility NO. K-48)

Dosing volume ; 11.22L/min...1 line
 Type ; Diaphragm pump
 Specification ; 40mm x ~20L/min x 0.75kw (330V x 50HZ)
 Quantity ; 6 pcs (2 pcs spare)
 Accessory ; Pressure gauge 6pcs/6pcs, Safety valve 4pcs/6pcs,
 Back pressure valve 4pcs/6pcs.

③ [Floor drain pump for Dosing pump Room](Facility NO. K-49)

Type ; Submersible pump
 Specification ; 50mm x 0.1m³/min x 10m x 0.75kw (330v 50HZ)
 Quantity ; 2pcs (1pc spare)



w3=attachment weight6.38 kg/pc
 P =flight pitchabout3.0m

$$(W1)=2 \times 11.27 + (37+6.38)/3.0=37\text{kg/m}$$

b)Carried sludge weight(W2), $= (1,000 \times Q \times r) / (60 \times v)$

w2= carried sludge weightkg/m

Q = Raked sludge volume24.0 m³ /hr

r = sludge gravity1.05

v = raking speed0.6m/min

$$(W2)=(1,000 \times 24.0 \times 1.05)/(60 \times 0.6)=700 \text{ kg/m} \dots\dots 700\text{kg/m}$$

c)Primary tension of chain(P1)= 200 kg (2 line)

d)Tension of friction(Raked sludge and bottom of Tank)


$$P2= W2 \times L2 \times \mu 2$$

P2=Tension of friction(sludge and bottom of tank)
 kg

w2=Raked sludge weight.....670kg/m

L2=length of horizontal shaft center...36m

$\mu 2$ =friction coefficiency(sludge to bottom...0.05



$$P2=670 \times 36 \times 0.05 = 1,206 \text{ kg}$$

e) Tension of friction (rail and flight shoe)

$$P3 = W1 \times L \times \mu 1$$

$P3$ = Tension of friction (rail and flight shoe) kg

$W1$ = flight weight 37kg/pc

L = 2 x 1.2 72m

$\mu 2$ = friction of rail and flight shoe 0.3

$$P3 = 37 \times 72 \times 0.3 = 800 \text{ kg}$$

f) Tension of lift up

$$P4 = W1 \times H$$

$P4$ = Tension of lift up kg

$W1$ = flight weight 37kg/pc

H = length of vertical shaft center 3.0m

$$P4 = 37 \times 3.0 = 111 \text{ kg}$$

g) Friction loss of pillow block

$$P5 = (P1 + P2 + P3 + P4) \times 0.1$$

$$P5 = (200 + 1.207 + 800 + 111) \times 0.1 = 232 \text{ kg}$$

h) Tension of chain

$$P = P1 + P2 + P3 + P4 + P5$$

$$P = 200 + 1.206 + 800 + 111 + 232 = 2.549 \text{ kg}$$

i) Power of motor (Drive unit)

$$PS = (n \times P \times v) / (6.120 \times \eta) \times \alpha$$

PS = Power of motor kw

n = Sedimentation tank quantity of drive 2

P = Tension of chain 2.549kg

v = rake speed 0.6m/min

η = Total efficiency 0.7

α = Safety ratio 2

$$PS = \{(2 \times 2.549 \times 0.6) / (6.120 \times 0.7)\} \times 2 = 1.43 \text{ kw}$$

Power of motor 1.5kw

4) Chain strength calculation

a) from tension of chain

chain 2 line tension of one side (P)=70%

$$S = P_o / (0.7 \times P)$$

S = Safety ratio of chain

P_o = Average breaking strength of chain 19,000kg

P = Tension of chain 2,549kg

$$S = 19,000 / (0.7 \times 2,549) = 10.7$$

b) Tension of chain from motor torque

① Tension of chain from motor output

$$T = (6,120 \times PS \times \eta \times f_o) / v$$

PS = Output of motor 1.5 kw

η = Total efficiency 0.7

f_o = Coefficiency (one side chain for total load) 0.7

v = Rake speed 0.6m/min

$$T = (6,120 \times 1.5 \times 0.7 \times 0.7) / 0.6 = 7,497 \text{kg}$$

② Safety ratio of chain

$$S = P_o / T$$

P_o = Average breaking strength of chain 19,000kg

T = Tension of chain 7,497kg

$$S = 19,000 / 7,497 = 2.53$$

5) Calculation Strength of drive shaft

$$M_t = 97,370 \times PS / r \times \eta$$

$$M_t = \pi / 16 \times d^3 \times \tau$$

$$d = \sqrt[3]{M_t \times 16 / (\pi \times \tau)}$$

$$= \sqrt[3]{97,370 \times (16 \times PS \times \eta) / (\pi \times \tau \times r)}$$

$$= 116 \times \sqrt[3]{(PS \times \eta) / (\pi \times \tau \times r)}$$

M_t ; twist moment of drive shaft kg-cm

PS ; power of drive motor 1.5kw

η ; drive efficiency 0.78

τ ; twist stress allowed 860 kg/cm²

r ; rotation of drive shaft 0.358rpm

d) Pump head (Primary sedimentation tank \rightarrow Sludge Thickener)

$$\text{Actual head (H1)} = (\nabla + 12.0\text{m}) - (\nabla + 2.5\text{m(max)}) = 9.5\text{m}$$

$$\text{Pipe length } L(150) = 15\text{m} + 80\text{m} + 65\text{m} + 45\text{m} + 2\text{m} + 3\text{m} = 220\text{m} \dots\dots$$

$$L(80) = 2\text{m} + 2\text{m} + 2\text{m} + 3\text{m} = 9\text{m}$$

Loss head

$$\text{Inlet mouth loss } H2(80) = f \times v^2 / 2g \quad f = 1.0$$

$$v(80) = 0.2\text{m}^3 / (60 \times 3.14 / 4 \times D^2) = 0.663\text{m/sec}$$

$$v(150) = 0.8\text{m}^3 / (60 \times 3.14 / 4 \times D^2) = 0.755\text{m/sec}$$

$$= 1.0 \times (0.663)^2 / 19.6 = 0.023\text{m}$$

$$\text{Piping loss } H3(80) = f1 \times L/D \times v^2 / 2g$$

$$f1(80) = 3.02 + 0.0005/D = 0.0263$$

$$f1(150) = 0.02 + 0.0005/D = 0.0234$$

$$= 0.0263 \times 10 / 0.08 \times (0.663)^2 / 19.6 = 0.074\text{m}$$

$$H4(150) = 0.0234 \times 220 / 0.15 \times (0.755)^2 / 19.6 = 0.999\text{m}$$

$$\text{Tee loss } H5(80) = f \times v^2 / 2g \quad f = 1.2$$

$$= 1.2 \times (0.663)^2 / 19.6 \times 2\text{pc} = 0.054\text{m}$$

$$H6(150) = 1.2 \times (0.755)^2 / 19.6 \times 2\text{pcs} = 0.070\text{m}$$

$$\text{Elbow loss } H = f \times v^2 / 2g \quad f = 0.2$$

$$H7(80) = 0.2 \times (0.663)^2 / 19.6 \times 1\text{pc} = 0.005\text{m}$$

$$H8(150) = 0.2 \times (0.775)^2 / 19.6 \times 5\text{pcs} = 0.031\text{m}$$

$$\text{Gate valve loss } H9(80) = f \times v^2 / 2g \quad f = 0.168$$

$$= 0.168 \times (0.663)^2 / 19.6 \times 5\text{pcs} = 0.089\text{m}$$

$$H10(150) = f \times v^2 / 2g \quad f = 0.145$$

$$= 0.145 \times (0.775)^2 / 19.6 \times 6\text{pcs} = 0.028\text{m}$$

$$\text{Check valve loss } H11(80) = f \times v^2 / 2g \quad f = 1.8$$

$$= 1.8 \times (0.663)^2 / 19.6 \times 1\text{pc} = 0.041\text{m}$$

$$\text{Total head} = H1 + H2 + H3 + H4 + H5 + H6 + H7 + H8 + H9 + H10$$


$$= 9.5 + 0.024 + 0.074 + 0.999 + 0.054 + 0.07 + 0.005 + 0.031 + 0.089 + 0.028$$

$$+ 0.041$$


$$= 10.915\text{m}$$

Safety ratio of sludge ; 50%(98% Sludge)

$$= 10.915\text{m} \times 1.5 = 16.37\text{m} \longrightarrow 17.0\text{m}$$




SLUDGE DISTRIBUTION TANK




SLUDGE PUMP

150φ 0.8 m³/min

200φ 2.4 m³/min



P.S.T. SLUDGE LINE



F.S.T. SLUDGE LINE

e) Power of motor

$$PS = 0.163 \times (\gamma \times Q \times H) / \eta \times \alpha$$

PS ; Power of motor	kw
γ ; Gravity of sludge	1.05
Q ; Flow volume	0.2m ³ /min
H ; Total head	17.0m
η ; Efficiency of pump	30%
α ; Safety ratio	1.2

$$PS = 0.163 \times (1.05 \times 0.2 \times 17.0) / 0.30 \times 1.2 = 2.33 \text{ kw} > 3.7 \text{kw Ok}$$

③ [Specification of sludge pump for P. S. T.] (Facility NO. M-21)

Type ; Horizontal sludge pump
 Specification; 80x80mmx0.2m³/minx15mx3.7kw (380Vx50HZ)
 Quantity ; 6 pcs(2 pcs spare)

④ [Sludge distribution tank]..... (Facility NO. M-43)

Type ; Weir type Dimension; 1.600Wx3000Lx1000H(Stainless steel)
 Quantity ; 1 pc


8) Scum transfer pump for P. S. T..... (To raw waste water pumping station)

- a) Scum transfer volume; 0.874m³ /min \longrightarrow 0.88m³/min
- b) Pump diameter ; D1=146 $\sqrt{Q/v}$ = 146 $\sqrt{0.88/(1.5 \sim 3.0)}$
 $= 79 \sim 112 \text{mm} \longrightarrow 100 \text{mm}$
 $v(100) = 0.88 \text{m}^3 / (60 \times 3.14 / 4 \times D^2) = 1.869 \text{m/sec}$

c) Pump head

- Actual head (H1) = (∇ +9.200) - (∇ +6.240) = 2.96m
- Pipe length = 5.5+3.0+35.0+110.0+60.0+21.0+5.5=240m \longrightarrow 250m
- Loss head
- Piping loss H2(100) = $f_1 \times L/D \times v^2 / 2g$ $f_1(100) = 0.02 + 0.0005/D = 0.025$
 $= 0.025 \times 250 / 0.1 \times (1.869)^2 / 19.6 = 11.139 \text{m}$
- Elbow loss H3(100) = $f \times v^2 / 2g$ $f = 0.2$
 $= 0.2 \times (1.869)^2 / 19.6 \times 9 \text{pcs} = 0.321 \text{m}$
- Check valve loss H4(100) = $f \times v^2 / 2g$ $f = 1.8$
 $= 1.8 \times (1.869)^2 / 19.6 \times 1 \text{pc} = 0.321 \text{m}$
- Gate valve loss H5(100) = $f \times v^2 / 2g$ $f = 0.164$
 $= 0.164 \times (1.869)^2 / 19.6 \times 1 \text{pc} = 0.030 \text{m}$

Total head $H = H_1 + H_2 + H_3 + H_4 + H_5$
 $= 2.96 + 11.139 + 0.321 + 0.321 + 0.03 = 14.771 \text{m} \longrightarrow 16 \text{m}$



NOTE: (P₁, P₂, P₃, P₄) EACH PUMP WILL BE OPERATED SIMULTANEOUSLY.

d) Power of motor $PS = 0.163 \times (\gamma \times Q \times H) / \eta \times 1.2$

PS ; Power of motor kw
 γ ; Gravity of scum 1.0
 Q ; Flow volume 0.88m³/min.....0.9m³/min
 H ; Total head 16.0m
 η ; Efficiency of pump 60 %
 α ; Safety ratio 1.2

$PS = 0.163 \times (1.0 \times 0.9 \times 16.0) / (0.60) \times 1.2 = 4.695 \text{kw} \rightarrow 5.5 \text{kw}$

Scum pit Scope of civil works

Scum pit capacity; Retention time 10min x 1 pc = 0.88m³/min x 10min = 8.8m³

Scum pit dimension; 1.2mW x 3.0mL x 2.5mH

Scum pit volume = 1.2 x 3.0 x 2.5 = 9.0m³ > 8.8m³ OK

④ [Inlet gate for P.S.T.] (Facility NO. #-18)

Type ; Sluice gate

Specification; 400W x 400H

Quantity ; 8 pcs

⑤ [Scum transfer pump for P.S.T.] (Facility NO. #-22)

Flow route ; Scum pump pit → (to raw waste water pumping station)

Type ; Submersible pump

Specification; 100mm x 0.9m³/min x 16m x 5.5kw

Quantity ; 4 pcs (2pcs spare ... warehouse)

Accessories ; Cable 10m/1pc, Chain 6m/1pc (Stainless steel), Guide pipe 1set/1pc, (Stainless steel), Automatic connection 1set/1pc

⑥ [Floor drain pump for P.S.T. pump room] (Facility NO. #-23)

Flow route ; floor pump pit → Primary sedimentation tank

Type ; Submersible pump

Specification; 50mm x 0.1m³/min x 10m x 0.75kw

Quantity ; 2 pcs (1pc spare)

⑦ [Scum screen] (Facility NO. #-6)

Type ; Wedge-wire screen

Specification; 1200W x 1,200H Pitch 2.0mm 60m³/hr stainless steel

Quantity ; 1pc

Accessory ; Scum container 350mm x 600mm x 400mm 2pcs/1pc
 (stainless steel net)

(9) Aeration tank

$$D_{max} = 55,800 \text{ m}^3/\text{day}$$

$$\text{BOD-SS Load} = 0.2 \sim 0.5 \text{ kg/kg. SS. day}$$

$$\text{MLSS} = 1,000 \sim 3,000 \text{ mg/L}$$

Aeration time = more than 6.0 hour

Influent Quantity

$$\text{BOD(in)} = 55,800 \text{ m}^3/\text{day} \times 330 \text{ ppm} (1-0.30) \times 10^{-3} = 12,889.8 \text{ kg-BOD/day}$$

$$\text{BOD(PPM)} = 12,889.8 / 55,800 \times 10^3 = 231 \text{ mg/L}$$

$$\text{SS(in)} = 55,800 \text{ m}^3/\text{day} \times 380 \text{ ppm} (1-0.4) \times 10^{-3} = 12,722.4 \text{ kg-SS/day}$$

$$\text{SS(ppm)} = 12,722.4 / 55,800 \times 10^3 = 228 \text{ mg/L}$$

$$\text{Capacity(V1)} = 55,800 \times 6.0 / 24 = 13,950 \text{ m}^3$$

$$(V2) = 12,889.8 / (0.30 \times 2,000) \times 10^3 = 21,482 \text{ m}^3$$

$$= 21,482 \text{ m}^3 \div 4 \text{ Line} = 5,371 \text{ m}^3 \text{ (each)}$$

$$\text{Depth (H)} = 5.0 \text{ m}$$

$$\text{Dimension} = 15.0 \text{ m} \times 72.0 \text{ m} \times 5.0 \text{ m} \times 4 \text{ pcs}$$

Surface Area = (Actual)

$$(SA) = 15.0 \times 72.0 \times 4 \text{ line} = 4,320 \text{ m}^2$$

$$= 4,320 \text{ m}^2 \div 4 \text{ line} = 1,080 \text{ m}^2 \text{ (each)}$$

Capacity (Actual)

$$(V) = 15.0 \times 72.0 \times 5.0 \times 4 \text{ line} = 21,600 \text{ m}^3$$

$$= 21,600 \text{ m}^3 \div 4 \text{ line} = 5,400 \text{ m}^3 \text{ (each)}$$

BOD-SS Load (Actual)

$$L(\text{BOD-SS}) = 12,889.8 / (21,600 \times 2,000 / 10^3) = 0.298 \text{ kg-BOD/kg-SS/day}$$

OK

Aeration time (Actual)

$$T_a = 21,600 / (55,800 / 24) = 9.29 \text{ hour} \quad \text{OK}$$

BOD Volume Load (Actual)

$$L(\text{BOD.V}) = 12,889.8 / 21,600 = 0.597 / \text{m}^3 \cdot \text{day} \quad \text{OK}$$

Return Sludge Volume ;

$$\text{Return Sludge Rate; } R_r = (\text{MLSS} - \text{SS(in)}) / (\text{Cr} - \text{MLSS}) \times 10^{-2}$$

$$\text{Cr} = \text{Return sludge generation ratio} (= 3,000 \text{ mg/L})$$

$$R_r = (2,000 - 223) / (3,000 - 2,000) \times 10^{-2} = 29.53\%$$

(Max 50%)

$$\text{RSV} = D_{max} Q \times R_r / 10^2 = 55,800 \times 29.53 / 10^2 = 16,477.74 \text{ m}^3/\text{day}$$

$$= 11.44 \text{ m}^3/\text{min}$$

Aeration time of influent sludge(Actual):

$$SA = \frac{V(AT) \times MLSS}{10^3 \times SS(in)}$$

$$= \frac{21,600 \times 2,000}{10^3 \times 12,722.4} = 3.40 \text{ day} \quad OK$$

$$(2.0 < SA < 4.0 \text{ day})$$

Sludge retention time(Actual)

$$SRT = \frac{V(A.T.) \times MLSS + V(F.S.T.) \times MLSS}{(Q_w \times Cr + D_{max}Q \times SSo)}$$

V(A.T.) ; Aeration tank capacity = 21,600 m³

V(F.S.T.); Final sedimentation tank capacity = 6,975 m³

Q_w ; Sludge volume at Final sedimentation tank = 1,380.38 m³/d

Cr ; Return sludge generation ratio = 8,000 mg/L

SSo ; Treated waste water Quantity = 30 mg/L

$$SRT = \frac{(21,600 \times 2,000 + 6,975 \times 2,000)}{(1,380.38 \times 8,000 + 55,800 \times 30)}$$

$$= 4.50 \text{ day}$$

Aeration;

Required Oxygen = $D_{max}Q \times BOD(in) \times \{1 - R(P)\} \times R(F) \times 10^3 \times 35 \text{ m}^3/\text{kg-BOD}$

R(P); Removal rate at Primary sedimentation tank = 30.0%

R(F); Removal rate at Aeration tank + Final sedimentation tank = 91.4%

$$\text{Required Oxygen} = 55,800 \times 330 \times (1 - 0.30) \times 0.914 \times 10^3 \times 35$$

$$= 412,345 \text{ m}^3/\text{day} = 286.35 \text{ m}^3/\text{min}$$

a) Required air

$$\text{Blower ; } q_1 = (286.35 \text{ m}^3/\text{min} + 4.0 \text{ m}^3/\text{min}) \div 8 \text{ pcs} = 36.3 \text{ m}^3/\text{min}$$

4.0 m³/min ; Neutralization tank mixing air

b) Aeration system

Type ; Circulation aeration by blower

(This method is popular for standard activated sludge system.)

c) Bubbling type

Type ; Fine bubble type

(This type is effective on O₂ dispersion and O₂ transfer in the tank, and of energy saving type.)

d) Capacity and quantity of air diffuser

- (1) Air capacity of 1 line..... $g = Q/N$
 Q ; Required air in total = 286.35 m³/min
 N ; Line quantity = 8
 $g = 286.35/8 = \text{approx } 35.8 \text{ m}^3/\text{min}$
- (2) Nos. of diffuser/line
 $n = (1000 \times q) / q_1$
 q , Diffuser capacity / line = 35.8 m³/min
 q_1 ; Maximum capacity of a diffuser = 200 ℓ /min
 $N = (1,000 \times 35.8 \text{ m}^3) / 200 = 179 \text{ pcs} \longrightarrow 180 \text{ pcs/1 line}$
- (3) Air capacity of a diffuser
 $q_2 = (1,000 \times q) / n$
 q ; Air capacity of 1 line = 35.8 m³/min
 n ; Diffuser quantity per 1 line = 180 pcs
 $q_2 = (1,000 \times 35.8) / 180 = 198.9 \text{ ℓ /min. pc}$

e) Measurement of air capacity and control

- Measurement method of air capacity \longrightarrow 1 line 1 flowmeter
 Control method of air capacity \longrightarrow 1 line 1 control valve
 (manual operation)
 Air capacity control of blower \longrightarrow Controlled by numbers of unit
 operating (manual operation)

① [Air diffuser for aeration tank]..... (Facility NO. K-28)

- Type ; Fine bubble diffuser (cylindrical diffuser)
 Air capacity; approx 200 ℓ /min. pc x 2
 Material ; ABS Plastic
 Dimension ; 70 Φ x 1,130mm connection ; 25mm PT thread
 Pressure loss; approx 100mmHg
 Quantity ; Hanger pipe (stainless steel) 90 set / 1 line x 8 line = 720 set
 (with double diffuser / 1 set)

② [Return sludge inlet gate]..... (Facility NO. K-24)

- Type ; Movable weir type
 Specification; 500W x 300ST
 Material ; FC20
 Quantity ; 8 pcs

g) Decision of aeration tank inlet movable weir

(1) Decision of weir width

Type ; four-sided weir

Over flow maximum water level; approx 200mm

Nos. of line ; 4 line

Flow volume of 1 movable weir

$$Q_1 (\text{Inlet volume}) = Q_{\text{max}}/4 = 55,800/4 = 13,950 \text{ m}^3/\text{day} = 0.1615 \text{ m}^3/\text{sec} (\text{1 line})$$

$$B = Q_1 / (1.84 \times H^{3/2}) \longrightarrow H = 0.2 \text{ m}$$

$$= 0.1615 / (1.84 \times 0.2^{3/2})$$

$$= 0.981 \text{ m} \longrightarrow \text{Weir width} = 1,000 \text{ mm}$$

(2) Over flow water depth of design flow volume

$$H = \left(\frac{Q}{1.84 \times b} \right)^{2/3} = \left(\frac{0.1615}{1.84 \times 1.0} \right)^{2/3} = 0.198 \text{ m}$$

(3) Aeration tank control method

Control of each aeration tank (in-flow volume, air capacity, return sludge volume) is made manually.

In-flow movable weir is operated manually


Aeration tank in-flow movable weir

Type ; movable weir made of cast iron

Dimension; width 1,000mm x 300mm ST

Stroke ; approx 300mm

Quantity ; 8 pcs



(10) Aeration blower equipment

a) Air capacity of blower

1 unit blower capacity (see 24 page): $36.3 \text{ m}^3 / \text{min} \longrightarrow 37.0 \text{ m}^3 / \text{min}$

b) Diameter of blower

$$D = 146 \sqrt{Q/V}$$

D ; Diameter of blower mm

Q ; Air capacity $37.0 \text{ m}^3 / \text{min}$

V ; Wind velocity $20 \sim 30 \text{ m/sec}$

$$D = 146 \sqrt{37 / (20 \sim 30)} = 162 \sim 198.6 \text{ mm} \longrightarrow 200 \text{ mm}$$

c) Pressure of blower

$$H = h_d - h_s$$

H ; Pressure of blower mmaq

hd ; Outlet pressure of blower mmaq

hs ; Inlet pressure of blower mmaq

(1) Outlet pressure of blower (hd)

1) Friction loss of outlet pipe (See page 32)

$$hd1 = 230 \text{ mmaq}$$

2) Loss of diffuser

$$hd2 = 100 \text{ mmaq}$$

3) Loss of air flow meter

$$hd3 = 50 \text{ mmaq} \times 1 \text{ pcs} = 50 \text{ mmaq}$$

4) Water pressure

$$hd4 = (\text{water level of aeration tank}) - (\text{Setting level of diffuser})$$

$$= 8.160 - 3.660 = 4.500 \text{ mmaq}$$

5) Clogging of diffusers

$$hd5 = 50 \text{ mmaq/year} \times 10 \text{ year} = 500 \text{ mmaq}$$

Total outlet pressure

$$hd = hd1 + hd2 + hd3 + hd4 + hd5$$

$$= 230 + 100 + 50 + 4.500 + 500 = 5.380 \text{ mmaq}$$

(2) Inlet pressure of blower (hs)

1) Friction loss of inlet pipe

$$hs1 = -65 \text{ mmaq (See page 31)}$$

2) Dry filter loss

$$hs2 = -20 \sim -30 \text{ mmaq}$$

Total inlet pressure

$$hs = hs1 + hs2$$

$$= (-65) + (-20 \sim -30) = (-85 \sim -95 \text{ mmaq}) \longrightarrow 95 \text{ mmaq}$$

(3) Required pressure (H)

$$H = 5.380 - (-95) = 5.475 \text{ mmaq} \longrightarrow 5.500 \text{ mmaq}$$

d) Friction loss of piping

1) Method of calculation

Temperature ; at 20°C

Humidity ; at 65%

Atmospheric pressure ; 1.322 mmaq

2) Calculation

(1) Friction of straight pipe

$$\Delta h = \lambda \times L/D \times v^2 / 2g \times \gamma \quad (\text{mmaq})$$

 λ ; Coefficiency of friction

L ; Pipe length m

D ; Pipe diameter 0.2 m

v ; Velocity of wind m/sec

g ; Accelation of gravity 9.8 m/sec² γ ; Gravity of air 1.198 kg/m³ λ ; Coefficiency of roughness = ϵ / D and Reynolds (Re) \longrightarrow Moody curve

$$\text{Reynolds (Re)} = (v \times D) / \nu$$

 ϵ ; 0.15 mm (Galvanized pipe) ν ; coefficiency $1.5 \times 10^{-5} \text{ m}^2/\text{sec}$

(2) Friction loss of elbow tee valve and other

$$\Delta h = f \times (V^2) / 2g \times \gamma \quad (\text{mmHg})$$

f ; coefficient of friction
 v ; velocity m/sec
 g ; acceleration of gravity 9.8 m/sec²
 γ ; gravity of air 1.198 kg/m³

(3) Calculation of air gravity

(3)-1 Air gravity of standard condition

$$\gamma = \gamma_0 \times (273) / (273+t) \times (h - 0.378 \times \phi \times F) / h_0 \quad (\text{kg/m}^3)$$

γ_0 ; Air gravity (0°C, 760mmHg) 1.293 kg/m³
 t ; Temperature (standard condition) 20°C
 ϕ ; Relative atmosphere (standard condition) 0.65
 F ; Saturated vapor pressure (standard condition) 238.3 mmHg
 h_0 ; Relative pressure (standard condition) 10332 mmHg
 h ; Atmospheric pressure 10322 mmHg
 $\gamma = 1.293 \times (273) / (273+20) \times (10322 - 0.378 \times 0.65 \times 238.3) / 10332$
 $= 1.198 \text{ kg/m}^3$

(3)-2 Air gravity of inlet side (γ_s)

$$\gamma_s = \gamma \times h_s / h \times T / T_s \quad (\text{kg/m}^3)$$

γ ; Gravity of air (standard condition)
 h ; Relative pressure (standard condition) 10332 mmHg
 T ; Relative temperature (standard condition) 293° K
 h_s ; Relative pressure of inlet side 10132 mmHg
 T_s ; Relative temperature of inlet side 293° K
 $\gamma_s = 1.198 \times 10132 / 10332 \times 293 / 293$
 $= 1.175 \text{ kg/m}^3$

(3)-3 Air gravity of outlet side (γ_d)

$$\gamma_d = \gamma \times h_d / h \times T / T_d \quad (\text{kg/m}^3)$$

$$T_d = T_s + T_s / \eta \theta \{ (h_d / h_s)^{0.4} - 1 \}$$

γ ; Air gravity (standard condition) 1.198 kg/m³
 h ; Relative pressure (standard condition) 10332 mmHg
 T ; Relative atmosphere (standard condition) 293° K
 h_d ; Relative pressure of outlet side (10332+5500) 15832 mmHg
 T_d ; Relative temperature of outlet side ° K

h_s ; Relative pressure of inlet side 10132mmaq
 T_s ; Relative temperature of inlet side 293° K
 η ; Adiabatic efficiency temperature 0.7
 $T_d = 293 + 293/0.7 \times ((15832/10132)^{1.4-1}/1.4 - 1)$
 $= 350$ ° K
 $\gamma_d = 1.198 \times 15832/10332 \times 293/350$
 $= 1.537$ kg/m³

(4) Revision of air capacity and air gravity

$G = \gamma \times Q = \gamma_s \times Q_s = \gamma_d \times Q_d$
 Q ; Air capacity m³/min
 Q_s ; Air capacity of inlet side m³/min
 Q_d ; Air capacity of outlet side m³/min
 $Q_s = \gamma / \gamma_s \times Q$
 $Q_d = \gamma / \gamma_d \times Q$

Friction loss of straight pipe

$\Delta h = k_1 \times (v^2) / 2g \times \gamma$
 $= k_2 \times Q^2 \times \gamma$ (k₁, k₂ ; constant)
 $\Delta h_{s1} = k_2 \times Q^2 \times \gamma$
 $= k_2 (\gamma / \gamma_s \times Q)^2 \times \gamma_s$
 $= (k_2 \times Q^2 \times \gamma) \times \gamma / \gamma_s$
 $= K_s \times \Delta h$ (K_s = γ / γ_s ; value of revise)
 result $\Delta h_{s1} = K_d \times \Delta h$ (K_d = γ / γ_d ; value of revise)

(5) Decision of friction loss inlet side and outlet side

(5)-1 Friction loss of inlet side (Δh_{s1})

See calculation table.....P/37 $\Delta h = 63.6$ mmaq
 $\Delta h_{s1} = K_s \times \Delta h$
 $= 1.198/1.175 \times 63.6$
 $= \text{approx } 65$ mmaq

(5)-2 Friction loss of outlet side (Δh_{d1})

See calculation table.....P/37 $\Delta h = 295.1$ mmaq

$$\begin{aligned}\Delta h d_1 &= K d \times \Delta h \\ &= 1.198 / 1.537 \times 295.1 \\ &= 230 \text{ mmaq}\end{aligned}$$

⑥ [Aeration blower specification] (Facility NO, M-52)


Type ; Roots blower
 Specification; 200A x 37.0m³ /min x 5500mmaq x 55.0kw
 Quantity ; 12unit (stand-by 4unit)
 Accessory ; per one unit
 Inlet silencer 1pc. Outlet silencer 1pc
 Safety valve 1pc. Pressure guage 1pc
 V-belt 1set Belt cover 1pc
 Flexible joint 1pc. Anchor bolt 1set
 Base 1pc Unti-Swing rubber 1set

⑦ [AirFlow meter] (Facility NO, FI-3)

Type ; Orifice type
 Size ; 300A (1,600 ~ 7800Nm³ /hr) One scale 200Nm³ /hr
 Flange sandwich type
 Quantity ; 8pcs
 Accessory ; cock piece and handle 1pc/1pc

⑧ [Chain hoist for blower house] (Facility NO, M-54)

Type ; Power operated type
 Specification ; 2.0 T x 4.0m x hoisting 1.5kw + travelling 0.4kw
 Quantity ; 2 set



AIR LINE FOR AERATION BLOWER




図 3.42 MOODY CURVE
 ムーディの図

e) Calculation table of air piping(friction loss)

Name	Dia Dmm	Length(m) pcs	capacity Qm3/min	velocity vm/sec	calculation	coeff- iciency	Loss head mmaq
①~②					$\gamma = 1.198$	λ	
Straight pipe	200	3.0	37.0	19.6	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.015	5.3
Inlet mouth	200	1	37.0	19.6	$f \times v^2 / 2g \times \gamma$	0.62	14.5
90° elbow	200	1	37.0	19.6	"	0.36	8.5
Silencer	200	1	37.0	19.6	"	1.5	35.3
(Total)							(63.6)
②~③							
Straight pipe	200	5.0	37.0	19.6	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.015	8.8
Check valve	200	1	37.0	19.6	$f \times v^2 / 2g \times \gamma$	2.0	47.0
Gate valve	200	1	37.0	19.6	"	0.1	2.4
90° elbow	200	1	37.0	19.6	"	0.36	8.5
Silencer	200	1	37.0	19.6	"	1.5	35.3
Tee	800	1	37.0	4.9	"	1.23	1.8
(Total)							(103.8)
③~④							
Straight pipe	800	6.0	148.0	4.9	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.014	0.2
Tee	800	1	148.0	4.9	$f \times v^2 / 2g \times \gamma$	1.23	1.8
(Total)							(2.0)
④~⑤							
Straight pipe	800	30.0	148.0	4.9	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.014	0.8
90° elbow	800	2	148.0	4.9	$f \times v^2 / 2g \times \gamma$	0.36	1.1
(Total)							(1.9)
⑤~⑥							
Straight pipe	800	26.0	296.0	9.9	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.013	2.9
90° elbow	800	2	296.0	9.9	$f \times v^2 / 2g \times \gamma$	0.36	4.3
(Total)							(7.2)

Name	Dia. Dmm	Length(m) pcs	capacity Qm ³ / min	velocity v m/sec	caluculation	coeff- iciency	Loss head mmaq
⑥~⑦							
Straight pipe	800	15.5	259.0	8.6	$\lambda xL/Dxv^2 / 2gx \gamma$	0.013	1.2
(Total)							(1.2)
⑦~⑧							
Straight pipe	700	15.5	222.0	9.6	$\lambda xL/Dxv^2 / 2gx \gamma$	0.014	1.8
Down reducer	700	1	222.0	9.6	$f xv^2 / 2gx \gamma$	0.06	0.4
(Total)							(2.2)
⑧~⑨							
Straight pipe	700	15.5	185.0	8.0	$\lambda xL/Dxv^2 / 2gx \gamma$	0.014	1.3
(Total)							(1.3)
⑨~⑩							
Straight pipe	600	15.5	148.0	8.7	$\lambda xL/Dxv^2 / 2gx \gamma$	0.014	1.8
Down reducer	600	1	148.0	8.7	$f xv^2 / 2gx \gamma$	0.06	0.3
(Total)							(2.1)
⑩~⑪							
Straight pipe	500	15.5	111.0	9.6	$\lambda xL/Dxv^2 / 2gx \gamma$	0.014	2.5
(Total)							(2.5)
⑪~⑫							
Straight pipe	400	15.5	74.0	9.8	$\lambda xL/Dxv^2 / 2gx \gamma$	0.012	2.8
(Total)							(2.8)
⑫~⑬							
Straight pipe	400	15.5	37.0	4.9	$\lambda xL/Dxv^2 / 2gx \gamma$	0.012	0.7
(Total)							(0.7)
⑬~⑭							
Straight pipe	300	7.0	37.0	8.8	$\lambda xL/Dxv^2 / 2gx \gamma$	0.017	1.9
Tee	300	1	37.0	8.8	$f xv^2 / 2gx \gamma$	1.23	5.9
90° elbow	300	2	37.0	8.8	"	0.36	0.4
B. F valve	300	1	37.0	8.8	"		50.0
(Total)							(58.2)

Name	Dia. Dmm	Length(m) pcs	capacity Qm ³ /min	velocity vm/sec	caluculation	coeff- iciency	Loss head mmaq
④~⑤							
Straight pipe	300	18.0	37.0	8.8	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.017	4.9
(Total)							(4.9)
⑤~⑥							
Straight pipe	250	18.0	27.8	9.5	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.018	7.2
Down reducer	250	1	27.8	9.5	$f \times v^2 / 2g \times \gamma$	0.06	0.4
(Total)							(7.6)
⑥~⑦							
Straight pipe	200	18.0	18.5	9.9	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.018	9.7
Down reducer	200	1	18.5	9.9	$f \times v^2 / 2g \times \gamma$	0.06	0.4
(Total)							(10.1)
⑦~⑧							
Straight pipe	150	18.0	9.3	8.8	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.019	10.8
Down reducer	150	1	9.3	8.8	$f \times v^2 / 2g \times \gamma$	0.06	0.3
(Total)							(11.1)
⑧~⑨							
Straight pipe	40	6.5	0.4	5.3	$\lambda \times L / D \times v^2 / 2g \times \gamma$	0.028	7.8
Tee	40	2	0.4	5.3	$f \times v^2 / 2g \times \gamma$	1.23	2.1
Grove valve	40	1	0.4	5.3	"		50.0
90° elbow	40	1	0.4	5.3	"	0.36	0.6
(Total)							(60.5)
Friction loss of inlet side (Total)							(63.6mmaq)
Friction loss of outlet side (Total)							(295.1mmaq)

e) Calculation of motor power (Blower)

(1) Average of available pressure (h)

$$h = h_s \times K / (K - 1) \times \left\{ (h_d / h_s)^{(K-1)/K} - 1 \right\}$$

h_s ; Rerative pressure (inlet side)	(10332-200)	= 10132 mmaq
h_d ; Rerative pressure (outlet side)	(10332+5480)	= 15812 mmaq
K ; Cocfficiency		= 1.4

$$h = 10132 \times 1.4 / (1.4 - 1) \times \left\{ (15812 / 10132)^{1.4 / 1.4 - 1} - 1 \right\}$$

$$= 4809 \text{ mmaq}$$

(2) Adiabatic air power of blower (P_1)

$$P_1 = (h \times (Q \times h_0 / h_s)) / 6.120$$

h ; Average of available pressure	=	4809 mmaq
Q ; Suction air capacity	=	37.0 m ³ /min
h_s ; Rerative pressure (inlet side)	=	10132 mmaq
h_0 ; Atmospheric pressure	=	10332 mmaq

$$P_1 = (4809 \times (37 \times 10332 / 10132)) / 6.120$$

$$= 29.65 \text{ KW}$$

(3) Motor power of blower (P_s)

$$P_s = P_1 / \eta \times T_s / T \times \alpha$$

P_1 ; Adiabatic air power of blower	=	29.65 KW
η ; Total adiabatic efficiency	=	0.63
T_s ; Rerative temperature of inlet side (273+35.4)	=	308.4 ° K
T ; Minimum temperature (273+10.4)	=	283.4 ° K
α ; Safety ratio	=	1.05

$$P_s = 29.65 / 0.63 \times 308.4 / 283.4 \times 1.05$$

$$= 53.8 \text{ KW} \longrightarrow 55.0 \text{ kw}$$

(10) Final sedimentation tank

$D_{max}Q = 55,800m^3/d$

Over flow rate = less than $25(20)m^3/m^2 \cdot day$ at $D_{max}Q$

Retention time = 1.8 ~ 3.0 hour at $D_{max}Q$

Capacity (v) = $55,800 \times 3.0 / 24 = 6,975m^3$ $6,975m^3 \div 4 \text{ line} = 1,744m^3(\text{each})$

Depth (H) = 2.5m

Dimension = 10.0mW x 70.0mL x 2.5mh x 4 pcs

[Return Sludge, to Aeration tank]

Maximum Return Sludge Ratio = 50%

$q = 55,800 \times 0.5 = 27,900m^3/day = 6,975m^3/day \cdot \text{each} \times 4 \text{ pcs}$

$= 290.7m^3/hr (= 4.85m^3/min) \times 4 \text{ pcs}$

[Sludge Generation]

Sludge Generation Ratio;

as 40.0% (Primary Sedimentation Tank)

as 86.8% (Aeration Tank + Final Sedimentation Tank)

SS Concentrate of Sludge; as 0.8 wt%

Removal SS = $55,800 \times 380 \times (1-0.4) \times 0.868 \times 10^{-3}$

$= 11,043kg-SS/day$ $11,043 \div 4 \text{ line} = 2,761kg-SS/day \cdot \text{each}$

$= 2,761kg-SS/day \cdot \text{each} \times 4 \text{ line}$

[Sludge Volume]

$SV = 11,043 / 0.008 \times 10^{-3}$

$= 1,380.38m^3/day$

$= 345.10m^3/day \cdot \text{each} \times 4 \text{ line}$

[Auxiliary equipment]

① Rake ; Chain flight double link type ... (5mwx2set) x 4 line

② Scum skimmer ; 300mm Pipe skimmer ... 8set

③ Return sludge pump; 4.9m³/min ... 6pcs (2pcs)

④ Sludge pump ; $q = 345.1 / (12 \times 60) \times 1/4 = 0.12m^3/min$, each

$= 0.2m^3/min$... 6pcs (2pcs)

(10)-1. Sludge characteristics

Concentrate ;max 3.0%
 Gravity : 1.02

(10)-2. Rake capacity(Q) =60 x V x h x ℓ

Q ;Sludge rake capacitym³ /hr
 V ;Raking speed0.3m/min
 h ;Flight height0.18m
 ℓ ;Filter width3.5m
 Q =60 x 0.3 x 0.18 x 3.5=11.34m³ /hr

(10)-3. Tension of chain


a). weight of rake parts(W1)=2 x w1 x (w2+w3)/P..... kg/m
 w1 ;chain weight 11.27kg/m(Stainless)
 w2 ;flight weight 37.0 kg/1pc
 w3 ;attachment weight 6.38kg/1pc
 P ;flight pitch about3.0m
 W1 =2 x 11.27 + (37+6.36)/3.0=37.0kg/m

b). Carried sludge weight (W2)=(1,000 x Q x γ) / (60 x V)
 w2 ;carried sludge weightkg/m
 Q ;sludge volume 11.34m³/hr
 γ ;Sludge gravity..... 1.02
 V ;raking speed 0.3m/min
 W2 =(1,000 x 11.3 x 1.02)/(60 x 0.3)=641kg/m

c). Primary tension of chain (P1)=200kg (2 line)

d). Tension of friction(Raking sludge and bottom tank)

P2 =W2 x L2 x μ 2
 P2 ;Tension of friction(sludge and bottom of tank)
kg
 W2 ;Raked sludge weight641kg
 L2 ;Length of horizontal shaft center ...65m
 μ 2;Friction coefficiency(Sludge to bottom) ...0.05



$$P2 = 641 \times 65 \times 0.05 = 2,084 \text{ kg}$$

e). Tension of friction (rail to flight shoe)

$$P3 = W1 \times L \times \mu 1$$

P3 ; Tension of friction (rail to flight shoe) ...kg

W1 ; Flight weight 37.0 kg/pc

L ; 2 x L2 135m

$\mu 2$; Friction coefficient (rail to shoe) 0.3

$$P3 = 37.0 \times 135 \times 0.3 = 1,499 \text{ kg}$$

f). Tension of lift up

$$P4 = W1 \times H$$

P4 ; Tension of lift up kg

W1 ; Flight weight 37.0 kg/1pc

H ; Length of vertical a shaft center 2.5m

$$P4 = 37.0 \times 2.5 = 92.5 \text{ kg}$$

g). Friction loss of pillow block

$$P5 = (P1 + P2 + P3 + P4) \times 0.1$$

$$= (200 + 2,084 + 1,499 + 92.5) \times 0.1 = 388 \text{ kg}$$

h). Tension of chain

$$P = P1 + P2 + P3 + P5$$

$$= 200 + 2,084 + 1,499 + 92.5 + 388 = 4,263.5 \text{ kg}$$

i). Power of motor(Drive unit)

$$PS = (n \times P \times V) / (6,120 \times \eta) \times \alpha$$

PS ; Power of motorKW
n ; Sedimentation tank quantity of drive2
P ; Tension of chain4,263.5kg
V ; raking speed0.3m/min
η ; Total efficiency0.7
α ; Safety ratio2

$$PS = (2 \times 4,263.5 \times 0.3) / (6,120 \times 0.7) \times 2 = 1.195 \text{kw}$$

Power of motor \longrightarrow 2.2KW

(10)-4.Chain strength calculation

a). From tension of chain

chain 2 line Tension of one side(P)=70%

$$S = P_0 / (0.7 \times P)$$

S ; Safety ratio of chain

P_0 ; Average breaking strength of chain 25,000 kg

P ; Tension of chain 4,263.5kg

$$S = 25,000 / (0.7 \times 4,263.5) = 8.37$$

b) Tension of chain from motor torque

① Tension of chain from motor output

$$T = (6,120 \times PS \times \eta \times f_0) / v$$

PS ; Output of motor 2.2kw

η ; Total efficiency 0.7

f_0 ; Coefficiency (against total load for one side chain) ...0.7

v ; Raking speed 0.3m/min

$$T = (6,120 \times 2.2 \times 0.7 \times 0.7) / 0.3 = 22,992 \text{kg}$$

② Safety ratio of chain

$$S = P_0 / T$$

P_0 ; Average breaking strength of chain 25,000kg

T ; Tension of chain 22,992kg

$$S = 25,000 / 22,992 = 1.087$$

(10)-5. Strength of drive shaft calculation

$$M_t = 97,370 \times P_s / r \times \eta$$

$$M_t = \pi / 16 \times d^3 \times \tau$$

$$d = \sqrt[3]{97,300 \times (16 \times P_s \times \eta) / (\pi \times \tau \times r)}$$

M_t ; Twist moment of drive shaft kg-cm

P_s ; Power of drive motor 2.2kw

η ; Drive efficiency 0.78

τ ; Twist stress allowed 860kg/cm

r ; Rotation of drive shaft 0.179rpm

$$r = v / (p \times z)$$

v ; Raking speed 0.6m/min

P ; Pitch of drive sprocket 0.1524m

z ; Teeth of drive sprocket 11

$$r = 0.3 / (0.1524 \times 11) = 0.179rpm$$

$$d = 116 \times \sqrt[3]{(2.2 \times 0.78) / (\pi \times 860 \times 0.179)} = 17.69cm$$

plus key ditch depth 177mm+10mm=187mm

Drive shaft diameter 190mm Φ

① [Specification of rake for final sedimentation tank] ... (Facility NO, M-30)

Type ; Chain flight double link type

Tank dimension; Width 5,000mm x Length 70,000mm x Depth 2,500mm

Length of rake; approx 65,000mm

Raking speed ; approx 0.6m/min

Flight pitch ; approx 3,000mm

Drive unit ; Cycro-reduction motor 2.2kw

Material ; Chain (stainless steel or plastic), Flight (Plastic)

Rail (15kg/m), Bolt/Nut (Stainless steel)

Quantity ; (5.0mW x 2set) x 4 line

Accessories ;

A ; Drive unit 2.2kw 4 pcs


B ; Grease up nozzle (4 pcs x 2 x 8 line) 64 pcs

C ; Weir (24m x 2) 4 pcs

(10)-6. Scum skimmer

Type and diameter ; Pipe skimmer 300mm

Scum effluent volume;



$$Q = k \times B \times H^{3/2}$$

k ; effluent coefficient119

B ; width of slitapprox 4.0m

H ; over flow water depth.....0.015m

$$Q = 119 \times 4.0 \times 0.015^{3/2} = 0.874 \text{m}^3/\text{min}$$

Water depth of inside pipe skimmer.....h

$$h = h_o / \sqrt{3}$$

h_o ; water depth of the upper stream max 0.15m

$$h = 0.15 / \sqrt{3} = 0.087 \text{m}$$

max effluent volume of pipe skimmer

$$Q_o = \sqrt{g \times D^2 \times h^3}$$

Q_o ; max effluent volumem³/sec

g ; acceleration of gravity.....9.8m/sec²

D ; diameter of gravity.....0.3m

h ; effluent water depth0.087m

$$Q_o = \sqrt{9.8 \times (0.3)^2 \times (0.087)^3} = 0.024 \text{m}^3/\text{sec}$$

$$= 1.45 \text{m}^3/\text{min} > 0.874 \text{m}^3/\text{min} \text{ OK}$$

② [Specification of scum skimmer for F.S.T.] Facility NO. M-31)

Type ; Pipe skimmer

Pipe diameter ; 300mm Φ

Length ; 5,000mm (Slit width 4,000mm)

Motor ; 0.4kw

Quantity ; 8pcs

(10)-7. Sludge pump for final sedimentation tank

a) Sludge volume ; $Q=1.380.38\text{m}^3/\text{day}$Actual pump 4pcs

$$\text{Pump capacity} = q = (1.380.38\text{m}^3/\text{d}) / (12 \times 60) \times 1/4 = 0.479\text{m}^3/\text{min}(\text{each})$$

$$= \text{approx } 0.6\text{m}^3/\text{min}(\text{each})$$

$$\text{b) Pump diameter; } D1 = 146 \sqrt{Q/v} \quad v = 1.5 \sim 2.5\text{m}/\text{sec}$$

$$= 146 \sqrt{0.6 / (1.5 \sim 2.5)} = 71.5 \sim 92.3\text{mm} \rightarrow 80\text{mm}$$

$$\text{c) Sludge Piping diameter; Sludge total volume} = 0.6\text{m}^3/\text{min} \times 4\text{pcs} = 2.4\text{m}^3/\text{min}$$

$$D2 = 146 \sqrt{2.4 / (1.5 \sim 2.5)} = 143 \sim 184.7\text{mm} \rightarrow 200\text{mm}$$

d) Pump head (Final sedimentation tank \rightarrow Sludge Thickener)

$$\text{Actual head (H1)} = \nabla + 9.5\text{m} - \nabla + 1.0\text{m} = 8.5\text{m}$$

$$\text{Pipe length } L(200) = 290\text{m} \dots\dots\dots$$

$$L(80) = 2\text{m} + 2\text{m} + 2\text{m} + 4\text{m} = 10\text{m}$$

Pipe loss head

$$\text{Inlet mouth loss } H2(80) = f \times v^2 / 2g \quad f = 1.0$$

$$v(80) = 0.6\text{m}^3 / (60 \times 3.14 / 4 \times D^2) = 1.990\text{m}/\text{sec}$$

$$v(200) = 2.4\text{m}^3 / (60 \times 3.14 / 4 \times D^2) = 1.274\text{m}/\text{sec}$$

$$H2(80) = 1.0 \times (1.990)^2 / 19.6 = 0.202\text{m}$$

$$\text{Piping loss } H \quad = f1 \times L/D \times v^2 / 2g$$

$$f1(80) = 0.02 + 0.0005/D = 0.0263$$

$$f1(200) = 0.02 + 0.0005/D = 0.0225$$

$$H3(80) = 0.0263 \times 10 / 0.08 \times (1.990)^2 / 19.6 = 0.665\text{m}$$

$$H4(200) = 0.0225 \times 290 / 0.2 \times (1.274)^2 / 19.6 = 2.702\text{m}$$

$$\text{Tee loss } H \quad = f \times v^2 / 2g \quad f = 1.2$$

$$H5(80) = 1.2 \times (1.990)^2 / 19.6 \times 2\text{pcs} = 0.485\text{m}$$

$$H6(200) = 1.2 \times (1.274)^2 / 19.6 \times 2\text{pcs} = 0.199\text{m}$$

$$\text{Elbow loss } H \quad = f \times v^2 / 2g \quad f = 0.2$$

$$H6(80) = 0.2 \times (1.990)^2 / 19.6 \times 1\text{pc} = 0.041\text{m}$$

$$H7(200) = 0.2 \times (1.274)^2 / 19.6 \times 8\text{pc} = 0.133\text{m}$$

$$\text{Gate valve loss } H \quad = f \times v^2 / 2g \quad f(80) = 0.164 \quad f(200) = 0.103$$

$$H8(80) = 0.164 \times (1.990)^2 / 19.6 \times 5\text{pcs} = 0.170\text{m}$$

$$H9(200) = 0.103 \times (1.274)^2 / 19.6 \times 6\text{pcs} = 0.052\text{m}$$

$$\text{Check valve loss } H \quad = f \times v^2 / 2g \quad f(80) = 1.8$$

$$H10(80) = 1.8 \times (1.990)^2 / 19.6 \times 1\text{pc} = 0.364\text{m}$$

$$\text{Total head} = H1 \sim H10 = 8.500 + 0.202 + 0.665 + 2.702 + 0.485 + 0.199 + 0.041$$

$$+ 0.133 + 0.170 + 0.070 + 0.364 = 13.513\text{m} \Rightarrow 17\text{m}$$

e) Power of motor (PS)

$$PS = 0.163 \times (\gamma \times Q \times H) / \eta \times \alpha$$

- γ ; Gravity of sludge 1.02
- Q ; Flow volume 0.6m³/min
- H ; Total head 17.0m
- η ; Efficiency of pump 40%
- α ; Safety ratio 1.2

$$PS = 0.163 \times (1.02 \times 0.6 \times 17) / 0.4 \times 1.2 = 5.09kw \rightarrow 5.5kw$$

③ [Specification of sludge pump for F. S. T.] (Facility NO. M-33)

- Type ; Horizontal sludge pump
- Specification ; 80x80x0.6m³/minx17m x 5.5kw
- Quantity ; 6pcs (2pcs spare)

(10)-8. Sludge return pump

a) Sludge return volume ; Q=290.7m³/hrx4pcs (=4.85m³/minx4pcs)

Sludge capacity ; Q=4.9m³/minx4pcs

b) Pump diameter ; $D1 = 146\sqrt{Q/v}$ $v = 1.5 \sim 2.0$ m/sec
 $= 146\sqrt{4.9/1.5 \sim 2.0} = 228.6 \sim 263.9$ mm \rightarrow 250mm

c) Piping diameter ; $D2 = 146\sqrt{Q/v}$ $v = 1.0 \sim 2.0$ m/sec
 $= 146\sqrt{4.0/1.0 \sim 2.0} = 228.6 \sim 323.2$ mm \rightarrow 300mm

d) Pump head (Final sedimentation tank \rightarrow Aeration tank)

Actual head (H1) = (+10.50) - (+7.80) = 2.70m

Inlet mouth loss $H2(250) = f \times v^2 / 2g$ $f = 1.0$
 $v(250) = 4.9m^3 / (60 \times 3.14 / 4 \times D^2) = 1.665$ m/sec
 $v(300) = 4.9m^3 / (60 \times 3.14 / 4 \times D^2) = 1.156$ m/sec

$H2(250) = 1.0 \times (1.665)^2 / 19.6 = 0.142$ m

Piping loss $H = f \times L/D \times v^2 / 2g$
 $f(250) = 0.02 + 0.0005/D = 0.0220$
 $f(300) = 0.02 + 0.0005/D = 0.0217$

$L(250) = 30$ m $H3(250) = 0.0220 \times (30/0.25) \times (1.665)^2 / 19.6 = 0.374$ m

$L(300) = 120$ m $H4(300) = 0.0217 \times (120/0.3) \times (1.156)^2 / 19.6 = 0.592$ m

Tee loss $H = f \times v^2 / 2g$ $f = 1.2$

$H5(250) = 1.2 \times (1.665)^2 / 19.6 \times 4$ pcs = 0.679m

$H6(300) = 1.2 \times (1.156)^2 / 19.6 \times 2$ pcs = 0.164m

Elbow loss	$H = f \times v^2 / 2g$	$f=0.2$	
	$H7(250)=0.2 \times (1.665)^2 / 19.6 \times 1pc$		=0.029m
	$H8(300)=0.2 \times (1.156)^2 / 19.6 \times 7pcs$		=0.096m
Gate valve loss	$H = f \times v^2 / 2g$	$f(250)=0.047$	
	$H9(250)=0.047 \times (1.665)^2 / 19.6 \times 1pc$		=0.007m
Check valve loss	$H = f \times v^2 / 2g$	$f=1.8$	
	$H10(250)=1.8 \times (1.665)^2 / 19.6 \times 1pc$		=0.255m
Total head (H)	$=H1+H2+H3+H4+H5+H6+H7+H8+H9+H10$		
	$=2.7+0.142+0.374+0.592+0.679+0.164+0.029$		
	$+0.096+0.007+0.255$		
	$=5.038m$		$\longrightarrow 8.0m$

c). Power of motor (PS)

$PS = 0.163 \times (\gamma \times Q \times H) / \eta \times \alpha$
 γ ; Gravity of sludge 1.02
 Q ; Flow volume 0.6m³/min
 H ; Total head 8.0m
 η ; Efficiency of pump 45%
 α ; Safety ratio 1.2
 $PS = 0.163 \times (1.02 \times 0.6 \times 8.0) / 0.45 \times 1.2 = 17.4kw \longrightarrow 18.5kw$

④ [Specification of sludge return pump for F.S.T.] (Facility NO. M-32)

Type ; Horizontal sludge pump
 Specification; 250 x 250 x 0.49m³/min x 8.0m x 18.5kw
 Quantity ; 6pcs(2pcs spare)

(10)-9. Scum transfer pump for final sedimentation tank

a) Scum transfer volume; 0.847m³/min \longrightarrow 0.88m³/min
 b) Pump diameter ; $D1 = 146 \sqrt{Q/v} = 146 \sqrt{0.88 / (1.5 \sim 3.0)}$
 $= 79 \sim 112mm \longrightarrow 100mm$
 $v(100) = 0.88m^3 / (60 \times 3.14 / 4 \times D^2) = 1.869m/sec$

c) Pump head

Actual head (H1) $= (\nabla + 9.2) - (\nabla + 5.5) = 3.7m$
 Pipe length = 250m
 Loss head
 Piping loss $H2(100) = f \times L/D \times v^2 / 2g$ $f=0.025$

$$=0.025 \times 250 / 0.1 \times (1.869)^2 / 19.6 = 11.139m$$

elbow loss $H3(100) = f \times v^2 / 2g$ $f=0.2$
 $=0.2 \times (1.869)^2 / 19.6 \times 6pc = 0.214m$

check valve loss $H4(100) = f \times v^2 / 2g$ $f=1.8$
 $=1.8 \times (1.869)^2 / 19.6 \times 1pc = 0.321m$

gate valve loss $H5(100) = f \times v^2 / 2g$ $f=0.164$
 $=0.164 \times (1.889)^2 / 19.6 \times 1pc = 0.030m$

Total head = $H1 + H2 + H3 + H4 + H5 = 3.7 + 11.139 + 0.214 + 0.321 + 0.030 = 15.404m \rightarrow 16m$

d) Power Of motor (PS) $= 0.163 \times (\gamma \times Q \times H) / \eta \times 1.2$

γ ; Gravity of scum 1.0
 Q ; Flow volume $0.88m^3 / mi \dots 0.9m^3 / min$
 H ; Total head 16.0m
 η ; Efficiency of pump 60%
 α ; Safety ratio 1.2

$PS = 0.163 \times (1.0 \times 0.9 \times 16.0) / (0.60) \times 1.2 = 4.694kw \rightarrow 5.5kw$

⑤ [Specification of scum transfer pump for F. S. T.] (Facility NO. M-34)

Type ; Submersible pump
 Specification; $100 \times 0.9m^3/min \times 16m \times 5.5kw$
 Quantity ; 4PCS (2pcs spare.....ware house)
 Accessory ; Cable 10m, Chain 6m/1pc (Stainless steel),
 Guide pipe 1set/1pc (Stainless steel),
 Automatic connection 1set/1pc

⑥ [Floor drain pump for F. S. T. pump room] (Facility NO. M-35)

Type ; Submersible pump
 Specification; $50mm \times 0.1m^3 / min \times 10m \times 0.75kw$
 Quantity ; 2pcs (1pc spare)

(ii). Chlorine Contact tank

Flow rate; DaveQ=46,500m³/day $H_{max}Q=93,000m^3/day$ Chlorine contact time=15min at $H_{max}Q$

=30min at DaveaQ

Capacity

V1 =93,000m³/day x 15/(24 x 60) =967m³V2 =46,500m³/day x 30/(24 x 60) =967m³V =967.9m³ =121m³ x 8pcs

Dimension ; 2.0m x 25.0m x 2.5m x 8pcs

Capacity ; V=2.0 x 25.0m x 2.5m x 8=1,000m³Chlorine dosing ratio :6mg/l at $D_{max}Q(D_{max}Q=55,800m^3/day)$ Q = 55,800m³/day x 6mg/l x 10⁻³ = 334.8 kg/day

334.8 kg/day ÷ 24hr =13.95kg/hr at 2pcs

1pc dosing capacity=13.95kg/2 pcs=7.0kg/hr(each)

① [Specification of chlorinator] (Facility NO. d-56)

Capacity ; 10.0kg/hr

Quantity ; 3pcs (1pc...stand-by)

Accessory ; Flow indicator and pressure gauge

② [Specification of Chlorine container] (Facility NO. M-55)

Capacity ; 1ton

Chlorine gas Storage=more than 30days

=334.8kg/d x 30 days =10,044 kg

=10,044 kg ÷ 1,000kg =10.05pcs → 12pcs

Quantity ; 12 pcs

Accessory ; Auxiliary valve, Flexible connector, Tank manifold,

Pressure indicator alarm.

③ [Specification of Booster pump] (Facility NO. M-57)

Specification; 65mm x 0.3m³/min x 40m x 5.5kw

Quantity ; 3pcs (1pc...standby)

Accessory ; Pressure gauge 2pcs/1pc

④ [Specification of injector] (Facility NO. M-75)

Specification; 40mm

Quantity ; 3pcs (1pc ...standby)

Accessory ; Pressure gauge 1pc/1pc

- ⑤ [Specification of control panel for chlorination] ... (Facility NO. M-79)
 Type ; Stand type
 Quantity ; 1pc
- ⑥ [Specification of chain hoist for chlorination house] ... (Facility NO. M-58)
 Type ; Power operated type
 Specification; 2.0 Ton x 4.0m x (380v 1.5kw/0.4kw)
 Quantity ; 1pc
- ⑦ [Specification of chlorine gas neutralization unit] ... (Facility NO. M-59)
 Type ; Packed column gas-liquid contact (2 column system)
 Specification; 500 kg/hr
 Chemical ; 15% NaOH solution (Gravity=1.165)
- ① -1. NaOH 15% storage tank; 16m³ x 1 tank
 ② -2. NaOH dissolve tank; 1.0 m³ steel tank (with mixer; 3Φ x 380V x 0.75kw x 1 pc)
 NaOH required = 16m³ x 15/100 x 1.165 = 2.796 ton
 NaOH dissolve tank = 1.0 m³ (45% liquid) = 1.0 x 45/100 x 1.48 = 0.666 ton
 Dissolve times = 2.796/0.666 = 4.2 → approx 5 times
- ③ -3. NaOH circulation pump; 900 l/min x 15 m x 5.5 kw x 2 pcs (1 pc spare)
 ④ -4. Exhaust fan ; 45 m³/min x 250 mmHg x 3.7 kw x 2 pcs (1pc spare)
 ⑤ -5. Chlorine gas leak detector; Type; Diffusion type diaphragm electrode
 Range: 0~3 ppm Power source; 1 Φ x 100V
 Quantity, 1 set (with sensor 3 points)
 2 points (Chlorine cylinder room), 1 point (chlorine dosing room)
- ⑧ [Specification of drain pump for chlorine house] ... (Facility NO. M-80)
 Type ; Submersible pump (Chemical pump)
 Specification; 50mm x 0.1 m³/min x 10m x 0.75 kw x 2 pcs (1 pc spare)
 Quantity ; 2 pcs (1 pc spare)

(12) Filtered tank RC

DmaxQ = 55,800 m³/day

Retention time; 8 min at DmaxQ

Capacity (V) = 55,800 m³/d x 3/1,440 = 310.0 m³ → 350 m³

Dimension ; 8.0m x 8.85m x 2.5m x 2pc

Volume ; 8.0 x 8.85 x 2.5 x 2 = 354 m³

- ① [Specification of inlet gate for filter tank] ... (Facility NO. M-37)
 Type ; Sluice gate

Specification ; Manual operation , 1.000x1000

Quantity ; 2 pcs

(13) Spray pump (For deforming aeration tank and sludge pipe washing etc.)

a) Required flow capacity: for 2 line aeration tank (at one spray pump)

$$Q = 48 \text{ pcs} \times 2 \text{ line} \times 10 \ell / \text{min} \cdot 1 \text{ pc} = 960 \ell / \text{min} \longrightarrow 1.0 \text{ m}^3 / \text{min}$$

b) Pump diameter : $D1 = 146 \sqrt{Q/v} = 146 \sqrt{1.0 / (1.5 \sim 3.0)}$

$$= 84.3 \sim 119.2 \text{ mm} \longrightarrow 100 \text{ mm}$$

$$v(100) = 1.0 / (60 \times 3.14 / 4 \times D1^2) = 2.123 \text{ m/sec}$$

Main pipe dia. ; $D2 = 146 \sqrt{Q/v} = 146 \sqrt{4.0 / (1.0 \sim 2.0)} = 206 \sim 252 \text{ mm} \geq 250 \text{ mm}$

$$v(250) = 4.0 / (60 \times 3.14 / 4 \times D2^2) = 1.359 \text{ m/sec}$$

c) Pump head

Actual head (H1) : $(\sqrt{7} + 9.20 \text{ m}) - (\sqrt{7} + 4.32 \text{ m}) = 4.88 \text{ m}$

(Sludge line washing water supply for sludge feeding inlet side)

Required pressure for spray nozzle $H_0 = 1.0 \text{ kg/cm}^2 = 10.0 \text{ m}$

Straight pipe loss; $H = f \times L/D \times v^2 / 2g$

$$f(250) = 0.02 + 0.0005/D = 0.022$$

$$f(125) = 0.02 + 0.0005/D = 0.024$$

$$f(100) = 0.02 + 0.0005/D = 0.025$$

$$v(125) = 1.0 / (60 \times 3.14 / 4 \times D^2) = 1.359 \text{ m/sec}$$

$$v(100) = 0.5 / (60 \times 3.14 / 4 \times D^2) = 1.062 \text{ m/sec}$$

pipe length $L(250) = 9 + 3 + 8 + 85 + 20 + 82 + 70 + 20 + 35 + 40 + 4 = 371 \text{ m} \longrightarrow 380 \text{ m}$

$$L(125) = 3.0 + 30 = 33 \text{ m} \longrightarrow 40 \text{ m}$$

$$L(100) = 20 = 20 \text{ m} \longrightarrow 20 \text{ m}$$

$$L(100) = 5 = 5 \text{ m} \longrightarrow 5 \text{ m}$$

$$H2(250) = 0.022 \times 380 / 0.25 \times (1.359)^2 / 19.6 = 3.151 \text{ m}$$

$$H3(125) = 0.024 \times 33 / 0.125 \times (1.359)^2 / 19.6 = 0.597 \text{ m}$$

$$H4(100) = 0.025 \times 20 / 0.1 \times (1.062)^2 / 19.6 = 0.283 \text{ m}$$

$$H5(100) = 0.025 \times 5 / 0.1 \times (2.123)^2 / 19.6 = 0.289 \text{ m}$$

elbow loss $H = f \times v^2 / 2g \quad f = 0.2$

$$H6(250) = 0.2 \times (1.359)^2 / 19.6 \times 8 \text{ pcs} = 0.151 \text{ m}$$

tee loss $H = f \times v^2 / 2g \quad f = 1.2$

$$H7(250) = 1.2 \times (1.359)^2 / 19.6 \times 4 \text{ pcs} = 0.453 \text{ m}$$

Gate valve loss $H = f \times v^2 / 2g \quad f(100) = 0.164 \quad f(250) = 0.047$

$$H8(250) = 0.047 \times (1.359)^2 / 19.6 \times 1 \text{ pcs} = 0.005 \text{ m}$$

$$H9(125) = 0.164 \times (1.062)^2 / 19.6 \times 1 \text{ pc} = 0.010 \text{ m}$$

$$H_{10}(100) = 0.164 \times (2.123)^2 / 19.6 \times 1pc = 0.038m$$

Check valve loss $H = f \times v^2 / 2g$ $f(100) = 1.8$

$$H_{11}(100) = 1.8 \times (1.062)^2 / 19.6 \times 1pc = 0.104m$$

Total head-loss $\sim H_{10} = 10.013 + 0.597 + 0.288 + 0.289 + 0.151 + 0.453 + 0.005$
 $+ 0.010 + 0.038 + 0.104 = 15.086m \longrightarrow 20m$

d) Power of motor (PS) = $0.163 \times (\gamma \times Q \times H) / \eta \times 1.2$

γ ; Gravity of treated water 1.0
 Q ; Flow volume 1.0m³/min
 H ; Total head 20.0m
 η ; Efficiency of pump 60%
 α ; Safety ratio 1.2

(PS) = $0.163 \times (1.0 \times 1.0 \times 20.0) / 0.60 \times 1.2 = 6.52kw \longrightarrow 7.5kw$

① [Spray pump specification] (Facility NO. M-36)

Type ; Submersible pump
 Specification; 100mm x 1.0m³/min x 20.0m x 7.5kw
 Quantity ; 6pcs (2pcs stand-by)
 Accessory ; Cable 10m/1pc, Chain 6m/1pc (stainless steel),
 Guide pipe 1set/1pc. (stainless steel).

② [pump hanger] (Facility NO. M-76)

Type ; Mild steel Pump hanger
 Quantity ; 1set/6pcs
 Accessory ; 0.5ton manual operation chain hoist 1pc

(14). Treated water tank RC

DmaxQ = 55,800m³/day
 Retention time ; 5min at DmaxQ
 Capacity ; $V = 55,800m^3/day \times 5 / (24 \times 60) = 193.7m^3 \longrightarrow 200m^3$
 Dimension ; 8.85m x 5.0m x 2.5m x 2pcs
 Capacity ; $V = 8.85 \times 5.0 \times 2.5 \times 2pcs = 221.25m^3$

① [Specification of inlet gate for treated water tank] (Facility NO. M-37)

Type ; Sluice gate
 Specification ; Manual operation 1,000x1,000
 Quantity ; 1 pc

② [Specification of Inlet gate for chlorine tank] (Facility NO. M-42)

Type ; Sluice gate
 Specification ; Manual operation 1' 1,000x1,000
 Quantity ; 3 pc

(15). Sludge thickener

Influent flow and quality

Sources of sludge Generation	Quantity (m ³ /day)	SS	
		(mg/ l)	(kg-DS/day)
Primary sedimentation tank	424.68	20,000	8,481.6
Final sedimentation tank	1,380.38	8,000	11,043.0
Back-washed water of filter	(2,720.00)	(942.6)	(2,564.0)
Separated water and washed water			
Total	4,524.46	4,882	22,088.6

Solid loading ; 25~59kg/m² .day
 Hydraulic loading; 16~32m³ /m² .day
 Surface area (SA); 22,088.6/40=553m²

Dimension ;

$$D = \sqrt{(553 \times 1/2) / (3.14/4)} = 18.3m \quad \text{---> } 19.0m \text{ } \Phi$$

= 19.0m Φ x 3.0m x 2 pcs

Surface area; SA = (3.14 x (19.0)²) / 4 = 283.5m² (each)
 283.5m² x 2pcs = 567 m²

Capacity ; V = 567m² x 3.0m = 1,701 m³

Solid loading; SL = 22,088.6/567 = 39.0kg/m² .day.....OK

Hydraulic loading; HL = 4,524.6/567 = 8.0m³ /m² .day.....OK

Retention time ;

$$RT = (1,701 / 4,524.46) \times 24 = 9.0 \text{ hour}$$

Concentrated sludge volume; (Sludge water rate=98%)

$$CSV = 22,088.6 / (1 - 0.98) \times 10^{-3} = 1,104.43 \text{ m}^3 / \text{day} = 0.77 \text{ m}^3 / \text{min}$$

Sludge drawing out method; Gravity

Effluent water;

$$ESW = (4,524.46 \text{ m}^3 / \text{day}) - (1,104.43 \text{ m}^3 / \text{day}) = 3,420.03 \text{ m}^3 / \text{day}$$

Auxiliary equipment;

Rake ; 2 set

Scum box; 2set

a). Power of thickener drive unit

Sludge volume at one hour; (Sludge water rate=98%)

$$Q(98\%) = 1,104.43 \text{ m}^3 / \text{day} = 46.02 \text{ m}^3 / \text{hour}$$

$$\text{One rotation time; } t = (D \times \pi) / (v \times 60) \quad v = 2 \text{ m/min}$$

$$t = (19.0 \times 3.14) / (2.0 \times 60) = 0.497 \text{ hour}$$

Sludge volume at t (=0.497 hour) hour

$$Q_t = Q(98\%) \times t = (46.02 \text{ m}^3 / \text{hour}) \times 0.497 \text{ hour} = 22.87 \text{ m}^3 / \text{t hour}$$

(one rotation)

Drive unit

Reducing ratio ; 1/44,500

Torque allowed ; 600kg-m

Rotation ; 1,500rpm / 44,500 = 0.0337rpm

Speed ; 19.0 x 3.14 x 0.0337rpm = 2.01m/min

a) Power of Rake (P1)

$$P1 = P_o / \eta 1$$

P_o ; theoretical rake power (kw)

$\eta 1$; Efficiency of rake

$$f \cot \alpha - 1$$

$$\eta 1 = \frac{\Phi \sin(\beta + \gamma) (\cot \beta + (\sin(\beta + \gamma)) / (\cot(\beta + \gamma)) + 1 / \Phi)}{f \cot \alpha - 1}$$

f ; Friction coefficient of sludge 0.55

α ; Taper angle of bottom 2.5 °

β ; Brake angle against rake arm 45°

γ ; Friction angle of sludge against plate 25°

$$\Phi = \sqrt{f^2 \times \cot^2 \alpha - \sin^2 (\beta + \gamma) - \cos(\beta + \gamma)}$$

$$\Phi = \sqrt{(0.55)^2 \times \cot^2 2.5^\circ - \sin^2 (45^\circ + 25^\circ) - \cos(45^\circ + 25^\circ)}$$

= 12.22

$$0.55 \times \cot 2.5^\circ - 1$$

$$\eta_1 = \frac{12.22 \times \sin(45^\circ + 25^\circ) \{ \cot 45^\circ (\sin(45^\circ + 25^\circ)) / (\cot(45^\circ + 25^\circ) + 1/12.22) \}}{0.637}$$

$$= 0.637$$

$$P_o = 1/6,120 \times Q \times (f \times \cos \alpha - \sin \alpha) \times (2D_1^3 + D_2^3 - 3D_1^2 \times D_2) / 6(D_1^2 - D_2^2)$$

Q ; Influent Sludge volume (dry solid) = 0.77 m³/min × 0.02 = 0.0154 kg/min-DS

D₁; Thickener diameter = 19.0 m

D₂; Rake hopper diameter = 3.0 m

$$P_o = 0.0154 / 6,120 \times (0.55 \times \cos 2.5^\circ - \sin 2.5^\circ) \times \{ (2 \times 19.0^3 + 3.0^3 - 3 \times 19.0^2 \times 3.0) / 6(19.0^2 - 3.0^2) \}$$

$$P_o = 0.00241 \times 10^3 \text{ kw}$$

$$P_1 = P_o / \eta_1 = 0.00241 / 0.637 = 0.00379 \text{ kw}$$

b) Power of friction loss ; (P₂)

$$P_2 = N / 974 \times (W \times d \times \mu) / 2$$

N ; Rake rotation speed 0.0337 rpm

W ; Machine Weight (part of rotation) 8,500 kg

d ; Diameter of drive bearing 1.20 m

μ ; Friction efficiency of bearing 0.1

$$P_2 = 0.0337 / 974 \times (8,500 \times 1.2 \times 0.1) / 2 = 0.0177 \text{ kw}$$

c) Power of solution loss (P₃)

$$P_3 = 1.000 / 102 \times (C \times \rho \times A \times v^3) / 2g$$

ρ ; Gravity of sludge 1.05

C ; Coefficiency of rake arm 4

A ; Resistance area of rake arm 3.0 m²

v ; Circumference speed 2.01 m/min = 0.0335 m/sec

g ; Acceration of gravity 9.8 m/sec²

$$P3 = 1,000/102 \times (4 \times 1.05 \times 3.0 \times 0.0335^3) / 19.6 = 0.000237 \text{kw}$$

d) Power of motor (PS)

$$PS = (P1 + P2 + P3) / \eta_0 \times \alpha$$

η_0 ; Total efficiency 0.4

α ; Safety ratio 3

$$PS = (0.00379 + 0.0177 + .000237) / 0.4 \times 3.0$$

$$= 0.163 \text{ kw} < 1.5 \text{ kw} \quad \text{OK}$$

① [Specification of sludge thickener] (Facility NO. M-38)

Type ; Center post drive type

Specification; 19.0m Φ x 3.0mH x 2.0m/min x 1.5kw

Quantity ; 2 pcs

Accessory ; Bridge(SS41), Center post(SS41), Drive unit, Rake, Center post.

(15)-2. Pipe line for effluent separated water (to Raw water pump station)

Volume of effluent separated water; Q=3,420.03m³ /day

Effluent time ; 12 hour

$$3,420.03 \text{m}^3 / 12 \text{hr} = 285 \text{m}^3 / \text{hr} = 4.75 \text{m}^3 / \text{min}$$

Effluent pipe dia. ; $D = 146 \sqrt{Q/v} \quad v = 0.6 \text{m/sec}$

$$D = 146 \sqrt{4.75/0.6} = 410.8 \text{mm} \longrightarrow 450 \text{mm}$$

(15)-3. Pipe line for sludge drain line (to Sludge basin)

Volume of sludge drain; 0.77m³ /min (One thickener)

Pipe dia. $D1 = 146 \sqrt{Q/v} \quad v = 0.6 \text{m/sec}$

$$= 146 \sqrt{0.77/0.6} = 165.4 \text{mm} \longrightarrow 250 \text{mm}$$

$$D2 = 146 \sqrt{1.54/0.6} = 233.9 \text{mm} \longrightarrow 350 \text{mm}$$

② [Specification of sludge drain valve for Sludge thickener

... (Facility NO. M-40)

Type ; Reverse action Diaphragm valve (with actuator)

Dia. ; 250mm

Material ; Diaphragm (Rubber)

Quantity ; 2 pcs

Accessory ; 3-way solenoid valve 1pc/1pc,
ON-OFF Limit switch 1 set/1pc

(15)-4. Required air capacity of actuator for sludge drain valve

$$Q = V(P + P_a) / P_a$$

Q ; Required air capacity (Nℓ)
 V ; Capacity of air cylinder for actuator (ℓ) 22.6 ℓ
 P ; Operation pressure (kg/cm² .G) 4.0kg/cm² .G
 P_a; Atmospheric pressure (1.0 kg/cm² .abs)

$$Q = 22.6(4+1)/1 \times 2 \text{ pcs} = 226\ell$$

Actuator action = 1 action/min \longrightarrow 250 ℓ /min

③ [Specification of compressor for sludge drain valve]... (Facility NO. M-69)

Type ; Pressure ON-OFF type
 Specification; 250ℓ /min x 9.5 kg/cm² x 2.2kw
 Quantity ; 2 pcs(1pc spare)
 Accessory ; Air filter 1set/2pcs, Regulator 1set/2pcs

④ [Specification of floor drain pump for thickener valve room

..... (Facility NO. M-39)

Type ; Submersible pump
 Specification; 50mm x 0.1m³ /min x 10m x 0.75kw
 Quantity ; 2pcs(1pc spare)

(16). Sludge basin

Concentrated sludge volume = 1,104.43m³/day = 0.77m³/min

Retention time RT = more than 12.0 hour

Capacity (V) = 1,104.43 x 12/24 = 552.2 m³ \longrightarrow 560m³

= 280m³ x 2 pcs = 560m³

Dimension ; 10.0m x 10.0m x 3.0mh x 2pcs

Capacity ; V = 10.0 x 10.0 x 3.0mh x 2 pcs = 600m³ > 560m³ OK

Retention time ; RT = 600 / (1,104.43) x 24 = 13.0 hour

Auxiliary equipment;

(1) Sludge basin Mixing blower

a) Required air capacity (q) = $600 \text{ m}^3 \times 1.0 \text{ m}^3/\text{m}^3 \cdot \text{hour} \times 1/60 = 10.0 \text{ m}^3/\text{min}$
 $= 10.0 \text{ m}^3/\text{min} (\text{each}) \times 2 \text{ pcs} (1 \text{ pc stand-by})$

b) Diameter of blower

$$D = 146 \sqrt{Q/V} \quad V = 20 \sim 30 \text{ m/sec}$$

$$= 146 \sqrt{10.0 / (20 \sim 30)} = 84.3 \text{ mm} \sim 103.3 \text{ mm} \longrightarrow 125 \text{ mm}$$

c) Pressure of blower $H = (\text{water depth}) 3000 \text{ mm} + (\text{loss}) 500 \text{ mm} = 3500 \text{ mm}$

⑤ [Specification of sludge basin mixing blower] ... (Facility NO. 3-5i)

Type ; Roots blower

Specification; 125 mm x 10.0 m³/min x 3500 mm aq x 11.0 kw

Quantity ; 2 pcs (1 pc stand-by)

⑥ [Specification of diffuser for sludge basin] ... (Facility NO. 4-1)

Type ; Disc type

Specification; 200 l /min/pc

Quantity ; 50 pcs

⑦ [Air flow meter for sludge basins] ... (Facility NO. 4-1)

Type ; Orifice type

Specification; 125 mm x 250 ~ 1,250 Nm³ /H

Quantity ; 1 pc

(2) Sludge feeding pump (to sludge bed)

a) Capacity ; (q) = $1,104.43 \text{ m}^3/\text{day} \times 1 / (8.0 \text{ hour} \times 60) \times 1/4 \text{ pcs}$
 $= 0.58 \text{ m}^3/\text{min} \longrightarrow 0.6 \text{ m}^3/\text{min}$

b) Pump diameter; $D = 146 \sqrt{Q/v} = 146 \sqrt{0.6 / (1.5 \sim 3.0)}$
 $= 50.6 \text{ mm} \sim 92.3 \text{ mm} \longrightarrow 80 \text{ mm}$

$$V(80) = 0.6 / (60 \times 3.14 / 4 \times D^2) = 1.987 \text{ m/sec}$$

c) Pump head

Actual head (H1) = $\nabla 152.0 \text{ m} - \nabla 104.2 = 47.8 \text{ m}$

Straight pipe loss $H = f \times L/D \times v^2 / 2g$

$$f(80) = 0.02 + 0.0005/D = 0.0263$$

$$f(250) = 0.02 + 0.0005/D = 0.0220$$

pipe length $L(80) = 6.5\text{m}$ $L(250) = 1.050\text{m}$

$$v(80) = 0.6 / (60 \times 3.14/4 \times D^2) = 1.987 \text{ m/sec}$$

$$v(250) = 2.4 / (60 \times 3.14/4 \times D^2) = 0.816 \text{ m/sec}$$

$$H_2(80) = 0.0263 \times 6.5 / 0.08 \times (1.987)^2 / 19.6 = 0.431 \text{ m}$$

$$H_3(250) = 0.0220 \times 1.050 / 0.25 \times (0.816)^2 / 19.6 = 3.139 \text{ m}$$

Elbow loss $H = f \times v^2 / 2g$ $f = 0.2$

$$H_4(80) = 0.2 \times (1.987)^2 / 19.6 \times 3\text{pcs} = 0.121 \text{ m}$$

$$H_5(250) = 0.2 \times (0.816)^2 / 19.6 \times 7\text{pcs} = 0.048 \text{ m}$$

Teeloss $H = f \times v^2 / 2g$ $f = 1.2$

$$H_6(250) = 1.2 \times (0.816)^2 / 19.6 \times 1\text{pc} = 0.041 \text{ m}$$

Gate valve loss $H(80) = f \times v^2 / 2g$ $f(80) = 0.164$ $f(250) = 0.047$

$$H_7(80) = 0.164 \times (1.987)^2 / 19.6 \times 2\text{pcs} = 0.066 \text{ m}$$

$$H_8(250) = 0.047 \times (0.816)^2 / 19.6 \times 1\text{pc} = 0.002 \text{ m}$$

Check valve loss $H = f \times v^2 / 2g$ $f = 1.8$

$$H_9(80) = 1.8 \times (1.987)^2 / 19.6 \times 1\text{pc} = 0.363 \text{ m}$$

Total head $= H_1 \sim H_9 = 47.8 + 0.431 + 3.139 + 0.121 + 0.048 + 0.041 + 0.066 + 0.002 + 0.363 = 52.011\text{m} \longrightarrow 53.0\text{m}$

d) Power of motor (PS)

$$PS = 0.163 \times (\gamma \times Q \times H) / \eta \times 1.2$$

$$= 0.163 \times (1.05 \times 0.6 \times 53.0) / 0.38 \times 1.2 = 17.19\text{kw} \longrightarrow 18.5\text{kw}$$

⑧ [Sludge feeding pump for sludge basin] (to sludge bed)


... (Facility NO. M-44)

Type ; Horizontal sludge pump
 Specification; 80mm x 0.6m³/min x 53.0m x 18.5kw
 Quantity ; 6pcs (2pcs standby)


⑨ [Specification of floor drain pump for sludge feeding house]

..... (Facility NO. M-45)

Type ; Submersible pump
 Specification; 50mm x 0.1 m³/min x 10m x 0.75kw
 Quantity ; 2 pcs (1pc spare)



$$L = 20 + 430 + 400 + 200 = 1,050\text{m}$$



CALCULATION OF MOTOR OUTPUT FOR RELAY PUMPS (No.1 P/S)

The motor output for No.1 Relay Pumps shall be calculated as follows.

(1) Relay Pump Specification

The specification of Relay Pumps shall be as follows.

Pump capacity : 6.9 cu.m/min

Pump total head : 18 m

(2) Pump Shaft Horse Power (L)

For the above pumps, the shaft horse power shall be calculated as follows.

$$L = \frac{0.163 \times Q \times H \times r}{E_{ff}} = \frac{0.163 \times 6.9 \times 18 \times 1.0}{0.65} = 31.2 \text{ kw}$$

where Q : Capacity cu.m/min

H : Total head m

r : Weight per unit volume of water kgf/l

E_{ff} : Pump efficiency

(3) Output Required for Motor (L_m)

$$L_m = L \times (1+A) = 31.2 \times (1+0.2) = \underline{37.5 \text{ kw}}$$

where A : margin

According to the above calculation the output required for motor shall be 45 kw.

CALCULATION OF MOTOR OUTPUT FOR RELAY PUMPS (No.2 P/S)

The motor output for No.2 Relay Pumps shall be calculated as follows.

(1) Relay Pump Specification

The specification of Relay Pumps shall be as follows.

Pump capacity : 4.56 cu.m/min

Pump total head : 25 m

(2) Pump Shaft Horse Power (L)

For the above pumps, the shaft horse power shall be calculated as follows.

$$L = \frac{0.163 \times Q \times H \times r}{E_{ff}} = \frac{0.163 \times 4.56 \times 25 \times 1.0}{0.64} = 29.1 \text{ kw}$$

where Q : Capacity cu.m/min

H : Total head m

r : Weight per unit volume of water kg/l

E_{ff} : Pump efficiency

(3) Output Required for Motor (L_m)

$$L_m = L \times (1+A) = 29.1 \times (1+0.2) = 35.0 \text{ kw}$$

where A : margine

According to the above calculation the output required for motor shall be 37 kw.

CALCULATION OF MOTOR OUTPUT FOR RELAY PUMPS (No.3 P/S)

The motor output for No.3 Relay Pumps shall be calculated as follows.

(1) Relay Pump Specification

The specification of Relay Pumps shall be as follows.

Pump capacity : 3.69 cu.m/min
Pump total head : 39 m

(2) Pump Shaft Horse Power (L)

For the above pumps, the shaft horse power shall be calculated as follows.

$$L = \frac{0.163 \times Q \times H \times r}{E_{rf}} = \frac{0.163 \times 3.69 \times 39 \times 1.0}{0.64} = 36.7 \text{ kw}$$

where Q : Capacity cu.m/min
H : Total head m
r : Weight per unit volume of water kgf/l
E_{rf} : Pump efficiency

(3) Output Required for Motor (L_m)

$$L_m = L \times (1+A) = 36.7 \times (1+0.2) = \underline{44.1 \text{ kw}}$$

where A : margin

According to the above calculation the output required for motor shall be 45 kw.

