

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGCOH)
GENERAL SECRETARIAT OF WORKS
THE FEDERAL DISTRICT OF MEXICO

THE FEASIBILITY STUDY
ON
WASTEWATER TREATMENT
IN
THE FEDERAL DISTRICT OF MEXICO

DATA BOOK

DECEMBER 1994

PACIFIC CONSULTANTS INTERNATIONAL, TOKYO

SSS

JR

94-129

315
318
333

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGCOH)
GENERAL SECRETARIAT OF WORKS
THE FEDERAL DISTRICT OF MEXICO

**THE FEASIBILITY STUDY
ON
WASTEWATER TREATMENT
IN
THE FEDERAL DISTRICT OF MEXICO**

DATA BOOK

JICA LIBRARY



1119589(8)

27644

DECEMBER 1994

PACIFIC CONSULTANTS INTERNATIONAL, TOKYO

国際協力事業団

27644

Table of Contents

Data/Calculations

1. Design Calculation for Wastewater Treatment Plant
2. Hydraulic Calculation for Urgent Project
3. Hydraulic Calculation for Final Project
4. Bill of Quantities
5. Bill of Quantities (Priced)
6. Wastewater and Sludge Treatment System Proposed by CNA
7. Results of the Geological Survey
8. Water Quality Data of Termoelectrica Valle de Mexico Treatment Plant and Gran Canal

Drawings

1. General Layout
2. Layout of Wastewater Treatment Plant
3. Hydraulic Profile of Wastewater Treatment Plant
4. Receiving Tank - Plan & Section
5. Distribution Tank - Plan & Section
6. Aeration Tank & Sedimentation Tank - Plan
7. Aeration Tank & Sedimentation Tank - Section
8. Disinfection Tank
9. Discharge Channel
10. Sludge Digestion Tank - Plan & Section
11. Process diagram of Wastewater Treatment Plant

12. Single Line Diagram
13. Control Building
14. Blower House
15. Centrifugal Thickener House
16. Sludge Dewatering House

DATA / CALCULATIONS

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY

DESIGN CALCULATION
FOR
WASTEWATER TREATMENT PLANT

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY

Design Calculation for Wastewater Treatment Plant

Design Condition

| Design Condition | | Unit | Final Project | Urgent Project |
|--|---------------|----------------------|---------------|----------------|
| Design Flow Rate (Daily Average) | Qd | m ³ /d | 3,456,000 | 3,024,000 |
| | Qm | m ³ /min. | 2,400 | 2,100 |
| | Qs | m ³ /sec. | 40.0 | 35.0 |
| Number of Unit | Nu | unit | 8 | 2 |
| Design Flow Rate per 1 Unit (Daily Average) | Qd' | m ³ /d | 432,000 | 1,512,000 |
| | Qm' | m ³ /min. | 300 | 1,050 |
| | Qs' | m ³ /sec. | 5.0 | 17.5 |
| Influent Water Quality (BOD) | Cbod | mg/l | 245 | 220 |
| | (SS) Css | mg/l | 260 | 235 |

1) Primary Sedimentation Tank

| Design Item | | Unit | Final Project | Urgent Project | | |
|-----------------------|----------------------------|------------------|-----------------------------------|----------------|--------|----|
| Design Calculation | Surface Loading | Ls | m ³ /m ² •d | 35 | --- | |
| | Required Surface Area | A=Qm'/Ls | m ² | 12,343 | --- | |
| Verification | Effective Width | B | m | 5 | 5 | |
| | Size of Structure | Effective Length | L | m | 39 | 39 |
| | | Effective Depth | H | m | 3 | 3 |
| | No. of Basin per 1 Unit | - | basin | 16 | 16 | |
| | No. of Channel per 1 Basin | - | channel | 4 | 4 | |
| | No. of Channel per 1 Unit | n | channel | 64 | 64 | |
| | Surface Loading ≤ Ls | Ls'=Qd'/B/L/n | m ³ /m ² •d | 34.62 | 121.15 | |
| | Surface Area ≥ A | A'=B x L x n | m ² | 12,480 | 12,480 | |
| | Average Velocity | Vps'=Qm'/B/H/n | m/min. | 0.31 | 1.09 | |
| Settling Time | T=L/Vps' | hr. | 2.1 | 0.6 | | |

2) Aeration Tank

| Design Item | | Unit | Final Project | Urgent Project |
|-----------------------------------|-------------------------------------|-------------------------|---------------|----------------|
| Influent Water Quality (BOD) | Cboda | mg/l | 196 | 220 |
| | (SS) Cssa | mg/l | 156 | 235 |
| F : M | Rfm | - | 0.30 | 1.5 - 5.0 |
| BOD Volumetric Load | Lv' | BODkg/m ³ •d | 0.32 - 0.64 | 1.2 - 2.4 |
| Return Sludge Solid Concentration | Cr | mg/l | 8,000 | 6,500 |
| Return Sludge Ratio | Rs | - | 35% | 10% |
| MLSS Concentration | Cmlss | mg/l | 2,190 | 805 |
| | Cmlss=(Cssa+Cr x Rs/100)/(1+Rs/100) | | | |
| MLVSS Concentration | Cmlvss = 0.75 x Cmlss | mg/l | 1,643 | 604 |
| Required Tank Volume | Va | m ³ | 171,836 | --- |
| | Va=(Qd' x Cboda)/(Rfm x Cmlvss) | | | |

| | | | | | | |
|--------------|---------------------------|--|-------------------------|---------|---------|----|
| Verification | Effective Width | $B=H \times (1 - 2)$ | m | 10.3 | 10.3 | |
| | Size of Structure | Effective Length | L | m | 89 | 89 |
| | | Effective Depth | H | m | 6 | 6 |
| | No. of Basin | n | basin | 32 | 32 | |
| | Cross Section per 1 Basin | $A_s=B \times H - 2$ | m ² | 59.8 | 59.8 | |
| | Volume per 1 Unit | $V_a=A_s \times L \times n$ | m ³ | 170,310 | 170,310 | |
| | F : M | $R_{fm}=(Qd' \times C_{boda})/V_a/C_{mlvss}$ | - | 0.30 | 3.23 | |
| | BOD Volumetric Load | $L_v=(Qd' \times C_{boda})/V_a/1,000$ | BODkg/m ³ ·d | 0.50 | 1.95 | |
| | Aeration Time | $T_a=V_a/Qd' \times 24$ | hr. | 9.5 | 2.7 | |
| | Sludge Age | $S_a=(C_{mlss} \times V_a)/Qd'/C_{ssa}$ | day | 5.53 | 0.39 | |

3) Secondary Sedimentation Tank

| Design Item | | | Unit | Final Project | Urgent Project | |
|--------------------|----------------------------|---|-----------------------------------|---------------|----------------|-----|
| Design Calculation | Surface Loading | L_s | m ³ /m ² ·d | 25 | --- | |
| | Required Surface Area | $A=Qm'/L_s$ | m ² | 17,280 | --- | |
| Verification | Effective Width | B | m | 5 | 5 | |
| | Size of Structure | Effective Length | $L=B' \times (3 \sim 4)$ | m | 54 | 54 |
| | | Effective Depth | H | m | 3.5 | 3.5 |
| | No. of Basin per 1 Unit | - | basin | 16 | 16 | |
| | No. of Channel per 1 Basin | - | channel | 4 | 4 | |
| | No. of Channel per 1 Unit | n | channel | 64 | 64 | |
| | Surface Loading $\leq L_s$ | $L_s'=Qd'/B/L/n$ | m ³ /m ² ·d | 25.00 | 87.50 | |
| | Surface Area $\geq A$ | $A'=B \times L \times n$ | m ² | 17,280 | 17,280 | |
| | Average Velocity | $V_{ps}=Qm'/B/H/n$ | m/min. | 0.27 | 0.94 | |
| | Solid Loading | $LD_{ss}=(Qd' \times C_{mlss} \times 1,000)/A'$ | kg/m ² ·d | 54.8 | 70.4 | |
| Settling Time | $T'=L/V_{ps}'$ | hr. | 3.3 | 1.0 | | |

4) Gravity Thickener

| Design Item | | | Unit | Final Project | Urgent Project | |
|--------------------|------------------------|---------------------------------------|----------------------|---------------|----------------|-----|
| Design Calculation | Primary Sludge | D_{pv} | m ³ /d | 2,010 | --- | |
| | | D_{ps} | t/d | 60.22 | --- | |
| | Solid Loading | LD_{gs} | kg/m ² ·d | 110 | --- | |
| | Required Surface Area | $A_g=D_{ps}/L_{Dgs}$ | m ² | 547.5 | --- | |
| Verification | Size of Structure | Diameter | D_g | m | 19 | --- |
| | | Depth | H_g | m | 4 | --- |
| | No. of Tank | n_g | tank | 2 | --- | |
| | Effective Surface Area | A_g' | m ² | 567.1 | --- | |
| | Effective Volume | $V_g=A_g' \times H_g$ | m ³ | 2,268.4 | --- | |
| | Solid Loading | $LD_{gs}'=D_{ps} \times 1,000 / A_g'$ | kg/m ² ·d | 106.2 | --- | |
| | Retention Time | $T_g'=V_g/D_{pv}$ | day | 1.13 | --- | |

5) Centrifugal Thickener

| | Design Item | | Unit | Final Project | Urgent Project |
|--------------------|------------------------|-----|---------------------|---------------|----------------|
| Design Calculation | Activated Sludge | Dsv | m ³ /d | 9,670 | 35,240 |
| | | Dss | t/d | 77.38 | 229.09 |
| | Capacity of 1 Set | Vc | m ³ /hr. | 170 | 170 |
| | Operation Hour per Day | He | hr. | 24 | 24 |
| | Operation Efficiency | Ect | -- | 80% | 80% |
| Verification | No. of Set | n | set | 3 | 11 |
| | Capacity of 1 Unit | Vc' | m ³ /d | 9,792 | 35,904 |

6) Anaerobic Digester

| | Design Item | | Unit | Final Project | Urgent Project | |
|--------------------|---|----------|-------------------|---------------|----------------|------|
| Design Calculation | Primary Sludge from Gravity Thickener | Dgv | m ³ /d | 800 | --- | |
| | | Dgs | t/d | 48.18 | --- | |
| | Activated Sludge from Centrifugal Thickener | Dcv | m ³ /d | 1,160 | 3,440 | |
| | | Dcs | t/d | 69.64 | 206.18 | |
| | Total Sludge | Dtv | m ³ /d | 1,960 | 3,440 | |
| | | Dts | t/d | 117.82 | 206.18 | |
| | Retention Time | Tr | day | 20 | 20 | |
| Verification | Size of Structure | Diameter | Da | m | 26 | 26 |
| | | Depth | Ha | m | 12.5 | 12.5 |
| | Capacity of 1 Set | Va | m ³ | 6,636.6 | 6,636.6 | |
| | No. of Set | n | set | 6 | 10 | |
| | Capacity of 1 Unit | Va' | m ³ | 39,819.6 | 66,366.0 | |
| | Retention Time | Tr' | day | 20.3 | 19.3 | |

7) Belt Filter Press

| | Design Item | | Unit | Final Project | Urgent Project |
|--------------------|---|-----|-------------------|---------------|----------------|
| Design Calculation | Digested Sludge from Anaerobic Digester | Ddv | m ³ /d | 1,110 | 1,950 |
| | | Dds | t/d | 66.77 | 116.83 |
| | Sludge Loading per Belt Width | Lbs | kg/hr*m | 250 | 250 |
| | Operation Time per Day | To | hr. | 12 | 12 |
| | Operation Efficiency | Eb | -- | 80% | 80% |
| Verification | Belt Width | Wb | m | 3 | 3 |
| | Capacity of 1 Set | Cb | kg/set/d | 7,200 | 7,200 |
| | No. of Set | n | set | 10 | 16 |
| | Capacity of 1 Unit | Vb' | t/d | 72.00 | 115.20 |

HYDRAULIC CALCULATION

FOR

URGENT PROJECT

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY

Hydraulic Calculation for Urgent Project


1) Connection Channel from Effluent Flume to Discharge Channel

Calculation Condition

| | | |
|--|----------------|------------------------|
| Flow Rate per 1 Unit | Q' | 17.5 m ³ /s |
| Width of Weir | B | 6.5 m |
| Water Depth of Discharge Channel | H | 2.980 m |
| Height of Weir | H _w | 1.624 m |
| Invert Elevation of Upstream of Discharge Channel | + 2,229.912 m | |
| Water Surface Elevation of Upstream of Discharge Channel | + 2,232.892 m | |

Calculation

| | | |
|---|----------------|---------|
| Head over Weir Crest | h _c | 1.289 m |
| $h_c = (Q/1.84/B)^{(2/3)}$ | | |
| Water Surface Elevation of Downstream of Effluent Flume | + 2,232.825 m | |
| | = 2,234.190 m | |



2) Effluent Flume of Secondary Sedimentation Tank

< Section a-a >

Calculation Condition

| | | |
|--|----------------|------------------------|
| Flow Rate per 1 Unit | Q _a | 17.5 m ³ /s |
| Width of Flume | B | 3.0 m |
| Length of Flume | L | 93.2 m |
| Invert Elevation of Downstream of Flume | + 2,231.276 m | |
| Water Surface Elevation of Downstream of Flume | + 2,234.190 m | |
| Water Depth of Flume | H | 2.914 m |

Calculation

| | | | |
|-------------------------------|---------------------|---|----------------------|
| Cross-sectional Area in Flume | A=BxH | A | 8.742 m ² |
| Wetted Perimeter | P=B+2xH | P | 8.828 m |
| Hydraulic Radius | R=A/P | R | 0.990 m |
| Velocity in Flume | v=Q _a /A | v | 2.002 m/s |
| Friction Head | h _{fa-a} | | 0.064 m |

$$h_{f a-a} = ((n \times v)^2) / (R^{4/3})$$

| | | |
|---|---|-------------|
| Difference of Invert Level between Downstream and Section a-a | + | 0.504 m |
| Invert Elevation of Section a-a of Flume | + | 2,231.780 m |
| Water Surface Elevation of Section a-a of Flume | + | 2,234.254 m |

< Section b-b >

Calculation Condition

| | | | |
|----------------------|------------------------|-------|--------------------------|
| Flow Rate | $Q_b = Q_a \times 3/4$ | Q_b | 13.125 m ³ /s |
| Width of Flume | | B | 3.0 m |
| Length of Flume | | L | 93.2 m |
| Water Depth of Flume | | H | 2.474 m |

Calculation

| | | | |
|-------------------------------|----------------------|-------------|----------------------|
| Cross-sectional Area in Flume | $A = B \times H$ | A | 7.422 m ² |
| Wetted Perimeter | $P = B + 2 \times H$ | P | 7.948 m |
| Hydraulic Radius | $R = A/P$ | R | 0.934 m |
| Velocity in Flume | $v = Q_a/A$ | v | 1.768 m/s |
| Friction Head | | $h_{f b-b}$ | 0.054 m |

$$h_{f b-b} = L \times ((n \times v)^2) / (R^{4/3})$$

| | | |
|--|---|-------------|
| Difference of Invert Level between Section a-a and Section b-b | + | 0.500 m |
| Invert Elevation of Section b-b of Flume | + | 2,232.280 m |
| Water Surface Elevation of Section b-b of Flume | + | 2,234.308 m |

< Section c-c >

Calculation Condition

| | | | |
|----------------------|------------------------|-------|-------------------------|
| Flow Rate | $Q_c = Q_a \times 2/4$ | Q_c | 8.750 m ³ /s |
| Width of Flume | | B | 3.0 m |
| Length of Flume | | L | 93.2 m |
| Water Depth of Flume | | H | 2.028 m |

Calculation

| | | | |
|-------------------------------|----------------------|-------------|----------------------|
| Cross-sectional Area in Flume | $A = B \times H$ | A | 6.084 m ² |
| Wetted Perimeter | $P = B + 2 \times H$ | P | 7.056 m |
| Hydraulic Radius | $R = A/P$ | R | 0.862 m |
| Velocity in Flume | $v = Q_a/A$ | v | 1.438 m/s |
| Friction Head | | $h_{f c-c}$ | 0.040 m |

$$h_{f c-c} = L \times ((n \times v)^2) / (R^{4/3})$$

| | | |
|--|---|-------------|
| Difference of Invert Level between Section b-b and Section c-c | + | 0.500 m |
| Invert Elevation of Section c-c of Flume | + | 2,232.780 m |
| Water Surface Elevation of Section c-c of Flume | + | 2,234.348 m |


< Section d-d >

Calculation Condition

| | | | |
|----------------------|------------------------|-------|-------------------------|
| Flow Rate | $Q_d = Q_a \times 1/4$ | Q_d | 4.375 m ³ /s |
| Width of Flume | | B | 3.0 m |
| Length of Flume | | L | 93.2 m |
| Water Depth of Flume | | H | 1.568 m |

Calculation

| | | | |
|--|------------------|---|----------------------|
| Cross-sectional Area in Flume | $A=B \times H$ | A | 4.704 m ² |
| Wetted Perimeter | $P=B+2 \times H$ | P | 6.136 m |
| Hydraulic Radius | $R=A/P$ | R | 0.767 m |
| Velocity in Flume | $v=Q \div A$ | v | 0.930 m/s |
| Friction Head | h_{fd-d} | | 0.019 m |
| $h_{fd-d} = L \times ((n \times v)^2) / (R^{4/3})$ | | | |
| Invert Elevation of Section d-d of Flume | | + | 2,232.780 m |
| Water Surface Elevation of Section d-d of Flume | | + | 2,234.367 m |
| | | = | 2,234.370 m |



3) Effluent Collection Trough

< Effluent Collection Trough >

Calculation Condition

| | | |
|--------------------------------|----|-------------------------|
| Flow Rate per 1 Unit | Q' | 17.5 m ³ /s |
| Number of Channel per 1 Unit | n1 | 64 |
| Number of Trough per 1 Channel | n2 | 2 |
| Flow Rate per 1 Trough | Q | 0.137 m ³ /s |

$Q = Q' / (n1 \times n2)$


| | | |
|---|---|-------------|
| Width of Trough | B | 0.4 m |
| Invert Gradient | i | 0.00 |
| Water Surface Elevation of Section d-d of Flume | + | 2,234.370 m |

Calculation

| | | |
|--|----|---------|
| Overflow Depth of Downstream of Effluent Collection Trough | he | 0.200 m |
| Head over Weir Crest | hc | 0.229 m |

$$h_c = (1 \times Q^2 / 9.8 / B^2)^{1/3}$$

| | | |
|---|----|-------------|
| Water Depth of Upstream of Effluent Collection Trough | ho | 0.4 m |
| $h_o = (2 \times h_c^3) / (h_c + h_c^2)^{1/2}$ | | |
| Invert Elevation of Effluent Collection Trough | + | 2,234.170 m |
| Water Surface Elevation of Upstream of Effluent Collection Trough | + | 2,234.570 m |




< V-notch Weir >

Calculation Condition

| | | |
|------------------------------|----|---------------------------------------|
| Flow Rate per 1 Unit | Q' | 17.5 m ³ /s |
| Number of Channel per 1 Unit | n1 | 64 channel(s) |
| Flow Rate per 1 Channel | Q1 | 0.273 m ³ /s |
| $Q1 = Q' / n1$ | | |
| Weir Over Flow Loading | W1 | 190 m ³ /m ² ·d |

Calculation

| | | |
|---|----|----------------------------|
| Width of V-notch Weir | Bw | 0.125 m |
| Required Length of Trough per 1 Channel | Lt | 125 m |
| Number of V-notch Weir per 1 Channel | Nn | 1,000 |
| Flow Rate through 1 V-notch Weir | Qw | 0.000273 m ³ /s |
| Head over V-notch Weir Crest | h | 0.03 m |
| $h = (Q / 1.42)^{2/5}$ | | |
| Allowance of Height of V-notch Weir | ha | 0.03 m |
| Water Surface Elevation of Secondary Sedimentation Tank | + | 2,234.630 m |



4) Connection Channel between Aeration Tank and Secondary Sedimentation Tank

Calculation Condition

| | | |
|---|----|-------------|
| Allowance of Head Loss between Connection Channel and Aeration Tank | ha | 0.050 m |
| Invert Elevation of Connection Channel | + | 2,234.100 m |
| Water Surface Elevation of Upstream of Connection Channel | + | 2,234.680 m |

5) Weir of Aeration Tank


Calculation Condition

| | | |
|--|----------------|-------------------------|
| Flow Rate per 1 Unit | Q' | 17.5 m ³ /s |
| Return Sludge Ratio | Rs | 10 % |
| Flow Rate $Q_1 = Q' \times (1 + Rs/100)$ | Q ₁ | 19.25 m ³ /s |
| Number of Channel per 1 Basin | n ₁ | 2 channel(s) |
| Number of Basin per 1 Unit | n ₂ | 16 basin(s) |
| Number of Channel per 1 Unit | n ₃ | 32 channel(s) |
| Design Flow Rate per 1 Channel | Q | 0.602 m ³ /s |

$$Q = Q'/n_3$$

Calculation

| | | |
|--|----|-------------|
| Width of Weir | B | 4.0 m |
| Type of Weir | | Rectangular |
| Head over the Weir Crest | hc | 0.188 m |
| $hc = (Q/1.84/B)^{(2/3)}$ | = | 0.190 m |
| Allowance of Weir Height | | 0.050 m |
| Elevation of Weir of Aeration Tank | + | 2,234.730 m |
| Water Surface Elevation of Downstream of Weir of Aeration Tank | + | 2,234.920 m |



6) Distribution Channel

< Distribution Channel 1 >

Calculation Condition

| | | |
|--|----|-------------------------|
| Flow Rate per 1 Unit | Q' | 17.5 m ³ /s |
| Number of Distribution Channel 1 | n1 | 8 |
| Flow Rate per 1 Distribution Channel 1 | Q1 | 2.188 m ³ /s |
| $Q1=Q'/n1$ | | |
| Width of Distribution Channel 1 | B1 | 2.0 m |
| Length of Distribution Channel 1 | L1 | 28 m |
| Channel Slope | i1 | 0.75 ‰ |
| Allowance between Water Surface | | |
| Elevation of Aeration Tank and Invert | | |
| Elevation of Distribution Channel 1 | + | 0.080 m |
| Invert Elevation of Distribution Channel 1 | + | 2,235.000 m |

Calculation

| | | |
|---|-----|---------------------------|
| Water Depth in Distribution Channel 1 | H1 | 0.866 m |
| Cross-sectional Area of Distribution Channel 1 | A1 | 1.732 m ² |
| Wetted Perimeter $P1=B1+2xH1$ | P1 | 3.732 m |
| Hydraulic Radius $R1=A1/P1$ | R1 | 0.464 m |
| Velocity in Channel 1 | v1 | 1.263 m/s |
| $v1=1/n*(R1^{(2/3)}*(i1^{(1/2)}))$ | | |
| (Flow Rate in Channel 1 | Q1' | 2.188 m ³ /s) |
| Head loss in Bend | hi1 | 0.081 m |
| $hi1=1.0 \times (v1^2)/2/9.8$ | | |
| Invert Elevation of Upstream of Distribution Channel 1 | + | 2,235.021 m |
| Water Surface Elevation of Upstream of Distribution Channel 1 | + | 2,235.968 m |

< Distribution Channel 2 >

Calculation Condition

| | | |
|--|----|-------------------------|
| Flow Rate per 1 Unit | Q' | 17.5 m ³ /s |
| Number of Distribution Channel 2 | n2 | 4 |
| Flow Rate per 1 Distribution Channel 2 | Q2 | 4.375 m ³ /s |
| $Q2=Q'/n2$ | | |
| Width of Distribution Channel 2 | B2 | 2.5 m |
| Length of Distribution Channel 2 | L2 | 43 m |
| Channel Slope | i2 | 0.75 ‰ |

Calculation

| | | |
|--|-----|---------------------------|
| Water Depth in Inlet Channel 2 | H2 | 1.164 m |
| Cross-sectional Area of Distribution Channel 2 | A2 | 2.909 m ² |
| Wetted Perimeter $P2=B2+2xH2$ | P2 | 4.827 m |
| Hydraulic Radius $R2=A2/P2$ | R2 | 0.603 m |
| Velocity in Channel 2 | v2 | 1.504 m/s |
| $v2=1/n*(R2^{(2/3)}*(i2^{(1/2)}))$ | | |
| (Flow Rate in Channel 2 | Q2' | 4.375 m ³ /s) |
| Head loss in Bend | hi2 | 0.115 m |
| $hi2=1.0 \times (v1^2)/2/9.8$ | | |

Invert Elevation of Upstream of Distribution Channel 2 + 2,235.053 m
 Water Surface Elevation of Upstream of Distribution Channel 2 + 2,236.332 m

< Distribution Channel 3 >


Calculation Condition


Flow Rate per 1 Unit Q' 17.5 m³/s
 Number of Distribution Channel 3 n_3 4
 Flow Rate per 1 Distribution Channel 3 Q_3 4.375 m³/s
 $Q_3 = Q'/n_3$
 Width of Distribution Channel 3 B_3 2.5 m
 Length of Distribution Channel 3 L_3 148 m
 Channel Slope i_3 0.75 ‰
 Allowance of Invert Elevation between Distribution Channel 2 and Channel 3 0.300 m
 Invert Elevation of Downstream of Distribution Channel 3 + 2,235.353 m

Calculation

Water Depth in Inlet Channel 2 H_3 1.164 m
 Cross-sectional Area of Distribution Channel 3 A_3 2.909 m²
 Wetted Perimeter $P_3 = B_3 + 2 \times H_3$ P_3 4.827 m
 Hydraulic Radius $R_3 = A_3 / P_3$ R_3 0.603 m
 Velocity in Channel 3 v_3 1.504 m/s
 $v_3 = 1/n \times (R^{2/3}) \times (i_3^{1/2})$
 (Flow Rate in Channel 3 Q_3 4.375 m³/s)
 Head loss in Bend h_{i3} 0.346 m
 $h_{i3} = (v_3^2) / 2 \times 9.8 \times 3 \text{ places}$

Invert Elevation of Upstream of Distribution Channel 3 + 2,235.464 m
 Water Surface Elevation of Upstream of Distribution Channel 3 + 2,236.974 m






7) Distribution Tank

Calculation Condition

| | | |
|-------------------------------------|-----------|-------------------------|
| Flow Rate | Q' | 17.5 m ³ /s |
| Number of Weir of Distribution Tank | $n1$ | 4 |
| Flow Rate per 1 Weir | Q | 4.375 m ³ /s |
| | $Q=Q'/n1$ | |
| Width of Weir | $B1$ | 2.5 m |

Calculation

| | | |
|--|------|-------------------------|
| Head over Crest of Upstream of Weir | $h1$ | 1.196 m |
| Head over Crest of Downstream of Weir | $h2$ | 0.804 |
| Flow Rate over Submersible Weir | Q' | 4.375 m ³ /s |
| Elevation of Weir of Distribution Tank | + | 2,236.170 m |
| Water Surface Elevation of Distribution Tank | + | 2,237.370 m |



8) Receiving Tank

< Connection Pipe between Distribution Tank and Receiving Tank >

Calculation Condition

| | | |
|--|----|------------------------|
| Flow Rate per 1 Unit | Q' | 17.5 m ³ /s |
| Diameter of Connection Pipe from Receiving Tank to Distribution Tank | D | 2.8 m |
| Pipe Length | L | 750 m |

Calculation

| | | |
|---|---------------------------|---------------------|
| Cross-sectional Area of Pipe | A | 6.16 m ² |
| Velocity | $v=Q'/A$ | 2.841 m/s |
| Hydraulic Radius | $R=D/4$ | 0.7 m |
| Surface Roughness Coefficient | Ch | 130 |
| Friction Head in Pipe | hl | 1.301 m |
| $hl=10.666 \times Ch^{(-1.85)} \times D^{(-4.87)} \times Q'^{1.85} \times L$ | | |
| Entrance Loss | $he=0.5 \times v^2/2/9.8$ | he 0.206 m |
| Exit Loss | $ho=1.0 \times v^2/2/9.8$ | ho 0.412 m |
| Total Head Loss in Connection Pipe between Distribution Tank and Receiving Tank | ht | 1.919 m |
| | = | 1.920 |
| Water Surface Elevation of Downstream of Receiving Tank | + | 2,239.290 m |


< Receiving Tank >

Calculation Condition

| | | |
|--------------------------------|-----------|------------------------|
| Flow Rate | Q' | 35.0 m ³ /s |
| Number of Weir | nI | 2 weir(s) |
| Design Flow Rate per 1 Channel | Q | 17.5 m ³ /s |
| | $Q=Q'/nI$ | |

Calculation

| | | |
|--|-------------------------|-------------|
| Width of Weir | B | 3.0 m |
| Type of Weir | | Rectangular |
| Head over the Weir Crest | hc | 2.158 m |
| | $hc=(Q/1.84/B)^{(2/3)}$ | = 2.160 m |
| Allowance of Weir Height | | 0.050 m |
| Elevation of Weir Crest | + | 2,239.400 m |
| Water Surface Elevation of Upwntstream of Weir | + | 2,241.560 m |



HYDRAULIC CALCULATION

FOR

FINAL PROJECT

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY

Hydraulic Calculation for Final Project


1) Connection Channel from Effluent Flume to Discharge Channel

Calculation Condition

| | | |
|--|----------------|-----------------------|
| Flow Rate per 1 Unit | Q' | 5.0 m ³ /s |
| Width of Weir | B | 6.5 m |
| Water Depth of Discharge Channel | H | 1.620 m |
| Height of Weir | H _w | 1.624 m |
| Invert Elevation of Upstream of Discharge Channel | + | 2,231.276 m |
| Water Surface Elevation of Upstream of Discharge Channel | + | 2,232.896 m |

Calculation

| | | |
|---|----------------|-------------|
| Head over Weir Crest | h _c | 0.559 m |
| $h_c = (Q/1.84/B)^{2/3}$ | | |
| Water Surface Elevation of Downstream of Effluent Flume | + | 2,233.459 m |
| | = | 2,233.460 m |



2) Effluent Flume of Final Sedimentation Tank

< Section a-a >

Calculation Condition

| | | |
|--|----------------|-----------------------|
| Flow Rate per 1 Unit | Q _a | 5.0 m ³ /s |
| Width of Flume | B | 3.0 m |
| Length of Flume | L | 93.2 m |
| Invert Elevation of Downstream of Flume | + | 2,231.276 m |
| Water Surface Elevation of Downstream of Flume | + | 2,233.460 m |
| Water Depth of Flume | H | 2.184 m |

Calculation

| | | | |
|-------------------------------|----------------------|---|----------------------|
| Cross-sectional Area in Flume | $A = B \times H$ | A | 6.552 m ² |
| Wetted Perimeter | $P = B + 2 \times H$ | P | 7.368 m |
| Hydraulic Radius | $R = A/P$ | R | 0.889 m |
| Velocity in Flume | $v = Q_a/A$ | v | 0.763 m/s |
| Friction Head | h _{fa-a} | | 0.011 m |

| | | | |
|---|--|---|-------------|
| | $h_{f a-a} = ((n \times v)^2) / (R^{4/3})$ | | |
| Difference of Invert Level between | | | |
| Downstream and Section a-a | | + | 0.504 m |
| Invert Elevation of Section a-a of Flume | | + | 2,231.780 m |
| Water Surface Elevation of Section a-a of Flume | | + | 2,233.471 m |

< Section b-b >

Calculation Condition

| | | | |
|----------------------|------------------------|----|-------------------------|
| Flow Rate | $Q_b = Q_a \times 3/4$ | Qb | 3.750 m ³ /s |
| Width of Flume | | B | 3.0 m |
| Length of Flume | | L | 93.2 m |
| Water Depth of Flume | | H | 1.691 m |

Calculation

| | | | |
|-------------------------------|----------------------|-------------|----------------------|
| Cross-sectional Area in Flume | $A = B \times H$ | A | 5.073 m ² |
| Wetted Perimeter | $P = B + 2 \times H$ | P | 6.382 m |
| Hydraulic Radius | $R = A/P$ | R | 0.795 m |
| Velocity in Flume | $v = Q_a/A$ | v | 0.739 m/s |
| Friction Head | | $h_{f b-b}$ | 0.012 m |

| | | | |
|---|---|---|-------------|
| | $h_{f b-b} = L \times ((n \times v)^2) / (R^{4/3})$ | | |
| Difference of Invert Level between Section | | | |
| a-a and Section b-b | | + | 0.500 m |
| Invert Elevation of Section b-b of Flume | | + | 2,232.280 m |
| Water Surface Elevation of Section b-b of Flume | | + | 2,233.483 m |

< Section c-c >

Calculation Condition

| | | | |
|----------------------|------------------------|----|-------------------------|
| Flow Rate | $Q_c = Q_a \times 2/4$ | Qc | 2.500 m ³ /s |
| Width of Flume | | B | 3.0 m |
| Length of Flume | | L | 93.2 m |
| Water Depth of Flume | | H | 1.203 m |

Calculation

| | | | |
|-------------------------------|----------------------|-------------|----------------------|
| Cross-sectional Area in Flume | $A = B \times H$ | A | 3.609 m ² |
| Wetted Perimeter | $P = B + 2 \times H$ | P | 5.406 m |
| Hydraulic Radius | $R = A/P$ | R | 0.668 m |
| Velocity in Flume | $v = Q_a/A$ | v | 0.693 m/s |
| Friction Head | | $h_{f c-c}$ | 0.013 m |

| | | | |
|---|---|---|-------------|
| | $h_{f c-c} = L \times ((n \times v)^2) / (R^{4/3})$ | | |
| Difference of Invert Level between Section | | | |
| b-b and Section c-c | | + | 0.500 m |
| Invert Elevation of Section c-c of Flume | | + | 2,232.780 m |
| Water Surface Elevation of Section c-c of Flume | | + | 2,233.496 m |


< Section d-d >

Calculation Condition

| | | | |
|----------------------|------------------------|----|-------------------------|
| Flow Rate | $Q_d = Q_a \times 1/4$ | Qd | 1.250 m ³ /s |
| Width of Flume | | B | 3.0 m |
| Length of Flume | | L | 93.2 m |
| Water Depth of Flume | | H | 0.716 m |

Calculation

| | | | |
|---|------------------|------------|----------------------|
| Cross-sectional Area in Flume | $A=B \times H$ | A | 2.148 m ² |
| Wetted Perimeter | $P=B+2 \times H$ | P | 4.432 m |
| Hydraulic Radius | $R=A/P$ | R | 0.485 m |
| Velocity in Flume | $v=Qa/A$ | v | 0.582 m/s |
| Friction Head | h_{fd-d} | h_{fd-d} | 0.014 m |
| $h_{fd-d}=L \times ((n \times v)^2)/(R^{4/3})$ | | | |
| Invert Elevation of Section d-d of Flume | | + | 2,232.780 m |
| Water Surface Elevation of Section d-d of Flume | | + | 2,233.510 m |
| | | = | 2,233.510 m |



3) Effluent Collection Trough of Secondary Sedimentation Tank

< Effluent Collection Trough >

Calculation Condition

| | | |
|--------------------------------|------|-------------------------|
| Flow Rate per 1 Unit | Q' | 5.0 m ³ /s |
| Number of Channel per 1 Unit | $n1$ | 64 |
| Number of Trough per 1 Channel | $n2$ | 2 |
| Flow Rate per 1 Trough | Q | 0.039 m ³ /s |


$Q=Q'/(n1 \times n2)$

| | | |
|---|---|-------------|
| Width of Trough | B | 0.4 m |
| Length of Trough | L | 54.0 m |
| Invert Gradient | i | 0.00 |
| Water Surface Elevation of Section d-d of Flume | + | 2,233.510 m |

Calculation

| | | |
|--------------------------------------|-------|---------|
| Critical Depth | h_c | 0.099 m |
| $h_c=(1 \times Q^{2/9.8}/B^2)^{1/3}$ | | |

| | | |
|---|--------------------------------|-------------|
| Water Depth of Upstream of Effluent Collection Trough | h_o | 0.180 m |
| | $h_o = (3 \times h_c^2)^{1/2}$ | |
| Invert Elevation of Effluent Collection Trough | + | 2,234.170 m |
| Water Surface Elevation of Upstream of Effluent Collection Trough | + | 2,234.350 m |



< V-notch Weir >

Calculation Condition

| | | |
|------------------------------|-------|-------------------------|
| Flow Rate per 1 Unit | Q' | 5.0 m ³ /s |
| Number of Channel per 1 Unit | n_1 | 64 channel(s) |
| Flow Rate per 1 Channel | Q_1 | 0.078 m ³ /s |


$$Q_1 = Q' / n_1$$

Calculation

| | | |
|---|-------|----------------------------|
| Width of V-notch Weir | B_w | 0.125 m |
| Required Length of Trough per 1 Channel | L_t | 125 m |
| Weir Over Flow Loading | W_l | 54 m ³ /m |
| Number of V-notch Weir per 1 Channel | N_n | 1,000 |
| Flow Rate through 1 V-notch Weir | Q_w | 0.000078 m ³ /s |
| Head over V-notch Weir Crest | h | 0.02 m |

$$h = (Q / 1.42)^{2/5}$$

| | | |
|---|-------|-------------|
| Allowance of Height of V-notch Weir | h_a | 0.03 m |
| Water Surface Elevation of Final Sedimentation Tank | + | 2,234.400 m |



4) Connection Channel between Aeration Tank and Secondary Sedimentation Tank

Calculation Condition

| | | |
|---|----|-------------|
| Allowance of Head Loss between Connection Channel and Aeration Tank | ha | 0.050 m |
| Invert Elevation of Connection Channel | + | 2,234.100 m |
| Water Surface Elevation of Upstream of Connection Channel | + | 2,234.450 m |

5) Weir of Aeration Tank


Calculation Condition

| | | |
|--------------------------------|-----------------------------|-------------------------|
| Flow Rate per 1 Unit | Q' | 5.0 m ³ /s |
| Return Sludge Ratio | Rs | 10 % |
| Flow Rate | $Q1=Q' \times (1 + Rs/100)$ | 5.50 m ³ /s |
| Number of Channel per 1 Basin | n1 | 2 channel(s) |
| Number of Basin per 1 Unit | n2 | 16 basin(s) |
| Number of Channel per 1 Unit | n3 | 32 channel(s) |
| Design Flow Rate per 1 Channel | Q | 0.172 m ³ /s |

$Q=Q'/n3$

Calculation

| | | |
|--|-------------------------|-------------|
| Width of Weir | B | 4.0 m |
| Type of Weir | | Rectangular |
| Head over the Weir Crest | hc | 0.082 m |
| | $hc=(Q/1.84/B)^{(2/3)}$ | = 0.090 m |
| Allowance of Weir Height | | 0.280 m |
| Elevation of Weir of Aeration Tank | + | 2,234.730 m |
| Water Surface Elevation of Upstream of Weir of Aeration Tank | + | 2,234.820 m |



6) Connection Channel between Aeration Tank and Primary Sedimentation Tank

Calculation Condition

| | | |
|---|----|-------------|
| Allowance of Head Loss between Aeration Tank and Primary sedimentation Tank | ha | 0.050 m |
| Invert Elevation of Connection Channel | + | m |
| Water Surface Elevation of Upstream of Connection Channel | + | 2,234.870 m |

7) Effluent Collection Trough of Primary Sedimentation Tank

< Effluent Collection Trough >

Calculation Condition

| | | |
|--------------------------------|----|-------------------------|
| Flow Rate per 1 Unit | Q' | 5.0 m ³ /s |
| Number of Channel per 1 Unit | n1 | 64 |
| Number of Trough per 1 Channel | n2 | 2 |
| Flow Rate per 1 Trough | Q | 0.039 m ³ /s |

$$Q = Q' / (n1 \times n2)$$

| | | |
|--|---|---------|
| Width of Trough | B | 0.4 m |
| Invert Gradient | i | 0.00 |
| Water Surface Elevation of Upstream of Aeration Tank | + | 0.172 m |

Calculation

| | | |
|----------------|----|---------|
| Critical Depth | hc | 0.099 m |
|----------------|----|---------|

$$hc = (1 \times Q^2 / 9.8 / B^2)^{1/3}$$


| | | |
|---|----|--------|
| Water Depth of Upstream of Effluent Collection Trough | ho | 0.18 m |
|---|----|--------|

$$ho = (3 \times hc^2)^{1/2}$$

| | | |
|---|---|---------|
| Allowance between Invert Elevation of Effluent Collection Trough and Connection Channel | + | 0.100 m |
|---|---|---------|

| | | |
|--|---|-------------|
| Invert Elevation of Effluent Collection Trough | + | 2,234.970 m |
|--|---|-------------|

| | | |
|---|---|-------------|
| Water Surface Elevation of Upstream of Effluent Collection Trough | + | 2,235.150 m |
|---|---|-------------|



< V-notch Weir >


Calculation Condition

| | | |
|------------------------------|----|-------------------------|
| Flow Rate per 1 Unit | Q' | 5.0 m ³ /d |
| Number of Channel per 1 Unit | n1 | 64 channel(s) |
| Flow Rate per 1 Channel | Q1 | 0.078 m ³ /s |

$$Q1 = Q'/n1$$

Calculation

| | | |
|---|----|----------------------------|
| Width of V-notch Weir | Bw | 0.125 m |
| Required Length of Trough per 1 Channel | Lt | 13.5 m |
| Number of V-notch Weir per 1 Channel | Nn | 108 |
| Flow Rate through 1 V-notch Weir | Qw | 0.000361 m ³ /s |
| Head over V-notch Weir Crest | h | 0.04 m |
| | | $h = (Q/1.42)^{(2/5)}$ |
| Allowance of Height of V-notch Weir | ha | 0.03 m |
| Water Surface Elevation of Primary Sedimentation Tank | + | 2,235.220 m |



8) Distribution Channel

< Distribution Channel 3 >

Calculation Condition


| | | |
|--|----|-------------------------|
| Flow Rate per 1 Unit | Q' | 5.0 m ³ /s |
| Number of Distribution Channel 3 | n3 | 4 |
| Flow Rate per 1 Distribution Channel 3 | Q3 | 1.250 m ³ /s |

$$Q3 = Q'/n3$$

| | | |
|---|----|-------------|
| Width of Distribution Channel 3 | B3 | 2.5 m |
| Length of Distribution Channel 3 | L3 | 148 m |
| Channel Slope | i3 | 0.75 ‰ |
| Allowance of Head Loss between Primary Sedimentation Tank and Distribution Channel | ha | 0.050 m |
| Allowance between of Water Surface Elevation of Primary Sedimentation Tank and Invert Elevation of Downstream of Distribution Channel 3 | + | 0.100 m |
| Invert Elevation of Downstream of Distribution Channel 3 | + | 2,235.353 m |

Calculation

| | | |
|---|-----|-------------------------|
| Water Depth in Inlet Channel 2 | H3 | 0.481 m |
| Cross-sectional Area of Distribution Channel 3 | A3 | 1.202 m ² |
| Wetted Perimeter $P3=B3+2 \times H3$ | P3 | 3.461 m |
| Hydraulic Radius $R3=A3/P3$ | R3 | 0.347 m |
| Velocity in Channel 3 | v3 | 1.040 m/s |
| $v3=1/n \times (R^{2/3}) \times (i^{1/2})$ | | |
| (Flow Rate in Channel 3) | Q3 | 1.250 m ³ /s |
| Head loss in Bend | hi3 | 0.166 m |
| $hi3=1.0 \times (v3^2)/2/9.8 \times 3 \text{ places}$ | | |
| Invert Elevation of Upstream of Distribution Channel 3 | | + 2,235.464 m |
| Water Surface Elevation of Upstream of Distribution Channel 3 | | + 2,236.111 m |



8) Distribution Tank


Calculation Condition

| | | |
|-------------------------------------|----|-------------------------|
| Flow Rate | Q' | 5.0 m ³ /s |
| Number of Weir of Distribution Tank | n1 | 4 |
| Flow Rate per 1 Weir | Q | 1.250 m ³ /s |
| $Q=Q'/n1$ | | |
| Width of Weir | B1 | 2.5 m |

Calculation

| | | |
|----------------------|---|---------|
| Head over Weir Crest | h | 0.417 m |
|----------------------|---|---------|

| | | | |
|--|------------------------|----|-------------|
| | $h=(Q/1.86/B)^{(2/3)}$ | = | 0.420 |
| Allowance of Weir Height | | ha | 0.050 m |
| Elevation of Weir of Distribution Tank | | + | 2,236.170 m |
| Water Surface Elevation of Distribution Tank | | + | 2,236.590 m |



8) Receiving Tank

< Connection Pipe between Distribution Tank and Receiving Tank >

Calculation Condition

| | | |
|--|----|-----------------------|
| Flow Rate per 1 Unit | Q' | 5.0 m ³ /s |
| Diameter of Connection Pipe from Receiving Tank to Distribution Tank | D | 2.0 m |
| Pipe Length | L | 2,140 m |

Calculation

| | | |
|---|----|-------------|
| Cross-sectional Area of Pipe | A | 3.14 m |
| Velocity $v=Q'/A$ | v | 1.592 m/s |
| Hydraulic Radius $R=D/4$ | R | 0.5 m |
| Surface Roughness Coefficient | Ch | 110 |
| Friction Head in Pipe | hl | 2.564 m |
| $hl=10.666 \times Ch^{(-1.85)} \times D^{(-4.87)} \times Q'^{1.85} \times L$ | | |
| Entrance Loss $he=0.5 \times v^2/2/9.8$ | he | 0.065 m |
| Exit Loss $ho=1.0 \times v^2/2/9.8$ | ho | 0.129 m |
| Total Head Loss of Connection Pipe between Distribution Tank and Receiving Tank | ht | 2.758 m |
| | = | 2.760 |
| Water Surface Elevation of Distribution Tank | + | 2,239.350 m |

< Receiving Tank >


Calculation Condition

| | | |
|--------------------------------|----|------------------------|
| Flow Rate | Q' | 40.0 m ³ /s |
| Number of Weir | n1 | 8 weir(s) |
| Design Flow Rate per 1 Channel | Q | 5.0 m ³ /s |

$$Q=Q'/n1$$

Calculation

| | | |
|--|---------------------------|-------------|
| Width of Weir | B | 3.0 m |
| Type of Weir | | Rectangular |
| Head over the Weir Crest | hc | 0.936 m |
| | $hc = (Q/1.84/B)^{(2/3)}$ | = 0.940 m |
| Allowance of Weir Height | | 0.050 m |
| Elevation of Weir Crest | + | 2,239.400 m |
| Water Surface Elevation of Upwstream of Weir | + | 2,240.340 m |



BILL OF QUANTITIES

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|---|---|----------------------------|---------|
| 1. Wastewater Treatment | | | |
| 1-1 Receiving Tank | | | |
| 1) Cast-in-place Concrete Pile | | | |
| | Ø 800, $l = 24.6$ m | 26 piles | |
| | Ø 800, $l = 29.4$ m | 35 piles | |
| 2) Earth Work | | | |
| (1) Excavation | | | |
| | $4.8 \times 4.8 \times 11.0 \times 2 = 507$ | | |
| | $6.4 \times 33.6 \times 4.8 = 1,032$ | | |
| | $23.6 \times 33.6 \times 1.3 = 1,031$ | | |
| | 2,570 | | |
| | $1/2 \times (1.0+7.1) \times 6.1 = 19.44$ m ² | | |
| | $19.44 \times (6.4+6.4+33.6) = 902.016$ | 902 m ³ | |
| | $1/2 \times (1.0+5.8) \times 4.8 \times 33.6 = 548.352$ | 548 m ³ | |
| | $1/2 \times (1.0+5.8) \times 4.8 = 13.92$ m ² | | |
| | $13.92 \times (11.0 \times 4 + 4.8 \times 2) = 746.112$ | 746 m ³ | |
| | $19.44 \times 4.8 \times 2 = 186.624$ | 187 m ³ | |
| | $1/2 \times (0.5+1.8) \times 1.3 = 1.495$ m ² | | |
| | $1.495 \times (33.6 - 2 \times 4.8 + 17.2 \times 2) = 34.164$ | 87 m ³ | |
| | Total | 5,040 m³ | |
| (2) Back Filling | | | |
| | $5.040 - 2,570 = 2,470$ | 2,470 m ³ | |
| (3) Surplus Soil | | | |
| | | 5,040 m ³ | |
| 3) Concrete Work ($\sigma_{ck} = 250$ kg/cm ²) | | | |
| wall | $5.0 \times 0.6 \times 12.0 \times 7 = 252$ | 252 m ³ | |
| bottom | $23.6 \times 33.6 \times 1.0 = 792.96$ | 793 m ³ | |
| wall | $(7.4 \times 33.6 - 5.0 \times 32.2) \times 4.8 = 420.672$ | 421 m ³ | |
| wall | $(33.6 \times 23.6 - 32 \times 21.5) \times 7.2 = 755.712$ | 756 m ³ | |
| | Total | 2,222 m³ | |
| 4) Form of Concrete Work ($\sigma_{ck} = 250$ kg/cm ²) | | | |
| inside | $2 \times (3.4 + 5.0) \times 12.0 \times 6 = 1,209.600$ | 1,209.600 | |
| inside | $2 \times (15.4 + 16.2 + 16.5 \times 2) \times 7.2 = 930.240$ | 930.240 | |
| inside | $2 \times (3.8 + 5.0) \times 12.0 \times 2 = 422.400$ | 422.400 | |
| outside | $2 \times (13.0 + 33.6 + 7.2 \times 23.6) = 1,213.440$ | 1,213.440 | |
| outside | $2 \times 6.4 \times 4.8 = 61.440$ | 61.440 | |
| | Total | 3,837.120 | |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|---|---|-----------------------|---------|
| | $3,837.12 \times 1.1 = 4,220.832$ | 4,221 m ² | |
| 5) Reinforced Bar | $2,222 \times 0.1 \text{ t/m}^3 = 222$ | 222 t | |
| 6) Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | $33.8 \times 23.8 \times 0.1 = 80.444$ | 80 m ³ | |
| 7) Form of Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | $2 \times (7.4 + 33.8) \times 0.1 = 8.240$ | 8 m ² | |
| | $(2 \times 15.0 + 33.8) \times 0.1 = 6.380$ | 6 m ² | |
| | Total | 14 m ² | |
| 8) Cobble Stone | $33.8 \times 23.8 \times 0.2 = 160.888$ | 161 m ³ | |
| 9) Concrete Work ($\sigma_{ck} = 160 \text{ kg/cm}^2$) | $4.8 \times 4.8 \times 11.0 \times 2 = 506.880$ | 507 m ³ | |
| | $-\pi/4 \times 3.6^2 \times 12.5 \times 2 = -254.469$ | -254 m ³ | |
| | Total | 253 m ³ | |
| 10) Form of Concrete Work ($\sigma_{ck} = 160 \text{ kg/cm}^2$) | $2 \times (11.0 + 4.8) \times 4.8 \times 2 = 303.360$ | 303 m ² | |
| | $-\pi/4 \times 3.6^2 \times 2 = -81.430$ | -81 m ² | |
| | Total | 222 m ² | |
| 11) Pipe | inlet $\varnothing 3,600$ | 25 m | |
| | Connecting pipe $\varnothing 2,000$ | | |
| | $\ell = 1.5$ with Blind Flange | 6 pieces | |
| 12) Accessory Work | | 1 ℓ s | |
| 1-2 Connecting Pipe | Total laying length | 1,040 m | |
| 1) Earth Work (1) Excavation | $1/2 \times (4.2 + 9.4) \times 5.2 \times 1,040 = 36,774.4$ | 36,774 m ³ | |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|--|--|--|---------|
| (2) Surplus Soil | | 36,774 m ³ | |
| (3) Back Filling | $3.4 \times 1.1 + \pi/4 \times 2.8^2 = 9.897 \text{ m}^2$ $36,774 - 9.897 \times 1,040 = 26,481$ | 26,481 m ³ | |
| 2) Cobble Stone | $3.4 \times 0.2 \times 1,040 = 707.2$ | 707 m ³ | |
| 3) Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | $3.4 \times 0.1 \times 1,040 = 353.6$ | 354 m ³ | |
| 4) Form of Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | $0.2 \times 1,040 = 208$ | 208 m ³ | |
| 5) Concrete Work ($\sigma_{ck} = 210 \text{ kg/cm}^2$) | $3.4 \times 0.8 \times 1,040 = 2,828.8$ | 2,829 m ³ | |
| 6) Form of Concrete Work ($\sigma_{ck} = 210 \text{ kg/cm}^2$) | $0.8 \times 2 \times 1040 = 1664$ | 1,664 m ² | |
| 7) Pile | $\varnothing 600, \ell = 25.5 \text{ m}$ $1,040 / 5.0 = 208$ | 208 piles | |
| 8) Steel Pipe | $\varnothing 2,800$ | 1,040 m | |
| 1-3 Distribution Tank (per 1 unit) | | | |
| 1) Cast-in-place Concrete Pile | $\varnothing 600, \ell = 23.8 \text{ m}$ $\varnothing 600, \ell = 27.5 \text{ m}$ | 3 piles 17 piles | |
| 2) Earth Work | | | |
| (1) Excavation | $5.0 \times 9.0 \times 3.7 = 166.500$ $13.2 \times 13.2 \times 3.1 = 540.144$ $1/2 \times (0.5 + 3.6) \times 3.1 \times 12.2 \times 4 = 310$ | 167 m ³ 540 m ³ 310 m ³ | |
| | Total | 1,017 m ³ | |
| (2) Surplus Soil | | 1,017 m ³ | |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|--|--|--------------------|---------|
| (3) Back Filling | $4.0 \times 8.5 \times 3.7 = 126$ $12.2 \times 12.2 \times 3.1 = 461$ $1017 - (126 + 461) = 430$ | 430 m ³ | |
| 3) Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| bottom | $12.2^2 \times 0.8 = 119$ | | |
| wall | $(12.2^2 - 11.2^2) \times 5.0 = 117$ $(119 + 117) \times 1.1 = 259.6$ | 260 m ³ | |
| 4) Form of Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| outside | $12.2 \times 5.8 \times 4 = 283.040$ | | |
| inside | $11.2 \times 4.8 \times 4 = 215.040$ | | |
| | $(283.040 + 215.040) \times 1.1 = 547.888$ | 548 m ² | |
| 5) Reinforced Bar | $260 \times 0.1 \text{ t/m}^3 = 26$ | 26 t | |
| 6) Concrete Work ($\sigma_{ck} = 160 \text{ kg/cm}^2$) | $4.0 \times 3.7 \times 8.5 = 125.800$ $-\pi/4 \times 2.8^2 \times 7.9 = -48.644$ | 77 m ³ | |
| 7) Form of Concrete Work ($\sigma_{ck} = 160 \text{ kg/cm}^2$) | $2 \times (4.0 + 8.5) \times 3.7 = 92.500$ $-\pi/4 \times 2.8^2 = -6.158$ | 86 m ² | |
| 8) Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | $12.4^2 \times 0.1 = 15.376$ | 15 m ³ | |
| 9) Form of Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | $4 \times 12.4 \times 0.1 = 4.960$ | 5 m ² | |
| 10) Cobble Stone | $12.4 \times 12.4 \times 0.2 = 30.752$ | 31 m ³ | |
| 11) Accessory Work | | 1 ℓ s | |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|--|--|----------------------|---------|
| 1-4 Influent Channel (per 1 unit) | | | |
| | width = 2.5m | | |
| | 93.2 x 3 - 11.2 = | 268.400 | |
| | 93.2 - 11.2 = | 82.000 | |
| | 50 x 4 = | 200.000 | |
| | | 550.400 | |
| | width = 2.0m | | |
| | 56 x 4 = | 224 | |
| 1) Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| w = 2.5m | 0.4 x 5.9 x 43 x 2 = 202.960 | 203 m ³ | |
| w = 2.5m | 0.3 x 1.95 x 3 x 43 x 2 = 150.930 | 151 m ³ | |
| w = 2.5m | 0.4 x 3.1 x 464.4 = 575.856 | 576 m ³ | |
| w = 2.5m | 0.3 x 1.95 x 2 x 464.4 = 543.348 | 543 m ³ | |
| w = 2.0m | 0.4 x 2.6 x 224 = 232.960 | 233 m ³ | |
| w = 2.0m | 0.3 x 1.5 x 2 x 224 = 201.600 | 202 m ³ | |
| | Total | 1,908 m ³ | |
| 2) Form of Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| w=2.5m inside | 1.95 x 86 x 4 = 670.800 | 671 m ² | |
| w=2.5m inside | 1.95 x 464.4 x 2 = 1,811.160 | 1,811 m ² | |
| w=2.5m outside | 2.35 x (93.2 x 3 - 11.2) x 2 = 1,261.480 | 1,261 m ² | |
| w=2.5m outside | 2.35 x 50 x 2 x 4 = 840.000 | 940 m ² | |
| w=2.0m inside | 1.5 x 2 x 224 = 672.000 | 672 m ² | |
| w=2.0m inside | 1.9 x 2 x 224 = 851.000 | 851 m ² | |
| | Total | 6,207 m ² | |
| 3) Reinforced Bar | | | |
| | 1,908 x 0.1 t/m ³ = 190.800 | 191 t | |
| 4) Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | | | |
| | t = 5 cm | | |
| w = 2.5m | 5.9 x 43 x 2 x 0.05 = 25.370 | 25 m ³ | |
| w = 2.5m | 3.1 x 464.4 x 0.05 = 71.982 | 72 m ³ | |
| w = 2.0m | 2.6 x 224.0 x 0.1 = 58.240 | 58 m ³ | |
| | Total | 155 m ³ | |
| 5) Form of Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | | | |
| | 43 x 2 x 0.05 x 2 = 8.600 | 9 m ² | |
| | 464.4 x 2 x 0.05 x 2 = 92.880 | 93 m ² | |
| | 224.0 x 2 x 0.05 = 22.400 | 22 m ² | |
| | Total | 124 m ² | |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|---|--|-----------------------|---------|
| 6) Cobble Stone | $t = 10 \text{ cm}$ $156 \times 2 = 312$ | 312 m ³ | |
| 7) Cast-in-place Concrete Pile | $\varnothing 600, \ell = 30 \text{ m}$ $32 + 56 = 88$ | 88 piles | |
| 5. Wastewater Treatment Facility (per 1 unit) | | | |
| 1) Aeration Tank | | | |
| (1) Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| wall | $(36.4 - 28.92) \times 372.8 \times 0.6 \times 2 =$ | 3,346 | |
| bottom | $(89.6 + 6.6) \times 372.8 \times 1.0 =$ | 35,863 | |
| | $(35.8 - 28.92) \times 89.6 \times 0.5 \times 37 =$ | 11,404 | |
| | $6.6 \times 0.3 \times 372.8 \times 2 =$ | 1,476 | |
| | $10.3 \times 6.1 \times 0.3 \times 3 \times 32 =$ | 1,810 | |
| | | 52,089 | |
| | $52,089 \times 1.1 = 57,298$ | 57,298 m ³ | |
| (2) Reinforced Bar | | | |
| | $57,298 \times 0.1 \text{ t/m}^3 = 5,730$ | 5,730 t | |
| (3) Form of Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| inside | $6.6 \times 372.8 \times 2 =$ | 4,921 | |
| wall inside | $5.6 \times 372.8 \times 3 =$ | 6,263 | |
| wall | $(35.8 - 28.92) \times 89.6 \times 37 \times 2 =$ | 45,617 | |
| | $89.6 \times 6.6 \times 4 =$ | 2,365 | |
| wall | $6.1 \times 10.3 \times 3 \times 2 \times 32 =$ | 12,063 | |
| wall outside | $8.2 \times 372.8 =$ | 3,057 | |
| | | 74,287 | |
| | $74,287 \times 1.2 = 89,144$ | 89,144 m ² | |
| (4) Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | | | |
| | $372.8 \times (89.6 + 6.6) \times 0.1 = 3,586$ | 3,586 m ³ | |
| (5) Form of Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | | | |
| | $0.1 \times (96.2 \times 2 + 372.8) = 56.520$ | 57 m ² | |
| (6) Cobble Stone | | | |
| | $3,586 \times 2 = 7,172$ | 7,172 m ³ | |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|---|--|-----------------------|---------|
| (7) Cost-in-place Concrete Pile | $\ell = 23.5 \text{ m}$ | | |
| | $33 \times 103 = 3,399$ | 3,399 piles | |
| (8) Accessory Work | | 1 ℓ_s | |
| 2) Secondary Sedimentation Tank | | | |
| (1) Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| bottom | $(3.4 + 54.6 + 7.6) \times 372.8 \times 0.8 = 19,565$ | | |
| | $8.5 \times 372.8 \times 0.6 \times 2 = 3,803$ | | |
| | $7.6 \times 372.8 \times 0.4 \times 2 = 2,267$ | | |
| | $4.0 \times 372.8 \times 0.4 \times 2 = 1,193$ | | |
| effluent channel | $3.4 \times 0.3 \times 372.8 = 380$ | | |
| | $0.4 \times 4.2 \times 54.6 \times 69 = 6,329$ | | |
| | $54.6 \times 6.8 \times 0.4 \times 4 = 594$ | | |
| | 34,131 | | |
| | $34,131 \times 1.1 = 37,544$ | 37,544 m ³ | |
| (2) Reinforced Bar | $37,544 \times 0.1 = 3,754$ | 3,754 t | |
| (3) Form of Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| wall | $8.5 \times 372.8 \times 4 = 12,675$ | | |
| slab | $7.6 \times 372.8 \times 2 = 5,667$ | | |
| slab | $(7.0 + 3.4) \times 372.8 = 3,877$ | | |
| wall | $4.0 \times 372.8 \times 4 = 5,965$ | | |
| wall | $4.2 \times 54.6 \times 2 \times 69 = 31,646$ | | |
| slab | $6.0 \times 54.6 \times 4 = 1,310$ | | |
| | 61,140 | | |
| | $61,140 \times 1.2 = 73,368$ | 73,368 m ² | |
| (4) Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | | | |
| | $(7.6 + 54.6 + 3.4) \times 372.8 \times 0.1 = 2,445.568$ | 2,446 m ³ | |
| (5) Form of Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | | | |
| | $2 \times (372.8 + 65.6) \times 0.1 = 87.680$ | 88 m ² | |
| (6) Cobble Stone | | | |
| | $2,446 \times 2 = 4,892$ | 4,892 m ³ | |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|--|---|------------------------|-----------------------|
| (7) Cost-in-Place Concrete Pile | $\emptyset 600, \ell = 23.3 \text{ m}$ | $372.8 / 5.4 = 69$ | |
| | $69 \times 3 = 207$ | 207 piles | |
| | $\emptyset 600, \ell = 25.5 \text{ m}$ | $69 \times 26 = 1,794$ | 1,794 piles |
| (8) Accessory Work | | 1 ℓ_s | |
| 6. Discharge Channel | | | |
| 1) Cast-in -place Concrete Pile | 1 pile / 2.9 m x 476 = 164 1 pile / 1.6 m x 70m = 44 1 pile / 1.6m x 300m = 188 3 piles / 2 m x 70 = 105 | Total | 501 piles |
| 2) Earth Work | | | |
| (1) Excavation | $1/2 \times (4.8 + 10) \times 5.7 \times 476 = 20,078$ $1/2 \times (6.4 + 12.8) \times 6.3 \times 70 = 4,234$ $1/2 \times (8.4 + 14.8) \times 6.4 \times 300 = 22,272$ $1/2 \times (10.2 + 17.7) \times 8.0 \times 70 = 7,812$ | Total | 54,396 m ³ |
| (2) Back Filling | $20,078 - 3.8 \times 5.7 \times 476 = 9,768$ $4,234 - 5.4 \times 6.3 \times 70 = 1,853$ $22,272 - 7.4 \times 8.0 \times 300 = 4,512$ $7,812 - 9.2 \times 3.9 \times 70 = 5,300$ | Total | 21,432 m ³ |
| (3) Surplus Soil | | | 54,396 m ³ |
| 3) Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | $3.8 \times 0.4 \times 476 = 724$ $5.2 \times 0.4 \times 476 \times 2 = 1,980$ $5.4 \times 0.4 \times 70 = 151$ $5.8 \times 0.4 \times 70 \times 2 = 324$ $7.4 \times 0.4 \times 300 = 888$ $5.9 \times 0.4 \times 300 \times 2 = 1,416$ $9.2 \times 0.4 \times 2 \times 70 = 515$ $3.0 \times 0.4 \times 3 \times 70 = 252$ | Total | 6,250 m ³ |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|--|--|----------|-----------------------------|
| 4) Form of Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | $5.6 \times 476 \times 2 = 5,331$ | | |
| | $5.2 \times 476 \times 2 = 4,950$ | | |
| | $6.3 \times 70 \times 2 = 882$ | | |
| | $5.8 \times 70 \times 2 = 812$ | | |
| | $6.4 \times 70 \times 2 = 896$ | | |
| | $5.9 \times 70 \times 2 = 826$ | | |
| | $3.8 \times 70 \times 2 = 532$ | | |
| | $3.0 \times 70 \times 4 = 840$ | | |
| | $4.0 \times 70 \times 2 = 560$ | | |
| | Total | | 15,629 m² |
| 5) Reinforced Bar | $0.1 \times 2704 = 270$ | | |
| | $0.1 \times 476 = 48$ | | |
| | $0.1 \times 2,304 = 230$ | | |
| | $0.1 \times 767.2 = 77$ | | |
| | Total | | 625 t |
| 6) Supporting Work | $4.0 \times 3.0 \times 7.0 \times 2 = 1,680$ | | |
| 7) Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | $3.8 \times 0.1 \times 476 = 181$ | | |
| | $5.4 \times 0.1 \times 70 = 38$ | | |
| | $7.4 \times 0.1 \times 300 = 222$ | | |
| | $9.2 \times 0.1 \times 70 = 64.4$ | | |
| | Total | | 505 m³ |
| 8) Form of Lean Concrete ($\sigma_{ck} = 100 \text{ kg/cm}^2$) | $0.1 \times 476 = 48$ | | |
| | $0.1 \times 70 = 7$ | | |
| | $0.1 \times 300 = 30$ | | |
| | $0.1 \times 70 = 7$ | | |
| | Total | | 92 m² |
| 7. Digestion Tank (per 1 tank) | | | |
| 1) Concrete Work ($\sigma_{ck} = 250 \text{ kg/cm}^2$) | | | |
| | $\pi/4 \times 29^2 \times 1.0$ | = | 661 |
| | $1/2 \times 1.5 \times 5.0 \times \pi \times 27$ | = | 318 |
| | $\pi/4 \times (27^2 - 26^2) \times 11.0$ | = | 458 |
| | $\pi/4 \times 26^2 \times 0.4$ | = | 212 |
| | | | 1,649 |
| | $1,649 \times 1.3 = 2,144$ | | 2,144 m³ |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|--|--|---|---------|
| 2) Cast-in-place Concrete Pile | $\varnothing 800, \ell = 23 \text{ m}$ | 90 piles | |
| 3) Form of Concrete Work ($\sigma_{ck}=250 \text{ kg/cm}^2$) | $\pi \times 29 \times 1.5 = 136.659$ $\pi \times (26.0 + 27.0) \times 11.0 = 1,831.549$ $\pi/4 \times 26^2 = 530.929$ <hr style="width: 100%;"/> $2,499.137$ | | |
| | $2,499.137 \times 1.05 = 2,624.094$ | 2,624 m ² | |
| 4) Reinforced Bar | $2,144 \times 0.12 \text{ t/m}^3 = 257$ | 257 t | |
| 5) Supporting Work | $\pi/4 \times 29.0^2 \times 13.0 = 8,586.758$ | 8,587 m ³ | |
| 6) Lean Concrete ($\sigma_{ck}=100 \text{ kg/cm}^2$) | $\pi/4 \times 29.0^2 \times 0.1 = 66.143$ | 66 m ³ | |
| 7) Form of Lean Concrete ($\sigma_{ck}=100 \text{ kg/cm}^2$) | $\pi \times 29.0 \times 0.1 = 9.123$ | 9 m ² | |
| 8) Cobble Stone | $\pi/4 \times 29.0^2 \times 0.2 = 132.286$ | 132 m ³ | |
| 9) Pipe Gallary | $7.0 \times 12.0 = 84.0$ | 84 m ² | |
| 10) Accessory Work | | 1 s | |
| 8. Other Work | | | |
| 8-1 Preparatory Work | | | |
| 1) Remove of Existing Concrete Structure | $280 \times 150 \times 0.2 = 8,400$ | 8,400 m ³ | |
| 2) Cutting of Stacked Lime | $1/2 \times 240 \times 150 \times 10.0 = 180,000$ $1/2 \times 100 \times 100 \times 10.0 = 50,000$ | 180,000 m ³ 50,000 m ³ | |
| | Total | 230,000 m ³ | |

Bill of Quantities

| Item | Equation | Quantity | Remarks |
|--|--|--------------|---------|
| 8-2 Main Earth Work | | | |
| 1) Excavation | | | |
| (1) Wastewater Treatment Facility | | | |
| | $(89.6 + 6.6 + 4.5) \times (372.8 + 9.0) = 38,447.26 \text{ m}^2$ | | |
| AT unit 1 | $38447.26 \times (34.9 - 27.82) = 272,206.601$ | 272,207 m3 | |
| AT unit 2 | $38447.26 \times (34.5 - 27.82) = 256,827.697$ | 256,828 m3 | |
| SST PIT | $14.0 \times (372.8 - 6.8 \times 4 + 9.0) = 4,964.4 \text{ m}^2$ | | |
| unit 1 | $4,964.4 \times (34.9 - 25.9) = 44,679.600$ | 44,680 m3 | |
| unit 2 | $4,964.4 \times (34.5 - 25.9) = 42,694.840$ | 42,694 m3 | |
| SST pipe gallery | $(7.6 + 54.6) \times 6.8 \times 4 = 1,691.84 \text{ m}^2$ | | |
| unit 1 | $1,691.84 \times (34.9 - 27.82) = 11,978.227$ | 11,978 m3 | |
| unit 2 | $1,691.84 \times (34.5 - 27.82) = 11,301.491$ | 11,301 m3 | |
| SST | $(65.6 - 14.0 + 3.5) \times (372.8 - 6.8 \times 4 + 7.0) = 19,428.260 \text{ m}^2$ | | |
| unit 1 | $19,428.26 \times (34.9 - 29.7) = 10,10276.952$ | 101,027 m3 | |
| unit 2 | $19,428.26 \times (34.5 - 29.7) = 93,255.648$ | 93,256 m3 | |
| | Sub Total | 833,971 m3 | |
| (2) Sludge Treatment Facility | | | |
| | $(120 \times 150 - 40 \times 80) \times 7.0 \times 2 = 207,200$ | 207,200 m3 | |
| pipe gallery | $1/2 \times (7.0 + 13.0) \times 6.0 \times 220 \times 2 = 26,400$ | 26,400 m3 | |
| | Sub Total | 233,600 m3 | |
| | Total | 1,067,571 m3 | |
| 2) Back Filling | | | |
| Wastewater Treatment Facility | $1/2 \times (1.0 + 8.2) \times 7.2 = 33.12 \text{ m}^2$ | | |
| | $33.12 \times 2 \times (372.8 + 161.9) \times 2 = 70,837.056$ | 70,837 m3 | |
| AD | $\pi/4 \times 27^2 \times 7.0 \times 10 \times 2 = 80,157.737$ | | |
| AD | $12.0 \times 13.0 \times 7.0 \times 5 \times 2 = 10,920.000$ | | |
| pipe gallery | $10 \times (28.0 \times 3 + 10.0 \times 2) \times 7.0 \times 2 = 14,560.000$ | | |
| pipe gallery | $7.0 \times 4.0 \times 180 \times 2 = 10,080.000$ | | |
| pipe gallery | $6.0 \times 5.0 \times 220 \times 2 = 13,200.000$ | | |
| | 128,917.737 | | |
| | $223,600 - 128,917.737 = 94,682.263$ | 94,682 m3 | |
| | Total | 165,519 m3 | |

BILL OF QUANTITIES (PRICED)

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY

Bill of Quantities (Priced)

| Item | Quantity | Unit Cost | Cost (Mill. N\$) | Remarks |
|---|-----------|-----------|-------------------|---------|
| 1. Wastewater Treatment | | | | |
| 1-1 Receiving Tank | | | | |
| 1) Cast-in-place Concrete Pile | | | | |
| Ø 800, ℓ = 24.6 m | 26 piles | 9,388.00 | 0.244 | |
| Ø 800, ℓ = 29.4 m | 35 piles | 11,059.60 | 0.387 | |
| 2) Earth Work | | | | |
| (1) Excavation | 5,040 m3 | 12.04 | 0.061 | |
| (2) Back Filling | 2,470 m3 | 55.11 | 0.136 | |
| (3) Surplus Soil | 5,040 m3 | 10.49 | 0.053 | |
| 3) Concrete work (σ ck = 250 kg/cm2) | 2,222 m3 | 440.11 | 0.978 | |
| 4) Form of Concrete work (σ ck = 250 kg/cm2) | 4,221 m2 | 26.87 | 0.113 | |
| 5) Reinforced Bar | 222 t | 1,970.00 | 0.437 | |
| 6) Lean Concrete (σ ck = 100 kg/cm2) | 80 m3 | 15.63 | 0.001 | |
| 7) Form of Lean Concrete (σ ck = 100 kg/cm2) | 14 m2 | 24.11 | 0.001 | |
| 8) Cobble Stone | 161 m3 | 52.56 | 0.008 | |
| 9) Concrete Work (σ ck = 160 kg/cm2) | 253 m3 | 305.92 | 0.077 | |
| 10) Form of Concrete Work (σ ck = 160 kg/cm2) | 222 m2 | 26.89 | 0.006 | |
| 11) Pipe | | | | |
| Inlet Ø 3,600 | 1 ℓs | - | 0.153 | |
| Connecting Pipe Ø 2,000, ℓ = 1.5 with Blind Flange | 1 ℓs | - | 0.036 | |
| 12) Accessory Work | 1 ℓs | - | 0.269 | |
| Sub-Total of 1-1 Receiving Tank | | | 2.960 | |
| 1-2 Connecting Pipe | | | | |
| 1) Earth Work | | | | |
| (1) Excavation | 36,774 m3 | 15.33 | 0.564 | |
| (2) Surplus Soil | 36,774 m3 | 10.49 | 0.386 | |
| (3) Back Filling | 26,481 m3 | 55.11 | 1.459 | |
| 2) Cobble Stone | 707 m3 | 52.56 | 0.037 | |
| 3) Lean Concrete | 354 m3 | 15.63 | 0.006 | |
| 4) Form of Lean Concrete | 208 m3 | 24.11 | 0.005 | |
| 5) Concrete Work (σ ck = 210 kg/cm2) | 2,829 m3 | 321.80 | 0.910 | |
| 6) Form of Concrete Work (σ ck = 210 kg/cm2) | 1,664 m3 | 26.87 | 0.045 | |
| 7) Cast-in-Place Concrete Pile | | | | |
| Ø 600, ℓ = 25.5 m | | | | |
| 1,040 / 5.0 = 208 | 208 piles | 6,969.20 | 1.450 | |
| 8) Steel Pipe | 1,040 m | 5,800.00 | 6.032 | |
| Sub-Total of 1-2 Connecting Pipe | | | 10.894 | |

Bill of Quantities (Priced)

| Item | Quantity | Unit Cost | Cost (Mill. N\$) | Remarks |
|--|-------------|-----------|-------------------|---------|
| 1-3 Distribution Tank (per 1 unit) | | | | |
| 1) Cast-in place Concrete Pile | | | | |
| Ø 600, ℓ= 23.8 m | 3 piles | 10,090.60 | 0.030 | |
| Ø 600, ℓ= 27.5 m | 17 piles | 8,112.10 | 0.138 | |
| 2) Earth Work | | | | |
| (1) Excavation | 1,017 m3 | 12.40 | 0.013 | |
| (2) Surplus Soil | 1,017 m3 | 10.49 | 0.011 | |
| (3) Backfilling | 430 m3 | 55.11 | 0.024 | |
| 3) Concrete Work (σ ck = 250 kg/cm2) | 260 m3 | 440.11 | 0.114 | |
| 4) Form of Concrete Work (σ ck = 250 kg/cm2) | 548 m2 | 26.87 | 0.015 | |
| 5) Reinforced Bar | 26 t | 1,970.00 | 0.051 | |
| 6) Concrete Work (σ ck = 160 kg/cm2) | 77 m3 | 305.92 | 0.024 | |
| 7) Form of Concrete Work (σ ck = 160 kg/cm2) | 86 m2 | 26.87 | 0.002 | |
| 8) Lean Concrete (σ ck = 100 kg/cm2) | 15 m3 | 15.63 | 0.001 | |
| 9) Form of Lean Concrete (σ ck = 100 kg/cm2) | 5 m2 | 24.11 | 0.001 | |
| 10) Cobble Stone | 31 m3 | 52.56 | 0.002 | |
| 11) Accessory Work | 1 s | - | 0.043 | |
| Sub-Total of 1-3 Distribution Tank | | | 0.469 | |
| 1-4 Influent Channel (per 1 unit) | | | | |
| 1) Concrete Work (σ ck = 250 kg/cm2) | 1,908 m3 | 440.11 | 0.840 | |
| 2) Form of Concrete Work (σ ck = 250 kg/cm2) | 6,207 m2 | 26.87 | 0.167 | |
| 3) Rainforced Bar | 191 t | 1,970.00 | 0.376 | |
| 4) Lean Concrete (σ ck = 100 kg/cm2) t = 5 cm | 155 m3 | 15.63 | 0.002 | |
| 5) Form of Lean Concrete (σ ck = 100 kg/cm2) | 124 m2 | 24.11 | 0.003 | |
| 6) Cobble Stone t = 10 cm | | | | |
| 156 x 2 = 312 | 312 m3 | 52.56 | 0.016 | |
| 7) Cast-in-place Concrete Pile | | | | |
| Ø 600, ℓ= 30 m | 88 piles | 7,542.10 | 0.664 | |
| 32 + 56 = 88 | | | | |
| Sub-Total of 1-4 Influent Channel | | | 2.068 | |
| 5. Wastewater Treatment Facility (per 1 unit) | | | | |
| 1) Aeration Tank | | | | |
| (1) Concrete Work (σ ck = 250 kg/cm2) | 57,298 m3 | 440.11 | 25.217 | |
| (2) Reinforced Bar | 5,730 t | 1,970.00 | 11.288 | |
| (3) Form of Concrete Work (σ ck = 250 kg/cm2) | 89,144 m2 | 26.87 | 2.395 | |
| (4) Lean Concrete (σ ck = 100 kg/cm2) | 3,586 m3 | 15.63 | 0.056 | |
| (5) Form of Lean Concrete (σ ck = 100 kg/cm2) | 57 m2 | 24.11 | 0.001 | |
| (6) Cobble Stone | 7,172 m3 | 52.56 | 0.377 | |
| (7) Cast-in-place Concrete Pile | | | | |
| Ø 600, ℓ= 23.5 m | 3,399 piles | 6,367.40 | 21.643 | |
| 33 x 103 = 3,399 | | | | |
| (8) Accessory Work | 1 ℓs | - | 6.098 | |
| Sub-Total of 1) Aeration Tank | | | 67.075 | |

Bill of Quantities (Priced)

| Item | Quantity | Unit Cost | Cost (Mill. N\$) | Remarks |
|--|-----------------------|-----------|-------------------|---------|
| 2) Secondary Sedimentation Tank | | | | |
| (1) Concrete Work (σ ck = 250 kg/cm ²) | 37,544 m ³ | 440.11 | 16.523 | |
| (2) Reinforced Bar | 3,754 t | 1,970.00 | 7.395 | |
| (3) Form of Concrete (σ ck = 250 kg/cm ²) | 73,368 m ² | 26.87 | 1.971 | |
| (4) Lean Concrete (σ ck = 100 kg/cm ²) | 2,446 m ³ | 15.63 | 0.038 | |
| (5) Form of Lean Concrete (σ ck = 100 kg/cm ²) | 88 m ² | 24.11 | 0.002 | |
| (6) Cobble Stone | 4,892 m ³ | 52.56 | 0.257 | |
| (7) Cast-in-place Concrete Pile | | | | |
| Ø 600, ℓ = 23.3 m | 207 piles | 6,361.80 | 1.317 | |
| $372.8 / 5.4 = 69, 69 \times 3 = 207$ | | | | |
| Ø 600, ℓ = 25.5 m | 1,794 piles | 6,922.70 | 12.419 | |
| $69 \times 26 = 1,794$ | | | | |
| (8) Accessory Work | 1 ℓ s | - | 3.992 | |
| Sub-Total of 2) Secondary Sedimentation Tank | | | 43.914 | |
| Sub-Total of 5. Wastewater Treatment Plant | | | 110.989 | |
| 6. Discharge Channel | | | | |
| 1) Cast-in-place Concrete Pile | 501 piles | 8,181.70 | 4.099 | |
| 2) Earth Work | | | | |
| (1) Excavation | 54,396 m ³ | 6.39 | 0.348 | |
| (2) Backfilling | 21,432 m ³ | 55.11 | 1.181 | |
| (3) Surplus Soil | 54,396 m ³ | 10.49 | 0.571 | |
| 3) Concrete Work (σ ck=250 kg/cm ²) | 6,250 m ³ | 440.11 | 2.751 | |
| 4) Form of Concrete Work (σ ck=250 kg/cm ²) | 15,629 m ² | 26.87 | 0.420 | |
| 5) Rainforced Bar | 625 t | 1,970.00 | 1.231 | |
| 6) Supporting Work | 1,680 m ³ | 269.17 | 0.452 | |
| 7) Lean Concrete (σ ck = 100 kg/cm ²) | 505 m ³ | 15.63 | 0.008 | |
| 8) Form of Lean Concrete (σ ck = 100 kg/cm ²) | 92 m ² | 24.11 | 0.002 | |
| Sub-Total of 6. Discharge Channel | | | 11.063 | |
| 7. Digestion Tank (per 1 tank) | | | | |
| 1) Concrete Work (σ ck=250 kg/cm ²) | 2,144 m ³ | 440.11 | 0.944 | |
| 2) Cast-in-place Concrete Pile | | | | |
| Ø 800, ℓ = 23 m | 90 piles | 8,495.90 | 0.765 | |
| 3) Form of Concrete (σ ck=250 kg/cm ²) | 2,624 m ² | 26.87 | 0.071 | |
| 4) Rainforced Bar | 257 t | 1,970.00 | 0.506 | |
| 5) Supporting Work | 8,587 m ³ | 269.17 | 2.311 | |
| 6) Lean Concrete (σ ck=100 kg/cm ²) | 66 m ³ | 15.63 | 0.001 | |
| 7) Form of Lean Concrete (σ ck=100 kg/cm ²) | 9 m ² | 24.11 | 0.001 | |
| 8) Cobble Stone | 132 m ³ | 52.56 | 0.007 | |
| 9) Pipe Gellary | 84 m ² | 2,000.00 | 0.168 | |
| 10) Accessory Work | 1 s | - | 0.955 | |
| Sub-Total of 7. Digestion Tank | | | 5.729 | |

Bill of Quantities (Priced)

| Item | Quantity | Unit Cost | Cost (Mill. N\$) | Remarks |
|--|--------------|-----------|-------------------|---------|
| 8. Other Work | | | | |
| 8-1 Preparatory Work | | | | |
| 1) Remove of Existing Concrete Structure | 8,400 m3 | 46.22 | 0.388 | |
| 2) Cutting of Stacked Lime | 230,000 m3 | 12.90 | 2.967 | |
| Sub-Total of 8-1 Preparatory Work | | | 3.355 | |
| 8-2 Main Earth Work | | | | |
| 1) Excavation | 1,067,571 m3 | 3.59 | 3.833 | |
| 2) Back Filling | 165,519 m3 | 55.11 | 9.122 | |
| Sub-Total of 8-2 Main Earth Work | | | 12.955 | |

Table Break-down of Construction Cost for Electrical Work

(Unit : Million N\$)

| Description | Urgent Project (1st Stage) | | | 2nd~4th Stage | | | Total |
|--|----------------------------|-----------|-------------|---------------|-----------|-------------|-------|
| | Quantity | Unit Cost | Const. Cost | Quantity | Unit Cost | Const. Cost | |
| 1) Wastewater Treatment | | | | | | | |
| (1) Extra-high Tension | 1 ls. | - | 5.2 | - | - | | 5.2 |
| (2) Power Board | 1 ls. | - | 9.6 | 1 ls. | - | 26.4 | 36.0 |
| (3) Blower House | 2 unit | 5.15 | 10.3 | 6 unit | 5.15 | 30.9 | 41.2 |
| (4) Secondary Sed. Tank | 2 unit | 5.15 | 10.3 | 6 unit | 5.15 | 30.9 | 41.2 |
| (5) Disinfection & Treated Wastewater Supply | 2 unit | 2.38 | 4.8 | 6 unit | 2.38 | 14.3 | 19.1 |
| Sub-Total | - | - | 40.2 | | | 102.5 | 142.7 |
| 2) Sludge | | | | | | | |
| (1) Centrifugal Thickener House | 2 unit | 9.51 | 19.0 | 2 unit | 9.51 | 19.0 | 38.0 |
| (2) Gravity Thickener | - unit | - | - | 4 unit | 2.03 | 8.1 | 8.1 |
| (3) Anaerobic Digester | 2 unit | 4.19 | 8.4 | 2 unit | 4.19 | 8.4 | 16.8 |
| (4) Mechanical Dewatering | 2 unit | 8.90 | 17.8 | 2 unit | 8.90 | 17.8 | 35.6 |
| (5) Generator House | 2 unit | 7.10 | 14.2 | 2 unit | 7.10 | 14.2 | 28.4 |
| (6) Others | 2 unit | 3.57 | 7.1 | 2 unit | 3.57 | 7.1 | 14.2 |
| Sub-Total | | | 66.5 | | | 74.6 | 141.1 |

**WASTEWATER AND SLUDGE TREATMENT SYSTEM
PROPOSED BY CNA**

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY

Wastewater and Sludge Treatment System Proposed by CNA

Wastewater and Sludge Treatment System

Treatment efficiency in terms of BOD₅ removal efficiency and SS removal efficiency of the wastewater treatment system, consisting of primary sedimentation with coagulation and filtration, has been analyzed. The flow diagram of the treatment system is shown in Fig. S.1.

Usually filtration is employed as one of the tertiary treatment unit after secondary treatment process. And no data has been reported related to the treatment system employing primary sedimentation with coagulation followed by sand filter or multimedia filter.

Generally, Soluble BOD₅ can not be removed by physical and chemical treatment processes. Only Non Filtrate BOD₅ (due to suspended solids) can be removed by physical and chemical treatment processes such as sedimentation and filtration.

The typical municipal wastewater has 68 % of Non Filtrate BOD₅ and 32% of Soluble BOD₅.

Expected BOD₅ and SS removal efficiency in each step of above mentioned treatment process is described below.

| Parameter | Expected removal efficiency (%) | | Total expected removal efficiency (%) |
|------------------|--|--------------------|---------------------------------------|
| | Primary Sedimentation with Coagulation | Multi Media Filter | |
| BOD ₅ | 50 | 15* | 57.5 |
| SS | 80 | 16 | 83.2 |

* Only non filtrate BOD₅ removal is taken into account, as Soluble BOD₅ removal should be avoided for efficient functioning of filter unit.

If this process is adopted for Texcoco wastewater treatment plant, expected treated wastewater quality will be as follows.

| Year | Influent Wastewater Quality (mg/l) | | Effluent Wastewater Quality (mg/l) | |
|------|------------------------------------|-----|------------------------------------|------|
| | BOD ₅ | SS | BOD ₅ | SS |
| 1997 | 220 | 235 | 77 | 9.4 |
| 2015 | 245 | 260 | 86 | 10.4 |

Hence this wastewater system cannot meet the design effluent quality requirements for the Final Project and is not recommended for the Final Project (Year 2015).

However for the reference, this treatment system is designed to meet the design conditions for the year of 1997. Detailed dimensions, of each facility, are shown in Table S.1.

Direct construction cost of this system for treating 35 m³/sec of wastewater is estimated to be N\$ 2,087.5 million and an annual O/M cost is estimated to be N\$ 294.5 million. The break-down of the construction cost and O/M cost is shown in Tables S.2 and Table S.3 respectively.

Table S.1 Basis of Facility Design

| Item | Design Criteria | Estimation of Facility Dimension | Configuration |
|--|--|---|--|
| 1. Wastewater Treatment | | | |
| 1) Receiving Tank | retention time (T) T=1.5min | $35m^3/s \times 60 \times 1.5min = 3150m^3$ $3150m^3 \times 1ls$ | 48m*16m*5.1m |
| 2) Distribution Tank | T=1.5min | $5m^3/s \times 60 \times 1.5min = 450m^3$ $450m^3 \times 7unit$ | 16m*8m*3.5m |
| 3) Preaeration Tank | T=15min | $5m^3/s \times 60 \times 15min = 4500m^3$ $4500m^3 \times 7unit$ | 10m*29m*4m*4 basin |
| 4) Mixing Tank | T=15min | $5m^3/s \times 60 \times 3min = 900m^3$ $900m^3 \times 7unit$ | 12m*6m*3.2m*4 basin |
| 5) Flocculation Chamber | T=30min | $5m^3/s \times 60 \times 30min = 9000m^3$ $9000m^3 \times 7unit$ | 10m*80m*3m*4 basin |
| 6) Primary Sedimentation Tank | Overflow Rate $35m^3/m^2 d$ | $432000m^3/35 = 12343m^2$ $12343m^2 \times 7unit$ | 10m*39m*3m*32basin |
| 7) Chlorine Dosage to Primary Effluent | Dosing Rate 5mg/l | - | - |
| 8) Multimedia Filter | Filtration Rate $120m^3/m^2 d$ | $432000m^3/120 = 3600m^2$ $3600m^2 \times 7unit$ | 12m*12m*3.5m*2.5basin |
| 9) Filtered Water Reservoir | | content : equivalent to backwash water of 2 basins $144m^2 \times 1m^3/m^2 min \times 6min \times 2basins = 1728m^3$ $1728m^3 \times 7unit$ | 15m*30m*2m*2basin |
| 10) Effluent Disinfection | Dosing Rate 2mg/l | - | - |
| 11) Effluent Conduit | | (Dia.) $4.0m \times 2pipes \times 1.5km$ | |
| 12) Blower | | $5m^3/s \times 60 \times 1.3 = 390m^3$ $390m^3/min \times 7unit$ | 100m ³ /min*110kw*4set |
| 2. Sludge Treatment | | | |
| 1) G/F for PRI Sludge | Solid Loading $30kg/m^2$ | required surface area;(A) $A = 122940/30 = 4098m^2$ $4098m^2 \times 7unit$ | (Dia.) 24m*9tanks |
| 2) Mixing Tank for Line Stabilization | Mixing Duration ; 30min | $2460m^3/(24 \times 2) = 51m^3$ $51m^3 \times 7unit$ | 3m*3m*3.5m*3 basin |
| 3) Pressure Filter Press | Solid Loading $5kg/m^2$ | required Filter area;(A) $A = 113310kg/(5 \times 9.6hr) = 2361m^2$ $2361m^2 \times 7unit$ | 200m ² *12set |
| 4) Backwash Water Storage | T=24 hr | $3600m^2 \times 1m^3/m^2 min \times 6min \times 1time/d = 21600m^3$ $21600m^3 \times 7unit$ | 51m*51m*4m*2basin |
| 5) G/F for Backwash water | Solid Loading $30kg/m^2$ | required surface area;(A) $A = 26410kg/30 = 880m^2$ $880m^2 \times 7unit$ | (Dia.) 24m*2tanks |
| 6) Belt Filter Press | Solid Loading per Belt Width; $150kg/m^2 hr$ | required Belt Width;(W) $W = 21130kg/(150 \times 9.6hr) = 14.7m$ $14.7m \times 7unit$ | (W)3m/set*5set |
| 7) Sanitary Landfill | | disposal volume $(340+100)m^3/d \times 365 = 160,600m^3/unit$ $160600m^3 \times 7unit$ | Total of 7 unit 1,124,200m ³ /year |

Table S.2 Construction Cost of Wastewater Treatment Plant (35m³/s)

(Unit : Million N\$)

| Item | Civil / Architect | | | Mechanical / Electrical | | | Construction Cost |
|---|-------------------|-----------|-------------------|-------------------------|-----------|-------------------|-------------------|
| | Quantity | Unit Cost | Construction Cost | Quantity | Unit Cost | Construction Cost | |
| 1. Wastewater Treatment | | | | | | | |
| 1) Receiving Tank(48m*16m*5.1m) | 1 | Is. | --- | 1 | Is. | --- | 3.9 |
| 2) Distribution Tank (V=450m ³) | 7 | Unit | 0.500 | 7 | Unit | 0.0 | 3.5 |
| 3) Preaeration Tank (V=4500m ³) | 7 | Unit | 3.825 | 7 | Unit | 0.8 | 32.4 |
| 4) Mixing Tank (12m*6m*3.2m*4basin) | 7 | Unit | 1.106 | 7 | Unit | 0.8 | 13.3 |
| 5) Flocculation Chamber (10m*80m*3m*4basin) | 7 | Unit | 8.160 | --- | --- | --- | 57.1 |
| 6) P/S(10m*80m*3m*4basin) | 7 | Unit | 32.100 | 7 | Unit | 20.8 | 370.5 |
| 7) Blower (100m ³ *4set) | --- | --- | --- | 7 | Unit | 4.4 | 30.8 |
| 8) Maltimedium Filter(12m*12m*25basin) | 7 | Unit | 26.775 | 7 | Unit | 13.4 | 281.2 |
| 9) Filtered Water Reservoir (V=1800m ³) | 7 | Unit | 1.530 | 7 | Unit | 1.9 | 24.0 |
| 10) Effluent Disinfection | --- | --- | --- | 7 | Unit | 1.0 | 7.0 |
| 11) Discharge Channel | 1 | Is. | --- | 1 | Is. | --- | 22.2 |
| Sub-total | | | 543.1 | | | | 845.9 |
| 12) Electrical Work | --- | --- | --- | 1 | Is. | --- | 60.6 |
| Total of 1. Wastewater Treatment | | | 543.1 | | | | 906.5 |
| 2. Sludge Treatment | | | | | | | |
| 1) Gravity Thickener (ø24 m x 11 tanks x 7units) | 7 | Unit | 28.600 | 7 | Unit | 16.5 | 315.7 |
| 2) Belt Filter Press (width 3.0 m x 5 sets x 7units) | --- | --- | --- | 7 | Unit | 7.85 | 55.0 |
| 3) Pressure Filter Press (200m ² *12set*7unit) | --- | --- | --- | 7 | Unit | 61.0 | 427.0 |
| 4) Backwash Sludge Basin (51m*51m*4m*2basin*7unit) | 7 | Unit | 16.548 | 7 | Unit | 1.7 | 127.7 |
| 5) Mixing for Lime Stabilization (3m*3m*3.5m*3basin*7unit) | --- | --- | --- | 7 | Unit | 0.8 | 5.6 |
| Sub-total | | | 316.0 | | | | 931.0 |
| 5) Electrical Work | --- | --- | --- | 1 | Is. | --- | 123.0 |
| Total of 2. Sludge Treatment | | | 316.0 | | | | 1,054.0 |
| 3. Building | | | | | | | |
| 1) Administrative Building (2800m ²) | 1 | Unit | 5.600 | --- | --- | --- | 5.6 |
| 2) Control Building (1800m ²) | 6 | Unit | 3.600 | --- | --- | --- | 21.6 |
| 3) Blower Building (300m ²) | 7 | Unit | 0.600 | --- | --- | --- | 4.2 |
| 4) Sludge Processing Building (3800m ²) | 7 | Unit | 7.600 | --- | --- | --- | 53.2 |
| Total of 3. Building | | | 84.6 | | | | 84.6 |
| 4. Other Work (Access Road and Site Preparation) | 1 | Is. | --- | --- | --- | --- | 42.4 |
| Total Construction Cost of Wastewater Treatment Plant | | | 986.1 | | | 1,101.4 | 2,087.5 |

Table S.3 Breakdown of Operation & Maintenance Cost (35m³/s)

1. Personnel Expenditure

| Item | No. of Employee | Unit Cost (N\$/year) | Personnel Expenditure (Million N\$) |
|----------|-----------------|----------------------|-------------------------------------|
| Employee | 590 | 17,000 | 10.0 |

2. Electrical Cost

| Item | Estimation | Electrical Cost (Million N\$/year) |
|--------------|---|------------------------------------|
| Basic Charge | 19,000kw * 24N\$/mon. kw * 12mon./year = 5.5Million N\$ | |
| Consumption | 407000kwh/d * 365days * 0.14N\$/kwh = 20.8Million N\$ | 26.3 |

3. Chemical Cost

| Chemical | Quantity (ton/year) | Unit Cost (N\$/ton) | Chemical Cost (Million N\$) |
|------------------------|---------------------|---------------------|-----------------------------|
| Anionic Polymer | 823 | 30,000 | 24.7 |
| Ca(OH) ₂ | 37,711 | 190 | 7.2 |
| FeCl ₃ | 55,188 | 1,540 | 85.0 |
| Gas (Cl ₂) | 7,726 | 1,700 | 13.1 |
| Total | | | 130 |

4. Sludge Disposal Cost

| Landfill Type | Cake Volume (m ³ /year) | Unit Cost (N\$/m ³) | Disposal Cost (Million N\$) | Remarks |
|---------------|------------------------------------|---------------------------------|-----------------------------|--|
| Disposal | 1,124,200 | 65 | 73.1 | include land aquisition cost (equivalent to 15N\$/cake volume) |

5. Repairing Cost

assume to 5% of Mechanical/Electrical work $1,101.4 * 0.05 =$ 55.1

6. Total of Operation & Maintenance cost 294.5




Fig. S.1 Flow of Treatment System