

RESULTS OF THE GEOLOGICAL SURVEY

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY



ALSYR

*Sistemas e Investigación
Geotécnica*

**WASTEWATER TREATMENT PLANT,
SOSA TEXCOCO, EDO. DE MÉXICO.
SOIL MECHANICS SURVEYOR**



ALSYR
*Sistemas e Investigación
Geotécnica*

TABLE OF CONTENTS

1.- INTRODUCTION

- 1.1 Background
- 1.2 Location and description of the land.
- 1.3 Description of the project.

2.- FIELD WORKS

- 2.1 Geological conditions.
- 2.2 Exploration and sampling.
- 2.3 Laboratory works.
- 2.4 Stratigraphics conditions.

3.- SOIL MECHANICS ANALYSIS

- 3.1 Selection of foundation.
- 3.2 Bearing capacity

4.- CONCLUSIONS.

LIST OF FIGURES

FIGURE 1.- General location.

FIGURE 2 and 4.- Stratigraphic profile of boring.

FIGURE 5 and 6.- Granulometric tests graphics.

FIGURE 7 to 20.- Triaxial compression tests graphics (UU)

FIGURE 21 to 27.- One-dimension consolidation tests graphics.

1.- INTRODUCTION

1.1.- Background

It's projected to build the waste water treatment plant that Sosa Texcoco, S. A. intends to install in a land inside the lake of Texcoco, at the northeast of Mexico City; reason why ALSYR, Sistemas e Investigación Geotécnica has been requested the elaboration of the soil mechanics study that may permit to know the stratigraphic conditions of the site, as well as determine the mechanical properties of the different materials composing it, same that are decisive in the foundation design.

This preliminary report included herein describes the activities makes in field and laboratory and include some conclusions related to the foundation design of the project structures.

1.2.- Location and description of the land

The land where the soil mechanics study was conducted has a rectangular shape of 1,000 m by 1,500 m aproximatly, in vicinity of the Gran Canal and railway México-Veracruz, fig. 1.

During the initial recognition of the land, the following general characteristics were established:

The present topography is flat, tipical of the bottom of the lake.

At the north of the site exist some mountains that may modify the stratigraphic conditions.

1.3.- Description of the project

The project comprise the construction of various tanks to water treatment, substations and buildings to process. The tanks are of 54 m by 80 m in view top and transmit at the ground level 6 Ton/m² and 10 Ton/m² in the case of the aeration tank.

2.- FIELD WORKS

With the purpose of anticipating the stratigraphic conditions that would be found during the exploration and in order to orientate the development of this activity, as well as to provide a general geological condition of the area, a regional recognition was performed to identify the different geological accidents established in the specialized literature.

2.1.- Geological conditions

The lowlands of the Valley are covered by Quaternary alluvial and lacustrine deposits. The volcanic basaltic series of Cerro Gordo, Chimalhuacán, Estrella, Chiconautla and the Sierra de Chichinautzin, which blocked the Valley to the south, also belong to the same geological era. The tuffs and breccia of the Tarango formation and the andesitic lavas of Iztaccihuatl and Ajusco in the highland parts to the south and east of the basin belong to the upper Tertiary. Recalling that to the north in Apasco and to the south in Cuernavaca and Cuautla limestones of the upper Cretaceous reach the surface, it was assumed that this type of rock should be found beneath the Valley of México.

2.2.- Exploration and Sampling

With the purpose of accurately determining the stratigraphical conditions at the site as well as defining the soils mechanical properties which are essential for the design and behavior of the foundations, three mixed type borings were performed, down to 35.00 m depth, where the standar penetration test where alternately utilized, advance with conical drill and the recovery of undisturbed samples with Shelby thin-wall tube.

The standar penetration test is classified as a dynamic type by percussion test and consist of driving into the ground a somooth tube of 50.8 mm and 38.1 mm of external and

internal diameters respectively, with the utilization of a 64 kg weight pile driver which freely falls down through a guide from 76 cm height in order to assure its correct stroking. The standar penetration resistance is determined as the number of strokes necessary to drive the tool a 30 cm length. Due to the fact that the mentioned penetrometer has a 60 cm length, this measure corresponds to the central 30 cm, discarding the first and the last 15 cm readings. With this penetration resistance reading it is possible to use correlations established with the shear strength resistance of the different types of soils and define exactly the compaction and consistency of the sample materials. Upon removing the tube after the test, disturbed samples of the existing stratigraphical conditions are recovered, same that are protected against moisture loss during their transportation to the laboratory where they are submitted to classification tests.

The advance with conical drill is utilized to penetrate particularly hard strata without samples recovery.

To obtain undisturbed samples and determine the mechanical properties of the materials in the laboratory, a Shelby sampling was utilized.

The depths at which each one of these procedures was utilized, the standar penetration register and a macroscopic classification of the recovered materials, were recorded in the field logs, that later one were used to establish the stratigraphical conditions and the corresponding mechanical properties based on the results of the laboratory tests.

2.3.- Laboratory works

The samples recovered from borings were sent to the laboratory to be submitted to a series of tests in order to determine their classification in accordance to the USSC and determine the mechanical properties of the subsoil materials.

Initially, the total samples were macroscopically classified according to their color, texture, composition and odor.

Afterwards, previously selected specimens were determined their index properties of consistency limits (liquid and plastic), sieve analysis or smaller fines percentage of mesh N° 200 (0.074 mm), so that they were unmistakably classified and thus be able to make reliable stratigraphic profiles and apply the correlations offered by the specialized literature for the validation of the mechanical tests results later on described, as well as for the estimation of those same properties in the materials where the obtention of undisturbed samples was not possible.

The undisturbed samples recovered were determined their shear strength mechanical properties on undrained triaxial compression tests and compressibility on one-dimension consolidation tests in the clayey materials.

The stratigraphic profiles indicated in figures 2 to 4 include a summary of the tests performed on samples of the borings 1 to 3.

Figures 5 and 6 shows granulometric curves, figures 7 to 20 mention the triaxial compression tests and figures 21 to 27 the graphics of consolidation tests.

2.4.- Stratigraphics conditions

Considering the results available right now, was possible to establish the following stratigraphic general conditions, however the subsoil is very erratic below 15.0 m:

Depth [m]	Description
0.00	Clay gray to dark brown and reddish, very soft consistency with a strata of fine clayey sand (CH)
8.50	Fine silty sand, dark gray of medium dense
9.80	Inorganic clay gray greenish, very soft to medium stiff, with thin slices of fine sand
15.50	Silty fine sand gray greenish, very dense
19.20	High plasticity clay greenish gray, stiff with a slice of fine sand
24.00	Sandy silt dark gray, very soft
25.00	High plasticity clay gray greenish, stiff
28.30	Silty fine sand, dark gray greenish, very dense
30.60	Clay gray greenish, of consistency stiff to hard, with a thin slice of fine sand, light gray
35.20	

It is important to annotate that the program of field works has been formulated by the client and it's necessary to enlarge the exploration campaign to at least 4 borings at each unit in project.

3.- SOIL MECHANICS ANALYSIS

3.1.- Selection of foundation

As it has been mentioned in the stratigraphic description, the subsoil is formed mainly by soft consistency clays in erratic thickness and the foundations in project transmit to ground subsoil moderate stress, however this pressure act in a extensive surface, inducing very important settlements; for this reason a shallow foundation is not permitted.

In the next we consider a pile analysis foundation, for to have a good behavior of the structure.

3.2.- Bearing capacity

In this order of ideas, was selected the Zeevaert's criteria to evaluate the bearing capacity of depth foundations, with negative friction because the region is in settlement process due to extraction of water.

Analyzing the soil profile, was established a hard strata adequate to support the pile foundation among 16.00 m and 21.00 m, and selected a depth foundation in 18.00 m, under the ground surface.

Was calculate different values of bearing capacity in agreement with the author's method:

B [m]	Qult, point [Ton]	Qult, positive friction [Ton]	Negative friction [Ton]	Qallow at head [Ton]	Qult, at failure [Ton]	Security Factor
0.40	72	12	44	40	150	3.75
0.45	88	14	50	52	175	3.37
0.50	108	15	55	68	225	3.31

Where:

B:	wide pile	[m]
Qult, point	Ultimate bearing capacity of pile point	[Ton]
Qult, positive friction	Positive friction among 16.00 m and 18.00 m depth	[Ton]
Negative friction	Negative friction among 0.00 m and 16.00 m depth	[Ton]
Qallow at head	Qult. point+Qult. positive friction-Negative friction	[Ton]
Qult. at failure	Q at occur the failure of foundation	[Ton]
Security factor	Qult. at failure divide over Qult net at head	

In this calculus was made next considerations:

1. Exist regional settlement that induces negative friction in pile foundations.
2. The positive friction was limited to up boundary of support strata because if upper strata participate of this positive friction, very important settlements may be occur.
3. The support strata is reasonable continual to establish a uniform behaviour of the pile foundation
(will be necessary verify this consideration with more exploration to confirm the soil profile)

Of this way, the settlements of pile foundation only will be by participation of the clay strata below the support strata, among 21.00 m and 29.00 m and results of order of 50 mm in 25 years, having the 50 % at the first year, without involve the regional settlement that need measure to found exactly the structural behaviour of the plant.

In other hand, was calculate the bearing capacity of shallow foundations that will be necessary to support light structures outside the influence area of depth foundations and results, with the Skempton's criteria of:

$$q_{\text{ad}} = 2.124 + 1.166 D_f \text{ [T/m}^2\text{]} D_f \text{ [m]}$$

To shallow foundations at depth foundations (Df) among 0.60 m to 2.00 m without calculate their settlements because requires the structural distribution and weight.

4.- CONCLUSIONS

The structures in project are the waste water treatment to Sosa Texcoco, S. A. inside the lake of Texcoco, at the northeast of Mexico City and consist in various concret tanks and buildings to process control and electrical unit.


The project manager found the exploration program in 3 mixed borings, amount inferior to a real necessity consider the subsoil condition and the project extention.

The stratigraphic profiles show the tipical subsoil conditions of lacustric valley of volcanic origin.

The bearing capacity of depth foundations was found with the Zeevaert's criteria involving negative friction to 16 m depth drive piles with the values show in the chapter 3.

It is important to consider that is necessary more exploration to found more precise the foundation depth to drive piles an to propose the distribution of piles and found its bearing capacity and performance.

We propose execute at least 4 borings in each unit of treatment and to install one piezometric station to find carefully the hidraulic conditions in the subsoil and calculate the behaviour of foundations to long term.



ING. LUIS MORALES VIRGEN

Calculation of Consolidation Settlement Time at Boring Point SM-2 (Depth = 5 ~ 5.9m)

1. Coefficient of Consolidation (Cv)

$$C_v = \frac{T_i \cdot H^2}{t_i} \dots\dots\dots (1)$$

Where

- Cv = coefficient of consolidation (cm²/s)
- Ti = time factors for indicated pressure distribution (degree of consolidation : Uz = 90 %)
- H = length of longest drainage path for a particle of water
- ti = time for i percent consolidation

From the laboratory test and Fig.28, Eq. (1) becomes

$$C_v = \frac{T_{90} \cdot H^2}{t_{90}}$$

$$= \frac{0.848 \times \left(\frac{1.894}{2}\right)^2}{2.088}$$

$$= 0.00036(\text{cm}^2 / \text{s})$$

2. Consolidation Settlement Time (t)

$$t = \frac{T_i \cdot H^2}{C_v} \dots\dots\dots (2)$$

Where

- t = consolidation settlement time
- Ti = time factors for indicated pressure distribution (degree of consolidation : Uz = 90 %)
- Hr = length of longest drainage
- Cv = coefficient of consolidation (cm²/s)

$$t = \frac{1}{0.00036} \times 0.848 \times \left(\frac{900}{2}\right)^2$$

$$= 4.77 \times 10^8 \text{ sec.}$$

$$= 5,521 \text{ days}$$

$$= 16 \text{ years}$$

FIGURES





FIGURE 1. GENERAL LOCATION

STANDARD PENETRATION TEST (No of Blows)	WATER CONTENT LIQUID LIMIT PLASTIC LIMIT	SPECIFIC GRAVITY			GRADUATION		STRENGTH TESTING		CLASSIFICATION (S.U.C.S.)	TYPE SAMPLE
		γ_m	e	C_w	(G) GRAVE (S) SAND (F) FINES	(%)	QU	CU		
1	0.01								CLAY GRAY TO DARK BROWN AND REDDISH. OF VERY SOFT CONSISTENCY WITH A THIN STRATA OF FINE SAND.	Pe
PH *	0.01									
PH *	0.01								(CH)	Sh
PH *	0.01									
PH *	0.01								FINE SAND SILTY LIGHT GRAY OF MEDIUM DENSE.	Pe
PH *	0.01									
PH *	0.01	2.505	1.461	2.371	100	0	24	76	INORGANIC SILT DARK GRAY TO GREENISH OF VERY STIFF CONSISTENCY. WITH A THIN SLICE OF CLAYEY SAND. DARK GRAY.	Sh
PH *	0.01									
PH *	0.01								SILTY SAND GREENISH GRAY DENSE.	Pe
PH *	0.01									

C O N V E N T I O N A L S Y M B O L S



N = NUMBER OF BLOWS STANDARD PENETRATION TEST 30 cm
 PH = OWN WEIGHT OF TOOL
 NR = NO RECOVERED SAMPLE
 Pe = STANDARD PENETRATION TEST
 Sh = SAMPLE WITH SHELBY
 BD = SAMPLE WITH DENISON
 * = ROLLER BIT
 M = MORE THAN 50 BLOWS
 N.T. = SURFACE LEVEL
 N.A.F. = WATER LEVEL

A L S Y R

PROJECT : WASTE WATER TREATMENT
SOSA TEXCOCCO

BORING : SM-1 SURFACE LEVEL :

WATER LEVEL : 7.40 m FIG. 20

STANDARD PENETRATION TEST (No of Blows)	WATER CONTENT ● LIQUID LIMIT △ PLASTIC LIMIT	SPECIFIC GRAVITY			GRADUATION: (G) GRAVE (S) SAND (F) FINES	STRENGTH TESTING (ton/m ²)		CLASSIFICATION (S.U.C.S.)	TYPE SAMPLE
		γ_m	γ_m	γ_w		QU	TRIAxIAL UNDRAINED		
N									
35*	●							INORGANIC SILT GREENISH GRAY OF HARD CONSISTENCY.	P ₀
35*	●							HIGH PLASTICITY CLAY GRAY AND YELLOWISH SOFT.	P ₀
3	●							FINE CLAYEY SAND LIGHT GRAY VERY DENSE.	Sh
2	●							HIGH PLASTICITY CLAY GREENISH GRAY STIFF.	P ₀
35/30	●								
Sh	●	2.502	1.594	98	0	75	24		
10*	●							FINE SILTY SAND LIGHT GRAY VERY DENSE.	
35/10	●								
35/10	●								
35/15	●								
35/15	●							HIGH PLASTICITY SILT WITH NOT MUCH FINE SAND. LIGHT GRAY HARD.	P ₀
22	●							VOLCANIC GLASS GRAY MEDIUM DENSE	
35/10	●								
35/10	●								
23	●							END BORING	

C O N V E N T I O N A L S Y M B O L S


- GRAVEL
- SAND
- SILT
- CLAY
- ORGANIC MAT. FILLER
- VOLCANIC GLASS
- N = NUMBER OF BLOWS STANDARD PENETRATION TEST 30 cm
- PH = OWN WEIGHT OF TOOL
- NR = NO RECOVERED SAMPLE
- P₀ = STANDARD PENETRATION TEST
- Sh = SAMPLE WITH SHELBY
- BD = SAMPLE WITH DENISON
- * = ROLLER BIT
- ☐ MORE THAN 50 BLOWS
- N.T. = SURFACE LEVEL
- N.A.F. = WATER LEVEL

A L S Y R

PROJECT : WASTE WATER TREATMENT
SOSA TEXCOCO

BORING : SM-1 SURFACE LEVEL :

WATER LEVEL : 7.40 m FIG. 2 b



C O N V E N T I O N A L S Y M B O L S

- GRAVEL
- SAND
- SILT
- CLAY
- ORGANIC MAT.
- FILLER
- VOLCANIC GLASS

N = NUMBER OF BLOWS STANDARD PENETRATION TEST 30 cm
 PH = OWN WEIGHT OF TOOL
 NR = NO RECOVERED SAMPLE

P₀ = STANDARD PENETRATION TEST * = ROLLER BIT
 Sh = SAMPLE WITH SHELBY
 SD = SAMPLE WITH DENISON


MORE THAN 50 BLOWS
 N.T. = SURFACE LEVEL
 N.A.F. = WATER LEVEL

A L S Y R

PROJECT : WASTE WATER TREATMENT
SOSA TEXCOCO

BORING : SM- 2 SURFACE LEVEL :

WATER LEVEL : 7.21 m FIG. 30




C O N V E N T I O N A L S Y M B O L S

- GRAVEL
- SAND
- SILT
- CLAY
- ORGANIC MAT.
- FILLER VOLCANIC GLASS
- * = STANDARD PENETRATION TEST
- Sh = SAMPLE WITH SHELBY
- SD = SAMPLE WITH DENISON
- * = ROLLER BIT
- * = MORE THAN 50 BLOWS
- N.T. = SURFACE LEVEL
- N.A.F. = WATER LEVEL

A L S Y R	
PROJECT : WASTE WATER TREATMENT SOSA TEXCOCO	
BORING : SM-2	SURFACE LEVEL :
WATER LEVEL : 7.21 m	FIG. 3 b

STANDARD PENETRATION TEST (NO. OF BLOWS)	WATER CONTENT LIQUID LIMIT PLASTIC LIMIT	S _e SPECIFIC GRAVITY		GRADUATION :		STRENGTH TESTING		CLASSIFICATION (S.U.C.S.)	TYPE SAMPLE	
		γ _m UNIT WEIGHT (TON/MS)	e VOID RATIO	G _w DEGREE OF SATURATION	(G) GRAVE (S) SAND (F) FINES	QU	TRIAXIAL UNDRAINED C β			
2	0.01							FINE CLAYEY SAND. LIGHT BROWN VERY LOOSE.		
3	0.02									
Sh	0.02	2.455	1.088	6.700	86.8	0	29	71	0.95	14°
PH	0.02									
Sh	0.02	2.361	1.142	9.320	100	0	7	93	1.25	0°
PH	0.02									
Sh	0.02	2.333	1.258	4.713	100				1.0	3°
Sh	0.02	2.434	1.128	9.116	99.5					
Sh	0.02	2.301	1.183	6.384	100	0	46	54	2.45	0°
Sh	0.02	2.529	1.165	9.526	100	0	18	82	1.6	6°
Sh	0.02	2.485	1.199	6.322	99.3				1.4	3°
1760	0.02									
9	0.02									
5	0.02									
1	0.02									
Sh	0.02	2.481	1.229	5.959	100	0	1	99	3.0	0°
35/20	0.02									
12	0.02									
35	0.02									
*	0.02									
Sh	0.02	2.361	1.483	2.854	96.0	0	3	97	8.7	0°
1745	0.02									
1745	0.02									
55/10	0.02									
35/15	0.02									
35/10	0.02									
35/15	0.02									
35/10	0.02									
35/20	0.02									
35/15	0.02									

C O N V E N T I O N A L S Y M B O L S



N = NUMBER OF BLOWS STANDARD PENETRATION TEST 30 cm
 PH = OWN WEIGHT OF TOOL
 NR = NO RECOVERED SAMPLE
 P₀ = STANDARD PENETRATION TEST
 Sh = SAMPLE WITH SHELBY
 BD = SAMPLE WITH DENISON
 * = ROLLER BIT
 [Symbol] MORE THAN 50 BLOWS
 N.T. = SURFACE LEVEL
 N.A.F. = WATER LEVEL

A L S Y R

PROJECT : WASTE WATER TREATMENT
SOSA TEXCOCO

BORING : SM-3 SURFACE LEVEL :


WATER LEVEL : 7.30 m FIG. 4 C

FINE CLAYEY SAND DARK GRAY, LOOSE.
 INORGANIC HIGH PLASTICITY CLAY GRAY GREENISH, VERY SOFT TO STIFF CONSISTENCY WITH THIN SLICES OF SANDY SILT VERY STIFF.
 CLAYEY FINE SAND WITH SOME GRAVEL AT THE TOP OF STRATA GRAY GREENISH, VERY DENSE.

HIGH PLASTICITY CLAY, GRAY TO DARK BROWN AND REDDISH VERY SOFT CONSISTENCY WITH TWO SLICES OF FINE SAND.

FINE CLAYEY SAND, LIGHT BROWN VERY LOOSE.

S I E V E A N A L Y S I S



SO UL ERS	GRAVEL	SAND	SILT OR CLAY
COARSE	FINE	COARSE	FINE

AVERAGE DEPTH	SAMPLE No	SYMBOL	D ₁₀	D ₃₀	D ₆₀	C _u -D ₁₀	C _c -D ₁₀	D ₅₀ /D ₁₀	GRAVEL	SAND	FINE	GROUP SUCS
ft			mm	mm	mm				(%)	(%)	(%)	
15.30	SM-1	—	—	—	0.13	—	—	—	0	66	34	SC
5.70	SM-2	-----	—	0.10	0.20	—	—	—	0	80	20	SC


A L S Y R

PROJECT WASTE WATER TREATMENT
SOSA TEXCOCO

LOCALIZATION : BORING :
EDD. DE MEXICO SM-1 and 2

FIG.: 5

S I E V E A N A L Y S I S



(%) PERCENT PASSING

(%) PERCENT RETAINED

GRAVEL		SAND		SILT OR CLAY	
COARSE	FINE	COARSE	MEDIUM	FINE	
D ₁₀ mm	D ₆₀ mm	D ₃₀ mm	D ₅₀ mm	D ₂₀ mm	D ₄₀ mm
0.16	0.60	0.094	0.16	0.075	0.15
Cu - D ₆₀ /D ₁₀	Cc - (D ₃₀ -D ₁₀)/D ₁₀	D ₃₀ /D ₁₀	D ₅₀ /D ₁₀	D ₂₀ /D ₁₀	D ₄₀ /D ₁₀
3.75	1.276	0.56	0.34	0.88	0.93

AVERAGE DEPTH (m)	SAMPLE No	SYMBOL	D ₁₀ mm	D ₃₀ mm	D ₅₀ mm	D ₆₀ mm	Cu - D ₆₀ /D ₁₀	Cc - (D ₃₀ -D ₁₀)/D ₁₀	GRAVEL (%)	SAND (%)	FINE (%)	GROUP SUCS
19.37	M-29	---	0.16	0.094	0.16	0.60	3.75	1.276	0	79	21	SC
20.47	M-31	---	0.16	0.35	0.60	0.60	3.75	1.276	0	93	7	SP-SC

A L S Y R



PROJECT WASTE WATER TREATMENT
SOSA TEXCOCO

LOCALIZATION : BORING : SM-3
EDD. DE MEXICO

FIG.: 6

TRIAxIAL COMPRESSION TEST

UNDRAINED (UU) CONSOLIDATED UNDRAINED (CU) CONSOLIDATED DRAINED (CD)



NORMAL STRESS $\bar{\sigma}$ (kg/cm²)



UNIT STRAIN ϵ (%)

TEST NUMBER	W _i (%)	e _i	G _{wi} (%)	γ_m (ton/m ³)	$\bar{\sigma}$ (kg/cm ²)	$\sqrt{3}$ (kg/cm ²)
1	94.7	2.308	100	1.474	0.25	0.49
2	101.3	2.478	100	1.450	0.50	0.50
3	93.8	2.328	100	1.459	1.00	0.53

A L S Y R	
PROJECT WASTE WATER TREATMENT SOSA TEXCOCO	
BORING : SM-1	DEPTH : 5.45 m
M-5 down	FIG. : 7

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU)
 CONSOLIDATED UNDRAINED (CU)
 CONSOLIDATED DRAINED (CD)



NORMAL STRESS $\bar{\sigma}$ (kg/cm²)

UNIT STRAIN ϵ (%)



TEST NUMBER	ei		Gwi (%)	χ_m (ton/m ²)	$\bar{\sigma}_3$ (kg/cm ²)	$\sqrt{1-\bar{\sigma}_3}$ (kg/cm ²)
	Wi (%)					
1	55.5	1.433	96.9	1.599	0.50	1.62
2	67.4	1.705	98.9	1.548	1.00	2.11
3	52.8	1.337	98.8	1.636	2.00	3.13

A L S Y R	
PROJECT WASTE WATER TREATMENT	
SOSA TEXCOCO	
BORING : SM-1	DEPTH : 25.30 m
M-27 DOWN	
FIG: 8	

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU)

CONSOLIDATED UNDRAINED (CU) CONSOLIDATED DRAINED (CD)





TEST NUMBER	W _i	e _i	G _{wi}	$\bar{\sigma}_m$	\sqrt{s}	$\sqrt{i}\sqrt{s}$
	(%)					
1	168.6	4.512	99.6	1.299	0.25	0.66
2	169.3	4.522	99.8	1.300	0.50	0.60
3	166.8	4.470	99.5	1.300	1.00	0.75

A L S Y R	
PROJECT : WASTE WATER TREATMENT	
SOSA TEXCOCCO	
BORING : SM-2	DEPTH : 5.20 m
FIG. : 9	

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU)

CONSOLIDATED UNDRAINED (CU) CONSOLIDATED DRAINED (CD)





NORMAL STRESS $\bar{\sigma}$ (kg/cm^2)

TEST NUMBER	W1	ei	Gwi	γ_m	$\bar{\sigma}$	$\sqrt{1/3}$
	(%)		(%)	ton/m^2	kg/cm^2	kg/cm^2
1	159.1	4.133	99.3	1.305	0.25	0.86
2	156.8	4.132	99.3	1.309	0.50	0.72
3	164.3	4.361	98.5	1.290	1.00	0.90

A L S Y R	
PROJECT WASTE WATER TREATMENT SOSA TEXCOCO	
BORING : SM-2	DEPTH : 15.20 m
FIG. : 10	

TRIAxIAL COMPRESSION TEST

UNDRAINED (UU) CONSOLIDATED UNDRAINED (CU) CONSOLIDATED DRAINED (CD)



NORMAL STRESS σ (kg/cm²)

UNIT STRAIN ϵ (%)

TEST NUMBER	W _i	e _i	G _{wi}	χ _m	σ ₃	σ ₁ -σ ₃
	(%)		(%)	ton/m ²	kg/cm ²	kg/cm ²
1	119.4	2.930	98.8	1.354	0.50	1.38
2	115.0	2.871	97.1	1.346	1.00	1.56
3	113.6	2.732	100	1.388	2.00	1.41



A L S Y R	
PROJECT WASTE WATER TREATMENT SOSA TEXCOCO	
BORING : SM-2	DEPTH : 25.70 m
FIG. 11	

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU)

CONSOLIDATED UNDRAINED (CU)

CONSOLIDATED DRAINED (CD)





TEST NUMBER	W _i	e _i	G _{wi}	γ _m	σ ₃	σ ₁ √3
	(%)		(%)	ton/m ³	kg/cm ²	kg/cm ²
1	95.0	2.327	97.1	1.393	0.50	5.48
2	96.1	2.344	97.4	1.393	1.00	6.18
3	96.3	2.306	99.3	1.411	2.00	7.88

A L S Y R	
PROJECT: WASTE WATER TREATMENT SOSA TEXCOCO	
BORING: SM-2	DEPTH: 26.40 m
FIG.: 12	

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU)
 CONSOLIDATED UNDRAINED (CU)
 CONSOLIDATED DRAINED (CD)





NORMAL STRESS $\bar{\sigma}$ (kg/cm²)

TEST NUMBER	W _i	e _i	G _{wi}	γ _m	γ ₃	γ _i γ ₃
	(%)		(%)	ton/m ³	kg/cm ³	kg/cm ³
1	170.2	4.915	85.3	1.126	0.125	0.35
2	187.8	5.334	86.0	1.111	0.250	0.46
3	229.1	6.529	86.5	1.078	0.500	0.58

A L S Y R	
PROJECT WASTE WATER TREATMENT	
SOSA TEXCOCO	
BORING : SM-3	DEPTH : 1.43 m
M-3 UP	
FIG. 13	

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU)
 CONSOLIDATED UNDRAINED (CU)
 CONSOLIDATED DRAINED (CD)



SHEAR STRESS (kg/cm²)

NORMAL STRESS $\bar{\sigma}$ (kg/cm²)



UNIT STRAIN $\epsilon \%$

TEST NUMBER	w_i	e_i	G _{wi} (%)	γ_m	$\bar{\sigma}_3$	$\sqrt{s_3}$
	(%)					
1	343.1	8.019	100	1.160	0.125	0.25
2	317.6	7.420	100	1.171	0.250	0.22
3	329.8	7.706	100	1.166	0.500	0.25

A L S Y R	
PROJECT: WASTE WATER TREATMENT SOSA, TEXCOCO	
BORING: SM-3	DEPTH: 3.38 m
M-5 down	
FIG: 14	

TRIAxIAL COMPRESSION TEST

UNDRAINED (UU)
 CONSOLIDATED UNDRAINED (CU)
 CONSOLIDATED DRAINED (CD)



SHEAR STRESS (kg/cm²)



NORMAL STRESS $\bar{\sigma}$ (kg/cm²)

TEST NUMBER	W _i	e _i	G _{wi}	γ _m	√s	√i√3
	(%)		(%)	ton/m ³	kg/cm ²	kg/cm ²
1	190.8	4.637	100	1.256	0.250	0.24
2	195.8	4.685	100	1.266	0.500	0.33
3	199.7	4.817	100	1.254	1.000	0.30

A L S Y R	
PROJECT WASTE WATER TREATMENT SOSA TEXCOCO	
BORING : SM-3	DEPTH : 4.88 m
M-7 down	FIG.: 15

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU) CONSOLIDATED UNDRAINED (CU) CONSOLIDATED DRAINED (CD)





TEST NUMBER	W _i	e _i	G _{wi}	Σ _m	√s	√i√s
	(%)		(%)	ton/m ³	kg/cm ²	kg/cm ²
1	284.8	6.490	100	1.182	0.250	0.45
2	276.4	6.347	100	1.185	0.500	0.49
3	276.0	6.315	100	1.183	1.000	0.50

A L S Y R	
PROJECT WASTE WATER TREATMENT	
SOSA TEXCOCO	
BORING : SM-3	DEPTH : 5.78 m
M-8 down	FIG: 16

TRIAxIAL COMPRESSION TEST

UNDRAINED (UU)
 CONSOLIDATED UNDRAINED (CU)
 CONSOLIDATED DRAINED (CD)





TEST NUMBER	W _i	e _i	G _{wi}	γ_m	$\bar{\sigma}$	$\sqrt{i}\bar{\sigma}$
	(%)		(%)		ton/m ²	kg/cm ²
1	299.9	7.637	99.3	1.171	0.250	0.45
2	300.0	7.733	98.1	1.158	0.500	0.46
3	297.9	7.575	99.4	1.173	1.000	0.58

A L S Y R	
PROJECT: WASTE WATER TREATMENT	
SOSA TEXCOCO	
BORING: SM-3	DEPTH: 6.50 m
M-9 DOWN	FIG.: 17

TRIAxIAL COMPRESSION TEST

UNDRAINED (UU)
 CONSOLIDATED UNDRAINED (CU)
 CONSOLIDATED DRAINED (CD)



SHEAR STRESS (kg/cm²)

0.2

NORMAL STRESS $\bar{\sigma}$ (kg/cm²)



UNIT STRAIN ϵ (%)

TEST NUMBER	W1	ei	Gwi (%)	γ_m (ton/m ³)	$\bar{\sigma}_3$ (kg/cm ²)	$\sqrt{s_1 s_3}$ (kg/cm ²)
	(%)					
1	257.6	6.445	99.3	1.194	0.250	0.33
2	245.5	6.180	98.7	1.196	0.500	0.35
3	256.2	6.341	100	1.206	1.000	0.37

A L S Y R	
PROJECT: WASTE WATER TREATMENT	
SOSA TEXCOCC	
BORING: SM-3	DEPTH: 7.60 m
M-10 DOWN	FIG.: 18

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU)
 CONSOLIDATED UNDRAINED (CU)
 CONSOLIDATED DRAINED (CD)



UNIT STRAIN ϵ (%)



NORMAL STRESS $\bar{\sigma}$ (kg/cm^2)

TEST NUMBER	w_i	e_i	G_w	γ_m	$\bar{\sigma}_3$	$\bar{\sigma}_1 - \bar{\sigma}_3$
	(%)					
1	234.4	5.989	97.5	1.192	0.50	0.68
2	223.0	5.621	98.8	1.215	1.00	0.60
3	213.9	5.421	98.3	1.218	2.00	0.59

A L S Y R	
PROJECT WASTE WATER TREATMENT SOSA TEXCOCO	
BORING : SM-3	DEPTH : 11.50 m
M-16 down	
FIG. 19	

TRIAXIAL COMPRESSION TEST

UNDRAINED (UU)
 CONSOLIDATED UNDRAINED (CU)
 CONSOLIDATED DRAINED (CD)



NORMAL STRESS $\bar{\sigma}$ (kg/cm²)


UNIT STRAIN ϵ (%)

TEST NUMBER	W _i	e _i	G _{wi}	γ_m	$\bar{\sigma}_3$	$\sqrt{i}\bar{\sigma}_3$
	(%)		(%)	ton/m ³	kg/cm ²	kg/cm ²
1	79.1	1.859	100	1.479	0.50	1.75
2	72.1	1.721	98.9	1.493	1.00	1.74
3	79.9	1.876	100	1.477	2.00	1.46

A L S Y R			
PROJECT WASTE WATER TREATMENT			
SOSA TEXCOCO			
BORING :	SM-3	DEPTH :	14.80 m
M-21 down			FIG: 20

CONSOLIDATION COMPRESSIBILITY CURVE

P_a - APPLY PRESSURE P - TOTAL PRESSURE P - EFFECTIVE PRESSURE P_o - PRECONSOLIDATION PRESS



MEDIUM DEEP (m)	SAMPLE No	SYMBOL	W (%)	e	Gw (%)	γ_m T/m³	S_w	\bar{P} kg/cm²	P_o kg/cm²
5.675	5 down	-----	226.4	5.714	99.3	1.218	2.505		0.63

\bar{P} - EFFECTIVE PRESSURE

P_o - PRECONSOLIDATION PRESSURE

A L S Y R

PROJECT : WASTE WATER TREATMENT

SOSA TEXCOCO

LOCALIZATION :
EDO. DE MEXICO

HORING: SM-1

CLASSIFICATION

FIG : 21

CONSOLIDATION

COMPRESSIBILITY CURVE

P_a - APPLY PRESSURE P - TOTAL PRESSURE P - EFFECTIVE PRESSURE P_c - PRECONSOLIDATION PRESSURE



MEDIUM DEEP (m)	SAMPLE No	SYMBOL	W (%)	e	Gw (%)	γ_m T/m ³	S _w	\bar{P} kg/cm ²	P _c kg/cm ²
25.15	27 up	—————	79.3	2.085	95.2	1.454	2.504		1.50


\bar{P} - EFFECTIVE PRESSURE

P_c - PRECONSOLIDATION PRESSURE

A L S Y R	
PROJECT : WASTE WATER TREATMENT	
SOSA TEXCOCO	
LOCALIZATION : EDO. DE MEXICO	BORING: SM-1
CLASSIFICATION	FIG : 22

CONSOLIDATION COMPRESSIBILITY CURVE

P_a - APPLY PRESSURE P - TOTAL PRESSURE P' - EFFECTIVE PRESSURE P_c - PRECONSOLIDATION PRESSURE




MEDIUM DEEP (m)	SAMPLE No	SYMBOL	W (%)	e	Gw (%)	γ_m T/m ³	S _s -	\bar{P} kg/cm ²	P _c kg/cm ²
5.23	6 up	—————	432.9	10.229	100	1.265	2.665		0.555
15.23	17 up	- - - - -	313.8	8.090	100	1.191	2.616		1.580

\bar{P} - EFFECTIVE PRESSURE
 P_c - PRECONSOLIDATION PRESSURE

A L S Y R	
PROJECT : WASTE WATER TREATMENT	
SOSA TEXCOCO	
LOCALIZATION : EDO. DE MEXICO	BORING: SM-2
CLASSIFICATION	FIG : 23

CONSOLIDATION COMPRESSIBILITY CURVE

Pa- APPLY PRESSURE P- TOTAL PRESSURE P- EFFECTIVE PRESSURE Pc- PRECONSOLIDATION PRE



MEDIUM DEEP (m)	SAMPLE No	SYMBOL	W (%)	e	Gw (%)	γ_m T/m³	S _n	\bar{P} kg/cm²	P _c kg/cm²
25.45	28	—————	95.4	2.305	100	1.433	2.424		1.75
26.43	29 down	-----	84.2	1.995	100	1.462	2.377		1.60

\bar{P} - EFFECTIVE PRESSURE


P_c - PRECONSOLIDATION PRESSURE

A L S Y R	
PROJECT : WASTE WATER TREATMENT	
SOSA TEXCOCO	
LOCALIZATION : EDO. DE MEXICO	BORING: SM-2
CLASSIFICATION	FIG : 24

CONSOLIDATION

COMPRESSIBILITY CURVE

P_a - APPLY PRESSURE P - TOTAL PRESSURE P - EFFECTIVE PRESSURE P_c - PRECONSOLIDATION PRE




MEDIUM DEEP (m)	SAMPLE No	SYMBOL	W (%)	e	Gw (%)	γ_m T/m ³	Sa	\bar{P} kg/cm ²	P_c kg/cm ²
1.425	3 up	—————	207.3	6.872	86.8	1.088	2.455		0.70
3.375	5 down	314.8	9.320	100	1.142	2.361		0.45

\bar{P} - EFFECTIVE PRESSURE

P_c - PRECONSOLIDATION PRESSURE

A L S Y R	
PROJECT : WASTE WATER TREATMENT	
SOSA TEXCOCO	
LOCALIZATION : EDO. DE MEXICO	BORING: SM-3
CLASSIFICATION	FIG : 25

CONSOLIDATION COMPRESSIBILITY CURVE



MEDIUM DEEP (m)	SAMPLE No	SYMBOL	W (%)	e	G _w (%)	γ_m T/m ³	S_e	\bar{P} kg/cm ²	P_c kg/cm ²
4.875	7 down	—————	323.5	9.116	99.5	1.128	2.333		0.50
6.675	9 down	—————	312.3	9.526	100	1.165	2.529		1.00


\bar{P} - EFFECTIVE PRESSURE

P_c - PRECONSOLIDATION PRESSURE

A L S Y R	
PROJECT : WASTE WATER TREATMENT	
SOSA TEXCOCD	
LOCALIZATION :	BORING:
EDO. DE MEXICO	SM-3
CLASSIFICATION	FIG : 26

CONSOLIDATION COMPRESSIBILITY CURVE

Pa- APPLY PRESSURE P- TOTAL PRESSURE P- EFFECTIVE PRESSURE Pc- PRECONSOLIDATION PRE



MEDIUM DEEP (m)	SAMPLE No	SYMBOL	w (%)	e	Gw (%)	γ_m T/m ³	Ss	\bar{P} kg/cm ²	Pc kg/cm ²
11.47	16down	—	219.8	5.959	100	1.229	2.491		1.60


\bar{P} - EFFECTIVE PRESSURE

Pc - PRECONSOLIDATION PRESSURE

A L S Y R	
PROJECT : WASTE WATER TREATMENT	
SOSA TEXCOCO	
LOCALIZATION : EDO. DE MEXICO	BORING: SM-3
CLASSIFICATION	FIG : 27

CONSOLIDATION COMPRESSIBILITY CURVE

P_a - APPLY PRESSURE P - TOTAL PRESSURE \bar{P} - EFFECTIVE PRESSURE P_o - PRECONSOLIDATION PRESS




MEDIUM DEEP (m)	SAMPLE No	SYMBOL	W (%)	e	Gw (%)	γ_m T/m ³	S _s	\bar{P} kg/cm ²	P_o kg/cm ²
14.77	21down	—————	106.7	2.854	96.0	1.483	2.351		

\bar{P} - EFFECTIVE PRESSURE

P_o - PRECONSOLIDATION PRESSURE

A L S Y R	
PROJECT : WASTE WATER TREATMENT	
SOSA TEXCOCO	
LOCALIZATION : EDD. DE MEXICO	BORING: SM-3
CLASSIFICATION	FIG : 27 a



\sqrt{t} Method

**WATER QUALITY DATA OF TERMoeLECTRICA VALLE DE
MEXICO TREATMENT PLANT
AND
GRAN CANAL**

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY

Table

Water Quality Data of Termoelectrica Valle de Mexico treatment plant

(1) Monthly Average										
1st unit (BOD)						1st unit (S S)				
Primary Sed. Tank				Secondary	Total	Primary Sed. Tank			Secondary	Total
		Removal		Effluent	Removal	Removal		Effluent	Removal	
Influent	Effluent	Efficiency			Efficiency	Influent	Effluent	Efficiency		Efficiency
APR.1993	266 mg/l	229	13.9 %	23	91.4 %	228 mg/l	133	41.7 %	19	91.7 %
MAY.1993	250 mg/l	182	27.2 %	40	84.0 %	375 mg/l	181	51.7 %	31	91.7 %
JUN.1993	255 mg/l	184	27.8 %	32	87.5 %	258 mg/l	152	41.1 %	21	91.9 %
JUL.1993	260 mg/l	247	5.0 %	14	94.6 %	306 mg/l	154	49.7 %	23	92.5 %
AUG.1993	-	-	###	-	###	314 mg/l	170	45.9 %	25	92.0 %
SEP.1993	208 mg/l	178	14.4 %	24	88.5 %	198 mg/l	100	49.5 %	21	89.4 %
OCT.1993	314 mg/l	288	8.3 %	38	87.9 %	266 mg/l	154	42.1 %	22	91.7 %
NOV.1993	255 mg/l	184	27.8 %	33	87.1 %	238 mg/l	128	46.2 %	23	90.3 %
DEC.1993	257 mg/l	187	27.2 %	34	86.8 %	255 mg/l	135	47.1 %	22	91.4 %
JUN.1994	246 mg/l	-	###	-	###	246 mg/l	117	52.4 %	21	91.5 %
Average			19.0 %		88.5 %			46.7 %		91.4 %
2nd/3rd unit (BOD)						2nd/3rd unit (S S)				
Primary Sed. Tank				Secondary	Total	Primary Sed. Tank			Secondary	Total
		Removal		Effluent	Removal	Removal		Effluent	Removal	
Influent	Effluent	Efficiency			Efficiency	Influent	Effluent	Efficiency		Efficiency
APR.1993	266 mg/l	216	18.8 %	20	92.5 %	228 mg/l	120	47.4 %	18	92.1 %
MAY.1993	250 mg/l	183	26.8 %	34	86.4 %	375 mg/l	183	51.2 %	34	90.9 %
JUN.1993	255 mg/l	180	29.4 %	35	86.3 %	258 mg/l	154	40.3 %	20	92.2 %
JUL.1993	260 mg/l	193	25.8 %	13	95.0 %	306 mg/l	170	44.4 %	23	92.5 %
AUG.1993	-	-	###	-	###	314 mg/l	160	49.0 %	24	92.4 %
SEP.1993	208 mg/l	172	17.3 %	22	89.4 %	198 mg/l	90	54.5 %	15	92.4 %
OCT.1993	314 mg/l	283	9.9 %	30	90.4 %	266 mg/l	146	45.1 %	18	93.2 %
NOV.1993	255 mg/l	180	29.4 %	35	86.3 %	238 mg/l	122	48.7 %	20	91.6 %
DEC.1993	257 mg/l	182	29.2 %	37	85.6 %	255 mg/l	132	48.2 %	20	92.2 %
JUN.1994	246 mg/l	-	###	-	90.7 %	246 mg/l	126	48.8 %	22	91.1 %
Average			23.3 %		89.2 %			47.8 %		92.1 %
4th unit (BOD)						4th unit (S S)				
Primary Sed. Tank				Secondary	Total	Primary Sed. Tank			Secondary	Total
		Removal		Effluent	Removal	Removal		Effluent	Removal	
Influent	Effluent	Efficiency			Efficiency	Influent	Effluent	Efficiency		Efficiency
APR.1993	266 mg/l	210	21.1 %	20	92.5 %	228 mg/l	130	43.0 %	18	92.1 %
MAY.1993	250 mg/l	192	23.2 %	24	90.4 %	375 mg/l	197	47.5 %	27	92.8 %
JUN.1993	255 mg/l	185	27.5 %	25	90.2 %	258 mg/l	152	41.1 %	20	92.2 %
JUL.1993	260 mg/l	224	13.8 %	16	93.8 %	306 mg/l	150	51.0 %	22	92.8 %
AUG.1993	-	-	###	-	###	314 mg/l	160	49.0 %	21	93.3 %
SEP.1993	208 mg/l	184	11.5 %	26	87.5 %	198 mg/l	88	55.6 %	17	91.4 %
OCT.1993	314 mg/l	295	6.1 %	32	89.8 %	266 mg/l	152	42.9 %	20	92.5 %
NOV.1993	255 mg/l	185	27.5 %	25	90.2 %	238 mg/l	127	46.6 %	19	92.0 %
DEC.1993	257 mg/l	189	26.5 %	28	89.1 %	255 mg/l	133	47.8 %	20	92.2 %
JUN.1994	246 mg/l	-	###	-	90.7 %	246 mg/l	128	48.0 %	23	90.7 %
Average			19.6 %		90.5 %			47.2 %		92.2 %

Table Water Quality Data of Termoelectrica Valle de Mexico treatment plant

(2) Minimum Value

	1st unit (BOD)						1st unit (SS)					
	Primary Sed. Tank			Secondary Effluent	Total Removal	Primary Sed. Tank			Secondary Effluent	Total Removal		
	Influent	Effluent	Removal Efficiency			Influent	Effluent	Removal Efficiency				
APR.1993	239 mg/l	192	19.7 %	11	95.4 %	196 mg/l	108	44.9 %	16	91.8 %		
MAY.1993	226 mg/l	173	23.5 %	30	86.7 %	200 mg/l	112	44.0 %	14	93.0 %		
JUN.1993	230 mg/l	170	26.1 %	23	90.0 %	200 mg/l	108	46.0 %	18	91.0 %		
JUL.1993	227 mg/l	213	6.2 %	12	94.7 %	196 mg/l	112	42.9 %	20	89.8 %		
AUG.1993	-	-	###	-	###	260 mg/l	152	41.5 %	22	91.5 %		
SEP.1993	125 mg/l	110	12.0 %	16	87.2 %	152 mg/l	60	60.5 %	16	89.5 %		
OCT.1993	223 mg/l	183	17.9 %	31	86.1 %	212 mg/l	112	47.2 %	18	91.5 %		
NOV.1993	230 mg/l	170	26.1 %	25	89.1 %	200 mg/l	96	52.0 %	20	90.0 %		
DEC.1993	232 mg/l	173	25.4 %	26	88.8 %	224 mg/l	116	48.2 %	18	92.0 %		
JUN.1994	183 mg/l	-	-	-	-	216 mg/l	116	46.3 %	20	90.7 %		
Average	-	-	19.6 %	-	89.8 %	-	-	47.4 %	-	91.1 %		

	2nd/3rd unit (BOD)						2nd/3rd unit (SS)					
	Primary Sed. Tank			Secondary Effluent	Total Removal	Primary Sed. Tank			Secondary Effluent	Total Removal		
	Influent	Effluent	Removal Efficiency			Influent	Effluent	Removal Efficiency				
APR.1993	239 mg/l	179	25.1 %	13	94.6 %	196 mg/l	100	49.0 %	16	91.8 %		
MAY.1993	226 mg/l	173	23.5 %	22	90.3 %	200 mg/l	122	39.0 %	18	91.0 %		
JUN.1993	230 mg/l	163	29.1 %	20	91.3 %	200 mg/l	112	44.0 %	16	92.0 %		
JUL.1993	227 mg/l	153	32.6 %	8	96.5 %	196 mg/l	120	38.8 %	18	90.8 %		
AUG.1993	-	-	###	-	###	260 mg/l	140	46.2 %	20	92.3 %		
SEP.1993	125 mg/l	105	16.0 %	18	85.6 %	152 mg/l	60	60.5 %	12	92.1 %		
OCT.1993	223 mg/l	173	22.4 %	26	88.3 %	212 mg/l	112	47.2 %	16	92.5 %		
NOV.1993	230 mg/l	163	29.1 %	20	91.3 %	200 mg/l	100	50.0 %	16	92.0 %		
DEC.1993	232 mg/l	165	28.9 %	22	90.5 %	224 mg/l	112	50.0 %	18	92.0 %		
JUN.1994	183 mg/l	168	8.2 %	10	94.5 %	216 mg/l	112	48.1 %	18	91.7 %		
Average	-	-	23.9 %	-	91.4 %	-	-	47.3 %	-	91.8 %		

	4th unit (BOD)						4th unit (SS)					
	Primary Sed. Tank			Secondary Effluent	Total Removal	Primary Sed. Tank			Secondary Effluent	Total Removal		
	Influent	Effluent	Removal Efficiency			Influent	Effluent	Removal Efficiency				
APR.1993	239 mg/l	179	25.1 %	11	95.4 %	196 mg/l	112	42.9 %	16	91.8 %		
MAY.1993	226 mg/l	173	23.5 %	16	92.9 %	200 mg/l	122	39.0 %	16	92.0 %		
JUN.1993	230 mg/l	170	26.1 %	15	93.5 %	200 mg/l	108	46.0 %	16	92.0 %		
JUL.1993	227 mg/l	180	20.7 %	10	95.6 %	196 mg/l	112	42.9 %	18	90.8 %		
AUG.1993	-	-	###	-	###	260 mg/l	140	46.2 %	20	92.3 %		
SEP.1993	125 mg/l	115	8.0 %	21	83.2 %	152 mg/l	56	63.2 %	12	92.1 %		
OCT.1993	223 mg/l	204	8.5 %	27	87.9 %	212 mg/l	116	45.3 %	18	91.5 %		
NOV.1993	230 mg/l	170	26.1 %	15	93.5 %	200 mg/l	100	50.0 %	16	92.0 %		
DEC.1993	232 mg/l	174	25.0 %	18	92.2 %	224 mg/l	116	48.2 %	18	92.0 %		
JUN.1994	183 mg/l	163	10.9 %	15	91.8 %	216 mg/l	112	48.1 %	18	91.7 %		
Average	-	-	19.3 %	-	91.8 %	-	-	47.2 %	-	91.8 %		

Table Water Quality of Gran Canal (Dry Season)

Location	Month Year	Dry Season					
		TSS	ISS	VSS	BOD	BOD Soluble	BOD Particle
Cerro Gordo	10/'91~3/'92	135	43	91	231 (100)	128 (55)	103 (45)
San Cristobal Num 1	12 /'92	203	49	154	271 (100)	175 (65)	96 (35)
San Cristobal Num 1	10/'91~3/'92	230	61	168	235 (100)	169 (72)	66 (28)
Lopez Portillo	10/'92	278	121	157	209 (100)	144 (69)	65 (31)
Lopez Portillo	10/'91~3/'92	235	97	138	251 (100)	182 (73)	69 (27)
Zumpango	10/'92	357	198	159	161 (100)	99 (61)	62 (39)
Zumpango	11/'92	244	106	139	165 (100)	124 (75)	41 (25)
Zumpango	12/'92	289	151	137	315 (100)	161 (51)	154 (49)
Zumpango	10/'91~3/'92	185	70	106	241 (100)	178 (74)	63 (26)
San Pedro	10/'91~3/'92	179	66	113	254 (100)	171 (67)	83 (33)
San Lazaro	10/'92	100	32	69	231 (100)	182 (79)	49 (21)
San Lazaro	11/'92	85	35	50	168 (100)	106 (63)	62 (37)
San Lazaro	12/'92	137	31	99	230 (100)	120 (52)	110 (48)
San Lazaro	10/'92~3/'92	120	25	95	185 (100)	111 (60)	74 (40)
San Juan de Aragon	9/'92	164	54	110	136 (100)	54 (40)	82 (60)
San Juan de Aragon	12/'92	148	34	100	203 (100)	145 (71)	58 (29)
San Juan de Aragon	10/'91~3/'92	166	43	123	244 (100)	131 (54)	113 (46)
San Juan de Aragon	10/'91~3/'92	74	34	41	27 (100)	7 (26)	20 (74)
Ejido	10/'92	240	143	96	110 (100)	72 (65)	38 (35)
Ejido	12/'92	129	51	78	215 (100)	136 (63)	79 (37)
Ejido	10/'91~3/'92	184	63	121	234 (100)	191 (82)	43 (18)
Avenida Central	10/'91~3/'92	180	70	110	249 (100)	129 (52)	120 (48)
Cerro Gordo	2/'93	133	33	105	217 (100)	147 (68)	70 (32)
Cerro Gordo	3/'93	153	46	107	233 (100)	119 (51)	114 (49)
Cerro Gordo	10/'92~3/'93	202	81	103	189 (100)	140 (74)	49 (26)
San Cristobal Num. 1	11/'93	179	105	71	199 (100)	164 (82)	35 (18)
San Cristobal Num. 1	12/'93	178	83	102	238 (100)	191 (80)	47 (20)
Lopez Portillo	3/'93	193	50	90	242 (100)	138 (57)	104 (43)
Lopez Portillo	10/'92~3/'93	233	100	130	226 (100)	139 (62)	87 (38)
Zumpango	11/'93	283	165	118	214 (100)	157 (73)	57 (27)
Zumpango	12/'93	443	165	278	228 (100)	120 (53)	108 (47)
San Pedro	2/'93	254	122	131	235 (100)	132 (56)	103 (44)
San Pedro	10/'92~3/'93	218	109	118	195 (100)	132 (68)	63 (32)
San Lazaro	1/'93	155	67	80	280 (100)	133 (48)	147 (53)
San Lazaro	2/'93	122	46	66	187 (100)	106 (57)	81 (43)
San Lazaro	3/'93	120	8	113	165 (100)	87 (53)	78 (47)
San Lazaro	11/'93	148	39	108	177 (100)	113 (64)	64 (36)
San Lazaro	12/'93	113	34	78	186 (100)	91 (49)	95 (51)
San Lazaro	10/'92~3/'93	123	31	80	212 (100)	111 (52)	101 (48)
San Juan de Aragon	1/'93	131	60	135	206 (100)	105 (51)	101 (49)
San Juan de Aragon	2/'93	125	30	67	153 (100)	105 (69)	48 (31)
San Juan de Aragon	12/'93	183	100	153	237 (100)	168 (71)	69 (29)
San Juan de Aragon	10/'92~3/'93	128	36	89	179 (100)	116 (65)	63 (35)
Ejido	1/'93	273	172	170	255 (100)	186 (73)	69 (27)
Ejido	2/'93	142	35	79	227 (100)	141 (62)	86 (38)
Ejido	3/'93	107	31	77	229 (100)	139 (61)	90 (39)
Ejido	10/'92~3/'93	171	75	88	198 (100)	139 (70)	59 (30)
Avenida Central	1/'93	167	76	91	256 (100)	156 (61)	100 (39)
Avenida Central	10/'92~3/'93	212	100	122	249 (100)	156 (63)	93 (37)


Table Water Quality of Gran Canal (Rainy Season)
Rainy Season

Location	Month Year	TSS	ISS	VSS	BOD	BOD	
						Soluble	Particle
ZUMPANGO	6 /'92	380	229	152	182 (100)	97 (53)	85 (47)
ZUMPANGO	8 /'92	458	256	201	131 (100)	55 (42)	76 (58)
ZUMPANGO	9 /'92	291	200	91	183 (100)	123 (67)	60 (33)
ZUMPANGO	4~9/'92	359	210	149	180 (100)	110 (61)	70 (39)
San Lazaro	6/'92	117	26	91	191 (100)	69 (36)	122 (64)
San Lazaro	8/'92	76	16	60	112 (100)	55 (49)	57 (51)
San Lazaro	9/'92	106	23	83	171 (100)	84 (49)	87 (51)
San Lazaro	4/'92~9/'92	113	25	88	165 (100)	77 (47)	88 (53)
San Juan de Aragon	6/'92	209	73	135	137 (100)	134 (98)	3 (2)
San Juan de Aragon	8/'92	105	31	85	103 (100)	46 (45)	57 (55)
San Juan de Aragon	4/'92~9/'92	19	10	12	30 (100)	5 (17)	25 (83)
San Juan de Aragon	4/'92~9/'92	173	55	129	185 (100)	78 (42)	107 (58)
Ejido	6/'92	240	103	137	142 (100)	136 (96)	6 (4)
Ejido	9/'92	271	217	85	185 (100)	57 (31)	128 (69)
Ejido	4/'92~9/'92	234	116	119	177 (100)	97 (55)	80 (45)
Cerro Gordo	7/'93	533	600	240	152 (100)	82 (54)	70 (46)
Cerro Gordo	4/'93~9/'93	268	325	220	228 (100)	82 (36)	146 (64)
Lopez Portillo	7/'93	301	73	66	149 (100)	69 (46)	80 (54)
Lopez Portillo	8/'93	278	174	130	167 (100)	115 (69)	52 (31)
Lopez Portillo	4/'93~9/'93	266	142	121	184 (100)	106 (58)	78 (42)
San Pedro	7/'93	432	200	140	146 (100)	69 (47)	77 (53)
San Pedro	4/'93~9/'93	199	200	140	153 (100)	69 (45)	84 (55)
San Lazaro	5/'93	106	10	102	161 (100)	83 (52)	78 (48)
San Lazaro	6/'93	92	23	69	119 (100)	51 (43)	68 (57)
San Lazaro	8/'93	128	34	94	114 (100)	78 (68)	36 (32)
San Lazaro	9/'93	132	22	109	111 (100)	72 (65)	39 (35)
San Lazaro	4/'93~9/'93	109	22	87	133 (100)	68 (51)	65 (49)
San Juan de Aragon	4/'93~9/'93	161	45	87	172 (100)	24 (14)	148 (86)
Ejido	4/'93	142	43	99	252 (100)	142 (56)	110 (44)
Ejido	5/'93	146	56	90	226 (100)	145 (64)	81 (36)
Ejido	6/'93	680	613	353	193 (100)	104 (54)	89 (46)
Ejido	8/'93	403	220	140	182 (100)	110 (60)	72 (40)
Avenida Central	7/'93	1168	625	268	170 (100)	77 (45)	93 (55)
Avenida Central	4/'93~9/'93	451	308	159	227 (100)	102 (45)	125 (55)
Obra de Toma	7/'93	2147	1882	265	165 (100)	59 (36)	106 (64)
Obra de Toma	4/'93~9/'93	788	1882	265	146 (100)	59 (40)	87 (60)
Zumpango	8/'92	458	256	201	131 (100)	55 (42)	76 (58)
San Lazaro	7/'93	70	11	59	99 (100)	38 (38)	61 (62)
San Juan de Aragon	7/'93	166	75	80	121 (100)	24 (20)	107 (58)
Ejido	7/'93	574	353	220	176 (100)	104 (59)	72 (41)
San Lazaro	4/'93	117	22	95	184 (100)	77 (42)	97 (80)
Ejido	9/'93	290	230	131	174 (100)	112 (64)	62 (36)
Ejido	4/'93~9/'93	378	231	166	202 (100)	121 (60)	81 (40)
Avenida Central	9/'93	359	220	140	141 (100)	128 (91)	13 (9)

DRAWINGS

DECEMBER 1994

JAPAN INTERNATIONAL COOPERATION AGENCY



- LEGEND
- ① Receiving Tank
 - ② Distribution Tank
 - ③ Aeration Tank
 - ④ Blower House
 - ⑤ Secondary Sedimentation Tank
 - ⑥ Control Building
 - ⑦ Centrifugal Thickener House
 - ⑧ Anaerobic Digester
 - ⑨ Gas Holder
 - ⑩ Sludge Dewatering House
 - ⑪ Gas Power Station
 - ⑫ Discharge Channel
 - ⑬ Primary Sedimentation Tank
 - ⑭ Gravity Thickener
 - ⑮ Extra-High Tension Substation
 - ⑯ Disinfection Tank

Note: [---] for Final Project


THE FEDERAL DISTRICT OF MEXICO
 THE GENERAL DIRECTION OF CONSTRUCTION
 AND HYDRAULIC OPERATION (DGOCH)

THE FEASIBILITY STUDY
 ON
 WASTEWATER TREATMENT
 IN
 THE FEDERAL DISTRICT OF MEXICO

1. General Layout


SCALE 1 / 5000

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)



Note: [Symbol] for Final Project

THE FEDERAL DISTRICT OF MEXICO THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGCCH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
2. Layout of Wastewater Treatment Plant	
SCALE	1 / 1000
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	



Receiving Tank

Distribution Tank

Aeration Tank

Sec. Sedimentation Tank

Effluent Flume


Disinfection Tank

Discharge Channel


THE FEDERAL DISTRICT OF MEXICO THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGOCH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
3. Hydraulic Profile of Wastewater Treatment Plant	
SCALE	FREE
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	

RECEIVING TANK


SCALE 1:200



PLAN




SECTION a - a



SECTION b - b

Unit : m


TYPICAL SECTION OF CONNECTING PIPE
SCALE 1:100




THE FEDERAL DISTRICT OF MEXICO THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGOCH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
4. Receiving Tank - Plan & Section	
SCALE	1/200
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	

DISTRIBUTION TANK


SCALE 1:100




PLAN



SECTION a - a



SECTION b - b




SECTION c - c

THE FEDERAL DISTRICT OF MEXICO THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGOCH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
5. Distribution Tank - Plan & Section	
SCALE	1/200
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	

WASTEWATER TREATMENT FACILITY PLAN

SCALE 1:200




UNIT : m

THE FEDERAL DISTRICT OF MEXICO THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGGOH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
6. Aeration Tank & Secondary Sedimentation Tank - Plan	
SCALE	1/200
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	


WASTEWATER TREATMENT FACILITY SECTION

SCALE 1:200




AERATION TANK

SEC. SEDIMENTATION TANK



SECTION (AERATION TANK)





SECTION (SEC. SEDIMENTATION TANK)


THE FEDERAL DISTRICT OF MEXICO THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGCOP)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
7. Aeration Tank & Secondary Sedimentation Tank - Section	
SCALE	1/200
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	

DISINFECTION TANK


SCALE 1:200



B - B






A - A



C - C

THE FEDERAL DISTRICT OF MEXICO	
THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGOCH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
8. Disinfection Tank	
SCALE	1/200
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	



OUTLET SECTION
 H = 1/500
 V = 1/200

THE FEDERAL DISTRICT OF MEXICO
 THE GENERAL DIRECTION OF CONSTRUCTION
 AND HYDRAULIC OPERATION (DGCOR)

THE FEASIBILITY STUDY
 ON
 WASTEWATER TREATMENT
 IN
 THE FEDERAL DISTRICT OF MEXICO


9. Discharge Channel

SCALE 1/1000


JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

ANAEROBIC DIGESTION TANK

SCALE 1:200



PLAN



SECTION


THE FEDERAL DISTRICT OF MEXICO
THE GENERAL DIRECTION OF CONSTRUCTION
AND HYDRAULIC OPERATION (DGOCH)

THE FEASIBILITY STUDY
ON
WASTEWATER TREATMENT
IN
THE FEDERAL DISTRICT OF MEXICO

10. Sludge Digestion Tank - Plan & Section

SCALE 1/200

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)



Facility No.	1	2	3	4	5	6	7	8	9	10	11	12
Name	Outlet Gate	Sludge Inlet Gate	Inlet Gate	Air Diffuser	Blower	Antifoaming Equipment	Inlet Gate	Sludge Collector	Sludge Return Pump	Excess Sludge Pump	Pump for Antifoaming Spray	Pump for Sand Filter
Type	Sluice Gate (Manual)	Sluice Valve (Manual)	Movable Weir (Manual)	Diffuser Tube	Centrifugal Type	Water Spray	Sluice Gate (Manual)	Chain Flight Double Link Type	Centrifugal Type	Centrifugal Type	Vertical Centrifugal Type	Vertical Centrifugal Type
Power (Kw)	-	-	-	-	900	-	-	2.2	30	11	22	22
T. Quantity (Standby)	2	64	64	64	14	64	128	64	48	32	12 (6)	12 (6)

Facility No.	13	14	15	16	17	18	19	20	21	22	23	24
Name	Chlorinator	Sludge Pump	Centrifugal Thickener	Sludge Feed Pump	Sludge Pump for Distribution Tank	Sludge Pump for Anaerobic Digester	Sludge Feed Pump	Gas Compressor	Digestion Tank	Recirculation Pump	Generator	Transfer Pump for Belt Filter Press
Type	-	Centrifugal Type	Solid Bowl Type	Centrifugal Type	Centrifugal Type	Progressing Cavity Type	Progressing Cavity Type	-	Cylindrical Type	Progressing Cavity Pump	-	Progressing Cavity Pump
Power (Kw)	-	22	200	11	11	7.5	7.5	45	-	15	1400 KVA	7.5
T. Quantity (Standby)	2	14 (2)	22	32 (8)	32 (8)	32 (8)	20	20	20	20	8	20

Facility No.	25	26	27	28	29	30	31	32				
Name	Sludge Feed Pump	Belt Filter Press	Air Compressor	Polymer Mixing and Dosing System	Filter Cloth Washing Pump	Sludge Pump for Distribution Tank	Sludge Cake Conveyor	Sludge Cake Hopper				
Type	Progressing Cavity Pump	-	-	-	Centrifugal Type	Centrifugal Type	-	-				
Power (Kw)	7.5	5.5	3.7	4.85	11	5.5	2.2	1.5 x 2				
T. Quantity (Standby)	32	32	24 (8)	32	24 (8)	24 (8)	32	16				

THE FEDERAL DISTRICT OF MEXICO
 THE GENERAL DIRECTION OF CONSTRUCTION
 AND HYDRAULIC OPERATION (DGCOP)

THE FEASIBILITY STUDY
 ON
 WASTEWATER TREATMENT
 IN
 THE FEDERAL DISTRICT OF MEXICO







11. Process Diagram of Wastewater
 Treatment Plant

SCALE FREE

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

LEGEND

ITEM	DESCRIPTION	ITEM	DESCRIPTION
DB	Disturbing Bulb	MC	Mold Contactor
VCB	Vacuum Circuit Breaker	MR	Mold Relay
LA	Lighting Arranger	A	Ammeter
CT	Current Transformer	F	Fuse
PT	Potential Transformer	MS	Motor Starter
I	Transformer	W	Watt Meter
MCB	Molded Case Circuit Breaker	CCM	Control Motor
RO	Refrigerant Overhaul		
DE	Gas Engine	TR	Thermocouple
VCB	Vacuum Contactor Breaker	OC	Overload Circuit Breaker
SW	Switching Station	UL	Under Load Relay
PF	Power Factor	U-1	Under Voltage Relay
OPT	Oil Proof Potential Transformer	U-2	Overload Relay
FCI	Fuse and Current Transformer		



THE FEDERAL DISTRICT OF MEXICO
THE GENERAL DIRECTION OF CONSTRUCTION
AND HYDRAULIC OPERATION (DGCOH)

THE FEASIBILITY STUDY
ON
WASTEWATER TREATMENT
IN
THE FEDERAL DISTRICT OF MEXICO


12. Single Line Diagram

SCALE	FREE
-------	------


JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

CONTROL BUILDING


SCALE 1:200



1ST FLOOR PLAN



SECTION a - a




GROUND FLOOR PLAN


THE FEDERAL DISTRICT OF MEXICO	
THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGOCH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
13. Control Building	
SCALE	1/300
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	

BLOWER HOUSE


SCALE 1:200



GROUND FLOOR PLAN



SECTION a - a




B1 FLOOR PLAN


THE FEDERAL DISTRICT OF MEXICO	
THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGCOR)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
14. Blower House	
SCALE	1/200
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	

CENTRIFUGAL THICKENER HOUSE


SCALE 1:500



GROUND FLOOR PLAN



SECTION a - a




B1 FLOOR PLAN


THE FEDERAL DISTRICT OF MEXICO	
THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGCCH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
15. Centrifugal Thickener House	
SCALE	1/200
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	

SLUDGE DEWATERING HOUSE


SCALE 1:200



GROUND FLOOR PLAN



SECTION a - a



B1 FLOOR PLAN

THE FEDERAL DISTRICT OF MEXICO	
THE GENERAL DIRECTION OF CONSTRUCTION AND HYDRAULIC OPERATION (DGGOH)	
THE FEASIBILITY STUDY ON WASTEWATER TREATMENT IN THE FEDERAL DISTRICT OF MEXICO	
16. Sludge Dewatering House	
SCALE	1/200
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)	

JICA