

(b) The effective energy at the receiving end is expressed by the below equation that reduces the station service rate by 0.3% and transmission loss rate by 0.7% from the average energy for the 43 year period.

$$\text{Effective Energy} = (1 - 0.003) \times (1 - 0.007) \times \text{Average annual energy}$$

Table 9-6 Alternative Thermal Power Plant for Comparative Study

Item	Unit	Description	
Type		Coal Fired Power Plant	
Installed Capacity	MW	300	
Annual Plant Factor	%	70	
Thermal Efficiency	%	38.3	
Annual Energy Production	GWh	1,839.6	
Investment Cost	10 ⁶ TL	4,019,400	
Service Life	Years	25	
Construction Period	Years	4	
Capital Recovery Factor		0.10596	
Coal Calorific Value	kcal/kg	6,500	
Coal Surface Moisture	%	7	
Oil Calorific Value	Kcal/kg	10,500	
Fuel Consumption Rate (Coal 95%)	kg/kWh	0.353	
Fuel Consumption Rate (Oil 5%)	kg/kWh	0.011	
O & M Cost, Administration Cost	%	3.0	
Unit Fuel Cost (Coal)	TL/kg	417.6	
Unit Fuel Cost (Oil)	TL/kg	1,113.6	
Annual Cost		Fixed Cost	Variable Cost
Capital Recovery	10 ⁶ TL	425,895.6	-
O & M Cost, Administration Cost	10 ⁶ TL	108,523.8	12,058.2
Fuel Cost	10 ⁶ TL	-	293,715.0
Total	10⁶ TL	534,419.4	305,773.2
Annual Cost at Receiving End			
kW Cost	TL/kW	2,326,506 ¹⁾	
kWh Cost	TL/kWh	184.33 ²⁾	

$$1) \quad \frac{534,419.4 \times 10^6 TL}{300,000 kW} \times 1.306^3 = 2,326,506$$

$$2) \quad \frac{305,773.2 \times 10^6 TL}{1,839.6 \times 10^6 kWh} \times 1.109^3 = 184.33$$

3) Adjustment Factor for kW & kWh

Item	kW	kWh
Transmission Loss Rate (%)	1.4	1.1
Station Service Rate (%)	8.1	8.8
Forced Outage Rate (%)	4.0	-
Scheduled Outage Rate (%)	12.0	-

$$\text{kW Adjustment Factor} = \frac{1}{(1-0.014) \times (1-0.081) \times (1-0.04) \times (1-0.12)} = 1.306$$

$$\text{kWh Adjustment Factor} = \frac{1}{(1-0.011) \times (1-0.088)} = 1.109$$

9.2.2 Layout

In the Master Plan Report, only the name of the Kesedağ site, 1 km upstream, other than the dam site presently projected was mentioned regarding an alternative to the Köprübaşı Project, while concerning the present plan, comparison studies were carried out only of dam heights and power station scales, no study being made at all about alternative layouts of dam site, waterway route, etc.

Therefore, the studies below were made regarding selection of alternative plans for development based on the results of review of the Master Plan Report and the results of field reconnaissances.

(1) Dam Site

The Master Plan Report, proposes a site 5.8 km downstream of Kesebük village (1.5 km northeast of Kesebük village) as the dam site (referred to as "M/P dam site"), with the high water level at EL. 437 m, the limit topographically, while the effective storage capacity is put as $200 \times 10^6 \text{ m}^3$. Besides the Kesedağ site 1 km Upstream, the site 2.5 upstream of M/P Dam has the topographical and geological conditions to become a dam site (referred to as "upstream dam site"). Because of topographic condition it is difficult to secure an effective storage capacity of $200 \times 10^6 \text{ m}^3$ at these sites practically. It is thought that these were not made concrete objects of comparison studies in the Master Plan Report because of this.

In the present study, optimization of storage capacity was taken into consideration, and as shown in Figure 9-4, the abovementioned Upstream dam site was selected as the alternative dam site, and upon a comparison study with the M/P dam site, the appropriateness of the M/P dam site was to be confirmed. As for the Kesedağ dam site, it was

decided to omit it from consideration since the valley width is large and the left-bank side ridge is thin.

The catchment areas at the dam sites, as a result of measurements by 1/250,000 and 1/25,000 topographic maps, were set as 1,994 km² for the Master Plan dam site, and 1,959 km² for the Upper dam site. The storage capacities at the dam sites were measured by 1/5,000 topographic maps. The storage-capacity curve for the Master Plan dam site is shown in Figure 9-5 and that for the Upper dam site in Figure 9-6.

(2) Waterway Route, Powerhouse Site

In the Master Plan Report it is proposed that the waterway route and powerhouse would be such that the intake and outlet would be connected by the shortest route, and there is no mention of comparison studies with alternative waterway routes and powerhouse sites.

With the waterway route and powerhouse site proposed in the Master Plan Report (hereinafter referred to as "M/P Layout") the penstock length will be very long and the tendency will be for construction cost and head loss to be increased. Consequently, with the purpose of shortening the penstock length, alternative layouts of three waterway routes, A, B, and C, with the headrace tunnel, surface-type penstock, semi-underground powerhouse, and open-canal tailrace as shown in Figure 9-4 were selected on the ridge to the west of the M/P Layout.

Further, although with the abovementioned A, B, and C layouts penstock lengths would be respectively shortened, lengths would still be long and the overall waterway routes including headrace tunnels would be longer than for the M/P Layout. Furthermore, since the headrace tunnels of all of the layouts, M/P, A, B, and C, would pass through a zone expected to have weathering reaching deep inside with earth

cover comparatively thin as described in 7.3, a D layout with a tunnel type penstock and underground powerhouse arranged immediately downstream of the intake, and with connection to the outlet site made by a tailrace tunnel in a straight line was considered for a total of five alternatives.

(3) Formulation of Alternative Development Plan

For the alternative development plan, combinations of the M/P dam and the Upstream dam with the M/P, A, B, C, and D layouts were made with cases set up according to effective storage capacity. The output of the power station was determined by calculating maximum power discharge with equivalent peak duration as 6 hours.

The annual sediment volume at the dam site will be as described in 6.4.7. It was decided that the design sediment volume of the reservoir would take into account sedimentation for a 50 year period, with the base of intake at the same elevation as the design sediment surface level.

Table 9-7 Sediment Surface Level and Low Water Level of Köprübaşı Reservoir

Dam Site	Catchment Area (km ²)	Design Sediment Surface Level (m)	Low Water Level (m)
M/P Dam	1,994	EL. 380.40	EL. 392.00
Upper Dam	1,959	EL. 388.40	EL. 400.00

The tail water level was decided at the same elevation as the water level of the Devrek River at the point of tailrace end of the Köprübaşı Project.

The characteristics of the various alternative plans are given in Table 9-8.






Figure 9-4 Alternative Development Plan of Köprübaşı Project




Figure 9-5 Area-Capacity Curve at M/P Dam Site




Figure 9-6 Area-Capacity Curve at Upper Dam Site

(4) Results of Comparison Studies of Alternative Development Plans

Comparison studies of the various alternative development plans were carried out combining the M/P Dam and the Upper Dam with the waterway routes of M/P, A, B, C, and D, while for the A and D routes, the effective storage capacities of M/P Dam and Upper Dam were varied at nine levels between $200 \times 10^5 \text{ m}^3$ and $25 \times 10^5 \text{ m}^3$. The outline of alternative development plan concerning layout are given in Table 9-8. The results of the studies are given in Table 9-9 and Figure 9-7.

a) Dam Sites

Comparison study of M/P dam site and upper dam site with D layout was carried out.

The Upper dam site has a saddle of EL. 435 m existing at the back of the right abutment and a necessity to provide an auxiliary dam at that part will arise if the effective storage capacity is set at more than $100 \times 10^6 \text{ m}^3$, and the economics would be abruptly worsened.

With the M/P dam site, it is judged that the upper limit of high-water level would be geologically EL. 437 m and the effective water storage of $163 \times 10^6 \text{ m}^3$ as previously mentioned, and the economics would be of a similar trend.

The M/P dam site is economically superior to the Upper dam site because (i) economics of M/P dam site is superior than that of upper dam site with D layout and (ii) order of economics of waterway route is D, A, B, C and M/P as described in b).

The superiority does not change no matter what combination with waterway route and powerhouse type is made.

b) Waterway Route, Powerhouse Type

In comparisons of the A, B, and C routes, which are headrace tunnel, surface-type penstock, and surface-type powerhouse schemes, Route A with the shortest penstock length will be superior economically to the others.

In the comparison of the route D with underground powerhouses and tailraces and route A, the route D is economically superior.

Route D, compared with Route A, not only will have a lower construction cost, but head loss will be less, and the output and electric energy production will be more than for Route A. Regarding the construction period for Route D, the underground powerhouse will not be the critical path and 4 years will be sufficient, the same as for Route A.

Thus, Route D with an underground powerhouse will be selected for the waterway route and powerhouse type.

Therefore, the dam is to be the M/P dam, a tunnel-type penstock and underground powerhouse are to be located immediately downstream of the intake, and the tailrace is to be a non-pressurized tunnel with the end portion an open canal. This alternative plan is to be taken as the optimum alternative development plan concerning layout. Optimization is to be carried out on reservoir scale, dam height, and power generation scale of this alternative plan.

Table 9-8 Outline of Alternative Development Plan Concerning Layout (1)

Name of Case	Upper										M/P			
	UP-D200	UP-D175	UP-D150	UP-D125	UP-D100	UP-D75	UP-D50	UP-D25	MP-D200	MP-D175	MP-D163			
Waterway Route														
Reservoir	D													
Catchment Area	1,959.00	1,959.00	1,959.00	1,959.00	1,959.00	1,959.00	1,959.00	1,959.00	1,959.00	1,959.00	1,959.00	1,959.00	1,994.00	
Annual Inflow	14.14	14.14	14.14	14.14	14.14	14.14	14.14	14.14	14.14	14.14	14.14	14.39	14.39	
High Water Level	455.40	450.60	445.50	440.00	434.10	427.40	419.90	411.10	403.60	439.20	437.00	439.20	437.00	
Low Water Level	400.00	400.00	400.00	400.00	400.00	400.00	400.00	400.00	392.00	392.00	392.00	392.00	392.00	
Available Drawdown	55.40	50.60	45.50	40.00	34.10	27.40	19.90	11.10	51.60	47.20	45.00	45.00	45.00	
Gross Storage Capacity	233	208	183	158	133	108	83	58	234	209	197	209	197	
Effective Storage Capacity	200	175	150	125	100	75	50	25	200	175	163	200	163	
Dam														
Type	D													
Height from Foundation	113	109	104	98	92	85	78	69	117	112	110	112	110	
Crest Length	940	850	750	590	390	300	270	240	600	560	540	560	540	
Volume	9,189	7,603	5,942	4,179	2,803	2,021	1,372	1,210	5,152	5,334	5,025	5,334	5,025	
Headrace Tunnel														
Type	-													
Diameters	-	-	-	-	-	-	-	-	-	-	-	-	-	
Length	-	-	-	-	-	-	-	-	-	-	-	-	-	
Penstock														
Type	Surface													
Diameters	3.5	3.4	3.3	3.2	3.2	3.0	2.7	2.3	3.5	3.4	3.4	3.4	3.4	
Length	282.00	282.00	282.00	282.00	282.00	282.00	282.00	282.00	271.00	271.00	271.00	271.00	271.00	
Powerhouse														
Type	Surface													
Tailrace Tunnel														
Type	Nonpressure													
Diameters	4.7	4.6	4.5	4.4	4.3	4.2	3.9	3.5	4.7	4.6	4.6	4.6	4.6	
Length	6,270.00	6,270.00	6,270.00	6,270.00	6,270.00	6,270.00	6,270.00	6,270.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	
Channel Length	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	
Development Plan														
Maximum Discharge	45	43	41	39	37	34	27	20	46	44	43	44	43	
Tail Water Level	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	
Gross Head	213.93	210.73	207.33	203.67	199.73	195.27	190.27	184.40	203.40	200.47	199.00	200.47	199.00	
Loss of Head	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	9.00	9.00	9.00	9.00	9.00	
Effective Head	203.93	200.73	197.33	193.67	189.73	185.27	180.27	174.40	194.40	191.47	190.00	191.47	190.00	
Installed Capacity	79	74	70	65	60	54	42	30	76	72	70	72	70	

Table 9-8 Outline of Alternative Development Plan Concerning Layout (2)

Name of Case	M/P										
	MP-D150	MP-D125	MP-D100	MP-D75	MP-D50	MP-D25	MP-MP163	MP-A163	MP-B163	MP-C163	
Dam Site											
Waterway Route											
Reservoir	M/P										
Catchment Area	Km ²	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00
Annual Inflow	m ³ /S	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39
High Water Level	m	434.50	429.40	423.90	417.80	410.90	402.60	437.00	437.00	437.00	437.00
Low Water Level	m	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00
Available Drawdown	m	42.50	37.40	31.90	25.80	18.90	10.60	45.00	45.00	45.00	45.00
Gross Storage Capacity	10 ⁶ m ³	184	159	134	109	84	59	197	197	197	197
Effective Storage Capacity	10 ⁶ m ³	150	125	100	75	50	25	163	163	163	163
Dam											
Type											
Height from Foundation	m	106	102	97	91	84	76	110	110	110	110
Crest Length	m	530	520	490	430	400	370	540	540	540	540
Volume	10 ⁶ m ³	4,689	4,052	3,436	2,844	2,284	1,654	5,025	5,025	5,025	5,025
Headrace Tunnel											
Type		-	-	-	-	-	-	Pressure	Pressure	Pressure	Pressure
Diameters	m	-	-	-	-	-	-	4.6	4.6	4.6	4.6
Length	m	-	-	-	-	-	-	2,900.00	4,970.00	4,970.00	3,980.00
Penstock											
Type		Embedded is tunnel	Embedded is tunnel	Embedded is tunnel	Embedded is tunnel	Embedded is tunnel	Embedded is tunnel	Surface	Surface	Surface	Surface
Diameters	m	3.4	3.3	3.2	3.0	2.7	2.4	3.4	3.4	3.4	3.4
Length	m	271.00	271.00	271.00	271.00	271.00	271.00	2,500.00	1,180.00	1,430.00	1,430.00
Powerhouse											
Type		Underground	Underground	Underground	Underground	Underground	Underground	Surface	Surface	Surface	Surface
Tailrace Tunnel											
Type		Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	-	-	-	-
Diameters	m	4.5	4.4	4.3	4.2	3.9	3.5	-	-	-	-
Length	m	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	-	-	-	-
Channel Length	m	200.00	200.00	200.00	200.00	200.00	200.00	700.00	480.00	230.00	630.00
Development Plan											
Maximum Discharge	m ³ /S	42	40	37	34	27	21	43	43	43	43
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	222.00	223.00	223.00	223.00
Gross Head	m	197.33	193.93	190.27	186.20	181.60	176.07	200.00	199.00	199.00	199.00
Loss of Head	m	9.00	9.00	9.00	9.00	9.00	9.00	21.00	14.00	14.00	15.00
Effective Head	m	188.33	184.93	181.27	177.20	172.60	167.07	179.00	185.00	185.00	184.00
Installed Capacity	MW	67	63	57	51	39	30	66	68	68	67




Figure 9-7 Comparative Study on Dam Site

Table 9-9 Comparative Study on Alternative Development Plan Concerning Layout (1)

Description	Name of Case	Upper										M/P		
		UP-D200	UP-D175	UP-D150	UP-D125	UP-D100	UP-D75	UP-D50	UP-D25	MP-D200	MP-D175	MP-D163		
		D										D		
Dam Site														
Waterway Route														
High Water Level	m	455.40	450.60	445.50	440.00	434.10	427.40	419.90	411.10	443.60	439.20	437.00		
Low Water Level	m	400.00	400.00	400.00	400.00	400.00	400.00	400.00	400.00	392.00	392.00	392.00		
Available Drawdown	m	55.40	50.60	45.50	40.00	34.10	27.40	19.90	11.10	51.60	47.20	45.00		
Gross Storage Capacity	10 ⁶ m ³	233	208	183	158	133	108	83	58	234	209	197		
Effective Storage Capacity	10 ⁶ m ³	200	175	150	125	100	75	50	25	200	175	163		
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00		
Effective Head	m	203.93	200.73	197.33	193.67	189.73	185.27	174.40	194.40	194.40	191.47	190.00		
Maximum Discharge	m ³ /s	45	43	41	39	37	34	27	20	46	44	43		
Installed Capacity	MW	79	74	70	65	60	54	42	30	76	72	70		
Firm Peak Power	MW	71.3	69.1	66.3	60.5	55.8	50.2	41.0	29.2	68.6	67.2	66.0		
Energy Production														
Average Energy	GWh	226.9	220.5	218.7	209.7	207.1	199.8	186.2	150.5	218.3	214.6	212.1		
Firm Energy	GWh	172.9	160.5	153.9	140.8	131.9	118.6	93.7	65.4	166.3	156.2	151.8		
Unit Benefit Value														
Firm Peak Power	T.L./KW	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506		
Average Energy	T.L./KWh	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33		
Benefit														
Firm Peak Power	10 ⁹ T.L.	158.2	153.2	147.2	134.1	123.8	111.4	91.0	64.8	153.3	150.2	147.5		
Average Energy	10 ⁹ T.L.	41.1	40.0	39.6	36.0	37.5	36.2	33.7	27.3	39.2	39.2	38.7		
Total	10 ⁹ T.L.	199.3	193.2	186.8	172.1	161.3	147.6	124.8	92.1	193.1	189.3	186.2		
Investment Cost														
Civil Facilities	10 ⁹ T.L.	1,288.2	1,160.2	1,015.1	873.5	753.6	653.8	527.8	462.5	1,049.8	959.1	916.0		
Hydro & Ele.-Mech. Eq.	10 ⁹ T.L.	372.1	357.0	348.0	331.9	318.1	303.8	267.5	232.0	353.6	338.4	334.3		
Total	10 ⁹ T.L.	1,670.3	1,517.2	1,363.1	1,205.4	1,071.8	957.5	795.3	694.5	1,403.4	1,297.5	1,250.2		
Annual Cost														
Civil Facilities	10 ⁹ T.L.	131.1	117.2	102.5	88.2	76.1	66.0	53.3	46.7	106.0	96.9	92.5		
Hydro & Ele.-Mech. Eq.	10 ⁹ T.L.	42.4	40.7	39.7	37.8	36.3	34.6	30.5	26.5	40.3	38.6	38.1		
Total	10 ⁹ T.L.	173.5	157.9	142.2	126.1	112.4	100.7	83.8	73.2	146.3	135.4	130.6		
Annual Surplus Benefit (B-C)	10 ⁹ T.L.	27.2	36.7	46.0	47.3	50.1	48.0	41.9	19.6	46.8	53.9	55.6		
Benefit Cost Ratio (B/C)		1.16	1.23	1.32	1.38	1.45	1.48	1.50	1.27	1.32	1.40	1.43		
Unit Annual Cost	T.L./KWh	765	716	650	601	543	504	450	486	670	631	616		

Table 9-9 Comparative Study on Alternative Development Plan Concerning Layout (2)

Description	M/P										
	MP-D150	MP-D125	MP-D100	MP-D75	MP-D50	MP-D25	MP-MP-163	MP-A163	MP-B163	MP-C163	MP-D163
Dam Site											
Waterway Route											
High Water Level	434.50	429.40	423.90	417.80	410.90	402.60	437.00	437.00	437.00	437.00	437.00
Low Water Level	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00
Available Drawdown	42.50	37.40	31.90	25.80	18.90	10.60	45.00	45.00	45.00	45.00	45.00
Gross Storage Capacity	184	159	134	109	84	59	197	197	197	197	197
Effective Storage Capacity	150	125	100	75	50	25	163	163	163	163	163
Tail Water Level	223.00	223.00	223.00	223.00	223.00	223.00	222.00	223.00	223.00	223.00	223.00
Effective Head	188.33	184.95	181.27	177.20	172.60	167.07	179.00	185.00	185.00	184.00	190.00
Maximum Discharge	42	40	37	34	27	21	43	43	43	43	43
Installed Capacity	67	63	57	51	39	30	66	68	68	67	70
Firm Peak Power	63.5	58.6	53.0	47.4	38.1	29.2	62.2	64.3	64.3	63.9	66.0
Energy Production											
Average Energy	209.3	203.3	196.8	188.7	172.9	150.5	199.8	206.5	206.5	205.4	212.1
Firm Energy	147.3	136.5	125.3	112.0	87.0	65.4	143.0	147.8	147.8	147.0	151.8
Unit Benefit Value											
Firm Peak Power	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506
Average Energy	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33
Benefit											
Firm Peak Power	141.9	130.9	118.4	105.9	85.1	65.3	138.9	143.6	143.6	142.8	147.5
Average Energy	38.2	37.1	35.9	34.4	31.5	27.5	36.5	37.7	37.7	37.5	38.7
Total	180.1	168.0	154.3	140.4	116.7	92.7	175.4	181.3	181.3	180.3	186.2
Investment Cost											
Civil Facilities	883.3	818.8	749.2	680.5	602.1	509.9	900.0	977.1	962.2	955.2	916.0
Hydro & Ele.-Mech. Eq.	326.6	314.1	301.9	287.2	251.9	223.1	460.2	350.8	373.4	389.1	334.3
Total	1,210.0	1,132.9	1,051.1	967.6	854.0	733.0	1,360.2	1,327.9	1,335.6	1,344.3	1,250.3
Annual Cost											
Civil Facilities	89.2	82.7	75.7	68.7	60.8	51.5	90.9	98.7	97.2	96.5	92.5
Hydro & Ele.-Mech. Eq.	37.2	35.8	34.4	32.7	28.7	25.4	52.5	40.0	42.6	44.4	38.1
Total	126.5	118.5	110.1	101.5	89.5	76.9	143.4	138.7	139.8	140.8	130.6
Annual Surplus Benefit (B-C)	53.6	49.5	44.2	38.9	27.2	15.8	32.0	42.6	41.5	39.5	55.6
Benefit Cost Ratio (B/C)	1.42	1.42	1.40	1.38	1.30	1.21	1.22	1.31	1.30	1.28	1.43
Unit Annual Cost (Average)	604	583	560	538	518	511	717	671	677	686	616

9.2.3 Reservoir Scale

(1) Reservoir Operation Study

The annual average inflow at the Köprübaşı dam site is 14.39 m³/s, with the snowmelt period of March to May corresponding to the high water season, 60% of the annual inflow occurring during this period. The inflow during December to February corresponding to the low water season has 8% of the annual inflow, and the seasonal variation range of inflow is not narrow. The minimum value of annual inflow is 37% of the average inflow, and the maximum value 164%. The maximum value of annual inflow is 4.5 times the minimum value.

As described above, inflows at the Köprübaşı project site have fairly large seasonal and annual fluctuations, and a certain degree of reservoir capacity is necessary for effective utilization for power generation.

As reservoir capacity for the Köprübaşı Project, it is possible to obtain an effective storage capacity of 163 x 10⁶ m³ at high water level elevation of 437 m. With regulating capacity of this degree it will not be possible to completely average out inflow, but it will be possible for spillover from the reservoir to be held to a minimum.

The reservoir operation rules of Köprübaşı Reservoir have been determined for each study case, based on considerations on the following factors.

- (a) The river water in a wet year is to be stored and released in a dry year, to make the firm discharge as large as possible.
- (b) During a year, the reservoir is to be operated in such a way that the water in the wet season is to be stored and supplied in the dry season.

- (c) The reservoir is to be operated so that the spill is as small as possible.
- (d) The reservoir is to be operated so that a stable supply of power is assured for a long period and at the same time the energy generation is large.

The calculations of reservoir operation have been performed by an electronic computer system, and based on the monthly average inflow, for the period of 36 years from October 1956 to September 1991.

The firm discharge is defined as the discharge which can be utilized for power generation at all times during 95% of the 36 year period, and it is obtained by making it the largest with the inflow mass curve considering carry over storage. The inflow mass curve and the effective storage capacity and the firm discharge are shown in Figure 9-8 and 9-9 respectively. In the operation calculations of the reservoir, amount of evaporation has not been counted because it is negligibly small.

In the calculation, the change of turbine and generator efficiency depending on the change of the reservoir water level has been taken into account. The maximum power discharge is limited by the rated output when the water level is higher than the rated intake water level, and the maximum power discharge is reduced by the reduction of head when the water level is below the rated intake water level.

The rated intake water level was set at an elevation which is below the high water level by 1/3 of the available drawdown.

The procedure of electric energy calculations is shown in Figure 9-10 and the reservoir operation rules in Figure 9-11. As an expediency, the operation rules were made according to the single rule curve of V_s for securing firm






Figure 9-8 Mass Curve at Köprübaşı Dam Site




Figure 9-9 Effective Storage Capacity and Firm Discharge at Köprübaşı Dam Site

available water. The V_s was obtained taking inflows for the 36 year period, determining the necessary capacity to be secured for not going under low water level with a probability higher than 95% by discharging firm available water for each case, and the envelope for these points was adopted.

(2) Optimum Reservoir Scale

The high water level and effective storage capacity were to be determined for the economically greatest advantage and various cases were set up for the D layout selected as optimum, upon which comparison studies were made.

In case of optimization of the layout through a combination of dam site and waterway route, the low-water level was fixed at the minimum intake water level according to sedimentation capacity and intake static draft head, by which comparative cases of different effective storage capacities were set up, but in optimization of high water level and effective storage capacity, not only high water level but also low water level was varied so the dam scale according to dam height was made a factor for optimization upon which comparison studies were made.

The outline of alternative development plan concerning reservoir scale are given in Table 9-10.

The results of examinations are given in Table 9-11 and Figure 9-12.

According to the examination results, high water level is low with the same effective storage capacity. That is, the economics is better the smaller the scale of the dam, and there is no merit in raising the low water level aiming for high head.

High-water level at EL. 437.00 m and effective storage capacity of $163 \times 10^6 \text{ m}^3$ will be the optimum reservoir scale.





Figure 9-10 Flow Chart of Calculation of Power and Energy



Symbols

- V_{n-1} : Storage at the end of previous month
- V_n : Storage at the end of current month
- V_n' : Temporary storage at the end of current month
- V_{max} : Maximum storage (Effective storage capacity)
- V_s : Secured storage for firm discharge
- f_n : Spill in current month
- q_n : Inflow in current month
- Q_n : Available discharge for power in current month
- Q_L : Firm discharge for power
- Q_H : Maximum discharge for power, variable depending on water level

Operation Rule

$$V_n' = V_{n-1} + q_n$$

1. $V_n' \geq V_{max}$

- (1) $V_n' - V_{max} \geq Q_H \rightarrow Q_n = Q_H$
- (2) $Q_H > V_n' - V_{max} \geq Q_L \rightarrow Q_n = V_n' - V_{max}$
- (3) $Q_L > V_n' - V_{max} \rightarrow Q_n = Q_L$

2. $V_s > V_n'$

- (1) $V_n' \geq Q_L \rightarrow Q_n = Q_L$
- (2) $Q_L > V_n' \rightarrow Q_n = V_n'$

$$V_n' = V_{max} - Q_n \geq 0.0 \rightarrow F_n = V_n' - V_{max} - Q_n$$

$$V_n' = V_{max} - Q_n < 0.0 \rightarrow f_n = 0.0$$

$$V_n = V_n' - Q_n - f_n$$

Figure 9-11 Operation Rule of Reservoir

Table 9-10 Outline of Alternative Development Plan Concerning Reservoir Scale (1)

Description	M/P												
	MP-D200-1	MP-D175-1	MP-D163-1	MP-D150-1	MP-D125-1	MP-D100-1	MP-D75-1	MP-D50-1	MP-D25-1	MP-D175-2	MP-D163-2		
Waterway Route													
Reservoir													
Catchment Area	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00
Annual Inflow	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39
High Water Level	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60
Low Water Level	392.00	402.60	406.80	410.90	417.80	423.90	429.40	434.50	439.20	439.20	439.20	439.20	439.20
Available Drawdown	51.60	41.00	36.80	32.70	25.80	19.70	14.20	9.10	4.40	47.20	41.80	41.80	41.80
Gross Storage Capacity	234	234	234	234	234	234	234	234	234	209	209	209	209
Effective Storage Capacity	200	175	163	150	125	100	75	50	25	175	175	175	163
Dam													
Type													
Height from Foundation	117	117	117	117	117	117	117	117	117	117	117	117	112
Crest Length	590	590	590	590	590	590	590	590	590	590	590	590	560
Volume	6,152	6,152	6,152	6,152	6,152	6,152	6,152	6,152	6,152	6,152	6,152	6,152	5,334
Headrace Tunnel													
Type													
Diameters													
Length													
Penstock													
Type													
Diameters	3.7	3.6	3.6	3.5	3.5	3.3	3.2	2.9	2.5	3.6	3.6	3.6	3.6
Length	271.00	285.84	291.72	297.46	307.12	315.66	323.35	330.50	337.08	271.00	271.00	271.00	278.55
Powerhouse													
Type	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground
Tailrace Tunnel													
Type	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure
Diameters	4.7	4.6	4.6	4.5	4.4	4.3	4.2	3.9	3.5	4.6	4.6	4.6	4.6
Length	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00
Channel Length	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00
Development Plan													
Maximum Discharge	45.00	44.00	43.00	42.00	40.00	37.00	34.00	27.00	21.00	44	44	44	43
Tail Water Level	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00
Gross Head	203.40	206.93	208.33	209.70	212.00	214.03	215.87	217.57	219.13	200.47	200.47	200.47	202.27
Loss of Head	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00
Effective Head	194.40	197.93	199.33	200.70	203.00	205.03	206.87	208.57	210.13	191.47	191.47	191.47	193.27
Installed Capacity	76	74	73	72	69	65	60	48	37	72	72	72	71

Table 9-10 Outline of Alternative Development Plan Concerning Reservoir Scale (2)

Description	M/P											MP-D75-3
	MP-D150-2	MP-D125-2	MP-D100-2	MP-D75-2	MP-D50-2	MP-D25-2	MP-D163-3	MP-D150-3	MP-D125-3	MP-D100-3	MP-D75-3	
Waterway Route												
D												
Reservoir	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00
Catchment Area	Km ²	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39
Annual Inflow	m ³ /s	439.20	439.20	439.20	439.20	439.20	439.20	439.20	439.20	439.20	439.20	439.20
High Water Level	m	402.60	410.90	417.80	423.90	429.40	434.50	398.00	407.20	414.60	421.10	437.00
Low Water Level	m	36.60	28.30	21.40	15.30	9.80	4.70	39.00	29.80	22.40	15.90	15.90
Available Drawdown	m	209	209	209	209	209	209	197	197	197	197	197
Gross Storage Capacity	10 ⁶ m ³	150	125	100	75	50	25	163	125	100	75	75
Effective Storage Capacity	10 ⁶ m ³											
Dam												
Type	m	112	112	112	112	112	112	110	110	110	110	110
Height from Foundation	m	560	560	560	560	560	560	540	540	540	540	540
Crest Length	m	5,334	5,334	5,334	5,334	5,334	5,334	5,025	5,025	5,025	5,025	5,025
Volume	10 ⁶ m ³											
Headrace Tunnel												
Type	m	-	-	-	-	-	-	-	-	-	-	-
Diameters	m	-	-	-	-	-	-	-	-	-	-	-
Length	m	-	-	-	-	-	-	-	-	-	-	-
Penstock												
Type	m	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel
Diameters	m	3.6	3.5	3.3	3.2	2.9	2.5	3.6	3.6	3.5	3.3	3.2
Length	m	285.84	297.46	307.12	315.66	323.36	330.50	271.00	279.40	292.28	302.64	311.74
Powerhouse												
Type		Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground
Tailrace Tunnel												
Type		Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure
Diameters	m	4.5	4.4	4.3	4.2	3.9	3.5	4.6	4.5	4.4	4.3	4.2
Length	m	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00
Channel Length	m	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00
Development Plan												
Maximum Discharge	m ³ /s	42	40	37	34	27	21	43	42	40	37	34
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00
Gross Head	m	204.00	206.77	209.07	211.10	212.92	214.63	199.00	201.00	204.07	206.53	208.70
Loss of Head	m	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00
Effective Head	m	195.00	197.77	200.07	202.10	203.93	205.63	190.00	192.00	195.07	197.53	199.70
Installed Capacity	MW	70	67	63	58	47	37	70	69	66	62	58

Table 9-10 Outline of Alternative Development Plan Concerning Reservoir Scale (3)

Description	Name of Case										
	MP-D50-3	MP-D25-3	MP-D150-4	MP-D125-4	MP-D100-4	MP-D75-4	MP-D50-4	MP-D25-4	MP-D125-5	MP-D100-5	MP-D75-5
M/P											
D											
Waterway Route											
Reservoir											
Catchment Area	Km ²	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00
Annual Inflow	m ³ /s	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39
High Water Level	m	437.00	437.00	434.50	434.50	434.50	434.50	434.50	429.40	429.40	429.40
Low Water Level	m	426.90	432.20	392.00	402.60	410.90	423.90	429.40	392.00	402.60	410.90
Available Drawdown	m	10.10	4.80	42.50	31.90	23.60	10.60	5.10	37.40	26.80	18.50
Gross Storage Capacity	10 ⁶ m ³	197	197	184	184	184	184	184	159	159	159
Effective Storage Capacity	10 ⁶ m ³	50	25	150	125	100	50	25	125	100	75
Dam											
Type											
Height from Foundation	m	110	110	108	108	108	108	108	102	102	102
Crest Length	m	540	540	430	430	430	430	430	520	520	520
Volume	10 ⁶ m ³	5,025	5,025	4,689	4,689	4,689	4,689	4,689	4,052	4,052	4,052
Headrace Tunnel											
Type											
Diameters	m	-	-	-	-	-	-	-	-	-	-
Length	m	-	-	-	-	-	-	-	-	-	-
Penstock											
Type											
Diameters	m	2.9	2.5	3.6	3.5	3.3	2.9	2.5	3.5	3.3	3.2
Length	m	319.86	327.28	271.00	285.84	297.46	315.66	323.36	271.00	285.84	297.46
Powerhouse											
Type											
Tailrace Tunnel											
Type											
Diameters	m	3.9	3.5	4.5	4.4	4.3	3.9	3.5	4.4	4.3	4.2
Length	m	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00
Channel Length	m	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00
Development Plan											
Maximum Discharge	m ³ /s	27.00	21.00	42.00	40.00	37.00	27.00	21.00	40.00	37.00	34.00
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00
Gross Head	m	210.62	212.40	197.33	200.87	203.63	207.97	209.80	193.93	197.47	200.23
Loss of Head	m	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00
Effective Head	m	201.63	203.40	188.33	191.87	194.62	198.97	200.80	184.93	188.47	191.23
Installed Capacity	MW	4.6	3.6	6.7	6.5	6.1	4.6	3.6	6.3	5.9	5.5

Table 9-10 Outline of Alternative Development Plan Concerning Reservoir Scale (4)

Description	M/P													
	MP-D50-5	MP-D25-5	MP-D100-6	MP-D75-6	MP-D50-8	MP-D25-6	MP-D75-7	MP-D50-7	MP-D25-7	MP-D50-8	MP-D25-8	MP-D50-9	MP-D25-9	
D														
Waterway Route														
Reservoir														
Catchment Area	Km ²	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00	1,994.00
Annual Inflow	m ³ /S	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39	14.39
High Water Level	m	429.40	429.40	423.90	423.90	423.90	417.80	417.80	417.80	417.80	410.90	410.90	410.90	402.60
Low Water Level	m	417.80	423.90	392.00	402.60	417.80	392.00	402.60	410.90	410.90	392.00	402.60	402.60	392.00
Available Drawdown	m	11.60	5.50	31.90	21.30	13.00	25.80	15.20	6.90	18.90	8.30	10.60	10.60	10.60
Gross Storage Capacity	10 ⁶ m ³	159	159	134	134	134	109	109	109	84	84	59	59	59
Effective Storage Capacity	10 ⁶ m ³	50	25	100	75	50	75	50	25	50	25	25	25	25
Dam														
Type	m	102	102	97	97	97	91	91	91	84	84	76	76	76
Height from Foundation	m	520	520	490	490	490	430	430	430	400	400	370	370	370
Crest Length	m	4,052	4,052	3,436	3,436	3,436	2,844	2,844	2,844	2,284	2,284	1,654	1,654	1,654
Volume	10 ⁶ m ³													
Headrace Tunnel														
Type	m	-	-	-	-	-	-	-	-	-	-	-	-	-
Diameters	m	-	-	-	-	-	-	-	-	-	-	-	-	-
Length	m	-	-	-	-	-	-	-	-	-	-	-	-	-
Penstock														
Type	m	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel	Embedded in Tunnel
Diameters	m	2.9	2.5	3.3	3.2	2.9	3.2	2.9	2.5	2.9	2.5	2.4	2.4	2.4
Length	m	307.12	315.66	271.00	285.84	297.46	271.00	285.84	297.46	271.00	284.84	271.00	271.00	271.00
Powerhouse														
Type		Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground	Underground
Tailrace Tunnel														
Type		Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure	Nonpressure
Diameters	m	3.9	3.5	4.3	4.2	3.9	4.2	3.9	3.5	3.9	3.5	3.5	3.5	3.5
Length	m	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00	4,899.00
Channel Length	m	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00	200.00
Development Plan														
Maximum Discharge	m ³ /S	27	21	37	34	27	34	27	21	27	21	21	21	21
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00
Gross Head	m	202.53	204.57	190.27	193.80	196.57	186.20	189.73	192.50	181.60	185.13	176.07	176.07	176.07
Loss of Head	m	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00
Effective Head	m	193.53	195.57	181.27	184.80	187.57	177.20	180.73	183.50	172.60	176.13	167.07	167.07	167.07
Installed Capacity	MW	44	35	57	53	43	51	41	33	39	31	30	30	30




Figure 9-12

Comparative Study on Development Alternative Concerning Reservoir Scale

Table 9-11 Comparative Study on Development Alternative Concerning Reservoir Scale (1)

Description	Name of Case	M/P									
		MP-D200-1	MP-D175-1	MP-D163-1	MP-D150-1	MP-D125-1	MP-D100-1	MP-D75-1	MP-D50-1	MP-D25-1	
M/P											
Alta-D											
Waterway Route											
High Water Level	m	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60	443.60
Low Water Level	m	392.00	402.60	406.80	410.90	417.80	423.90	429.40	434.90	439.20	443.60
Available Drawdown	m	51.60	41.00	36.80	32.70	25.80	19.70	14.20	9.10	4.40	4.40
Gross Storage Capacity	10 ⁶ m ³	234	234	234	234	234	234	234	234	234	234
Effective Storage Capacity	10 ⁶ m ³	200	175	163	150	125	100	75	50	25	25
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00
Effective Head	m	194.40	197.93	199.33	200.70	203.00	205.03	206.87	208.57	210.13	210.13
Maximum Discharge	m ³ /s	46	44	43	42	40	37	34	27	21	21
Installed Capacity	MW	76	74	73	72	69	65	60	48	37	37
Firm Peak Power	MW	68.6	69.6	69.1	68.1	65.4	61.5	57.4	47.0	37.3	37.3
Energy Production											
Average Energy	GWh	218.3	219.9	219.9	220.0	219.9	218.9	217.0	206.1	188.6	188.6
Firm Energy	GWh	166.3	162.4	158.5	156.3	151.5	141.2	130.3	104.8	82.9	82.9
Unit Benefit Value											
Firm Peak Power	T.L./KW	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506
Average Energy	T.L./KWh	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33
Benefit											
Firm Peak Power	10 ⁹ T.L.	153.3	155.5	154.4	152.2	146.1	137.4	128.3	105.0	83.4	83.4
Average Energy	10 ⁹ T.L.	39.8	40.1	40.1	40.1	40.1	40.0	39.6	37.6	34.4	34.4
Total	10 ⁹ T.L.	193.1	195.7	194.5	192.3	186.3	177.4	167.9	142.6	117.8	117.8
Investment Cost											
Civil Facilities	10 ⁹ T.L.	1,049.8	1,042.4	1,039.1	1,036.1	1,028.7	1,021.5	1,012.3	991.6	967.8	967.8
Hydro & Ele-Mech. Eq.	10 ⁹ T.L.	353.6	347.3	343.9	343.6	335.9	324.6	308.3	278.1	248.4	248.4
Total	10 ⁹ T.L.	1,043.4	1,389.7	1,383.1	1,379.6	1,364.6	1,346.1	1,320.7	1,269.7	1,216.1	1,216.1
Annual Cost											
Civil Facilities	10 ⁹ T.L.	106.0	105.3	105.0	104.6	103.9	103.2	102.2	100.2	97.7	97.7
Hydro & Ele-Mech. Eq.	10 ⁹ T.L.	40.3	39.6	39.2	39.2	38.3	37.0	35.1	31.7	28.3	28.3
Total	10 ⁹ T.L.	146.3	144.9	144.2	143.8	142.2	140.2	137.4	131.9	126.1	126.1
Annual Surplus Benefit (B-C)	10 ⁹ T.L.	46.8	50.8	50.4	48.5	44.1	37.2	30.5	10.8	-8.3	-8.3
Benefit Cost Ratio (B/C)		1.32	1.35	1.35	1.34	1.31	1.27	1.22	1.08	0.93	0.93
Unit Annual Cost	T.L./KWh	670	659	655	654	647	640	633	640	640	640

Table 9-11 Comparative Study on Development Alternative Concerning Reservoir Scale (2)

Description	Name of Case	MP-D175-2	MP-D163-2	MP-D150-2	MP-D125-2	MP-D100-2	MP-D75-2	MP-D50-2	MP-D25-2	MP-D163-3	
		M/P									
Waterway Route											
High Water Level	m	439.20	439.20	439.20	439.20	439.20	439.20	439.20	439.20	439.20	437.00
Low Water Level	m	392.00	397.40	402.60	410.90	417.80	423.90	429.40	434.50	439.00	392.00
Available Drawdown	m	47.20	41.80	36.60	28.30	21.40	15.30	9.80	4.70	4.70	45.00
Gross Storage Capacity	10 ⁶ m ³	209	209	209	209	209	209	209	209	209	197
Effective Storage Capacity	10 ⁶ m ³	175	163	150	125	100	75	50	25	25	162
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00
Effective Head	m	191.47	193.27	195.00	197.77	200.07	202.10	203.93	205.63	205.63	190.00
Maximum Discharge	m ³ /s	44	43	42	40	37	34	27	21	21	43
Installed Capacity	MW	72	71	70	67	63	58	47	37	37	70
Firm Peak Power	MW	67.2	66.9	65.9	63.4	59.7	55.9	45.9	36.5	36.5	66.0
Energy Production											
Average Energy	GWh	214.6	214.8	214.8	214.9	213.9	212.4	201.8	184.3	184.3	212.1
Firm Energy	GWh	156.2	154.1	151.8	147.2	136.9	127.8	102.6	80.8	80.8	151.8
Unit Benefit Value											
Firm Peak Power	T.L./KW	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506
Average Energy	T.L./KWH	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33
Benefit											
Firm Peak Power	10 ⁹ T.L.	150.2	149.5	147.3	141.7	133.4	124.9	102.6	81.6	81.6	147.5
Average Energy	10 ⁹ T.L.	39.2	39.2	39.2	39.2	39.0	38.8	36.8	33.6	33.6	38.7
Total	10 ⁹ T.L.	189.3	188.7	186.5	180.9	172.4	163.7	139.4	115.2	115.2	186.2
Investment Cost											
Civil Facilities	10 ⁹ T.L.	959.1	956.5	953.3	945.5	938.4	929.6	909.0	885.1	885.1	916.0
Hydro & Ele.-Mech. Eq.	10 ⁹ T.L.	328.4	329.6	329.6	334.0	322.8	307.4	279.8	250.7	250.7	334.3
Total	10 ⁹ T.L.	1,287.5	1,286.1	1,283.0	1,279.6	1,261.2	1,237.0	1,188.8	1,135.8	1,135.8	1,250.3
Annual Cost											
Civil Facilities	10 ⁹ T.L.	96.9	96.6	96.3	95.5	94.8	93.9	91.8	89.4	89.4	92.5
Hydro & Ele.-Mech. Eq.	10 ⁹ T.L.	38.6	38.7	38.7	38.1	36.8	35.0	31.9	28.6	28.6	38.1
Total	10 ⁹ T.L.	135.4	135.2	135.0	133.6	131.6	128.9	123.7	118.0	118.0	130.6
Annual Surplus Benefit (B-C)	10 ⁹ T.L.	53.9	53.4	51.5	47.3	40.9	34.7	15.7	-2.8	-2.8	55.6
Benefit Cost Ratio (B/C)		1.40	1.39	1.38	1.35	1.31	1.27	1.13	0.98	0.98	1.43
Unit Annual Cost	T.L./KWH	631	630	628	622	615	607	613	640	640	616

Table 9-11 Comparative Study on Development Alternative Concerning Reservoir Scale (3)

Description	Name of Case	M/P									
		MP-D150-3	MP-D125-3	MP-D100-3	MP-D75-3	MP-D50-3	MP-D25-3	MP-D150-4	MP-D125-4	MP-D100-4	
Waterway Route											
High Water Level	m	437.00	437.00	437.00	437.00	437.00	437.00	434.50	434.50	434.50	434.50
Low Water Level	m	398.00	407.20	414.60	421.10	426.90	432.20	392.00	402.60	410.90	410.90
Available Drawdown	m	39.00	29.80	22.40	15.90	10.10	4.80	42.50	31.90	23.60	23.60
Gross Storage Capacity	10 ⁶ m ³	197	197	197	197	197	197	184	184	184	184
Effective Storage Capacity	10 ⁶ m ³	150	125	100	75	50	25	150	125	100	100
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00
Effective Head	m	192.00	195.07	197.53	199.70	201.63	203.40	188.33	191.87	194.63	194.63
Maximum Discharge	m ³ /s	42	40	37	34	27	21	42	40	37	37
Installed Capacity	MW	69	66	62	58	46	36	67	65	61	61
Firm Peak Power	MW	64.8	62.4	58.8	55.1	45.3	36.0	63.5	61.2	57.8	57.8
Energy Production											
Average Energy	GWh	212.3	212.3	211.7	209.9	200.1	182.9	209.3	209.4	208.8	208.8
Firm Energy	GWh	149.6	145.0	136.4	125.7	102.3	80.4	147.3	142.7	134.2	134.2
Unit Benefit Value											
Firm Peak Power	T.L./KW	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506
Average Energy	T.L./KWh	184.83	184.33	184.93	184.93	184.33	184.33	184.33	184.33	184.33	184.33
Benefit											
Firm Peak Power	10 ⁹ T.L.	144.8	139.4	131.4	123.1	101.2	80.4	141.9	136.8	129.2	129.2
Average Energy	10 ⁹ T.L.	38.7	38.7	38.6	38.5	36.5	33.4	38.2	38.2	38.1	38.1
Total	10 ⁹ T.L.	183.5	178.2	170.0	161.4	137.8	113.8	180.1	175.0	167.3	167.3
Investment Cost											
Civil Facilities	10 ⁹ T.L.	912.9	905.7	899.0	889.6	869.1	845.5	883.3	875.8	869.5	869.5
Hydro & Ele.-Mech. Eq.	10 ⁹ T.L.	334.7	327.3	315.7	305.4	273.7	243.9	326.6	322.9	314.1	314.1
Total	10 ⁹ T.L.	1,247.6	1,233.0	1,214.7	1,195.0	1,142.7	1,089.4	1,210.0	1,198.7	1,183.5	1,183.5
Annual Cost											
Civil Facilities	10 ⁹ T.L.	92.2	91.5	90.8	89.8	87.8	85.4	89.2	88.5	87.8	87.8
Hydro & Ele.-Mech. Eq.	10 ⁹ T.L.	38.2	37.3	36.0	34.8	31.2	27.8	37.2	36.8	35.8	35.8
Total	10 ⁹ T.L.	130.4	128.8	126.8	124.7	119.0	113.2	126.5	125.3	123.6	123.6
Annual Surplus Benefit (B-C)	10 ⁹ T.L.	53.2	49.4	43.2	36.8	18.8	0.6	53.6	49.7	43.7	43.7
Benefit Cost Ratio (B/C)	T.L./KWh	1.41	1.38	1.34	1.29	1.16	1.01	1.42	1.40	1.35	1.35
Unit Annual Cost	T.L./KWh	614	607	599	594	594	619	604	598	592	592

Table 9-11 Comparative Study on Development Alternative Concerning Reservoir Scale (4)

Description	Name of Case	M/P											
		MP-D75-4	MP-D50-4	MP-D25-4	MP-D125-5	MP-D100-5	MP-D75-5	MP-D50-5	MP-D25-5	MP-D100-6			
M/P													
Alta-D													
Waterway Route													
High Water Level	m	434.50	434.50	434.50	429.40	429.40	429.40	429.40	429.40	429.40	429.40	429.40	423.90
Low Water Level	m	417.80	423.90	429.40	392.00	402.60	410.90	417.80	423.90	423.90	423.90	423.90	392.00
Available Drawdown	m	16.70	10.60	5.10	37.40	26.80	18.50	11.60	5.50	5.50	5.50	31.90	
Gross Storage Capacity	10 ⁶ m ³	184	184	184	159	159	159	159	159	159	159	134	
Effective Storage Capacity	10 ⁶ m ³	75	50	25	125	100	75	50	25	25	25	100	
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	
Effective Head	m	196.93	198.97	200.80	184.93	188.47	191.23	193.53	195.57	195.57	195.57	181.27	
Maximum Discharge	m ³ /s	34	27	21	40	37	34	27	21	21	21	37	
Installed Capacity	MW	57	46	36	63	59	55	44	35	35	35	57	
Firm Peak Power	MW	54.1	44.7	35.6	58.6	55.6	52.2	43.3	34.6	34.6	34.6	53.0	
Energy Production													
Average Energy	GWh	207.1	197.2	179.8	203.3	203.1	201.8	192.3	175.0	175.0	175.0	196.8	
Firm Energy	GWh	123.6	100.3	78.6	136.5	129.9	120.9	97.9	76.4	76.4	76.4	125.3	
Unit Benefit Value													
Firm Peak Power	T.L./KW	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	
Average Energy	T.L./KWh	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	
Benefit													
Firm Peak Power	10 ⁹ T.L.	120.9	99.9	79.6	130.9	124.2	116.6	96.8	77.3	77.3	77.3	118.4	
Average Energy	10 ⁹ T.L.	37.8	36.0	32.8	37.1	37.1	36.8	35.1	31.9	31.9	31.9	35.9	
Total	10 ⁹ T.L.	158.7	135.9	112.4	168.0	161.3	153.5	131.8	109.3	109.3	109.3	154.3	
Investment Cost													
Civil Facilities	10 ⁹ T.L.	860.0	839.8	816.4	818.8	811.6	803.3	782.8	759.8	759.8	759.8	749.2	
Hydro & Ele-Mech. Eq.	10 ⁹ T.L.	301.2	275.4	245.5	314.1	305.7	298.0	268.4	241.5	241.5	241.5	301.9	
Total	10 ⁹ T.L.	1,161.2	1,115.2	1,061.9	1,132.9	1,117.3	1,101.2	1,051.2	1,001.3	1,001.3	1,001.3	1,051.1	
Annual Cost													
Civil Facilities	10 ⁹ T.L.	86.9	84.8	82.5	82.7	82.0	81.1	79.1	76.7	76.7	76.7	75.7	
Hydro & Ele-Mech. Eq.	10 ⁹ T.L.	34.3	31.4	28.0	35.8	34.9	34.0	30.6	27.5	27.5	27.5	34.4	
Total	10 ⁹ T.L.	121.2	116.2	110.4	118.5	116.8	115.1	109.7	104.3	104.3	104.3	110.1	
Annual Surplus Benefit (B-C)	10 ⁹ T.L.	37.5	19.7	1.9	49.5	44.5	38.4	22.2	5.0	5.0	5.0	44.2	
Benefit Cost Ratio (B/C)		1.31	1.17	1.02	1.42	1.38	1.33	1.20	1.05	1.05	1.05	1.40	
Unit Annual Cost	T.L./KWh	585	589	614	583	575	570	570	596	596	596	560	

Table 9-11 Comparative Study on Development Alternative Concerning Reservoir Scale (5)

Description	Name of Case	M/P									
		MP-D75-6	MP-D50-6	MP-D25-6	MP-D75-7	MP-D50-7	MP-D25-7	MP-D50-8	MP-D25-8	MP-D25-9	
Alta-D											
Waterway Route											
High Water Level	m	423.90	423.90	423.90	417.80	417.80	417.80	410.90	410.90	410.90	402.60
Low Water Level	m	402.60	410.90	417.80	392.00	402.60	410.90	392.00	402.60	402.60	392.00
Available Drawdown	m	21.30	13.00	6.10	25.80	15.20	6.90	18.90	8.30	10.60	
Gross Storage Capacity	10 ⁶ m ³	134	134	134	109	109	109	84	84	59	
Effective Storage Capacity	10 ⁶ m ³	75	50	25	75	50	25	50	25	25	
Tail Water Level	m	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	223.00	
Effective Head	m	184.80	187.57	189.87	177.20	180.73	183.50	172.60	176.13	167.07	
Maximum Discharge	m ³ /s	34	27	21	34	27	21	27	21	21	
Installed Capacity	MW	53	43	34	51	41	33	39	31	30	
Firm Peak Power	MW	50.1	41.8	33.5	47.4	40.1	32.3	38.1	31.0	29.2	
Energy Production											
Average Energy	GWh	195.6	186.0	170.1	188.7	180.3	164.8	172.9	159.0	150.5	
Firm Energy	GWh	116.6	93.8	74.2	112.0	91.4	72.0	87.0	69.7	65.4	
Unit Benefit Value											
Firm Peak Power	T.L./KW	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	2,326,506	
Average Energy	T.L./KWh	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	184.33	
Benefit											
Firm Peak Power	10 ⁹ T.L.	112.0	93.4	74.9	105.9	89.6	72.2	85.1	69.3	65.3	
Average Energy	10 ⁹ T.L.	35.7	33.9	31.0	34.4	32.9	30.1	31.5	29.0	27.5	
Total	10 ⁹ T.L.	147.6	127.3	105.9	140.4	122.5	102.3	116.7	98.3	92.7	
Investment Cost											
Civil Facilities	10 ⁹ T.L.	740.8	721.1	697.8	680.5	660.7	638.0	602.1	579.3	509.9	
Hydro & Ele.-Mech. Eq.	10 ⁹ T.L.	289.1	263.6	238.5	287.2	256.4	233.2	251.6	226.9	223.1	
Total	10 ⁹ T.L.	1,029.9	984.6	936.3	967.6	917.0	871.3	854.0	806.2	733.0	
Annual Cost											
Civil Facilities	10 ⁹ T.L.	74.8	72.8	70.5	68.7	66.7	64.4	60.8	58.5	51.5	
Hydro & Ele.-Mech. Eq.	10 ⁹ T.L.	33.0	30.0	27.2	32.7	29.2	26.6	28.7	25.9	25.4	
Total	10 ⁹ T.L.	107.8	102.9	97.7	101.5	96.0	91.0	89.5	84.4	76.9	
Annual Surplus Benefit (B-C)	10 ⁹ T.L.	39.9	24.5	8.2	38.9	26.6	11.2	27.2	13.9	15.8	
Benefit Cost Ratio (B/C)		1.37	1.24	1.08	1.38	1.28	1.12	1.30	1.16	1.21	
Unit Annual Cost	T.L./KWh	551	553	574	538	532	552	518	531	511	

9.2.4 Power Station Scale

Factors determining the installed capacity of a hydroelectric power station are effective head and maximum available discharge as indicated in the equation below, while maximum available discharge is generally determined by firm discharge and equivalent peak duration hours.

$$\text{Installed Capacity (kW)} = 9.8 \times \text{Turbine-Generator Efficiency} \times \text{Effective Head (m)} \times \text{Maximum Discharge (m}^3/\text{s)}$$

$$\text{Maximum Available Discharge} = \frac{\text{Firm Discharge (m}^3/\text{s)} \times 24 \text{ hr}}{\text{Equivalent Peak Duration Hours (hr)}}$$

Of the abovementioned factors, effective head and firm discharge are determined by physical conditions such as effective storage capacity and intake and tail water levels, but equivalent peak duration hours are determined by conditions different from the above.

According to the electric power demand and supply plan, the situations of the electric power system in the year 2001 when the Köprübaşı Project is scheduled to be commissioned, and 2010, the last year of the demand and supply plan, will be as indicated in Table 9-12.

Table 9-12 Demand and Supply Balance

Year	2001	2010
Demand		
a. Peak Power (MW)	22,610	43,590
b. Annual Energy Consumption (GWh)	140,850	271,450
Supply		
c. Thermal (MW)	18,070	36,970
d. Hydro (MW)	13,841	23,086
e. Total (MW)	31,911	60,056
Annual Energy Production		
f. Thermal (GWh)	113,208	236,558
g. Hydro (Dependable) (GWh)	35,619	52,219
Supply Margin (e-a) (MW)	9,301	16,466
Supply Margin Rate ((e-a)/a) (%)	41	38
Equivalent Peak Duration Hours for Hydro (g/d)/365 (Hour)	7.1	6.2

According to the above table, the average equivalent peak duration times of all hydroelectric power generation in 2001 and 2010 will be 7.1 hours and 6.2 hours, but since these have been calculated with daily energy production of the maximum load day as the annual average electric energy, the actual peak duration times are thought to be somewhat longer than these. However, since the trend is for the proportion of hydroelectric power generation in the entire electric power system to decrease year by year, it is thought equivalent peak duration time will also be shortened year by year.

In the Köprübaşı Project, similarly to most other hydroelectric power generation projects, since storage capacity is large enough that roughly the entire quantity of inflow can be used for power generation, a large increase in electric energy production cannot be expected even when equivalent peak duration time is made shorter and installed capacity larger.

Therefore, for the equivalent peak duration time of the Köprübaşı Project, it is judged reasonable for about 6 hours, the average for all hydroelectric power generation, to be made the limit.

Examination of the optimum scale of installed capacity for the Köprübaşı Project was made by comparisons on setting up maximum available discharges for the cases of 8 hours, 10 hours, and 12 hours, with 6 hours the limit for equivalent peak duration times for dependable discharge of 10.75 m³/s.

The result of the comparison studies, as shown in Table 9-13 and Figure 9-13, is that equivalent peak duration time of 6 hours is optimum. Therefore, maximum available discharge of 43 m³/s and installed capacity of 70 MW will be the optimum scale.

Table 9-13 Optimization Study on Installed Capacity of Köprübaşı Project

Description	Unit	Case			
		A	B	C	D
Peak Hours	Hours	6	8	10	12
Maximum Discharge	m ³ /s	43	32	26	22
Installed Capacity	MW	70	53	42	35
Firm Peak Power	MW	66.0	49.3	39.4	32.9
Energy Production					
Average Energy	GWh	212.1	204.4	195.5	187.4
Firm Energy	GWh	151.8	151.8	151.8	151.8
Benefit (B)	10 ⁹ TL	186.2	147.7	123.7	107.7
Investment Cost	10 ⁹ TL	1,250.3	1,187.1	1,144.4	1,118.4
Annual Cost	10 ⁹ TL	130.6	123.6	118.8	115.9
Annual Surplus Benefit (B-C)	10 ⁹ TL	55.6	23.8	4.8	-8.3
Benefit Cost Ratio (B/C)		1.43	1.19	1.04	0.93
Unit Annual Cost	TL/KWh	616	605	608	619




Figure 9-13 Optimization Study on Installed Capacity

9.2.5 Optimum Development Plan

As a result of studies of development plan up to this point, the optimum development plan of Köprübaşı Project is to construct a 110 m high dam at the site of 3 km upstream from Köprübaşı village; provide 163×10^6 m³ of effective storage capacity with high water level of EL 437 m, take 43 m³/s of discharge by intake located at right bank of dam; discharge the water to underground powerhouse through embedded penstock in inclined shaft tunnel; generate maximum output of 70 MW by utilizing 190 m head; and after generation discharge water through tailrace tunnel to the Devrek River at the site of Dirgene village.

Table 9-14 shows the characteristics of the optimum development plan of the Köprübaşı Project. Table 9-15 shows the preliminary estimated construction cost of the Köprübaşı Project. Table 9-16 and Figure 9-14 shows the reservoir water level, inflow, discharge for power and spilled water quantity in the Köprübaşı Project according to the results of reservoir operation respectively. Table 9-17 and 9-18 shows the monthly energy production and firm energy production of the Köprübaşı Project respectively. Table 9-19 and 9-20 shows the monthly peak power and peak power durations of the Köprübaşı Project respectively. Figure 9-15 shows the monthly peak power, monthly energy production and firm energy production of the Köprübaşı Project.

Table 9-14 Outline of Optimum Development Plan of Köprübaşı Project

Description		Unit	
Reservoir			
	Catchment Area	Km ²	1,994.00
	Annual Inflow	m ³ /S	14.39
	High Water Level	m	437.00
	Low Water Level	m	392.00
	Available Drawdown	m	45.00
	Gross Storage Capacity	10 ⁶ m ³	197.70
	Effective Storage Capacity	10 ⁶ m ³	163.00
Dam			
	Type		
	Height from Foundation	m	110
	Crest Length	m	540
	Volume	10 ³ m ³	5,025
Penstock			
	Type		Embedded in Tunnel
	Diameter	m	3.40
	Length	m	271.00
Powerhouse			
	Type		Underground
Tailrace Tunnel			
	Type		Nonpressure
	Diameters	m	4.60
	Length	m	4,899.00
	Channel Length	m	200.00
Development Plan			
	Firm Discharge	m ³ /S	10.75
	Maximum Discharge	m ³ /S	43.00
	Tail Water Level	m	223.00
	Gross Head		
		Maximum	m 214.00
		Normal	m 199.00
		Minimum	m 169.00
	Loss of Head	m	9.00
	Effective Head		
		Maximum	m 205.00
		Normal	m 190.00
		Minimum	m 160.00
	Installed Capacity	MW	70
	Numbered of Unit		2
	Firm Peak Power	MW	66.0
	Annual Energy		
		Average	GWh 212.1
		Firm	GWh 151.8
		Secondary	GWh 60.3

Table 9-15 Preliminary Estimated Cost of Optimum Development Plan of Köprübaşı Project

Unit: 10⁹ T.L.

Item	
Civil Work	
Relocation Road	41.0
Clamp Facilities	10.0
Care of River	22.4
Dam	248.0
Spillway	44.9
Outlet works	2.7
Intake	3.9
Penstock	5.0
Powerhouse	48.8
Tailrace	100.6
Switchyard	3.4
Sub-total	479.7
Hydraulic Equipment	39.7
Electro-Mechanical Equipment	182.7
Transmission Line	43.1
Total Cost	878.1
Contingency	94.9
Engineering and Administration Cost	119.6
Land Aquisition	81.9
Interest during Construction	157.7
Grand Total	1,250.3





Figure 9-14 Köprübaşı Reservoir Operation





Figure 9-15 Energy Generation of Köprübaşı Project

Table 9-16 Summary of Operation Study on Köprübaşı Reservoir

Unit: 10⁶ m³

Month Year	INFLOW	POWER DISCHARGE	SPILL
1956	7046.87	7243.75	215.66
1957	3299.88	3923.75	0.0
1958	4835.30	4053.68	0.0
1959	5140.16	5043.31	165.26
1960	3923.84	3934.50	0.0
1961	3897.34	3951.31	0.0
1962	4032.06	4329.28	0.0
1963	5944.79	5494.05	0.0
1964	6364.23	6096.12	244.85
1965	7190.62	6499.91	678.22
1966	4701.27	4985.11	0.0
1967	4255.32	4189.19	0.0
1968	8596.53	7022.68	1336.61
1969	5254.86	5436.27	0.0
1970	4163.31	4243.24	0.0
1971	6657.41	6287.70	71.10
1972	6305.09	6041.63	0.0
1973	5840.28	6215.66	0.0
1974	5114.35	5095.25	0.0
1975	5092.13	4997.85	49.95
1976	4557.29	4757.34	0.0
1977	3217.48	3923.75	0.0
1978	4463.89	3862.56	0.0
1979	4839.81	4542.57	0.0
1980	6252.20	6337.12	119.01
1981	6648.61	6153.53	356.54
1982	6175.92	6040.04	0.0
1983	5397.45	5201.44	0.0
1984	5935.53	6261.87	0.0
1985	4939.58	5108.03	0.0
1986	5183.22	5235.25	0.0
1987	5232.98	5111.34	0.0
1988	4327.08	4275.23	0.0
1989	4421.25	4691.40	0.0
1990	4456.94	4322.88	0.0
1991	5395.14	4966.24	0.0
TOTAL	189110.03	185874.84	3235.19

Table 9-17 Total Energy Generation of Köprübaşı Project

Month Year	Unit: GWh												
	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1956	13796	13266	13849	26687	48039	51470	50402	31556	15353	14043	13773	13030	305260
1957	13148	12479	12716	12574	11490	13105	12859	13416	13083	13276	12894	12113	153134
1958	12113	11268	11266	11065	10154	12116	12828	13911	19123	14110	13937	13228	155119
1959	13365	12666	12804	12592	11356	13330	50402	28525	16115	14091	13890	13153	206211
1960	13279	12558	12678	12477	11890	13234	13329	14083	13683	14053	13839	13134	158236
1961	13263	12522	12686	12513	11391	13199	14559	14178	13650	14024	13834	13074	158891
1962	13160	12427	12649	12525	11352	13342	30271	14571	13597	13790	13452	12659	173796
1963	12729	11971	12218	12568	11934	18901	30489	43782	26837	14106	13933	13243	224711
1964	13456	12830	13382	13569	13460	52082	35306	34161	25465	14098	13915	13250	254974
1965	13470	12842	13410	13717	13635	52082	50402	48485	15136	14151	14021	13308	272660
1966	13458	12765	13132	13395	12350	17039	44465	23342	13675	13973	13679	12934	206207
1967	13020	12281	12346	12049	10671	12215	12840	23383	15471	14051	13781	13028	165137
1968	13144	12439	13012	13725	48722	52082	50402	31605	17221	14060	13856	13250	293516
1969	13552	12928	13226	13231	12202	22151	47351	36422	13698	14069	13839	13104	225770
1970	13218	12485	12674	12518	11492	13305	17332	20883	16577	14030	13749	12998	171260
1971	13104	12373	12574	12824	11958	16409	50402	50507	38340	14128	14004	13351	259974
1972	13568	12896	13285	13462	12622	34346	40537	28272	33089	22746	14128	13612	252763
1973	18105	22761	15279	15898	31221	41220	36290	23769	17373	14107	13945	13245	263212
1974	13401	12827	13359	13395	12184	15201	28930	43836	17230	14077	13896	13236	211573
1975	13418	12705	12888	12702	11423	13012	13101	52082	20603	14093	13955	13309	203290
1976	13510	12952	13361	13578	12821	19617	38733	18366	13696	14022	13759	13051	197366
1977	13199	12491	12759	12674	11397	12919	12926	13527	13028	13218	12847	12040	153025
1978	12013	11192	9534	10974	10463	12314	12683	13822	13486	13820	13639	12911	146850
1979	13036	12336	12544	12783	12179	13933	15498	21443	30808	14146	14013	13307	186025
1980	13492	12858	13311	13586	13024	51292	50402	40247	15672	14030	13765	13040	264719
1981	13187	12581	13223	13769	25173	52082	34112	36152	15579	14112	13938	13225	257132
1982	13379	12709	13269	13788	18681	40743	49228	27264	20259	14081	13949	13355	252905
1983	13590	12913	13079	12897	11860	23983	43782	19880	16513	18749	14777	13605	215608
1984	13993	13516	22487	20731	22264	29904	48388	36786	15510	14074	13898	13227	264678
1985	13378	12704	12943	12840	11788	19830	47006	24875	13691	14034	13772	13020	209880
1986	13150	12467	12790	13347	28940	37032	22230	23769	13892	14024	13726	12958	216345
1987	13023	12289	12435	12541	11740	13513	36379	36118	18995	14077	13863	13122	208096
1988	13240	12583	12921	12983	12175	13323	15241	17860	22628	14122	13945	13193	174192
1989	13320	12802	13437	13580	12453	42786	17407	14130	13620	13914	13617	12838	193903
1990	12957	12461	13172	13425	12157	13590	13445	31036	13660	13974	13728	13001	176605
1991	13159	12542	12839	12732	11680	13476	13434	15117	38979	32111	14088	13498	203655
TOTAL	481311	462567	473536	491911	566443	900180	1113389	975155	667309	535586	497643	471650	7636671
AVERAGE	13370	12849	13154	13664	15735	25005	30927	27088	18536	14877	13823	13101	212130
MAXIMUM	18105	22761	22487	26687	48722	52082	50402	52082	38979	32111	14777	13612	305260
MINIMUM	12013	11192	9534	10974	10154	12116	12683	13416	13028	13218	12847	12040	146850

Table 9-18 Firm Energy Generation of Köprübaşı Project

Month Year	Unit: GWh												
	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1956	13020.	12600.	13020.	13020.	12180.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153720.
1957	13020.	12418.	12572.	12365.	11361.	13020.	12600.	13020.	12600.	13020.	12831.	11887.	150714.
1958	11704.	10688.	10521.	10246.	9473.	11709.	12600.	13020.	12600.	13020.	13020.	12600.	141202.
1959	13020.	12600.	12699.	12392.	11025.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	151616.
1960	13020.	12534.	12516.	12226.	11752.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	151928.
1961	13020.	12481.	12528.	12279.	11218.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	151404.
1962	13020.	12342.	12474.	12295.	11162.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	151172.
1963	12590.	11683.	11855.	12358.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	150124.
1964	13020.	12600.	13020.	13020.	12180.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153720.
1965	13020.	12600.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153300.
1966	13020.	12600.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153300.
1967	13020.	12130.	12037.	11619.	10191.	11851.	12600.	13020.	12600.	13020.	13020.	12600.	147703.
1968	13020.	12360.	13003.	13020.	12180.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153463.
1969	13020.	12600.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153300.
1970	13020.	12428.	12510.	12284.	11365.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	151486.
1971	13020.	12264.	12366.	12728.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	152018.
1972	13020.	12600.	13020.	13020.	12180.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153720.
1973	13020.	12600.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153300.
1974	13020.	12600.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153300.
1975	13020.	12600.	12822.	12551.	11264.	13004.	12600.	13020.	12600.	13020.	13020.	12600.	152120.
1976	13020.	12600.	13020.	13020.	12180.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153720.
1977	13020.	12436.	12633.	12510.	11227.	12868.	12600.	13020.	12600.	13020.	12762.	11782.	150476.
1978	11563.	10582.	9534.	10122.	9901.	11991.	12600.	13020.	12600.	13020.	13020.	12600.	140553.
1979	13020.	12210.	12322.	12670.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	151861.
1980	13020.	12600.	13020.	13020.	12180.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153720.
1981	13020.	12567.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153267.
1982	13020.	12600.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153300.
1983	13020.	12600.	13020.	12835.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153114.
1984	13020.	12600.	13020.	13020.	12180.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153720.
1985	13020.	12600.	12903.	12751.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	152913.
1986	13020.	12401.	12678.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	152758.
1987	13020.	12141.	12166.	12319.	11726.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	151251.
1988	13020.	12540.	12871.	12960.	12168.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153438.
1989	13020.	12600.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153300.
1990	12923.	12392.	13020.	13020.	11760.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	152994.
1991	13020.	12509.	12750.	12594.	11638.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	152391.
TOTAL	465418.	445305.	454078.	453435.	417128.	465041.	453598.	468718.	453598.	468718.	468271.	452067.	5465363.
AVERAGE	12928.	12370.	12613.	12595.	11567.	12918.	12600.	13020.	12600.	13020.	13008.	12557.	151816.
MAXIMUM	13020.	12600.	13020.	13020.	12180.	13020.	12600.	13020.	12600.	13020.	13020.	12600.	153720.
MINIMUM	11563.	10582.	9534.	10122.	9473.	11709.	12600.	13020.	12600.	13020.	12762.	11782.	140553.

Table 9-19 Monthly Peak Power of Köprübaşı Project

Month Year	Unit: MW												
	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1956	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1957	70.0	69.0	67.6	66.5	67.6	70.0	70.0	70.0	70.0	70.0	70.0	70.0	825.7
1958	62.9	59.4	56.6	55.1	56.4	65.0	70.0	70.0	70.0	70.0	70.0	70.0	773.3
1959	70.0	70.0	68.3	66.6	65.6	70.0	70.0	70.0	70.0	70.0	70.0	70.0	830.5
1960	70.0	69.6	67.3	65.7	67.5	70.0	70.0	70.0	70.0	70.0	70.0	70.0	830.2
1961	70.0	69.3	67.4	66.0	66.8	70.0	70.0	70.0	70.0	70.0	70.0	70.0	829.5
1962	70.0	68.6	67.1	66.1	66.4	70.0	70.0	70.0	70.0	70.0	70.0	70.0	828.2
1963	67.7	64.9	63.7	66.4	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	822.8
1964	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1965	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1966	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1967	70.0	67.4	64.7	62.4	60.7	63.7	70.0	70.0	70.0	70.0	70.0	70.0	808.9
1968	70.0	68.7	69.9	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	839.6
1969	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1970	70.0	69.0	67.3	66.0	67.6	70.0	70.0	70.0	70.0	70.0	70.0	70.0	830.0
1971	70.0	68.1	66.5	68.4	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	833.0
1972	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1973	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1974	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1975	70.0	70.0	68.9	67.5	67.0	69.9	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1976	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1977	70.0	69.1	67.9	67.3	66.8	69.2	70.0	70.0	70.0	70.0	70.0	70.0	833.4
1978	62.2	58.8	51.3	54.4	58.9	64.5	70.0	70.0	70.0	70.0	68.6	65.5	824.3
1979	70.0	67.8	66.2	68.1	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	770.0
1980	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	832.2
1981	70.0	69.8	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1982	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	839.8
1983	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1984	70.0	70.0	70.0	69.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	839.0
1985	70.0	70.0	69.4	68.6	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1986	70.0	68.9	68.2	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	837.9
1987	70.0	67.5	65.4	66.2	69.8	70.0	70.0	70.0	70.0	70.0	70.0	70.0	837.1
1988	70.0	69.7	69.2	69.7	69.9	70.0	70.0	70.0	70.0	70.0	70.0	70.0	828.9
1989	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	838.5
1990	69.5	68.8	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
1991	70.0	69.5	68.5	67.7	69.3	70.0	70.0	70.0	70.0	70.0	70.0	70.0	838.3
1991	70.0	69.5	68.5	67.7	69.3	70.0	70.0	70.0	70.0	70.0	70.0	70.0	835.0
TOTAL	2502.2	2473.9	2441.3	2437.8	2460.5	2500.2	2520.0	2520.0	2520.0	2520.0	2517.6	2511.5	29925.0
AVERAGE	69.5	68.7	67.8	67.7	68.3	69.5	70.0	70.0	70.0	70.0	69.9	69.8	831.2
MAXIMUM	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	840.0
MINIMUM	62.2	58.8	51.3	54.4	56.4	63.0	70.0	70.0	70.0	70.0	68.6	65.5	770.0

Table 9-20 Peak Power Duration of Köprübaşı Project

PEAK POWER DURATION OF KÖPRUBAŞI PROJECT (SS10 - 9109)
 90% --- 67.5(7404)
 95% --- 65.7(5904)

Unit: MW

NO.	DATE	P	NO.	DATE	P	NO.	DATE	P	NO.	DATE	P	NO.	DATE	P	NO.	DATE	P	NO.	DATE	P	NO.	DATE	P
1	5801	70.0	51	6011	70.0	151	7208	70.0	201	7904	70.0	251	8406	70.0	301	9009	70.0	351	8002	401	7003	66.5	
2	6206	70.0	52	6012	70.0	152	7209	70.0	202	7906	70.0	252	8407	70.0	302	9010	70.0	352	8003	402	5004	66.5	
3	6401	70.0	53	6101	70.0	153	7312	70.0	203	7907	70.0	253	8408	70.0	303	9011	70.0	353	8004	403	5105	66.4	
4	6601	70.0	54	6102	70.0	154	7313	70.0	204	7908	70.0	254	8409	70.0	304	9012	70.0	354	8005	404	6204	66.4	
5	6804	70.0	55	6103	70.0	155	7302	70.0	205	7809	70.0	255	8410	70.0	305	9001	70.0	355	8006	405	7303	66.2	
6	7211	70.0	56	6104	70.0	156	7304	70.0	206	7910	70.0	256	8411	70.0	306	9002	70.0	356	8007	406	8004	66.2	
7	7401	70.0	57	6105	70.0	157	7305	70.0	207	7911	70.0	257	8412	70.0	307	9003	70.0	357	8008	407	6104	66.1	
8	8311	70.0	58	6205	70.0	158	7306	70.0	208	7912	70.0	258	8501	70.0	308	9004	70.0	358	8009	408	6904	66.0	
9	8504	70.0	59	6206	70.0	159	7307	70.0	209	8001	70.0	259	8502	70.0	309	9005	70.0	359	8010	409	5612	66.0	
10	8601	70.0	60	6207	70.0	160	7308	70.0	210	8002	70.0	260	8503	70.0	310	9006	70.0	360	8011	410	6004	65.7	
11	8811	70.0	61	6208	70.0	161	7309	70.0	211	8003	70.0	261	8504	70.0	311	9007	70.0	361	8012	411	5904	65.7	
12	5502	70.0	62	6210	70.0	162	7310	70.0	212	8004	70.0	262	8505	70.0	312	9008	70.0	362	8013	412	5805	65.6	
13	5503	70.0	63	6212	70.0	163	7311	70.0	213	8005	70.0	263	8506	70.0	313	9009	70.0	363	8014	413	7612	65.5	
14	5505	70.0	64	6301	70.0	164	7312	70.0	214	8006	70.0	264	8510	70.0	314	9010	70.0	364	8015	414	8003	65.4	
15	5506	70.0	65	6302	70.0	165	7302	70.0	215	8009	70.0	265	8511	70.0	315	9001	70.0	365	8016	415	4202	66.9	
16	5507	70.0	66	6303	70.0	166	7309	70.0	216	8010	70.0	266	8512	70.0	316	9002	70.0	366	8017	416	6603	66.7	
17	5508	70.0	67	6304	70.0	167	7310	70.0	217	8011	70.0	267	8606	70.0	317	9003	70.0	367	8018	417	7706	66.5	
18	5509	70.0	68	6305	70.0	168	7311	70.0	218	8012	70.0	268	8607	70.0	318	9004	70.0	368	8019	418	6203	65.7	
19	5510	70.0	69	6306	70.0	169	7312	70.0	219	8101	70.0	269	8608	70.0	319	9005	70.0	369	8020	419	6606	65.7	
20	5511	70.0	70	6308	70.0	170	7301	70.0	220	8102	70.0	270	8609	70.0	320	9006	70.0	370	8021	420	5706	63.0	
21	5512	70.0	71	6309	70.0	171	7303	70.0	221	8103	70.0	271	8610	70.0	321	9007	70.0	371	8022	421	5701	62.9	
22	5601	70.0	72	6311	70.0	172	7304	70.0	222	8104	70.0	272	8701	70.0	322	9008	70.0	372	8023	422	6604	62.4	
23	5605	70.0	73	6312	70.0	173	7305	70.0	223	8105	70.0	273	8702	70.0	323	9009	70.0	373	8024	423	7701	62.2	
24	5607	70.0	74	6402	70.0	174	7306	70.0	224	8106	70.0	274	8703	70.0	324	9010	70.0	374	8025	424	6605	60.7	
25	5608	70.0	75	6403	70.0	175	7307	70.0	225	8107	70.0	275	8704	70.0	325	9001	70.0	375	8026	425	5702	59.4	
26	5609	70.0	76	6404	70.0	176	7308	70.0	226	8108	70.0	276	8710	70.0	326	9002	70.0	376	8027	426	6205	58.9	
27	5707	70.0	77	6405	70.0	177	7309	70.0	227	8109	70.0	277	8711	70.0	327	9003	70.0	377	8028	427	7702	58.8	
28	5708	70.0	78	6406	70.0	178	7310	70.0	228	8110	70.0	278	8712	70.0	328	9004	70.0	378	8029	428	5703	56.6	
29	5709	70.0	79	6407	70.0	179	7311	70.0	229	8112	70.0	279	8801	70.0	329	9005	70.0	379	8030	429	5704	55.4	
30	5710	70.0	80	6408	70.0	180	7312	70.0	230	8203	70.0	280	8802	70.0	330	9006	70.0	380	8031	430	5704	54.4	
31	5711	70.0	81	6409	70.0	181	7601	70.0	231	8204	70.0	281	8803	70.0	331	9007	70.0	381	8032	431	7704	54.4	
32	5712	70.0	82	6410	70.0	182	7602	70.0	232	8207	70.0	282	8804	70.0	332	9008	70.0	382	8033	432	7703	51.3	
33	5807	70.0	83	6411	70.0	183	7608	70.0	233	8208	70.0	283	8805	70.0	333	9009	70.0	383	8034	433	9004	67.7	
34	5808	70.0	84	6412	70.0	184	7609	70.0	234	8209	70.0	284	8806	70.0	334	9010	70.0	384	8035	434	6201	67.7	
35	5809	70.0	85	6501	70.0	185	7610	70.0	235	8210	70.0	285	8807	70.0	335	9001	70.0	385	8036	435	6905	67.6	
36	5810	70.0	86	6502	70.0	186	7707	70.0	236	8211	70.0	286	8808	70.0	336	9002	70.0	386	8037	436	5605	67.6	
37	5811	70.0	87	6503	70.0	187	7708	70.0	237	8212	70.0	287	8810	70.0	337	9003	70.0	387	8038	437	5603	67.6	
38	5812	70.0	88	6504	70.0	188	7709	70.0	238	8301	70.0	288	8812	70.0	338	9004	70.0	388	8039	438	5905	67.5	
39	5901	70.0	89	6506	70.0	189	7710	70.0	239	8302	70.0	289	8813	70.0	339	9005	70.0	389	8040	439	7404	67.5	
40	5904	70.0	90	6507	70.0	190	7712	70.0	240	8304	70.0	290	8904	70.0	340	9006	70.0	390	8041	440	8602	67.5	
41	5907	70.0	91	6508	70.0	191	7801	70.0	241	8305	70.0	291	8905	70.0	341	9007	70.0	391	8042	441	6602	67.4	
42	5908	70.0	92	6509	70.0	192	7805	70.0	242	8306	70.0	292	8907	70.0	342	9008	70.0	392	8043	442	6003	67.4	
43	5909	70.0	93	6510	70.0	193	7807	70.0	243	8307	70.0	293	8908	70.0	343	9009	70.0	393	8044	443	5903	67.3	
44	5910	70.0	94	6511	70.0	194	7808	70.0	244	8308	70.0	294	8909	70.0	344	9010	70.0	394	8045	444	6902	67.3	
45	5911	70.0	95	6512	70.0	195	7809	70.0	245	8309	70.0	295	8911	70.0	345	9001	70.0	395	8046	445	7604	67.3	
46	6001	70.0	96	6607	70.0	196	7810	70.0	246	8310	70.0	296	8912	70.0	346	9002	70.0	396	8047	446	6103	67.1	
47	6006	70.0	97	6608	70.0	197	7811	70.0	247	8312	70.0	297	8913	70.0	347	9003	70.0	397	8048	447	7405	67.0	
48	6007	70.0	98	6609	70.0	198	7812	70.0	248	8401	70.0	298	8914	70.0	348	9004	70.0	398	8049	448	7605	66.8	
49	6008	70.0	99	6611	70.0	199	7902	70.0	249	8402	70.0	299	9006	70.0	349	9005	70.0	399	8050	449	6608	66.8	
50	6010	70.0	100	6612	70.0	200	7903	70.0	250	8405	70.0	300	9008	70.0	350	9006	70.0	400	8051	450	5804	66.6	

9.3 Downstream Çay Project

The Çay Project is planned on the Devrek River in the Master Plan as a development project downstream of the Köprübaşı Project.

A review was made of the Çay Project proposed in the Master Plan in connection with the development plan of the Köprübaşı Project just decided in 9.2. Results of the review are described below.

9.3.1 Reservoir Scale

(1) Reservoir High Water Level

In the Master Plan, the reservoir high water level of the Çay Project is given as EL 219 m and the end of the tailrace of the Köprübaşı Project is located inside the Çay Project reservoir approximately 1.5 km downstream of the planned end of the Çay Project reservoir backwater.

However, according to the 1/1,000 topographical map prepared newly by the DSI in 1993 and used for the present study, the river bed elevation of the Devrek River at the end of the Köprübaşı Project tailrace is EL 221 m, while the tailrace water level at that point will be at EL 223 m, and when the reservoir high water level of the Çay Project is made EL 219 m as in the Master Plan, the location of the backwater end will be approximately 0.6 km downstream of the tailrace end. As a result, there would be an idle head of 4 m between the Köprübaşı Project and the Çay Project.

As stated in 9.2, it will not be economical for the location of the Köprübaşı Project tailrace end site to be moved downstream from the present location, and to utilize this idle head for power generation, it will be necessary for the reservoir high water level in the Çay Project to be raised 4 m above the EL 219 m proposed in the Master Plan to make it EL 223 m.

For the dam site of the Çay Project, unlike that of the Köprübaşı Project, there are no topographical or geological restrictions to be seen in particular about raising the high water level above EL 219 m, and it is judged there is a good possibility that it will be feasible for the high water level to be raised to EL 223 m.

Accordingly, it will be appropriate for an examination to be made concerning this point in the feasibility study of the Çay Project.

(2) Effective Storage Capacity

In the Master Plan the available drawdown of the reservoir in the Çay Project is put as 39 m for an effective storage capacity of $144 \times 10^6 \text{ m}^3$. In the upstream Köprübaşı Project, approximately 99% of the inflow is utilized for power generation through regulation of runoff by the Köprübaşı reservoir, while the annual inflow to the Çay Project from the remaining catchment area between the Köprübaşı Project and the Çay Project will be $129 \times 10^6 \text{ m}^3$, which is 28% of the inflow for the Köprübaşı Project. Hence, if there were to be an effective storage capacity of about $46 \times 10^6 \text{ m}^3$ for the Çay Project, it would be possible for inflow from the remaining catchment area to be regulated for power generation as to be done in the Köprübaşı Project.

When the reservoir high water level of the Çay Project is made EL 223 m, if there were to be an available depth of 8 m, an effective storage capacity of $46 \times 10^6 \text{ m}^3$ would be secured. It will become possible for operation at a higher water level than in the scheme proposed in the Master Plan, and output and energy production will be increased.

Therefore, optimization of the effective storage capacity of the Çay Project will be necessary upon considering the

runoff regulating effect of the Köprübaşı Project in the feasibility study of the Çay Project.

9.3.2 Power Station Scale

The Çay Project would be the downstreammost power generation project on the Devrek River and there is no reservoir plan downstream of the Çay Project even to the mouth of the mainstream Filyos River after merging of the Devrek River with the Filyos River. In the Master Plan the maximum available discharge of the Çay Project is given as $46 \text{ m}^3/\text{s}$, approximately 10% more than the Köprübaşı Project, with the plan being for the Çay Project to be used as a peaking power station.

However, the river channel length from the powerhouse site of the Çay Project to the confluence with the Filyos River is 40 km, and that from the confluence to the mouth of the Filyos River is 50 km. Although there is no necessity for consideration regarding this point at the present time, since there is no facility for water utilization on the downstream stretch, it will be necessary for thorough consideration to be given to fluctuation in the downstream river water level due to power generation operation.

With the Çay Project, if equalizing operation were to be done similarly to the Suat Uğurlu Project and the Derbent Project which are downstreammost power generation projects on other rivers, and if the equivalent peak duration time were to be made about 12 hours, the maximum available discharge would be $28 \text{ m}^3/\text{s}$, and in this case also about 89% of the reservoir inflow can be utilized for power generation.

Therefore, it will be appropriate for examinations to be made concerning equalizing operation in the feasibility study of the Çay Project.

9.3.3 Alternative Development Plan for Çay Project

As a result of above mentioned the review high water, it is considered that the development plan indicated in Table 9-21 would serve as a basic alternative development plan in the feasibility study of the Çay Project.

In this case incremental annual average energy production, annual firm energy production and firm peak power by the Köprübaşı Project at the Çay Project are 12 GWh, 28 GWh and 6.6 MW respectively.

Table 9-21 Alternative Development Plan of Çay Project

Item	Unit	Description
Catchment Area	km ²	2,422
Annual Inflow	10 ⁶ m ³	582.54
High Water Level	m	223.00
Normal Water Level	m	219.00
Low Water Level	m	215.00 (188.00)
Total Storage Capacity	10 ⁶ m ³	185
Effective Storage Capacity	10 ⁶ m ³	46 (145)
Tail Water Level	m	125.00
Effective Head	m	90.50 (82.80)
Maximum Discharge	m ³ /s	28 (25)
Installed Capacity	MW	22 (18)
Firm Peak Power	MW	21.4 (14.8)
Annual Energy Projection	GWh	116 (104)
Firm Energy Projection	GWh	94 (66)

Note: Figures in the () are the figures in case of without Köprübaşı Project

In the above alternative plan, since the output is held low considering equalizing operation, when evaluation is done by the benefit cost method, it is judged that the economics of the Çay Project by itself is that it will be barely feasible. But when

an evaluation is made combined with the Köprübaşı Project, it would be amply economical, and the judgment is that it is a project which should be developed at an early time in succession to the Köprübaşı Project from the standpoint of operation of the Köprübaşı Project.

Chapter 10 TRANSMISSION LINE AND POWER SYSTEM ANALYSIS

Chapter 10

TRANSMISSION LINE AND POWER SYSTEM ANALYSIS

Contents

	<u>Page</u>
10.1 Summary of Power System	10 - 1
10.2 Transmission Line for Köprübaşı Power Station .	10 - 1
10.2.1 Route Survey	10 - 1
10.2.2 Transmission Line	10 - 3
10.3 Power System Analysis	10 - 4
10.3.1 Conditions of System Calculation	10 - 4
10.3.2 Results of System Calculation	10 - 6

List of Figures

- Figure 10-1 154 kV Transmission Line in Köprübaşı Project
- Figure 10-2 Impedance Map in 2001
- Figure 10-3 Power Flow Diagram in 2001 (Köprübaşı: Operation)
- Figure 10-4 Power Flow Diagram in 2001 (Köprübaşı: Stoppage)
- Figure 10-5 Dynamic Stability Swing Curve
- Figure 10-6 Dynamic Stability Swing Curve
- Figure 10-7 Bus Voltage Fluctuation Curve
- Figure 10-8 Bus Voltage Fluctuation Curve
- Figure 10-9 Short Circuit Current

List of Table

- Table 10-1 Summary of Transmission Lines

Chapter 10 TRANSMISSION LINE AND POWER SYSTEM ANALYSIS

10.1 Summary of Power System

The transmission system in Turkey comprises 380 kV of primary system and 154 kV of secondary system. In addition, 66 kV and 34.5 kV form the lower voltage systems. The total distance of transmission lines at the end of 1992 is 9,500 km for 380 kV and 22,000 km for 154 kV. Since Turkey has the borders on the east and west, its power systems are linked with those of the adjacent foreign countries thus allowing the power interchange.

The voltage of linked transmission lines widely differs among the countries such as 400 kV, 200 kV, 154 kV, etc. depending upon the adopted system voltage of these countries. Presently, this international linkage of power systems tends to be extended more and more and thus a number of projects are under planning now.

10.2 Transmission Line for Köprübaşı Power Station

10.2.1 Route Survey

The route survey for the planned transmission line was conducted as to the following two routes based on the master plan prepared by DSI and the long-term plan by TEK. During the local site survey that was conducted using the topographic maps, the condition of main roads and those of roads located in mountainous areas, as well as actual state of the transmission line routes were fully investigated.

- Master plan route by DSI:

Köprübaşı - Bolu (Existing 154 kV substation)

Distance: 40 km

- Planned route by TEK:

Köprübaşı - Devrek (Planned substation)

Distance: 30 km

As a result of the survey, it was found that there are no technical restrictions which may obstruct construction of these two routes and thus it is possible to implement the plan for these two routes. However, after further discussion with TEK, it was notified that the power should be sent to Ereğli and Karabük substations from the Köprübaşı power station in order to cater for the nearby power demand first.

Accordingly, the following two additional routes are further reviewed:

Köprübaşı - Karabük (Existing 154 kV substation)

Distance: 80 km

Köprübaşı - Ereğli (Existing 154 kV substation)

Distance: 50 km

Since these routes were already surveyed by TEK for itself, and moreover in consideration of the geographical features of these routes, it must be possible to construct the transmission lines these routes. Nonetheless, as a result of the review performed by our survey team, it is still conceivable that the construction costs might be rising if these direct routes from Köprübaşı to Karabük and Ereğli are chosen.

For that reason, the transmission line routes shown in the transmission plan prepared by TEK and the master plan by DSI which have fully taken into account the location of the Çay power station should be considered in the study of the route.

As for the design, it is most suitable to extend the two-circuit outgoing transmission lines with two-circuit steel towers from the Köprübaşı power station to the Çıplak district which closes to the Çay power station, where these lines are separated into two independent lines with one-circuit steel towers to reach Karabük and Ereğli substations respectively.

10.2.2 Transmission Line Plan

(1) Lead-in substation

It is presumed that power demand (in 2001 or so) for 154 kV system near the Köprübaşı power station is 540 MW and thus the generated power from this station is consumed by the near 154 kV system. In view of the demand distribution, it may be concluded that the 154 kV transmission lines from the Köprübaşı power station should be lead in to Karabük and Ereğli substations (See Figure 10-1).

(2) Summary of transmission line facilities

Table 10-1 shows the summary of transmission line facilities.

Table 10-1 Summary of Transmission Lines

Section	Voltage (kV)	Conductor size (MCM)	Length (km)	No. of circuit (cct)
Köprübaşı-Karabük	154	ACSR1272	80	1
Köprübaşı-Ereğli	154	ACSR1272	50	1

a) Transmission line voltage

The transmission line voltage is taken for 154 kV in order to match the bus voltage of lead-in substations.

b) Conductor size

Conductor size is taken for ACSR127MCM out of the standard sizes currently used by TEK.

c) Number of circuits and routes

The number of circuits is taken for one. The number of transmission line routes is taken for two though one route is still acceptable due to the output of the Köprübaşı power station itself and its percentage to the integrated power system are very small. This is because to enhance the system reliability by constructing it in a loop form and moreover is in consideration of the future plan for the Çay power station.

10.3 Power System Analysis

10.3.1 Conditions for System Calculation

(1) Purpose of calculation and contents

A power system analysis was conducted to verify the characteristics of the power system near the Köprübaşı power station.

The contents of the calculation are as follows:

- Power flow calculation
- Stability calculation
- Short-circuit current calculation

(2) Target year of calculation and range of simulation

The target year of calculation is presumed to be around 2001 when the operation of the Köprübaşı power station is commissioned. The peak power demand at that time for the integrated power system is estimated to be 22,610 MW.

Since the planned output of 70 MW of the Köprübaşı power station is consumed in the nearby 154 kV system, the range

of calculation is only limited to the 154 kV system. In addition, the 380 kV system from far side of the Osmanca substation was simplified as one-generator system because the nearby 154 kV system is connected to 380 kV system at Osmanca substation.

To simplify as the one-generator system as mentioned above, the short-circuit current flow from the integrated 380 kV system into 380 kV bus of the Osmanca substation is taken for 15 kA (equivalent to 9,870 MVA of short-circuit capacity). Figure 10-2 shows the range of the system and the line impedance used for the calculation.


(3) Power flow calculation

Power flow and voltage calculation was conducted by presuming the operational conditions of the power system as follows:

System voltage being maintained:	95 to 105%
Operating voltage of generator:	100 ±5%
Operation power factor of generator:	Above 0.85
Tap ratio of transformer:	1.00 ±0.10 P.U

(4) Stability calculation

In power system stability study after commissioning the Köprübaşı power station, a three-phase-ground- fault is applied as the system disturbance on the 154 kV transmission lines: Köprübaşı - Ereğli line and Köprübaşı - Karabük line, and then the fluctuations of generators were checked. In this study, the fault resistance is taken for zero, and the high-speed reclosing of the faulty transmission line is not assumed. The fault sequence to apply to these transmission lines is illustrated below. The fault clearing time is taken for 0.10 seconds assuming that the protective relays operate normally.



(5) Short-circuit current calculation

Three phase short-circuit current was calculated for the Köprübaşı power station and its nearby 154 kV system presuming, as previously mentioned in Section (2), that the short-circuit current to be flown into the 380 kV bus of the Osmanca substation is 15 kA. Regarding a generator constant, the transient reactance (X_d') is used.

10.3.2 Results of System Calculation

(1) Power flow calculation

Power flow calculation was performed in two cases: when the Köprübaşı power station is in operation case and is not in operation case, and then the effect of operating the power station was checked and verified.

a) Köprübaşı Power Station in operation

Figure 10-3 shows the power flow when the Köprübaşı power station is in operation in 2001. The power demand of the 154 kV system near the Köprübaşı power station is about 540 MW and that the loads are comparatively large for Erdemir, Çatalağzi and Karabük substations among the related substations. On the other hand, the main supply is obtainable only from the Çatalağzi thermal power station, which is about 300 MW. Accordingly, about 240 MW of power lacking in the 154 kV system should be balanced by receiving from the 380 kV system and by generation of the Köprübaşı

power station.

However, once the Köprübaşı power station (70 MW) has commissioned, the power receiving from other systems will be reduced to about 170 MW. As a result, the voltage drop at nearby substations will be reduced and the secondary voltages of all 154 kV substations are easily maintained at 100% or over.

b) Köprübaşı Power Station in non-operation

Figure 10-4 shows the power flow when the Köprübaşı power station is not in operation. In this case, it is known that the voltage drop becomes larger at 154 kV substations that are located distant from the 380 kV system and from the Çatalağzi power station. In particular, at Karabük and İsmetpaşa substations, it may be very difficult to maintain the secondary voltage at 100%. In addition, because the power receiving from the 380 kV system increases, the transmission loss increases.

It is also known that the transmission loss of the 154 kV system increases by 4.0 MW when the Köprübaşı power station is not in operation. This transmission loss amounts to 5.7% of 70 MW of the rated output from the Köprübaşı power station.

c) Priority of construction of new transmission lines

According to the transmission line plan prepared by TEK, one each of new lines is to be constructed starting from the Köprübaşı power station to Ereğli and Karabük substations. From the power flow calculation, however, it was found that the power flow from Köprübaşı to Karabük is 55 MW while that of Köprübaşı to Ereğli is only 15 MW which is very light (Figure 10-3).

In view of it, it may be concluded that the line from Köprübaşı to Ereğli is not necessarily be completed as the Köprübaşı power station commissions. Instead, it is surely possible to postpone the construction of that line until the downstream development, the Çay project, is completed. For this reason, the priority should be given to the construction of the line between Köprübaşı to Karabük.

(2) Stability calculation

Figure 10-5 and 10-6 show the results of the stability calculation in generator swing curves. Figure 10-5 is the case that the Köprübaşı - Karabük line is opened after the fault, while Figure 10-6 is the same fault case for Köprübaşı - Ereğli line. In both cases, the generator of the Köprübaşı power station can maintain its operation stably.

Figure 10-7 and 10-8 show the voltage fluctuation curves of the 154 kV busses of Köprübaşı, Karabük and Ereğli substations. Figure 10-7 is the case that the Köprübaşı - Karabük line is opened after the fault, and Figure 10-8 is the same condition for the Köprübaşı - Ereğli line.

The range of voltage drop of Karabük illustrated in Figure 10-7 is larger compared with that in Figure 10-8. These characteristics show that the operation of the Köprübaşı - Karabük line is taken an important function for maintaining the 154 kV local system.

(3) Short-circuit current calculation

Figure 10-9 shows the short-circuit currents of the 380 kV and the 154 kV buses, which are obtained on the assumption that the short-circuit current flown from the integrated 380 kV system into the 380 kV bus of the Osmanca substation is 15 kA and which differ from the actual values but

nonetheless still are conceivable to be more or less the same in general.

The top-six 154 kV bus short-circuit currents are selected from the substations (or power stations) and listed below.

Osmanca:	8.7 kA (2312 MVA)
Eređli :	8.0 kA (2140 MVA)
Erdemir:	7.6 kA (2026 MVA)
Çatalađzi:	6.9 kA (1833 MVA)
Akçakoca:	6.3 kA (1679 MVA)
Köprübaşı:	4.5 kA (1213 MVA)

(4) Development effect of Köprübaşı power station

The development of the Köprübaşı power station brings such advantageous effect as to improve characteristics of the power system in the vicinity of this power station. The effecting points are as shown below:

- a) As for the demand and supply balance in this region, 55% of the demand is supplied from the Çatalađzi thermal power station, while the balance is supplied from the 380 kV and 154 kV systems. After commissioning of the Köprübaşı power station, it is possible to supply as much as almost 70% of the total power demand regionally.
- b) Receiving power from the 380 kV system decreased, the transmission line loss in the 154 kV system is reduced and the system voltage level is improved.
- c) Likewise, receiving power from the 380 kV system decreased, addition of 380/154 kV transformers at Osmanca and Eređli substations may favorably be postponed.





Figure 10-1 154 kV Transmission Line in Köprübaşı Project

LEGEND :

$R + j X (Y/2)$
 [% at 100MVA Base]






KÖPRÜBASİ HYDROELECTRIC
 POWER DEVELOPMENT PROJECT

Impedance Map in 2001

Figure 10-2

LEGEND :

- $P+jQ$: MW+jMVar
- V/θ : % / deg
-  : Transformer
-  : Static condenser






KÖPRÜBAŞI HYDROELECTRIC POWER DEVELOPMENT PROJECT

Power Flow Diagram in 2001 (Koprubasi : operation)

Figure 10-3

LEGEND :

- $P+jQ$: MW+jMVar
- V/θ : % / deg
-  : Transformer
-  : Static condenser



KÖPRÜBASİ HYDROELECTRIC
POWER DEVELOPMENT PROJECT

Power Flow Diagram in 2001
(Koprubasi : stoppage)

Figure 10-4




Figure 10-5 Dynamic Stability Swing Curve

Köprübaşı-Karabük Line opened after 3 ϕ G-fault
at Köprübaşı P.S




Figure 10-6 Dynamic Stability Swing Curve

Köprübaşı-Ereğli Line opened after 3 ϕ G-fault
at Köprübaşı P.S




Figure 10-7 Bus Voltage Fluctuation Curve

Köprübaşı-Karabük Line opened after 3φG-fault
at Köprübaşı P.S




Figure 10-8 Bus Voltage Fluctuation Curve

Köprübaşı-Karabük Line opened after 3φG-fault at Köprübaşı P.S

Chapter 11 FEASIBILITY DESIGN

Chapter 11

FEASIBILITY DESIGN

Contents

	<u>Page</u>
11.1 Civil Work	11 - 1
11.1.1 Dam	11 - 1
11.1.2 Spillway	11 - 4
11.1.3 Care of River	11 - 5
11.1.4 Outlet	11 - 5
11.1.5 Intake	11 - 6
11.1.6 Penstock	11 - 6
11.1.7 Underground Powerhouse	11 - 7
11.1.8 Tailrace	11 - 8
11.2 Electro-Mechanical Equipment	11 - 10
11.2.1 Selection of Number of Unit	11 - 10
11.2.2 Type and Rating of Major Equipment	11 - 10
11.2.3 Main Circuit Equipment	11 - 12
11.2.4 Telecommunication Equipment	11 - 13
11.3 Transmission Line	11 - 14
11.3.1 Transmission Line Route	11 - 14
11.3.2 Conductor, Insulator and Ground-wire	11 - 15
11.3.3 Supporting Structure	11 - 15

List of Figure

- Figure 11-1 Optimization Study on Tailrace Tunnel
- Figure 11-2 Rating Curve of Tailrace Tunnel
- Figure 11-3 Waterway Plan and Profile
- Figure 11-4 Dam General Plan
- Figure 11-5 Dam Profile and Section
- Figure 11-6 Spillway Plan and Profile
- Figure 11-7 Outlet Works Plan and Profile
- Figure 11-8 Penstock and Powerhouse Plan
- Figure 11-9 Penstock and Powerhouse Profile
- Figure 11-10 Powerhouse Transverse and Longitudinal Sections
- Figure 11-11 Powerhouse Plans
- Figure 11-12 Cable Tunnel and Switchyard Plan and Profile
- Figure 11-13 Tailrace Channel Plan and Section
- Figure 11-14 Single Line Diagram
- Figure 11-15 Plan of Switchyard
- Figure 11-16 Standard Suspension Tower
- Figure 11-17 Standard Suspension Tower

Chapter 11 FEASIBILITY DESIGN

11.1 Civil Work

11.1.1 Dam

(1) Locations and Outlines

The Devrek river, in the Project area including the dam site, repeatedly meanders due to the geologic structure. It flows north as a whole and joins the Yenice River, then reaches the Black Sea. In a area of 2 to 3 km where includes the dam site, the Devrek River has hairpin turns at two places where it changes course to the south and then to the north, providing a topography advantageous for a rockfill dam site.

The dam site proposed for the Project is located on the downstream hairpin curve, and is roughly the same site as proposed in the Master Plan.

The left-bank side of the dam site provides a comparatively massive abutment of a uniform slope of approximately 30° , but the valley is wider to the downstream direction. On the other hand, the right-bank side is of a comparatively scraggy ridge topography, with the slope of approximately 40° near the river bed and with gentle slope at higher abutment than the low water level. As a whole an asymmetric cross-sectional shape is presented at the dam site.

The valley width at the dam site is approximately 50 m at the river bed, while it is approximately 540 m at the dam crest.

The thickness of river-bed deposits at the dam site is around 15 m, and the deposits are comprised of a

comparatively thinly deposited sand layer underlain by a gravel deposit. Granodiorite is distributed underlying the river-bed deposits. Rock properties in terms of RQD and permeability and others suggests that the abutment will satisfy the requirements for the high dam foundation.

(2) Selection of Dam Type

Topographical features and geological conditions of the dam site tells us that it is possible to construct the rockfill dam and concrete gravity dam. Advantages and disadvantages of both type dams are indicates as follows:

Rockfill Dam

- Since the rockfill dam allows the foundation with low shear strength, foundation excavation can be planned economically.
- Since the dam site is located at a hairpin curve, an economical layout is possible for the spillway and diversion tunnel which generally increase rockfill dam construction costs.
- Dam embankment materials such as impervious core material, filter material, and rock material can be collected and hauled from within a range of several kilometers upstream of the dam site. This will be economical.
- Excavated material at the dam and spillway can be utilized for embankment materials.

Concrete Gravity Dam

- The concrete gravity dam foundation should have higher shear strength. Consequently, the foundation excavation

line will be deeper compared with a rockfill dam, and both dam volume and excavation quantities will increase.

- The spillway of the concrete dam can be constructed in the dam body. This is an advantage compared with the rockfill-dam.
- Care-of-river during construction can be economically done by the river diversion method, method of temporary diversion conduit in the dam, or a combination of these methods.

Construction costs on dam, spillway, diversion tunnel, and cofferdams for both dams are summarized as follows:

Construction cost for rockfill dam : 315×10^9 TL
Construction cost for concrete gravity dam: 403×10^9 TL

Because of less construction cost, the rockfill dam is selected.

(3) Selection of Dam Axis

An upstream dam axis, midstream dam axis proposed in the Master Plan, and downstream dam axis are prepared within a range of 70 m for the purpose of contemplating the dam axis. It is not reasonable to make another alternatives beyond the range because of the topography.

The downstream dam axis is selected because it has minimum volume among three alternatives.

(4) Dam Body

The rockfill dam consists of an impervious core zone at dam center, two fine coarse filter zones and rockfill zones at both upstream and downstream side. Slope gradients are 1:2.5 for the upstream slope and 1:2.0 for the downstream

slope. The impervious core zone has 8 m in thickness at the crest and the thickness corresponding to roughly 50% of the acting water pressure at the foundation. Stability of the dam is analyzed by a circular arc method. The analyses conclude that the dam is stable against the maximum earthquake expected at the site.

The embankment quantity is to be approximately $5 \times 10^6 \text{ m}^3$. Rock material of $3,067,000 \text{ m}^3$ will be mainly conveyed from a quarry located at the right-bank, 1.5 km upstream of the dam, while coarse-particled rock included in excavation muck is also used. Filter materials of $735,000 \text{ m}^3$ will be conveyed from river-bed deposits at the upstream side of the dam and excavation muck in their natural site or upon adjustments of gradation. Impervious core material of $757,000 \text{ m}^3$ is collected from a borrow areas upstream or downstream of the dam. Selection of the borrow area should be subject to additional investigations carried out after the F/S.

11.1.2 Spillway

The spillway is placed at the right-bank side to shortcut a bend taking advantage of the topographical feature of the dam site.

The spillway has total width of 29 m at the portal and two radial gates of 13.00 m in width and 14.50 m in height. The spillway has a capacity to discharge the $2,500 \text{ m}^3/\text{sec}$ of the probable maximum flood at the high water level 437 m.

The spillway has a chute of 26 m in width and a flip bucket at the end of the chute. Water energy is expected to be dissipated at a plunge pool.

11.1.3 Care-of-River

Prior to dam foundation excavation at the river bed, cofferdams are provided at upstream and downstream of the dam, and a diversion tunnel will be constructed for the river diversion.

The design flood discharge during construction is to be 350 m³/sec corresponding to a 25-year return period flood, and the cofferdams and diversion tunnel have a capacity to safely discharge the flood. Study on the care-of-river is made varying the height of the upstream cofferdam at a number of levels for the optimum combination with the diversion tunnel. As the results, the elevation of upstream cofferdam crest is EL. 365 m and the diameter of the diversion tunnel is 6.00 m. The height of the coffer dam will be approximately 20 m, and the total length of the tunnel of standard horseshoe shape will be 390 m.

The upstream cofferdam is located apart from the dam in consideration of the topographical conditions, arrangement of the hauling road, and the conditions for executing dam foundation excavation. The area between the main dam and the cofferdam is utilized for a spoil bank.

The downstream cofferdam is located at the downstream end of the dam.

11.1.4 Outlet

Outlet is installed at the diversion tunnel, and is available for controlling reservoir water level at initial water impoundment and for emergency discharge.

The outlet works has a new intake, a connecting vertical shaft, a conduit on auxiliary gate, and on outlet valve. The capacity of the outlet works is determined generally upon comparison studies on reservoir capacity, inflow, number of days allowable for lowering water level, construction cost. In this case,

taking into account data in similar projects in Turkey, the mode of initial water impoundment, and others, the diameter of the outlet valve is temporally designed to be 1.50 m with a capacity of 33.1 m³/sec at full open.

11.1.5 Intake

The intake is located at approximately 500 m upstream of the right-bank side of the dam (spillway) taking into consideration the followings:

- Topographical condition for easy installation of the intake structure,
- Shortening length of the access road

In order to minimize the excavated slope at steep ground the intake is separated from the vertical shaft for the intake gate.

The elevation of the intake bottom is EL. 380 m, 12 m deeper than the low water level in order to prevent air from entering into penstock.

11.1.6 Penstock

A tunnel type steel penstock is installed between the intake gate shaft and inlet valve at the turbine. One line penstock has a gradient of 1:1 at the inclined portion with internal diameter of 3.40 m, through Y type branch, it becomes two lines of 2.20 m in internal diameter at the bottom horizontal portion.

The penstock is designed under the condition that the steel penstock bears the maximum design head of 275.90 m at the turbine center taking into account a pressure rise of 30% at load shut-down.

In case that properties of the surrounding rock are rationally determine in a future, it will be possible by having the surrounding rock shared some part of the design head to reduce the thickness of the steel penstock.

11.1.7 Underground Powerhouse

As stated in the Chapter 9, the underground powerhouse is selected from technical and economic reasons concerning the entire waterway system.

The powerhouse cavern consists of a generator hall installing two turbine-generator units, a main transformer hall, a control room, and others. The size of the excavated cavern is 16 m in width, 62 m in length, and 35.30 m in height.

The underground powerhouse is associated with a ventilation tunnel and drainage gallery. An access tunnel and the cable tunnel connect the powerhouse to the ground surface.

The powerhouse is located at approximately 150 m under the north slope of the ridge providing the right-bank abutment of the dam.

It is estimated from topographical survey, field reconnaissances and an exploratory drilling that the projected powerhouse site will satisfy the following requirements for the underground powerhouse.

- A massive rock body with sound rock and no remarkable faults and fracture zones for making it possible to construct the powerhouse cavern and drainage gallery.
- Ease in location of the access tunnel and cable tunnel.

The powerhouse cavern has a mushroom type cross-section. The ceiling arch and side wall of the cavern are lined with concrete. As a few properties of the rock around the cavern are known, a

standard design such as pre-stressed steel cable anchors, rock bolts, and a drainage tunnel is adopted for securing stabilization of excavated rock.

An inclined shaft of 424 m in length and 1:3.2 in gradient is constructed between the main transformer hall and the projected switchyard. The shaft is initially used as a work adit for excavation of the powerhouse, then used as the cable tunnel after being lined with concrete.

A tunnel of 126 m in length is constructed toward the arch portion of the cavern from part way along the cable tunnel. This tunnel is initially utilized for excavation of the powerhouse, then used for the ventilation at the powerhouse after being lined with concrete.

The access tunnel of 1,100 m in length with an internal diameter of 5.00 m and gradient of 1:8.8 connects the powerhouse erection bay (EL 233 m) to its portal located at an EL. 358 m in the vicinity of an existing road, approximately 1 km downstream of the powerhouse.

11.1.8 Tailrace

The tailrace will release a maximum discharge of 43.0 m³/sec to the Devrek River. It consists of a non-pressure tunnel and a trapezoidal open canal.

After power generation with the two turbine-generator units, two draft tunnels of 3.3 m in inner diameter and approximately 20 m in length will merge at the surge chamber. Then they will become single standard horseshoe shape tunnel of 4.6 m in inner diameter and 4,899 m in length. This is a non-pressure tunnel with gradient of 1:1,200.

The trapezoidal open canal of 200 m in length connects the tunnel to the Devrek River because it goes across river terraces having specific heights of 4 to 5 m from the Devrek River.

Above results is shown Figure 11-15 and 16.

Two draft gates are equipped at the ends of the draft tunnels. One outlet gate is equipped at the end of the tailrace tunnel.

11.2 Electro-mechanical Equipment

11.2.1 Selection of Number of Units

The installed capacity of Köprübaşı project is 70,000 kW.

There are several conceivable combinations of the number of units and unit capacity, but in general the fewer the number of units is, the lower the construction cost becomes.

It is possible that the number of units for Köprübaşı power station will be "one" just from the technical and economical point of view and also considering the scale of unit. However, "two" units alternative has been selected finally as a result of taking the actual problems on the operation of hydro power plants in Turkey into consideration, such as an accident stop and spare parts procurement, etc. And also the basic policy of the DSI is to select the plural number of units for hydropower projects.

11.2.2 Type and Ratings of Major Equipment

From the maximum discharge and the effective head, a vertical shaft Francis type is judged as appropriate for this project.

The generator is directly coupled to the turbine shaft and is a vertical shaft, three phases, alternating current, synchronous generator.

Generator voltage is stepped up to the transmission voltage by a main transformer.

The type of main transformer will be of three phases, oil-immersed.

Two circuits of 154 kV transmission line will be provided at the outdoor switchyard to send power. The type of switchyard is that of Aluminum pipe bus in accordance with TEK's standard for the time being.

The ratings of major electro-mechanical equipment are as follows:

Water Turbine

Type	Vertical shaft, Francis
Number of units	2
Normal effective head	190.0 m
Maximum discharge	43 m ³ /s
Turbine output	36,200 kW
Revolving speed	429 rpm

Generator

Type	Three phases, alternating current, synchronous
Number of units	2
Output	38,900 kVA
Power factor	0.9 lagging
Voltage	11.0 kV
Frequency	50 Hz
Revolving speed	429 rpm

Main Transformer

Type	Indoor, three phases
Number of units	2
Capacity	38,900 kVA
Voltage primary:	11.0 kV
secondary:	154 kV

Outdoor Switchyard

Bus system	Single bus + transfer bus
Bus	Aluminum pipe
Number of transmission lines connected	154 kV x 2 cct

11.2.3 Main Circuit Equipment

As the underground powerhouse is relatively far from outdoor switchyard, the main transformer is installed in the powerhouse to reduce the cost of power cables connecting between the underground powerhouse and the outdoor switchyard.

A parallel-in circuit breaker is equipped at the low voltage side of the main transformer and is used for synchronizing generator to the power system.

The type of the parallel-in circuit breaker will be of load breaking which is not capable of interrupting the current exceeding the full load current for economical reason.

For interruption of fault current of the generator feeder, the circuit breaker at high voltage side of the main transformer will serve.

For connection between the main transformer and the outdoor switchyard, 154 kV XLPE power cable will be adopted.

Two circuits of 154 kV transmission lines will be connected to the single bus plus transfer bus system in the outdoor switchyard. It is the TEK's standard to provide a transfer bus to enable an inspection of the circuit breaker for the transmission line keeping the line alive through the transfer bus.

To secure station service power in any failures on the transmission line or the switchyard equipment, 2 diesel engine-generator sets will be installed in this power station.

Fig. 11-14 and 11-15 indicate the single line diagram of the power station and the switchyard plan, respectively.