

3.C.6 Specification of River Crossing

LOPBURI

	Item	Unit	No.1 5-2B	No.2 6-2B
Plan Condition	Area Coverage	ha	72.10	157.00
	Design Population	person	1,684	6,290
	Wastewater Flow	m ³ /s	0.03	0.09
Additional Condition	Dia	mm	200	200x2 line
	Length	m	130	130
	Innert Elevation	mm	12.10	12.80
	Velocity	m/s	0.80	1.46

ANGTHONG

	Item	Unit	No.1 1-5B
Plan Condition	Area Coverage	ha	314.50
	Design Population	person	5,259
	Wastewater Flow	m ³ /s	0.08
Additional Condition	Dia	mm	200x2 line
	Length	m	210
	Innert Elevation	mm	8.00
	Velocity	m/s	1.27

SENA

	Item	Unit	No.1 1-1C
Plan Condition	Area Coverage	ha	52.40
	Design Population	person	2,476
	Wastewater Flow	m ³ /s	0.04
Additional Condition	Dia	mm	200
	Length	m	80
	Innert Elevation	mm	5.13
	Velocity	m/s	1.27

3.1.6.2 Comparative Evaluation of Wastewater Treatment Methods

1. Chainat Wastewater Treatment Plant

(1) Stabilization Pond

1) Structural Design

The stabilization pond system is composed of a series of inflow pump, anaerobic pond, facultative pond and maturation pond. The design effective storage capacity of the pond system is 88,500 m³ with a total retention time of 15 days. The effective water depths of the ponds for anaerobic, facultative and maturation pond are 4.0 m, 2.0 m and 1.5 m, respectively.

The design net treatment plant area is estimated at 7.6 ha including ponds, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, anaerobic pond, facultative pond and maturation pond are as follows.

- Inflow pump station : 6.39 m³/min. x 7.6 m (dry hourly max.)
- Anaerobic pond : 52.5 m x 72.5 m x 4.0 m x 2 units
- Facultative pond : 65.5 m x 115.5 m x 2.0 m x 2 units
- Maturation pond : 61.125 m x 81.125 m x 1.5 m x 4 units

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment system are estimated in terms of unit wastewater amount per day excluding land acquisition cost. The unit land acquisition cost at the potential treatment plant site is to be 0.30 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the stabilization pond in Chai Nat are estimated as shown below.

Construction cost : 8.91 million Baht

Land acquisition cost : 14.25 million Baht

Annual O&M cost : 0.13 million Baht/year

(2) Aerated Lagoon

1) Structural Design

The aerated lagoon system consists of inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond in series. The design effective storage capacity of the lagoons and pond is 41,300 m³ with a total retention time of 7 days. The effective water depths of the lagoons and ponds are 4.0 m for aerated lagoon, 4.0 m for facultative aerated lagoon and 1.5 m for polishing pond.

The design net treatment plant area including lagoons and ponds, sludge drying bed, control building yard and buffer zone is about 3.6 ha.

The design capacity of the inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond are as follows.

- Inflow pump station : 6.39 m³/min. x 7.6 m (dry hourly max.)
- Aerated lagoon : 32.5 m x 67.5 m x 4 m x 2 units
: Aerator 11 kw x 4 units/lagoon
- Facultative aerated lagoon : same as aerated lagoon
: Aerator 2.2 kw x 5 units/lagoon
- Polishing pond : 36.25 m x 56.25 m x 1.5 m x 2 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the aerated lagoon treatment plant are estimated as follows:

Construction cost : 14.96 million Baht
Land acquisition cost : 6.75 million Baht
Annual O&M cost : 0.50 million Baht/year

(3) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective storage capacity of ditch is 2,950 m³ with a detention time of 12 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4 hrs with a surface loading of 15 m³/m²/d.

The design net treatment area including ditch, final sedimentation basin, drying bed and control building is about 2.0 ha.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows:

Inflow pump station	: 6.39 m ³ /min. x 7.6 m (dry hourly max.)
Oxidation Ditch	: 4 m(W) x 75 m(L) x 2.5 m(D) x 4 units
Final Sedimentation basin	: ϕ 16 m x 2.5 m(D) x 2 units
Drying Bed	: 8 m x 16 m x 24 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

Construction cost	: 35.63 million Baht
Land acquisition cost	: 3.75 million Baht
Annual O&M cost	: 3.46 million Baht

2. Sing Buri East Area Wastewater Treatment Plant

(1) Stabilization Pond

1) Structural Design

The stabilization pond system is composed of inflow pump, anaerobic pond, facultative pond and maturation pond in series. The design effective storage capacity of the ponds is 46,500 m³ with a retention time of 15 days. The effective water depths of the ponds are 4.0 m for anaerobic pond, 2.0 m for facultative pond and 1.5 m for maturation pond.

The design net treatment plant area is estimated to be 4.8 ha including ponds, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, anaerobic pond, facultative pond and maturation pond are as follows:

- Inflow pump station : 3.26 m³/min. x 8.5 m
(dry hourly max.)
- Anaerobic pond : 37.5 m x 52.5 m x 4.0 m x 2 units
- Facultative pond : 45.5 m x 85.5 m x 2.0 m x 2 units
- Maturation pond : 36.25 m x 71.25 m x 1.5 m x 4 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the stabilization pond in Sing Buri East are estimated. The unit land acquisition cost of proposed sewage treatment area is 0.2 million Baht/rai in 1993.

Construction cost : 4.53 million Baht
Land acquisition cost : 6.00 million Baht
Annual O&M cost : 0.07 million Baht

(2) Aerated Lagoon

1) Structural Design

The aerated lagoon system consists of inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond in series. The design effective storage capacity of the lagoons and ponds is 21,700 m³ with a retention time of 7 days. The effective water depth of the lagoons and ponds are 4.0 m for aerated lagoon and facultative aerated lagoon and 1.5 m for polishing pond.

The design net treatment plant area is about 2.6 ha including lagoons and ponds, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond are as follows:

- Inflow pump station: 3.26 m³/min. x 8.5 m (dry hourly max.)
- Aerated lagoon : 27.5 m x 42.5 m x 4 m x 2 units
: Aerator 5.7 kw x 4 units/lagoon
- Facultative aerated lagoon : same as aerated lagoon
: Aerator 1.25 kw x 5 units/lagoon
- Policing pond : 16.25 m x 32.25 m x 1.5 m x 4 units
- Drying bed : 5 m x 7 m x 10 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the aerated lagoon treatment plant are estimated as follows:

Construction cost : 8.34 million Baht
Land acquisition cost : 3.25 million Baht
Annual O&M cost : 0.31 million Baht

(3) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective storage capacity of ditch is 1,600 m³ with a detention time of 12.4 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4.4 hrs with a surface loading of 13.7 m³/m²/d.

The design net treatment area is about 1.37 ha including ditch, final sedimentation basin, drying bed and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows.

Oxidation Ditch	: 4 m(W) x 80 m(L) x 2.5 m(D) x 2 units
Final Sedimentation basin	: ϕ 12 m x 2.5 m(D) x 2 units
Drying Bed	: 8 m x 12 m x 20 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows.

Construction cost	: 18.72 million Baht
Land acquisition cost	: 1.71 million Baht
Annual O&M cost	: 1.75 million Baht

3. Sing Buri West Area Wastewater Treatment Plant

(1) Stabilization Pond

1) Structural Design

The stabilization pond system is composed of inflow pump, anaerobic pond, facultative pond and maturation pond in series. The design total effective storage capacity of the ponds is 123,000 m³ with a total retention time of 15 days. The effective water depth of the ponds are 4.0 m for anaerobic pond, 2.0 m for facultative pond and 1.5 m for maturation pond.

The design net treatment plant area including ponds, sludge drying bed, control building yard and buffer zone is 9.85 ha.

The design capacity of the inflow pump station, anaerobic pond, facultative pond and maturation pond are as follows.

- Inflow pump station : 8.82m³/min. x 4.8 m (dry hourly max.)
- Anaerobic pond : 62.5 m x 82.5 m x 4.0 m x 2 units
- Facultative pond : 85.5 m x 120.5 m x 2.0 m x 2 units
- Maturation pond : 76.25 m x 91.25 m x 1.5 m x 4 units

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment system per unit wastewater amount per day excluding land acquisition cost were estimated. The unit land acquisition cost of the potential treatment plant site is to be 0.17 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the stabilization pond in Sing Buri West are estimated as shown below.

Construction cost : 12.58 million Baht
Land acquisition cost : 10.47 million Baht
Annual O&M cost : 0.17 million Baht

(2) Aerated Lagoon

1) Structural Design

The aerated lagoon system consists of inflow pump station, aerated lagoon, facultative aerated lagoon and policing pond in series. The design total effective storage capacity of the lagoons and pond is 57,500 m³ with a total retention time of 7 days. The effective water depth of the lagoons and pond are 4.0 m of aerated lagoon, 4.0 m for facultative aerated lagoon and 1.5 m for policing pond.

The design net treatment plant area including lagoons and pond, sludge drying bed, control building yard and buffer zone is about 4.7 ha.

The design capacity of the inflow pump station, aerated lagoon, facultative aerated lagoon and policing pond are as follows.

- Inflow pump station : 8.82 m³/min. x 4.8 m
(dry hourly max.)
- Aerated lagoon : 42.5 m x 72.5 m x 4 m x 2 units
: Aerator 11 kw x 6 units/lagoon
- Facultative aerated lagoon : same as aerated lagoon
: Aerator 3.7 kw x 5 units/lagoon
- Policing pond : 41.25 m x 66.25 m x 1.5 m x 2 units
- Drying bed : 6 m x 8 m x 16 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the aerated lagoon treatment plant are estimated as follows.

- Construction cost : 20.17 million Baht
- Land acquisition cost : 4.99 million Baht
- Annual O&M cost : 0.63 million Baht

(3) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective total storage capacity of ditch is 4,100 m³ with a detention time of 12 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4 hrs with a surface loading of 15 m³/m²/d.

The design net treatment area including ditch, final sedimentation basin, drying bed and control building is about 2.25 ha.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows.

Inflow pump station	: 8.82 m ³ /min. x 4.8 m (dry hourly max.)
Oxidation Ditch	: 4 m(W) x 70 m(L) x 2.5 m(D) x 6 units
Final Sedimentation basin	: ϕ 16 m x 2.5 m(D) x 3 units
Drying Bed	: 10 m x 17 m x 30 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows.

Construction cost	: 49.52 million Baht
Land acquisition cost	: 2.39 million Baht
Annual O&M cost	: 4.83 million Baht

4. Lop Buri Wastewater Treatment Plant

(1) Stabilization Pond

1) Structural Design

The stabilization pond system is composed of inflow pump, anaerobic pond, facultative pond and maturation pond in series. The design effective storage capacity of the ponds is 247,500 m³ with a retention time of 15 days. The effective water depths of the ponds are 4.0 m for anaerobic pond, 2.0 m for facultative pond and 1.5 m for maturation pond.

The design net treatment plant area is estimated at 18.24 ha including ponds, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, anaerobic pond, facultative pond and maturation pond are as follows:

- Inflow pump station : 17.8 m³/min. x 6.2 m (dry weather)
- Anaerobic pond : 62.5 m x 82.5 m x 4.0 m x 4 units
- Facultative pond : 67.5 m x 102.5 m x 2.0 m x 6 units
- Maturation pond : 56.25 m x 81.25 m x 1.5 m x 12 units

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment systems are estimated in terms of unit wastewater amount per day excluding land acquisition cost. The unit land acquisition cost of the potential treatment plant site is to be 0.50 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the stabilization pond in Lop Buri are estimated as shown below.

Construction cost	: 26.2 million Baht
Land acquisition cost	: 57.0 million Baht
Annual O&M cost	: 0.32 million Baht

(2) Aerated Lagoon

1) Structural Design

The aerated lagoon system consists of inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond in series. The design effective storage capacity of the lagoons and ponds is 115,500 m³ with a retention time of 7 days. The effective water depth of the lagoons and pond are 4.0 m for aerated lagoon, 4.0 m for facultative aerated lagoon and 1.5 m for polishing pond.

The design net treatment plant area is estimated at 8.05 ha including lagoons and pond, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond are as follows:

- Inflow pump station : 17.8 m³/min. x 6.2 m (dry weather)
- Aerated lagoon : 42.5 m x 73.5 m x 4 m x 4 units
: Aerator 11 kw x 6 units/lagoon
- Facultative aerated lagoon : same as aerated lagoon
: Aerator 2.2 kw x 7 units/lagoon
- Polishing pond : 41.25 m x 67.25 m x 1.5 m x 4 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the aerated lagoon treatment plant are estimated as follows:

Construction cost : 38.06 million Baht
Land acquisition cost : 25.16 million Baht
Annual O&M cost : 1.07 million Baht

(3) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective storage capacity of ditch is 8,250 m³ with a detention time of 12 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4 hrs with a surface loading of 15 m³/m²/d.

The design net treatment area is estimated at about 3.75 ha including ditch, final sedimentation basin, drying bed and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows.

Inflow Pump	: 17.8 m ³ /min. x 6.2 m (dry weather)
Oxidation Ditch	: 4 m(W) x 138 m(L) x 2.5 m(D) x 6 units
Final Sedimentation basin:	φ16 m x 2.5 m(D) x 6 units
Drying Bed	: 10 m x 15 m x 55 units (8,250 ha)

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

Construction cost	: 99.64 million Baht
Land acquisition cost	: 11.72 million Baht
Annual O&M cost	: 9.78 million Baht

5. Ang Thong Wastewater Treatment Plant

(1) Stabilization Pond

1) Structural Design

The stabilization pond system is composed of inflow pump, anaerobic pond, facultative pond and maturation pond in series. The design effective storage capacity of the ponds is 55,500 m³ with a retention time of 15 days. The effective water depths of the ponds are 4.0 m for anaerobic pond, 2.0 m for facultative pond and 1.5 m for maturation pond.

The design net treatment plant area is estimated at 5.44 ha including ponds, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, anaerobic pond, facultative pond and maturation pond are as follows:

- Inflow pump station : 3.96 m³/min. x 4.8 m
- Anaerobic pond : 42.5 m x 54.5 m x 4.0 m x 2 units
- Facultative pond : 55.5 m x 83.5 m x 2.0 m x 2 units
- Maturation pond : 46.25 m x 67.25 m x 1.5 m x 4 units

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment systems are estimated in terms of unit wastewater amount per day excluding land acquisition cost. The unit land acquisition cost at the potential treatment plant site is to be 0.2 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the stabilization pond in Ang Thong are estimated as shown below.

Construction cost	: 5.46 million Baht
Land acquisition cost	: 6.80 million Baht
Annual O&M cost	: 0.09 million Baht

(2) Aerated Lagoon

1) Structural Design

The aerated lagoon system consists of inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond in series. The design effective storage capacity of the lagoons and pond is 25,900 m³ with a retention time of 7 days. The effective water depths of the lagoons and pond are 4.0 m of aerated lagoon, 4.0 m for facultative aerated lagoon and 1.5 m for polishing pond.

The design net treatment plant area is estimated to be about 2.8 ha including lagoons and pond, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond are as follows:

- Inflow pump station : 3.96m³/min. x 4.8 m
(dry, hourly max.)
- Aerated lagoon : 32.5 m x 43.5 m x 4 m x 2 units
: Aerator 3.7 kw x 8 units / lagoon
- Facultative aerated lagoon : same as aerated lagoon
: Aerator 0.75 kw x 10 units / lagoon
- Polishing pond : 26.25 m x 47.25 m x 1.5 m x 2 units
- Drying Bed : 4 m x 6 m x 16 units 384 m²

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the aerated lagoon treatment plant are estimated as follows:

- Construction cost : 9.79 million Baht
- Land acquisition cost : 3.50 million Baht
- Annual O&M cost : 0.35 million Baht

(3) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective storage capacity of ditch is 1,850 m³ with a detention time of 12 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4 hrs with a surface loading of 15 m³/m² /d.

The design net treatment area is estimated at 1.52 ha including ditch, final sedimentation basin, drying bed and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows:

Inflow Pump	: 3.96 m ³ /min. with 4.8 m hydraulic head (dry weather, hourly max.)
Oxidation Ditch	: 4 m(W) x 93 m(L) x 2.5 m(D) x 2 units
Final Sedimentation basin	: ϕ 13 m x 2.5 m(D) x 2 units
Drying Bed	: 10 m x 15 m x 14 units 2,100 m ²

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

Construction cost	: 22.34 million Baht
Land acquisition cost	: 1.90 million Baht
Annual O&M cost	: 2.16 million Baht

6. Pa Mok East Area Wastewater Treatment Plant

(1) Stabilization Pond

1) Structural Design

The stabilization pond system is composed of inflow pump, anaerobic pond, facultative pond and maturation pond in series. The design effective storage capacity of the ponds is 30,000 m³ with a retention time of 15 days. The effective water depths of the ponds are 4.0 m for anaerobic pond, 2.0 m for facultative pond and 1.5 m for maturation pond.

The design net treatment plant area is estimated to be 3.74 ha including ponds, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, anaerobic pond, facultative pond and maturation pond are as follows:

- Inflow pump station : 2.16 m³/min. x 7.6 m (dry)
- Anaerobic pond : 27.5 m x 45.5 m x 4.0 m x 2 units
- Facultative pond : 40.5 m x 62.5 m x 2.0 m x 2 units
- Maturation pond : 36.25 m x 46.25 m x 1.5 m x 4 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the stabilization pond in Pa Mok East are estimated with a same manner as Pa Mok West and the results are shown below. The unit land acquisition cost of proposed sewage treatment plant area is 0.15 million Baht/rai in 1993.

Construction cost : 2.86 million Baht
Land acquisition cost : 3.51 million Baht
Annual O&M cost : 0.05 million Baht

(2) Aerated Lagoon

1) Structural Design

The aerated lagoon system consists of inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond in series. The design effective storage capacity of the lagoons and ponds is 14,000 m³ with a retention time of 7 days. The effective water depth of the lagoons and ponds are 4.0 m for aerated lagoon and facultative aerated lagoon and 1.5 m for polishing pond.

The design net treatment plant area is estimated to be about 2.1 ha including lagoons and pond, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond are as follows:

- Inflow pump station : 2.16 m³/min. x 7.6 m (dry)
- Aerated lagoon : 22.5 m x 33.5 m x 4 m x 2 units
: Aerator 2.2 kw x 7 units/lagoon
- Facultative aerated lagoon : same as aerated lagoon
: Aerator 0.75 kw x 5 units/lagoon
- Polishing pond : 21.25 m x 32.25 m x 1.5 m x 2 units
- Drying bed : 4 m x 6 m x 8 units (192 m²)

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the aerated lagoon treatment plant are estimated as follows:

- Construction cost : 5.60 million Baht
- Land acquisition cost : 1.97 million Baht
- Annual O&M cost : 0.22 million Baht

(3) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective total storage capacity of ditch is 1,000 m³ with a detention time of 12 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4.7 hrs with a surface loading of 12.7 m³/m²/d.

The design net treatment area is estimated at about 1.22 ha including ditch, final sedimentation basin, drying bed and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows:

Oxidation Ditch	: 4 m(W) x 50 m(L) x 2.5 m(D) x 2 units
Final Sedimentation basin	: ϕ 10 m x 2.5 m(D) x 2 units
Drying Bed	: 12 m x 14 m x 6 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

Construction cost	: 12.08 million Baht
Land acquisition cost	: 1.14 million Baht
Annual O&M cost	: 1.16 million Baht

7. Pa Mok West Area Wastewater Treatment Plant

(1) Stabilization Pond

1) Structural Design

The stabilization pond system is composed of inflow pump, anaerobic pond, facultative pond and maturation pond in series. The design effective storage capacity of the ponds is 25,500 m³ with a retention time of 15 days. The effective water depths of the ponds are 4.0 m for anaerobic pond, 2.0 m for facultative pond and 1.5 m for maturation pond.

The design net treatment plant area is estimated to be 3.44 ha including ponds, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, anaerobic pond, facultative pond and maturation pond are as follows:

- Inflow pump station : 1.81m³/min. x4.9 m (dry)
- Anaerobic pond : 27.5 m x 39.5 m x 4.0 m x 2 units
- Facultative pond : 35.5 m x 60.5 m x 2.0 m x 2 units
- Maturation pond : 31.25 m x 46.25 m x 1.5 m x 4 units

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment system in terms of unit wastewater amount per day excluding land acquisition cost were estimated. The unit land acquisition cost of the potential treatment plant site is to be 0.15 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the stabilization pond in Pa Mok West are estimated as shown below.

Construction cost	: 2.41 million Baht
Land acquisition cost	: 3.23 million Baht
Annual O&M cost	: 0.04 million Baht

(2) Aerated Lagoon

1) Structural Design

The aerated lagoon system consists of inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond in series. The design effective storage capacity of the lagoons and pond is 11,900 m³ with a retention time of 7 days. The effective water depths of the lagoons and pond are 4.0 m of aerated lagoon, 4.0 m for facultative aerated lagoon and 1.5 m for polishing pond.

The design net treatment plant area is estimated at about 1.98 ha including lagoons and pond, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond are as follows:

- Inflow pump station : 1.81 m³/min. x 4.9 m (dry)

- Aerated lagoon : 17.5 m x 37.5 m x 4 m x 2 units
: Aerator 2.2 kw x 6 units/lagoon

- Facultative aerated lagoon : same as aerated lagoon
: Aerator 0.75 kw x 5 units/lagoon

- Polishing pond : 21.25 m x 27.25 m x 1.5 m x 2 units

- Drying bed : 4 m x 5 m x 8 units (160 m²)

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the aerated lagoon treatment plant are estimated as follows:

Construction cost : 4.83 million Baht
Land acquisition cost : 1.86 million Baht
Annual O&M cost : 0.20 million Baht

(3) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective storage capacity of ditch is 850 m³ with a detention time of 12 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4 hrs with a surface loading of 15 m³/m²/d.

The design net treatment area is estimated at about 1.17 ha including ditch, final sedimentation basin, drying bed and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows:

Inflow Pump	: 1.81 m ³ /min. with 4.9 m (dry)
Oxidation Ditch	: 4m(W) x 43m(L) x 2.5m(D) x 2 units
Final Sedimentation basin	: ϕ 9 m x 2.5m(D) x 2 units
Drying Bed	: 10 m x 15 m x 6 units (900 m ²)

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

Construction cost	: 10.27 million Baht
Land acquisition cost	: 1.10 million Baht
Annual O&M cost	: 0.99 million Baht

8. Sena Wastewater Treatment Plant

(1) Stabilization Pond

1) Structural Design

The stabilization pond system is composed of inflow pump, anaerobic pond, facultative pond and maturation pond in series. The design effective storage capacity of the ponds is 39,000 m³ with a retention time of 15 days. The effective water depths of the ponds are 4.0 m for anaerobic pond, 2.0 m for facultative pond and 1.5 m for maturation pond.

The design net treatment plant area is estimated at 4.36 ha including ponds, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, anaerobic pond, facultative pond and maturation pond are as follows:

- Inflow pump station : 2.78 m³/min. x 6.2 m
- Anaerobic pond : 32.5 m x 50.0 m x 4.0 m x 2 units
- Facultative pond : 45.5 m x 71.5 m x 2.0 m x 2 units
- Maturation pond : 36.25 m x 61.25 m x 1.5 m x 4 units

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment system in terms of unit wastewater amount per day excluding land acquisition cost were estimated. The unit land acquisition cost of the potential treatment plant site is to be 0.2 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the stabilization pond in Sena are estimated as shown below.

Construction cost	: 3.77 million Baht
Land acquisition cost	: 5.43 million Baht
Annual O&M cost	: 0.06 million Baht

(2) Aerated Lagoon

1) Structural Design

The aerated lagoon system consists of inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond in series. The design effective storage capacity of the lagoons and pond is 18,200 m³ with a retention time of 7 days. The effective water depths of the lagoons and pond are 4.0 m of aerated lagoon, 4.0 m for facultative aerated lagoon and 1.5 m for polishing pond.

The design net treatment plant area is estimated at about 2.35 ha including lagoons and pond, sludge drying bed, control building yard and buffer zone.

The design capacity of the inflow pump station, aerated lagoon, facultative aerated lagoon and polishing pond are as follows:

- Inflow pump station : 2.78 m³/min. x 6.2 m (dry weather)
- Aerated lagoon : 22.5 m x 43.5 m x 4 m x 2 units
: Aerator 2.2 kw x 9 units/lagoon
- Facultative aerated lagoon : same as aerated lagoon
: Aerator 1.5 kw x 4 units/lagoon
- Polishing pond : 21.25 m x 41.25 m x 1.5 m x 2 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the aerated lagoon treatment plant are estimated as follows:

Construction cost : 7.11 million Baht
Land acquisition cost : 2.94 million Baht
Annual O&M cost : 0.27 million Baht

(3) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective storage capacity of ditch is 1,300 m³ with a detention time of 12 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4 hrs with a surface loading of 15 m³/m²/d.

The design net treatment area is estimated at about 1.33 ha including ditch, final sedimentation basin, drying bed and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows:

Inflow pump station	: 2.78 m ³ /min. x 6.2 m (dry weather)
Oxidation ditch	: 4 m(W) x 65 m(L) x 2.5 m(D) x 2 units
Final sedimentation basin	: ϕ 11 m x 2.5 m(D) x 2 units
Drying bed	: 10 m x 15 m x 9 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

Construction cost	: 15.70 million Baht
Land acquisition cost	: 1.66 million Baht
Annual O&M cost	: 1.52 million Baht

9. Rang Sit Area Wastewater Treatment Plant

(1) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The design effective storage capacity of ditch is 32,000 m³ with a detention time of 12.3 hours. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4.4 hours with a surface loading of 13.8 m³/m²/d.

The design net treatment area is estimated at about 9.1 ha including ditch, final sedimentation basin, centrifugal dewatering and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin are as follows:

Inflow Pump	: 67.7 m ³ /min. x 7.3 m (dry hourly max.)
Oxidation Ditch	: 4m(W) x 156m(l) x 2.5m(d) x 20 units
Final Sedimentation basin	: ϕ 17 m x 2.5m(D) x 20 units

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment system in terms of unit wastewater amount per day excluding land acquisition cost were estimated. The unit land acquisition cost of the potential treatment plant site is to be 2 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

Construction cost	: 484.06 million Baht
Land acquisition cost	: 113.75 million Baht
Annual O&M cost	: 40.73 million Baht

(2) Conventional Activated Sludge (AS)

1) Structural Design

The conventional activated sludge system consists of inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and sludge disposed facilities. Daily maximum wastewater of 75,000 m³/d is used for design of conventional activated sludge system.

The major mechanical/electrical equipment is inflow pump and surface aerator. Their design capacities are as follows:

- Inflow Pump : 240 kw for dry, 350 kw for wet weather
- Surface Aerator : 11 kw/unit x 18 units
22 kw/unit x 12 units

The design net treatment plant area is estimated at about 7.5 ha including inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and centrifugal dewatering.

The design capacity of the inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin are as follows.

- Inflow pump station : 67.7 m³/min. x 7.3 m
(dry hourly max.)
- Primary sedimentation basin : ϕ 16.0 m x 4.0 m(D)
x12 units
- Aeration tank : 15.0 m(W) x 75.0 m(L) x 3.0 m(D)
x 12 units
- Secondary sedimentation : ϕ 18.5 m x 2.5 m(D)
x 12 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the AS in Rangsit are estimated as shown below.

Construction cost : 598.75 million Baht
Land acquisition cost : 93.75 million Baht
Annual O&M cost : 38.71 million Baht

(3) Rotating Biological Contactor (RBC)

1) Structural Design

The rotating biological contactor system consists of inflow pump station, primary sedimentation basin, aeration tank, secondary sedimentation basin and sludge disposed facilities. Daily maximum wastewater of 75,000 m³/d is used for design of RBC system.

The major mechanical/electrical equipment is inflow pump and rotating biological contactor. Their design capacity are as follows:

- Inflow pump : 240 kw for dry, 350 kw
for wet weather
- Rotating biological contactor : ϕ 3.6 m x 7.5 m(L) x 120 units

The design net treatment plant area is estimated at about 6.7 ha including inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and centrifugal dewatering.

The design capacity of inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin are as follows:

- Inflow pump station : 67.7 m³/min. x 7.3 m
(dry hourly max.)
- Primary sedimentation basin : ϕ 16.0 m x 4.0 m(D)
x 12 units
- Aeration tank : 3.8 m(W) x 7.8 m(L) x 2.5 m
x 120 units
- Secondary sedimentation basin : ϕ 18.5 m x 2.5 m
x 12 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the RBC treatment plant are estimated as follows.

Construction cost	:	759.62 million Baht
Land acquisition cost	:	83.75 million Baht
Annual O&M cost	:	42.14 million Baht

10. Bang Bua Thong North Area Wastewater Treatment Plant

(1) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The daily average wastewater is used for designing oxidation ditch. The design effective storage capacity of ditch is 9,840 m³ with a detention time of 12 hrs. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4.2 hrs with a surface loading of 14.2 m³/m²/d.

The design net treatment area is estimated at about 4.5 ha including ditch, final sedimentation basin, centrifugal dewatering and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin are as follows:

Inflow Pump	: 21.3 m ³ /min. 8.0 m (dry hourly max.)
Oxidation Ditch	: 4m(W) x 123m(L) x 2.5m(D) x 8 units
Final Sedimentation basin	: ϕ 21 m x 2.5m(D) x 4 units

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment system in terms of unit wastewater amount per day excluding land acquisition cost were estimated. The unit land acquisition cost of the potential treatment plant site is to be 8 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

the AS in Bang Bua Thong North area are estimated as shown below.

Construction cost : 181.26 million Baht
Land acquisition cost : 150.00 million Baht
Annual O&M cost : 12.14 million Baht

(3) Rotating Biological Contactor (RBC)

1) Structural Design

The rotating biological contactor system consists of inflow pump station, primary sedimentation basin, aeration tank, secondary sedimentation basin and sludge disposal facilities. daily maximum wastewater of 23,600 m³/d is used for designing of RBC system.

The major mechanical/electrical equipment is inflow pump and rotating biological contactor. Their design capacity are as follows:

- Inflow pump : 85 kw for dry weather, 187 kw for wet weather
- Rotating biological contactor : ϕ 3.6 m x 7.5 m x 35 units

The design net treatment plant area is estimated at about 3.0 ha including inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and centrifugal dewatering.

The design capacity of inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin are as follows:

- Inflow pump station : 21.3 m³/min. x 8.0 m
(dry hourly max.)
- Primary sedimentation : ϕ 15.0 m x 4.0 m(D)
basin x 4 units
- Aeration tank : 3.8 m(W) x 7.8 m(L) x 2.5 m
x 35 units
- Secondary sedimentation : ϕ 17.0 m x 3.0m x 4 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the RBC treatment plant are estimated as follows:

Construction cost	:	226.00 million Baht
Land acquisition cost	:	150.00 million Baht
Annual O&M cost	:	13.25 million Baht

11. Bang Bua Thong South Area Wastewater Treatment Plant

(1) Oxidation Ditch

1) Structural Design

The oxidation ditch is a modification of the conventional activated sludge process. It is composed of aeration ditch and final sedimentation basin. The daily average wastewater of 7,900 m³/d is used for oxidation ditch design. The design effective storage capacity of ditch is 4,000 m³ with a detention time of 12.2 hours. The effective water depth of ditch is 2.5 m. The sedimentation time of final sedimentation basin is 4.0 hours with a surface loading of 14.9 m³/m²/d.

The design net treatment area is estimated at about 2.25 ha including ditch, final sedimentation basin, drying bed and control building.

The design capacity of the inflow pump, oxidation ditch, final sedimentation basin and drying bed are as follows:

Inflow Pump	: 8.61 m ³ /min. 7.0 m (hourly max. dry)
Oxidation Ditch	: 4 m(W) x 100 m(L) x 2.5 m(D) x 4 units
Final Sedimentation basin	: φ13 m x 2.5 m(D) x 4 units
Drying Bed	: 11 m x 15 m x 24 units (3,960 m ²)

2) Construction and O&M Costs

In the previous Section 3.11 in Chapter 2, the construction and O&M costs of several treatment system in terms of unit wastewater amount per day excluding land acquisition cost were estimated. The unit land acquisition cost of the potential treatment plant site is to be 0.50 million Baht/rai. The construction and land acquisition costs, and annual O&M cost of the oxidation ditch are estimated as follows:

Construction cost : 47.71 million Baht
Land acquisition cost : 7.03 million Baht
Annual O&M cost : 4.65 million Baht

(2) Conventional Activated Sludge

1) Structural Design

The conventional activated sludge system consists of inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and sludge disposal facilities. Daily maximum wastewater of 9,500 m³/d is used for design of conventional activated sludge system.

The major mechanical/electrical equipment is inflow pump and air diffuser. Their design capacities are as follows:

- Inflow Pump : 11.7 kw for dry weather, 34.8 kw
for wet weather
- Surface Aerator : 11 kw/unit x 6 units

The design net treatment plant area is estimated at about 0.8 ha including inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and sludge drying bed.

The design capacity of the inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and drying bed are as follows:

- Inflow pump station : 8.61 m³/min. x 7.0 m
(dry hourly max.)
: 25.8 m³/min. x 7.0 m
(wet hourly max.)
- Primary sedimentation basin : ϕ 14.4 m x 2.5 m(D) x 2 units
- Aeration tank : 4.0 m(W) x 30.0 m(L) x 5.0 m(D)
x 4 units
- Secondary sedimentation basin : ϕ 15.6 m x 2.6 m x 2 units

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the AS in Bang Bua Thong South are estimated as shown below.

Construction cost : 65.42 million Baht
Land acquisition cost : 2.5 million Baht
Annual O&M cost : 4.68 million Baht

(3) Rotating Biological Contactor (RBC)

1) Structural Design

The rotating biological contactor system consists of inflow pump station, primary sedimentation basin, aeration tank, secondary sedimentation basin and sludge disposal facilities. Daily maximum wastewater of 9,500 m³/d is used for design of RBC system.

The major mechanical/electrical equipment is inflow pump and rotating biological contactor. Their design capacity are as follows:

- Inflow pump : 11.7 kw for dry weather
34.8 kw for wet weather
- Rotating biological contactor : ϕ 3.6 m x 7.5 m(L) x 14 units

The design net treatment plant area is estimated at about 0.8 ha including inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and sludge drying bed.

The design capacity of inflow pump, primary sedimentation basin, aeration tank, secondary sedimentation basin and sludge drying bed are as follows:

- Inflow pump station : 8.61 m³/min. x 7.0 m (dry hourly max.)
- Primary sedimentation basin : ϕ 14.4 m x 2.5 m(D) x 2 units
- Aeration tank : 3.8 m(W) x 7.8 m(L) x 2.5 m x 14 units

- Secondary sedimentation : $\phi 15.6$ m x 2.6 m x 2 units
- Drying bed : 12 m x 15 m x 12 units (2,160 m²)

2) Construction and O&M Costs

The construction and land acquisition costs, and annual O&M cost of the RBC treatment plant are estimated as follows:

Construction cost	: 74.52 million Baht
Land acquisition cost	: 2.50 million Baht
Annual O&M cost	: 5.14 million Baht

3.1.6.3 Comparison of Treatment Plant Construction Cost by NPV

Net present value is estimated with following conditions.

Project Life 30 Years
 Construction Period 2 years of 1996 - 1997
 Land Acquisition in 1996
 Operation & Maintenance Period Start from 1997 to 2025
 Annual Discount Rate 8%

	(million Baht)			
Chai Nat	Stabilization Pond	Aerated lagoon	Oxidation Ditch	
Const. Cost	11.67	19.60	46.68	
Land Acquisition	17.95	8.50	4.72	
O/M Cost	18.20	70.05	484.70	
Total	47.82	98.15	536.10	

	(million Baht)			
Lop Buri	Stabilization Pond	Aerated lagoon	Oxidation Ditch	
Const. Cost	34.32	49.66	130.54	
Land Acquisition	71.80	31.69	14.76	
O/M Cost	44.85	149.90	1,370.02	
Total	150.97	231.45	1,515.32	

	(million Baht)			
Pa Mok West	Stabilization Pond	Aerated lagoon	Oxidation Ditch	
Const. Cost	3.16	6.33	13.46	
Land Acquisition	4.07	2.34	1.39	
O/M Cost	5.60	28.01	138.66	
Total	12.83	36.68	153.51	

	(million Baht)			
B B T North	Oxidation Ditch	Activated Sludge	RBC	
Const. Cost	186.97	237.47	296.09	
Land Acquisition	283.44	188.96	188.96	
O/M Cost	1,709.02	1,700.62	1,856.13	
Total	2,179.43	2,127.05	2,341.18	

	(million Baht)			
Sing Buri East	Stabilization Pond	Aerated lagoon	Oxidation Ditch	
Const. Cost	5.93	10.92	24.52	
Land Acquisition	7.56	4.09	2.15	
O/M Cost	9.79	43.42	245.17	
Total	23.28	58.43	271.84	

	(million Baht)			
Ang Thong	Stabilization Pond	Aerated lagoon	Oxidation Ditch	
Const. Cost	7.15	12.82	29.27	
Land Acquisition	8.57	4.41	2.39	
O/M Cost	12.82	49.05	302.56	
Total	28.34	66.28	334.22	

	(million Baht)			
Sena	Stabilization Pond	Aerated lagoon	Oxidation Ditch	
Const. Cost	4.93	9.32	20.57	
Land Acquisition	6.84	3.70	2.09	
O/M Cost	8.40	37.85	212.89	
Total	20.17	50.87	235.55	

	(million Baht)			
B B T South	Oxidation Ditch	Activated Sludge	RBC	
Const. Cost	62.50	85.71	97.63	
Land Acquisition	8.86	3.15	3.15	
O/M Cost	851.41	655.59	720.01	
Total	722.77	744.45	820.79	

	(million Baht)			
Sing Buri West	Stabilization Pond	Aerated lagoon	Oxidation Ditch	
Const. Cost	16.48	26.42	64.88	
Land Acquisition	13.19	6.29	3.01	
O/M Cost	23.82	88.27	676.60	
Total	53.49	120.98	744.49	

	(million Baht)			
Pa Mok East	Stabilization Pond	Aerated lagoon	Oxidation Ditch	
Const. Cost	3.75	7.34	15.83	
Land Acquisition	4.42	2.48	1.44	
O/M Cost	7.02	30.83	162.51	
Total	15.19	40.65	179.78	

	(million Baht)			
Fangsit	Oxidation Ditch	Activated Sludge	RBC	
Const. Cost	634.17	784.43	995.18	
Land Acquisition	143.29	118.10	105.50	
O/M Cost	5,705.61	5,422.67	5,903.15	
Total	6,483.07	6,325.20	7,003.83	

Table 3.1.6.3 (2) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Sing Buri East)

(Unit: Million Baht)

Year	Stabilization Pond			Aerated Lagoon			Oxidation Ditch			Total	
	Const.	Land	O/M	Const.	Land	O/M	Const.	Land	O/M		
1996	2.85	7.56		5.25	4.09		9.34	11.79	2.15	13.94	
1997	3.08			5.67			5.67	12.73		12.73	
1998			0.10			0.46	0.46		2.57	2.57	
1999			0.11			0.49	0.49		2.78	2.78	
2000			0.12			0.53	0.53		3.00	3.00	
2001			0.13			0.57	0.57		3.24	3.24	
2002			0.14			0.62	0.62		3.50	3.50	
2003			0.15			0.67	0.67		3.78	3.78	
2004			0.16			0.72	0.72		4.08	4.08	
2005			0.18			0.78	0.78		4.41	4.41	
2006			0.19			0.84	0.84		4.76	4.76	
2007			0.21			0.91	0.91		5.14	5.14	
2008			0.22			0.98	0.98		5.55	5.55	
2009			0.24			1.06	1.06		6.00	6.00	
2010			0.26			1.15	1.15		6.48	6.48	
2011			0.28			1.24	1.24		6.99	6.99	
2012			0.30			1.34	1.34		7.55	7.55	
2013			0.33			1.44	1.44		8.16	8.16	
2014			0.35			1.56	1.56		8.81	8.81	
2015			0.38			1.69	1.69		9.51	9.51	
2016			0.41			1.82	1.82		10.28	10.28	
2017			0.44			1.97	1.97		11.10	11.10	
2018			0.48			2.12	2.12		11.98	11.98	
2019			0.52			2.29	2.29		12.94	12.94	
2020			0.56			2.48	2.48		13.98	13.98	
2021			0.60			2.67	2.67		15.10	15.10	
2022			0.65			2.89	2.89		16.31	16.31	
2023			0.70			3.12	3.12		17.61	17.61	
2024			0.76			3.37	3.37		19.02	19.02	
2025			0.82			3.64	3.64		20.54	20.54	
TOTAL	5.93	7.56	9.79	10.92	4.09	43.42	58.43	24.52	2.15	245.17	271.84

Table 3.1.6.3 (3) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Sing Buri West)

(Unit: Million Baht)

Year	Stabilization Pond			Aerated Lagoon			Oxidation Ditch			Total	
	Const.	Land	O/M	Const.	Land	O/M	Const.	Land	O/M		
1996	7.92	13.19		12.70	6.29		18.99	3.01		34.20	
1997	8.56			13.72			13.72			33.69	
1998			0.25			0.93	0.93		7.10	7.10	
1999			0.27			1.00	1.00		7.66	7.66	
2000			0.29			1.08	1.08		8.28	8.28	
2001			0.31			1.17	1.17		8.94	8.94	
2002			0.34			1.26	1.26		9.66	9.66	
2003			0.37			1.36	1.36		10.43	10.43	
2004			0.40			1.47	1.47		11.26	11.26	
2005			0.43			1.59	1.59		12.16	12.16	
2006			0.46			1.71	1.71		13.14	13.14	
2007			0.50			1.85	1.85		14.19	14.19	
2008			0.54			2.00	2.00		15.32	15.32	
2009			0.58			2.16	2.16		16.55	16.55	
2010			0.63			2.33	2.33		17.87	17.87	
2011			0.68			2.52	2.52		19.30	19.30	
2012			0.73			2.72	2.72		20.84	20.84	
2013			0.79			2.94	2.94		22.51	22.51	
2014			0.86			3.17	3.17		24.31	24.31	
2015			0.92			3.43	3.43		26.26	26.26	
2016			1.00			3.70	3.70		28.36	28.36	
2017			1.08			3.99	3.99		30.63	30.63	
2018			1.16			4.31	4.31		33.08	33.08	
2019			1.26			4.66	4.66		35.72	35.72	
2020			1.36			5.03	5.03		38.58	38.58	
2021			1.47			5.44	5.44		41.67	41.67	
2022			1.58			5.87	5.87		45.00	45.00	
2023			1.71			6.34	6.34		48.60	48.60	
2024			1.85			6.85	6.85		52.49	52.49	
2025			2.00			7.39	7.39		56.69	56.69	
TOTAL	16.48	13.19	23.82	26.42	6.29	88.27	120.98	64.88	3.01	676.60	744.49

Table 3.1.1.6.3 (4) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Iop Buri)

(Unit: Million Baht)

Year	Stabilization Pond			Aerated Lagoon			Oxidation Ditch					
	Const.	Land	O/M	Total	Const.	Land	O/M	Total	Const.	Land	O/M	Total
1996	16.50	71.80		88.30	23.97	31.69		55.66	62.76	14.76		77.52
1997	17.82			17.82	25.89			25.89	67.78			67.78
1998			0.47	0.47			1.57	1.57			14.37	14.37
1999			0.51	0.51			1.70	1.70			15.52	15.52
2000			0.55	0.55			1.83	1.83			16.76	16.76
2001			0.59	0.59			1.98	1.98			18.10	18.10
2002			0.64	0.64			2.14	2.14			19.55	19.55
2003			0.69	0.69			2.31	2.31			21.11	21.11
2004			0.75	0.75			2.49	2.49			22.80	22.80
2005			0.81	0.81			2.69	2.69			24.63	24.63
2006			0.87	0.87			2.91	2.91			26.60	26.60
2007			0.94	0.94			3.14	3.14			28.73	28.73
2008			1.02	1.02			3.39	3.39			31.02	31.02
2009			1.10	1.10			3.67	3.67			33.51	33.51
2010			1.18	1.18			3.96	3.96			36.19	36.19
2011			1.28	1.28			4.28	4.28			39.08	39.08
2012			1.38	1.38			4.62	4.62			42.21	42.21
2013			1.49	1.49			4.99	4.99			45.58	45.58
2014			1.61	1.61			5.39	5.39			49.23	49.23
2015			1.74	1.74			5.82	5.82			53.17	53.17
2016			1.88	1.88			6.28	6.28			57.42	57.42
2017			2.03	2.03			6.79	6.79			62.02	62.02
2018			2.19	2.19			7.33	7.33			66.98	66.98
2019			2.37	2.37			7.91	7.91			72.34	72.34
2020			2.56	2.56			8.55	8.55			78.12	78.12
2021			2.76	2.76			9.23	9.23			84.37	84.37
2022			2.98	2.98			9.97	9.97			91.12	91.12
2023			3.22	3.22			10.77	10.77			98.41	98.41
2024			3.48	3.48			11.63	11.63			106.29	106.29
2025			3.76	3.76			12.56	12.56			114.79	114.79
TOTAL	34.32	71.80	44.85	150.97	49.86	31.69	149.90	231.45	130.54	14.76	1,370.02	1,515.32

Table 3.1.6.3 (5) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Ang Thong)

(Unit: Million Baht)

Year	Stabilization Pond			Aerated Lagoon			Oxidation Ditch			Total		
	Const.	Land	O/M	Total	Const.	Land	O/M	Total	Const.		Land	O/M
1996	3.44	8.57		12.01	6.17	4.41		10.58	14.07	2.39		16.46
1997	3.71			3.71	6.66			6.66	15.20			15.20
1998			0.13	0.13			0.51	0.51			3.17	3.17
1999			0.14	0.14			0.56	0.56			3.43	3.43
2000			0.15	0.15			0.60	0.60			3.70	3.70
2001			0.17	0.17			0.65	0.65			4.00	4.00
2002			0.18	0.18			0.70	0.70			4.32	4.32
2003			0.19	0.19			0.76	0.76			4.66	4.66
2004			0.21	0.21			0.82	0.82			5.04	5.04
2005			0.23	0.23			0.88	0.88			5.44	5.44
2006			0.24	0.24			0.95	0.95			5.87	5.87
2007			0.26	0.26			1.03	1.03			6.34	6.34
2008			0.29	0.29			1.11	1.11			6.85	6.85
2009			0.31	0.31			1.20	1.20			7.40	7.40
2010			0.33	0.33			1.30	1.30			7.99	7.99
2011			0.36	0.36			1.40	1.40			8.63	8.63
2012			0.39	0.39			1.51	1.51			9.32	9.32
2013			0.42	0.42			1.63	1.63			10.07	10.07
2014			0.45	0.45			1.76	1.76			10.87	10.87
2015			0.49	0.49			1.90	1.90			11.74	11.74
2016			0.53	0.53			2.06	2.06			12.68	12.68
2017			0.57	0.57			2.22	2.22			13.70	13.70
2018			0.62	0.62			2.40	2.40			14.79	14.79
2019			0.67	0.67			2.59	2.59			15.98	15.98
2020			0.72	0.72			2.80	2.80			17.25	17.25
2021			0.78	0.78			3.02	3.02			18.63	18.63
2022			0.84	0.84			3.26	3.26			20.13	20.13
2023			0.91	0.91			3.52	3.52			21.74	21.74
2024			0.98	0.98			3.80	3.80			23.47	23.47
2025			1.06	1.06			4.11	4.11			25.35	25.35
TOTAL	7.15	8.57	12.62	28.34	12.83	4.41	49.05	66.29	29.27	2.39	302.56	334.22

Table 3.1.1.6.3 (6) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Pa Mok East)

(Unit: Million Baht)

Year	Stabilization Pond			Aerated Lagoon			Oxidation Ditch		
	Const.	Land	O/M	Const.	Land	O/M	Const.	Land	O/M
	Total	Total	Total	Total	Total	Total	Total	Total	Total
1996	1.80	4.42	6.22	3.53	2.48	6.01	7.61	1.44	9.05
1997	1.95		1.95	3.81		3.81	8.22		8.22
1998			0.07			0.32			1.70
1999			0.08			0.35			1.84
2000			0.09			0.38			1.99
2001			0.09			0.41			2.15
2002			0.10			0.44			2.32
2003			0.11			0.47			2.50
2004			0.12			0.51			2.70
2005			0.13			0.55			2.92
2006			0.14			0.60			3.15
2007			0.15			0.65			3.41
2008			0.16			0.70			3.68
2009			0.17			0.75			3.97
2010			0.19			0.81			4.29
2011			0.20			0.88			4.64
2012			0.22			0.95			5.01
2013			0.23			1.03			5.41
2014			0.25			1.11			5.84
2015			0.27			1.20			6.31
2016			0.29			1.29			6.81
2017			0.32			1.40			7.36
2018			0.34			1.51			7.94
2019			0.37			1.63			8.58
2020			0.40			1.76			9.27
2021			0.43			1.90			10.01
2022			0.47			2.05			10.81
2023			0.50			2.21			11.67
2024			0.54			2.39			12.61
2025			0.59			2.58			13.62
TOTAL	3.75	4.42	15.19	7.34	2.48	40.65	15.83	1.44	162.51
									179.78

Table 3.1.6.3 (7) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Pa Mok West)

(Unit: Million Baht)

Year	Stabilization Pond		Aerated Lagoon		Oxidation Ditch		Total	
	Const.	O/M	Const.	O/M	Const.	O/M		
1996	1.52	4.07	5.59	2.34	3.04	1.39	7.86	
1997	1.64		1.64		3.29		6.99	
1998		0.06	0.06	0.29		1.45	1.45	
1999		0.06	0.06	0.32		1.57	1.57	
2000		0.07	0.07	0.34		1.70	1.70	
2001		0.07	0.07	0.37		1.83	1.83	
2002		0.08	0.08	0.40		1.98	1.98	
2003		0.09	0.09	0.43		2.14	2.14	
2004		0.09	0.09	0.47		2.31	2.31	
2005		0.10	0.10	0.50		2.49	2.49	
2006		0.11	0.11	0.54		2.69	2.69	
2007		0.12	0.12	0.59		2.91	2.91	
2008		0.13	0.13	0.63		3.14	3.14	
2009		0.14	0.14	0.69		3.39	3.39	
2010		0.15	0.15	0.74		3.66	3.66	
2011		0.16	0.16	0.80		3.96	3.96	
2012		0.17	0.17	0.86		4.27	4.27	
2013		0.19	0.19	0.93		4.61	4.61	
2014		0.20	0.20	1.01		4.98	4.98	
2015		0.22	0.22	1.09		5.38	5.38	
2016		0.23	0.23	1.17		5.81	5.81	
2017		0.25	0.25	1.27		6.28	6.28	
2018		0.27	0.27	1.37		6.78	6.78	
2019		0.30	0.30	1.48		7.32	7.32	
2020		0.32	0.32	1.60		7.91	7.91	
2021		0.35	0.35	1.73		8.54	8.54	
2022		0.37	0.37	1.86		9.22	9.22	
2023		0.40	0.40	2.01		9.96	9.96	
2024		0.43	0.43	2.17		10.76	10.76	
2025		0.47	0.47	2.35		11.62	11.62	
TOTAL	3.16	4.07	12.83	28.01	13.46	1.39	138.66	153.51

Table 3.1.6.3 (8) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Sena)

(Unit: Million Baht.)

Year	Stabilization Pond			Aerated Lagoon			Oxidation Ditch			
	Const.	Land	O/M	Const.	Land	O/M	Const.	Land	O/M	Total
1996	2.37	6.84		4.48	3.70		9.89	2.09		11.98
1997	2.56			4.84			10.68			10.68
1998			0.09			0.40			2.23	2.23
1999			0.10			0.43			2.41	2.41
2000			0.10			0.46			2.61	2.61
2001			0.11			0.50			2.81	2.81
2002			0.12			0.54			3.04	3.04
2003			0.13			0.58			3.28	3.28
2004			0.14			0.63			3.54	3.54
2005			0.15			0.68			3.83	3.83
2006			0.16			0.73			4.13	4.13
2007			0.18			0.79			4.46	4.46
2008			0.19			0.86			4.82	4.82
2009			0.21			0.93			5.21	5.21
2010			0.22			1.00			5.62	5.62
2011			0.24			1.08			6.07	6.07
2012			0.26			1.17			6.56	6.56
2013			0.28			1.26			7.08	7.08
2014			0.30			1.36			7.65	7.65
2015			0.33			1.47			8.26	8.26
2016			0.35			1.59			8.92	8.92
2017			0.38			1.71			9.64	9.64
2018			0.41			1.85			10.41	10.41
2019			0.44			2.00			11.24	11.24
2020			0.48			2.16			12.14	12.14
2021			0.52			2.33			13.11	13.11
2022			0.56			2.52			14.16	14.16
2023			0.60			2.72			15.30	15.30
2024			0.65			2.93			16.52	16.52
2025			0.70			3.17			17.84	17.84
TOTAL	4.93	6.84	8.40	9.32	3.70	37.85	20.57	2.09	212.89	235.55

Table 3.1.6.3 (9) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Rangsit)

(Unit: Million Baht)

Year	Oxidation Ditch			Activated Sludge			RBC		
	Const.	Land	O/M	Const.	Land	O/M	Const.	Land	O/M
1996	304.89	143.29		377.13	118.10		478.45	105.50	
1997	329.28			407.30			516.73		
1998			59.85			56.88			61.92
1999			64.63			61.43			66.87
2000			69.80			66.34			72.22
2001			75.39			71.65			78.00
2002			81.42			77.38			84.24
2003			87.93			83.57			90.98
2004			94.97			90.26			98.26
2005			102.57			97.48			106.12
2006			110.77			105.28			114.60
2007			119.63			113.70			123.77
2008			129.20			122.79			133.68
2009			139.54			132.62			144.37
2010			150.70			143.23			155.92
2011			162.76			154.69			168.39
2012			175.78			167.06			181.86
2013			189.84			180.43			196.41
2014			205.03			194.86			212.13
2015			221.43			210.45			229.10
2016			239.14			227.28			247.42
2017			258.28			245.47			267.22
2018			278.94			265.10			288.59
2019			301.25			286.31			311.68
2020			325.35			309.22			336.62
2021			351.38			333.96			363.55
2022			379.49			360.67			392.63
2023			409.85			389.53			424.04
2024			442.64			420.69			457.96
2025			478.05			454.34			494.60
TOTAL	634.17	143.29	5,705.61	784.43	118.10	5,422.67	995.18	105.50	5,903.15
			6,483.07			6,325.20			7,003.83

Table 3.1.6.3 (10) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Bang Bua Thong North)

(Unit: Million Baht)

Year	Oxidation Ditch			Activated Sludge			RBC		
	Const.	Land	O/M	Const.	Land	O/M	Const.	Land	O/M
1996	89.89	283.44		114.17	188.96		142.35	188.96	
1997	97.08			123.30			153.74		
1998			17.93			17.84			19.47
1999			19.36			19.26			21.03
2000			20.91			20.81			22.71
2001			22.58			22.47			24.52
2002			24.39			24.27			26.49
2003			26.34			26.21			28.61
2004			28.45			28.31			30.89
2005			30.72			30.57			33.37
2006			33.18			33.02			36.04
2007			35.83			35.66			38.92
2008			38.70			38.51			42.03
2009			41.80			41.59			45.39
2010			45.14			44.92			49.03
2011			48.75			48.51			52.95
2012			52.65			52.39			57.18
2013			56.86			56.58			61.76
2014			61.41			61.11			66.70
2015			66.33			66.00			72.03
2016			71.63			71.28			77.80
2017			77.36			76.98			84.02
2018			83.55			83.14			90.74
2019			90.24			89.79			98.00
2020			97.45			96.98			105.84
2021			105.25			104.73			114.31
2022			113.67			113.11			123.45
2023			122.76			122.16			133.33
2024			132.59			131.93			144.00
2025			143.19			142.49			155.52
TOTAL	186.97	283.44	1,709.02	237.47	188.96	1,700.62	296.09	188.96	1,856.13
			2,179.43			2,127.05			2,341.18

Table 3.1.6.3 (11) COMPARISON OF PROJECT COST OF TREATMENT PLANT BY PRESENT VALUE (Bang Bua Thong South)

(Unit: Million Baht)

Year	Oxidation Ditch			Activated Sludge			RBC				
	Const.	Land	O/M	Const.	Land	O/M	Const.	Land	O/M		
	Total			Total			Total				
1996	30.05	8.86		38.91	41.21	3.15	44.36	46.94	3.15	50.09	
1997	32.45			32.45	44.50		44.50	50.69		50.69	
1998			6.83	6.83			6.88		7.55	7.55	
1999			7.38	7.38			7.43		8.16	8.16	
2000			7.97	7.97			8.02		8.81	8.81	
2001			8.61	8.61			8.66		9.51	9.51	
2002			9.30	9.30			9.36		10.27	10.27	
2003			10.04	10.04			10.10		11.10	11.10	
2004			10.84	10.84			10.91		11.98	11.98	
2005			11.71	11.71			11.79		12.94	12.94	
2006			12.65	12.65			12.73		13.98	13.98	
2007			13.66	13.66			13.75		15.10	15.10	
2008			14.75	14.75			14.85		16.30	16.30	
2009			15.93	15.93			16.03		17.61	17.61	
2010			17.21	17.21			17.32		19.02	19.02	
2011			18.58	18.58			18.70		20.54	20.54	
2012			20.07	20.07			20.20		22.18	22.18	
2013			21.67	21.67			21.81		23.96	23.96	
2014			23.41	23.41			23.56		25.87	25.87	
2015			25.28	25.28			25.44		27.94	27.94	
2016			27.30	27.30			27.48		30.18	30.18	
2017			29.49	29.49			29.68		32.59	32.59	
2018			31.85	31.85			32.05		35.20	35.20	
2019			34.39	34.39			34.61		38.02	38.02	
2020			37.14	37.14			37.38		41.06	41.06	
2021			40.12	40.12			40.37		44.34	44.34	
2022			43.33	43.33			43.60		47.89	47.89	
2023			46.79	46.79			47.09		51.72	51.72	
2024			50.53	50.53			50.86		55.86	55.86	
2025			54.58	54.58			54.93		60.33	60.33	
TOTAL	62.50	8.86	651.41	722.77	85.71	3.15	744.45	97.63	3.15	720.01	820.79

3.2.6 Design of Wastewater Collection System

Table 3.2.6 (1) Distribution of Population and Wastewater Quantity (SING BURI)

No. of Sewers Current Down- stream	Commercial Area			Residential Area (Medium)			Residential Area (Low)			Public Land			Industrial Area			Vacant Area			Service Area			Adopted			
	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	
1/1	0.00	200	0	0.00	100	0	28.50	30	855	0	0.00	0	0.00	0	26.60	0	128.90	6.74	855	126.90	6.74	856			
1/2	0.00	200	0	4.50	100	450	6.00	30	180	13.70	0	0.00	0	0.00	0	24.20	26.03	630	24.20	26.03	630				
1/3	0.00	200	0	37.30	100	3,730	0.00	30	0	0.00	0	0.00	0	0.00	0	37.30	100.00	3,730	37.30	100.00	3,730				
1/4	0.00	200	0	23.70	100	2,370	27.40	30	822	0.00	0	0.00	0	0.00	0	51.10	62.47	3,192	51.10	62.47	3,192				
1/5	0.00	200	0	5.10	100	510	37.30	30	1,119	6.80	0	0.00	0	0.00	0	49.20	33.11	1,629	49.20	33.11	1,629				
2/1	0.00	200	0	0.00	100	0	0.00	30	0	0.00	0	26.40	0	47.30	0	73.70	0.00	0	73.70	0.00	0	73.70	0.00	235	
2/2	0.00	200	0	0.00	100	0	0.00	30	0	3.30	0	18.50	0	63.70	0	87.50	0.00	0	87.50	0.00	0	87.50	0.00	278	
2/3	0.00	200	0	0.00	100	0	0.00	30	0	13.90	0	0.00	0	67.40	0	81.30	0.00	0	81.30	0.00	0	81.30	0.00	257	
2/4	0.00	200	0	0.00	100	0	5.60	30	168	1.70	0	0.00	0	27.30	0	34.60	4.88	168	34.60	4.88	168	34.60	4.88	109	
1/6	0.00	200	0	0.00	100	0	14.50	30	435	2.20	0	0.00	0	0.00	0	16.70	26.05	435	16.70	26.05	435	16.70	26.05	55	
1/7	0.00	200	0	0.00	100	0	22.00	30	660	0.00	0	0.00	0	21.00	0	43.00	15.35	660	43.00	15.35	660	43.00	15.35	137	
1/8	0.00	200	0	0.00	100	0	0.00	30	0	18.20	0	0.00	0	42.20	0	60.50	0.00	0	60.50	0.00	0	60.50	0.00	192	
S.T.	0.00		0	70.60		7,060	141.30		4,238	73.60		44.90		355.50		686.00	16.47	11,299	686.00	16.47	11,299	686.00	16.47	11,300	
3/1	0.00	200	0	0.00	100	0	55.90	30	1,977	0.00	0	0.00	0	0.00	0	65.90	30.00	1,977	65.90	30.00	1,977	65.90	30.00	1,977	
3/2	8.50	200	1,700	24.40	100	2,440	39.80	30	1,194	1.10	0	0.00	0	0.00	0	73.80	72.28	5,334	73.80	72.28	5,334	73.80	72.28	5,334	
4/1	1.90	200	380	2.70	100	270	23.60	30	708	0.00	0	0.00	0	0.00	0	28.20	48.16	1,358	28.20	48.16	1,358	28.20	48.16	1,356	
4/2	18.60	200	3,720	31.60	100	3,160	20.00	30	600	0.00	0	0.00	0	12.10	0	82.30	90.89	7,490	82.30	90.89	7,490	82.30	90.89	7,481	
3/3	27.40	200	5,480	0.00	100	0	0.00	30	0	2.40	0	0.00	0	0.00	0	29.80	183.89	5,480	29.80	183.89	5,480	29.80	183.89	5,480	
3/4	8.50	200	1,700	17.40	100	1,740	0.00	30	0	9.60	0	0.00	0	0.00	0	35.50	96.90	3,440	35.50	96.90	3,440	35.50	96.90	3,440	
3/5	0.00	200	0	11.20	100	1,120	0.00	30	0	22.00	0	0.00	0	0.00	0	33.20	33.73	1,120	33.20	33.73	1,120	33.20	33.73	1,113	
5/1	0.00	200	0	0.00	100	0	31.20	30	936	9.90	0	0.00	0	0.00	0	41.10	22.77	936	41.10	22.77	936	41.10	22.77	936	
3/6	0.00	200	0	0.00	100	0	0.00	30	0	0.00	0	0.00	0	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	
3/7	0.00	200	0	0.00	100	0	109.10	30	3,273	6.10	0	0.00	0	0.00	0	115.20	28.41	3,273	115.20	28.41	3,273	115.20	28.41	3,274	
S.T.	64.90		12,980	87.30		8,730	289.60		8,688	51.10		0.00		12.10		505.00	60.19	30,398	505.00	60.19	30,398	505.00	60.19	30,391	
Total	64.90		12,980	157.90		15,790	430.90		12,927	124.70		44.90		367.60		1,191.00	35.01	41,697	1,191.00	35.01	41,697	1,191.00	35.01	41,691	
Adopted	52.20			164.70			493.00		105.90			36.90		338.90		1,191.00		41,700							

Table 3.2.6 (2) Hydraulic Calculation for Design of Sewers (SHING BURI-EAST)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow		Grand Total Flow	Designing of Sewers						Remarks	
		Area	Total	Length	Total		Rainfall	Ran-off Coeff.	Area	Arranged Area	Rainfall		Pop. Density	Population	Design Flow	Slope	Velocity	Flow		Elevation
		ha	ha	m	m	min	m ² /sec-ha	ha	ha	m ³ /sec	Per/ha	Person	m ³ /sec	%	m/sec	m ³ /sec	M	M	m	
1-1A		12690	12690	1700	1700					5.74	856	856	0.012	200	0.61	0.043	1126	9930	100	
1-1B		000	12690	0	1700					0.00	0	856	0.012	200	0.61	0.043	1150	6110	506	
1-1C		000	12690	1000	2700					0.00	0	856	0.012	200	0.61	0.043	1150	6110	506	P. U
1-2		2420	15170	250	2950					25.03	630	1485	0.022	200	0.61	0.043	1175	7473	395	
1-3A		3730	18640	0	2950					100.03	730	5216	0.076	140	0.62	0.078	1155	6905	431	P. U
1-3B		000	18640	1000	3950					0.00	0	5216	0.076	150	0.64	0.081	1155	10124	109	
1-4		5110	23950	1250	5200					62.47	192	8408	0.122	130	0.69	0.136	1150	8274	258	
1-5A		4920	28870	800	6000					33.11	1629	10037	0.146	130	0.78	0.221	1201	5004	636	
1-5B	1-6	000	28870	0	6000					0.00	0	10037	0.146	130	0.64	0.125	1201	5519	595	P. U
2-1		7370	7370	550	550					3.18	235	235	0.003	200	0.61	0.043	1201	10680	100	
2-2		8750	16120	650	1200					3.18	278	513	0.007	200	0.61	0.043	1313	9445	326	
2-3A		8130	24250	0	1200					3.16	257	770	0.011	200	0.61	0.043	1270	7981	439	
2-3B		000	24250	1900	3100					0.00	0	770	0.011	200	0.61	0.043	1270	7981	439	P. U
2-4A		3450	27730	40	3140					3.16	109	879	0.013	200	0.61	0.043	1236	7109	492	
2-4B		000	27730	0	3140					0.00	0	879	0.013	200	0.61	0.043	1200	5906	576	
																	1200	5906	576	P. U
																	1200	10557	101	

Table 3.2.6 (4) Hydraulic Calculation for Design of Sewers (SHING BURI-WEST)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm				Wastewater Flow			Other W. W		Designing of Sewers						Remarks		
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Area	Arranged Area	Rainfall	Pop. Density	Population	Design Flow	Sewer	Total	Grand Total	Diameter	Slope	Velocity	Flow		Elevation	Invert Level
		ha	ha	m	m	min	m ³ /sec-ha	ha	ha	m ³ /sec	Person/ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M.	M	m	
3-1		6590	6590	1150	1150						30.00	1977	1977	0.029		0.029	300	2.00	0.51	0.043	1133	10500	130	
3-2	3-3	7330	13970	380	1530						72.28	335	7312	0.106		0.106	500	1.10	0.54	0.125	1093	7599	259	
4-1		2820	2820	400	400						48.16	1359	1359	0.020		0.020	300	2.00	0.51	0.043	1190	10570	100	
4-2		8240	11060	510	910						90.90	7490	8849	0.129		0.129	600	1.10	0.72	0.204	1222	3380	219	
3-3		2930	2830	700	2230						183.95	21640	21640	0.315		0.315	800	1.50	1.02	0.512	1075	6878	301	
3-4		3550	31550	1100	3330						96.90	3440	25080	0.365		0.365	800	1.50	1.02	0.512	1081	5728	422	
3-5		090	31560	0	3330						0.00	0	25080	0.365		0.365	800	0.90	0.79	0.337	1095	3930	535	U
3-5B	3-6	3310	34870	440	3770						33.53	1110	26190	0.381		0.381	800	1.50	1.02	0.512	1095	8900	198	
5-1		4130	4110	670	670						22.77	936	936	0.014		0.014	300	2.00	0.51	0.043	1170	10370	100	
3-6		090	38980	23	3793						0.00	0	27126	0.395		0.395	800	1.50	1.02	0.512	1225	7225	416	
3-7	T. PL ANT	11520	50500	430	4223						28.42	3274	30400	0.443		0.443	800	1.50	1.02	0.512	1049	7182	254	

Table 3.3.6 Design of Wastewater Collection System

Table 3.3.6 (1) Distribution of Population and Wastewater Quantity (LOP BURI)

Current Sewer	No. of Sewers	Commercial Area			Residential Area (Medium)			Residential Area (Low)			Public Land			Industrial Area			Vacant Area			Service Area			Adopted		
		Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)
1/1		0.00	200	0	57.50	100	5,750	45.20	30	1,356	50.50	0	0.00	0	0.00	0	170.50	41.53	7,106	170.50	42.50	7,246			
1/2		51.50	200	10,320	7.10	100	710	0.00	30	0	8.50	0	0.00	0	0.00	0	75.50	145.90	11,030	75.50	136.50	10,319			
	1/3																								
2/1		11.90	200	2,380	57.00	100	5,700	25.00	30	750	0.00	0	0.00	0	0.00	0	132.50	66.59	8,830	132.50	38.85	5,152			
2/2		0.00	200	0	0.00	100	0	0.00	30	0	0.00	0	0.00	0	0.00	0	0.00	0.00	0	0.00	0	0			
1/3		28.20	200	5,640	18.90	100	1,890	0.00	30	0	0.30	0	0.00	0	0.00	0	47.80	157.53	7,530	47.80	136.50	6,525			
	1/4																								
3/1		14.80	200	2,960	26.10	100	2,610	0.00	30	0	5.50	0	0.00	0	0.00	0	48.50	114.35	5,570	48.50	136.50	6,820			
1/4		0.00	200	0	26.20	100	2,620	9.60	30	288	0.00	0	0.00	0	0.00	0	36.70	79.24	2,908	36.70	71.16	2,612			
	1/5																								
4/1		0.00	200	0	10.90	100	1,090	0.00	30	0	22.50	0	0.00	0	0.00	0	33.40	32.34	1,050	33.40	71.16	2,377			
1/5		0.00	200	0	0.00	100	0	0.00	30	0	0.00	0	0.00	0	0.00	0	0.00	0.00	0	0.00	0	0			
1/6		0.00	200	0	8.90	100	890	0.00	30	0	13.70	0	0.00	0	0.00	0	39.80	22.36	890	39.80	44.32	1,764			
	1/7																								
5/1		0.00	200	0	0.00	100	0	52.00	30	1,560	0.00	0	0.00	0	0.00	0	69.10	22.58	1,560	69.10	23.35	1,613			
5/2		0.00	200	0	0.00	100	0	1.70	30	51	0.00	0	0.00	0	0.00	0	3.00	17.00	51	3.00	23.95	70			
	5/3																								
6/1		0.00	200	0	43.30	100	4,330	13.60	30	408	8.70	0	0.00	0	0.00	0	104.40	45.38	4,738	104.40	40.06	4,182			
6/2		25.30	200	5,060	15.90	100	1,590	0.00	30	0	6.40	0	0.00	0	0.00	0	52.50	126.43	6,650	52.50	40.06	2,107			
5/3		0.00	200	0	0.00	100	0	0.00	30	0	1.50	0	0.00	0	0.00	0	27.10	0.00	0	27.10	98.71	2,675			
5/4		0.00	200	0	5.10	100	510	37.40	30	1,122	2.00	0	0.00	0	0.00	0	60.80	26.84	1,632	60.80	98.71	6,002			
1/7		0.00	200	0	0.00	100	0	2.20	30	66	1.20	0	0.00	0	0.00	0	33.40	1.98	66	33.40	13.23	442			
	1/8																								
7/1		0.00	200	0	0.00	100	0	33.90	30	1,017	2.00	0	0.00	0	0.00	0	60.60	16.78	1,017	60.60	16.68	1,005			
7/2		0.00	200	0	0.00	100	0	21.40	30	642	0.00	0	0.00	0	0.00	0	27.10	23.69	642	27.10	21.62	586			
1/8	T.P	0.00	200	0	0.00	100	0	0.00	30	0	0.00	0	0.00	0	0.00	0	0.00	0.00	0	0.00	0.00	0			
Total		131.80		26,360	276.80		27,680	242.00		7,260	122.90		0.00		0.00		1,023.00	56.92	61,300	1,023.00	59.92	61,296			
Adopted		78.60						232.50		188.60			0.00		0.00		323.20		61,300						

Table 3.3.6 (2) Hydraulic Calculation for Design of Sewers (LOP BURI)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W. W.		Designing of Sewers						Remarks				
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Area	Arranged Area	Rainfall	Pop. Density	Pop. Sewer	Person	Design Flow	Sewer	Total	Grand Total	Diameter	Slope		Velocity	Flow	Elevation	Invert Level
		ha	ha	m	m	min	mm/sec-ha	ha	ha	m ³ /sec	Psy/ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	M	m	m
1-1A		17050	17050	730	730						42.50	7247	7247	0.06		0.06	500	130	0.89	0.136	1130	11338	1300		
1-1B		090	17050	50	790						0.00	0	7247	0.06		0.06	300	400	0.87	0.061	1130	4550	692		FUSEKOSI
1-1C		090	17050	0	790						0.00	0	7247	0.06		0.06	500	110	0.84	0.125	1177	4310	713		
1-2	1-3	7550	24610	1180	1970						136.51	10320	17567	256		0.256	800	130	0.85	0.477	1177	9458	145		
2-1		13250	13250	1440	1440						38.85	5152	5152	0.075		0.075	400	150	0.84	0.081	1020	8765	100		
2-2A		090	13250	70	1510						0.00	0	5152	0.075		0.075	400	150	0.84	0.081	1089	5906	435		
2-2B		090	13250	0	1510						0.00	0	5152	0.075		0.075	600	090	0.85	0.184	1139	3792	695		P. U
1-3	1-4A	4730	42650	950	2920						136.56	29244	0.426		0.426	800	130	0.95	0.477	1139	7768	276			
3-1		4850	4850	620	620						136.56	6621	0.996		0.996	500	130	0.89	0.136	1130	9410	195			
1-4A		3670	51170	450	3370						71.16	2611	38476	0.560		0.560	1000	130	1.10	0.864	940	5128	319		
1-4B		090	51170	0	3370						0.00	0	38476	0.560		0.560	1000	060	0.75	0.587	1095	4396	537		
1-4C	1-5	090	51170	400	3770						0.00	0	38476	0.560		0.560	1000	130	1.10	0.864	1095	8790	198		
4-1		3340	3340	320	320						71.16	2377	0.935		0.935	300	200	0.81	0.943	1250	11312	106			

Table 3.3.6 (3) Hydraulic Calculation for Design of Sewers (LOP BURI)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W.W		Designing of Sewers						Remarks			
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Area	Total	Area	Total	Population	Design Flow	Sewer	Total	Grand Total	Diameter	Slope	Velocity		Flow	Elevation	Invert Level
		ha	ha	m	m	min	mm/sec-ha	ha	ha	ha	ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	m	
1-5		000	54510	45	3815							0.00	0	40853	0595		600	0.90	0.65	0184	1120	4349	630	
1-6A		000	54510	0	3815							0.00	0	40853	0595		800	0.70	0.70	0350	1302	4399	776	
1-6B	1-7	3980	58430	485	4300							44.32	1764	42517	0521		1000	1.30	1.10	0364	1302	7345	399	
5-1		6810	6910	1650	1650							23.35	1614	1514	0024		300	2.00	0.51	0343	1043	9100	130	
5-2A		300	7210	0	1650							23.35	70	1684	0025		300	2.00	0.51	0343	973	5384	432	
5-2B		000	7210	130	1780							0.00	0	1684	0025		200	2.50	0.68	0021	973	12100	257	
5-2C	5-3	000	7210	440	2220							0.00	0	1684	0025		300	2.00	0.51	0343	1029	8360	130	
5-1A		10440	10440	1500	1500							40.06	4183	4183	0061		400	1.50	0.64	0381	1085	9415	130	
5-1B		000	10440	0	1500							0.00	0	4183	0061		300	2.00	0.61	0343	1120	6304	396	
5-1C		000	10440	800	2300							0.00	0	4183	0061		400	1.50	0.64	0381	1120	6304	396	
5-2A		5250	15790	0	2300							40.06	2107	6290	0092		500	1.10	0.64	0125	1150	8310	276	
5-2B		000	15790	130	2430							0.00	0	6290	0092		200	1.90	1.82	0357	1150	12300	150	
5-3		2710	25620	150	2580							98.71	2674	10548	0155		600	1.30	0.78	0221	1097	7580	284	
5-4A		6030	31790	0	2580							98.71	6002	16650	0242		600	1.30	0.78	0221	1429	7454	619	

3.4.6 Design of Wastewater Collection System

Table 3.4.6 (1) Distribution of Population and Wastewater Quantity (ANG THONG)

Current Sewer	No. of Sewers	Commercial Area		Residential Area (Medium)		Residential Area (Low)		Public Land		Industrial Area		Vacant Area		Service Area		Adopted								
		Area (ha)	P.Dens (p./ha)	Design P. (person)	Area (ha)	P.Dens (p./ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	P.Dens (p./ha)	Design P. (person)	Area (ha)	P.Dens (p./ha)	Design P. (person)					
1/1		0.00	120	0	0.00	20	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	67.30	0.00	0	67.30	16.72	1,125	
1/2		0.00	120	0	0.00	20	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	20.90	0.00	0	20.90	16.72	343	
2/1		0.00	120	0	0.00	20	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	58.60	0.00	0	58.60	16.72	980	
1/3		0.00	120	0	0.00	20	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0.00	0	0.00	0.00	0	
1/4		0.00	120	0	8.00	5.00	20	100	2.10	0	0.00	0	0.00	0	15.10	38.41	580	15.10	38.41	580	15.10	16.72	252	
3/1		2.00	120	240	20.40	60	1,224	45.10	20	902	11.00	0	0.00	0	78.50	30.14	2,366	78.50	30.14	2,366	78.50	16.72	1,313	
4/1		2.10	120	252	9.50	60	570	57.40	20	1,148	5.10	0	0.00	0	74.10	26.59	1,970	74.10	26.59	1,970	74.10	16.72	1,239	
1/5		0.00	120	0	0.00	20	0	0.00	0	0.00	0	0.00	0	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	
5/1		4.40	120	528	9.20	60	552	15.60	20	312	23.60	0	0.00	0	52.80	26.36	1,392	52.80	26.36	1,392	52.80	32.19	1,700	
5/2		6.40	120	768	2.80	60	168	9.60	20	192	2.70	0	0.00	0	21.50	52.47	1,128	21.50	52.47	1,128	21.50	32.19	652	
5/3		0.00	120	0	18.90	60	1,134	3.00	20	60	7.10	0	0.00	0	29.00	41.17	1,194	29.00	41.17	1,194	29.00	57.23	1,660	
1/6		19.80	120	2,376	13.90	60	834	8.80	20	176	1.00	0	0.00	0	43.50	77.84	3,386	43.50	77.84	3,386	43.50	57.23	2,490	
1/7		0.00	120	0	11.70	60	702	39.10	20	782	5.90	0	0.00	0	56.70	26.17	1,484	56.70	26.17	1,484	56.70	29.98	1,700	
1/8		0.00	120	0	0.00	20	0	0.00	0	0.00	0	0.00	0	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	
T.P																								
Total		34.70		4,164	94.40		5,664	183.60		3,672	83.00		122.30		518.00	26.06	13,500	518.00	26.06	13,500	518.00	26.06	13,499	
Adopted		23.00			51.80			127.30		54.40			261.50		518.00			518.00			518.00			

Table 3.4.6 (2) Hydraulic Calculation for Design of Sewers (ANG THONG)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm				Wastewater Flow			Other W. W.		Grand Total	Designing of Sewers						Remarks	
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Area	Total	Rainfall	Pop Density	Population Sewer	Person	Design Flow		Sewer	Total	Design Flow	Diameter	Slope	Velocity		Flow
		ha	ha	m	m	min	m ³ /sec-ha	ha	ha	m ³ /sec	Person/ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	M	m
1-1		5730	5730	1150	1150						16.72	1126	0.016			0.016	300	200	0.61	0.043	793	6300	100	
1-2	1-3A	2090	8820	30	1180						16.72	349	0.021			0.021	300	200	0.61	0.043	696	3731	230	
2-1		5860	5860	800	800						16.72	980	0.014			0.014	300	200	0.61	0.043	656	5230	100	
1-3A		000	14680	0	1180						0.00	0	0.036			0.036	300	200	0.61	0.043	737	2504	444	P. U
1-3B		000	14680	1500	2680						0.00	0	0.036			0.036	300	150	0.53	0.037	737	5955	108	
1-3C		000	14680	0	2680						0.00	0	0.036			0.036	300	200	0.61	0.043	750	3475	330	P. U
1-3D		000	14680	690	3270						0.00	0	0.036			0.036	300	150	0.53	0.037	750	6205	107	
1-4A		1510	16130	30	3400						16.72	252	0.039			0.039	400	140	0.62	0.078	790	5003	256	
1-4B		090	16130	0	3400						0.00	0	0.039			0.039	400	200	0.74	0.093	790	3176	429	
1-4C	1-5A	090	16130	590	3990						0.00	0	0.039			0.039	400	140	0.62	0.078	750	3134	403	P. U
3-1	1-5A	7850	7850	650	650						16.72	1313	0.019			0.019	300	200	0.61	0.043	780	6150	102	
4-1		7410	7410	880	980						16.72	1239	0.018			0.018	300	200	0.61	0.043	780	5870	100	
1-5A		090	31450	0	3990						0.00	0	0.077			0.077	400	140	0.62	0.078	730	4415	293	P. U

Table 3.4.6 (3) Hydraulic Calculation for Design of Sewers (ANG THONG)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W.W		Designing of Sewers						Remarks										
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Arranged Area	Total	Rainfall	Pop. Density	Person	Sewer	Total	Design Flow	Sewer	Total	Grand Total	Diameter		Slope	Velocity	Flow	Elevation	Invert Level	Earth Cover				
		ha	ha	m	m	min	m ² /sec·ha	ha	ha	m ² /sec	Per/ha	Person	m ² /sec	m ² /sec	m ² /sec	m ² /sec	m ² /sec	m ² /sec	mm	%	m/sec	m ³ /sec	M	M	M	m					
1-5B	1-6	000	31430	210	4200						0.00	0	5259	0077					200	1200	149	0047	730	8000	040		8000-027	旺盛管			
5-1		5280	5280	530	530						32.19	1700	1700	0025					300	200	051	0043	713	5800	190						
5-2A		2150	7430	70	600						32.19	692	2392	0035					300	150	053	0037	820	4597	327						
5-2B		000	7430	0	500						0.00	0	2392	0035					300	200	051	0043	757	0975	537	P.U					
5-2C		000	7430	260	850						0.00	0	2392	0035					300	150	053	0037	750	5790	148						
5-3		2500	10330	470	1330						57.23	1650	4052	0059					400	140	052	0078	627	5238	130						
1-6		4350	46130	620	4820						57.23	2489	11800	0172					600	110	072	0204	792	4259	301						
1-7A		5570	51830	0	4820						29.98	1700	13500	0197					600	090	055	0184	751	3432	353						
1-7B		000	51830	930	5750						0.00	0	13500	0197					600	110	072	0204	751	5904	106						
1-8	T-PL ANT	000	51830	480	5230						0.00	0	13500	0197					600	110	072	0204	833	4644	304						

3.5.6 Design of Wastewater Collection System

Table 3.5.6 (1) Distribution of Population and Wastewater Quantity (PA MOK)

No. of Sewers (Current Down- stream Sewer)	Commercial Area		Residential Area (Medium)		Residential Area (Low)		Public Land		Industrial Area		Vacant Area		Service Area		Adopted						
	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)			
1/1	8.70	120	1,044	8.80	60	528	30.60	20	612	0	0.00	0	39.00	0	125.70	17.37	2,184	125.70	17.59	2,211	
1/2	0.00	120	0	29.90	60	1,794	0.00	0	0.00	0	0.00	0	0.00	0	28.90	60.00	1,794	29.90	17.59	526	
1/3	0.00	120	0	5.20	60	312	17.00	20	340	0	0.00	0	0.00	0	22.70	28.72	652	22.70	17.59	399	
1/4	0.00	120	0	6.20	60	372	49.50	20	990	0	0.00	0	16.00	0	89.10	15.29	1,362	89.10	17.59	1,567	
2/1	0.00	120	0	3.00	60	180	32.00	20	640	0	0.00	0	85.60	0	120.60	6.80	820	120.60	17.59	2,121	
1/5	0.00	120	0	0.00	60	0	25.20	20	504	0	0.00	0	1.20	0	27.00	18.67	504	27.00	17.59	475	
S.T.	8.70		1,044	53.10		3,186	154.30		3,086	57.10		141.80			415.00	17.63	7,316	415.00	17.59	7,300	
3/1	0.00	120	0	0.00	60	0	13.10	20	262	24.20	0	0.00	0	79.40	0	116.70	2.25	262	116.70	22.73	2,653
3/2	2.30	120	276	35.00	60	2,100	0.00	20	800	8.00	0	0.00	0	7.00	0	52.30	45.43	2,376	52.30	22.73	1,189
3/3																					
4/1	3.70	120	444	13.30	60	798	13.70	20	274	4.00	0	0.00	0	2.60	0	37.30	40.64	1,516	37.30	20.00	746
4/2	0.00	120	0	0.00	60	0	17.90	20	358	1.60	0	0.00	0	2.00	0	21.50	16.65	358	21.50	20.00	490
3/3	5.00	120	600	3.50	60	210	4.00	20	80	0.00	0	0.00	0	0.00	0	12.50	71.20	890	12.50	22.73	284
3/4	0.00	120	0	0.00	60	0	0.00	20	0	0.00	0	0.00	0	0.00	0	0.00	0	0	0.00	0.00	0
3/5	0.00	120	0	0.00	60	0	28.90	20	598	7.50	0	0.00	0	20.30	0	57.70	10.36	598	57.70	12.09	698
3/6	0.00	120	0	0.00	60	0	0.00	20	0	0.00	0	0.00	0	0.00	0	0.00	0	0	0.00	0.00	0
S.T.	11.00		1,320	51.80		3,108	78.60		1,572	45.30		111.30			296.00	20.13	6,000	296.00	20.13	6,000	
Total	19.70		2,364	104.90		6,294	232.90		4,656	102.40		253.10			713.00	18.68	13,316	713.00	18.68	13,316	
Adopted	19.70			104.90			232.10			47.00		309.30			713.00		13,300				

Table 3.5.6 (2) Hydraulic Calculation for Design of Sewers (PA MOK-EAST/WEST)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W.W		Grand Total	Designing of Sewers						Remarks		
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Arranged Area	Rainfall	Pop. Density	Population	Design Flow	Sewer		Total	Design Flow	Diameter	Slope	Velocity	Flow		Elevation	Invert Level
		ha	ha	m	m	min	m ³ /sec-ha	ha	ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	M	m		
1-1		12577	12577	765	765					17.59	2213	0.032			300	150	0.53	0.037	654	5300	101	5300	101	
1-2		2890	15587	480	1245					17.59	526	0.040			400	140	0.52	0.078	528	3943	101	3943	101	
1-3A		2270	17837	530	1775					17.59	399	0.046			400	140	0.52	0.078	528	3943	100	3943	100	
1-3B		000	17837	0	1775					0.00	0	0.046			400	140	0.52	0.078	650	2159	391	2159	391	
1-4	1-5	8910	26747	1580	3355					17.59	1567	0.069			400	140	0.52	0.078	650	5046	102	5046	102	
2-1		12060	12060	1800	1800					17.59	2122	0.031			300	150	0.53	0.037	658	5350	100	5350	100	
1-5	T.P.L ANT	2700	41507	100	3455					17.59	475	0.106			500	130	0.64	0.125	655	1960	413	1960	413	
3-1A		11670	11670	1550	1550					22.73	2653	0.039			400	140	0.62	0.078	610	5225	130	5225	130	
3-1B		090	11670	0	1550					0.00	0	0.039			300	200	0.61	0.043	610	2659	301	2659	301	
3-2	3-3	5230	16930	800	2350					22.73	1189	0.056			400	140	0.62	0.078	610	4800	107	4800	107	
4-1		3730	3730	600	600					20.00	746	0.011			300	200	0.61	0.043	550	4170	100	4170	100	
4-2		2150	5880	450	1050					20.00	430	0.017			300	200	0.61	0.043	570	2809	256	2809	256	
3-3		1250	24030	440	2790					22.73	284	0.077			400	140	0.62	0.078	586	1779	375	1779	375	

3.6.6 Design of Wastewater Collection System

Table 3.6.6 (1) Distribution of Population and Wastewater Quantity (SENA)

No. of Sewers Current Down- stream	Commercial Area		Residential Area (Medium)		Residential Area (Low)		Public Land		Industrial Area		Vacant Area		Service Area		Adopted				
	Area (ha)	P.Dens. (p./ha)	Area (ha)	P.Dens. (p./ha)	Area (ha)	P.Dens. (p./ha)	Area (ha)	P.Dens. (p./ha)	Area (ha)	P.Dens. (p./ha)	Area (ha)	P.Dens. (p./ha)	Area (ha)	P.Dens. (p./ha)	Area (ha)	P.Dens. (p./ha)			
1/1	0.00	200	0	12.30	100	1,230	0	13.70	0	0.00	0	0.00	0	52.40	38.59	2,022	52.40	47.24	2,475
1/2	4.60	200	920	4.80	100	480	24.90	30	747	0	0.00	0	36.40	58.98	2,147	36.40	47.24	1,720	
1/3	1.40	200	280	4.20	100	420	2.30	30	69	0	0.00	0	7.90	97.34	769	7.90	47.24	373	
1/4	0.00	200	0	9.30	100	930	5.10	30	153	0	0.00	0	20.70	52.32	1,083	20.70	47.24	978	
2/1	0.00	200	0	0.00	100	0	5.30	30	159	0	0.00	0	5.70	27.89	159	5.70	47.24	269	
2/3A	5.30	200	1,060	1.30	100	130	1.00	30	30	0	0.00	0	8.70	0.00	1,220	8.70	47.24	411	
2/3c	0.00	200	0	3.40	100	340	10.70	30	321	0	0.00	0	28.00	23.61	661	28.00	47.24	1,323	
1/4 T.P	0.00	200	0	5.00	100	500	28.00	30	840	0	0.00	0	39.20	34.18	1,340	39.20	47.24	1,852	
Total	11.30		2,260	40.30		4,030	103.70		3,111	37.00	6.70	199.00	199.00	9,401	199.00	9,401	199.00	9,401	
Adopted	13.60			40.80		36.60		23.30	0.00	0.00	34.80	199.00	199.00	9,400	199.00	9,400	199.00	9,400	

3.7.6 Design of Wastewater Collection System

Table 3.7.6 (1) Distribution of Population and Wastewater Quantity (RANGSIT)

No. of Sewers Current Sewer stream	Commercial Area			Residential Area (Medium)			Residential Area (Low)			Public Land			Industrial Area			Vacant Area			Service Area			Adopted			
	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	Area (ha)	P.Dens. (p./ha)	Design P. (person)	
1/1	167.40	120	20,088	187.10	60	11,226	40.50	20	810	31.10	0	68.80	0	563.60	57.00	32,124	563.60	57.00	32,124	563.60	57.00	32,124	563.60	57.00	32,124
(101-106)																									
1/3	1/10	0.00	120	0.00	60	19,578	25.50	20	510	0.00	0	0.00	0	351.80	57.10	20,088	351.80	57.10	20,088	351.80	57.10	20,088	351.80	57.10	20,088
2/1	2/3	153.40	120	18,408	60	0	0.00	20	0	18.20	0	0.00	0	190.80	96.48	18,408	190.80	96.48	18,408	190.80	96.50	18,412	190.80	96.50	18,412
3/1	3/3	137.00	120	16,440	60	7,812	0.00	20	0	3.60	0	0.00	0	270.80	89.56	24,252	270.80	89.56	24,252	270.80	89.60	24,264	270.80	89.60	24,264
4/1	4/3	0.00	120	0	60	0	176.00	20	3,520	0.00	0	0.00	0	221.30	15.91	3,520	221.30	15.91	3,520	221.30	15.90	3,519	221.30	15.90	3,519
(5/1-5/2)	5/3	0.00	120	0	60	9,782	65.90	20	1,312	0.00	0	0.00	0	227.80	48.42	11,044	227.80	48.42	11,044	227.80	48.50	11,048	227.80	48.50	11,048
6/4	6/6	55.00	120	6,600	60	12,540	39.10	20	782	2.80	0	0.00	0	305.90	65.13	19,922	305.90	65.13	19,922	305.90	65.10	19,914	305.90	65.10	19,914
6/7	6/10	0.00	120	0	60	7,950	0.00	20	0	0.00	0	0.00	0	132.50	60.00	7,950	132.50	60.00	7,950	132.50	60.00	7,950	132.50	60.00	7,950
6/11	6/14	0.00	120	0	60	0	135.80	20	2,716	0.00	0	51.20	0	227.30	11.95	2,716	227.30	11.95	2,716	227.30	12.00	2,728	227.30	12.00	2,728
(9/1-9/4)	6/15	0.00	120	0	60	0	155.40	20	3,308	0.00	0	0.00	0	399.00	8.29	3,308	399.00	8.29	3,308	399.00	8.30	3,312	399.00	8.30	3,312
(10/1-10/2)	7/1	0.00	120	0	60	7,362	0.00	20	0	0.00	0	0.00	0	162.20	45.39	7,362	162.20	45.39	7,362	162.20	45.40	7,364	162.20	45.40	7,364
7/1	7/4	0.00	120	0	60	0	155.30	20	3,306	0.00	0	0.00	0	277.00	11.94	3,306	277.00	11.94	3,306	277.00	11.90	3,296	277.00	11.90	3,296
8/1	8/3	0.00	120	0	60	0	155.30	20	3,306	0.00	0	0.00	0	277.00	11.94	3,306	277.00	11.94	3,306	277.00	11.90	3,296	277.00	11.90	3,296
Adopted		512.80	61,536	1,270.00	76,200	813,201	16,264	55.70	16,264	55.70	0	120.00	0	558.90	46.25	154,000	512.80	46.25	154,000	512.80	46.25	154,019	512.80	46.25	154,019

Table 3.7.6 (2) Hydraulic Calculation for Design of Sewers (RANGSIT)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other % W		Grand Total	Designing of Sewers						Remarks		
		Area	Total	Area	Total		Area	Total	Area	Total	Pop. Density	Population	Design Flow	Sewer		Total	Diameter	Slope	Velocity	Flow	Elevation		Invert Level	Birth Cover
		ha	ha	ha	ha	min	ha	ha	ha	ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	M	m		
1-1	1-2	56360	56360	1240	1240						57.0232137	32137	601	0364	0364	0965	1200	120	139	1351	250	-0305	100	
2-1		15900	15900	50	50						96.5015344	15344	287			0287	800	160	105	0529	130	-0066	100	
2-2		3180	19080	60	110						96.503069	18413	0345			0345	800	160	105	0529	220	-0156	149	
1-2	1-3A	090	75440	73	1813						0.00	-1	50549	0946		1310	1200	120	139	1351	139	-3637	420	
3-1		24620	24620	710	710						89.6022060	22060	413			0413	800	160	105	0529	243	-0614	100	
3-2		2460	27080	630	1340						89.602204	24264	0454			0454	800	160	105	0529	260	-0633	237	
3-3		000	27080	60	1400						0.00	0	24264	0454		0454	800	160	105	0529	260	-0633	237	
1-3A		000	102520	0	1400						0.00	0	74813	1400		1764	1500	120	139	2449	290	-3555	408	P. U
1-3		1060	103580	220	1620						57.10	605	75416	1411		1775	1500	120	139	2449	319	-0944	252	
1-4		9420	113080	280	1910						57.10	6379	80797	1312		1876	1500	120	139	2449	319	-0944	253	
1-5		090	113080	71	1981						0.00	0	80797	1312		1876	1000	280	152	1269	295	-1332	177	
1-6A		090	113080	0	1981						0.00	0	80797	1312		1876	1500	120	139	2449	450	-3564	453	FUSEKOSI
1-6	1-7A	10990	123990	680	2561						57.10	6275	87072	1330		1894	1500	120	139	2449	450	-3764	655	
																					450	-2015	493	
																					288	-2801	407	

Table 3.7.6 (3) Hydraulic Calculation for Design of Sewers (RANGSIT)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time		Run-off Storm			Wastewater Flow		Other N.W		Grand Total Design Flow	Designing of Sewers						Remarks	
		Area	Total	Length	Total	min	Total	Rainfall	Rainfall Coeff.	Arranged Area	Total	Pop Density	Population	Design Flow		Sewer	Total	Diameter	Slope	Velocity	Flow		Elevation
		ha	ha	m	m			m ³ /sec-ha	ha	ha	Per/ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	M	m
1-1		6940	6940	420	420						15.90	1104	1104	0.021		300	220	0.54	0.045	210	0.770	1.00	
1-2	1-3	6400	13340	320	740						15.90	1018	2122	0.040		300	220	0.54	0.045	214	0.255	2.97	
5-1		4990	4990	300	300						15.90	794	794	0.015		300	220	0.54	0.045	240	1.070	1.00	
5-2		3600	8790	230	530						15.90	604	1398	0.026		300	220	0.54	0.045	215	0.924	1.50	
4-3		800	22130	65	805						0.00	-1	3519	0.066		400	130	0.70	0.088	204	2.671	4.28	
4-4A		800	22130	0	805						0.00	0	3519	0.066		400	130	0.70	0.088	235	2.794	5.21	
4-4		800	22130	50	855						0.00	0	3519	0.066		400	130	0.70	0.088	285	2.194	5.21 P.U.	
1-7A		800	146120	0	2561						0.00	0	90591	1.895	0.364	1500	120	1.39	2.449	288	2.801	4.97 P.U.	
1-7	1-8	10150	156270	700	3261						57.10	5796	96387	1.804	0.384	1500	120	1.39	2.449	288	0.220	1.95	
6-1		11730	11730	430	430						48.50	5714	5714	0.107		500	160	0.77	0.151	180	0.258	1.00	
6-2		9110	20890	570	1000						48.50	4418	10132	0.190		600	160	0.87	0.246	180	0.824	1.78	
6-3		1890	22730	54	1054						48.50	917	11049	0.207		600	160	0.87	0.246	179	1.568	2.83	
6-3A		800	22730	0	1054						0.00	0	11049	0.207		600	160	0.87	0.246	179	4.921	5.47	
6-4		270	23050	200	1254						65.10	176	11225	0.210		600	160	0.87	0.246	180	4.430	5.58 P.U.	

Table 3.7.6 (4) Hydraulic Calculation for Design of Sewers (RANGSIT)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W. W		Designing of Sewers						Remarks				
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Area	Arranged Area	Rainfall	Pop. Density	Population	Design Flow	Sewer	Total	Grand Total	Diameter	Slope	Velocity		Flow	Elevation	Invert Level	Earth Cover
		ha	ha	m	m	min	m ² /sec-ha	ha	ha	m ² /sec	Per/ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	M	m	
6-5		21350	44410	580	1934						65.10	13905	25136	470			800	150	1.05	0.529	249	-0430	211		
6-6		8350	53370	690	2624						65.10	8933	30963	0579			1000	140	1.14	0.897	241	-1367	326		
6-7	6-8A	4420	57750	330	2954						60.00	2552	33615	0829			1000	140	1.14	0.897	235	-2943	422		
7-1		7840	7840	350	350						45.40	3560	3560	0967			400	130	0.70	0.988	200	-0551	130		
7-2		8130	15970	90	440						45.40	3691	7251	0136			500	150	0.77	0.151	180	-0245	150		
7-3		000	15970	54	494						0.00	0	7251	0136			300	500	0.97	0.068	179	-0409	156		
7-3A		000	15970	0	494						0.00	0	7251	0136			500	150	0.77	0.151	225	-4222	615		
7-4		250	16220	240	734						45.40	113	7364	0138			500	150	0.77	0.151	225	-4222	394		
6-8A		000	74010	0	2954						0.00	0	40979	0767			1000	140	1.14	0.897	238	-2034	339 P. U		
6-8		8240	82250	420	3374						60.00	4944	45923	0859			1000	140	1.14	0.897	236	-0245	135		
6-9		590	82840	190	3564						60.00	354	46277	0866			1000	140	1.14	0.897	213	-0700	175		
6-10		000	82840	1620	5184						0.00	0	46277	0866			1000	140	1.14	0.897	213	-0700	175		
6-11		530	83370	200	5384						12.00	63	46340	0867			1000	140	1.14	0.897	270	-3189	431		
6-12A		000	83370	0	5384						0.00	0	46340	0867			1000	140	1.14	0.897	263	-3499	505		
6-12	6-13A	5840	89310	1480	5864						12.00	713	47053	0881			1000	140	1.14	0.897	263	-3939	555 P. U		
																					253	-0529	133		
																					200	-1731	265		

Table 3.7.6 (5) Hydraulic Calculation for Design of Sewers (RANGSIT)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Designing of Sewers						Remarks					
		Area	Total	Length	Total		Rainfall	Ran-off Coeff.	Area	Total	Rainfall	Pop. Density	Population	Design Flow	Other W.W	Grand Total	Diameter	Slope		Velocity	Flow	Elevation	Invert Level	Earth Cover
		ha	ha	m	m	min	m ³ /sec-ha	ha	ha	m ³ /sec	Person/ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	m		
8-1		11650	11650	640	640					11.90	1388	1388	0.026		0.026	300	220	0.84	0.045	230	0.870	130		
8-2		10330	21980	740	1380					11.90	1229	2617	0.049		0.049	400	130	0.70	0.088	230	1.000	257		
8-2A		000	21980	0	1380					0.00	0	2617	0.049		0.049	400	130	0.70	0.088	230	1.000	257		
8-3	6	5710	27700	380	1760					11.90	680	3297	0.062		0.062	400	130	0.70	0.088	230	0.550	132		
																400	130	0.70	0.088	230	0.560	101		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		
																400	130	0.70	0.088	230	0.521	499		

Table 3.7.6 (6) Hydraulic Calculation for Design of Sewers (RANGSIT)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W.W		Designing of Sewers						Remarks								
		Area	Total	Area	Total		Rainfall	Ranoff Coeff.	Area	ha	ha	ha	Pop Density	Person	m ³ /sec	Design Flow	Sewer	Total	Grand Total	Diameter		Slope	Velocity	Flow	Elevation	Invert Level	Earth Cover		
		ha	ha	m	m	min	m ³ /sec-ha	m ³ /sec	mm	mm	mm	mm	mm	mm	mm	mm	mm	mm	mm	mm	%	m/sec	m ³ /sec	m	m	m	m	m	
10-1		13810	13810	750	750					8.30	1147	1147	0.021					0.021			220	0.84	0.045	290	1570	130	-0280	285	
10-2		9550	23350	800	1550					8.30	792	1939	0.036					0.036			220	0.84	0.045	290	-0290	286	-2270	504	
10-2A		090	23350	0	1550					0.00	0	1939	0.036					0.036			220	0.84	0.045	290	-2270	504			
6-15		2750	158630	200	7171					12.00	332	54240	1.015					0.172			1200	1.19	1.351	327	0020	179	-0240	222	
6-16		090	158630	48	7214					0.00	0	54240	1.015					0.172			800	1.39	0.700	327	-0049	645	-4169	657	FUSEKOSI
6-17A		090	158630	0	7214					0.00	0	54240	1.015					0.172			1200	1.19	1.351	327	-4169	614	-0600	258	
6-17		9000	165630	700	7914					8.30	747	54987	1.029					0.172			1200	1.19	1.351	327	0510	259	-1530	318	
6-18		7540	173170	350	8264					8.30	625	55612	1.041					0.172			1200	1.19	1.351	294	-1540	319	-2000	359	
1-8		1650	331130	1690	9954					57.10	947	152946	2.862					0.536			1600		3.558	298	2400	348	-4234	434	
1-9		1900	333090	160	10114					57.10	1085	154031	2.863					0.536			1600		3.558	291	-4244	355	-4414	437	
1-10	T.P.L ANT	090	333090	520	10634					0.00	0	154031	2.863					0.536			1600		3.558	236	-4424	388	-4984	518	

3.8.6 Design of Wastewater Collection System

Table 3.8.6 (1) Distribution of Population and Wastewater Quantity (BANG BUA THONG)

No. of Sewers Current Down- stream	Commercial Area			Residential Area (Medium)			Residential Area (Low)			Public Land			Industrial Area			Vacant Area			Service Area			Adopted		
	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	
1/1	17.20	200	3,440	106.10	100	10,610	15.00	30	450	5.40	0	0.00	0	0.00	0	143.70	100.90	14,500	143.70	100.90	14,500	100.90	14,498	
(101-105)																								
1/4	48.30	200	9,660	4.70	100	470	3.10	30	93	4.60	0	0.00	0	0.00	0	60.70	168.42	10,223	60.70	168.42	10,223	168.40	10,222	
1/7	25.00	200	4,400	25.60	100	2,560	16.40	30	492	0.00	0	0.00	0	0.00	0	64.00	116.44	7,452	64.00	116.44	7,452	116.40	7,450	
(107-108)																								
1/11	0.00	200	0	14.40	100	1,440	11.90	30	357	0.00	0	0.00	0	0.00	0	26.30	68.33	1,797	26.30	68.33	1,797	68.30	1,796	
2/1	7.90	200	1,580	0.00	100	0	20.90	30	627	4.60	0	0.00	0	0.00	0	33.40	66.08	2,207	33.40	66.08	2,207	66.10	2,208	
2/3	0.00	200	0	73.20	100	7,320	19.80	30	594	0.00	0	0.00	0	0.00	0	93.00	85.10	7,914	93.00	85.10	7,914	85.10	7,914	
(201-202)																								
2/8	0.00	200	0	0.00	100	0	2.10	30	63	0.00	0	0.00	0	0.00	0	2.10	30.00	63	2.10	30.00	63	30.00	63	
3/1	0.00	200	0	0.00	100	0	163.80	30	4,914	0.00	0	0.00	0	0.00	0	190.00	25.86	4,914	190.00	25.86	4,914	25.90	4,921	
3/6	0.00	200	0	95.80	100	9,580	0.00	30	0	0.00	0	0.00	0	0.00	0	95.80	100.00	9,580	95.80	100.00	9,580	100.00	9,580	
N.T.	95.40		19,080	319.80		31,980	253.00		7,590	14.60	0	26.20	0	26.20	0	709.00		58,650	709.00		58,650		58,653	
4/1	0.00	200	0	0.00	100	0	157.00	30	4,710	0.00	0	88.00	0	88.00	0	245.00	19.22	4,710	245.00	19.22	4,710	19.20	4,704	
5/1	0.00	200	0	0.00	100	0	52.20	30	1,566	0.00	0	23.80	0	23.80	0	75.80	20.66	1,566	75.80	20.66	1,566	20.70	1,569	
6/1	0.00	200	0	0.00	100	0	121.00	30	3,630	0.00	0	0.70	0	0.70	0	121.70	29.83	3,630	121.70	29.83	3,630	29.80	3,627	
7/1	0.00	200	0	62.70	100	6,270	75.30	30	2,259	0.00	0	0.00	0	0.00	0	139.20	61.27	8,529	139.20	61.27	8,529	61.30	8,533	
7/2	0.00	200	0	0.00	100	0	7.30	30	219	0.00	0	0.00	0	0.00	0	7.30	30.00	219	7.30	30.00	219	30.00	219	
8/1	0.00	200	0	10.50	100	1,050	41.50	30	1,245	0.00	0	0.00	0	0.00	0	52.00	44.13	2,295	52.00	44.13	2,295	44.13	2,295	
S.T.	0.00		0	73.20		7,320	454.30		13,629	0.00	0	113.50	0	113.50	0	841.00	32.68	20,949	841.00	32.68	20,949	32.70	20,946	
Adopted	95.40		19,080	393.00		39,300	707.30		21,219	14.60	0	139.70	0	139.70	0	1,350.00		79,599	1,350.00		79,599		79,600	

Table 3.8.6 (2) Hydraulic Calculation for Design of Sewers (BANG BUA THONG-NORTH)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W.W		Grand Total Flow	Designing of Sewers						Remarks	
		Area	Total	Length	Total		Rainfall	Ran-off Coeff.	Area	Arranged Area	Rainfall	Pop Density	Person	Design Flow		Sewer	Total	Diameter	Slope	Velocity	Flow		Elevation
		ha	ha	m	m	min	m ³ /sec-ha	ha	ha	m ³ /sec	Per/ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	m	
1-1		2840	2840	530	530						100.98266	2866	0.554		0.554	400	1.30	0.70	0.088	155	0.215	100	
1-2A		8300	11340	0	530						100.98577	11443	0.214		0.214	600	1.50	0.87	0.246	254	-2542	453	P. U
1-2		1360	12790	510	1040						100.91372	12815	0.240		0.240	500	1.50	0.87	0.246	254	0.790	110	
1-3		1670	14370	38	1078						100.91685	14500	0.271		0.271	400	4.00	1.05	0.132	189	-3459	302	FUSEKOSI
1-3A		000	14370	0	1078						0.00	0	14500	0.271	0.271	600	1.50	0.87	0.246	194	-3821	491	
1-4		1930	16300	400	1476						168.48250	17750	0.332		0.332	800	1.50	1.05	0.529	194	-0830	172	
1-5		000	16300	15	1493						0.00	0	17750	0.332	0.332	800	1.50	1.05	0.529	219	-1330	257	
1-6	1-7	4140	20440	710	2203						168.46972	24722	0.463		0.463	800	1.50	1.05	0.529	219	-1374	270	
2-1		3340	3340	380	380						56.102208	2208	0.041		0.041	300	2.20	0.64	0.045	174	0.410	190	
2-2		000	3340	15	395						0.00	0	2208	0.041	0.041	300	2.20	0.64	0.045	192	-0527	212	
2-3		6410	9750	710	1105						35.105455	7663	0.143		0.143	500	1.60	0.77	0.151	192	-0750	214	
2-4		2890	12640	170	1375						35.102460	10123	0.189		0.189	600	1.30	0.87	0.246	230	-2165	382	
2-5		000	12640	17	1292						0.00	0	10123	0.189	0.189	600	1.30	0.87	0.246	216	-2475	459	
2-6		210	12850	160	1452						30.00	65	10186	0.191	0.191	600	1.50	0.87	0.246	276	-2485	450	
1-7		000	33290	60	2263						116.4	-1	34907	0.553	0.553	1000	1.40	1.14	0.997	209	-3208	422	

Table 3.8.6 (3) Hydraulic Calculation for Design of Sewers (BANG BUA THONG-NORTH)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W.W		Designing of Sewers						Remarks							
		Area	ha	Area	ha		Length	m	Total	ha	ha	ha	Pop. Density	Person	m ³ /sec	Design Flow	m ³ /sec	Total	m ³ /sec	Diameter		%	Slope	Velocity	m/sec	Flow	m ³ /sec	Elevation
1-8A		3350	36550	0	2263						116.43911	38818	0726		0726				1000	140	114	0897	178	0897	178	-3292.393	192	P. U
1-8		2170	38820	650	2913						116.42526	41344	0774		0774				1000	140	114	0897	178	0897	178	-3330.193	226	
1-9		870	39690	250	3163						116.41012	42356	0793		0793				1000	140	114	0897	231	0897	231	-1341.227	218	
1-10		000	39690	30	3193						0.00	0	0793		0793				1000	140	114	0897	154	0897	154	-1723.218		
1-11	1-12	2630	42320	250	3443						68.301797	44153	0826		0826				1000	140	114	0897	151	0897	151	-2757.322		
3-1		7170	7170	1100	1100						25.901858	1858	0935		0935				300	220	064	0945	272	0945	272	-1390.190		
3-2		000	7170	50	1150						0.00	0	0935		0935				300	220	064	0945	246	0945	246	-2454.459		
3-3A		000	7170	0	1150						0.00	0	0935		0935				300	220	064	0945	246	0945	246	-2584.471		
3-3		5550	12720	930	2080						25.901437	3235	0962		0962				400	130	070	0988	246	0988	246	-1300.193		
3-4		000	12720	50	2130						0.00	0	0962		0962				400	130	070	0988	220	0988	220	-3029.379		
3-5A		000	12720	0	2130						0.00	0	0962		0962				400	130	070	0988	250	0988	250	-2129.413		
3-5		6280	19090	45	2175						25.901626	4921	0992		0992				500	150	077	0151	250	0151	250	-3900.196		
3-6		000	19090	240	2415						0.00	0	0992		0992				500	150	077	0151	250	0151	250	-3474.148		
3-7		9580	26390	470	2885						100.09580	14501	0271		0271				800	150	105	0529	242	0529	242	-0260.131		
1-12	T. PL ANT	000	70900	50	3493						0.00	0	1098		1098				1200	120	119	1351	234	1351	234	-3388.443		

Table 3.8.6 (4) Hydraulic Calculation for Design of Sewers (BANG BUA THONG-SOUTH)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W. F.		Designing of Sewers						Remarks				
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Area	Arranged Area	Rainfall	Pop. Density	Population	Design Flow	Sewer	Total	Grand Total	Diameter	Slope	Velocity		Flow	Elevation	Invert Level	Earth Cover
		ha	ha	m	m	min	m ² /sec-ha	ha	ha	m ² /sec	Person/ha	Person	m ² /sec	m ² /sec	m ² /sec	m ² /sec	mm	%	m/sec	m ³ /sec	M	M	M	m	
4-1		5870	5870	1080	1080						19.20	1128	0.921		0.921	0.921	300	220	0.64	0.945	290	290	0.670	1200	
4-2		2710	8580	760	1840					19.20	520	1648	0.931		0.931	0.931	300	220	0.64	0.945	290	290	0.670	1200	
4-3A		0900	8580	0	1840					0.00	0	1648	0.931		0.931	0.931	400	130	0.70	0.988	151	151	0.650	1000	
4-3	4-1A	9130	17710	1290	3130					19.20	1753	3401	0.964		0.964	0.964	400	130	0.70	0.988	151	151	0.650	1000	
5-1A		1930	1930	0	0					20.70	412	412	0.908		0.908	0.908	300	220	0.64	0.945	276	276	0.823	151	
5-1		0900	1930	40	40					0.00	0	412	0.908		0.908	0.908	300	220	0.72	0.951	276	276	0.812	152	
5-2		2530	4430	760	800					20.70	518	930	0.917		0.917	0.917	300	220	0.64	0.945	293	293	0.690	1201	
5-3A		0900	4430	0	800					0.00	0	930	0.917		0.917	0.917	300	220	0.64	0.945	249	249	0.84	1201	
5-3		3030	7570	750	1550					20.70	637	1567	0.929		0.929	0.929	300	220	0.64	0.945	249	249	0.84	1201	
4-4A		0900	25280	0	3130					0.00	0	4968	0.993		0.993	0.993	500	150	0.77	0.951	250	250	0.900	106	
4-4		530	25810	640	3770					19.20	102	5070	0.995		0.995	0.995	500	150	0.77	0.951	243	243	0.890	137	
4-5	4-6	1670	27430	640	4410					19.20	320	5390	0.101		0.101	0.101	500	150	0.77	0.951	237	237	0.894	218	
5-1		4610	4610	930	930					29.80	1374	1374	0.926		0.926	0.926	300	220	0.64	0.945	252	252	1.190	1300	
5-2	5-3	4610	9220	440	1370					29.80	1374	2748	0.951		0.951	0.951	400	130	0.70	0.988	246	246	1.185	1225	

Table 3.8.6 (5) Hydraulic Calculation for Design of Sewers (BANG BUA THONG-SOUTH)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time		Run-off Storm			Wastewater Flow			Other W.W		Grand Total Design Flow	Designing of Sewers					Remarks				
		Area	Total	Length	Total	min	sec	Rainfall	Rainfall Coeff.	Area	Area Total	Rainfall	Pop Density	Population Sewer	Population Total		Design Flow	Sewer	Total	Design Flow	Velocity		Flow	Elevation	Invert Level	Earth Cover
		ha	ha	m	m			m ³ /sec·ha		ha	ha	m ³ /sec	Per/ha	Person	Person	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	%	m/sec	m ³ /sec	M	M	m	
7-1		13920	13920	350	350							81.308533	8533	0.160		0.160				1.50	0.87	0.246	180	0.150	190	
7-2		730	14650	340	690							30.00	219	0.164		0.164				1.50	0.87	0.246	189	-0.498	174	
6-3		000	23870	15	1385							0.00	0	0.215		0.215				1.50	0.87	0.246	246	-2277	409	
6-4A		000	23870	0	1385							0.00	0	0.215		0.215				1.50	0.87	0.246	246	-2301	411	P.U
6-4	6-5	26820	26820	650	2235							29.80	879	0.232		0.232				1.50	0.87	0.246	246	0.780	102	
8-1		5230	5230	370	370							44.132295	2295	0.043		0.043				3.00	0.64	0.945	223	0.909	130	
8-5		000	32020	15	2250							0.00	0	0.275		0.275				1.50	1.05	0.529	237	0.955	249	
4-6	T.PL ANT	4690	64100	480	4890							19.20	883	0.392		0.392				1.50	1.05	0.529	237	-17.69	327	

PART 3

**PRELIMINARY ENGINEERING DESIGN
OF SEWERAGE SYSTEMS FOR
RANGSIT AREA AND
BANG BUA THONG MUNICIPALITY**

2.6.1 Population Distribution and Hydraulic Calculation

Table 2.6.1.1 Population Distribution

No. of Sewers	Commercial-Area			Residential-Area			Residential-Area			Publicland			IndustrialArea			VacantArea			ServiceArea			Adopted				
	Current/Down-Stream	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	Area (ha)	P.Dens. (p/ha)	Design P. (person)	
1/1	1/2	17.9	120	2,148	35.7	60	2,142	0.0	20	0	0.0	0	68.8	0	56.8	0	189.2	22.67	4,290	189.2	57.00	10,784				
101	104	149.5	120	17,940	151.4	60	9,084	34.1	20	682	9.0	0	0.0	0	0.7	0	344.7	80.38	27,706	344.7	57.00	19,648				
105	106	0.0	120	0	0.0	60	0	6.4	20	128	22.1	0	0.0	0	1.2	0	29.7	4.31	128	29.7	57.00	1,593				
1/3	1/10	0.0	120	0	0.0	60	0	0.0	20	0	0.0	0	0.0	0	0.0	0	0.0	0.00	0	0.0	0.00	0	0.00	0		
2/1	2/2	0.0	120	0	0.0	60	0	0.0	20	0	2.8	0	0.0	0	0.0	0	2.8	0.00	0	2.8	0.00	0	76.50	214		
3/1	3/3	137.0	120	16,440	130.2	60	7,812	0.0	20	0	3.6	0	0.0	0	0.0	0	270.8	89.55	24,252	270.8	89.60	24,264				
4/1	4/3	0.0	120	0	0.0	60	0	111.5	20	2,230	0.0	0	0.0	0	44.6	0	155.1	14.29	2,230	155.1	15.90	2,482				
(5/1-5/2)	5/1	6/3	0.0	120	0	60	0	0.0	20	0	0.0	0	0.0	0	0.0	0	0.0	0.00	0	0.0	0.00	0	0.00	0		
5/4	5/5	0.0	120	0	0.0	60	0	0.0	20	0	0.0	0	0.0	0	0.0	0	0.0	0.00	0	0.0	0.00	0	0.00	0		
5/7	5/10	0.0	120	0	132.5	60	7,950	0.0	20	0	0.0	0	0.0	0	0.0	0	132.5	60.00	7,950	132.5	60.00	7,950				
6/11	6/15	0.0	120	0	0.0	60	0	0.0	20	0	0.0	0	0.0	0	0.0	0	0.0	0.00	0	0.0	0.00	0	0.00	0		
(9/1-9/4)	9/1	6/18	0.0	120	0	60	0	0.0	20	0	0.0	0	0.0	0	0.0	0	0.0	0.00	0	0.0	0.00	0	0.00	0		
(10/1-10/4)	10/1	7/4	0.0	120	0	122.7	60	7,362	0.0	20	0	0.0	0	39.5	0	0.0	0	162.2	45.39	7,362	162.2	45.40	7,364			
8/1	8/3	0.0	120	0	0.0	60	0	0.0	20	0	0.0	0	0.0	0	0.0	0	0.0	0.00	0	0.0	0.00	0	0.00	0		
Adopted		304.4		35,528	572.5		34,350	152.0		3,040	37.5	0	68.8	0	152.8	0	1,288.0	57.39	73,916	1,288.0	57.76	74,399				

Table 2.6.1.2 (1) Hydraulic Calculation for Design of Sewers (Rang Sit)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time		Run-off Storm			Wastewater Flow			Other W. #		Designing of Sewers						Remarks						
		Area	Total	Length	Total	min	Total	Rainfall	Ran-off Coeff.	Area	Area	Arranged Area	Rainfall	Pop Density	Population	Design Flow	Sewer	Total	Grand Total	Design Flow	Diameter		Slope	Velocity	Flow	Elevation	Invert Level	Earth Cover
		ha	ha	m	m		m ³ /sec-ha	mm	ha	ha	ha	m ³ /sec	Person	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	M	m
101A		11150	11150	0	0							80.402873	8973	0.168	0.003	0.003	0.171	500	150	0.77	0.151	232	0.200	158	232	0.200	158	
101		090	11150	150	150						0.00	0	8973	0.168	0.003	0.171	500	150	0.87	0.246	246	0.100	157	246	0.100	157		
102		3950	15150	1110	1260						30.403208	12181	0.228	0.005	0.008	0.236	600	150	0.87	0.246	246	0.150	159	246	0.150	159		
102A		090	15150	0	1260						0.00	0	12181	0.228	0.008	0.236	600	150	0.87	0.246	253	0.2762	474	253	0.2762	474	P. U	
103		090	15150	400	1660						0.00	0	12181	0.228	0.008	0.236	600	150	0.87	0.246	253	0.2891	139	253	0.2891	139		
104		18750	33940	60	1720						80.4015107	27288	0.11	0.008	0.008	0.519	800	150	1.05	0.529	250	0.039	177	250	0.039	177		
1-1	1-2	21650	58830	1240	2960						22.704969	32257	0.504	0.353	0.361	0.965	1200	120	1.19	1.351	139	0.535	134	139	0.535	134		
2-1		280	280	0	0						96.50	271	271	0.005	0.282	0.282	0.287	800	150	1.05	0.529	220	1.345	258	220	1.345	258	
2-2		3130	3450	60	60						96.503068	3339	0.562	0.282	0.282	0.344	800	150	1.05	0.529	220	1.355	269	220	1.355	269		
1-2	1-3A	090	59290	73	3033						0.00	0	35596	0.566	0.643	1.309	1200	120	1.19	1.351	139	0.5607	420	139	0.5607	420		
301		6370	6370	1120	1120						89.605708	5708	0.107	0.107	0.107	0.107	500	150	0.77	0.151	317	1.523	130	317	1.523	130		
302		11700	18070	800	1920						89.6010463	16191	0.303	0.303	0.303	0.303	800	150	1.05	0.529	298	0.7134	294	298	0.7134	294		
303	305	090	18070	40	1960						89.60	0	16191	0.303	0.303	0.303	800	150	1.05	0.529	298	0.714	423	298	0.714	423		

Table 2.6.1.2 (3) Hydraulic Calculation for Design of Sewers (Rang Sit)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W. W		Designing of Sewers						Remarks				
		Area	Total	Length	Total		Rainfall	Run-off Coeff.	Area	Total	Rainfall	Pop. Density	Population	Design Flow	Sewer	Total	Grand Total	Diameter	Slope	Velocity		Flow	Elevation	Invert Level	Earth Cover
5-1		4990	4990	300	300					15.90	794	794	0.015		0.015	0.015	300	2.20	0.54	0.345	24.0	13.10	1.00		
5-2		3830	8790	230	530					15.90	604	1398	0.026		0.026	0.026	300	2.20	0.54	0.345	24.5	0.22	1.50		
4-3		000	13550	65	595					0.00	0	2155	0.040		0.026	0.056	400	1.30	0.70	0.388	20.4	2.57	4.28		
4-4A		000	13550	0	595					0.00	0	2155	0.040		0.026	0.056	400	1.30	0.70	0.388	23.5	-27.94	5.21		P. U
4-4		000	13550	50	645					0.00	0	2155	0.040		0.026	0.056	400	1.30	0.70	0.388	28.5	13.70	1.35		
1-7A		000	99920	0	4981					0.00	-1	62014	1.161		0.399	2.050	1500	1.20	1.39	2.449	28.2	-23.01	4.77		P. U
1-7		000	99920	700	5681					57.10	0	62014	1.161		1.007	2.166	1500	1.20	1.39	2.449	28.8	0.20	1.35		
6-5		000	000	0	0					55.10	0	0	0.000		0.580	0.580	1000	1.40	1.14	0.897	24.7	-29.33	4.21		
6-7		4420	4420	330	330					60.00	2652	2652	0.050		0.580	0.630	1000	1.40	1.14	0.897	23.6	-29.33	4.21		
7-1		4970	4970	225	225					45.40	2257	2257	0.042		0.042	0.042	300	2.20	0.54	0.345	18.0	0.470	1.00		
7-1		2870	7840	350	575					45.40	1303	3560	0.067		0.067	0.067	400	1.30	0.70	0.388	20.0	-0.134	1.75		
7-2		6130	6130	350	350					45.40	2797	2797	0.052		0.052	0.052	400	1.30	0.70	0.388	17.5	0.315	1.30		
7-3		1970	8130	120	470					45.40	895	3592	0.059		0.059	0.059	400	1.30	0.70	0.388	17.9	-0.414	1.77		

Table 2.6.1.2 (4) Hydraulic Calculation for Design of Sewers (Rang Sit)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W.W		Grand Total Flow	Designing of Sewers						Remarks	
		Area	Total	Length	Total		Rainfall	Rainfall Coeff.	Area	Arranged Area	Rainfall	Pop Density	Population	Design Flow		Sewer	Total	Diameter	Slope	Velocity	Flow		Elevation
		ha	ha	m	m	min	m ² /sec·ha	ha	ha	m ² /sec	Person/ha	Person	m ³ /sec	m ³ /sec	m ³ /sec	mm	%	m/sec	m ³ /sec	M	M	m	m
7-2		000	15970	90	665					0.00	-1	7251	0.136		0.136	500	1.60	0.77	0.151	130	-0.934	225	
7-3		000	15970	54	719					0.00	0	7251	0.136		0.136	300	5.00	0.97	0.068	179	-1.158	241	
7-3A		000	15970	0	719					0.00	0	7251	0.136		0.136	500	1.60	0.77	0.151	226	-1.322	594	
7-4		250	16220	240	959					45.40	113	7364	0.138		0.138	500	1.60	0.77	0.151	226	-1.560	338	
8-8A		000	20640	0	959					0.00	0	10016	0.187		0.187	1000	1.40	1.14	0.897	238	-2.094	393	
8-8		8240	28820	420	1375					60.00	14944	14960	0.280		0.280	1000	1.40	1.14	0.897	238	-2.245	195	
8-9		000	28820	190	1569					60.00	0	14960	0.280	0.007	0.287	1000	1.40	1.14	0.897	234	-0.413	137	
8-10		000	28820	1620	3189					0.00	0	14960	0.280	0.587	0.867	1000	1.40	1.14	0.897	213	-0.700	175	
8-11		000	28820	200	3389					12.00	0	14960	0.280	0.001	0.868	1000	1.40	1.14	0.897	210	-3.189	481	
8-12A		000	28820	0	3389					0.00	0	14960	0.280	0.588	0.868	1000	1.40	1.14	0.897	253	-3.499	505	
8-12	6	000	28820	1480	4869					12.00	0	14960	0.280	0.013	0.881	1000	1.40	1.14	0.897	253	-0.530	102	
8-3	6	000	000	0	0					11.90	0	0	0.000	0.062	0.062	400	1.80	0.70	0.088	290	-0.223	119	
9-4		000	000	0	0					12.00	0	0	0.000	0.203	0.203	300	2.20	0.84	0.045	290	-1.510	318	
8-13A	6	000	28820	0	4869					0.00	0	14960	0.280	0.956	1.146	1200	1.20	1.19	1.351	200	-1.731	244P.U	

Table 2.6.1.2 (5) Hydraulic Calculation for Design of Sewers (Rang Sit)

No. of Sewers	Downstream Sewers No.	Drainage Area		Length		Concentrated Time	Run-off Storm			Wastewater Flow			Other W.W		Designing of Sewers						Remarks				
		Area	Total	Length	Total		Rainfall	Rainfall	Run-off Coeff.	Arranged Area	Rainfall	Pop. Density	Population	Design Flow	Sewer	Total	Grand Total	Diameter	Slope	Velocity		Flow	Elevation	Invert	Earth Cover
		ha	ha	m	m	min	m ² /sec-ha	ha	ha	m ² /sec	Person/ha	Person	m ² /sec	m ² /sec	m ² /sec	m ² /sec	mm	%	m/sec	m ³ /sec	M	M	M	m	
5-13		0.00	288.00	57	492.6						0.00	0	14960	0.280		0.366	1.146	800	2.80	1.34	0.674	2.00	-45.00	55.33	FUSEKOSI
6-14		0.00	288.00	0	492.6						0.00	0	14960	0.280		0.366	1.146	1200	1.20	1.19	1.351	2.45	-45.48	5.80	
5-14	5-15	0.00	288.00	50	497.6						0.00	0	14960	0.280		0.366	1.146	1200	1.20	1.19	1.351	2.45	0.930	1.37	
10-2A		0.00	0.00	0	0						0.00	0	0	0.000		0.036	0.036	300	2.20	0.54	0.045	3.10	1.400	1.37	
5-15		0.00	288.00	200	517.6						12.00	0	14960	0.280		0.908	1.188	1200	1.20	1.19	1.351	3.10	0.920	1.19	
5-15		0.00	288.00	43	521.9						0.00	0	14960	0.280		0.908	1.188	800	2.80	1.39	0.700	3.27	-84.23	3.33	FUSEKOSI
6-17A		0.00	288.00	0	521.9						0.00	0	14960	0.280		0.908	1.188	1200	1.20	1.19	1.351	3.27	-85.49	5.52	
5-17		0.00	288.00	700	591.9						8.30	0	14960	0.280		0.922	1.202	1200	1.20	1.19	1.351	3.27	0.910	2.59	
5-18		0.00	288.00	350	626.9						8.30	0	14960	0.280		0.934	1.214	1200	1.20	1.19	1.351	2.94	-15.42	3.19	
1-8		0.00	1288.00	1690	785.9						57.10	0	76974	1.441		1.959	3.400	1600	1.00	1.56	3.998	2.98	-24.12	3.49	
1-9		0.00	1288.00	160	811.9						57.10	0	76974	1.441		1.979	3.420	1600	1.00	1.56	3.998	2.91	-42.86	4.37	
1-10	T.PL ANT	0.00	1288.00	520	853.9						0.00	0	76974	1.441		1.979	3.420	1600	1.00	1.56	3.998	2.96	-43.26	4.39	