

Fig. Result of Step Drawdown Test (S-T Curve)

Step	Water Level (m)	Sw Drawdown (m)	Pumping Rate		Sc l/min/m	$\frac{Sw}{Q}$ (m/m <sup>3</sup> /min)
			l/s	G/min		
1	135.80	4.26	8.63	136	121.5	8.23
2	136.20	4.66	8.73	138	112.1	8.92
3	138.17	6.63	8.83	140	79.9	12.51
4	139.45	7.91	8.96	142	67.9	14.71
5	141.60	10.06	9.08	144	54.2	18.45

S.W.L. = 131.54 m




Fig. Result of Step Drawdown Test  
(Santa Lucía Utatlán: November, 24, '94)

# Result of the analysis of the Pumping Test (Jacob method)

(Santa Lucia Utatlán)

$$T = \frac{0.183Q}{\Delta s}$$

$$= \frac{0.183 \times 283}{0.45} = 359 \text{ m}^2/\text{day}$$

$$= 0.249 \text{ m}^2/\text{min}$$

$AS = 0.45 \text{ m}$

$t \text{ (min)}$

5000

1000

500

100

50

10

5


$S_w \text{ (m)}$

5

10

# Result of the analysis of the Pumping Test (Theis curve)

(Santa Lucia Utatlán)



$$T = \frac{Q}{4\pi S} w(u)$$

$$= \frac{883 \times 25}{4\pi \times 7.7} = 228 \text{ m}^2/\text{day}$$

$$= 0.158 \text{ m}^2/\text{min}$$

$$S = \frac{u 4Tt}{r^2} = \frac{10^{-11} \times 4 \times 0.158}{(0.1016)^2 \times 10^{-1}}$$

$$= 6.12 \times 10^{-9}$$

$$r = 0.1016m$$

$1/t$


# Result of the analysis of the Pumping Test (recovery method)

(Santa Lucía Utatlán)

$$\begin{aligned}
 T &= \frac{0.183Q}{4S'} \\
 &= \frac{0.183 \times 883}{0.3} \\
 &= 538 \text{ m}^2/\text{day} \\
 &= 0.374 \text{ m}^2/\text{min}
 \end{aligned}$$

$$4S' = 0.3 \text{ m}$$

$$\begin{aligned}
 Q &= 162 \text{ g/min} \\
 &= 883 \text{ m}^3/\text{day}
 \end{aligned}$$





# Result of pumping test

(Momostenango)





MOM

## PRUEBA DE BOMBEO (ESCALONADA)

ORIFICIO 4" en tubo de 6"

NIVEL DE BOMBEO 145.34 Metros

NIVEL ESTÁTICO 63.50 Metros

EQUIPO: F-3

JICA - IN FOM

MOMOSTENANGO DEPARTAMENTO DE TOTONICAPAN

BOMBA INSTALADA A 581 PIES

PRODUCCION 295 G.P.M.

BOMBA DE 14 ETAPAS, DE 60 H.P.

OPERADOR : ANTONIO DE PAZ

FECHA	TIEMPO				NIVELES		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	PRUEBA DE BOMBEO ESCALONADA
07/12/94	6.00	0				63.50		PRIMER ESCALON CON 179 GPM.
		2		7.5	64.30		179	NIVEL DE BOMBEO MEDIDO CON
		4		7.5	65.35		179	SONDA ELECTRICA.
		6		7.5	66.45		179	
		8		7.5	67.50		179	
		10		7.5	68.20		179	
		15		7.5	70.00		179	
		20		7.5	72.50		179	
		25		7.5	72.80		179	
		30		7.5	73.70		179	
		40		7.5	74.30		179	
		50		7.5	75.20		179	
		60		7.5	76.10		179	
		70		7.5	77.35		179	
		80		7.5	78.20		179	
		90		7.5	78.25		179	
		120		7.5	80.00		179	
	8.00	0		12.5	80.00		230	SEGUNDO ESCALON CON 230 GPM.
		2		12.5	85.00		230	
		4		12.5	87.50		230	
		6		12.5	88.50		230	
		8		12.5	89.50		230	
		10		12.5	90.30		230	
		15		12.5	97.20		230	
		20		12.5	92.00		230	

Mom

FECHA	TIEMPO				NIVELES		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
07/12/94	8.00	25		12.5	92.80		230	
		30		12.5	93.00		230	
		40		12.5	94.50		230	
		50		12.5	97.30		230	
		60		12.5	98.30		230	
		70		12.5	99.00		230	
		80		12.5	99.66		230	
		90		12.5	100.45		230	
		120		12.5	102.00		230	
	10.00	0		19	102.00		278	TERCER ESCALON CON 278 GPM.
		2		19	105.40		278	
		4		19	108.06		278	
		6		19	108.79		278	
		8		19	109.13		278	
		10		19	109.49		278	
		15		19	110.33		278	
		20		19	111.50		278	
		25		19	112.40		278	
		30		19	114.94		278	
		40		19	115.30		278	
		50		19	116.51		278	
		60		19	117.16		278	
		70		19	118.08		278	
		80		19	119.36		278	
		90		19	120.00		278	
		120		19	121.77		278	
	12.00	0		27	121.77		329	CUARTO ESCALON CON 329 GPM.
		2		27	128.77		329	

FECHA	T I E M P O				N I V E L E S		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
07/12/94	12.00	4		27	128.79		329	
		6		27	129.26		329	
		8		27	130.09		329	
		10		26.5	130.86		326	
		15		26	132.50		323	
		20		26	133.17		323	
		25		25.5	133.51		320	
		30		25	134.69		317	
		40		24.5	136.45		314	
		50		24	137.00		310	
		60		24	138.49		310	
		70		23	140.58		305	
		80		23	141.10		305	
		90		23	141.70		305	
		120		21.5	145.34		295	SE PARO PRUEBA DE BOMBEO
		0			145.34			RECUPERACION DEL POZO
		2			124.00			
		4			95.34			
		6			93.70			
		8			93.00			
		10			92.21			
		15			89.36			
		20			87.87			
		25			86.00			
		30			85.00			
		40			83.22			
		50			81.92			
		60			80.88			

[illegible]

Morm

## PRUEBA DE BOMBEO (LARGA DURACION)

ORIFICIO 4" en tubo de 6"

NIVEL DE BOMBEO 133.80 Metros

NIVEL ESTÁTICO 65.00 Metros

EQUIPO: FAILING - 3

JICA - INFORM

MOMOSTENANGO, DEPTO. TOTONICAPAN

BOMBA INSTALADA A 581 PIES

PRODUCCION 200 G.P.M.

BOMBA DE 14 ETAPAS, DE: 60 H.P.

OPERADOR: ANTONIO DE PAZ

FECHA	TIEMPO				NIVELES		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
08/12/94	6:00	0				65.00		
		2		9.5	65.00		200	NIVEL DE BOMBEO MEDIDO CON
		4		9.5	77.70		200	SONDA ELECTRICA.
		6		9.5	73.13		200	
		8		9.5	83.83		200	
		10		9.5	86.65		200	
		15		9.5	86.81		200	
		20		9.5	87.64		200	
		25		9.5	88.21		200	
		30		9.5	88.58		200	
		40		9.5	90.40		200	
		50		9.5	92.00		200	
		60		9.5	92.59		200	
		70		9.5	93.20		200	
		80		9.5	93.69		200	
		90		9.5	94.79		200	
		120		9.5	96.00		200	
		150		9.5	97.00		200	
		180		9.5	98.00		200	
		210		9.5	99.00		200	
		240		9.5	99.68		200	
		300		9.5	101.00		200	
		360		9.5	103.12		200	
		420		9.5	104.00		200	
		480		9.5	108.06		200	

Mom

FECHA	TIEMPO				NIVELES		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
		540		9.5	109.53		200	
		600		9.5	110.83		200	
		660		9.5	111.00		200	
		720		9.5	113.05		200	
		780		9.5	114.10		200	
		840		9.5	115.00		200	
		900		9.5	115.10		200	
12/12/94	1.00	960		9.5	116.00		200	
		1020		9.5	116.30		200	
		1080		9.5	116.94		200	
		1140		9.5	117.60		200	
		1200		9.5	118.10		200	
		1260		9.5	118.85		200	
		1320		9.5	119.00		200	
		1380		9.5	119.92		200	
		1440		9.5	120.30		200	
		1500		9.5	121.51		200	
		1560		9.5	121.54		200	
		1620		9.5	122.21		200	
		1680		9.5	123.69		200	
		1740		9.5	124.42		200	
		1800		9.5	125.33		200	
		1920		9.5	126.53		200	
		2040		9.5	127.40		200	
		2160		9.5	127.80		200	
		2280		9.5	128.70		200	
		2400		9.5	129.80		200	
		2520		9.5	130.80		200	

Hom

FECHA	T I E M P O				N I V E L E S		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
		2640		9.5	131.80		200	
		2760		9.5	132.80		200	
		2880		9.5	133.80		200	SE PARO PRUEBA DE BOMBEO.
		1			130.90			RECUPERACION DEL POZO.
		2			128.63			
		3			126.24			
		4			124.33			
		5			122.44			
		6			120.10			
		7			118.08			
		8			116.11			
		9			114.45			
		10			112.77			
		15			110.78			
		20			108.19			
		25			104.25			
		30			100.33			
		40			98.48			
		50			96.60			
		60			95.04			
		70			95.98			
		80			94.60			
		90			92.48			
		120			90.04			
		150			89.13			
		180			87.15			
		210			85.34			
		240			83.50			



[illegible]




Fig. Result of Step Drawdown Test (S-T Curve)

Step	Water Level (m)	Sw Drawdown (m)	Pumping	Rate	Sc l/min/m	$\frac{Sw}{Q}$ (m/m <sup>3</sup> /min)
			l/s	G/min		
1	80.00	16.50	11.29	179	41.06	24.35
2	102.00	38.50	14.51	230	22.61	44.22
3	121.77	58.27	17.54	278	18.06	55.37
4	145.34	79.84	18.61	295	13.99	71.49

S.W.L. = 63.50 m





Fig. Result of the Step Drawdown Test  
(Momostenango: 6 de Diciembre de 1994)

Result of the analysis of the Pumping Test (Jacob method)  
(Momostenango)




Result of the analysis of the Pumping Test (Theis curve)  
(Momostenango)

$$Q = 200 \text{ GPM}$$

$$= 12.62 \text{ l/sec}$$

$$= 1090.2 \text{ m}^3/\text{day}$$



$$T = \frac{Q W(u)}{4\pi S}$$

$$= \frac{1090.2 \times 3.2}{4\pi \times 18}$$

$$= 15.43 \text{ m}^2/\text{day}$$

$$= 0.0107 \text{ m}^2/\text{min}$$

$$S = \frac{u 4 T t}{r^2}$$

$$= \frac{10^{-3} \times 4 \times 0.0107}{(0.106)^2 \times 0.17}$$

$$= 0.244$$

$$u = 10^{-2}$$


$$W(u) = 3.2$$

$$S = 18 \text{ m}$$

$$1/t = 0.17$$

# Result of the analysis of the Pumping Test (recovery method)

(Momostenango)





# Result of pumping test

(Genova)





## PRUEBA DE BOMBEO (ESCALONADA)

ORIFICIO 3" en tubo de 4"  
 NIVEL DE BOMBEO 155.38 Metros  
 NIVEL ESTÁTICO 27.85 Metros  
 EQUIPO: TH-60

JICA - INFOM

GENOVA COATEPEQUE

BOMBA INSTALADA A 486 PIES  
 PRODUCCION 207 G.P.M.  
 BOMBA DE 5 ETAPAS, DE 40 H.P.  
 OPERADOR : AUGUSTO BLANCO

FECHA	TIEMPO				NIVELES		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	PRUEBA DE BOMBEO ESCALONADA
10/12/94	9.00	0				27.85		PRIMER ESCALON CON 151 GPM.
		2		13	45.77		151	NIVEL DE BOMBEO MEDIDO CON
		4		13	43.53		151	SONDA ELECTRICA,
		6		13	43.84		151	
		8		13	44.22		151	
		10		13	44.68		151	
		15		13	48.23		151	
		20		13	50.75		151	
		25		13	52.38		151	
		30		13	54.58		151	
		40		13	55.59		151	
		50		13	56.51		151	
		60		13	57.68		151	
		70		13	58.55		151	
		80		13	59.12		151	
		90		13	59.75		151	
		120		13	61.32		151	
	11.00	0		16.5	61.32		170	SEGUNDO ESCALON CON 170 GPM.
		2		16.5	64.08		170	
		4		16.5	64.54		170	
		6		16.5	64.88		170	
		8		16.5	64.99		170	
		10		16.5	65.18		170	
		15		16.5	65.86		170	
		20		16.5	66.37		170	

6c

FECHA	T I E M P O				N I V E L E S		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
10/12/94	11.00	25		16.5	66.71		170	
		30		16.5	65.95		170	
		40		16.5	67.59		170	
		50		16.5	68.28		170	
		60		16.5	68.89		170	
		70		16.5	69.28		170	
		80		16.5	70.03		170	
		90		16.5	70.39		170	
		120		16.5	71.54		170	
	13.00	0		18.5	71.54		180	TERCER ESCALON CON 180 GPM.
		2		18.5	73.10		180	
		4		18.5	73.37		180	
		6		18.5	73.53		180	
		8		18.5	73.59		180	
		10		18.5	73.70		180	
		15		18.5	74.00		180	
		20		18.5	74.42		180	
		25		18.5	74.68		180	
		30		18.5	74.85		180	
		40		18.5	75.53		180	
		50		18.5	75.96		180	
		60		18.5	76.33		180	
		70		18.5	76.84		180	
		80		18.5	77.12		180	
		90		18.5	77.42		180	
		120		18.5	78.39		180	
	15.00	0		23	78.39		201	CUARTO ESCALON CON 201 GPM.
		2		23	81.24		201	

FECHA	T I E M P O				N I V E L E S		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
10/12/94	15.00	4		23	82.06		201	
		6		23	82.35		201	
		8		23	82.49		201	
		10		23	82.66		201	
		15		23	83.22		201	
		20		23	83.79		201	
		25		23	84.18		201	
		30		23	84.53		201	
		40		23	85.26		201	
		50		23	85.60		201	
		60		23	86.10		201	
		70		23	86.66		201	
		80		23	87.00		201	
		90		23	87.25		201	
		120		23	88.66		201	
	17.00	0		43	88.66		275	QUINTO ESCALON
		2		42	94.59		272	
		4		35	105.17		250	
		6		33	107.40		242	
		8		30	108.47		230	
		10		30	109.09		230	
		15		28	110.13		222	
		20		27	111.14		219	
		25		26.5	112.24		216	
		30		25.5	112.35		212	
		40		25.5	112.99		212	
		50		25	113.29		210	
		60		24.5	113.64		207	

[illegible]

## PRUEBA DE BOMBEO (LARGA DURACION)

ORIFICIO 3" en tubo de 4"

NIVEL DE BOMBEO 122.00 Metros

NIVEL ESTÁTICO 33.64 Metros

EQUIPO: TH-60

JICA - INFOM

GENOVA COATEPEQUE

BOMBA INSTALADA A 486 PIES

PRODUCCION 201 G.P.M.

BOMBA DE 5 ETAPAS, DE: 40 H.P.

OPERADOR: AUGUSTO BLANCO

FECHA	TIEMPO				NIVELES		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
11/12/94	9.00	0				33.64		
		2		23	51.77		201	NIVEL DE BOMBEO MEDIDO CON
		4		23	56.23		201	SONDA ELECTRICA.
		6		23	59.36		201	
		8		23	61.13		201	
		10		23	62.74		201	
		15		23	65.13		201	
		20		23	67.24		201	
		25		23	68.92		201	
		30		23	70.42		201	
		40		23	71.95		201	
		50		23	73.73		201	
		60		23	75.09		201	
		70		23	76.23		201	
		80		23	77.22		201	
		90		23	78.07		201	
		120		23	80.56		201	
		150		23	82.23		201	
		180		23	83.98		201	
		210		23	85.49		201	
		240		23	86.75		201	
		300		23	89.52		201	
		360		23	91.33		201	
		420		23	93.49		201	
		480		23	96.43		201	

FECHA	T I E M P O				N I V E L E S		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
11/12/94	18.00	540		23	100.98		201	
		600		23	102.11		201	
		660		23	102.43		201	
		720		23	102.80		201	
		780		23	103.44		201	
		840		23	103.93		201	
		900		23	103.97		201	
12/12/94	1.00	960		23	104.50		201	
		1020		23	104.00		201	
		1080		23	104.12		201	
		1140		23	104.57		201	
		1200		23	106.52		201	
		1260		23	107.22		201	
		1320		23	107.54		201	
		1380		23	107.57		201	
		1440		23	107.59		201	
		1500		23	117.06		201	
		1560		23	121.32		201	
		1620		23	121.55		201	
		1680		23	121.42		201	
		1740		23	121.34		201	
		1800		23	121.62		201	
		1920		23	121.62		201	
		2040		23	121.98		201	
		2160		23	122.00		201	
		2280		23	122.00		201	
13/12/94	1.00	2400		23	122.00		201	
		2520		23	122.00		201	

FECHA	T I E M P O		P R E S I O N E S		N I V E L E S		PRODUCCION	OBSERVACIONES
	Hora	Minutos	Presión	Pulgadas	Dinámico	Estático	G.P.M.	
13/12/94	5.00	2640		23	122.00		201	
		2760		23	122.00		201	
	9.00	2880		23	122.00		201	SE PARO PRUEBA DE BOMBEO.
		1			101.69			RECUPERACION DEL POZO.
		2			90.38			
		3			77.46			
		4			71.51			
		5			70.15			
		6			69.98			
		7			69.77			
		8			69.65			
		9			69.51			
		10			69.45			
		15			68.91			
		20			68.44			
		25			68.05			
		30			67.69			
		40			66.96			
		50			66.30			
		60			65.64			
		70			65.64			
		80			64.98			
		90			64.20			
		120			63.06			
		150			61.23			
		180			59.71			
		210			58.96			
		240			58.40			








Fig. Result of Step Drawdown Test (S-T Curve)

Step	Water Level (m)	Sw Drawdown (m)	Pumping Rate		Sc l/min/m	Sw $Q_3$ (m <sup>3</sup> /min)
			l/s	G/min		
1	61.26	33.52	9.53	151	17.05	58.64
2	71.32	43.58	10.72	170	14.77	67.72
3	78.33	50.59	11.36	180	13.47	74.25
4	88.39	60.65	12.68	201	12.54	79.71
5	117.35	89.61	13.06	207	8.74	114.36

S.W.L. = 27.74 m






Fig. Result of the Step Drawdown Test  
(Genova: December 10, 1994)

# Result of the analysis of the Pumping Test (Jacob method)

(Génova)



Result of the analysis of the Pumping Test (Theis curve)  
(Génova)




# Result of the analysis of the Pumping Test (recovery method)

(Génova)

$$T = \frac{0.183 Q}{\Delta S'}$$

$$= \frac{0.183 \times 1095.6}{1.3}$$

$$= 15.42 \text{ m}^2/\text{day}$$





### 3. RESULTS OF WATER QUALITY ANALYSIS





3-1

Quality Standard for Drinking Water  
in Guatemala by COGUANOR

Table A1-1 Quality Standard for Drinking Water  
in Guatemala by COGIANOR

Physical Quality

Parameter	MAL	MPL
Color	5 u*	50 u
Odor	No detected -1)	No detected
pH	7.0-8.5	6.5-9.2
Taste	No detected	No detected
Total solids	500 mg/l	1500 mg/l
Turbidity	5 u**	25 u**
Temperature	18-30 °C	34 °C >

Note: \* platinum-cobalt scale

\*\* Jackson Turbidity Metrics Unit (J.T.M)  
or Nephelometric Unit (n.t.u.)

1) 1-3 u of Odor in INFOM Standard

Electric Conductivity : 50 - 1500 uS/cm at 25 °C

Table A1-3 Quality Standard for Drinking Water  
in Guatemala by COGIANOR

	MAL	MPL
Free Residual Chlorine	0.3 - 0.5 mg/l	0.6 - 1.0 mg/l

MAL in INFOM Standard: 0.7 mg/l

PAL in INFOM Standard: 0.5 mg/l<

Table A1-2 Quality Standard for Drinking Water  
in Guatemala by COGIANOR

Chemical Quality

Parameter	MAL (mg/l)	MPL (mg/l)
Anionic Detergents*	0.200	1.000
Aluminium (Al) *	0.050	0.100
Barium (Ba) -1)	-	1.000
Boron (B) *	-	1.000
Calcium (Ca)	75.000	200.000
Chlorine (Cl-)	200.000	600.000
Copper (Cu) *	0.050	1.500
Fluorine (F-)	-	1.700
Magnesium (Mg)	50.000	150.000
Manganese (Mn)	0.050	0.500
Nickel (Ni) -2)	0.010	0.020
Phenole Substances	0.001	0.002
Sulfate (SO4--)*	200.000	400.000
Total Hardness (as CaCO3)	100.000	500.000
Total Iron (Fe)	0.100	1.000
Zinc (Zn) *	5.000	15.000

\*: Not standardized parameters in INFOM Standard  
1), 2): Found in Toxic Substances in INFOM Standard

Table A1-4 Quality Standard for Drinking Water in Guatemala by COGUANOR

Toxic Substances

Parameter	MPL (mg/l)
Arsenic (As)	0.050
Cadmium (Cd)	0.010
Chromium (Cr)	0.050
Cyanide (CN-)	0.050
Lead (Pb)	0.100
Mercury (Hg)	0.002
Nitrate (NO3-) -1)	45.000
Nitrite (NO2-) *	0.010
Silver (Ag) *	0.050
Selenium (Se)	0.010

\*: Not standardized parameters in INFOM Standard  
1): Found in Chemical Substances of INFOM Standard

Table A1-6 Quality Standard for Drinking Water in Guatemala by COGUANOR

Bacteriological Quality

Parameter	PML
General Bacteria	500 CFU/ml >
Total Coliform	2 MPN/100ml >
Fecal Coliform	Negative

Table A1-5 Quality Standard for Drinking Water in Guatemala by COGUANOR

Biocide Quality

Parameter	MAL (mg/l)	MPL (mg/l)
Aldrin	0.0010	0.0170
Chlordane	0.0030	0.0030
Organophosphorus and Carbamate	0.1000	0.1000
DDT	0.0500	0.0500
Dieldrin	0.0010	0.0170
Endrin	0.0002	0.0010
Heptachlor	0.0010	0.0180
Epoxyheptachlor	0.0010	0.0180
Lindane	0.0010	0.0560
Methoxychlor	0.0040	0.0350
Toxaphene	0.0050	0.0250
Chlorophenoxy		
Herbicides:		
2,4 - D (1)	0.0200	0.1000
2,4,5 - TP (2)	0.0300	0.1000
2,4,5 - I (3)	0.0020	0.1000

(1) : 2,4-Dichlorophenoxyacetic Acid  
(2) : 2,4,5-Trichlorophenoxypropanoic Acid  
(3) : 2,4,5-Trichlorophenoxyacetic Acid

3-2

Water Quality of the Existing Water  
Supply Systems by Simple Method

Table A2-1 Water Quality of the Existing Water Supply Systems by Simple Method (April 13 - 29, 1994)

Guatemala Department													
NO	Municipality	Water source	Place of measurement	Temp. (° C)	pH	EC (US/cm) (25° C)	Coliforms (NO/ml)	G. Bacteria (NO/ml)	Turbid.	Color	Odor	Taste	Remarks
2	San Jose Pinula	Tank-1 (S + W)	House tap	21.6	6	101.7	231. 210. 358	260. 376. 484	No	Clear	No	No	*Cl gas addition in the tank
		Tank-1	Common tap	22.1	6	106.2	0. 0. 0	12. 16. 4	No	Clear	No	No	*3-4 hs/day supply
		Tank-2 (Tank-1 + W)	Primary school	22.4	6	123.6	0. 0. 0	-	No	Clear	No	No	*1 Q/month pay
		Well-3	House tap	21.8	6	110.9	0. 0. 0	0. 4. 4	No	Clear	No	No	*New tank under construction in zona-3
		Well-3	House tap	22.3	5	178.8	1. 0. 0	8. 24. 40	No	Clear	No	No	*Turbidity by eyes
		Well-3	House tap	21.8	6	170.2	0. 0. 0	8. 36. 52	No	Clear	No	No	
8	San Pedro Sacatepequez	Spring-1	Spring-1	19.0	5.5	163.9	0. 0	100. 68	No	Clear	No	No	*INFOM advised Cl treatment, but not be done, diarrhea happened
		Spring-2	Spring-2	17.5	6	151.0	0. 0	12. 8	No	Clear	No	No	*2-5 hs/day supply
		Tank-2	House tap	17.5	6.5	124.6	0. 0	16. 20	No	Clear	No	No	*3 Q/month
		Tank-2	House tap	17.8	6.5	124.2	2. 1	28. 20	No	Clear	No	No	
		S + W	Common tap	18.5	6.5	123.0	6. 3	84. 168	No	Clear	No	No	*Turbidity by eyes

Table A2-2 Water Quality of the Existing Water Supply Systems by Simple Method (April 13 - 29, 1994)

Sacatepéquez Department													
NO	Municipality	Water source	Place of measurement	Temp. (° C)	pH	EC (US/cm) (25° C)	Coliforms (NO/ml)	G. Bacteria (NO/ml)	Turbid.	Color	Odor	Taste	Remarks
11	Santa Maria de Jesus	Spring-1	Common tap	22.2	7	199.1	1. 1. 2	0. 4. 13	No	Clear	No	No	*No Cl treatment
		Spring-2	Common tap	21.7	7	211.0	0. 0. 0	12. 44	No	Clear	No	No	*Common tap-every 2 days supply
		Spring-2	Common tap	21.7	6.5	139.9	6. 10	64. 100	No	Clear	No	No	*No payment
		Well	House tap	20.4	6.5	291.0	0. 1	44. 20	No	Clear	No	No	*Turbidity by eye



Table A2-5 Water Quality of the Existing Water Supply Systems by Simple Method (April 13 - 29, 1994)

Quetzaltenango Department													
No	Municipality	Water source	Place of measurement	Temp. (° C)	pH	EC (US/cm) (25° C)	Coliforms (NO/ml)	G. Bacteria 24 hrs	Turbid.	Color	Odor	Taste	Remarks
4	San Carlos Sija	Tank (S-1 - 3)	Tank	15.0	6	48.6	0. 8	20. 12	No	Clear	No	No	*No treatment *Water supply for 350 houses (100 % in urban)
		Tank	Common tap	15.3	6	49.4	3. 7	28. 40	No	Clear	No	No	
		Tank	House tap	17.4	6	47.9	3. 5	8. 32	No	Clear	No	No	
		Private-spring	Private-spring	13.1	6	175.5	6. 9	36. 64	Looked very low	Slightly white	No	No	*Private wells and springs with water the supply system *New tank is under-construction
18	San Francisco la Union	Tank-1 (S)	Tank-1	-	-	-	-	-	-	-	-	-	*No treatment *Supply for 102-houses-100 % in urban area
		Tank-2 (S)	Tank-2	19.1	6	126.3	0. 0	68. 88	No	Clear	No	No	
		Private well	(ca. 13 m deep)	15.8	6	536.0	14. 25	36. 100	Looked low	Slightly white	No	No	*Every 2days only a.m. supply
		Private well	(ca. 23 m deep)	15.4	6	186.3	0. 0	24. 12	No	Clear	No	No	*5 Qs/month *Private wells with water supply system
21	Genova	Tank (S-1-7)	Tank	25.6	6	91.1	10. 9	24. 24	No	Clear	No	No	*No treatment *Water supply for 350 houses (70 %)
		Tank	Common tap	30.0	6	91.0	7. 10	24. 32	No	Clear	No	No	
		Tank	House tap	29.4	6	91.3	4. 7	44. 176	No	Clear	No	No	*2 hs only a.m.
		Private well	(ca. 7 m deep)	26.8	6	133.9	18. 17	1118. 1264	No	Clear	No	No	*Private wells with water supply system *Pipe from springs will be exchanged to bigger one - 50 % water supply up
22	Flores Costa Cuca	Tank-1 (S-1+2)	Tank-1	24.3	6	107.1	13. 11	120. 80	No	Clear	No	No	*Tank-1 : for 30 ys
		Tank-2 (T-1+W)	Tank-2	25.9	6	201.0	13. 22	72. 108	No	Clear	No	No	*Tank-2 : for 1.5 ys
		Tank-2	House tap	25.9	6	178.9	8. 10	200. 208	No	Clear	No	No	*0.75 Qs/month
		Private-well	(ca. 8 m deep)	25.0	6	166.4	41. 40	256. 200	No	Clear	No	No	*Private well with water supply system



3-3

Water Quality of the Existing  
Supply Systems by INFOM  
(1990)

Table A2-6 Water Quality of the Existing Supply System analyzed by INFOM since 1990

Guatemala Department						
Municipality	San Jose del Golfo			Sta. Catarina Pinula		
Date Place	4-9-90 Munici- pality	4-9-90 Llena- cantaros	30-4-91 Casa N. Carrera	8-9-92 Munici- pality	15-2-93 Casa A. Dionisio	10-8-93 Casa G. A. Barillas
Parameter						
Residual chloride (mg/l)	0.0	0.0	0.0	0.0	0.0	0.0
Appearance	Clear	Clear	Clear	Clear	Yellowish	Clear
Temp. (°C)	-	-	-	-	22.4	-
pH	-	-	-	-	6.8	-
True color	-	-	-	-	140	-
Odor	No	No	No	No	No	No
SS	1*	1*	2#	1*	3\$	1*
Turbidity (U.N.T)	-	-	-	-	22.4	-
Hardness (mg/l)	-	-	-	-	113	-
Chlorine (mg/l)	-	-	-	-	25	-
T-Fe (mg/l)	-	-	-	-	2.35	-
Mn (mg/l)	-	-	-	-	2	-
NO3-N (mg/l)	-	-	-	-	0.0	-
NO2-N (mg/l)	-	-	-	-	0.00	-
Sulphide (mg/l)	-	-	-	-	0	-
EC (uS/cm)	-	-	-	-	1	-
T-S (mg/l)	-	-	-	-	186	-
General-bacteria (NO/ml)	40	60	500	90	5000	200
Total-coliforms (MPN/100ml)	13	17	220	23	220	79
Fecal-coliforms (MPN/100ml)	2	2	8	<2	79	<2

Guatemala Department						
San Pedro Sacatepéquez			Sacatepéquez Department			
Municipality	San Pedro Sacatepéquez			Santa María de Jesús		
Date Place	28-8-90 Disri. Tank	19-4-93 Munici- pality	28-9-93 Park	13-8-90 Iglrsia	8-5-91 Llena- cantaros	24-8-92 Central Park
Parameter						
Residual chloride (mg/l)	0.0	0.0	0.0	0.0	0.0	0.0
Appearance	Clear	Clear	Clear	Clear	Clear	Clear
Temp. (°C)	19.7	-	22.6	18	-	-
pH	-	-	7.1	7.2	-	-
True color	10	-	5	5	-	-
Odor	1	No	0	2	No	No
SS	1*	1*	-	3\$	2*	2*
Turbidity (U.N.T)	0.3	-	0.5	0.25	-	-
Hardness (mg/l)	45	-	48	76	-	-
Chlorine (mg/l)	36	-	23	28	-	-
T-Fe (mg/l)	0.01	-	0.00	0.00	-	-
Mn (mg/l)	0.1	-	0.0	0.1	-	-
NO3-N (mg/l)	1.8	-	1.4	0.7	-	-
NO2-N (mg/l)	0.002	-	0.001	0.003	-	-
Sulphide (mg/l)	1.0	-	0.0	0.0	-	-
EC (uS/cm)	143.7	-	-	171.8	-	-
T-S (mg/l)	72.0	-	1.6	86.1	-	-
General-bacteria (NO/ml)	300	400	-	80	20	10000
Total-coliforms (MPN/100ml)	11	70	-	2	8	34
Fecal-coliforms (MPN/100ml)	<2	<2	-	<2	2	22

Table A2-7 Water Quality of the Existing Supply System analyzed by INFOM since 1990

Sacatepéquez Department					Chimaltenango Department	
Municipality	Ciudad Vieja				San Juan Comalapa	
Date	10-1-90	10-8-92	2-8-93	1-6-93	25-11-91	24-11-92
Place	Munici- pality	Pozo Nuevo	Pozo Fluyente	Munici- pality	Llena- cantaros	N. el Cojol
Parameter						
Residual chloride (mg/l)	-	0.0	0.0	0.0	0.1	0.0
Appearance	-	Clear	Clear	Clear	Clear	Clear
Temp. (°C)	21.5	-	24.3	-	-	-
pH	7.2	-	7.4	-	-	-
True color	10	-	40	-	-	-
Odor	1	No	0	No	-	No
SS	-	1*	1*	1*	2#	1*
Turbidity (U.N.T)	0.3	-	4.0	-	-	-
Hardness (mg/l)	120	-	123	-	-	-
Chlorine (mg/l)	31	-	28	-	-	-
T-Fe (mg/l)	0.02	-	0.02	-	-	-
Mn (mg/l)	0.2	-	0.0	-	-	-
NO3-N (mg/l)	3.7	-	0.3	-	-	-
NO2-N (mg/l)	0.004	-	0.001	-	-	-
Sulphide (mg/l)	14.0	-	0.0	-	-	-
EC (uS/cm)	156.7	-	169.9	-	-	-
T-S (mg/l)	1	-	1	-	-	-
General-bacteria (NO/ml)	-	20	60000	40	600	10000
Total-coliforms (MPN/100ml)	-	<2	>1600	7	79	5
Fecal-coliforms (MPN/100ml)	-	-	<2	<2	23	2

Sololá Department			Totonicapán Department		
Municipality	Sololá		Nahuala	Momostenango	
Date	22-7-91	31-8-93	2-7-90	17-4-90	
Place	Hospital Nacional	Munici- pality	Centro de Salud	Llena- cantaros	
Parameter					
Residual chloride (mg/l)	1.0	1.0	0.0	-	
Appearance	Clear	Clear	Clear	-	
Temp. (°C)	-	-	-	18.7	
pH	-	-	-	6.6	
True color	-	-	-	10	
Odor	No	No	No	0	
SS	1*	1*	1*	-	
Turbidity (U.N.T)	-	-	-	0.4	
Hardness (mg/l)	-	-	-	-	
Chlorine (mg/l)	-	-	-	30	
T-Fe (mg/l)	-	-	-	0.02	
Mn (mg/l)	-	-	-	0.0	
NO3-N (mg/l)	-	-	-	1.0	
NO2-N (mg/l)	-	-	-	0.003	
Sulphide (mg/l)	-	-	-	1.0	
EC (uS/cm)	-	-	-	16.4	
T-S (mg/l)	-	-	-	33.1	
General-bacteria (NO/ml)	1	1	1000	-	
Total-coliforms (MPN/100ml)	<2	<2	8	-	
Fecal-coliforms (MPN/100ml)	-	-	4	-	

Table A2-8 Water Quality of the Existing Supply System analysed by INFOM since 1990

Quetzaltenango Department						
Municipality	Genova Costa Cuca	F. C. C.	San Carlos Sijá			
Date	27-8-90	7-10-91	7-10-91	27-3-90	27-3-90	27-3-90
Place	Casa de M. Escobal	Tank Lavadero	Casa de F. V.	Casa de F. R. G	Market	Casa de F. Ramon
Parameter						
Residual chloride (mg/l)	0.0	0.0	0.0	0.0	0.0	0.0
Appearance	Clear	Clear	Clear	Clear	Clear	Clear
Temp. (°C)	-	-	-	-	-	17.6
pH	-	6.6	-	-	-	7.3
True color	-	10	10	-	-	10
Odor	No	0	0	No	No	1
SS	3*	1*	1*	1*	2#	1*
Turbidity (U.N.T)	-	0.55	1.3	-	-	0.45
Hardness (mg/l)	-	-	-	-	-	22
Chlorine (mg/l)	-	27	29	-	-	39
T-Fe (mg/l)	-	0.01	0.03	-	-	0.01
Mn (mg/l)	-	-	-	-	-	0.3
NO <sub>3</sub> -N (mg/l)	-	3.2	8.0	-	-	1.5
NO <sub>2</sub> -N (mg/l)	-	0.003	0.007	-	-	0.003
Sulphide (mg/l)	-	0.0	0.0	-	-	0.0
EC (uS/cm)	-	82.2	96.0	-	-	47.7
T-S (mg/l)	-	41.1	48.1	-	-	23.8
General-bacteria (NO/ml)	59000	3	600	180	700	200
Total-coliforms (NMP/100ml)	2	<2	350	8	49	79
Fecal-coliforms (NMP/100ml)	2	-	33	<2	49	<2

Quetzaltenango Department						
Municipality	San Fco. la Unión	Cajola				
Date	28-8-90	26-2-90				
Place	Municipality	Municipality				
Parameter						
Residual chloride (mg/l)	0.0	0.0				
Appearance	Yellowish	Clear				
Temp. (°C)	16.7	17.1				
pH	7.4	7.3				
True color	30	20				
Odor	1	2				
SS	2#	1*				
Turbidity (U.N.T)	0.94	3.0				
Hardness (mg/l)	75	162				
Chlorine (mg/l)	32	28				
T-Fe (mg/l)	0.79	0.04				
Mn (mg/l)	0.3	0.2				
NO <sub>3</sub> -N (mg/l)	1.2	1.6				
NO <sub>2</sub> -N (mg/l)	0.001	0.002				
Sulphide (mg/l)	5.0	9.0				
EC (uS/cm)	170.7	143.0				
T-S (mg/l)	86.0	71.5				
General-bacteria (NO/ml)	150	60				
Total-coliforms (NMP/100ml)	2	8				
Fecal-coliforms (NMP/100ml)	-	2				

3-4

## Quality of Drinking Water from Distribution Tank

Table A3-1 Quality of Drinking Water from Distribution Tank

Municipality: San José Pinula

Tank No.1

Date: October 8, 1994

Appearance: Clear

Odor: No

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	20.0	T-Fe (mg/l)	0.12	Pb (mg/l)	0.0
pH	6.6	T-Hardness		T-Residual	
EC (uS/cm)	65.0	(mg/l as CaCO <sub>3</sub> )	32.54	(mg/l at 104° C)	142.40
Color (u)	5.0	Cr(6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0.0	Chloride (mg/l)	13.25	(CFU/ml)	33
Residual Chlorine	0.0	Mn (mg/l)	0.0	Total coliforms	
COD (Mn) (mg/l)	-	Zn (mg/l)	0.0	(MPN/100ml)	2>
NO <sub>3</sub> -N (mg/l)	0	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-2 Quality of Drinking Water from Distribution Tank

Municipality: San Pedro Sacatepéquez

Tank No.2

Date: October 13, 1994

Appearance: Clear

Odor: No

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	21.0	T-Fe (mg/l)	0.04	Pb (mg/l)	0.0
pH	6.9	T-Hardness		T-Residual	
EC (uS/cm)	340.0	(mg/l as CaCO <sub>3</sub> )	52.88	(mg/l at 104° C)	159.6
Color (u)	10.0	Cr(6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0.0	Chloride (mg/l)	8.37	(CFU/ml)	1450
Residual Chlorine	-	Mn (mg/l)	0.0	Total coliforms	
COD (Mn) (mg/l)	0.0	Zn (mg/l)	0.01	(MPN/100ml)	93
NO <sub>3</sub> -N (mg/l)	5	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-3 Quality of Drinking Water from Distribution Tank

Municipality: Santa María de Jesús

Tank No.2

Date: November 5, 1994

Appearance: Clear

Odor: No

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	20.0	T-Fe (mg/l)	0.01	Pb (mg/l)	0.0
pH	7.2	T-Hardness		T-Residual	
EC (uS/cm)	200	(mg/l as CaCO <sub>3</sub> )	138.30	(mg/l at 104° C)	250.8
Color (u)	5.0	Cr(6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0.0	Chloride (mg/l)	11.16	(CFU/ml)	4610
Residual Chlorine	-	Mn (mg/l)	0.0	Total coliforms	
COD (Mn) (mg/l)	0.0	Zn (mg/l)	0.03	(MPN/100ml)	110
NO <sub>3</sub> -N (mg/l)	10	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-4 Quality of Drinking Water from Distribution Tank

Municipality: San Martín Jilotepec

Appearance: Clear

Tank No.

Odor: No

Date: October 29, 1994

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	22.0	T-Fe (mg/l)	0.39	Pb (mg/l)	0.0
pH	7.0	T-Hardness		T-Residual	
EC (uS/cm)	130.0	(mg/l as CaCO <sub>3</sub> )	63.05	(mg/l at 104°C)	179.2
Color (u)	5.0	Cr(6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0.0	Chloride (mg/l)	9.76	(CFU/ml)	1030
Residual Chlorine	-	Mn (mg/l)	0.0	Total coliforms	
COD (Mn) (mg/l)	-	Zn (mg/l)	0.08	(MPN/100ml)	1100
NO <sub>3</sub> -N (mg/l)	0	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-5 Quality of Drinking Water from Distribution Tank

Municipality: San Juan Comalapa

Appearance: Clear

Tank No. 1

Odor: No

Date: November 10, 1994

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	17.0	T-Fe (mg/l)	0.11	Pb (mg/l)	0.0
pH	7.2	T-Hardness		T-Residual	
EC (uS/cm)	55	(mg/l as CaCO <sub>3</sub> )	32.54	(mg/l at 104°C)	92.8
Color (u)	5.0	Cr(6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0.0	Chloride (mg/l)	9.07	(CFU/ml)	21
Residual Chlorine	0.0	Mn (mg/l)	0.0	Total coliforms	
COD (Mn) (mg/l)	0.0	Zn (mg/l)	0.03	(MPN/100ml)	2>
NO <sub>3</sub> -N (mg/l)	0	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-6 Quality of Drinking Water from Distribution Tank

Municipality: Sololá

Appearance: Clear

Tank No. 1

Odor: No

Date: November 10, 1994

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	16.0	T-Fe (mg/l)	0.0	Pb (mg/l)	0.0
pH	7.1	T-Hardness		T-Residual	
EC (uS/cm)	75	(mg/l as CaCO <sub>3</sub> )	44.76	(mg/l at 104°C)	140.4
Color (u)	0.0	Cr(6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0.0	Chloride (mg/l)	9.76	(CFU/ml)	4
Residual Chlorine	1.0	Mn (mg/l)	0.0	Total coliforms	
COD (Mn) (mg/l)	0.0	Zn (mg/l)	0.0	(MPN/100ml)	2>
NO <sub>3</sub> -N (mg/l)	5	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-7 Quality of Drinking Water from Distribution Tank

Municipality: Santa Lucía Uatlán

Appearance: Clear

Tank No.1

Odor: No

Date: November 10, 1994

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	15.0	T-Fe (mg/l)	0.0	Pb (mg/l)	0.0
pH	6.8	T-Hardness		T-Residual	
EC (uS/cm)	50	(mg/l as CaCO <sub>3</sub> )	30.52	(mg/l at 104°C)	109.6
Color (u)	5.0	Cr (6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0.0	Chloride (mg/l)	11.16	(CFU/ml)	10
Residual Chlorine	-	Mn (mg/l)	0.0	Total coliforms	
COD (Mn) (mg/l)	0.0	Zn (mg/l)	0.01	(MPN/100ml)	2>
NO <sub>3</sub> -N (mg/l)	0	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-8 Quality of Drinking Water from Distribution Tank

Municipality: Momostenango

Appearance: Clear

Tank No.1

Odor: No

Date: November 17, 1994

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	18.0	T-Fe (mg/l)	0.0	Pb (mg/l)	0.0
pH	7.0	T-Hardness		T-Residual	
EC (uS/cm)	90	(mg/l as CaCO <sub>3</sub> )	24.41	(mg/l at 104°C)	112.0
Color (u)	5	Cr (6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0.0	Chloride (mg/l)	7.67	(CFU/ml)	616
Residual Chlorine	-	Mn (mg/l)	0.0	Total coliforms	
COD (Mn) (mg/l)	0.0	Zn (mg/l)	0.01	(MPN/100ml)	460
NO <sub>3</sub> -N (mg/l)	0	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-9 Quality of Drinking Water from Distribution Tank

Municipality: San Francisco La Unión

Appearance: Clear

Tank No.1

Odor: No

Date: November 17, 1994

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	16.0	T-Fe (mg/l)	0.18	Pb (mg/l)	0.0
pH	7.3	T-Hardness		T-Residual	
EC (uS/cm)	175	(mg/l as CaCO <sub>3</sub> )	54.97	(mg/l at 104°C)	128.8
Color (u)	0	Cr (6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0	Chloride (mg/l)	9.07	(CFU/ml)	1336
Residual Chlorine	-	Mn (mg/l)	0.16	Total coliforms	
COD (Mn) (mg/l)	0.0	Zn (mg/l)	0.02	(MPN/100ml)	290
NO <sub>3</sub> -N (mg/l)	0	Cu (mg/l)	0.0	Fecal coliforms	N
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		



Table A3-10 Quality of Drinking Water from Distribution Tank

Municipality: Génova

Tank No. 1

Date: November 18, 1994

Appearance: Clear

Odor: No

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	24.0	T-Fe (mg/l)	0.04	Pb (mg/l)	0.0
pH	6.8	T-Hardness		T-Residual	
EC (uS/cm)	70	(mg/l as CaCO <sub>3</sub> )	32.54	(mg/l at 104° C)	77.2
Color (u)	0	Cr (6+) (mg/l)	0.0	General bacteria	
Turbid. (mg/l)	0	Chloride (mg/l)	13.25	(CFU/ml)	63
Residual Chlorine	-	Mn (mg/l)	0.16	Total coliforms	
COD (Mn) (mg/l)	0.0	Zn (mg/l)	0.0	(MPN/100ml)	29
NO <sub>3</sub> -N (mg/l)	10	Cu (mg/l)	0.0	Fecal coliforms	P
NO <sub>2</sub> -N (mg/l)	0.0	As (mg/l)	0.0		
NH <sub>4</sub> -N (mg/l)	0.0	Cd (mg/l)	0.0		

Table A3-11 Quality for Drinking Water from Test Well

Municipality: San José Pinula

Date: October 8, 1994

Appearance: Clear

Odor: No

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	23.0	T-Fe (mg/l)	0.10	Cd (mg/l)	0.0
pH	6.7	T-Hardness		Pb (mg/l)	0.0
EC (uS/cm)	240	(mg/l as CaCO <sub>3</sub> )	152.54	T-Residual	
Color (u)	0	Cr (6+) (mg/l)	0.0	(mg/l at 104° C)	309.2
Turbid. (mg/l)	0	Chloride (mg/l)	18.83	General bacteria	
COD (Mn) (mg/l)	-	Mn (mg/l)	0.0	(CFU/ml)	2200
NO <sub>3</sub> -N (mg/l)	10	Zn (mg/l)	0.05	Total coliforms	
NO <sub>2</sub> -N (mg/l)	0.0	Cu (mg/l)	0.0	(MPN/100ml)	3
NH <sub>4</sub> -N (mg/l)	0.0	As (mg/l)	0.0	Fecal coliforms	N

Table A3-12 Quality for Drinking Water from Test Well

Municipality: San Pedro Sacatepéquez

Date: October 13, 1994

Appearance: Clear

Odor: No

Taste: No

Parameter	Value	Parameter	Value	Parameter	Value
Temp. (°C)	20.0	T-Fe (mg/l)	0.06	Cd (mg/l)	0.0
pH	6.8	T-Hardness		Pb (mg/l)	0.0
EC (uS/cm)	380	(mg/l as CaCO <sub>3</sub> )	44.74	T-Residual	
Color (u)	5	Cr (6+) (mg/l)	0.0	(mg/l at 104° C)	198.0
Turbid. (mg/l)	0	Chloride (mg/l)	8.37	General bacteria	
COD (Mn) (mg/l)	0.0	Mn (mg/l)	0.0	(CFU/ml)	2300
NO <sub>3</sub> -N (mg/l)	0	Zn (mg/l)	0.12	Total coliforms	
NO <sub>2</sub> -N (mg/l)	0.0	Cu (mg/l)	0.0	(MPN/100ml)	1100
NH <sub>4</sub> -N (mg/l)	0.0	As (mg/l)	0.0	Fecal coliforms	N