

5.1.2 Direct utilization facilities (burning)

(1) Industry sector

As shown in Table 2.6, 14 % of the total coal consumption was consumed in industry sector in 1993. Efficiency of coal utilization is around 60 % and low comparability because the designs and operations of the majority of facilities are based on the former Soviet Union, without any energy conservation concepts. For example, in the cement industry, the production of cement was 82,300 ton/year and consumption of coal for cement was 56,800 ton/year in 1993. Specific energy consumptions is estimated 2,070 kcal/kg-clinker (based on heating value of coal: 3,000 kcal/kg), which can be compared with that of the same type of cement plant, 1,400 kcal/kg in China and 1,300 kcal/kg in Japan. The facilities designed by Czechoslovakia also does not have any energy conservation concepts. Therefore, by modification and improvement of process, energy consumption will be improved by 20 to 30 %.

(2) Public and household sector

As shown in Table 2.6, 4 % of coal is consumed in public and household sector. Actual efficiency of coal use in the sector is not available, but is estimated to be very low as the efficiency of small boilers and ovens is low, 20 to 30 %. Additionally, it is said that about one ton out of 4 to 6 tons of coal is not used in, which is purchased mainly by one family around urban area because it has been pulverized or powdered.

(3) Other sectors

Coal consumption of the other sectors is 2 % of total and used in almost same fields of public and household sector, heating and cooking. Present efficiency of coal use in the other sector is estimated to be the same level with public and household sector, because coal is used for heating and cooking.

5.1.3 Indirect coal utilization facilities (electricity and heat)

(1) Industry sector

As shown in Figure 2.3, 67 % of produced electricity is consumed in the industry sector. Share of the industry sector will be in the same range, 60 to 70 %, though actual data of share in thermal energy consumption is not available. Efficiency of electricity use and thermal energy use in the industry sector is not available, but estimated to be comparatively low because most

of industrial facilities were designed by the former Soviet without any energy conservation concepts. According to ADB report, the following example data are reported. In a textile factory, specific energy consumption (fuel + electricity) for fabric is 19.0 kWh/kg fabric. The corresponding value for European textile mills is 16.5 kWh/kg fabric. This shows that the Mongolian textile mill has 10 to 15 % higher specific energy consumption level than European textile mills. Another example in Vodka, brewery and soft drinks shared companies are as follows: specific heat consumption of 48.1 kWh/hl beer corresponding to 10 kWh/hl of European breweries and specific power consumption of 270 kWh/hl beer corresponding to 11-15 kWh in European breweries. These figures show that the Mongolian brewery has a 4-10 time higher specific energy consumption level than European breweries.

(2) Other sectors

Electricity in the other sectors, 33 % of total consumption, is used for several usages, including heating of buildings and homes that are out of the hot water supply area. Present efficiency of electricity and thermal energy use in the other sectors is not available, but estimated to be very low due to no energy conservation effort and no energy control device. The electrical energy consumption in Mongolian households is approximately 2,000-2,500 kWh/year. The main areas of consumption are as follows:

- Lighting
- Cooking
- Refrigeration(food storage)
- TV and radio sets
- Miscellaneous

Refrigerators are estimated to consume 20 to 25 % of the total power consumption in the households. The annual specific energy consumption of refrigerator is 1.64- 3.80 kWh/year dm^3 , and the specific consumption of comparable refrigerators sold in Sweden is 0.9-1.0 kWh/year dm^3 .

Most multi-family buildings in Ulaanbaatar are very similar to the buildings in many places of the former Soviet Union. There are mainly two types:

- 1) Houses consisting of prefabricated structural concrete elements.
- 2) Brick buildings, where most parts are constructed on site.

The present annual specific energy consumption is approximately 480 kWh/m² today. This should be compared to an average consumption of approximately 220 kWh/m² in the average Swedish buildings under the similar climatic conditions.

5.2 Technical potential of energy (coal) conservation

In this section, technical analysis on possibility of energy-saving in existing facilities is not included, because such analysis is out of scope of the study.

5.2.1 Coal conservation in conversion facilities

(1) Electric power plant

It is planned to repair and modify the plants in CES before 2000, and therefore, it is sure that energy conservation measures would be applied in the course of renovation by 2000, utilizing the most modern technology. At the present, the internal use of electricity is higher than the design value due to bad condition of coal causing longer running time of mills. By improvement of condition of coal supply, energy consumption will be also improved in power plants. As mentioned in 4.1.2, a mine-mouth coal fired power plant will be constructed at coal mining site in around 2005. Such a new power plant would be designed to secure high energy efficiency, 35 % of gross generation efficiency, applying new technology. Application of more efficient power generation system such as combined cycle co-generation system will not be industrialized until the hike of the oil price.

(2) Heat supply system

Coal conservation for large boilers will be implemented by 2000 in the same schedule with the power plant. Heat loss of the hot water distribution system must be minimized by renovation of the system, which includes installation of the flow meter in each consumer. According to the ADB report, present heat loss amount to about 50 % of the delivered heat and it could be decreased to 30 % at least by renovation of facilities and energy-saving efforts by users. Taking renovation above into consideration, the effect of energy-saving in power sector is included in coal demand forecast of 2.4.

Note: 35 % of gross conversion efficiency as the average of recent coal fired power plants in Japan is used for estimation.

5.2.2 Coal saving in direct coal utilization (coal burning)

Present and desirable thermal efficiency of medium size boilers and the typical home ovens are as follows:

	present	desirable efficiency
Industrial boiler/heater	60 %	88-92 %
Household oven	50 %	60-65 %

As mentioned in 5.1.2 (1) above, kilns in cement plants are not so efficient in Mongolia compared with those in China and Japan. Rather high amount of energy-saving effort in the out of power sector will be achieved by the energy-saving effort which is promoted by price control of the Government, however, saving measures by modification of facilities will require rather long period due to lack of the capital fund. Taking uncertainty of expected energy conservation of said boilers into consideration, the effect of energy conservation in coal direct use, excepting power plants, is not included in coal demand forecast of 2.4.

5.2.3 Energy conservation in indirect coal utilization (electricity and heat)

Best and faster method for electricity-saving is the price control by the Government, while the profit of price control policy must be applied to subsidy of capital fund for energy-saving. Electricity saving and thermal energy conservation in the industry sector can be achieved mostly by modification of the equipment and sometimes the whole plant, and therefore it will require a long period. According to the ADB report, in the textile factory, by implementation of low cost maintenance, specific energy consumption can be decreased by at least approximately 10 %. Another report prepared for the Ministry of Trade and Industry by the Boston Consulting Group describes that, in textile finishing operations, saving in the order of 20 - 30 % in consumption levels are typically realizable through minor changes, such as recuperation of waste heat, better insulation of steam and condensate pipes and process equipment, and improvements in the control of the production process and boiler operation. Taking uncertainty of expected energy conservation by electricity and heat users into consideration, the effect of energy conservation in indirect coal use is not included in the coal demand forecast of 2.4.

5.2.4 Other energy (coal) conservation potential

(1) Converting oil to coal

In Mongolia, petroleum products are used mainly in three fields, a) gasoline and diesel oil for vehicle and machines, b) diesel oil for power generation in rural areas, and c) fuel oil for controlling the coal fired boilers. Amount of petroleum consumption for a) and b) is 2 million tons (tce/y in 1990) and it will be difficult to convert it into coal in technical and economic point of view. Amount of fuel oil consumption for c) is about 4 % of coal consumption of power plants, 130,000 tons/year of coal(3,500 kcal/kg) or 50,000 tons/year of oil, and it will be minimized by repair and modification of existing boilers before 2000.

(2) Upgrading of coal quality

Upgrading of coal quality by washing is not recommendable because it is uneconomical procedure for lignite. Upgrading of coking coal in Tavantolgoi will be implemented for export. Briquetting of lignite is a recommendable upgrading method which could decrease air pollutants and increase thermal efficiency of small boilers and stoves.

(3) Utilization of flammable wastes

It is sure that an effective utilization of flammable wastes is already implemented as fuel for household use in Mongolia, and thus, it is not necessary to introduce a large scale waste disposal combustion boiler.

5.3 Policy and procedure for promotion of energy conservation

Basic political measures for promoting energy conservation are as follows:

(i) Guidance and inducement : Campaigns for energy conservation

Establishment of standard energy efficiency

Education and training program at the Energy Conservation Center

(ii) Incentives

: Price control for each fuel

Tax control for energy saving devices

Financial assistance for energy saving devices

(iii) Compulsory

: Restriction of car driving

Restriction of petrol station

Tax control and financial assistance are effective measures for energy-saving in the industry sectors.

Above all, the most effective political measures for the whole sectors are to increase prices including tax for each fuel controlled by the Government, the profit made by price increase, however, must be used to support of low income people as well as to fund tax control and low-interest loans.

5.4 Energy conservation plan

The energy conservation measure will be classified into the following three categories:

(1) First category

The first category means the energy conservation by the methods of modification for operation and maintenance of plant and equipment, which will not be accompanied by new investments, and will include following measures,

1) Cultivation of energy conservation mind;

- Education and training of workers to improve their ideas for energy conservation
- Promotion and incentive to energy saving activities by the managements

2) Technical consideration;

- Adjustment of fuel air ratio to improve efficiency of furnaces and
- Repair of damaged thermal insulation
- Prevention of steam leakage and recovery of condensate water
- Stopping idle machinery
- Cleaning of heat exchanger to keep good heat recovery conditions

The improvement in above mentioned first category, e.g. the appropriate management of operation and maintenance of plant and equipment, which does not require a large amount of new investments, can accomplish a certain (not a small) energy saving. The energy conservation in Mongolia shall be proceeded in this category first. Repair and modification of existing power plants should be proceeded immediately to avoid power failure and scheduled power cut.

(2) Second category

The second category means the energy conservation by partial improvement of existing machinery and equipment, which will be accompanied by some investments, and will include following measures:

- Recovery of waste heat and preheating of combustion air for furnaces and boilers
- Reinforcement of thermal and cold insulation
- Installment of meters for heat, electricity and fuel supply to households
- Installment of controlling instruments for small boilers

(3) Third category

The third category means the energy conservation by complete replacements of the obsolete equipment and facilities to energy conservation types, which will require large amount of investments. The objectives of these measures in the third category are usually not only for energy-saving but also for quality improvement and cost reduction of product as the fundamental reformation of the system. The examples of measures will be such as a continuous casting system in steel making industry and a new suspension preheater kiln in cement industry. As mentioned in 4.1 to 4.5, most of the equipment and facilities were designed by the former Soviet Union without any energy saving concepts, and the energy conservation has never been considered. Therefore it is necessary to proceed with the energy-saving in accordance with long-range energy saving modification plan.

In view of constraint on funds for modernization of industrial process and facility, including energy-saving measures, the Government must support the supply of the required funds by reviewing the tax system to industry sector and supplying low-interest loans. It will proceed energy-saving. In addition to study work for tax control and supplying low-interest loans, it is necessary to bring the energy price up to the international level, as soon as possible, particularly by considering its impact on the people's lives.

Before entering this action, the Government is required to resolve the issues regarding the unpreferable credit and debt system which the enterprises in Mongolia suffer from.

6 Air Quality Protection in Relation to Coal-Combustion

6.1 Present state of air quality

6.1.1 State of pollution sources

(1) General situation

More than half of the population of Mongolia live in urban areas, and half of the urban population live in Ulaanbaatar. Approximately 40% of the whole nation are supplied with electricity. However, the percentage for those living in gers is 15% at most.

Air quality in Mongolia has been reportedly worsening in urban areas such as Ulaanbaatar, Darkhan, Sharyngol, Erdenet and Choybalsan. The pollution is considered to be caused by exhaust gases from power plants, motorvehicles, and domestic heating devices. Among these pollution sources, coal-fired facilities and devices are considered to be the major cause of air pollution because coal is the dominant fuel in this country. Furthermore, the fact that the serious air pollution occurs in the cold season suggests that household heating is closely related to the pollution. In addition to individual stoves for gers and apartment houses, domestic heating also depends on coal-fired boilers for central heating systems and those in power plants and heating centers for district heating systems that provide steam through pipelines.

(2) Coal-fired power plant

Power plants in Mongolia burn domestically produced coal. The major power plants being operated are the Fourth Ulaanbaatar generating 70% of the national total production, the Third Ulaanbaatar generating 20% of the national total, Erdenet, Darkhan and the Second Ulaanbaatar. Thus in Ulaanbaatar City, three coal-fired power plants, the Second, the Third and the Fourth, are now in operation supplying electricity and steam as a heat medium to apartment houses and office buildings. These three power plants consumed 2.9 million ton of coal in 1993 ; the amount corresponds to approximately 80% of the total consumption in the City at 3.6 million tons. The Third Ulaanbaatar power plant has scrubbers and the Fourth Ulaanbaatar power plant has electrostatic precipitators. However, no plant has desulfurization or denitration facility.

(3) Boilers

Total 222 units of large to small boilers exist for industrial use and for heating of offices that are not connected to the district heating system. Among them, 137 units are now in operation consuming 0.4 million tons of coal per year. These boilers are not equipped with flue gas

treatment devices such as filters.

(4) Stoves used in gers

Out of about 590,000 people in Ulaanbaatar, almost a half live in multi-story apartment houses constructed by the government. The rest lived in about 53,000 gers (or simple wooden houses) located at the foot of hills or in the suburbs. The numbers of gers by districts of the City are shown in Table 6.1.

Table 6.1 Number of Gers in Ulaanbaatar (1994)

Sukhbaatar	Bayangol	Bayanzur- ukh	Chingeltei	Khauul	Songinoh- airhan	Total
7,356	4,970	10,622	12,858	6,296	13,241	53,343

Average fuel consumption in gers for stoves is estimated at 4 to 5 tons of coal and approximately 4 m³ of firewood per ger per year. Combustion efficiency of these stoves are very low and the height of stacks is low at 3 to 4 meters preventing dispersion of pollutants in the atmosphere. Therefore, the stoves are regarded as one of the major causes of high pollutant concentration at the ground level.

(5) Coal consumption in Ulaanbaatar

Coal, as a major fuel, was consumed at about 3.6 million tons in Ulaanbaatar in 1993. The shares of the consumption by end users are summarized in Table 6.2.

Table 6.2 Coal Consumption in Ulaanbaatar (1993)

	Consumers	Consumption (1,000 ton)
Power Plants	No. 2	129
	No. 3	861
	No. 4	1,906
	Sub-total	2,896
Others	Boilers for Factories	400
	Stoves in Households	260
	Sub-total	660
Total		3,556

6.1.2 Emission of coal-related pollutants

(1) Quality of coal

Quality of coal used in Ulaanbaatar is shown in Table 6.3 by coal producing mines. The table also gives the share of each mine at coal consumers. The average quality of the mixed coal is shown in Table 6.4 by respective consumers.

Table 6.3 Quality of Coal Used in Ulaanbaatar by Coal Mine

Coal Mine	Sulfur Content	Calorific Value				Share of Coal Mine by User (%)			
		High Heating Value (dry, ash free basis)		Low Heating Value (wet with ash)		Power Plant			Others
	weight %	kcal / kg	MJ / kg	kcal / kg	MJ / kg	No. 2	No. 3	No. 4	
Baganuur	0.77	6,731	28.18	3,586	15.01	58.3	38.9	85.4	78.9
Sharyngol	0.60	7,200	30.14	4,050	16.96	40.7	59.6	0.0	0.6
Shivee Ovoo	0.75	6,700	28.05	3,527	14.77	1.0	1.5	14.6	20.5

Table 6.4 Average Quality of Coal by Consumers in Ulaanbaatar

Consumer	Sulfur Content	Calorific Value			
		High Heating Value (dry, ash free basis)		Low Heating Value (wet, with ash basis)	
	weight %	kcal / kg	MJ / kg	kcal / kg	MJ / kg
Power Plant No. 2	0.70	6,921	28.98	3,774	15.80
Power Plant No. 3	0.67	7,010	29.35	3,862	16.17
Power Plant No. 4	0.77	6,726	28.16	3,577	14.98
Boilers for Factories	0.76	6,727	28.17	3,577	14.97
Households	0.76	6,727	28.17	3,577	14.97

(2) Emission factors for coal-related pollutants

In Mongolia, no officially determined emission factors are available. Therefore, foreign technical documents are referred to. One document is "Analysis of Structure of Energy Utilization and Global Environment, Science and Technology Agency of Japan, 1992" (hereinafter referred to as "Asia"), and the other is "Study of Comprehensive Energy Plan in East-Siberia and Far East of Russian Federation, the Institute of Energy Economics of Japan, 1994" (hereinafter referred to as "Russia"). Combining the information from both documents, the adaptable emission factors of coal-related pollutants, i.e. SO₂, NO_x, dust and benzpyrene, are proposed as shown in Table 6.5.

Table 6.5 Proposed Emission Factors of Coal-related Air Pollutants

Pollutants	Unit	Power plants	Boilers	Stoves	Reference
SO ₂	kg/t	19.5 x S%	15.5 x S%	12.0 x S%	1
NO ₂	kg/TJ	430	240	110	2
Dust	kg/TJ	1,045	2,000	1,420	2
Benzpyrene	g/TJ	0.17	1.5	22	2

Note : Reference 1 : Asia
Reference 2 : Russia

In selection of the emission factors from those given in above two documents, the Russia is more beneficial because it has the wider coverage of pollutants than that of the Asia. But since the emission factor for SO₂ is given with a very wide range, 180 to 680 kg/TJ, it is difficult to select proper values without the information of sulfur contents of Russian brown coal for which the emission factors were determined. Therefore, the SO₂ emission factor alone was referred to the document Asia as shown in the table.

(3) Estimated present emissions of pollutants

Present emissions of coal-related pollutants were estimated based on the afore-mentioned emission factors, coal amount and quality. They are shown in Table 6.6.

Table 6.6 Estimated Present Emissions of Coal-related Pollutants (1993)

Emission Sources		SO ₂ (1,000 ton/y)	NO ₂ (1,000 ton/y)	Dust (1,000 ton/y)	Benzpyrene (kg/y)
Power Plant	No.2	1.8	1.6	3.9	0.6
Power Plant	No.3	11.2	10.9	26.4	4.3
Power Plant	No.4	28.6	23.1	56.1	9.1
Boilers for Factory		4.7	2.7	22.5	16.9
Stoves		2.4	0.8	10.4	160.9
Total		48.7	39.1	119.3	191.9

6.1.3 Concentration of air pollutants

(1) Environmental standards of pollutant concentration

The environmental standards for concentrations of SO₂, NO₂ and dust in Mongolia are shown in Table 6.7 in comparison with those in Japan.

Table 6.7 Environmental Standards of SO₂, NO₂ and Dust

Averaging time		Mongolia	Japan
SO ₂	1 day	0.05 mg/m ³ (19 ppb)	(0.106 mg/m ³) 40 ppb
	1 hour	0.5 mg/m ³ (188 ppb)	(0.266 mg/m ³) 100 ppb
NO ₂	1 day	0.04 mg/m ³ (21 ppb)	(0.077 - 0.115 mg/m ³) 40 - 60 ppb
	1 hour	0.085 mg/m ³ (45 ppb)	
Dust		TSP	SPM
	1 day	0.15 mg/m ³	0.1 mg/m ³
	1 hour	0.5 mg/m ³	0.2 mg/m ³

Note : 1) The conversion of unit between mg/m³ and ppb for SO₂ and NO₂ was made for the condition of 20°C and 1 atmospheric pressure.

2) TSP : Total suspended particulates

SPM : Suspended particulate matter of the diameter less than 10 μm.

The daily average standards for SO₂ and NO₂ in Mongolia are about two times more stringent than those in Japan.

(2) Results of monitoring by the government

The Ministry of Environment has following three fixed stations for air quality monitoring in Ulaanbaatar City.

ST-1 : Central Laboratory of Environmental Monitoring

ST-2 : Baruun Durvon Zam

ST-3 : Bayan Khoshuu

Their locations are shown in Figure 6.1. The stations are operated by the Central Laboratory of Environmental Monitoring, a subordinate to the Ministry of Environment. The laboratory also operates a mobile monitoring unit to cover the whole city. SO₂ and NO₂ are observed at both the fixed and mobile stations.

1) Fixed monitoring stations

Results of monitoring of SO₂ and NO₂ at the fixed stations since 1990 are shown in Table 6.8 and Table 6.9.

(a) SO₂

Annual average concentrations ranged from 0.004 mg/m³ (ST-1 in 1994) to 0.013 mg/m³ (ST-3 in 1992). Annual maximum daily average values ranged from 0.03 mg/m³ (ST-2 in 1994) to 0.25 mg/m³ (ST-2 in 1992). Although the environmental standard of 0.05 mg/m³ as daily average was exceeded by the annual maximum daily average value in 1990 through 1993 at all stations, it was satisfied in 1994 at all stations. Referring to the seasonal variation, the summer average for the 4 - 5 year period was low at 0.003 mg/m³ (ST-1, ST-2) to 0.005 mg/m³ (ST-3), but the winter average was much higher at 0.011 mg/m³ (ST-1) to 0.017 mg/m³ (ST-3).

(b) NO₂

The NO₂ pollution in Ulaanbaatar can be said, in general, to be worse than that of SO₂. Annual average concentrations ranged from 0.025 mg/m³ (ST-1 in 1994) to 0.115 mg/m³ (ST-2 in 1993). All of annual maximum daily average values exceeded the environmental standard of 0.04 mg/m³ for daily average. The concentration was highest at ST-2 where even annual average values exceeded the daily average standard. This station is located besides a major road and considered to be strongly affected by automobile exhaust gases. At station ST-3, annual average values exceeded the daily average standard in 1991 and 1993. The general seasonal trend is that the concentration is highest in the winter and lowest in the summer.




Figure 6.1 Location of Monitoring Stations and Power Plants in Ulaanbaatar

2) Points monitored by mobile unit

Monitoring by the mobile unit in Ulaanbaatar City in 1994 was conducted at nine points shown in Figure 6.1. Sampling at each point was made three times a day, morning, daytime and evening, with a sampling period of two to three hours. The monitoring was repeated through the year so that the measurements at each station could cover four seasons. Results acquired at monitoring points are shown in Table 6.10.

(a) SO_2

The maximum seasonal average of hourly concentration was 0.034 mg/m^3 at point 3 in the autumn. The maximum hourly concentration in the year was 0.1 mg/m^3 at point 5 and was far below the hourly environmental standard of 0.5 mg/m^3 .

(b) NO_2

The maximum seasonal average of hourly concentration was 0.090 mg/m^3 at point 3 in the autumn. The maximum hourly concentrations in the year ranged from 0.084 mg/m^3 at point 2 to 0.2 mg/m^3 at point 6, and exceeded the hourly standard of 0.085 mg/m^3 except at point 2.

Table 6.8 Yearly Change of SO₂ and NO₂ Concentrations at Fixed Monitoring Stations in Ulaanbaatar

Year		(unit : mg/m ³)					
		ST - 1		ST - 2		ST - 3	
		SO ₂	NO ₂	SO ₂	NO ₂	SO ₂	NO ₂
1990	Max.	0.07	0.22	0.13	0.30	0.08	0.16
	Ave.	0.007	0.037	0.006	0.083	0.006	0.036
1991	Max.	0.10	0.21	0.11	0.39	0.12	0.17
	Ave.	0.009	0.034	0.009	0.086	0.006	0.042
1992	Max.	0.19	0.13	0.25	0.40	0.17	0.19
	Ave.	0.009	0.029	0.012	0.103	0.013	0.039
1993	Max.	0.07	0.11	0.10	0.38	0.06	0.17
	Ave.	0.009	0.032	0.007	0.115	0.008	0.046
1994	Max.	0.04	0.19	0.03	0.38	-	-
	Ave.	0.004	0.025	0.004	0.048	-	-
Average through 1990 to 1994	Max.	0.19	0.22	0.25	0.40	0.17	0.19
	Ave.	0.007	0.031	0.008	0.087	0.008	0.041
Environmental Standard	daily	0.05	0.04	0.05	0.04	0.05	0.04
	hourly	0.5	0.085	0.5	0.085	0.5	0.085

Note : Max. values refer to the maximum of daily average values.

Table 6.9 Seasonal Variation of SO₂ and NO₂ Concentrations at Fixed Monitoring Stations in Ulaanbaatar (1990 ~ 1994)

Monitoring Station		(unit : mg/m ³)									
		SO ₂					NO ₂				
		winter	spring	summer	autumun	whole period	winter	spring	summer	autumun	whole period
ST - 1	Max.	0.094	0.15	0.072	0.19	0.19	0.22	0.019	0.10	0.19	0.22
	Ave.	0.011	0.007	0.003	0.007	0.007	0.041	0.026	0.02	0.036	0.031
ST - 2	Max.	0.16	0.25	0.058	0.13	0.25	0.40	0.26	0.30	0.39	0.40
	Ave.	0.012	0.008	0.003	0.008	0.008	0.12	0.074	0.062	0.094	0.087
ST - 3	Max.	0.17	0.13	0.036	0.12	0.17	0.19	0.15	0.081	0.16	0.19
	Ave.	0.017	0.006	0.005	0.005	0.008	0.052	0.035	0.028	0.041	0.041

Note : 1) Winter : December to February, Spring : March to May, Summer : June to August, Autumn : September to November

2) Max. values refer to the maximum of daily average values

3) Data at ST-3 are for the period of 1990 - 1993.

Table 6.10 Result of Seasonal Monitoring of SO₂ and NO₂ in Ulaanbaatar by Mobile Unit (1994)

(unit : mg/m³)

Monitoring Point		SO ₂					NO ₂				
		winter	spring	summer	autumn	whole year	winter	spring	summer	autumn	whole year
1 YARMAG	Max.	0.024	0.013	0.009	0.028	0.028	0.084	0.100	0.028	0.090	0.100
	Ave.	0.006	0.008	0.007	0.021	0.009	0.039	0.050	0.018	0.054	0.041
2 TOLGOIT	Max.	0.044	0.015	0.016	0.037	0.044	0.078	0.068	0.025	0.084	0.084
	Ave.	0.016	0.009	0.009	0.029	0.015	0.041	0.032	0.021	0.068	0.039
3 III EMNELEG	Max.	0.018	0.012	0.009	0.040	0.040	0.147	0.051	0.031	0.127	0.147
	Ave.	0.008	0.008	0.006	0.034	0.011	0.057	0.031	0.021	0.090	0.049
4 IV SURGUUL	Max.	0.026	0.011	0.008	0.022	0.026	0.096	0.149	0.060	0.109	0.149
	Ave.	0.011	0.006	0.006	0.015	0.009	0.047	0.038	0.031	0.050	0.042
5 17 SURGUUL	Max.	0.040	0.100	0.003	0.024	0.100	0.112	0.045	0.045	0.087	0.112
	Ave.	0.013	0.020	0.002	0.016	0.014	0.059	0.030	0.026	0.044	0.044
6 ZURAGT	Max.	0.027	0.010	0.008	0.016	0.027	0.200	0.089	0.016	0.069	0.200
	Ave.	0.012	0.006	0.006	0.010	0.009	0.078	0.041	0.011	0.049	0.054
7 DUURI	Max.	0.040	0.010	0.002	0.009	0.040	0.154	0.064	0.045	0.101	0.154
	Ave.	0.015	0.006	0.002	0.007	0.009	0.066	0.042	0.027	0.070	0.054
8 ZUUN DURVONZAM	Max.	0.062	0.008	0.005	0.018	0.062	0.126	0.124	0.038	0.076	0.126
	Ave.	0.014	0.004	0.004	0.012	0.009	0.066	0.044	0.025	0.069	0.054
9 68 SURGUUL	Max.	0.042	0.011	0.008	0.042	0.042	0.082	0.088	0.013	0.079	0.088
	Ave.	0.012	0.005	0.004	0.027	0.011	0.053	0.039	0.011	0.052	0.043

Note : Winter corresponds to December, January and February, spring to March and April, summer to June, and autumn to November.

(2) Dust (TSP) concentration observed by the JICA team

Dust (total suspended particulates : TSP) concentrations were observed at existing three fixed monitoring stations in Ulaanbaatar City by using a high-volume air sampler and an analytical balance. Sampling was made by turns from one point to another because only one sampler was available. Results obtained are summarized in Tables 6.11 and 6.12. Detailed results are shown in Table 6.13.

ST-1 is located 1.5 km east of the Third power plant, and the TSP concentration was lower than in other stations. The daily average TSP concentrations at ST-1 ranged from 0.06 to 1.21 mg/m³, and the environmental standard of 0.15 mg/m³ was exceeded for 15 days out of 35 days of the measurement. The maximum concentration appeared on April 27. The overall average was 0.18 mg/m³, which was the lowest among the three points.

ST-2 is located at a busy intersection of Enkhtayvan Avenue and Zanabazar Street. The TSP concentration was possibly affected by the exhaust of motor vehicles and road dust. The daily average TSP concentrations at ST-2 ranged from 0.12 to 0.77 mg/m³, and the environmental standard of 0.15 mg/m³ was exceeded for 33 days out of 36 days of the measurement. The maximum concentration appeared on April 16. The overall average was 0.30 mg/m³, which was the medium among the three points.

ST-3 is located northwest of Ulaanbaatar City where many gers exist. Therefore, the station is likely to be influenced by the exhaust of stoves for domestic heating in the morning and the evening. The daily average TSP concentrations at ST-3 ranged from 0.16 to 1.17 mg/m³, and the environmental standard of 0.15 mg/m³ was exceeded in all of 33 days of measurement. The maximum concentration appeared on March 10, and it was as high as about eight times the standard. The overall average was 0.47 mg/m³, which was the highest among the three points.

Table 6.11 Summary of Measurement of Daily Average TSP Concentration in Ulaanbaatar (January - May, 1995)

Data		ST - 1	ST - 2	ST - 3
Average	(mg/m ³)	0.18	0.30	0.47
Minimum	(mg/m ³)	0.06	0.12	0.16
Maximum	(mg/m ³)	1.21	0.77	1.17
Number of data		35	36	33

Table 6.12 Frequency of Appearance of Daily Average TSP Concentration Levels

Concentration Level (mg/m ³)	Frequency of Appearance (day)		
	ST - 1	ST - 2	ST - 3
~0.15	20	3	0
~0.20	9	11	4
~0.30	1	10	10
~0.40	3	4	7
~0.50	1	3	4
~1.00	0	5	4
1.00 <	1	0	4
Number of data	35	36	33

Table 6.13 Daily Average Concentration of TSP in Ulaanbaatar Observed by the JICA Team (January - May, 1995)

ST - 1		ST - 2		ST - 3	
Date	TSP Concentration (mg/m ³)	Date	TSP Concentration (mg/m ³)	Date	TSP Concentration (mg/m ³)
Jan. 13	0.09	Jan. 17	0.13	Jan. 20	0.32
14	0.31	18	0.12	21	0.19
15	0.13	19	0.18	22	0.23
16	0.09	26	0.16	30	0.32
23	0.15	27	0.21	31	0.28
24	0.14	28	0.18	Feb. 01	0.30
25	0.17	29	0.18	14	0.36
Feb. 02	0.16	Feb. 08	0.16	15	0.28
03	0.07	09	0.18	16	0.29
04	0.08	10	0.16	17	0.29
05	0.07	11	0.20	18	0.29
06	0.09	12	0.22	19	0.25
07	0.08	13	0.23	20	0.39
21	0.11	28	0.33	Mar. 07	0.89
22	0.10	Mar. 01	0.21	08	0.41
23	0.20	02	0.19	09	0.20
24	0.12	03	0.24	10	1.17
25	0.11	04	0.30	11	0.16
26	0.16	05	0.32	12	0.44
27	0.11	06	0.42	13	0.50
Mar. 14	0.09	21	0.59	Apr. 05	1.71
15	0.16	22	0.30	06	1.28
16	0.46	23	0.60	07	0.39
17	0.34	24	0.26	08	0.32
18	0.24	Apr. 11	0.32	09	0.20
19	0.10	12	0.24	10	1.04
20	0.14	13	0.20	May 02	0.55
Apr. 24	0.17	14	0.40	03	0.48
25	0.19	15	0.74	04	0.31
26	0.17	16	0.77	05	0.57
27	1.21	May 09	0.47	06	0.60
28	0.18	10	0.23	07	0.29
29	0.31	11	0.70	08	0.28
30	0.06	12	0.16		
May 01	0.06	13	0.18		
		14	0.15		

6.2 Air quality in the future

6.2.1 Estimated emissions of pollutants from coal-related facilities

From the result of the coal demand forecast described in Section 2.4, expected coal consumption in Ulaanbaatar by sector in 2000, 2005 and 2010 is summarized in Table 6.14. For each future year, two cases are considered: high demand case and low demand case.

Amounts of pollutant emissions in the future years resulting from the forecasted coal consumption were estimated in the same manner as that in Section 6.1.1. The result of the estimation is shown in Table 6.15.

6.2.2 Ground-level concentration of SO₂ and NO₂ emitted from power plants

(1) Basic consideration

Wind characteristics in Ulaanbaatar are complex because the city lies on the basined topography surrounded by mountains and the Tuul River. Instantaneous wind directions vary from place to place as it was often observable through the trajectories of the smoke from the Third and the Fourth power plants. Atmospheric thermal inversion is said to occur frequently in the winter in Ulaanbaatar. The inversion layer acts as a lid because it prevents pollutants from dispersing into the upper atmosphere. Although the height of the lid changes from time to time, pollutants from the stacks of the Third and the Fourth power plants are often discharged above the lid. In this case, the contributions of these power plants to the ground-level pollutant concentration are relatively small.

In the following analysis, ground-level concentrations of SO₂ and NO₂ emitted from the power plants are estimated under the no-lid condition where the emissions from the power plants have relatively large influence on the ground.

(2) Estimation of ground-level concentrations of SO₂ and NO₂

The following Sutton equation is used to estimate a maximum ground-level concentration of a pollutant.

$$C_{\max} = 0.234(Q/uHe^2)(Cz/Cy)$$

Table 6.14 Forecasted Coal Consumption in Ulaanbaatar (unit: 1,000 ton)

		1993	2000		2005		2010	
		Actual	H	L	H	L	H	L
Power	No. 2	129	0	0	0	0	0	0
Plants	No. 3	861	738	668	880	766	1,073	890
	No. 4	1,906	2,102	1,961	2,377	2,027	2,875	2,364
	Sub-total	2,896	2,840	2,630	3,257	2,794	3,948	3,255
Industries	Industry	400	286	273	369	335	498	420
	Add. Indus.	0	100	100	200	200	300	300
	Sub-total	400	386	373	569	535	798	720
Others	Transport		30	30	33	33	36	36
	Agriculture		204	204	226	226	249	249
	Residential		291	291	322	322	355	355
	Others		267	267	295	295	326	326
	Sub-total	260	793	793	875	875	966	966
Total		3,556	4,019	3,795	4,701	4,203	5,712	4,941

Note : H : high demand case, L : low demand case

Table 6.15 Estimate Pollutants Emissions Corresponding to Forecasted Coal Consumption in Ulaanbaatar

	Year 2000 (High demand case)				Year 2000 (Low demand case)			
	SO ₂ (1,000 ton)	NO ₂ (1,000 ton)	Dust (1,000 ton)	Benzpyrene (kg)	SO ₂ (1,000 ton)	NO ₂ (1,000 ton)	Dust (1,000 ton)	Benzpyrene (kg)
P.P. No. 2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
P.P. No. 3	9.6	9.3	22.6	3.7	8.7	8.4	20.2	3.3
P.P. No. 4	31.6	25.5	61.9	10.1	29.4	23.8	59.4	9.4
Industries	4.6	2.6	21.8	16.3	4.4	2.5	21.0	15.8
Stoves	7.2	2.5	31.7	491.2	7.2	2.5	31.7	491.2
Total	53.0	39.8	138.0	521.3	49.8	37.2	132.4	519.7
	Year 2005 (High demand case)				Year 2005 (Low demand case)			
	SO ₂ (1,000 ton)	NO ₂ (1,000 ton)	Dust (1,000 ton)	Benzpyrene (kg)	SO ₂ (1,000 ton)	NO ₂ (1,000 ton)	Dust (1,000 ton)	Benzpyrene (kg)
P.P. No. 2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
P.P. No. 3	12.0	11.1	27.0	4.4	10.5	9.7	23.5	3.8
P.P. No. 4	32.4	28.8	70.0	11.4	27.7	24.5	59.7	9.7
Industries	6.7	3.8	32.0	24.0	6.3	3.6	30.1	22.6
Stoves	8.0	2.7	35.0	542.3	8.0	2.7	35.0	542.3
Total	59.1	46.4	164.0	582.1	52.4	40.5	148.3	578.4
	Year 2010 (High demand case)				Year 2010 (Low demand case)			
	SO ₂ (1,000 ton)	NO ₂ (1,000 ton)	Dust (1,000 ton)	Benzpyrene (kg)	SO ₂ (1,000 ton)	NO ₂ (1,000 ton)	Dust (1,000 ton)	Benzpyrene (kg)
P.P. No. 2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
P.P. No. 3	14.6	13.5	32.9	5.4	12.2	11.2	27.3	4.4
P.P. No. 4	39.2	34.8	84.6	13.8	32.3	28.6	69.6	11.3
Industries	9.4	5.4	44.9	33.7	8.5	4.9	40.6	30.4
Stoves	8.8	3.0	38.6	598.7	8.8	3.0	38.6	598.7
Total	72.1	56.7	201.1	651.6	61.7	47.7	176.1	644.9

- where, C_{max} : Maximum ground-level pollutant concentration (mg/m^3)
 Q : Pollutant emission intensity (mg/s)
 u : Wind speed (m/s)
 H_e : Effective stack height (m)
 C_z, C_y : Sutton's dispersion parameters

The effective stack height H_e is calculated as follows.

$$H_e = H + dH$$

- where, H : Actual stack height (m)
 dH : Rise of the plume (m) to be calculated by the following CONCAWE equation

$$dH = 0.175(Qh)^{1/2}(u)^{-3/4}$$

- where, Qh : Heat emission intensity (cal/s) = $(d)(C_p)(Q_g)(dT)$
 d : Density of exhaust gas at $0^\circ C$ ($1.293 \times 10^3 g/m^3$)
 C_p : Specific heat at constant pressure ($0.24 cal/^\circ K/g$)
 Q_g : Gas discharge rate ($m^3 N/s$)
 dT : Difference between exhaust gas temperature and air temperature ($^\circ K$)

The annual average wind speed in Ulaanbaatar during 1983 - 1992 was 2.1 m/s as shown in Table 6.16. Therefore, the wind speed of 2.0 m/s was used.

Table 6.16 Monthly Mean Temperature and Wind Speed in Ulaanbaatar (1983 - 1992)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Temperature ($^\circ C$)	-21.3	-17.3	-8.7	0.8	10.4	14.3	16.5	15.2	8.3	1.0	-11.1	-18.5	-0.9
Wind speed (m/s)	1.5	2.0	2.6	3.7	3.8	3.3	2.8	2.7	2.8	2.5	2.0	1.7	2.1

The value of C_z/C_y was selected to be 0.15 which corresponds to the atmospheric stability class of "neutral."

The stack height of each power plant is as follows:

the Second plant : 100 m, the Third plant : 150 m, the Fourth plant : 250 m

Table 6.17 Estimated Maximum Ground-level Concentration of SO₂

Source	Item	1993	2000		2005		2010	
		Present	H	L	H	L	H	L
P.P. No. 2	Cmax (mg/m ³)	0,022	-	-	-	-	-	-
	Xmax (m)	6,851	-	-	-	-	-	-
P.P. No. 3	Cmax (mg/m ³)	0,037	0,034	0,032	0,039	0,036	0,043	0,039
	Xmax (m)	13,780	13,211	12,869	13,863	13,346	14,676	13,910
P.P. No. 4	Cmax (mg/m ³)	0,037	0,040	0,038	0,039	0,035	0,043	0,038
	Xmax (m)	21,712	22,244	21,864	22,952	22,043	24,145	22,921

Note : 1) H : High coal demand case, L : Low coal demand case
 2) Cmax : Maximum ground-level concentration
 3) Xmax : Distance from the source to the point of Cmax

Table 6.18 Estimated Maximum Ground-level Concentration of NO₂

Source	Item	1993	2000		2005		2010	
		Present	H	L	H	L	H	L
P.P. No. 2	Cmax (mg/m ³)	0,020	-	-	-	-	-	-
	Xmax (m)	6,851	-	-	-	-	-	-
P.P. No. 3	Cmax (mg/m ³)	0,036	0,033	0,031	0,036	0,034	0,040	0,036
	Xmax (m)	13,780	13,211	12,869	13,863	13,346	14,676	13,910
P.P. No. 4	Cmax (mg/m ³)	0,030	0,032	0,031	0,034	0,031	0,038	0,034
	Xmax (m)	21,712	22,244	21,864	22,952	22,043	24,145	22,921

Note : 1) H and L : Same as Table 6.17
 2) Cmax and Xmax : Same as Table 6.17

Computed maximum ground-level concentrations of SO₂ and NO₂ emitted from each of three power plants are shown in Table 6.17 and Table 6.18, respectively. Computations for the future years were made for the two cases of coal demand: high demand and low demand.

Although the total coal consumption in the power plants is expected to increase from 1993 to 2010, the results of the simplified simulation in Tables 6.17 and 6.18 indicate that the increases of the ground-level concentrations of SO₂ and NO₂ emitted from each of the Third and the Fourth power plants are rather small at 10 - 15 %.

6.2.3 Dust and benzpyrene

(1) Dust

As shown in Table 6.14, the current total coal consumption in three power plants accounts for about 80 % of the total coal consumption in Ulaanbaatar. In the Fourth power plant which consumes coal by 66 % of the power plants total, electrostatic precipitators with dust collection efficiency over 98 % are installed, and the stack is as high as 250 m. Therefore, its influence on the ground-level concentration of dust is considered to be relatively small.

In the Third power plant which consumes coal by 30 % of the power plants total, scrubbers are installed and the stack height is 150 m. This plant also is considered to have relatively small influence on the ground-level concentration of dust.

The coal consumption in the Second power plant is small at 5 % of the power plants total. But since the stack height is lower at 100 m and no dust collectors are installed, it is likely to have certain influence on the ambient concentration of dust. However, there will be no dust emission from this plant in 2000 since it is planned to be abolished.

Attention should be paid to dust emissions from stoves in gers. Although amount of the emission from each stove is small, these stoves are considered to be a significant cause of dust pollution in the zones concentrated with gers, because the height of stacks for these stoves are very low.

(2) Benzpyrene

Among common fuels such as oil, coal, gas and wood, generation of benzpyrene through fuel combustion is generally highest with coal followed by wood, oil and gas. The generation rate with a fuel widely varies depending on the combustion efficiency; the lower the combustion

efficiency, the higher the generation rate. Since combustion efficiency of household stoves is generally lower than that of large combustion facilities due to incomplete combustion, the benzpyrene generation per unit amount of coal is much higher in household stoves than in power generation boilers. In addition, stacks of household stoves are very low. Therefore, benzpyrene generated in coal-burning household stoves in Ulaanbaatar must have much larger environmental impact than that generated in power plants.

6.3 Technical potential of air pollution control

6.3.1 Sources and pollutants necessary to be controlled

As discussed above, among stationary air pollution sources burning coal in Ulaanbaatar, low-height emission sources such as household heating stoves and small-to-medium size boilers, rather than power generation boilers, are likely to have large influence on the ground-level air quality, particularly on the concentrations of dust and benzpyrene.

Therefore, it is considered that the priority in air pollution control should be placed on the control of low-height emission sources for improvement of air quality in Ulaanbaatar towards the future.

6.3.2 Introduction of bio-briquette

The switchover of presently used coal to other quality fuels such as gas is economically difficult in Mongolia. A more realistic measure would be the use of briquette made of Mongolian coal in stoves and small-to-medium size boilers. Among various kinds of briquette, that produced by mixing biomass into pulverized coal and shaping into pellets by high compression, called "bio-briquette", is considered to be most suitable in terms of cost and pollutant reducing effects. If necessary, a desulfurization agent such as lime can be also added.

An example in Japan for the effects of bio-briquette in reducing pollutant emission is reported to be as follows:

Reduction of dust (smoke and soot) : about 70 %

Reduction of SO₂ (with an agent) : 75 - 85 % for coals of the sulfur content at 1 % or less

80 - 93 % for coals of the sulfur content at more than 1 %

When dust is reduced, benzpyrene would be also reduced roughly in proportion.

Reductions of pollutant emissions in Ulaanbaatar by the use of bio-briquette are roughly estimated under the following conditions and assumptions.

Target year : 2010

Case of coal demand	:	high demand
Sources using bio-briquette	:	household stoves and boilers other than power generation boilers
Dust and benzpyrene reduction rate	:	70 %
SO ₂ reduction rate	:	75 % (sulfur content of coal : 0.76 %)

The estimated reductions of pollutant emissions are shown in Table 6.19

Table 6.19 Reduction of Pollutant Emission by the Use of Bio-briquette in Stoves and Small-to-medium Size Boilers (2010, Case of high coal demand)

Pollutant Source	Pollutant Emission Without use of bio-briquette			Pollutant Emission With use of bio-briquette		
	Dust	Benzpyrene	SO ₂	Dust	Benzpyrene	SO ₂
	(1,000 ton)	(kg)	(1,000 ton)	(1,000 ton)	(kg)	(1,000 ton)
Power plants	117.5	19.2	53.8	117.5	19.2	53.8
Boilers	44.9	33.7	9.4	13.5	10.1	2.4
Stoves	38.6	598.7	8.8	11.6	179.6	2.2
Total	201.1	651.6	72.1	142.6	208.9	58.4
(%)	(100)	(100)	(100)	(71)	(32)	(81)

Table 6.19 indicates significant reductions of pollutant emissions through the use of bio-briquette, particularly of dust and benzpyrene emissions. Moreover, the effects on the reduction of the ground-level concentrations will be much larger.

If SO₂ pollution due to stoves and boilers is confirmed to be insignificant, bio-briquette can be made without addition of a desulfurizing agent.

6.4 Environmental protection plan

As result of this chapter, coal-burning household stoves (particularly, stoves in gers) in

Ulaanbaatar have much larger environmental impact for pollutant emissions and Bio-briquette is key factor in order to improve the pollutant emissions. In this section, Bio-briquette plant for stoves in gers is investigated.

6.4.1 Coal consumption of gers' stoves

At present, there are about 50 thousand gers in Ulaanbaatar and it is said that about 4~5 tons per annum of coal are consumed in a ger. Moreover, it is also said that about 20% of coal is lost due to pulverized. If number of gers in Ulaanbaatar aren't change in the future (2010), total coal consumption in gers amounts to 200 thousand ton per annum. Amount of benzpyrene through these coal combustion will be 154kg per year. However, it is expected to reduce amount of benzpyrene by 70% through using Bio-briquette.

6.4.2 Required capacity and investment cost of Bio-briquette plants

Bio-briquette will be reduced coal consumption in gers because of decreasing of pulverized coal loss and improvement of combustion efficiency. As the result, it is considered that the capacity of Bio-briquette plants will need total 160 thousand tons per annum. However, it is difficult immediately to finance in order to construct Bio-briquette plants. It is supposed that the area of gathering gers are half of total gers. Therefore, first of all, Bio-briquette plants should be constructed for half of total gers and capacity of the plant is 80 thousand tons per annum. Considering financing, it is desirable to construct two plants of 40,000 t/y capacity every five years. Required investment cost and operating cost is described in section 7.2.2 and according to this section, capital investment cost of about 40,000 t/y capacity of Bio-briquette plant is about US\$ 6.5 million and operating cost without raw materials is about US\$ 2.7/ton-briquette. Construction of Bio-briquette plant should be examined in view of the environmental protection and improving the energy efficiency.

7 Preliminary Study on Selected Plans

7.1 Preliminary study on selected coal development plans

In order to evaluate economics of the selected coal mine development plans, the detailed plans of each coal mines are examined in this section. The plans include project term, mining method, mining equipments, manpower, cost estimation, surface facilities, social infrastructure, etc. Based upon these data, for the purpose of economic evaluation, coal prices at 10% EIRR is calculated on the basis of the following criteria:

- project life : 23 years
- time value of money : constant price in 1994 with 400Tg/US\$
- project financing : 100% of own fund
- price and the life span of equipment : based on Part 1 of the study
- inflation : no inflation

Formula for cash flow used in the economic analysis of EIRR is as follows:

$$\begin{aligned} & +\text{Revenue} \\ & -\text{Total operating cost} \\ & -\text{Total capital cost} \\ & \underline{-\text{Increase in working capital}} \\ & = \text{Cash flow for EIRR on total project} \end{aligned}$$

However, economic evaluation of Tavantolgoi mine can not be calculated so that the development of the coal mine depends on the electric power market and the coking coal market in the neighbor countries, which the demands and price of the products cannot be estimated at present time.

7.1.1 Tsaidamnuur mine

(1) Details of plan

1) Infrastructure and surrounding mines

This coal deposit is located in the south of Baganuur mine. A 110kV and a 200V power lines are located in the east and south of the Tsaidamnuur deposit. Two road routes pass through the deposit. Bagahangai coal mine and a fluorite mine are located around the Tsaidamnuur deposit.

The features of local conditions are as follows:

- Infrastructure facilities are accessible.
- Geological structure and coal quality are very similar to those of Baganuur mine.
- Therefore, it is easy to develop this deposit with a small investment for the infrastructure.

2) Design basis Coal mine development plan is made on the following conditions:

- The project term is 23 years.
- Oxidized coal from the surface till 10m depth is regarded as overburden, which must be removed.
- Stripping ratio and mining depth are up to 4.2 and less than 200m, respectively.
- Stripping ratio is defined as overall average stripping ratio and constant during project term.
- Bench cut method by using shovel and truck system is adopted as the mining method.
- Average transportation distance is three km and constant during project term.

(2) Machinery requirement, manpower, cost estimation, etc.

The proposed mining plan is shown on Table 7.1 including major mining machine and surface facilities.

1) Major mining machines

The fleet for overburden removal consists of 12 m³ electric shovel and 80 ton dump trucks. The electric shovel is selected because it has stronger digging force and durability and can be driven by electricity instead of imported fuel oil. Because the electric mining machine is suitable for the large-scaled work with less frequency of working place change, it is necessary to operate it in advancing stripping activity. This fleet is recommended as a superior in Part 1 study. The fleet for coal mining consists of 5.7 m³ backhoe type hydraulic shovel and 46 ton dump trucks. Backhoe type hydraulic shovel has advantages as follows:

- precise selective mining effective for coal quality control.
- adaptability for overburden removal with its greater digging force.
- capability of digging below the machine level.
- capability of performing incidental works such as making drainage ditch and treating surface of working face, etc.

2) Manpower requirement

Manpower requirement in the Tsaidamnuur coal mine is estimated based on the Shivee Ovoo and 480 persons will be required. Manpower requirement in detail should be established by categories in the next step.

3) Surface facilities

(a) General

Usually the following facilities are required; workshops and warehouses, power supply and distribution, water supply, dewatering and drainage, crushing/sizing/loading, office, stockpile, transportation, communication, etc.

(b) Workshop

Workshops must provide adequate facilities for the inspection, repair and maintenance of plants and mining equipment. Repair shops require the following spaces or bays for:

- Equipment repair
- Heavy vehicle repair
- Light vehicle repair
- Electric repair
- Undercarriage repair

Workshop areas are composed of repair shop, service facility, warehouses, material handling, vehicle washing, vehicle parking, etc. Mine fleet services are performed in general near the working areas and are included refueling, routine servicing, tire maintenance, etc. Service facilities provide,

- Light vehicle services
- Heavy vehicle services
- Washing services
- Refueling and greasing services

Mines are usually located in remote areas, therefore they should maintain stocks of spare parts, consumable items and replacement components required for plants and equipment in the warehouses.

(c) Power supply and distribution facilities

Power is to be obtained from the CES (Central Energy System) through existing power

lines and/or extension. Sometimes power is also provided through a private generating station. Transformers provide power at the required working voltage. Power is generally transmitted via overhead line to transformers, then by cable to the equipment.

(d) Water supply facilities

Potable water and industrial water are required for mining operations and townships. Hot water is also needed for both mining operations and townships as well. Underground water from the dewatering wells and drainage water may not be suitable for drinking, but for industrial purposes. All sources should be considered in order to select the optimum; rivers, lakes, groundwater, etc. It is necessary to investigate to prove the sustainability of a water source. Water is taken from rivers, lakes or groundwater, then sent to the pump station through pipelines, sometimes directly, sometimes via water treatment facilities, at the mining complex, and then delivered to places required. A number of processes require steam and hot water for heating and industrial purposes. Therefore boilers are to be constructed to meet the demand. Hot water is delivered from the coal-fired boilers to places required through insulated pipelines.

(e) Dewatering and drainage facilities

If the groundwater level is high and affects on mining conditions and coal quality, it is necessary to dewater and lower the water level before mining. The groundwater is to be dewatered for a certain period before mining starts. It will be very difficult to mine the coal seams without dewatering, if the moisture content of the seams are very high. Therefore, it is essential to dewater the groundwater without any delay. Water drainage is of prime importance for open pit mining operations. Ditches and sumps should be dug in and around the pit, and pumping facilities should be installed for the drainage.

(f) Crushing/sizing/loading facilities

In regard to the coal quality, end users of coal suffer not only from poor quality of coal but also uncrushed run-of-mine coal, mixing with lumpy waste and foreign materials. A crushing, sizing and loading plant is needed for the coal mine, and all the run-of-mine coal should be processed at the plant before shipping.

(g) Office facilities

In order to maintain mining and plant operations, an operational center will be required for management, planning and control of daily activities.

(h) Stockpile facilities and transportation facilities

Crushed coal is delivered from the crushing/sizing plant to a loading section. Most of the coal is directly transhipped to train loading silos through a conveyor system. In the case that freight cars are not available for loading, crushed coal is diverted to stockpile areas for temporary stock. Spontaneous combustion characteristics of coal must be seriously studied and proper procedures and facilities should be provided in both the raw coal stockyard and product coal stockyard. A process of natural drying of coal may be required to reduce moisture content.

(i) Communication

It is important to consider any communication both external and internal services. Telephone, facsimile and mobile radio services may be required for the mine operations.

(j) Mine infrastructure

a) Townships

Due to the remote location of the project, a new town will be developed to provide accommodation for the labor force. It is expected that the population of the town will depend on the total labor force. The town development will commence at the same time as the mine pre-production development, so that accommodation will be available for operational personnel when mine development starts. Location, size of workforce, mine life, existing facilities, and company and government policies will influence the magnitude of the residential and community facilities required. Township size is based on the workforce requirements and allowance. The following facilities should be provided for the town:

- Housing: for employees
- Roads
- Services: potable water, power, sewerage and drainage
- Recreation facilities
- Shopping facilities

- Community facilities: town hall, fire station, police, bank and post office
- Commercial facilities
- Medical facilities
- Educational facilities

As mentioned earlier, construction costs will be covered by the three major portions:

- National and/or local governments,
- Coal mine,
- Private or commercial entities

The coal mining company will be responsible to construct houses for employees. The following costs are estimated for the construction of town-ships and housings.

- Employees	480
- Population	1,300
- Cost estimates (US\$ 1,000)	9,000

It is estimated that total costs of townships are US\$ 26,000 thousand. However, US\$17,000 thousand out of total costs should be prepared by governments. It is expected that the coal mining company will prepare US 9,000 thousand for developing townships.

Governments	17,000
Company	9,000
Private	-
Total	26,000

b) Transportation and power line

Consideration and evaluation of the available transportation are essential. The transportation systems available for consideration include:

- Road
- Railroad

(i) Road

Two kilometers of roads are to be constructed for the access road from the main roads.

Cost estimate: $247/\text{km} \times 2\text{km} = 495$ (US\$ 1,000)

(ii) Railroad in the property

Two kilometers of side track road is to be constructed for the material and coal haulage.

- Cost estimate for side track: $675/\text{km} \times 2\text{km} = 1,350$ (US\$ 1,000)

- Rolling stock = 1,350 (US\$1,000)

Assumption: All the produced coal will be hauled to Ulaanbaatar

Haul distance to Ulaanbaatar is 90km

Unit rolling stock: \$7,500/million ton. km

- Total costs of railroad (US\$1,000)

Side track 1,350

Rolling stock 1,350

Total 2,700

(iii) Power line and communication method

Power line is to be extended from the CES for convenience. It is important to consider any communication both the external and internal services. Telephone, facsimile and mobile radio services may be required for the mine operations.

Power line: $\$71,250 \times 2\text{km} \approx 143$ (US\$1,000)

(iv) Other = 334 (US\$1,000)

c) Total (a)+b)) 12,672 (US\$1,000)

4) Infrastructure development costs

(a) General

New facilities of townships, railroads, roads, power lines, etc. should be developed for the new potential mines.

a) Road

Existing roads in the area provide access to the portion of the property. Some parts of roads will be newly developed.

b) Railroad

The coal will be transported by trains to consuming cities. A new rail line is to be constructed from the project site to connect with the existing line.

c) Power line and communication

It is necessary to extend power line for supplying power from CES system.

d) Townships (Undertating by governments)

(b) Cost estimates

Railroad:	Length (km)	10
	Costs (US\$1,000)	6,750
Road:	Length (km)	10
	Costs (US\$1,000)	2,475
Power line:	Length (km)	25
	Costs (US\$1,000)	1,780
Other facilities:		1,100
Town ships		17,000
Total (US\$1,000)		29,105

(3) Total capital cost

Capital cost for coal mine consists of the major mining equipment and the general purpose equipment and the surface facilities, which is not include any taxation.

Initial capital costs:		70,800 (US\$ 1,000)
Replacement cost :		85,600 (US\$ 1,000)
Total capital costs :		156,400 (US\$ 1,000)
Infrastructure cost:	Railroad	6,800 (US\$ 1,000)
	Road	2,500 (US\$ 1,000)
	Power line	1,800 (US\$ 1,000)
	Townships	17,000 (US\$ 1,000)
	Other	1,100 (US\$ 1,000)
	Sub-total	29,100 (US\$ 1,000)
Grand total:		185,500 (US\$ 1,000)

(4) Operating costs

Operating costs consist of two components; material and labor and depreciation. The cost index of \$1.43/BCM of the shovel and truck system is used for the comparison of new mining system in Baganuur coal mine renovation study in Part 1. This index is used to plan the new potential mines because the shovel and truck system is adopted, too.

(5) Economic evaluation

Coal price in 10% EIRR (Economic Internal Rate of Return) was calculated in order to evaluate economic of the project. Project year is 23 and capital cost of initial and replacement is invested as shown Table 7.1. These capital cost is shown in border price based on Part 1 of the study. Operating cost per ton-coal that is calculated by the cost index of US\$1.43/BCM is US\$5.43/t. The economic evaluation doesn't include social infrastructure (Social infrastructure means the cost of railroad, road, and power line from coal mine site to existing facilities, cost of township and other costs). Table 7.2 shows the net cash flow of EIRR every year and coal price in 10% EIRR is US\$11.1/t (4,444Tg/t).

Table 7.1 Proposed Mining Plan of Tsaidamnur Mine (1/2)

1) Details of plan

Coal seam condition			Reserves ($\times 10^6 t$)			Development plan								
Thickness (m)	Dip ($^\circ$)	Strike length (km)	Depth (m)	Stripping ratio	Reserves ($\times 10^6 t$)	Annual Production ($\times 10^4 t$)	Cumulative coal Production ($\times 10^6$)	Strike length (km)	Depth (m)	Total Stripping ratio	Average overburden removal ($\times 10^3 m^3$)	Volume of coal production ($\times 10^6 m^3$)	Fleet number	
	5	4	200	2.3	864	2,000	40,000	2	34	3.0	6,000	1,600	Coal mining	Stripping
		5											6	5.7m ² 46t
													1	3 (2.41)

2) Cost estimation

Capital costs (Initial) ($\times 10^5$ US\$)

Equipment	Mining equipment		General purpose equipment	Surface facilities		Grand Total
	Specification	Quantity		Amount of price		
Power shovel	12m ² (waste)	3	(Bulldozer,	Workshop	1,355	70,816
Hydraulic shovel	5.7m ² (coal)	1	Grader,	Warehouse	543	
Front end loader	5 m ²	2	Front end loader,	Coal stockyard	799	
Dump truck	80t (waste)	20	Service truck,	Sizing & loading	4,704	
Dump truck	40t (coal)	8	Water truck,	Power distribution	1,038	
Bulldozer	400 Hp	4	Fuel truck,	Communication	85	
Grader	254 Hp	4	Anfo truck,	Drainage & water supply	4,000	
Drill	160 mm	4	etc.)	Mine office	500	
Sub-Total			4,454	Explosiv magazine	200	
				Boiler	300	
				Road maintenance	300	
				Coal quality system	240	
				Mine infrastructure	12,672	
Equipment total			44,080	Subtotal	26,736	

Table 7.1 Proposed Mining Plan of Tsaidamuur Mine (2/2)

Capital Costs for coal mine (Initial & replacement)

Capital costs for infrastructure

Operating Costs

US\$ 000' s

Year	Mining Equipment	General Purpose Equipment	Surface Facilities	Total
-3	—	153	12,672	12,825
-2	24,242	2,553	9,180	35,975
-1	15,384	1,748	4,884	22,016
Initial total	39,626	4,454	26,736	70,816
1	—	—	—	—
2	—	—	—	—
3	—	—	—	—
4	—	—	4,000	4,000
5	—	—	255	255
6	—	—	—	—
7	16,224	153	2,181	18,558
8	11,375	2,553	799	14,727
9	—	1,748	6,976	8,724
10	—	—	85	85
11	—	—	255	255
12	—	—	—	—
13	—	—	—	—
14	—	153	4,000	4,153
15	16,224	2,553	2,181	20,958
16	11,375	1,748	799	13,922
17	—	—	—	—
18	—	—	—	—
19	—	—	—	—
20	—	—	—	—
Replacement total	55,198	8,908	21,531	85,637
Total capital	94,824	13,362	48,267	156,453

Railroad	Length (km)	Costs (\$000' s)
	10	6,750
Road		
	10	2,475
	25	1,780
Powerline (km)		
	1,780	—
Township		
Population	1,300 (480 employees included)	—
	17,000	—
Other		
	1,100	—
Total	29,105	—

Year	Waste Million BCM	Coal Million ton	Costs Million \$	\$/T
-3	—	—	—	—
-2	4.72	1.00	7.89	7.89
-1	5.42	1.50	9.47	6.31
1	6.00	2.00	10.87	5.43
2	6.00	2.00	10.87	5.43
3	6.00	2.00	10.87	5.43
4	6.00	2.00	10.87	5.43
5	6.00	2.00	10.87	5.43
6	6.00	2.00	10.87	5.43
7	6.00	2.00	10.87	5.43
8	6.00	2.00	10.87	5.43
9	6.00	2.00	10.87	5.43
10	6.00	2.00	10.87	5.43
11	6.00	2.00	10.87	5.43
12	6.00	2.00	10.87	5.43
13	6.00	2.00	10.87	5.43
14	6.00	2.00	10.87	5.43
15	6.00	2.00	10.87	5.43
16	6.00	2.00	10.87	5.43
17	6.00	2.00	10.87	5.43
18	6.00	2.00	10.87	5.43
19	1.68	1.00	3.55	3.55
20	0.18	0.50	0.83	1.66
Total	120.00	40.00	217.40	5.44

※ million bcm

Details of Operating cost

Index	Unit
Operating cost	\$/BCM 1.43
Strip ratio	3.0 : 1
Production	※
Waste	6.0
Coal	1.6
Total	7.6

Table 7.2 Economic Evaluation of Tsaidamnur Mine

Coal price of 10% EIRR 4,444T/gt

Year	1	2	3	4	5	6	7	8	9	10	11	12
Price (\$US/t)	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1
Production (mil.t)	0.0	1.0	1.5	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
Revenue(mil.\$US)	0.0	11.1	16.7	22.2	22.2	22.2	22.2	22.2	22.2	22.2	22.2	22.2
Investment (mil.\$)	12.8	36.0	22.0	0.0	0.0	0.0	4.0	0.3	0.0	18.6	14.7	8.7
A Initial	12.8	36.0	22.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Mining Equipment	0.0	24.2	15.4									
General Purpose Equipment	0.2	2.6	1.7									
Surface Facilities	12.7	9.2	4.9									
B Replacement	0.0	0.0	0.0	0.0	0.0	0.0	4.0	0.3	0.0	18.6	14.7	8.7
Operating Cost (mil.\$)	0.0	5.4	8.1	10.9	10.9	10.9	10.9	10.9	10.9	10.9	10.9	10.9
NCF before Tax (mil.\$)	-12.8	-30.3	-13.5	11.4	11.4	11.4	7.4	11.1	11.4	-7.2	-3.4	2.6
(=Revenue-Investment-Operating Cost)												
	13	14	15	16	17	18	19	20	21	22	23	total
Price (\$US/t)	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1
Production (mil.t)	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.0	0.5	40.0
Revenue(mil.\$US)	22.2	22.2	22.2	22.2	22.2	22.2	22.2	22.2	22.2	11.1	5.6	444.4
Investment (mil.\$)	0.1	0.3	0.0	0.0	4.2	21.0	13.9	0.0	0.0	0.0	0.0	136.5
A Initial	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	70.8
Mining Equipment												39.6
General Purpose Equipment												4.5
Surface Facilities												26.7
B Replacement	0.1	0.3	0.0	0.0	4.2	21.0	13.9	0.0	0.0	0.0	0.0	85.7
Operating Cost (mil.\$)	10.9	10.9	10.9	10.9	10.9	10.9	10.9	10.9	10.9	5.4	2.7	217.1
NCF before Tax (mil.\$)	11.3	11.1	11.4	11.4	7.2	-9.6	-2.6	11.4	11.4	5.7	2.8	70.9
(=Revenue-Investment-Operating Cost)												

Discount Rate 10%
 Total NPV before Tax 0 (mil.\$)
 EIRR (IRR on NCF B.Tax) 10%

7.1.2 Tugrugnuur mine

(1) Details of plan

1) Infrastructure

- This coal deposit is located 25km east of the existing railway.
- Power will be supplied through a 110kV transmission line which is laid from Baganuur mine to Shivee Ovoo mine via Baganjargalan. A 220V power line is also laid from Maint to Baganjargalan which is one of the regional township around the deposit.
- Geological, mining and infrastructure conditions are similar to those of Tsaidamnuur deposit.
- It will be easy to develop this deposit as well as Tsaidamnuur with a small investment for the infrastructure.

2) Design basis

Coal mine development plan is made on the following conditions:

- The project term is 23 years.
- Oxidized coal from the surface till 10m depth is regarded as overburden, which must be removed.
- Stripping ratio and mining depth are up to 4.2 and less than 200m, respectively.
- Stripping ratio is defined as overall average stripping ratio and constant during project term.
- Bench cut method by using shovel and truck system is adopted as the mining method.
- Average transportation distance is three km and constant during project term.

(2) Machinery requirement, manpower, cost estimation, etc.

The proposed mining plan is shown on Table 7.3 including major machines and surface facilities.

1) Major mining machines

The fleet for overburden removal consists of 12 m³ electric shovel and 80 ton dump trucks. The electric shovel is selected because it has stronger digging force and durability and can be driven by electricity instead of imported fuel oil. Because the electric mining machine is suitable for the large-scaled work with less frequency of working place change, it is

necessary to operate it in advancing stripping activity. This fleet is recommended as a superior in Part 1 study. The fleet for coal mining consists of 5.7 m³ backhoe type hydraulic shovel and 46 ton dump trucks. Backhoe type hydraulic shovel has advantages as follows:

- precise selective mining effective for coal quality control.
- adaptability for overburden removal with its greater digging force.
- capability of digging below the machine level.
- capability of performing incidental works such as making drainage ditch and treating surface of working face, etc.

2) Manpower requirement

Manpower requirement in the Tugrugnuur coal mine is estimated based on the Shivee Ovoo, and 570 persons will be required. Manpower requirement in detail should be established by categories in the next step.

3) Surface facilities

(a) General

Usually the following facilities are required; workshops and warehouses, power supply and distribution, water supply, dewatering and drainage, crushing/sizing/loading, office, stockpile, transportation, communication, etc.

(b) Workshop

Workshops must provide adequate facilities for the inspection, repair and maintenance of plants and mining equipment. Repair shops require the following spaces or bays for:

- Equipment repair
- Heavy vehicle repair
- Light vehicle repair
- Electric repair
- Undercarriage repair

Workshop areas are composed of repair shop, service facility, warehouses, material handling, vehicle washing, vehicle parking, etc. Mine fleet services are performed in general near the working areas and are included refueling, routine servicing, tire

maintenance, etc. Service facilities provide,

- Light vehicle services
- Heavy vehicle services
- Washing services
- Refueling and greasing services

Mines are usually located in remote areas, therefore they should maintain stocks of spare parts, consumable items and replacement components required for plants and equipment in the warehouses.

(c) Power supply and distribution facilities

Power is to be obtained from the CES (Central Energy System) through existing power lines and/or extension. Sometimes power is also provided through a private generating station. Transformers provide power at the required working voltage. Power is generally transmitted via overhead line to transformers, then by cable to the equipment.

(d) Water supply facilities

Potable water and industrial water are required for mining operations and townships. Hot water is also needed for both mining operations and townships as well. Underground water from the dewatering wells and drainage water may not be suitable for drinking, but for industrial purposes. All sources should be considered in order to select the optimum; rivers, lakes, groundwater, etc. It is necessary to investigate to prove the sustainability of a water source. Water is taken from rivers, lakes or groundwater, then sent to the pump station through pipelines, sometimes directly, sometimes via water treatment facilities, at the mining complex, and then delivered to places required. A number of processes require steam and hot water for heating and industrial purposes. Therefore boilers are to be constructed to meet the demand. Hot water is delivered from the coal-fired boilers to places required through insulated pipelines.

(e) Dewatering and drainage facilities

If the groundwater level is high and affects on mining conditions and coal quality, it is necessary to dewater and lower the water level before mining. The groundwater is to be

dewatered for a certain period before mining starts. It will be very difficult to mine the coal seams without dewatering, if the moisture content of the seams are very high. Therefore, it is essential to dewater the groundwater without any delay. Water drainage is of prime importance for open pit mining operations. Ditches and sumps should be dug in and around the pit, and pumping facilities should be installed for the drainage.

(f) Crushing/sizing/loading facilities

In regard to the coal quality, end users of coal suffer not only from poor quality of coal but also uncrushed run-of-mine coal, mixing with lumpy waste and foreign materials. A crushing, sizing and loading plant is needed for the coal mine, and all the run-of-mine coal should be processed at the plant before shipping.

(g) Office facilities

In order to maintain mining and plant operations, an operational center will be required for management, planning and control of daily activities.

(h) Stockpile facilities and transportation facilities

Crushed coal is delivered from the crushing/sizing plant to a loading section. Most of the coal is directly transhipped to train loading silos through a conveyor system. In the case that freight cars are not available for loading, crushed coal is diverted to stockpile areas for temporary stock. Spontaneous combustion characteristics of coal must be seriously studied and proper procedures and facilities should be provided in both the raw coal stockyard and product coal stockyard. A process of natural drying of coal may be required to reduce moisture content.

(i) Communication

It is important to consider any communication both external and internal services. Telephone, facsimile and mobile radio services may be required for the mine operations.

(j) Mine infrastructure

a) Townships

Due to the remote location of the project, a new town will be developed to provide

accommodation for the labor force. It is expected that the population of the town will depend on the total labor force. The town development will commence at the same time as the mine pre-production development, so that accommodation will be available for operational personnel when mine development starts. Location, size of workforce, mine life, existing facilities, and company and government policies will influence the magnitude of the residential and community facilities required. Township size is based on the workforce requirements and allowance. The following facilities should be provide for the town:

- Housing: for employees
- Roads
- Services: potable water, power, sewerage and drainage
- Recreation facilities
- Shopping facilities
- Community facilities: town hall, fire station, police, bank and post office
- Commercial facilities
- Medical facilities
- Educational facilities.

As mentioned earlier, construction costs will be covered by the three major portions:

- National and/or local governments,
- Coal mine,
- Private or commercial entities

The coal mining company will be responsible to construct houses for employees. The following costs are estimated for the construction of town-ships and housings.

- Employees	570
- Population	1,550
- Cost estimates (US\$ 1,000)	9,000

It is estimated that total costs of twnships are US\$ 27,000 thousand. However, US\$18,000 thousand out of total costs should be prepared by governments. It is expected that the coal mining company will prepare US 9,000 thousand for developing townships.

Governments	18,000
Company	9,000

Private	-
Total	27,000

b) Transportation and power line

Consideration and evaluation of the available transportation are essential. The transportation systems available for consideration include:

- Road
- Railroad

(i) Road

Two kilometers of roads are to be constructed for the access road from the main roads.

Cost estimate: $247/\text{km} \times 2\text{km} = 495$ (US\$ 1,000)

(ii) Railroad in the property

Two kilometers of side track road is to be constructed for the material and coal haulage.

- Cost estimate for side track: $675/\text{km} \times 2\text{km} = 1,350$ (US\$ 1,000)
- Rolling stock

Assumption : All the produced coal will be hauled to Ulaanbaatar

Haul distance to Ulaanbaatar: 135km

Unit rolling stock: \$7,500/million ton. km

Rolling stock: 2,025 (US\$1,000)

- Total costs of railroad (US\$1,000)

Side track	1,350
Rolling stock	2,025
Total	3,375

(iii) Power line and communication method

Power line is to be extended from the CES for convenience.

It is important to consider any communication both the external and internal services. Telephone, facsimile and mobile radio services may be required for the mine operations.

Power line: $\$71,250 \times 2\text{km} \approx 143$ (US\$1,000)

(iv) Other 400 (US\$1,000)

c) Total (a)+b)) 13,413 (US\$1,000)

4) Infrastructure development costs

(a) General

New facilities of townships, railroads, roads, power lines, etc. should be developed for the new potential mines.

a) Road

Existing roads in the area provide access to the portion of the property. Some parts of roads will be newly developed.

b) Railroad

The coal will be transported by trains to consuming cities. A new rail line is to be constructed from the project site to connect with the existing line.

c) Power line and communication

It is necessary to extend power line for supplying power from CES system.

d) Townships (Undertaking by governments)

(b) Cost estimates

Railroad:	Length (km)	25
	Costs (US\$1,000)	16,875
Road:	Length (km)	25
	Costs (US\$1,000)	6,188
Power line:	Length (km)	15
	Costs (US\$1,000)	1,065
Other facilities:	(US\$1,000)	2,413
Townships:	(US\$1,000)	18,000
Total (US\$1,000)		44,545

(3) Total capital cost

Capital cost for coal mine consists of the major mining equipment and the general purpose equipment and the surface facilities, which is not include any taxation.

Initial capital costs:		84,200 (US\$ 1,000)
Replacement cost :		101,800 (US\$ 1,000)
Total capital costs :		186,000 (US\$ 1,000)
Infrastructure cost:	Railroad	16,900 (US\$ 1,000)
	Road	6,200 (US\$ 1,000)
	Power line	1,100 (US\$ 1,000)
	Townships	18,000 (US\$ 1,000)
	Other	2,400 (US\$ 1,000)
	Sub-total	44,500 (US\$ 1,000)
Grand total:		230,500 (US\$ 1,000)

(4) Operating costs


Operating costs consist of two components; material and labor and depreciation. The cost index of \$1.43/BCM of the shovel and truck system is used for the comparison of new mining system in Baganuur coal mine renovation study in Part 1. This index is used to plan the new potential mines because the shovel and truck system is adopted, too.

(5) Economic evaluation

Coal price in 10% EIRR was calculated under the same assumption of Tsaidamunuur coal mine. Table 7.4 shows the net cash flow of EIRR every year and coal price in 10% EIRR is US\$13.9/t (5,547Tg/t).

Table 7.3 Proposed Mining Plan of Tugrugnuur Mine (1/2)

1) Details of plan

Coal seam condition			Reserves ($\times 10^4 t$)			Development plan								
Thickness (m)	Dip ($^{\circ}$)	Strike length (km)	Depth (m)	Stripping ratio	Reserves ($\times 10^4 t$)	Annual Production ($\times 10^4 t$)	Cumulative coal Production ($\times 10^4 t$)	Strike length (km)	Depth (m)	Total Stripping ratio	Average overburden removal ($\times 10^3 m^3$)	Volume of coal production ($\times 10^3 m^3$)	Fleet number	
													Coal mining	Stripping
	7	15	88	4.2	288	2,000	40,000	4	47	4.2	8,400	1,600	5.7m ³ /46t	12m ³ /80t
													1	4 (3.37)

2) Cost estimation

Mining equipment				General purpose equipment		Surface facilities			Total
Equipment	Specification	Quantity	Amount of price						
Power shovel	12m ³ (waste)	4	16,037	(Bulldozer,		Workshop		1,599	
Hydraulic shovel	5.7m ³ (coal)	1	2,016	Grader,		Warehouse		683	
Front end loader	5 m ³	2	867	Front end loader,		Coal stockyard		799	
Dump truck	80t (waste)	27	21,330	Service truck,		Sizing & loading		4,704	
Dump truck	40t (coal)	8	3,520	Water truck,		Power distribution		1,038	
Bulldozer	400 Hp	5	2,620	Fuel truck,		Communication		85	
Grader	254 Hp	5	1,830	Anfo truck,		Drainage & water supply		4,000	
Drill	160 mm	5	2,295	etc.)		Mine office		590	
Sub-Total			50,514	5,623		Explosive magazine		236	
						Boiler		354	
						Road maintenance		354	
						Coal quality system		240	
						Mine infrastructure		13,413	
Equipment total			56,137			Subtotal		28,045	
									84,182

($\times 10^3$ US\$)

Capital costs (initial)

Table 7.3 Proposed Mining Plan of Tugrugnuur Mine (2/2)

Capital Costs for coal mine
(Initial & replacement)

Year	Mining Equipment	General Purpose Equipment	Surface facilities	Total
-3	—	153	13,413	13,566
-2	27,768	3,424	9,833	41,025
-1	22,746	2,046	4,799	29,591
Initial total	50,514	5,623	28,045	84,182
1	—	—	—	—
2	—	—	—	—
3	—	—	—	—
4	—	—	4,000	4,000
5	—	—	301	301
6	—	153	—	153
7	19,750	3,424	2,181	25,355
8	14,728	2,046	799	17,573
9	—	—	6,976	6,976
10	—	—	85	85
11	—	—	301	301
12	—	—	—	—
13	—	—	—	—
14	—	153	4,000	4,153
15	19,750	3,424	2,181	25,355
16	14,728	2,046	799	17,573
17	—	—	—	—
18	—	—	—	—
19	—	—	—	—
20	—	—	—	—
Replacement total	68,956	11,246	21,623	101,825
Total capital	119,470	16,869	49,668	186,007

US\$ 000' s

Capital costs for infrastructure

Railroad	Length (km)	25
	Costs (\$000' s)	16,875
Road	Length (km)	25
	Costs (\$000' s)	6,188
Powerline (km)	15	
	Costs (\$000' s)	1,069
Township	Population	1,550 (570 employees included)
	Costs (\$000' s)	18,000
Other	Costs (\$000' s)	2,413
Total		44,545

Operating Costs

Year	Waste million BCM	Coal million ton	Costs million \$	\$/T
-3	—	—	—	—
-2	7.77	1.00	12.26	12.26
-1	7.37	1.50	12.26	8.17
1	8.40	2.00	14.30	7.15
2	8.40	2.00	14.30	7.15
3	8.40	2.00	14.30	7.15
4	8.40	2.00	14.30	7.15
5	8.40	2.00	14.30	7.15
6	8.40	2.00	14.30	7.15
7	8.40	2.00	14.30	7.15
8	8.40	2.00	14.30	7.15
9	8.40	2.00	14.30	7.15
10	8.40	2.00	14.30	7.15
11	8.40	2.00	14.30	7.15
12	8.40	2.00	14.30	7.15
13	8.40	2.00	14.30	7.15
14	8.40	2.00	14.30	7.15
15	8.40	2.00	14.30	7.15
16	8.40	2.00	14.30	7.15
17	8.40	2.00	14.30	7.15
18	8.40	2.00	14.30	7.15
19	1.20	1.00	2.86	2.86
20	0.46	0.50	1.23	2.46
Total	168.00	40.00	286.01	7.15

※ million bcm

Details of Operating cost

Index	Unit
Operating cost	\$/BCM 1.43
Strip ratio	4.2 : 1
Production	※
Waste	8.4
Coal	1.6
Total	10.0

Table 7.4 Economic Evaluation of Tugrugnuur Mine

	1	2	3	4	5	6	7	8	9	10	11	12
Coal price of 10% EIRR												
			5.547t/gt									
Year	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9
Price (\$US/t)	13.867											
Production (mil.t)	0.0	1.0	1.5	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
Revenue(mil.\$US)	0.0	13.9	20.8	27.7	27.7	27.7	27.7	27.7	27.7	27.7	27.7	27.7
Investment cost(mil.\$)	13.6	41.0	29.6	0.0	0.0	0.0	4.0	0.3	0.2	25.4	17.6	7.0
A Initial	13.6	41.0	29.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Mining Equipment	0.0	27.8	22.7	0.0								
General Purpose Equipment	0.2	3.4	2.0									
Surface Facilities	13.4	9.8	4.8									
B Replacement	0.0	0.0	0.0	0.0	0.0	0.0	4.0	0.3	0.2	25.4	17.6	7.0
Operating Cost (mil.\$)	0.0	7.1	10.7	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3
NCF before Tax (mil.\$)	-13.6	-34.3	-19.5	13.5	13.5	13.5	9.5	13.2	13.3	-11.9	-4.1	6.5
(=Revenue-Investment-Operating cost)												
Year	13	14	15	16	17	18	19	20	21	22	23	total
Price (\$US/t)	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9
Production (mil.t)	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.0	0.5	40.0
Revenue(mil.\$US)	27.7	27.7	27.7	27.7	27.7	27.7	27.7	27.7	27.7	13.9	6.9	554.7
Investment cost(mil.\$)	0.1	0.3	0.0	0.0	4.2	25.4	17.6	0.0	0.0	0.0	0.0	186.0
A Initial	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	84.2
Mining Equipment												50.5
General Purpose Equipment												5.6
Surface Facilities												28.0
B Replacement	0.1	0.3	0.0	0.0	4.2	25.4	17.6	0.0	0.0	0.0	0.0	101.8
Operating Cost (mil.\$)	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	7.1	3.6	285.6
NCF before Tax (mil.\$)	13.4	13.2	13.5	13.5	9.3	-11.9	-4.1	13.5	13.5	6.7	3.4	83.1
(=Revenue-Investment-Operating cost)												
Discount Rate	10%											
Total NPV before Tax												0 (mil.\$)
EIRR (IRR on NCF B.Tax)	10%											10%

7.1.3 Khoot mine

(1) Details of plan

1) General

Khoot coal mine will be developed as the substitution for Sharyngol mine. Present mining areas of Sharyngol mine are deeper than 200 meters and the strip ratios have been increasing year by year. As a minable reserve is limited to 30 million tons, it is supposed to maintain a production level at 1 million tons per annum from now on. And further, mining conditions become worse and operating costs have been increasing. However, very luckily, coal quality of Sharyngol mine is superior to that of Baganuur or Shivee Ovoo mine. The quality of Sharyngol coal is as below:

- Moisture (as received):	15.0%
- Ash (dry):	17.5%
- Sulfur (dry):	0.6%
- Volatile Matter (dry ash free):	41.0%
- Calorific value (as received) :	3,900 ~ 4,200 kcal/kg

On the other hand, the quality of Khoot mine is as below:

- Moisture (as received):	13.8%
- Ash (dry):	14.5%
- Sulfur (dry):	0.7%
- Volatile Matter (dry ash free):	43.0%
- Calorific value (as received) :	4,800 kcal/kg

The quality of Khoot mine is well superior to that of Sharyngol mine, and Khoot coal can be utilized as a substitute for Sharyngol coal. The industries which need the medium calory coal such as Sharyngol coal are located in Ulaanbaatar, Darkhan, Choir, etc. along the railway both now and in future. No coal field without Khoot can be found near the railway, which can produce and supply the medium calory coal like Sharyngol easily and stably. The Khoot deposit is the only potential area to be a substitute for the Sharyngol mine. Therefore, the Khoot deposit should be developed as one of the new development areas.

2) Infrastructure and surrounding mines

A power line is already available between Choir and Govi-Ugtall and this line will be

extended toward Mandalgovi and be completed in the summer of 1995. Khoot mine is located 40km south of Govi-Ugtaal. It is planned that a new power line is extended from Mandalgovi to Tavantolgoi in the future. It is also planned that a new spur track of around 90km is constructed from Choir to Khoot. And further, the railway will be constructed from Khoot to Tavantolgoi in the future. Uvdokhuduk deposit is located about 40km south-east of Khoot. This deposit was explored in detail and feasibility reports are now available for the development. However, coal seams contain high sulfur, ranging up to 5 to 7%, then it is difficult to utilize the coal for burning. It is very attractive to utilize this source for coal liquefaction in the long term plan. Surrounding areas of the Khoot deposit are rich in mineral resources; fluorite, lead, limestone, uranium and so on. Some are in exploration stages, and others are in development stages. It has been proved that the underground water source is available around Khoot area. A good potable water source is located 15km and an industrial water source 50km from the Khoot deposit. The water yield must provide adequate insurance in meeting demand.

The features of local conditions are as follows:

- A small coal mine has already been developed since 1993 and produces some thousand tons per annum for local use.
- This area is rich in coal, oil shale, fluorite, limestone, uranium, lead and so on. Therefore, it is very interesting to develop comprehensively all the available mineral resources.
- The Khoot coal is an only source to be utilized as a substitute for Sharyngol coal.
- However, regional infrastructure should be developed in terms of railways, roads, power lines, communications, water supply, etc.
- Once this area was developed and infrastructure facilities were established, it would be easy to justify a development of the Tavantolgoi project for the next development stage.

3) Design basis

Coal mine development plan is made on the following conditions:

- The project term is 23 years.
- Oxidized coal from the surface till 10m depth is regarded as overburden, which must be removed.
- Stripping ratio and mining depth are up to 4.2 and less than 200m, respectively.

- Stripping ratio is defined as overall average stripping ratio and constant during project term.
- Bench cut method by using shovel and truck system is adopted as the mining method.
- Average transportation distance is three km and constant during project term.

(2) Machinery requirement, manpower, cost estimation, etc.

The proposed mining plan is shown on Table 7.5 including major mining machines and surface facilities.

1) Major mining machines

The fleet for overburden removal consists of 12 m³ electric shovel and 80 ton dump trucks. The electric shovel is selected because it has stronger digging force and durability and can be driven by electricity instead of imported fuel oil. Because the electric mining machine is suitable for the large-scaled work with less frequency of working place change, it is necessary to operate it in advancing stripping activity. This fleet is recommended as a superior in Part 1 study. The fleet for coal mining consists of 5.7 m³ backhoe type hydraulic shovel and 46 ton dump trucks. Backhoe type hydraulic shovel has advantages as follows:

- precise selective mining effective for coal quality control.
- adaptability for overburden removal with its greater digging force.
- capability of digging below the machine level.
- capability of performing incidental works such as making drainage ditch and treating surface of working face, etc.

2) Manpower requirement

Manpower requirement in the Khoot coal mine is estimated based on the Shivee Ovoo, and 360 persons will be required. Manpower requirement in detail should be established by categories in the next step.

3) Surface facilities

(a) General

Usually the following facilities are required; workshops and warehouses, power supply and distribution, water supply, dewatering and drainage, crushing/sizing/loading, office, stockpile, transportation, communication, etc.

(b) Workshop

Workshops must provide adequate facilities for the inspection, repair and maintenance of plants and mining equipment. Repair shops require the following spaces or bays for:

- Equipment repair
- Heavy vehicle repair
- Light vehicle repair
- Electric repair
- Undercarriage repair

Workshop areas are composed of repair shop, service facility, warehouses, material handling, vehicle washing, vehicle parking, etc. Mine fleet services are performed in general near the working areas and includes refueling, routine servicing, tire maintenance, etc. Service facilities provide,

- Light vehicle services
- Heavy vehicle services
- Washing services
- Refueling and greasing services

Mines are usually located in remote areas therefore they should maintain stocks of spare parts, consumable items and replacement components required for plants and equipment in the warehouses.

(c) Power supply and distribution facilities

Power is to be obtained from the CES (Central Energy System) through existing power lines and/or extension. Sometimes power is also provided through a private generating station. Transformers provide power at the required working voltage. Power is generally transmitted via overhead line to transformers, then by cable to the equipment.

(d) Water supply facilities

Potable water and industrial water are required for mining operations and townships. Hot water is also needed for both mining operations and townships as well. Underground water from the dewatering wells and drainage water may not be suitable for drinking, but for industrial purposes. All sources should be considered in order to select the optimum; rivers, lakes, groundwater, etc. It is necessary to investigate to prove the sustainability of

a water source. Water is taken from rivers, lakes or groundwater, then sent to the pump station through pipelines, sometimes directly, sometimes via water treatment facilities, at the mining complex, and then delivered to places required. A number of processes require steam and hot water for heating and industrial purposes. Therefore boilers are to be constructed to meet the demand. Hot water is delivered from the coal-fired boilers to places required through insulated pipelines.

(e) Dewatering and drainage facilities

If the groundwater level is high and affects on mining conditions and coal quality, it is necessary to dewater and lower the water level before mining. The groundwater is to be dewatered for a certain period before mining starts. It will be very difficult to mine the coal seams without dewatering, if the moisture content of the seams are very high. Therefore, it is essential to dewater the groundwater without any delay. Water drainage is of prime importance for open pit mining operations. Ditches and sumps should be dug in and around the pit, and pumping facilities should be installed for the drainage.

(f) Crushing/sizing/loading facilities

In regard to the coal quality, end users of coal suffer not only from poor quality of coal but also uncrushed run-of-mine coal, mixing with lumpy waste and foreign materials. A crushing, sizing and loading plant is needed for the coal mine, and all the run-of-mine coal should be processed at the plant before shipping.

(g) Office facilities

In order to maintain mining and plant operations, an operational center will be required for management, planning and control of daily activities.

(h) Stockpile facilities and transportation facilities

Crushed coal is delivered from the crushing/sizing plant to a loading section. Most of the coal is directly transhipped to train loading silos through a conveyor system. In the case that freight cars are not available for loading, crushed coal is diverted to stockpile areas for temporary stock. Spontaneous combustion characteristics of coal must be seriously studied and proper procedures and facilities should be provided in both the raw coal

stockyard and product coal stockyard. A process of natural drying of coal may be required to reduce moisture content.

(i) Communication

It is important to consider any communication both external and internal services. Telephone, facsimile and mobile radio services may be required for the mine operations.

(j) Mine infrastructure

a) Townships

Due to the remote location of the project, a new town will be developed to provide accommodation for the labor force. It is expected that the population of the town will depend on the total labor force. The town development will commence at the same time as the mine pre-production development, so that accommodation will be available for operational personnel when mine development starts. Location, size of workforce, mine life, existing facilities, and company and government policies will influence the magnitude of the residential and community facilities required. Township size is based on the workforce requirements and allowance. The following facilities should be provided for the town:

- Housing: for employees
- Roads
- Services: potable water, power, sewerage and drainage
- Recreation facilities
- Shopping facilities
- Community facilities: town hall, fire station, police, bank and post office
- Commercial facilities
- Medical facilities
- Educational facilities.

As mentioned earlier, construction costs will be covered by the three major portions:

- National and/or local governments,
- Coal mine,
- Private or commercial entities

The coal mining company will be responsible to construct houses for employees. The

following costs are estimated for the construction of town-ships and housings.

- Employees	360
- Population	980
- Cost estimates (US\$ 1,000)	8,000

It is estimated that total costs of townships are US\$ 24,000 thousand. However, US\$16,000 thousand out of total costs should be prepared by governments. It is expected that the coal mining company will prepare US 8,000 thousand for developing townships.

Governments	16,000
Company	8,000
Private	-
Total	24,000

b) Transportation and power line

Consideration and evaluation of the available transportation are essential. The transportation systems available for consideration include:

- Road
- Railroad

(i) Road

Two kilometers of roads are to be constructed for the access road from the main roads.

Cost estimate: $247/\text{km} \times 2\text{km} = 495$ (US\$ 1,000)

(ii) Railroad in the property

Two kilometers of side track road is to be constructed for the material and coal haulage.

- Cost estimate for side track: $675/\text{km} \times 2\text{km} = \$1,350$ (US\$ 1,000)

- Rolling stock

Assumption: All the produced coal will be hauled to Ulaanbaatar

Haul distance to Ulaanbaatar: 270km

Unit rolling stock: \$7,500/million ton. km

Rolling stock: 2,025 (US\$1,000)

- Total costs of railroad (US\$1,000)	
Side track	1,350
Rolling stock	2,025
Total	3,375

(iii) Power line and communication method

Power line is to be extended from the CES for convenience. It is important to consider any communication both the external and internal services. Telephone, facsimile and mobile radio services may be required for the mine operations.

Power line: $\$71,250 \times 2\text{km} \approx 143$ (US\$1,000)

(iv) Other 401 (US\$1,000)

c) Total (a)+b)) 12,414 (US\$1,000)

4) Infrastructure development costs

(a) General

New facilities of townships, railroads, roads, power lines, etc. should be developed for the new potential mines.

a) Road

Existing roads in the area provide access to the portion of the property. Some parts of roads will be newly upgraded.

b) Railroad

The coal will be transported by trains to consuming cities. A new rail line is to be constructed from the project site to connect with the existing line.

c) Power line and communication

It is necessary to extend power line for supplying power from CES system.

d) Townships (Undertaking by governments)

(b) Cost estimates

Railroad:	Length (km)	90
	Costs (US\$1,000)	60,750
Road:	Length (km)	90
	Costs (US\$1,000)	4,050 (up grade)

Power line:	Length (km)	40
	Costs (US\$1,000)	2,850
Other facilities:		6,765
Town ships		16,000
Total (US\$1,000)		90,415

(3) Total capital cost

Capital cost for coal mine consists of the major mining equipment and the general purpose equipment and the surface facilities, which is not include any taxation.

Initial capital costs:		51,600 (US\$ 1,000)
Replacement cost:		57,800 (US\$ 1,000)
Total capital costs:		109,400 (US\$ 1,000)
Infrastructure cost:	Railroad	60,800 (US\$ 1,000)
	Road	4,100 (US\$ 1,000)
	Power line	2,900 (US\$ 1,000)
	Townships	16,000 (US\$ 1,000)
	Other	6,800 (US\$ 1,000)
	Sub-total	90,400 (US\$ 1,000)
Grand total:		199,800 (US\$ 1,000)

(4) Operating costs

Operating costs consist of two components; material and labor. The cost index of \$1.43/BCM of the shovel and truck system is used for the comparison of new mining system in Baganuur coal mine renovation study in Part 1. This index is used to plan the new potential mines because the shovel and truck system is adopted, too.

(5) Economic evaluation

Coal price in 10% EIRR was calculated under the same assumption of Tsaidamunuur coal mine. Table 7.6 shows the net cash flow of EIRR every year and coal price in 10% EIRR is US\$14.7/t (5,892Tg/t).

Table 7.5 Proposed Mining Plan of Khoot Mine (1/2)

1) Details of plan

Coal seam condition				Reserves ($\times 10^9 t$)				Development plan						
Thickness (m)	Dip (°)	Strike length (km)	Depth (m)	Stripping ratio	Reserves ($\times 10^9 t$)	Annual Production ($\times 10^3 t$)	Cumulative coal Production ($\times 10^3$)	Strike length (km)	Depth (m)	Total Stripping ratio	Average overburden removal ($\times 10^3 m^3$)	Volume of coal production ($\times 10^3 m^3$)	Fleet number	
													Coal mining	Stripping
7	5	3	65	4.2	20								5.7m ³ +46t	12m ³ +80t
6	5	3	55	4.2	15	1,000	20,000	3	34	3.8	3,800	800	1	2
7	2	3	58	4.2	50								(0.50)	(1.52)
					85									

2) Cost estimation

Capital costs (Initial) ($\times 10^3$ US\$)

Equipment	Mining equipment			General purpose equipment	Surface facilities			Total
	Specification	Quantity	Amount of price					
Power shovel	12m ³ (waste)	2	8,018	(Bulldozer,	Workshop	1,003		
Hydraulic shovel	5.7m ³ (coal)	1	2,016	Grader,	Warehouse	413		
Front end loader	5 m ³	2	867	Front end loader,	Coal stockyard	777		
Dump truck	80t (waste)	13	10,270	Service truck,	Sizing & loading	2,753		
Dump truck	40t (coal)	4	1,760	Water truck,	Power distribution	845		
Bulldozer	400 Hp	3	1,572	Fuel truck,	Communication	63		
Grader	254 Hp	2	732	Anfo truck,	Drainage & water supply	2,960		
Drill	160 mm	3	1,377	etc.)	Mine office	370		
Sub-Total			26,612		Explosive magazine	148		51,629
					Boiler	222		
					Road maintenance	222		
					Coal quality system	240		
					Mine infrastructure	12,414		
Equipment total			29,199		Subtotal	22,430		

Table 7.5 Proposed Mining Plan of Khoot Mine (2/2)

Capital Costs for coal-mine
(Initial & replacement)

Year	Mining Equipment	General Purpose Equipment	Surface facilities	Total
-3	—	168	12,414	12,582
-2	15,634	1,674	9,180	26,488
-1	10,978	745	836	12,559
Initial total	26,612	2,587	22,430	51,629
1	—	—	—	—
2	—	—	—	—
3	—	—	—	—
4	—	—	2,960	2,960
5	—	—	189	189
6	—	168	—	168
7	11,625	1,674	1,467	14,766
8	6,969	745	777	8,491
9	—	—	4,616	4,616
10	—	—	80	80
11	—	—	189	189
12	—	—	—	—
13	—	—	—	—
14	—	168	2,960	3,128
15	11,625	1,674	1,467	14,766
16	6,969	745	777	8,491
17	—	—	—	—
18	—	—	—	—
19	—	—	—	—
20	—	—	—	—
Replacement total	37,188	5,174	15,482	57,844
Total capital	63,800	7,761	37,912	109,473

US\$ '000's

Capital costs for infrastructure

Railroad	Length (km)	90
	Costs (\$'000's)	60,750
Road	Length (km)	90
	Costs (\$'000's)	4,050
Powerline (km)	40	
	Costs (\$'000's)	2,850
Township	Population	980 (360 employees included)
	Costs (\$'000's)	16,000
Other	Costs (\$'000's)	6,765
Total		90,415

Operating Costs

Year	Waste million BCM	Coal million ton	Costs million \$	\$/T
-3	—	—	—	—
-2	3.57	0.50	5.68	11.35
-1	3.37	0.75	5.68	7.57
1	3.80	1.00	6.58	6.58
2	3.80	1.00	6.58	6.58
3	3.80	1.00	6.58	6.58
4	3.80	1.00	6.58	6.58
5	3.80	1.00	6.58	6.58
6	3.80	1.00	6.58	6.58
7	3.80	1.00	6.58	6.58
8	3.80	1.00	6.58	6.58
9	3.80	1.00	6.58	6.58
10	3.80	1.00	6.58	6.58
11	3.80	1.00	6.58	6.58
12	3.80	1.00	6.58	6.58
13	3.80	1.00	6.58	6.58
14	3.80	1.00	6.58	6.58
15	3.80	1.00	6.58	6.58
16	3.80	1.00	6.58	6.58
17	3.80	1.00	6.58	6.58
18	3.80	1.00	6.58	6.58
19	0.66	0.50	1.52	3.03
20	0	0.25	0.29	1.14
Total	76.00	20.00	131.61	6.58

※ million bcm

Details of Operating cost

Index	Unit
Operating cost	\$/BCM 1.43
Strip ratio	3.8 : 1
Production	※
Waste	3.8
Coal	0.8
Total	4.6

Table 7.6 Economic Evaluation of Khoot Mine

Coal price of 10% EIRR 5,892T/g/t

Year	1	2	3	4	5	6	7	8	9	10	11	12
Price (\$US/t)	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7
Production (mil.t)	0.0	0.5	0.8	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Revenue(mil.\$US)	0.0	7.4	11.8	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7
Investment cost (mil.\$)	12.6	26.5	12.6	0.0	0.0	0.0	3.0	0.2	0.2	14.8	8.5	4.6
A. Initial	12.6	26.5	12.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Mining Equipment	0.0	15.6	11.0	0.0								
General Purpose Equipment	0.2	1.7	0.7									
Surface Facilities	12.4	9.2	0.8									
B Replacement	0.0	0.0	0.0	0.0	0.0	0.0	3.0	0.2	0.2	14.8	8.5	4.6
Operating Cost (mil.\$)	0.0	3.3	5.3	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6
NCF before Tax (mil.\$)	-12.6	-22.4	-6.0	8.2	8.2	8.2	5.2	8.0	8.0	-6.6	-0.3	3.5
(=Revenue-Investment-Operating cost)												

Year	13	14	15	16	17	18	19	20	21	22	23	total
Price (\$US/t)	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	
Production (mil.t)	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.5	0.3	20.1
Revenue(mil.\$US)	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	7.4	4.4	296.1
Investment cost (mil.\$)	0.1	0.2	0.0	0.0	3.1	14.8	8.5	0.0	0.0	0.0	0.0	109.5
A. Initial	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	51.6
Mining Equipment												26.6
General Purpose Equipment												2.6
Surface Facilities												22.4
B Replacement	0.1	0.2	0.0	0.0	3.1	14.8	8.5	0.0	0.0	0.0	0.0	57.9
Operating Cost (mil.\$)	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	3.3	2.0	132.0
NCF before Tax (mil.\$)	8.0	8.0	8.2	8.2	5.0	-6.6	-0.3	8.2	8.2	4.1	2.4	54.5
(=Revenue-Investment-Operating cost)												

Discount Rate 10%
 Total NPV before Tax 0 (mil.\$)
 EIRR (IRR on NCF B.Tax) 10%

7.1.4 Tavantolgoi mine

(1) Basis of plan

1) Features of the coal deposit

Tavantolgoi deposit is located 540km south of Ulaanbaatar and 96km east of Dalanzadgad. The climate of this area is semi-desert and the population is sparse. Reserves of this deposit is tremendous, geological and mining conditions are excellent. Coal quality is classified into bituminous coal and the several coal seams are classified into coking coal, which can be produced with washing process for industrial use. However, large amount of investment should be required for the construction of infrastructure. This area is currently short of infrastructure, such as railway, road, power line, water supply, etc. A new power line is planned to be extended from Mandalgovi to Tavantolgoi around 2000. The railway is planned to be constructed from Choir to Khoot, and in the next stage from Khoot to Tavantolgoi in future.

2) Design basis

Coal mine development plan is made on the following conditions:

- The plan should be conducted on the base of the future export market.
- The project term is 23 years
- The annual production is 11.0 million ton of run of mine coal.
- The breakdown of the annual production is as follows:

(a) Thermal coal for the mine mouth power plant to export electric power by HVDC transmission line; 9 million ton

(b) Coking coal for export; 1.21 million ton

(c) Thermal coal for local use; 0.79 million ton

(d) Total: 11.0 million ton

- The plant yield of coking coal is 55.0%
- Stripping ratio is 4.4 and constant during project term.
- Bench cut method of using shovel and truck system is adopted as the mining method.
- Average transportation distance is three km and constant during project term.

(2) Machinery requirement

1) Major mining machines

Table 7.7 shows the machinery requirement for above-mentioned design basis.

The fleet for overburden removal consists of 12 m³ electric shovel and 80 ton dump trucks. The electric shovel is selected because it has stronger digging force and durability and can be driven by electricity instead of imported fuel oil. Because the electric mining machine is suitable for the large-scaled work with less frequency of working place change, it is necessary to operate it in advancing stripping activity. This fleet is recommended as a superior in Part 1 of the study. The fleet for coal mining consists of 5.7 m³ backhoe type hydraulic shovel and 46 ton dump trucks. Backhoe type hydraulic shovel has advantages as follows:

- precise selective mining effective for coal quality control.
- adaptability for overburden removal with its greater digging force.
- capability of digging below the machine level.
- capability of performing incidental works such as making drainage ditch and treating surface of working face, etc.

2) Manpower requirement

Manpower requirement in the Tavantolgoi coal mine is estimated based on the Shivee Ovoo coal mine, and 3,200 persons will be required. Manpower requirement in detail should be established by categories in the next stage.

(3) Surface facilities

The typical coal mine producing coking coal needs the following surface facilities; Washing plant, workshops and warehouses, power supply and distribution, water supply, dewatering and drainage, crushing/sizing/loading, office, stockpile, transportation, communication, etc. Table 7.7 includes the list of surface facilities.

1) Washing plant

To produce coking coal washing process is needed. The heavy medium separator is adopted to washing plant. The possibility of industrial water supply from ground water or surface water resources must be surveyed.

2) Workshop and warehouses

Workshops must provide adequate facilities for the inspection, repair and maintenance of plants and mining equipment.

Workshop areas are composed of repair shop, service facility, warehouses, material handling, vehicle washing, vehicle parking, etc. Mine fleet services are performed in general near the working areas and includes refueling, routine servicing, tire maintenance, etc.

Repair shops require the following functions for:

- Equipment repair
- Heavy vehicle repair
- Light vehicle repair
- Electric repair
- Undercarriage repair

Mines are usually located in remote areas therefore they should maintain stocks of spare parts, consumable items and replacement components required for plants and equipment in the warehouses.

3) Power supply and distribution facilities

Power is to be obtained from the mine mouth power plant constructed near the Tarantolgoi coal mine, which power is also provided through a new transmission line from CES at the beginning of the project. Transformers provide power at the required working voltage. Power is generally transmitted via overhead line to transformers, then by cable to the equipment.

4) Water supply facilities

Potable water and industrial water are required for mining operations, especially in washing process, and townships. Underground water from the dewatering wells and drainage water may not be suitable for drinking, but for industrial purposes. All sources should be considered in order to select the optimum water supply system; rivers, lakes, groundwater, etc. It is necessary to investigate to prove the sustainability of a water source. Water is taken from rivers, lakes or groundwater, then sent to the pump station through pipelines, sometimes directly, sometimes via water treatment facilities, at the mining complex, and then delivered to places required.

5) Dewatering and drainage facilities

If the groundwater level is high in Tavantolgoi area and affects on mining works and coal quality, it is necessary to dewater and lower the water level before mining. Dewatering of the groundwater is to be started for a certain period before mining starts and is necessary to be continued during the project period without any trouble. Water drainage is of prime importance for open pit mining operations. Ditches and sumps should be dug in and around the pit, and pumping facilities should be installed for the drainage.

6) Crushing/sizing/loading Facilities

In regard to the coal quality, end users of thermal coal suffer not only from poor quality of coal but also uncrushed run-of-mine coal, mixing with lumpy waste and foreign materials. A crushing, sizing and loading plant is needed for the coal mine, and all the run-of-mine coal should be processed at the plant before shipping.

7) Office facilities

In order to maintain mining and plant operations, an operational center will be required for management, planning and control of daily activities.

8) Stockpile facilities and transportation facilities

Crushed thermal coal is delivered from the crushing/sizing plant to the mine mouth power plant silos through a conveyor system directly. Thermal coal for local use is conveyed to a loading section. Crushed coal for local use is diverted to stockpile areas for temporary stock. Spontaneous combustion characteristics of coal must be seriously studied and proper procedures and facilities should be provided in both the raw coal stockyard and product coal stockyard. A process of natural drying of coal may be required to reduce moisture content. Coking coal produced with washing process is transported by rail for export.

9) Communication

It is important to consider any communication both external and internal services. Telephone, facsimile and mobile radio services may be required for the mine operations.

10) Mine infrastructure

(a) Townships

Due to the remote location of the project, a new town will be developed to provide accommodation for the labor force. The town development will be commenced at the same time as the mine pre-production development, so that accommodation will be available for operational personnel when mine development starts. The following facilities should be provided for the town:

- Housing: for employees
- Utilities supply facilities: potable water, power, sewerage and drainage
- Recreation facilities
- Shopping facilities
- Community facilities: town hall, fire station, police, bank and post office
- Medical facilities
- Educational facilities

As mentioned earlier, construction costs will be covered by the two major portions:

- National and/or local governments
- Coal mine company

The coal mining company will be responsible to construct houses for employees. The followings are estimated for the construction of town-ships and housings.

- Employees 3,200
- Population 8,700

(b) Transportation and power line

a) Road

Two kilometers of roads are to be constructed for the access road from the main roads.

b) Railroad in the property

Two kilometers of side track road is to be constructed for the material and coal haulage.

c) Power line and communication method

Power line is planned to be extended from the CES. It is important to consider any

communication both the external and internal services. Telephone, facsimile and mobile radio services may be required for the mine operations.

(4) Capital cost for coal mine

1) Mining equipment and surface facilities

Capital cost consists of the mining equipment and the general purpose equipment and the surface facilities, which is not include any taxation..

Initial capital costs:		365,900 (US\$ 1,000)
Replacement cost:		451,500 (US\$ 1,000)
Total capital costs:		817,400 (US\$ 1,000)
Infrastructure cost:	Railroad	297,000 (US\$ 1,000)
	Road	13,500 (US\$ 1,000)
	Power line	21,400 (US\$ 1,000)
	Townships	46,000 (US\$ 1,000)
	Other	33,200 (US\$ 1,000)
	Sub-total	411,100 (US\$ 1,000)
Grand total:		1,228,500 (US\$ 1,000)

2) Infrastructure development costs

(a) General

New facilities of townships, railroads, roads, power lines, etc. should be developed.

a) Road

Existing roads in the area provide access to the portion of the property. Some parts of roads will be newly upgraded.

b) Railroad

The coal will be transported by trains to consuming cities and for export. A new rail line is to be constructed from the project site to connect with the existing line.

c) Power line

It is planned to extend power line for supplying power from CES system.

d) Town ships (Above mentioned)

(b) Cost estimates

Railroad:	Length (km)	440
	Costs (US\$1,000)	297,000
Road:	Length (km)	300
	Costs (US\$1,000)	13,500 (up grade)
Power line:	Length (km)	300
	Costs (US\$1,000)	21,375
Other facilities: (US\$1,000)		33,188
Town ships: (US\$1,000)		46,000
Total (US\$1,000)		411,063

Table 7.7 Proposed Mining Plan of Tavantolgoi Mine (2/2)

Capital costs for infrastructure

US\$ 000's

Year	Mining Equipment	General Purpose Equipment	Surface facilities	Total
-3	—	433	34,970	35,403
-2	145,018	9,653	25,904	180,575
-1	118,652	5,766	25,528	149,946
Initial total	263,670	15,852	86,402	365,924
1	—	—	—	—
2	—	—	—	—
3	—	—	—	—
4	—	—	11,276	11,276
5	—	—	849	849
6	—	433	—	433
7	103,460	9,653	5,416	118,529
8	77,154	5,766	2,253	85,173
9	—	—	18,763	18,763
10	—	—	240	240
11	—	—	849	849
12	—	—	—	—
13	—	—	—	—
14	—	433	11,276	11,709
15	103,460	9,653	5,416	118,529
16	77,154	5,766	2,253	85,173
17	—	—	—	—
18	—	—	—	—
19	—	—	—	—
20	—	—	—	—
Replacement total	361,228	31,704	58,551	451,523
Total capital	624,898	47,556	144,993	817,447

Railroad	Length (km)	Costs (\$000's)
	440	297,000
Road		
	Length (km)	300
	Costs (\$000's)	13,500
Powerline (km)	300	
	Costs (\$000's)	21,375
Township		
	Population	8,700
	(3,200 employees included)	
	Costs (\$000's)	46,000
Other		
	Costs (\$000's)	33,188
Total		411,063

7.1.5 Training center

The Training center consists of three major section; training section, maintenance section and parts supply section.

Note: At the initial stage of the training center, the foreign experts dispatched by the economic aid system may assist each section.

(1) Training

1) Training courses

Course	Training period(month)	No. of trainees	No. of course/y
Operator	6+2+4	5	1
Mechanic			
Engine	6+2+4	5	1
Chassis	6+2+4	5	1

2) Organization,staff

Director:	1
Instructor	
Operator course	
Instructor :	1
Sub-instructor:	1
Mechanic course	
Instructor:	1
Sub-instructor:	1
Administration:	2 (supported by the administration of the existing coal mine)
Total:	7

3) Investment required (US\$ 1,000)

Buildings :	1,000
Facilities & equipment:	4,000
Total	5,000

4) Annual budget : 155 (US\$ 1,000)

Salary for staff , consumable and general administration are included, but education fees for instructors at the initial stage are not included.

(2) Maintenance section

1) Facilities

This function serves for overhaul, repair and preventive maintenance and has following facilities.


- chassis repair equipment
- engine repair and test equipment
- fuel system repair and test equipment
- power line component repair and test equipment
- electronic component repair equipment
- undercarriage and tire repair equipment
- welding and fabrication group equipment
- washing equipment
- painting equipment

In addition to the facilities mentioned above, such facilities are installed as offices, amenity facilities, warehouses, service facilities, material handling facilities, parking lots etc.

2) Figure 7.1(1/4-4/4) show examples of workshop.


3) Organization, staff

General manager:	1
Chief engineer:	5
Engineer:	5
Mechanic /electrician:	30
Administration:	- (covered by training part)
Total:	41




GROUND FLOOR PLAN S = 1/300

Figure 7.1 Example of Workshop (1/4)




A-SIDE ELEVATION S= 1/300




C-SIDE ELEVATION S= 1/300


Figure 7.1 Example of Workshop' (2/4)




B-SIDE ELEVATION S=1/300



D-SIDE ELEVATION S=1/300




A - A SECTION S=1/300



B - B SECTION S=1/300

Figure 7.1 Example of Workshop (3/4)



1. Office
2. Parts Stock
3. Repair Section
4. Painting Section
5. Vehicle Washing Section
6. Fuel & Grease Stock
7. Gas Storage
8. Material handling Section
9. Heavy material Stockyard
10. Demonstration Section
11. Parking lot
12. Stockyard
13. Amenity facility
14. Entrance

LEGEND (PAVEMENT)





-  HEAVY PAVEMENT
-  HEAVY TO MEDIUM PAVEMENT
-  GRAVEL
-  LIGHT PAVEMENT

Figure 7.1 Example of Workshop (4/4)

4) Investment required (US\$ 1,000)	
Buildings:	2,000
Facilities & equipment :	2,200
Total:	4,200

5) Annual operating cost: 230 (US\$ 1,000)

(3) Spare parts service section

- Procurement and store of common spare parts that existing coal mines in Mongolia use.
- Distribution of common spare parts
- Repair of recovery parts
- Management of stocks

Common spare parts is the follow:

- Engine set
- Chassis set
- Power line component
- Electronic component
- undercarriage and tire

(4) Summary of the training center

1) Investment required (US\$ 1,000)	
Buildings:	3,000
Facilities & equipment:	6,200
Total:	9,200

2) Annual operating cost: 385 (US\$ 1,000)

3) Number of staff : 48

4) Funds for investment and annual operating cost

- Initial cost is prepared by government
- Operating cost is prepared by each coal mine at the rate of coal production