


APPENDIX

for

CHAPTER 6

(6.3-4)



Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

(1/21)

No	ABB	Substation	Voltage (kV)	1996				1997					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci. (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci. (MVA)	utilization factor (%)
1	BB	Bangbon	69-12 69-24	3 x 40 x	120 0	59.67 0	77.66 0.00	64.7 0.0	3 x 40 x	120 0	55.90 0	72.55 0.00	60.5 0.0
2	BN	Banyachalong	115-24	1 x 60	60	32.04	41.70	69.5	2 x 60	120	51.63	83.87	59.9
3	BA	Bangkapi	69-12 69-24	2 x 40 1 x 60	80 60	38.41 21.93	49.99 28.51	62.5 47.6	2 x 40 1 x 60	80 60	28.47 22.00	36.95 28.55	16.2 17.6
4	BA	Bangkhren	115-24	1 x 60	60	22.38	29.13	48.6	1 x 60	60	27.15	35.23	58.7
5	BR	Bangkhumprom	69-12	3 x 40	120	64.58	81.05	70.1	3 x 40	120	61.17	79.77	66.5
6	BL	Bangko	69-12	2 x 40	80	38.55	50.18	62.7	1 x 40	40	23.76	30.83	77.1
7	BO	Bangkok noi	69-12 69-24	1 x 40 1 x 40	40 40	18.05 19.08	23.49 24.83	38.7 62.1	1 x 40 1 x 40	40 40	13.32 18.00	21.03 23.36	60.1 38.3
8	BC	Bangkrachao	69-12 69-24	2 x 10 x	20 0	6.34 0	8.25 0.00	41.3 0.0	2 x 10 x	20 0	6.88 0.00	8.93 0.0	11.6 0.0
9	BN	Bangmod	69-12 69-24	2 x (40) x	80 0	39.40 0	51.28 0.00	64.1 0.0	2 x (40) x	80 0	40.05 0.00	51.97 0.00	65.0 0.0
10	BC	Bangna	69-12 69-24	1 x 40 1 x 40	40 40	14.02 21.04	18.25 27.38	45.6 68.5	x 2 x 40	40 40	0.00 40.70	0.00 52.82	0.0 66.0
11	B/	Bangnamluet	115-24	1 x 20	20	71.44	92.98	66.4	1 x 20	20	82.87	107.51	76.8
12	B/	Bangping	115-24	2 x 80	160	69.22	90.09	75.1	2 x 80	160	64.11	83.20	69.3
13	BK	Bangplakod	69-12 69-24	3 x (40) x	120 0	57.74 0	75.15 0.00	62.6 0.0	3 x (40) x	120 0	66.45 0.00	86.23 0.00	71.9 0.0
14	BP	Bangpree	69-24	2 x 60	120	59.54	77.49	64.6	2 x 60	120	51.83	67.00	55.8
15	PG	Bangpangang	69-12 69-24	1 x 40 1 x 60	40 60	22.00 20.52	28.63 26.71	71.6 44.5	1 x 40 1 x 60	40 60	20.19 28.00	26.20 36.34	65.5 60.6
16	BD	Bangpood	69-24	2 x 60	120	52.76	68.67	57.2	x	0	0.00	0.00	0.0
17	B/	Bangpu	115-24	2 x 40	80	51.05	66.44	83.1	2 x 40	80	49.14	63.77	53.1
18	BY	Bangrakvai	115-24	2 x 50	100	39.35	51.22	42.7	2 x 60	120	42.23	51.80	70.2
19	BS	Bangsoi long	115-24	1 x 60	60	28.69	37.31	62.2	1 x 60	60	32.30	41.92	59.9
20	BY	Bangyechhan	69-12 69-24	2 x 40 x	80 0	37.59 0	48.93 0.00	61.2 0.0	1 x 40 x	40 0	22.13 22.00	28.72 28.55	71.8 71.1
21	CG	Chalongkrung	115-24	1 x 60	60	29.30	38.14	63.6	1 x 60	60	35.29	45.80	76.3
22	CA	Chanasen	69-12 69-24	2 x 40 1 x 80	80 60	38.20 15.99	49.72 20.81	62.2 34.7	2 x 40 1 x 80	80 60	29.81 31.85	38.68 41.33	48.1 68.9
23	CL	Chidlom	230-12 69-24	2 x 50 x	100 0	50.33 0	65.51 0.00	65.5 0.0	2 x 50 x	100 0	47.51 0.00	61.69 0.00	61.7 0.0
24	DM	Donmuang	69-12 69-24	x 2 x 40	0 80	0 44.80	0 58.31	0 41.7	x 2 x 40	0 80	0 15.13	0 58.57	0 41.8
25	AK	Itaekwang	69-24	2 x 60	120	46.71	60.80	50.7	2 x 60	120	18.73	63.21	52.7
26	KP	Kinpetich	69-12 69-24	3 x (40) x	120 0	50.61 0	65.87 0.00	54.9 0.0	3 x (40) x	120 0	63.33 0.00	82.14 0.00	68.7 0.0
27	KJ	Kioogjan	69-12 69-24	x 1 x 40	0 60	0 69.29	0 90.18	0 56.4	x 1 x 40	0 60	0 63.82	0 82.82	0 51.8
28	KW	Kioogjai	69-12 69-24	x 1 x 40	0 40	0 16.69	0 21.72	0 54.3	x 1 x 40	0 40	0 18.93	0 21.57	0 61.4
29	SK	Kioogsauchai	69-12	1 x 40	40	27.74	36.11	90.3	1 x 40	40	43.28	56.16	70.2

No	ABB	Substation	Voltage (KV)	1998				1999					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coincidental (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coincidental (MVA)	utilization factor (%)
1	BB	Bangbon	69-12	3 x 40	120	51.54	66.83	55.7	2 x 40	80	31.15	40.36	50.5
			69-24	x	0	0.00	0.00	0.0	1 x 40	40	23.95	31.01	77.6
2	BS	Bangchalong	115-24	2 x 60	120	57.21	87.15	72.6	2 x 60	120	61.90	80.21	66.8
3	BA	Bangkapai	69-12	2 x 40	80	29.00	37.61	47.0	2 x 40	80	31.66	41.92	56.2
			69-24	1 x 60	60	23.49	30.16	50.8	1 x 60	60	21.00	31.10	51.8
4	KA	Bangbuen	115-24	1 x 60	60	28.24	36.62	61.0	2 x 60	120	33.05	42.82	35.7
5	BR	Bangthumpru	69-12	3 x 40	120	62.70	81.30	67.8	3 x 40	120	71.23	92.29	76.9
6	BL	Banglio	69-12	1 x 40	40	17.00	22.04	55.1	1 x 40	40	17.00	22.04	55.1
			69-24	1 x 40	40	20.29	26.31	65.8	1 x 40	40	21.78	28.22	70.6
7	BD	Bangkok noi	69-12	1 x 40	40	19.94	25.86	61.6	1 x 40	40	20.17	26.11	65.3
			69-24	1 x 60	60	22.00	28.53	77.6	1 x 60	60	23.66	30.66	51.1
8	BC	Bangkrachao	69-12	2 x 10	20	7.16	9.28	46.1	2 x 10	20	7.45	9.65	48.3
			69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
9	BN	Bangnod	69-12	2 x (40)	80	38.31	49.68	62.1	2 x (40)	80	25.85	33.49	41.9
			69-24	x	0	0.00	0.00	0.0	1 x 60	60	20.00	25.91	43.2
10	BC	Bangna	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-24	2 x 40	80	43.65	56.60	70.8	2 x 40	80	45.16	58.52	73.2
11	BJ	Bangnaejued	115-24	1 x 20	20	108.07	108.07	77.2	1 x 20	20	85.16	110.31	78.8
12	BI	Bangsiang	115-24	2 x 60	120	88.26	88.51	73.6	2 x 60	120	88.32	88.53	73.8
13	BN	Bangsiakod	69-12	3 x (40)	120	82.82	81.45	67.9	3 x (40)	120	61.57	79.78	66.5
			69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
14	BP	Bangpluec	69-24	2 x 60	120	53.70	69.63	58.0	2 x 60	120	55.85	72.37	60.3
			115-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
15	PC	Bangsongphung	69-12	1 x 40	40	18.12	24.79	62.0	x	0	0.00	0.00	0.0
			69-24	1 x 60	60	30.00	38.90	64.8	x	0	0.00	0.00	0.0
			115-24	x	0	0.00	0.00	0.0	2 x 60	120	51.12	66.21	55.2
16	BP	Bangpood	69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			115-24	2 x 60	120	51.11	66.28	55.2	2 x 60	120	53.15	68.87	57.1
17	BU	Bangpu	115-24	2 x 40	80	45.04	58.40	73.0	2 x 40	80	45.03	58.35	72.9
18	BT	Bangrakvai	115-24	1 x 60	60	44.08	57.15	47.6	2 x 60	120	48.81	63.28	52.7
19	BS	Bangsuatong	115-24	1 x 60	60	32.59	43.55	72.6	1 x 60	60	31.91	45.27	75.5
20	BT	Bangrookhan	69-12	1 x 40	40	21.70	28.14	70.4	1 x 40	40	21.30	27.60	69.0
			69-24	1 x 40	40	24.00	31.12	77.8	1 x 40	40	21.18	31.33	78.3
21	CC	Chalongkrung	115-24	1 x 60	60	30.70	39.81	66.4	1 x 60	60	31.93	41.37	69.0
22	CA	Chankusua	69-12	2 x 40	80	31.67	41.07	51.3	1 x 40	40	16.59	21.50	53.7
			69-24	1 x 60	60	33.13	42.96	71.6	1 x 60	60	18.80	23.23	63.2
23	CL	Chidlom	230-12	2 x 50	100	49.45	61.12	64.1	2 x 50	100	50.96	66.03	66.0
			69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
24	DM	Donmang	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			115-24	2 x 60	120	46.94	60.87	50.7	2 x 60	120	48.81	63.21	52.7
25	BE	Buethang	69-24	2 x 60	120	51.67	67.00	55.8	2 x 60	120	53.91	69.89	58.2
26	AT	Kingsetch	69-12	3 x (40)	120	69.14	89.66	74.7	3 x (40)	120	65.16	81.13	70.1
			69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
27	KJ	Klongjan	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-24	1 x 40	40	59.24	76.82	48.9	1 x 40	40	52.99	68.66	12.9
28	KN	Klongyai	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-24	1 x 40	40	22.69	29.42	73.6	1 x 40	40	23.60	30.58	76.5
29	SC	Klongsamachai	69-12	1 x 40	40	42.42	55.01	68.8	1 x 40	40	15.55	20.15	50.1

No	ABB	Substation	Voltage (KV)	2000				2001					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MW)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MW)	utilization factor (%)
1	BB	Bangbon	69-12	2 x 40	80	35.32	45.78	57.2	0	0.00	0.00	0.00	0.0
			69-21	1 x 40	40	20.00	25.92	64.8	120	61.08	82.90	69.1	69.1
2	BN	Bangkeablong	115-21	2 x 60	120	63.76	82.61	68.9	2 x 60	63.67	81.96	70.8	70.8
3	BA	Bangkapi	69-12	2 x 40	80	36.22	46.95	58.7	2 x 40	31.49	44.62	55.8	55.8
			69-21	1 x 60	60	30.00	38.89	64.8	1 x 60	33.72	43.63	72.1	72.1
4	KA	Kangkhaen	115-24	2 x 60	120	36.98	47.93	39.9	2 x 60	36.91	47.79	39.8	39.8
5	BR	Bengkhumprom	69-12	3 x 40	120	73.40	95.14	79.3	3 x 40	36.50	73.10	60.9	60.9
6	BL	Bangklo	69-12	1 x 40	40	17.50	22.88	56.7	1 x 40	0	0.00	0.00	0.0
			69-21	1 x 30	30	22.15	29.10	72.8	2 x 40	41.15	53.21	66.6	66.6
7	BO	Bangkok noi	69-12	1 x 40	40	19.97	25.88	64.7	1 x 40	18.72	21.22	60.6	60.6
			69-21	1 x 60	60	25.00	32.40	51.0	1 x 60	27.60	35.71	59.5	59.5
8	BC	Bangkraebao	69-12	2 x 10	20	8.67	11.24	56.2	2 x 10	8.93	11.55	57.8	57.8
			69-21	1 x 0	0	0.00	0.00	0.0	0	0.00	0.00	0.0	0.0
9	BN	Bangmod	69-12	2 x (40)	80	41.22	53.43	66.8	2 x (40)	39.53	51.14	63.9	63.9
			69-21	1 x 60	60	28.00	36.29	60.5	1 x 60	31.77	41.10	68.5	68.5
10	BC	Bangren	69-12	1 x 40	40	0.00	0.00	0.0	1 x 40	0	0.00	0.0	0.0
			69-21	2 x 40	80	40.27	52.20	65.3	2 x 40	41.27	53.39	66.7	66.7
11	BJ	Bangruad	115-24	1 x 20	20	75.17	97.43	63.6	1 x 20	70.52	91.21	63.2	63.2
12	BI	Bangping	115-24	2 x 60	120	63.63	82.48	68.7	2 x 60	66.57	86.13	71.8	71.8
13	BN	Banglabod	69-12	3 x (40)	120	63.51	82.32	68.6	3 x (40)	68.51	88.61	73.9	73.9
			69-24	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
14	BP	Bangpice	69-24	2 x 60	120	62.65	81.21	67.7	2 x 60	59.25	76.66	63.9	63.9
			115-24	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
15	PC	Bangponpong	69-12	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
			69-24	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
16	BD	Bangpod	69-24	2 x 60	120	52.69	68.30	56.9	2 x 60	62.18	80.15	67.0	67.0
17	BU	Bangpa	115-24	2 x 60	120	54.75	70.97	59.1	2 x 60	48.00	62.10	51.8	51.8
18	BY	Bangruakai	115-24	2 x 40	80	44.48	57.65	72.1	2 x 40	45.82	59.28	74.1	74.1
19	BS	Bangsanlong	115-24	2 x 60	120	50.22	65.09	51.2	2 x 60	42.27	51.69	45.6	45.6
20	BY	Bangyechan	69-12	1 x 40	40	18.00	23.39	58.3	1 x 40	0	0.00	0.0	0.0
			69-24	1 x 40	40	24.00	31.11	75.8	2 x 40	40.78	52.76	66.0	66.0
21	CC	Chalongkrung	115-24	1 x 60	60	32.88	42.62	71.0	1 x 60	33.87	43.82	73.0	73.0
22	CK	Chankusom	69-12	1 x 40	40	17.09	22.15	55.4	1 x 40	17.60	22.77	56.9	56.9
			69-21	1 x 40	40	19.33	25.94	63.9	1 x 40	18.63	24.68	62.0	62.0
23	CL	Chidlom	230-12	2 x 50	100	52.48	68.03	66.0	2 x 50	51.06	68.91	69.9	69.9
			69-24	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
24	DN	Danuaeng	69-12	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
			69-24	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
25	NK	Nangkrang	69-24	2 x 60	120	55.71	72.21	60.2	2 x 60	74.53	96.12	83.6	83.6
26	KP	Khongtich	69-12	3 x (40)	120	67.12	87.00	72.5	3 x (40)	41.91	51.26	67.8	67.8
			69-21	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
27	KJ	Klongjan	69-12	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
			69-24	1 x 40	40	51.58	70.75	41.2	1 x 40	56.22	72.71	45.5	45.5
28	KV	Klongpui	69-12	1 x 0	0	0.00	0.00	0.0	1 x 0	0.00	0.00	0.0	0.0
			69-24	2 x 60	120	31.30	44.46	37.1	2 x 60	43.33	56.05	46.7	46.7
29	SC	Songsaenchai	69-12	1 x 40	40	16.02	20.77	51.9	1 x 40	16.19	21.33	53.3	53.3

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No	ABB	Substation	Voltage (KV)	1996				1997						
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci. (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci. (MVA)	utilization factor (%)	
			69-24	X	0	0	0.00	X	0	0.00	X	0	0.00	0.0
			115-24	X	0	0	0.00	X	0	0.00	X	0	0.00	0.0
30	KS	Klongsamsamit	69-12	2 X 20	40	39.95	52.00	65.0	40	44.95	80	58.33	72.9	72.9
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
31	KN	Klongsarn	69-12	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
			69-24	2 X 40	80	43.23	56.27	70.3	40	43.61	80	56.59	70.7	70.7
32	KT	Klongtoey	69-12	2 X 40	80	39.29	51.14	63.9	40	31.19	80	40.48	50.6	50.6
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
33	KG	Klongratsing	69-12	2 X (40)	80	29.39	38.25	47.8	(40)	31.85	80	41.34	51.7	51.7
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
34	KU	Kruaeri	69-12	1 X 40	(40)	39.65	51.61	64.5	40	32.07	80	41.61	52.0	52.0
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
35	LK	Lardplabao	115-24	1 X 60	60	24.88	32.38	54.0	60	28.15	60	36.53	60.9	60.9
36	LP	Lardprao	69-12	2 X 20	40	26.93	35.05	43.7	(40)	44.41	80	57.64	72.0	72.0
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
37	LN	Lampini	69-12	4 X 40	160	85.39	111.14	138.5	40	87.55	160	113.61	149.0	149.0
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
38	MY	Mahaivan	69-12	2 X 40	80	16.00	20.83	26.0	40	17.57	80	22.80	28.5	28.5
			69-24	1 X 60	60	20.14	26.21	33.7	60	23.75	60	30.82	38.4	38.4
39	MM	Mahaek	69-12	2 X 40	(40)	54.16	70.49	88.7	40	65.73	120	85.30	106.4	106.4
			115-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
40	MA	Mahaad	69-12	2 X 40	80	39.64	51.59	64.5	40	43.11	80	55.94	69.9	69.9
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
41	MS	Mahaasin	69-12	2 X 40	80	53.14	69.16	86.5	40	67.22	120	87.23	109.7	109.7
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
42	MB	Mahaaburi	115-24	2 X 60	120	52.90	68.85	87.4	60	50.76	120	65.87	83.9	83.9
43	MC	Mochit	69-12	2 X 40	(40)	44.52	57.95	73.3	40	49.99	120	64.87	81.1	81.1
			69-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
44	MC	Mahaangain	115-24	2 X 60	120	59.63	77.61	98.7	60	55.31	120	71.78	90.8	90.8
45	MI	Mahaithong I	115-24	1 X 60	60	41.64	54.20	70.3	60	50.67	120	65.75	83.9	83.9
46	MI	Maha-na	69-12	1 X (40)	40	14.79	19.25	24.3	40	16.00	40	20.76	25.9	25.9
			69-24	2 X 60	120	17.18	22.36	28.6	60	23.35	120	30.30	38.3	38.3
			115-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
47	MI	Mahaikhan	69-12	1 X 40	40	22.00	28.63	36.8	40	24.05	40	31.21	39.0	39.0
			69-24	1 X 60	60	24.24	31.55	40.6	60	25.00	60	32.11	40.1	40.1
48	MI	Mahaaburi	69-12	2 X 20	40	48.81	63.53	81.4	20	44.71	80	58.02	72.5	72.5
			115-12	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
			115-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
49	MI	Maha Bangkok	69-12	2 X 20	40	13.70	17.83	23.0	20	14.46	40	18.66	23.6	23.6
			69-24	3 X 40	120	17.11	22.27	28.6	40	32.91	120	42.75	53.6	53.6
50	PE	Pakkrad	69-12	2 X 40	80	36.36	48.93	62.4	40	40.00	80	50.00	62.5	62.5
			69-24	1 X 60	60	35.60	46.34	59.2	60	40.00	60	50.00	62.5	62.5
			115-12	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
			115-24	X	0	0.00	0.00	X	0	0.00	X	0	0.00	0.0
51	PI	Paknan	115-24	2 X 40	80	48.81	63.53	81.4	40	42.96	80	55.75	69.1	69.1
52	PS	Petchakasom	69-12	1 X 40	40	44.76	58.25	73.3	40	50.63	80	65.70	83.9	83.9
			69-24	1 X 40	40	20.86	27.15	34.6	40	18.43	40	23.92	29.9	29.9
53	PI	Praisingto	69-24	2 X 60	120	48.00	62.47	80.0	60	59.79	120	77.59	98.4	98.4

No	ABB	Substation	Voltage (KV)	1998				1999					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coincident (MVA)	utilization factor (%)	Rank configuration	Capacity (MVA)	coincident (MW)	non-coincident (MVA)	utilization factor (%)
30	KS	Nongsanpusmit	69-21	X	0	0.00	0.00	0.0	1 X 60	60	26.22	33.97	56.6
			115-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
31	KS	Nongsanpusmit	69-12	2 X 20	80	47.72	61.88	77.1	2 X 20	40	41.91	58.19	72.7
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
32	KT	Nongsanpusmit	69-12	2 X 40	80	45.82	58.82	73.5	2 X 40	80	41.93	51.33	67.9
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
33	KT	Nongtoey	69-12	1 X 40	40	14.41	18.72	46.8	1 X 40	40	15.00	19.14	48.6
			69-21	1 X 40	40	20.60	25.93	61.8	1 X 40	40	20.82	26.98	67.1
34	KT	Nongtoey	69-12	2 X 40	80	34.20	44.95	55.4	2 X 40	80	31.05	43.20	66.5
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
35	KU	Kruna	69-12	1 X 40	40	33.20	43.05	53.8	1 X 40	40	34.53	44.71	55.9
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
36	LX	Lardplakao	115-21	1 X 60	60	25.08	32.52	54.2	1 X 60	60	35.04	45.40	75.7
			69-12	2 X 40	80	33.56	43.52	54.1	1 X 40	40	14.90	19.31	48.3
37	LN	Lumpini	69-12	4 X 40	160	91.04	118.05	73.8	4 X 40	160	94.68	122.68	76.1
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
38	MN	Mahaisavan	69-12	2 X 40	80	18.07	23.43	29.3	2 X 40	80	18.60	21.10	30.1
			69-21	1 X 60	60	24.70	32.03	53.1	1 X 60	60	25.59	33.29	55.5
39	MN	Maharack	69-12	2 X 40	120	69.88	90.82	75.5	2 X 40	120	72.68	91.18	78.5
			115-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
40	MA	Mai-ad	69-12	2 X 40	80	38.71	50.20	62.8	2 X 40	80	40.26	52.17	65.2
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
41	MS	Mahasarakun	69-12	2 X 40	120	69.91	90.65	75.5	2 X 40	120	72.71	94.21	78.5
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
42	MD	Minburi	115-21	2 X 60	120	45.97	59.61	49.7	2 X 60	120	47.83	61.97	51.6
			69-12	2 X 40	80	45.41	58.88	49.1	2 X 40	80	47.52	61.37	51.3
43	MC	Mochit	69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
			115-21	2 X 60	120	51.69	67.03	55.9	2 X 60	120	53.76	69.66	58.1
44	MG	Mueang-in	115-21	2 X 60	120	56.36	73.73	61.4	2 X 60	120	57.13	74.03	61.7
			69-12	1 X 40	40	16.35	21.20	53.0	1 X 40	40	16.56	21.16	53.6
45	MI	Mueang-chong I	69-21	2 X 60	120	24.57	31.86	26.6	2 X 60	120	26.00	33.69	28.1
			115-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
46	MN	Na-na	69-12	2 X 60	120	47.99	62.23	51.9	2 X 60	120	49.71	64.11	53.7
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
47	MI	Nongbhum	69-12	2 X 60	120	47.99	62.23	51.9	2 X 60	120	49.71	64.11	53.7
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
48	NR	Northaburi	69-12	1 X 40	40	21.58	27.98	70.0	1 X 40	40	22.41	29.08	72.7
			115-21	1 X 60	60	20.36	26.40	44.0	1 X 60	60	29.17	37.80	63.0
49	NX	North Bangkok	69-12	3 X 40	120	31.26	41.43	37.0	3 X 40	120	38.17	49.85	41.5
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
50	PE	Pakared	69-12	1 X 40	40	0.00	0.00	0.0	1 X 40	40	0.00	0.00	0.0
			69-21	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
51	PN	Paknam	69-12	1 X 40	40	20.60	26.71	66.8	1 X 40	40	21.29	27.59	69.0
			115-21	2 X 60	120	44.66	57.91	48.2	2 X 60	120	47.00	60.90	50.8
52	PS	Petcharasew	115-21	2 X 40	80	45.98	59.62	74.5	2 X 40	80	43.00	55.71	69.6
			69-12	1 X 40	40	51.66	66.99	79.0	1 X 40	40	51.03	66.13	78.0
53	PI	Phaisangto	69-12	1 X 40	40	19.17	24.86	62.2	1 X 40	40	19.91	25.81	61.6
			69-21	2 X 60	120	52.18	67.65	58.1	2 X 60	120	51.67	70.81	59.0

No	ABB	Substation	Voltage (KV)	2000				2001					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MW)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MW)	utilization factor (%)
			69-21	1 x 60	60	27.00	35.00	58.3	1 x 60	60	27.82	35.99	60.0
			115-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
30	ES	Klongsanpasanit	69-12	2 x 20	40	45.25	58.86	75.0	2 x 20	40	47.65	61.65	77.1
			69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
31	KN	Klongsarn	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-24	2 x 40	80	42.59	55.20	69.0	2 x 40	80	43.85	56.74	70.9
32	KT	Klongtoey	69-12	1 x 40	40	14.89	19.30	48.3	x	0	0.00	0.00	0.0
			69-24	1 x 40	40	22.00	28.52	71.3	2 x 40	80	38.00	49.15	61.5
33	TC	Klongratsing	69-12	2 x (40)	80	45.70	59.23	74.0	x	0	0.00	0.00	0.0
			69-21	x	0	0.00	0.00	0.0	2 x 60	120	43.20	55.89	46.5
34	KU	Krunai	69-12	1 x 40	40	35.57	46.10	57.6	1 x 40	40	36.63	47.39	59.2
			69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
35	LK	Lardplakao	115-21	1 x 60	60	35.85	46.47	77.3	1 x 60	60	21.69	31.94	53.2
36	LP	Lardprao	69-12	1 x (40)	40	15.45	20.03	50.1	2 x (40)	80	30.67	39.68	49.6
			69-24	1 x 60	60	20.50	26.57	44.3	1 x 60	60	18.35	23.75	39.5
37	LX	Lumpini	69-12	4 x 40	160	97.52	126.40	79.0	1 x 40	40	22.38	28.95	72.1
			69-24	x	0	0.00	0.00	0.0	2 x 40	80	71.70	92.75	66.3
38	AN	Nahaisawan	69-12	1 x 40	40	14.47	18.76	46.9	x	0	0.00	0.00	0.0
			69-24	1 x 60	60	35.82	47.73	47.7	2 x 40	80	62.01	80.27	57.3
39	YK	Nahaeck	69-12	2 x 40	80	71.70	92.84	77.5	x	0	0.00	0.00	0.0
			115-21	x	0	0.00	0.00	0.0	3 x 60	180	73.85	95.51	53.1
40	XA	Nai-ad	69-12	2 x 40	80	41.47	53.75	67.2	x	0	0.00	0.00	0.0
			69-24	x	0	0.00	0.00	0.0	2 x 40	80	42.71	55.25	69.1
41	XS	Nakasun	69-12	2 x 40	80	64.09	83.07	69.2	2 x 40	80	41.99	54.33	67.9
			69-24	x	0	0.00	0.00	0.0	1 x 60	60	28.85	37.33	62.2
42	XB	Ninburi	115-21	2 x 60	120	40.08	51.55	43.3	2 x 60	120	52.13	67.44	56.2
43	XC	Nochit	69-12	2 x 40	80	50.50	65.46	54.6	2 x 40	80	65.63	84.91	70.8
			69-24	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
44	XC	Nuangsein	115-21	2 x 60	120	55.27	71.77	59.8	2 x 60	120	57.01	73.80	61.5
45	XI	Nuangthorik 1	115-21	2 x 60	120	60.83	78.87	65.7	2 x 60	120	67.65	87.53	72.9
46	NN	Nara	69-12	1 x (40)	40	17.00	22.04	55.1	1 x (40)	40	16.99	21.98	55.0
			69-24	2 x 60	120	39.96	51.79	43.2	2 x 60	120	28.16	36.13	30.4
			115-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
47	NI	Nongkhua	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-21	2 x 60	120	52.05	67.47	56.2	2 x 60	120	59.55	77.01	61.2
48	NR	Nonthaburi	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			115-12	1 x 40	40	19.11	24.77	61.9	x	0	0.00	0.00	0.0
			115-21	1 x 60	60	36.56	47.39	79.0	2 x 60	120	65.05	84.15	70.1
49	NK	North Bangkok	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-21	3 x 40	120	40.70	52.75	44.0	3 x 40	120	11.92	15.21	45.2
50	PE	Pakkred	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			115-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
51	PN	Paknam	115-21	3 x 60	180	75.43	97.77	51.3	3 x 60	180	72.15	93.73	52.1
52	PS	Petchakasom	69-12	2 x 40	80	42.67	55.31	69.1	2 x 60	120	50.89	65.81	51.9
			69-21	1 x 40	40	44.86	58.14	68.6	2 x 22.1	44.8	25.71	33.30	71.3
			69-12	1 x 40	40	0.00	0.00	0.0	1 x 40	40	16.81	21.79	51.5
53	PI	Phaisiingto	69-21	2 x 60	120	59.11	76.81	63.8	3 x 50	150	88.76	116.13	61.5

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No.	ABB	Substation	Voltage (KV)	1996				1997				
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)
54	PJ	Poojao	69-12 69-24	3 x 40 x	120 0	63.12 0	82.15 0.00	68.5 0.0	120 0	61.97 0.00	80.12 0.00	67.0 0.0
55	PC	Prachuen	69-12 69-24	2 x 40 x	80 0	38.35 0	49.91 0.00	62.1 0.0	80 0	41.37 0.00	53.69 0.00	67.1 0.0
56	PK	Prakanong	69-12 69-24	2 x 40 x	80 0	42.86 0	55.78 0.00	69.7 0.0	80 0	43.11 0.00	55.91 0.00	69.9 0.0
57	PK	Prakaso	115-24	2 x 40 1 x 60	140	67.15	87.40	62.1	140	59.61	77.39	55.3
58	PO	Promok	69-12 69-24	2 x 40 x	80 0	41.09 0	53.48 0.00	66.9 0.0	80 0	45.73 0.00	59.31 0.00	74.2 0.0
59	PD	Prapradang	69-12 69-24	3 x 40 x	120 0	58.20 0	75.75 0.00	63.1 0.0	120 0	52.79 0.00	68.51 0.00	57.1 0.0
60	PA	Prasamit	69-12 69-24	3 x 40 x	120 0	61.15 0	79.59 0.00	66.3 0.0	120 0	50.45 0.00	65.17 0.00	54.6 0.0
61	PA	Prathavan	69-12 69-24	3 x 40 x	120 0	65.10 0	84.73 0.00	70.6 0.0	120 0	69.71 0.00	90.16 0.00	75.1 0.0
62	RT	Ratindra	115-24	2 x 60 x	120	40.57	52.80	41.0	120	43.51	55.50	47.1
63	RI	Rakhaeng	69-12 69-24	2 x 40 1 x 60	140	52.12	67.84	48.5	140	55.06	71.15	51.0
64	RI	Rasrua	69-12 69-24	3 x 40 x	120 0	60.12 0	78.25 0.00	65.2 0.0	120 0	61.85 0.00	84.16 0.00	70.1 0.0
65	RE	Reklao	115-24	2 x 60 x	120	55.73	72.54	60.5	120	57.60	74.75	62.3
66	RC	Rungpracha	69-12 69-24	3 x 60 x	180	65.00	84.60	47.0	180	85.41	110.38	61.6
67	SI	Sailom	69-12 69-24	2 x 40 x	80 0	45.29 0	58.95 0.00	73.7 0.0	80 0	38.96 0.00	50.56 0.00	63.2 0.0
68	SR	Sarong	69-12 69-24	2 x 40 1 x 60	80 60	20.00 19.19	26.03 24.98	32.5 41.6	80 60	19.15 20.00	21.85 25.45	31.1 43.3
69	SI	Saen	69-12 69-24	3 x 40 x	120 0	59.22 0	77.08 0.00	61.2 0.0	120 0	62.36 0.00	80.92 0.00	67.4 0.0
70	SS	Sasab	69-12 69-24	1 x 40 2 x 40	40 80	16.44 38.95	21.40 50.70	53.5 63.1	40 80	19.92 45.69	25.85 59.29	64.6 74.1
71	SD	Sapadum	69-12	1 x 40 x	160	85.96	111.88	69.9	160	88.59	114.96	71.9
72	SP	Sapamai	69-12 69-24	2 x 60 x	120	51.70	67.29	56.1	120	46.31	60.10	50.1
73	SI	Silom	69-12 69-24	2 x 40 x	80 0	42.44 0	55.24 0.00	69.1 0.0	80 0	37.73 0.00	48.96 0.00	61.2 0.0
74	SI	Siraya	69-12 69-24	2 x 40 x	80 0	41.06 0	53.44 0.00	66.8 0.0	80 0	41.35 0.00	53.66 0.00	67.1 0.0
75	SI	Sirvijai	69-12 69-24	1 x 40 2 x 60	40 120	16.95 43.43	22.06 56.53	55.2 47.1	40 120	22.56 15.39	29.28 58.99	73.2 49.1
76	SK	South Bangkok	69-12 69-24	2 x 20 x	40 0	11.51 0	14.98 0.00	37.5 0.0	40 0	12.16 0.00	15.78 0.00	39.5 0.0
77	ST	South Thanburi	69-12 69-24	2 x (40) x	80 0	38.98 0	52.04 0.00	65.1 0.0	80 0	44.27 0.00	57.45 0.00	71.8 0.0
78	YA	Sriharua	69-12 115-12	1 x (40) x	40 0	20.61 0	26.83 0.00	67.1 0.0	40 0	23.81 0.00	30.90 0.00	77.3 0.0
79	SO	Suanso	69-12 69-24	2 x 40 x	80 0	38.04 0	49.51 0.00	61.9 0.0	80 0	44.09 0.00	57.21 0.00	71.5 0.0

No.	ABB	Substation	Voltage (KV)	1998				1999					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinc. (MW)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinc. (MW)	utilization factor (%)
51	PJ	Poojao	69-12	3 x 40	120	64.46	83.38	69.7	0.0	120	70.96	91.91	76.6
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
55	PC	Prachuchuen	69-12	2 x 40	80	38.51	49.93	62.4	0.0	80	35.16	45.95	57.4
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
56	PK	Prakanong	69-12	1 x 40	40	20.43	26.50	66.3	0.0	40	23.48	30.12	76.1
			69-21	1 x 40	40	20.69	26.81	67.1	0.0	40	21.21	31.36	78.1
57	PK	Prakasa	115-21	2 x 40	140	61.93	79.11	56.5	0.0	140	63.51	82.29	59.8
			69-12	2 x 40	80	45.59	58.11	73.9	0.0	80	45.31	58.75	73.4
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
59	PD	Prapradaeng	69-12	3 x 40	120	66.35	86.04	71.7	0.0	120	49.76	64.18	53.7
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
60	PA	Prasamit	69-12	2 x 40	80	41.79	51.19	67.7	0.0	80	41.00	53.13	66.4
			69-21	1 x 40	40	21.08	27.91	68.3	0.0	40	21.38	31.59	79.0
61	PK	Prathuwan	69-12	3 x 40	120	54.58	70.77	59.0	0.0	120	73.17	91.81	79.0
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
62	KT	Baninira	115-21	2 x 60	120	45.96	58.32	49.0	0.0	120	46.26	59.94	50.0
			69-12	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
63	PH	Banbhanbong	69-21	2 x 40	140	56.53	73.30	52.4	0.0	140	57.30	71.25	53.0
64	PH	Banburana	69-12	3 x 40	120	69.32	90.15	75.1	0.0	120	72.30	93.68	78.1
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
65	PH	Banliao	115-21	2 x 60	120	59.13	77.06	61.2	0.0	120	62.36	80.30	67.3
			69-12	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
66	RC	Rungpracha	69-21	3 x 60	180	72.93	93.79	52.1	0.0	180	78.59	101.83	56.6
67	SN	Sailoo	69-12	2 x 40	80	38.71	50.20	62.8	0.0	80	40.51	52.53	65.7
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
68	SR	Saareng	69-12	2 x 40	80	22.52	29.20	36.5	0.0	80	12.00	15.55	38.9
			69-21	1 x 60	60	11.00	14.26	23.8	0.0	60	23.82	38.61	32.2
69	SN	Saason	69-12	3 x 40	120	65.05	84.35	70.3	0.0	120	67.87	87.91	73.3
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
70	SS	Sansub	69-12	1 x 40	40	20.71	26.86	67.1	0.0	40	21.54	27.91	69.8
			69-21	2 x 40	80	41.52	53.84	67.3	0.0	80	43.18	55.95	69.9
71	SD	Sayandaa	69-12	4 x 40	160	93.52	121.27	75.8	0.0	160	96.72	125.32	78.3
			69-12	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
			69-21	2 x 60	120	48.16	62.45	52.0	0.0	120	50.09	61.90	51.1
73	SL	Silom	69-12	2 x 40	80	35.49	46.02	57.5	0.0	80	31.80	45.09	56.1
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
74	SY	Siraya	69-12	2 x 40	80	42.21	54.73	68.4	0.0	80	39.79	51.56	61.5
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
75	SY	Sukwilai	69-12	1 x 40	40	23.47	30.43	76.1	0.0	40	21.32	27.63	69.1
			69-21	2 x 60	120	47.21	61.22	51.0	0.0	120	52.10	67.51	56.3
76	SA	South Bangkok	69-12	2 x 20	40	12.65	16.40	41.0	0.0	40	14.15	18.33	45.8
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
77	ST	South Thanburi	69-12	2 x (40)	80	44.30	57.44	71.8	0.0	80	21.78	28.22	70.6
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
78	YA	Sri Thanya	69-12	1 x (40)	40	23.69	30.72	76.8	0.0	40	25.05	33.81	56.3
			115-12	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
			115-24	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0
79	SD	Shamsom	69-12	2 x 40	80	46.14	59.83	74.8	0.0	80	45.37	58.78	73.5
			69-21	x	0	0.00	0.00	0.0	0.0	0	0.00	0.00	0.0

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

(9/21)

No.	ABB	Substation	Voltage (KV)	2000				2001					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)
54	PJ	Poojiao	69-12	3 X 40	120	72.01	93.38	77.8	0	0.00	69.15	89.17	71.6
			69-24	X	0	0.00	0.00	0.0	3 X 40	120	0.00	0.00	0.0
55	PC	Prachuchuen	69-12	2 X 40	80	45.04	58.38	73.0	0	0.00	37.63	48.68	18.7
			69-24	X	0	0.00	0.00	0.0	1 X 40	60	0.00	0.00	0.0
56	PK	Prakanong	69-12	1 X 40	40	23.59	30.57	76.4	0	0.00	0.00	0.00	0.0
			69-24	X	0	0.00	0.00	0.0	2 X 40	80	40.19	52.00	65.0
57	PK	Prakusa	115-24	2 X 40	100	65.11	81.82	68.6	1 X 60	140	68.11	88.55	63.3
			69-12	X	40	22.59	28.29	73.2	X	0	0.00	0.00	0.0
58	PO	Pranick	69-24	1 X 40	40	15.57	15.57	38.9	2 X 40	80	35.61	45.11	51.6
			69-12	X	120	51.10	66.82	55.5	3 X 40	120	38.09	75.16	62.6
59	PD	Prapradeng	69-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
			69-12	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
60	PA	Prasarnit	69-12	3 X 40	120	61.00	79.07	65.9	3 X 40	120	62.83	81.29	67.7
			69-24	X	120	67.12	87.00	72.5	1 X 40	40	23.81	30.81	77.0
61	PM	Prathuewan	69-12	2 X 40	80	45.11	58.48	73.1	2 X 40	80	45.32	58.63	73.3
			69-24	X	0	0.00	0.00	0.0	2 X 60	120	41.02	56.95	47.5
62	RT	Ramintra	69-12	2 X 40	80	45.11	58.48	73.1	2 X 40	80	45.86	59.31	74.2
			69-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
63	RH	Ramkhamhaeng	69-12	2 X 60	120	55.65	72.13	60.1	2 X 60	120	56.05	72.52	60.1
			69-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
64	RN	Rasburana	69-12	3 X 40	120	81.02	108.90	90.5	3 X 60	180	75.50	97.68	81.3
			69-24	X	80	45.11	58.48	73.1	2 X 40	80	45.86	59.31	74.2
65	RK	Romklao	69-12	2 X 60	120	55.65	72.13	60.1	2 X 60	120	56.05	72.52	60.1
			69-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
66	RC	Rongpracha	69-12	3 X 60	180	81.02	108.90	90.5	3 X 60	180	75.50	97.68	81.3
			69-24	X	0	0.00	0.00	0.0	2 X 40	80	45.86	59.31	74.2
67	SN	Sailom	69-12	1 X 40	40	12.82	16.62	41.5	1 X 40	40	0.00	0.00	0.0
			69-24	X	0	0.00	0.00	0.0	3 X 60	180	61.91	80.10	44.5
68	SR	Sarong	69-12	2 X 60	120	38.25	49.58	41.3	2 X 40	80	41.21	53.32	66.7
			69-24	X	0	0.00	0.00	0.0	1 X 40	40	23.31	30.20	75.5
69	SN	Sanson	69-12	3 X 40	120	67.36	87.31	72.8	2 X 40	80	42.80	56.7	66.7
			69-24	X	0	0.00	0.00	0.0	1 X 40	40	18.86	24.10	61.0
70	SS	Sarsab	69-12	1 X 40	40	20.00	25.92	64.8	1 X 40	40	11.81	15.09	67.6
			69-24	X	0	0.00	0.00	0.0	2 X 40	80	41.81	51.09	67.6
71	SD	Sapadum	69-12	4 X 40	160	98.12	127.18	78.5	4 X 40	160	81.58	109.13	68.1
			69-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
72	SP	Supamei	69-12	2 X 60	120	51.59	66.87	55.7	2 X 60	120	53.14	68.75	57.3
			69-24	X	80	46.19	59.87	74.8	2 X 40	80	37.10	48.00	60.0
73	SL	Silom	69-12	2 X 40	80	40.98	53.12	65.4	1 X 40	40	21.02	27.20	68.0
			69-24	X	0	0.00	0.00	0.0	1 X 40	40	21.19	27.12	68.5
74	SV	Sipraya	69-12	1 X 40	40	23.76	30.80	77.0	1 X 40	40	22.95	29.69	74.2
			69-24	X	0	0.00	0.00	0.0	2 X 60	120	46.57	60.25	50.2
75	SV	Sonajjai	69-12	2 X 20	40	17.03	22.08	55.2	2 X 20	40	15.02	19.13	32.1
			69-24	X	0	0.00	0.00	0.0	1 X 60	60	15.02	19.13	32.1
76	SK	South Bangkok	69-12	2 X 60	120	51.16	70.20	58.5	2 X 60	120	53.18	69.19	57.7
			69-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
77	ST	South Thonburi	69-12	1 X 40	40	24.05	31.18	77.9	1 X 40	40	19.12	24.71	61.8
			69-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
78	YA	Sri thanya	115-24	2 X 40	80	41.21	57.30	71.6	2 X 40	80	41.21	57.30	71.6
			69-12	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
79	ST	Suanson	69-12	2 X 40	80	41.21	57.30	71.6	2 X 40	80	41.21	57.30	71.6
			69-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0

No.	ABB	Substation	Voltage (KV)	1996					1997				
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)
80	SU	Surawong	69-12	3 X 40	120	60.74	79.06	65.9	3 X 40	120	71.42	92.68	77.2
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
81	TS	Taksin	69-12	1 X 40	40	18.68	24.31	60.8	1 X 40	40	20.63	26.77	56.9
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
82	TP	Toprak	69-24	2 X 40	80	77.54	100.92	72.1	2 X 40	80	68.71	89.15	62.7
83	TT	Thaenotok	69-12	1 X 40	40	28.51	37.24	93.1	1 X 40	40	21.31	31.53	78.9
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
84	TB	Thonburi	69-12	2 X 40	80	44.00	57.27	71.6	2 X 40	80	38.09	49.43	61.8
			69-24	1 X 50	60	20.04	26.08	43.5	1 X 50	60	17.72	23.00	38.3
85	TK	Tongbung	69-12	2 X 40	80	41.63	51.18	67.7	2 X 40	80	43.26	56.14	70.2
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
86	TB	Tanpochaboon	69-12	2 X 40	80	55.60	73.67	92.1	2 X 40	80	39.77	51.61	64.5
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
87	TT	Tangethonglang	69-12	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
			69-24	3 X 60	180	64.73	84.25	46.8	3 X 60	180	70.72	91.77	51.0
88	TL	Tatlieb	69-12	3 X 40	120	64.34	83.74	69.8	3 X 40	120	69.63	90.36	75.3
89	VT	Yothec	69-12	2 X 40	80	34.63	45.07	56.3	2 X 40	80	39.92	51.80	61.8
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
90	BE	Bungbae	69-12	1 X 40	40	22.49	29.27	73.2	1 X 40	40	23.90	31.02	77.5
			115-12	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
			115-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
91	BZ	Bangson	69-12	1 X (40)	40	32.00	41.65	104.1	2 X (40)	80	33.04	42.88	53.6
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
92	RI	Bearing	69-24	1 X 60	60	44.05	57.33	95.6	X	0	0.00	0.00	0.0
			115-24	X	0	0	0.00	0.0	2 X 60	120	50.51	65.55	54.6
93	EM	Ekamai	69-12	1 X (40)	40	30.31	39.45	98.6	2 X (40)	80	40.97	53.17	66.5
			69-24	X	0	0	0.00	0.0	1 X 60	60	32.67	42.40	70.7
			115-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
94	EB	Ekaburi	115-24	1 X 60	60	16.00	20.83	34.7	1 X 60	60	18.00	23.36	38.9
95	HA	Huamak	69-12	1 X 40	40	19.51	25.39	63.5	X	0	0.00	0.00	0.0
			69-24	X	0	0	0.00	0.0	1 X 40	40	22.28	28.91	72.3
			115-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
96	IN	Intamura	69-24	2 X 50	100	36.03	46.90	99.1	2 X 60	120	40.10	52.01	43.4
97	JR	Jangron	69-12	1 X (40)	40	16.33	21.25	53.1	1 X (40)	40	17.68	22.91	57.1
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
98	KD	Khator	115-24	1 X 50	50	40.16	52.66	87.8	2 X 60	120	45.99	59.68	49.7
99	KI	Kingkas	115-24	2 X 50	100	40.47	52.67	43.9	2 X 60	120	41.83	51.28	45.2
100	KH	Klongsubaswad	115-24	2 X 60	120	41.20	53.82	44.7	2 X 60	120	47.30	61.38	51.2
101	LB	Lardkrabang	115-24	2 X 60	120	31.96	41.62	34.7	2 X 60	120	40.65	52.75	44.0
102	X3	Kuangthong 3	115-24	1 X 60	60	34.00	44.25	73.8	2 X 60	120	42.06	51.58	45.3
103	NS	Nonsae	69-12	2 X (40)	80	30.69	39.94	49.9	2 X (40)	80	33.67	43.69	51.6
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
104	PP	Pradipat	69-12	2 X (40)	80	37.76	49.15	61.4	2 X (40)	80	40.22	52.20	65.3
			69-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
105	SA	Saimitip	69-12	X	0	0	0.00	0.0	1 X (40)	40	18.23	23.66	59.1
			69-24	1 X 60	60	36.54	47.56	79.3	1 X 60	60	22.00	28.55	47.6
			115-24	X	0	0	0.00	0.0	X	0	0.00	0.00	0.0
106	SB	Suanbinnam	69-12	1 X (40)	40	20.22	26.32	65.8	X	0	0.00	0.00	0.0
			69-24	1 X 60	60	18.00	23.43	39.1	X	0	0.00	0.00	0.0

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No.	ABB	Substation	Voltage (kV)	1998				1999				
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci. (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci. (MVA)
80	SU	Surawong	69-12 69-24	3 x 40 x	120 0	72.65 0.00	94.18 0.00	78.5 0.0	120 0	65.71 0.00	85.11 0.00	71.0 0.0
81	TS	Taksin	69-12 69-24	1 x 40 x	40 40	19.21 22.00	24.91 28.53	62.3 71.3	0 80	0.00 42.86	0.00 55.51	0.0 69.1
82	TP	Toprak	69-24	2 x 40 x	80	75.90	98.12	70.3	80	83.21	107.82	77.0
83	TT	Thonburi	69-12 69-24	1 x 40 x	40 0	43.31 0.00	56.16 0.00	70.2 0.0	1 x (40) 0	45.14 0.00	58.19 0.00	73.1 0.0
84	TB	Thonburi	69-12	2 x 40 x	80	36.88	47.96	60.0	80	36.51	47.31	59.2
85	TK	Tongkung	69-12	1 x 60 x	60	23.23	30.12	50.2	60	29.18	38.20	63.7
86	TB	Tongkung	69-12	2 x 40 x	80	41.99	58.31	72.9	80	45.29	58.68	73.4
87	FT	Fangthonglang	69-12	2 x 40 x	80	41.37	53.61	67.1	120	63.70	82.51	68.8
88	FL	Fatlieb	69-12	3 x 60 x	180	74.56	96.68	53.7	180	67.86	87.93	48.9
89	VT	Yothee	69-12 69-24	2 x 40 x	80	41.92	53.81	67.3	80	43.18	55.95	69.9
90	BE	Bangkok	69-12 115-12 115-24	1 x 40 x	40	24.65	31.97	75.9	0	0.00	0.00	0.0
91	EZ	Bangson	69-12 69-24	2 x (40) x	80	37.16	48.19	60.2	1 x (40) 60	21.37 23.92	31.58 30.99	78.9 51.7
92	R1	Boaring	69-24 115-24	2 x 60 x	120	52.73	68.38	57.0	120	55.64	71.32	59.1
93	EX	Ekamai	69-12 69-24	1 x (40) x	40	21.81	28.28	70.7	40	22.68	29.39	73.5
94	EB	Ekbari	115-24	1 x 60 x	60	20.51	26.53	44.4	1 x 60 60	21.36	27.58	46.1
95	BA	Banank	69-12 69-24	1 x 40 x	40	23.17	30.05	75.1	1 x 40 40	20.10	26.01	65.1
96	IR	Intanara	69-12 69-24	2 x 60 x	120	41.71	54.08	45.1	120	43.37	56.20	46.8
97	JR	Jangron	69-12 69-24	1 x (40) x	40	18.39	23.85	59.6	40	19.13	24.79	62.0
98	KO	Koitor	115-24	2 x 60 x	120	49.77	64.54	53.8	120	53.37	72.00	60.0
99	KI	Kingsae	115-24	2 x 60 x	120	42.50	55.11	45.9	120	50.87	65.91	51.9
100	KH	Kongkasuead	115-24	2 x 60 x	120	50.90	66.00	55.0	120	52.82	68.11	57.0
101	LB	Lardkrabang	115-24	2 x 60 x	120	49.54	64.24	53.5	120	41.70	57.92	48.3
102	M3	Muangthong 3	115-24	2 x 60 x	120	51.14	70.20	58.3	120	56.31	72.96	60.8
103	NS	Norsec	69-12	1 x (40) x	40	15.79	20.48	51.2	40	11.23	14.55	36.1
104	PT	Pradipat	69-12 69-24	2 x (40) x	80	38.59	50.04	62.6	80	42.17	51.61	68.3
105	SA	Saibualip	69-12 69-24	2 x 60 x	120	46.41	60.17	50.2	120	48.81	63.25	52.7
106	SB	Sarabinnam	69-12 69-24	2 x 60 x	120	46.41	60.17	50.2	120	48.81	63.25	52.7

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

(12/21)

No	ABB	Substation	Voltage (KV)	2000				2001					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinc: (MW)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinc: (MW)	utilization factor (%)
80	SU	Surarong	69-12	3 x 40	120	67.68	87.72	73.1	1 x 40	40	23.51	30.12	76.0
			69-21	x	0	0.00	0.00	0.0	2 x 60	120	46.20	59.77	49.8
81	TS	Taksin	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-21	2 x 40	80	41.15	57.23	71.5	2 x 40	80	37.47	48.48	60.6
82	TP	Teprak	69-21	2 x 40	80	79.14	102.57	73.3	2 x 40	80	70.60	91.31	65.2
83	TT	Thanontok	69-12	1 x 40	40	40.94	53.07	66.3	x	0	0.00	0.00	0.0
			69-21	x	0	0.00	0.00	0.0	2 x 60	120	47.79	61.83	51.5
84	TB	Thanburi	69-12	2 x 40	80	40.75	52.82	66.0	2 x 40	80	42.45	54.92	63.7
			69-21	1 x 60	60	27.05	35.06	58.4	1 x 60	60	29.45	38.10	63.5
85	TK	Tongkung	69-12	2 x 40	80	42.64	55.27	69.1	x	0	0.00	0.00	0.0
			69-21	x	0	0.00	0.00	0.0	2 x 40	80	41.40	53.56	67.0
86	TB	Tangpetchaboon	69-12	2 x 40	80	65.74	85.21	71.0	x	0	0.00	0.00	0.0
			69-21	x	0	0.00	0.00	0.0	3 x 60	180	83.28	107.75	59.9
87	VT	Vangthonglang	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-21	3 x 60	180	69.90	90.60	50.3	3 x 60	180	71.22	99.90	55.5
88	VL	Vallitob	69-12	3 x 40	120	73.22	94.90	79.1	3 x 40	120	66.82	86.15	72.0
89	YT	Yothce	69-12	2 x 40	80	44.48	57.65	72.1	2 x 40	80	44.10	57.05	71.3
			69-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
90	BE	Bangbac	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			115-12	2 x (40)	80	45.94	59.55	74.4	1 x (40)	40	22.52	29.14	72.8
			115-21	x	0	0.00	0.00	0.0	1 x 60	60	30.24	39.12	65.2
91	BZ	Bangson	69-12	1 x 40	40	23.54	30.52	76.3	x	0	0.00	0.00	0.0
			69-21	1 x 60	60	28.64	37.12	81.9	2 x 80	120	42.80	55.37	46.1
92	RI	Rearing	69-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			115-21	2 x 60	120	56.84	73.67	61.4	2 x 60	120	63.69	82.40	68.7
93	EM	Ekamai	69-12	1 x (40)	40	21.67	28.09	70.2	1 x (40)	40	19.94	25.80	61.5
			69-21	2 x 60	120	58.00	75.18	82.7	2 x 60	120	62.12	80.37	67.0
			115-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
94	EB	Ekkari	115-21	2 x 60	120	30.00	38.89	32.4	2 x 60	120	41.20	53.30	41.1
95	BA	Buaek	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-21	1 x 40	40	20.70	26.83	67.1	1 x 60	60	21.32	27.58	46.0
			115-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
96	IN	Intumra	69-21	2 x 60	120	44.68	57.91	49.3	2 x 60	120	46.02	59.54	49.6
97	JR	Jangron	69-12	1 x (40)	40	24.70	30.72	76.8	1 x (40)	40	24.41	31.58	79.0
			69-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
98	KO	Khoter	115-21	2 x 60	120	51.08	66.21	55.2	3 x 60	180	74.51	96.10	53.6
99	KI	Kingkay	115-21	2 x 60	120	59.57	69.44	57.9	2 x 60	120	56.79	73.17	61.2
100	KL	Klongbasurad	115-21	2 x 60	120	50.41	65.34	54.5	2 x 60	120	51.92	67.17	56.0
101	LB	Lardkrabang	115-21	2 x 60	120	46.72	60.56	50.5	2 x 60	120	49.27	63.74	53.1
102	MS	Muangthong 3	115-21	2 x 60	120	58.00	75.18	62.7	2 x 60	120	60.74	78.58	65.5
103	NS	Nansac	69-12	1 x (40)	40	14.72	19.08	47.7	x	0	0.00	0.00	0.0
			69-21	1 x 60	60	26.88	34.84	58.1	2 x 60	120	43.04	55.68	46.1
104	PT	Prudpat	69-12	2 x (40)	80	45.24	58.63	73.3	1 x (40)	40	22.25	28.79	72.0
			69-21	x	0	0.00	0.00	0.0	1 x 60	60	31.07	40.20	67.0
105	SA	Saunatip	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-21	2 x 60	120	64.81	84.00	70.0	3 x 60	180	62.29	80.59	44.8
			115-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
106	SB	Sarabinnua	69-12	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0
			69-21	x	0	0.00	0.00	0.0	x	0	0.00	0.00	0.0

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

(1.3/2.1)

No	ABB	Substation	Voltage (KV)	1986				1997						
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci. (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci. (MVA)	utilization factor (%)	
			115-12	X	0	0	0.00	0.0	0.0	1 X (40)	40	21.02	31.17	77.9
			115-24	X	0	0	0.00	0.0	0.0	1 X 60	60	20.00	25.95	43.3
107	RC	Suvarabong	115-21	1 X 60	60	23.16	30.14	50.2	50.2	1 X 60	60	30.40	39.15	65.8
108	OB	South Bangphee	115-21	1 X 60	60	36.22	47.14	78.6	78.6	2 X 60	120	43.33	56.23	46.9
109	SE	Srielaem	115-21	2 X 60	120	42.13	51.83	45.7	45.7	2 X 60	120	68.69	78.76	65.6
110	SG	Suanluang	69-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
			115-24	3 X 60	180	78.55	102.21	56.8	56.8	3 X 60	180	65.04	84.10	46.9
111	UK	Surasak	69-12	1 X (40)	40	24.34	31.68	79.2	79.2	2 X (40)	80	37.86	49.13	61.1
			69-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
112	TV	Tubun	115-21	X	0	0	0.00	0.0	0.0	1 X 60	60	32.26	41.86	69.8
113	TV	Taveccatana	115-24	1 X 60	60	20.44	26.60	44.3	44.3	1 X 60	60	22.28	28.91	48.2
114	TR	Thonburitrom	69-12	1 X (40)	40	21.00	27.33	68.3	68.3	1 X (40)	40	23.39	30.36	75.9
			115-21	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
115	TB	Tungsoyong	69-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
			115-24	2 X 60	120	34.20	44.51	37.1	37.1	2 X 60	120	43.95	57.03	47.3
116	YK	Yenartart	69-12	2 X (40)	80	45.60	59.95	74.2	74.2	2 X (40)	80	44.55	57.81	72.3
			69-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
117	AB	Bangboi	115-24	1 X 60	60	16.10	20.96	34.9	34.9	2 X 60	120	20.00	25.95	21.6
118	JK	Bangjak	69-12	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
			115-12	1 X (40)	40	16.32	21.24	53.1	53.1	1 X (40)	40	13.00	16.87	42.2
			115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
119	MD	Bangkradee	69-12	1 X (40)	40	12.10	15.75	36.4	36.4	1 X (40)	40	11.50	14.92	37.3
			115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
120	PH	Bangshan	115-24	1 X 60	60	17.18	22.36	37.3	37.3	1 X 60	60	17.82	23.13	38.3
121	MI	Bemai	69-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
122	DO	Dindabong	69-12	X	0	0	0.00	0.0	0.0	1 X (40)	40	17.36	22.53	56.3
			115-12	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
			115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
123	EC	Ekachai	69-12	1 X (40)	40	10.40	13.54	33.8	33.8	1 X (40)	40	11.00	14.28	35.7
			115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
124	CK	Choklang	69-24	1 X 60	60	16.00	20.83	34.7	34.7	2 X 60	120	17.00	22.06	48.4
			115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
125	JY	Jangratana	115-24	1 X 60	60	42.97	55.93	93.2	93.2	2 X 60	120	45.36	60.16	50.1
126	JJ	Jatujang	69-12	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
			69-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
			115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
127	KE	Kaset	69-12	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
			69-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
128	KG	Klongkue	115-24	X	0	0	0.00	0.0	0.0	1 X 60	60	22.00	28.35	47.6
129	KL	Klongprapa	115-24	1 X 60	60	8.21	10.73	17.9	17.9	1 X 60	60	12.00	15.57	26.0
130	KB	Nir-udom	69-12	1 X 40	40	26.16	34.05	85.1	85.1	1 X 40	40	10.00	12.98	32.1
			69-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
131	KI	Muangthong 4	115-24	X	0	0	0.00	0.0	0.0	1 X 60	60	28.56	37.06	61.8
132	K5	Muangthong 5	115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
133	K6	Muangthong 6	115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
134	K7	Muangthong 7	115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
135	NL	Sang Terrig	69-12	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
136	TH	Patankarn	115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0
137	PI	Phuapla	115-24	X	0	0	0.00	0.0	0.0	X	0	0.00	0.00	0.0

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No.	ABB	Substation	Voltage (KV)	1998				1999					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)
			115-12	1 x (40)	40	20.49	26.57	66.4	1 x (40)	40	23.05	29.87	74.7
			115-24	1 x 60	60	26.32	34.13	56.9	1 x 60	60	29.53	38.39	54.0
107	RG	Surabong	115-24	1 x 60	60	28.57	37.04	61.7	1 x 60	60	31.36	40.63	61.7
108	OB	South Bangplice	115-24	2 x 60	120	45.24	58.56	48.9	2 x 60	120	49.94	63.55	52.0
109	SE	Sriacian	115-24	2 x 60	120	58.32	88.59	73.8	2 x 60	120	66.67	86.39	72.0
110	SG	Suanluang	69-24	3 x 60	180	70.98	92.04	51.1	3 x 60	180	66.84	86.60	48.1
			115-24	2 x (40)	80	44.10	57.19	71.5	2 x (40)	80	43.00	55.72	69.7
111	UK	Surasak	69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
			115-24	1 x 60	60	31.48	40.83	88.0	1 x 60	60	36.18	46.88	78.1
112	TN	Taiban	115-24	2 x 60	120	42.92	55.14	46.0	2 x 60	120	50.24	65.23	54.4
113	TF	Tarawatana	69-12	2 x (40)	80	43.53	56.44	70.6	2 x (40)	80	40.61	52.62	65.8
114	TR	Thonburirom	115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
115	TI	Tungsonghong	69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
			115-24	2 x 60	120	37.39	48.48	40.4	2 x 60	120	38.89	50.39	42.0
116	YK	Yonarkart	69-12	2 x (40)	80	44.39	57.56	72.0	2 x (40)	80	46.13	59.77	74.7
			69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
117	AB	Bangbor	115-24	2 x 60	120	22.23	28.83	24.0	2 x 60	120	23.12	29.96	25.0
118	JK	Bangjak	69-12	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
			115-12	1 x (40)	40	16.93	21.95	54.9	1 x (40)	40	18.14	23.51	58.8
			115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
119	XD	Bangkradee	69-12	1 x (40)	40	12.00	15.56	38.9	1 x (40)	40	0.00	0.00	0.0
			115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
120	3H	Bangshan	115-24	2 x 60	120	26.95	34.17	28.5	2 x 60	120	35.61	46.14	38.5
121	XI	Banmai	69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
122	DD	Dinadong	69-12	1 x (40)	40	18.85	24.44	61.1	1 x (40)	40	19.61	25.41	63.5
			115-12	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
			115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
123	EC	Ekachai	69-12	1 x (40)	40	13.00	16.86	42.1	1 x (40)	40	0.00	0.00	0.0
			115-24	2 x 60	120	18.71	24.26	20.2	2 x 60	120	15.00	19.41	32.1
124	GA	Chookiang	69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
125	JV	Jongsutana	115-24	2 x 60	120	59.49	77.14	64.3	2 x 60	120	59.87	77.58	61.7
126	JJ	Jatujak	69-12	2 x (40)	80	25.00	32.42	40.5	2 x (40)	80	29.00	37.58	47.0
			69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
			115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
127	KE	Kasat	69-12	1 x (40)	40	16.77	21.75	51.4	1 x (40)	40	0.00	0.00	0.0
			69-24	1 x 60	60	26.19	33.96	56.6	1 x 60	60	48.69	63.09	52.6
128	KG	Kiangkong	115-24	1 x 60	60	33.12	42.95	71.6	1 x 60	60	41.11	57.58	48.0
129	KL	Klongprapa	115-24	1 x 60	60	16.18	21.37	35.6	1 x 60	60	19.14	24.80	41.3
130	KU	Kit-udom	69-12	1 x 40	40	12.96	16.03	40.1	1 x 40	40	12.85	16.65	41.6
			69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
131	KH	Kuangthong 4	115-24	2 x 60	120	60.00	77.80	64.8	2 x 60	120	59.40	76.97	61.1
132	X5	Kuangthong 5	115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
133	X6	Kuangthong 6	115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
134	X7	Kuangthong 7	115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
135	NL	Kuangthong	69-12	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0
136	TA	Patumkarn	115-24	1 x 60	60	0.00	0.00	0.0	1 x 60	60	14.36	18.61	31.0
137	PL	Phobla	115-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.00	0.0

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No.	ABB	Substation	Voltage (KV)	2000				2001				
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MW)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MW)
			115-12	1 x (40)	40	23.75	30.78	77.0	0	0.00	0.00	0.0
			115-21	1 x 60	60	39.51	39.55	120	55.89	72.31	59.3	
107	BC	Sarabhoj	115-21	1 x 60	60	24.30	31.50	52.5	1 x 60	60	25.02	32.37
108	BC	South Bangkok	115-21	2 x 60	120	52.61	68.19	56.8	2 x 60	120	59.31	76.77
109	SE	Sriejan	115-21	2 x 80	120	67.06	86.92	72.4	3 x 60	180	85.68	110.85
110	SR	Suanluang	69-21	3 x 60	180	58.61	88.94	49.4	3 x 60	180	55.47	73.05
111	UK	Surasak	69-12	2 x (40)	80	23.88	30.95	36.7	2 x 60	120	34.99	45.15
			69-24	2 x 60	120	65.13	84.12	70.4	2 x 60	120	62.39	80.72
112	TV	Taibun	115-21	2 x 60	120	54.47	70.60	58.8	2 x 60	120	61.26	79.28
113	TV	Tareccattana	115-21	2 x 60	120	41.82	54.21	57.8	2 x (40)	80	43.08	55.74
114	TV	Thomburiom	115-21	2 x 60	120	43.44	56.31	46.9	2 x 60	120	41.26	53.38
115	TH	Tungsohng	69-24	2 x (40)	80	44.31	57.44	71.8	2 x 60	120	41.81	57.98
116	YA	Yenarkart	69-12	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
			69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
117	AB	Bangbor	115-21	2 x 60	120	41.81	54.19	45.2	2 x 60	120	43.07	55.72
118	JK	Bangkok	69-12	1 x (40)	40	17.73	22.98	57.5	1 x (40)	40	13.02	16.85
			115-21	1 x 60	60	18.60	24.11	40.2	1 x 60	60	19.16	24.13
119	XP	Bangkraoche	69-12	2 x 60	120	27.72	35.93	29.9	2 x 60	120	35.28	45.61
120	BH	Bangshan	115-21	2 x 60	120	36.68	47.54	39.6	2 x 60	120	37.78	48.98
121	NI	Bunwai	69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	28.39	36.73
122	PD	Dindaong	69-12	2 x (40)	80	40.20	52.11	65.1	2 x (40)	80	45.40	58.74
			115-21	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
123	BC	Etachai	69-12	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
124	OK	Chookiang	69-24	2 x 60	120	35.39	45.87	38.2	2 x 60	120	48.45	62.68
			115-21	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
125	JH	Jungvatana	115-21	2 x 60	120	51.67	79.93	66.6	2 x 60	120	59.52	77.01
126	JJ	Jatujak	69-12	2 x (40)	80	38.29	48.63	62.0	2 x 60	120	51.65	66.82
			69-24	2 x 60	120	0.00	0.00	0.0	2 x 60	120	23.16	29.96
127	AE	Ausset	69-12	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
			69-24	2 x 60	120	50.11	61.99	51.2	2 x 60	120	51.65	66.82
128	KG	Klongkum	115-21	2 x 60	120	45.78	59.34	49.5	2 x 60	120	47.15	61.00
129	XL	Klongpruea	115-21	1 x 60	60	19.71	25.55	42.6	2 x 60	120	32.30	41.79
130	NU	Nitruwaa	69-12	1 x 40	40	13.46	17.45	43.6	1 x 40	40	21.53	27.85
			69-24	2 x 60	120	55.82	72.35	60.3	2 x 60	120	59.30	76.98
131	MI	Kuangthong 1	115-21	2 x 60	120	61.35	79.52	66.3	2 x 60	120	59.19	76.38
132	MS	Kuangthong 5	115-21	2 x 60	120	60.72	78.70	65.6	2 x 60	120	59.51	77.03
133	MS	Kuangthong 6	115-21	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
134	MT	Kuangthong 7	115-21	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
135	NU	Nangleroy	69-12	2 x 60	120	18.25	23.66	39.1	2 x 60	120	31.80	45.02
136	TA	Patanakum	115-21	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0
137	PI	Pitopla	115-21	2 x 60	120	0.00	0.00	0.0	2 x 60	120	0.00	0.0

No	ABB	Substation	Voltage (KV)	1996				1997						
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	
138	PH	Praves	115-21	X	0	0	0.00	0.00	X	0	0	0.00	0.00	0.0
139	RP	Proepong	115-21	X	0	0	0.00	0.00	X	0	0	0.00	0.00	0.0
140	SI	Saimoi	115-24	X	0	0	0.00	0.00	X	0	0	0.00	0.00	0.0
141	SN	Sawarn	115-12	X	0	0	0.00	0.00	X	1	40	23.88	30.99	77.5
142	SN	Sawarn	115-24	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
143	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
144	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
145	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
146	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
147	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
148	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
149	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
150	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
151	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
152	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
153	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
154	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
155	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
156	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
157	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
158	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
159	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
160	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
161	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
162	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
163	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
164	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
165	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
166	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
167	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
168	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
169	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
170	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
171	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
172	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
173	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
174	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
175	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
176	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
177	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
178	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
179	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0
180	SN	Sawarn	115-21	X	0	0	0.00	0.00	X	X	0	0.00	0.00	0.0

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

(17/21)

No	ABB	Substation	Voltage (KV)	1998				1999						
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coincident (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coincident (MVA)	utilization factor (%)	
138	PT	Prases	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
139	RP	Prompong	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
140	ST	Sainoi	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
141	YB	Suayarn	115-12	2 X (40)	80	37.95	48.44	60.6	60.6	2 X (40)	80	44.79	58.01	72.6
142	SI	Salorn	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
143	RP	Shimpee	115-21	1 X 60	60	23.84	30.91	51.5	51.5	1 X 60	60	22.88	29.65	49.1
144	ST	Sriwong	69-12	X	0	0.00	0.00	0.00	0.0	2 X (40)	80	23.00	29.80	37.3
145	YI	Suanvai	69-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
146	TF	Sutinbong	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
147	TI	Tha-bvian	69-12	X	0	0.00	0.00	0.00	0.0	2 X (40)	80	36.71	47.57	59.5
148	TC	Trochan	115-12	2 X (40)	80	41.24	53.47	66.8	66.8	2 X (40)	80	44.32	57.43	71.8
149	TY	Tubao	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
150	TK	Falkampung	69-12	1 X 60	60	17.74	23.00	38.3	38.3	1 X 60	60	20.10	26.13	44.1
151	FR	Falkart	69-12	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
152	AK	Asok	69-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
153	BT	Bangbong	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
154	BS	Bangboeac	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
155	BF	Bangkae	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
156	PV	Bangplecchai	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
157	TD	Bangtard	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
158	JB	Joraboo	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
159	KB	Klongbangi	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
160	LA	Khongva	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
161	GP	Klongpae	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
162	KR	Krungkrocia	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
163	LJ	Land & Thuse	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
164	KB	Kuangbang 8	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
165	XG	Kuangbang 9	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
166	KL	Prachao	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
167	RJ	Paichapratop	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
168	NP	Samngoo	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
169	ON	Saankom	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
170	OS	Saankom	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
171	IR	Srinakorn	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
172	LD	Thonglor	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
173	TU	Tungku	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
174	TD	Wadeed	69-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
175	GY	Bangkruay	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
176	GC	Bangkruay	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
177	MA	Bongpia	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
178	LD	Klongdan	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
179	GT	Klongratiam	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0
180	LC	Luangpang	115-21	X	0	0.00	0.00	0.00	0.0	X	0	0.00	0.00	0.0

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No	ABB	Substation	Voltage (KV)	2000				2001						
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	
138	PH	Prates	115-24	2 x 60	120	32.63	12.28	35.3	x	60	120	13.61	56.12	37.0
139	RP	Prompong	115-24	2 x 60	120	48.04	62.27	51.9	x	60	120	35.75	48.25	38.5
140	SI	Sairoi	115-21	x	0	0.00	0.00	0.0	x	60	120	22.36	28.93	21.1
141	YS	Sanyarn	115-12	2 x (40)	80	41.57	53.88	67.4	x	(10)	80	42.50	51.99	68.7
142	SH	Satorn	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
143	HP	Shimpee	115-21	2 x 60	120	48.92	63.11	52.8	x	60	120	53.35	69.02	57.5
144	SH	Shiang	69-12	2 x (40)	80	41.70	57.91	72.4	x	(10)	80	31.88	45.13	56.4
145	YI	Suanvai	69-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
146	WV	Sunintavong	115-24	x	0	0.00	0.00	0.0	x	60	120	21.36	27.61	23.0
147	TI	Tha-kwan	115-24	2 x 60	120	14.00	18.15	15.1	x	60	120	16.36	21.17	17.6
148	TC	Troktan	69-12	2 x (40)	80	37.81	49.01	61.3	x	(10)	80	38.95	50.39	63.0
149	TY	Tubiao	69-24	2 x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
150	TK	Tukhaeng	115-24	1 x 60	60	20.00	25.92	43.2	x	60	120	30.36	39.28	32.7
151	TK	Tuktakart	69-12	1 x 40	40	21.60	28.00	70.0	x	60	120	31.25	41.31	36.9
152	AK	Aeoke	69-24	1 x (40)	60	17.00	22.64	55.1	x	x	0	0.00	0.00	0.0
153	BT	Bongbuong	115-24	1 x 60	60	15.95	19.90	33.2	x	60	120	33.32	43.11	35.9
154	BS	Bonghuasae	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
155	BT	Bongkac	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
156	PT	Pangplechai	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
157	TD	Tongtard	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
158	JB	Jorabao	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
159	KB	Klongbangoi	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
160	LA	Lhongu	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
161	GP	Klongpae	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
162	KR	KrungLepraesta	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
163	LR	Land & Boae	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
164	MS	Muanghong 8	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
165	MS	Muanghong 9	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
166	RL	Prarakao	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
167	RJ	Bojheprarop	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
168	NP	Saengao	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
169	ON	Suanikam	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
170	OS	Songsumikon	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
171	IK	Srinakarin	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
172	LO	Thonglor	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
173	TU	Tungkrui	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
174	MO	Yutdeedee	69-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
175	CV	Rangkray	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
176	GO	Bonggang	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
177	MA	Rangpila	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
178	LD	Klongkan	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
179	GT	Klongkrathum	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0
180	LE	Luanggang	115-24	x	0	0.00	0.00	0.0	x	x	0	0.00	0.00	0.0

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No	ABB	Substation	Voltage (KV)	1996				1997					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)
181	LS	Lumpashe	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
182	NI	Nimitsoi	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
183	NY	Nongyai	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
184	IL	Pinkhao	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
185	PH	Pongpetch	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
186	PT	Puttanonton	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
187	RO	Rajchakru	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
188	RR	Rajdaari	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
189	AT	Satorntai	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
190	TL	Talingschan	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
191	TK	Tiarsuamit	115-24	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
192	RW	Trimit	69-12	X	0	0.00	0.00	0.0	X	0	0.00	0.00	0.0
Total					11.645	5.267.77	6.856.23	58.9		12.825	5.745.69	7.456.16	58.1

Diversity Factor 1.1809
Power Factor 0.9100

Diversity Factor 1.1805
Power Factor 0.9070

Number of Bank 277
Number of Substation 130
Ratio a/b 2.1308

Number of Bank 257
Number of Substation 124
Ratio a/b 2.0726

Appendix 6.3-4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No	ABB	Substation	Voltage (KV)	1998				1999					
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)
181	LS	Lumpashe	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
182	NI	Nimitmai	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
183	NY	Nongyai	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
184	IL	Pinkhao	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
185	PH	Pongpetch	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
186	PT	Pottanontom	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
187	RO	Rajchakru	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
188	RR	Rajdamri	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
189	AT	Satorntai	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
190	TL	Talingchan	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
191	TM	Tiamnammit	115-24	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
192	RV	Tritait	69-12	X	0	0.00	0.00	0.00	X	0	0.00	0.00	0.00
Total					13.585	6.171.46	8.002.55	58.9		14.425	6.826.59	8.586.21	59.5

Diversity Factor 1.1813
Power Factor 0.9110

Number of Bank a 289
Number of Substation b 135
Ratio a/b 2.1407

1.1817
0.9120

302
139
2.1727

Appendix 6.3.4 Load and Installed Capacity of Distribution Substations (JICA Study Team Plan, Planning Year = 1997 - 2001)

No	ABB	Substation	Voltage (KV)	2000				2001						
				Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	Bank configuration	Capacity (MVA)	coincident (MW)	non-coinci (MVA)	utilization factor (%)	
181	LS	Lumpashe	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
182	NI	Nimitrai	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
183	NY	Kangrai	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
184	JL	Prinkhao	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
185	PH	Pongpetch	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
186	PT	Puttanonton	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
187	RO	Rajchakru	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
188	RR	Rajdamri	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
189	AT	Satorntai	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
190	TL	Talingchan	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
191	TX	Tianruamit	115-24	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
192	RN	Tribit	69-12	X	0	0.00	0.00	0.00	0.00	X	0	0.00	0.00	0.00
Total					15.405	7.131.03	9.213.01	69.0		17.545	7.664.89	9.916.55	56.3	

Diversity Factor 1.1825
Power Factor 0.9140


1.1821
0.9120

Number of Bank 311
Number of Substation 151
Ratio a/b 2.2583


318
144
2.2083



APPENDIX
for
CHAPTER 9



Appendix 9.3-1



Model of Feeder Rising Point (In case of 200m mesh)

No of Feeder	Length of UG Cable
1	75 m
2	150 m
3	275 m
4	400 m
5	625 m
6	850 m
7	1,125 m
8	1,400 m
9	1,825 m
10	2,250 m
11	2,725 m
12	3,200 m
13	3,825 m
14	4,450 m
15	5,125 m
16	5,800 m
17	6,625 m
18	7,450 m
19	8,325 m
20	9,200 m
21	10,225 m
22	11,250 m
23	12,325 m
24	13,400 m
25	14,625 m
26	15,850 m
27	17,125 m
28	18,400 m
29	19,825 m
30	21,250 m
31	22,725 m
32	24,200 m

Supply Area of Substation (In case of 200m mesh)

Density (MVA/sq. km)	Supply Area (sq. km)				Supply Reach (km)				Total Feeder Length (km)			
	3×40	4×40	3×60	3×80	3×40	4×40	3×60	3×80	3×40	4×40	3×60	3×80
1	96.00	128.00	144.00	192.00	5.53	6.38	6.77	7.82	940.60	1,267.14	1,416.00	1,912.18
2	48.00	64.00	72.00	96.00	3.91	4.51	4.79	5.53	471.12	624.00	712.76	940.60
3	32.00	42.67	48.00	64.00	3.19	3.69	3.91	4.51	316.78	418.06	471.12	624.00
4	24.00	32.00	36.00	48.00	2.76	3.19	3.39	3.91	235.15	316.78	348.00	471.12
5	19.20	25.60	28.80	38.40	2.47	2.85	3.03	3.50	184.03	252.98	279.06	371.81
6	16.00	21.33	24.00	32.00	2.26	2.61	2.76	3.19	152.00	212.45	235.15	316.78
7	13.71	18.29	20.57	27.43	2.09	2.41	2.56	2.95	133.30	179.62	199.56	272.34
8	12.00	16.00	18.00	24.00	1.95	2.26	2.39	2.76	117.78	152.00	178.19	235.15
9	10.67	14.22	16.00	21.33	1.84	2.13	2.26	2.61	104.53	135.75	152.00	212.45
10	9.60	12.80	14.40	19.20	1.75	2.02	2.14	2.47	92.95	121.64	136.61	184.03
15	6.40	8.53	9.60	12.80	1.43	1.65	1.75	2.02	60.72	81.78	92.95	121.64
20	4.80	6.40	7.20	9.60	1.24	1.43	1.51	1.75	43.82	60.72	69.77	92.95
25	3.84	5.12	5.76	7.68	1.11	1.28	1.35	1.56	35.27	49.78	52.80	72.05
30	3.20	4.27	4.80	6.40	1.01	1.17	1.24	1.43	28.62	41.33	43.82	60.72
35	2.74	3.66	4.11	5.49	0.93	1.08	1.14	1.32	26.48	34.44	40.55	51.55
40	2.40	3.20	3.60	4.80	0.87	1.01	1.07	1.24	21.69	28.62	34.15	43.82
45	2.13	2.84	3.20	4.27	0.82	0.95	1.01	1.17	20.43	26.96	28.62	41.33
50	1.92	2.56	2.88	3.84	0.78	0.90	0.96	1.11	16.63	22.40	27.15	35.27
55	1.75	2.33	2.62	3.49	0.75	0.86	0.91	1.05	15.87	21.37	25.90	33.63
60	1.60	2.13	2.40	3.20	0.71	0.82	0.87	1.01	15.18	20.43	21.69	28.62
65	1.48	1.97	2.22	2.95	0.69	0.79	0.84	0.97	14.60	19.65	20.86	27.48
70	1.37	1.83	2.06	2.74	0.66	0.76	0.81	0.93	11.70	16.23	20.09	26.48
75	1.28	1.71	1.92	2.56	0.64	0.74	0.78	0.90	11.31	15.69	16.63	22.40
80	1.20	1.60	1.80	2.40	0.62	0.71	0.76	0.87	10.95	15.18	16.10	21.69
85	1.13	1.51	1.69	2.26	0.60	0.69	0.73	0.85	10.63	14.75	15.60	21.05
90	1.07	1.42	1.60	2.13	0.58	0.67	0.71	0.82	10.34	11.92	15.18	20.43
95	1.01	1.35	1.52	2.02	0.57	0.65	0.69	0.80	10.05	11.62	14.79	19.90
100	0.96	1.28	1.44	1.92	0.55	0.64	0.68	0.78	7.84	11.31	12.00	16.63
105	0.91	1.22	1.37	1.83	0.54	0.62	0.66	0.76	7.63	11.05	11.70	16.23
110	0.87	1.18	1.31	1.75	0.53	0.61	0.65	0.75	7.46	10.77	11.45	15.87
115	0.83	1.11	1.25	1.67	0.52	0.60	0.63	0.73	7.29	10.54	11.18	15.51
120	0.80	1.07	1.20	1.60	0.50	0.58	0.62	0.71	7.16	10.34	10.95	15.18
125	0.77	1.02	1.15	1.54	0.49	0.57	0.61	0.70	7.02	10.10	10.72	14.89
130	0.74	0.98	1.11	1.48	0.48	0.56	0.59	0.69	6.88	7.92	10.54	14.60
135	0.71	0.95	1.07	1.42	0.48	0.55	0.58	0.67	6.74	7.80	10.34	11.92
140	0.69	0.91	1.03	1.37	0.47	0.54	0.57	0.66	6.65	7.63	10.15	11.70
145	0.66	0.88	0.99	1.32	0.46	0.53	0.56	0.65	6.50	7.50	7.96	11.49
150	0.64	0.85	0.96	1.28	0.45	0.52	0.55	0.64	4.80	7.38	7.84	11.31
155	0.62	0.83	0.93	1.24	0.44	0.51	0.54	0.63	4.72	7.29	7.71	11.14
160	0.60	0.80	0.90	1.20	0.44	0.50	0.54	0.62	4.65	7.16	7.59	10.95
165	0.58	0.78	0.87	1.16	0.43	0.50	0.53	0.61	4.57	7.07	7.46	10.77
170	0.56	0.75	0.85	1.13	0.42	0.49	0.52	0.60	4.49	6.93	7.38	10.63
175	0.55	0.73	0.82	1.10	0.42	0.48	0.51	0.59	4.45	6.84	7.24	10.49
180	0.53	0.71	0.80	1.07	0.41	0.48	0.50	0.58	4.37	6.74	7.16	10.34
185	0.52	0.69	0.78	1.04	0.41	0.47	0.50	0.57	4.33	6.65	7.07	10.20
190	0.51	0.67	0.76	1.01	0.40	0.46	0.49	0.57	4.28	6.55	6.97	10.05
195	0.49	0.66	0.74	0.98	0.40	0.46	0.48	0.56	4.20	6.50	6.88	7.92
200	0.48	0.64	0.72	0.96	0.39	0.45	0.48	0.55	4.16	4.80	6.79	7.84
205	0.47	0.62	0.70	0.94	0.39	0.45	0.47	0.55	4.11	4.72	6.69	7.76
210	0.46	0.61	0.69	0.91	0.38	0.44	0.47	0.54	4.07	4.69	6.65	7.63
215	0.45	0.60	0.67	0.89	0.38	0.44	0.46	0.53	4.02	4.65	6.55	7.55
220	0.44	0.58	0.65	0.87	0.37	0.43	0.46	0.53	3.98	4.57	6.45	7.46
225	0.43	0.57	0.64	0.85	0.37	0.43	0.45	0.52	3.93	4.53	4.80	7.38
230	0.42	0.56	0.63	0.83	0.36	0.42	0.45	0.52	3.89	4.49	4.76	7.29
235	0.41	0.54	0.61	0.82	0.36	0.42	0.44	0.51	3.84	4.41	4.69	7.24
240	0.40	0.53	0.60	0.80	0.36	0.41	0.44	0.50	3.79	4.37	4.65	7.16

Supply Reach : Length of Radius

Feeder Length : Road of 200m Mesh

Cost of Model Case (In case of 200m mesh)

Size of Conductor (sq. mm)	Bank Configuration	Capacity (MVA)	Maximum Loading (MVA)	Feeder Voltage (kV)	No. of Feeders (ckt)	UG Cable Length (m)	Overhead Length (km)	Unit Cost				Cost (Thousand Baht)			kVA Cost (Baht/kVA)
								Feeder GIS (thousand Baht)	UG Cable (Baht/m)	Overhead (Baht/m)	Feeder GIS	UG Cable	Overhead	Total	
185	3x40	120	96	12	3 x 5 = 15	5.125	10.95	8.700	3.960	2.880	18.640	20.900	31.540	70.480	734.2
				24	3 x 3 = 9	1.825	10.95	12.500	4.240	3.060	16.070	7.740	33.510	57.320	597.1
				36	3 x 2 = 6	850	10.95	17.500	5.460	3.230	15.000	4.640	35.370	55.010	573.0
	4x40	160	128	12	4 x 5 = 20	9.200	15.18	8.700	3.960	2.880	24.860	36.430	43.720	105.010	820.4
				24	4 x 3 = 12	3.200	15.18	12.500	4.240	3.060	21.430	13.570	46.450	81.450	636.3
				36	4 x 2 = 8	1.400	15.18	17.500	5.460	3.230	20.000	7.640	49.030	76.670	599.0
	3x60	180	144	12	3 x 8 = 24	13.400	16.10	8.700	3.960	2.880	29.630	53.060	46.370	129.260	897.6
				24	3 x 4 = 12	3.200	16.10	12.500	4.240	3.060	21.430	13.570	49.270	84.270	585.2
				36	3 x 3 = 9	1.825	16.10	17.500	5.460	3.230	22.500	9.960	52.000	84.460	586.5
	3x80	240	192	12	3 x 10 = 30	21.250	21.69	8.700	3.960	2.880	37.290	84.150	62.470	183.910	957.9
				24	3 x 5 = 15	5.125	21.69	12.500	4.240	3.060	26.790	21.730	66.370	114.890	598.4
				36	3 x 4 = 12	3.200	21.69	17.500	5.460	3.230	30.000	17.470	70.060	117.530	612.1
240	120	96	12	3 x 4 = 12	3.200	10.95	8.700	3.960	2.920	14.910	12.670	31.970	59.550	620.3	
			24	3 x 2 = 6	850	10.95	12.500	4.240	3.100	10.710	3.600	33.950	48.260	502.7	
			36	3 x 2 = 6	850	10.95	17.500	5.460	3.270	15.000	4.640	35.810	55.450	577.6	
4x40	160	128	12	4 x 4 = 16	5.800	15.18	8.700	3.960	2.920	19.890	22.970	44.330	87.190	681.2	
			24	4 x 2 = 8	1.400	15.18	12.500	4.240	3.100	14.290	5.940	47.060	57.290	525.7	
			36	4 x 2 = 8	1.400	15.18	17.500	5.460	3.270	20.000	7.640	49.640	77.280	603.8	
3x60	180	144	12	3 x 6 = 18	7.450	16.10	8.700	3.960	2.920	22.370	29.500	47.010	98.880	686.7	
			24	3 x 3 = 9	1.825	16.10	12.500	4.240	3.100	16.070	7.740	49.910	73.720	511.9	
			36	3 x 2 = 6	850	16.10	17.500	5.460	3.270	15.000	4.640	52.650	72.290	502.0	
3x80	240	192	12	3 x 8 = 24	13.400	21.69	8.700	3.960	2.920	29.630	53.060	63.330	146.220	761.6	
			24	3 x 4 = 12	3.200	21.69	12.500	4.240	3.100	21.430	13.570	67.240	102.240	532.5	
			36	3 x 3 = 9	1.825	21.69	17.500	5.460	3.270	22.500	9.960	70.930	103.390	538.5	

Appendix 9.3-2

Determining transformer capacity

Maximum power demand is assumed and network transformer capacity determined using the following equation:

It is necessary that in the event power to one circuit is cut off, power supply to the load be maintained continuously, without load restriction, using the remaining transformers in overload operation.

$$\text{Transformer capacity (kVA)} = \frac{P}{N-1} \times \frac{100}{\alpha}$$

P : Maximum power demand (kVA)

N : Number of receiving circuits (ckt)

α : Allowable transformer overload ratio (%)

Example


Maximum power demand : 3,300 kVA

Number of receiving circuits : 3 ckt

Allowable transformer overload ratio : 130 %

$$\text{Transformer capacity} = \frac{3,300}{3-1} \times \frac{100}{130} = 1,270 \text{ kVA}$$

In consideration of the future load increase as well as the standard rating of a transformer, the network transformer capacity should be 1,500 kVA.




1. Countermeasure for protecting regular network transformer from flooding

Since the entire manhole is predicted to be inundated, the regular network transformer is of a construction having a water tightness sufficient to withstand the water pressure at a water depth of 5 m so as to make the transformer free from inflow of water into its internal parts.

2. Countermeasure for protecting the manhole from flooding



To prevent inflow of water to manhole from the portion of duct as a countermeasure for protecting the manhole from flooding, a duct manhole water-proofing device and cut-off cover are applied.

Duct manhole water-proofing device



No	Designations
①	Packing
②	Waterproof admixture
③	Support fitting I
④	Support fitting II
⑤	Center fitting
⑥	Clamp metal
⑦	Support bolt
⑧	Clamp bolt
⑨	Waterproof cast iron pipe

Cut-off cover



Application example of duct manhole water-proofing device.

3. Countermeasure for drainage from manhole

The following equipment and devices are installed for draining puddles collected in manhole:

(1) Submarine pump

- Capacity : 0.75 kW
- Pipe diameter : 50 mm
- Pump capacity : 200 liter/min
- Total head : 10 m or over


The submarine pump should be designed to enable manual operation and automatic operation according to the water level relay.

(2) Catch basin

- Since a large amount of soil, sand and other foreign matter are contained in puddles, a screen for preventing inflow of suspended matter is installed in the catch basin to discharge only water into sewage pipe.
- The capacity of catch basin should be 0.2 m³ or over.

(3) Drain pipe

- The diameter of drain pipe should be 50 mm, and the pipe material be determined taking into account corrosion of the pipe.



Appendix 9.3-3 Examples of water-proofing countermeasures in regular network system

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.


Second section of faint, illegible text, appearing to be a list or a series of short paragraphs.





Text block on the right side of the page, containing several lines of illegible text.

Small block of text at the bottom left, possibly a footer or a reference note.


Final line of text at the bottom of the page, appearing to be a signature or a date.



- : Underground Cable
- : Overhead Line
- : Normally Close
- : Normally Open
- : Interconnecting Switch
- × : Disconnecting Switch



In Case of Interconnecting between Underground Line and Overhead Line (3-division 3-linkage system)



- : Underground Cable
- : Overhead Line
- : Section Switch
- : Interconnecting Switch
- : Section Switch

In Case of Mixture with Underground Line and Overhead Line (3-division 3-linkage system)

Appendix 9.3-4 Example of Basic Configuration as Mixture with Underground Line and Overhead Line

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy auditing of the accounts.

2. The second part of the document outlines the procedures for handling discrepancies. If there is a difference between the recorded amount and the actual amount received or paid, it is crucial to investigate the cause immediately. This could be due to a clerical error, a missing receipt, or a fraudulent transaction.

3. The third part of the document provides a detailed breakdown of the monthly financial statements. It includes a summary of income, expenses, and the resulting profit or loss for each month. This information is essential for understanding the overall financial performance of the business.

4. The fourth part of the document discusses the importance of regular financial reviews. It suggests that the accounts should be reviewed at least once a month to identify any potential issues early on. This proactive approach can help prevent small problems from becoming major financial setbacks.

5. The fifth part of the document provides a checklist of items to be included in the monthly financial statements. This checklist includes items such as bank statements, credit card statements, and receipts for all purchases and sales.

6. The sixth part of the document discusses the importance of maintaining a clear and organized filing system for all financial documents. This makes it easy to locate any document when needed, which is especially important during an audit or tax filing.

7. The seventh part of the document provides a summary of the key points discussed in the document. It reiterates the importance of accuracy, transparency, and regular reviews in maintaining the financial health of the business.

8. The eighth part of the document provides a list of resources for further information on financial management. This includes books, articles, and websites that provide additional insights into the subject.

9. The ninth part of the document provides a list of common financial mistakes to avoid. These include failing to record all transactions, not reconciling bank statements, and not paying taxes on time.

10. The tenth part of the document provides a list of questions to ask your accountant or financial advisor. These questions can help you get the most out of your professional relationship and ensure that your financial goals are being met.

11. The eleventh part of the document provides a list of financial ratios to calculate. These ratios, such as the current ratio and the debt-to-equity ratio, provide valuable insights into the financial health and stability of the business.

12. The twelfth part of the document provides a list of financial indicators to monitor. These indicators, such as the gross profit margin and the operating profit margin, can help you identify trends and make informed decisions about the future of the business.

13. The thirteenth part of the document provides a list of financial documents to keep. These documents, such as the balance sheet and the income statement, are essential for understanding the financial performance of the business.

14. The fourteenth part of the document provides a list of financial goals to set. These goals, such as increasing revenue and reducing expenses, can help you focus your efforts and achieve long-term success.

15. The fifteenth part of the document provides a list of financial tools to use. These tools, such as spreadsheets and accounting software, can help you manage your finances more effectively and efficiently.


16. The sixteenth part of the document provides a list of financial services to consider. These services, such as financial planning and investment management, can help you achieve your financial goals and secure your future.

17. The seventeenth part of the document provides a list of financial risks to avoid. These risks, such as over-investing and not diversifying, can lead to significant financial losses.

18. The eighteenth part of the document provides a list of financial opportunities to pursue. These opportunities, such as new markets and products, can help you grow your business and increase your revenue.

19. The nineteenth part of the document provides a list of financial challenges to overcome. These challenges, such as cash flow problems and high debt levels, can be overcome with the right strategies and solutions.


20. The twentieth part of the document provides a list of financial success stories. These stories, such as those of successful entrepreneurs and investors, can provide inspiration and motivation for your own financial journey.




Appendix 9.3-5 Basic Configuration of Low-voltage Underground Distribution Line

Main body of the document containing several paragraphs of text. The text is extremely faint and illegible due to low contrast and noise.








Appendix 9.3-6 Basic Combination of Underground Distribution Facilities

SEARCHED INDEXED
SERIALIZED FILED

APR 11 1964
FBI - MEMPHIS
COMMUNICATIONS SECTION

COMMUNICATIONS SECTION

[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and is not readable.]



Appendix 9.3-7

Time-delay Fault Detecting System

The time-delay fault detecting system designed to function in collaboration with the reclosing system in the substation is a kind of the time relay, which functions with time for detecting and eliminating the faulty section of the distribution line, and used in combination with the automatic switches installed on the distribution line.

Outline of Fault Detection

When the fault has occurred in the distribution line, the fault is detected by the relay in the substation to cause the circuit breaker for the distribution feeder line to be tripped, thereby the power supply is discontinued.

Then, after 60 seconds, the circuit breaker will be closed to resume the power supply.


When the power supply is resumed, the time-delay fault detector causes the automatic switches to be closed sequentially based on the X-time interval (time interval for closing).

When the power is supplied to the faulty section, the relay of the substation detects the fault again to cause the circuit breaker to be retripped.

At this point, the time-delay fault detector set to Y-time interval (time interval for detection) is closed and locked in order to prevent it from causing the automatic switch to be closed again.


Then, the circuit breaker will be closed again after 60 seconds from the retripping to energize all the sound sections preceding the faulty section which will be separated.

①




When the fault has occurred, the relay will be actuated to open the circuit breaker.

②




All the fault detecting relays are opened.

③




After 60 seconds, the power supply until automatic switch(I) will be resumed by reclosing the circuit breaker.

④




After 7 seconds, the automatic switch(I) is closed and the power supply is resumed until automatic switch (II).

⑤




After 7 seconds, the automatic switch(II) is closed and the power supply to the faulty point is resumed.

⑥




The relay is actuated to trip the circuit breaker.

⑦




All the fault detecting relays are opened, and the automatic switch(II) is locked.

⑧



After 60 seconds, the power supply until automatic switch(I) will be resumed by reclosing the circuit breaker.


⑨



After 7 seconds, the automatic switch (I) is closed and the power supply is resumed until automatic switch (II).

The automatic switch (II) is left opened, and the power supply to all the sound sections preceding the faulty section which will be separated.

- | | | |
|-------------------------|------------------------|-----------------------|
| ① Porcelain insulator | ⑩ Lower metal | ⑬ Earth terminal |
| ② Upper plate | ⑪ Flange | ⑭ Insulator |
| ③ Leading conductor | ⑫ Supporting insulator | ⑮ Spacer |
| ④ Shielding cover | ⑬ Protective casing | ⑯ Spacer |
| ⑤ Fixing plate | ⑭ Sealing metal | ⑰ Epoxy resin support |
| ⑥ Oil reservoir | ⑮ Sealing mold | ⑱ Stress relief corn |
| ⑦ Condenser corn | ⑯ Water proof tape | ⑲ Pressing pipe |
| ⑧ Reinforced insulation | ⑰ Insulating oil | ⑳ Spring Unit |
| ⑨ Support | ⑱ Shielding | |



Appendix 9.5-1 Terminal Joint for 230kV XLPE cable