


Case A When the available water is sufficient:

- A1 Combination with the 2nd Sabaki P/L
- A2 Combination with the 2nd Mzima P/L

Case B When the available water is not sufficient, the deficit will have to be supplemented by other reservoir or water source. Examples are as shown below and their conceptual figures are presented in the attached sheet:


- B1 Combination with Rare reservoir plus Rare P/L
(deficit is supplied by Rare reservoir)
- B2 Combination with 2nd Mzima P/L plus Tsavo reservoir
(deficit is supplied by Tsavo reservoir)
- B3 Combination with 2nd Sabaki P/L plus Tsavo reservoir
(deficit is supplied by Tsavo reservoir)

There might be other means of supplementing the deficit such as the combination with other water sources like local rivers and/or groundwater. Situation being as such, a thorough study will be needed in future to select the best plan. In this connection, the selected plans in this study should be retained as those to represent the objective situations as of present. Reconsideration will have to be performed newly under the new situation with the water resources development on the Athi River added.



EXAMPLES OF CONCEIVABLE PLANS WITH MUNYU SCHEME

ORGANIZATION CHART OF WATER ENGINEERING DEPARTMENT IN THE MINISTRY OF WATER DEVELOPMENT



PROVINCIAL ORGANIZATIONS!
 Note: The above chart shows the organization chart as of August 1980
 Source: Water Engineering Department
 ORS No. PSD/129

EXISTING BULK WATER SUPPLY SOURCES

<u>Descriptions</u>	<u>(1) Marere Springs</u>	<u>(2) Pemba Intake</u>	<u>(3) Mzima Springs</u>
1. Type of Source	Spring	Pemba River	Spring
2. Time of Construction	1916	1973	1952-56
3. Design Capacity	2,500 m ³ /day	6,540 m ³ /day	36,000 m ³ /day
4. Time of Expansion	(1) 1930's (2) 1950's	1979	
5. Expanded Capacity	(1) 10,500 m ³ /day (2) 13,500 m ³ /day	-	-
6. Facilities			
a) Intake pumps	-	2 pumps	-
b) Transmission pumps	-	3 pumps (Booster pumps for filters)	-
c) Treatment Facilities	Sedimentation basins and Chlorination equipment	Sedimentation basins, filters & chlorination equipment	Chlorination facility (not used now)
d) Power	-	Fuel Engine	-
7. Estimated Production Capacity	10,000 m ³ /day	2,000 m ³ /day	36,000 m ³ /day
8. Others			Potential intake capacity: 72,000 m ³ /day

EXISTING BULK WATER SUPPLY SOURCES (CONTINUED)

Description (4) Tiwi B.H. No 1 (5) Tiwi B.H. No 2 (6) Tiwi B.H. No 4 (7) Malindi Intake


1. Type of Source	Ground Water	Ground Water	Ground Water	Sabaki River
2. Time of Construction	-	-	-	1961
3. Design Capacity	45 m ³ /hr.	67.5 m ³ /hr.	80 m ³ /hr.	1,800 m ³ /day
4. Time of Expansion	1976	1979-80	1979	1970's
5. Expanded Capacity	-	-	-	2,000 m ³ /day
6. Facilities				
a) Intake pumps	Submersible pump	Submersible pump	Submersible pump	2 pumps
b) Transmission pumps	-	-	-	2 pumps
c) Treatment Facilities	Chlorination equipment	Chlorination equipment	Chlorination equipment	Presettling basins, sedimentation basins, filters and chlorination facilities.
d) Power	Electricity	Electricity	Electricity	Electricity
7. Estimated Production Capacity	2,000 m ³ /day	1,200 m ³ /day	1,700 m ³ /day	2,200 m ³ /day
8. Others				

EXISTING BULK WATER SUPPLY FACILITIES


Facilities	(1) Marere Pipeline	(2) Mzima Pipeline	(3) Pemba Water Works	(4) Mazaras-Jaribuni Pipeline
1. Spring Intake	Mazere Springs	Mzima Springs	-	-
2. River Intake	-	-	Pemba River Intake	-
3. Boreholes	-	-	-	-
4. Treatment Plant	Sedimentation, laminating chamber & chlorination facility.	Chlorination facility.	Sedimentation basins, filters & chlorination facility.	-
5. Transmission Main	D300mm-D250mm: 4.2km	D530mm-D760mm: 219 km	Connection to Marere Pipeline	D200mm-D180mm: 50 km
6. Booster Pumping Station	Mile 8 booster pumping station	-	-	Mazaras booster pumping station
7. Reservoirs	Changamwe & Kaya Bombo reservoirs: 29,600 m ³ & 1,100 m ³	Mazaras reservoirs: 61,000 m ³	-	Ribe, Kaloieni & Ditzoni reservoirs: 450 m ³ x 3nos. Jaribuni Water Tank: 45 m ³
8. Others	-	10 Break pressure tanks on Mzima Pipeline	Intake pumps & high lift pumps for filters	-

EXISTING WATER SUPPLY FACILITIES (CONTINUED)

Facilities	(5) North Mainland Pipeline	(6) Marexe Kaya Bombo Pipeline	(7) Tiwi Boreholes	(8) Malindi Pipeline
1. Spring Intake	-	-	-	-
2. River Intake	-	-	-	Sabaki River Intake
3. Boreholes	-	-	No. 1, 2, 3, & 4 Boreholes with pumps	2 Boreholes in Ganda with pumps
4. Treatment Plant	-	-	Chlorination facilities	Presettling basins, sedimentation basins, filters & chlorination facilities
5. Transmission Main	D250mm 19 Km	D200mm-D150mm 10 Km	D200mm	D300mm-D100mm
6. Booster Pumping Station	-	-	-	Malindi T. Plant booster pumps
7. Reservoirs	Nguu Tatu reservoirs: 4,550 m ³ and 18,000 m ³	Kaya Bombo reservoir: 1,100 m ³	Tiwi water tank: 2,200 m ³	Garalani reservoirs: 1,135 m ³ & Ganda reservoirs: 1,600 m ³
8. Others	-	-	-	-



- INDEX**
- SPRING INTAKE
 - ◡ SURFACE INTAKE
 - TREATMENT PLANT
 - ⊕ BOREHOLES
 - ▽ PUMPING STATION
 - PIPELINE
 - STORAGE RESERVOIRS
 - B.P.T.
 - URBAN WATER SUPPLY
 - RURAL WATER SUPPLY
 - ▨ PROJECT AREA
 - SABAKI PIPELINE
 - - - INTERNATIONAL BOUNDARY
 - · - · - DISTRICT BOUNDARY



EXISTING WATER SUPPLIES AND MAJOR WATER SUPPLY FACILITIES

40°E

39°E

38°E

3°S

4°S

SEE ENLARGED MAP

MOMBASA WATER SUPPLY
ANNUAL AVERAGE DAILY WATER DELIVERED

Unit: m³/day

<u>WATER SUPPLY ZONE</u>	<u>1977</u>	<u>1978</u>	<u>1979</u>	<u>6th February 1980</u>
Mombasa Island	20,335	22,781	23,632	24,670
North Mainland	4,800	5,663	5,400	6,332
South Mainland	2,634	2,909	3,300 ⁽¹⁾	3,780
West Mainland	8,393	8,971	9,300	11,230
Sokoke/Kilifi	748	714	946	1,211
Marere Pipeline in route	2,158	2,144	2,568	2,568
Subtotal	39,068	43,182	45,146	49,801
Consumers in route				
Mzima Pipeline	2,929	3,225	2,865 ⁽¹⁾	4,328
TOTAL	41,997	46,407	48,011	54,129

Remarks: (1) Extrapolated figures.

MOMBASA WATER SUPPLY
WATER AVAILABLE OR PRODUCED

Unit: m³/day

<u>Water Supply Source</u>	<u>1977</u>	<u>1978</u>	<u>1979</u>	<u>6th February 1980</u>
Mzima at Mazeras	32,036	32,884	33,636	32,181
Marere Headwork	8,536	10,067	10,975	10,800
Pemba Treatment Plant	947	696	NIL (1)	2,195
South Coast Boreholes + NM Wells	1,700	1,768	1,578	3,611
Subtotal	43,219	45,415	46,189	48,787
Available/Consumers in route Mzima PL.	2,929	3,225	2,865	4,328
TOTAL	46,148	48,640	49,054	53,115

Remarks: (1 Plant stopped due to dam construction.

Source: Statistic Unit
Chief Operation & Maintenance Engineer
D & M Division
Coast Province Water Branch

PRESENT CONSUMERS BY WATER USE CATEGORIES

Name of Water Supply	Class								Total
	1	2	3	4	5	6	7	8	
1. Kilifi	304	0	0	21	0	45	0	0	370 nos
	82	0	0	6	0	12	0	0	100 (%)
2. Tezo Roka	193	0	0	31	0	3	0	0	227
	85	0	0	14	0	1	0	0	100
3. Kaloleni	222	0	0	11	0	19	0	0	252
	88	0	0	4	0	8	0	0	100
4. Malindi	1672	0	0	42	0	74	3	10	1809
	92	0	0	2	0	4	0	1	100
5. Gede Watamu	218	1	0	21	2	18	30	4	294
	74	0	0	7	1	16	10	1	100
6. Voi	514	0	0	4	3	9	0	0	530
	97	0	0	1	1	2	0	0	100
7. Wundanyi	275	5	0	2	0	2	0	0	284
	97	2	0	1	0	1	0	0	100
8. Mwajika-Teri	25	0	0	0	0	0	0	0	25
	100	0	0	0	0	0	0	0	100
9. Dembwa	59	0	0	3	0	0	0	0	62
	95	0	0	5	0	0	0	0	100
10. Mazeras-Rabai	109	25	13	13	5	11	7	0	183
	60	14	7	7	3	6	4	0	100
11. Mariakani	257	10	0	8	2	10	13	0	300
	86	3	0	3	1	3	4	0	100
12. Mackinnon Road	8	0	0	2	0	0	0	0	10
	80	0	0	20	0	0	0	0	100
13. Kwale	145	0	0	4	0	33	0	0	182
	80	0	0	2	0	18	0	0	100
14. Hsambweni	43	0	0	2	7	13	8	0	67
	64	0	0	3	1	19	12	0	100
15. Kinango	52	0	0	11	0	10	0	0	73
	71	0	0	15	0	14	0	0	100
16. South Mainland	685	153	91	43	9	51	49	5	1,086
	63	14	8	4	1	5	5	0	100
17. North Mainland	1781	104	36	71	16	38	44	14	2104
	85	5	2	3	1	2	2	1	100
18. Mombasa Island	9788	1333	1814	1191	368	425	22	1	14942
	66	9	12	8	2	3	0	0	100
19. West Mainland	1911	84	307	134	107	69	67	0	2679
	71	3	11	5	4	3	3	0	100
Total	19421	1715	1161	1659	513	898	245	42	26755 nos.
	73	6	8	6	2	3	1	0	100 (%)

- Remarks: (1) Upper figures show numbers of service connection.
(2) Lower figures show ratio in percentage to the total.
(3) Number of class stands for following categories:
- 1: Single family
 - 2: Multiple
 - 3: Flats
 - 4: Commercial
 - 5: Industrial
 - 6: Institution
 - 7: Kiosks
 - 8: Beach hotels

Source: CPWB Office, data of February, 1979.

LEAKAGE AND LOSSES


Unit: m³/day

	<u>1977</u>	<u>1978</u>	<u>1979</u>
1. Water Available or Produced	46,148	48,640	49,054
2. Annual Average Daily Water Delivered	41,997	46,407	48,011
3. Balance/Leakage and Losses	4,151	2,233	1,043
4. Percentage of Total Production	9.0%	4.6%	2.1%

Source: Statistic Unit.

Chief Operations and Maintenance
Engineer.

Design and Maintenance Division,
Coast Province Water Branch.



ANNEX 2309

SEWAGE
TREATMENT PLANT (T/P)



STORM WATER DRAINAGE
DRAINED AREA

EXISTING WASTE WATER SYSTEM
IN MOMBASA

2
Km

P O R T T U D O R

P O R T T U D O R

M O M B A S A

M O M B A S A I S L A N D

M O M B A S A I S L A N D

P C

K I L I N D I N I

M T O N G W A N I

T Z

M I W A N D O N I

I N D A

L i k e n i

L R 444

Ros Avenue

30

N

1

0

1

2

Km

Ros Mkwangumba

Ros Mkwangumba

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

M O M B A S A I S L A N D

HISTORICAL CENSUS POPULATION OF COAST PROVINCE

	1962		1969		1979	
	Population (10 ⁵)	% to Nation	Population (10 ⁵)	% to Nation	Population (10 ⁵)	% to Nation
Total Kenya	5,636	100	10,943	100	15,322	100
Coast Province	727	8.42	943	8.62	1,339	8.74
<u>Project Area</u>	625	7.24	815	7.45	1,123	7.33
Kilifi District	212	2.45	266	2.43	372	2.42
Southern Division	(94)	(1.08)	(113)	(1.03)	(151)	(0.99)
Northern Division	(36)	(0.44)	(47)	(0.43)	(64)	(0.42)
Central Division	(43)	(0.50)	(57)	(0.52)	(95)	(0.55)
Nalindia Division	(37)	(0.43)	(49)	(0.45)	(72)	(0.47)
Gede Location	(5)		(11)		(17)	
Ganda Location	(27)		(31)		(44)	
Ujiore Location	(5)		(7)		(10)	
Kwale District	156	1.83	206	1.88	287	1.87
Mombasa District	180	2.08	247	2.26	342	2.23
Taita Taveta District	75	0.87	96	0.88	123	0.80
Voi Division	(19)	(0.22)	(30)	(0.27)	(38)	(0.25)
Mundanyi Division	(56)	(0.65)	(66)	(0.60)	(85)	(0.55)

	1962		1969		1979	
	Population (10 ³)	% to Nation	Population (10 ³)	% to Nation	Population (10 ³)	% to Nation
<u>Non-Project Area</u>	104	1.20	130	1.19	216	1.44
<u>Kilifi District</u>						
Malindi Division	36	0.42	42	0.38	57	0.37
<u>Taita-Taveta District</u>						
Taveta Division	15	0.17	15	0.14	25	0.16
<u>Lamu District</u>	23	0.27	22	0.20	42	0.27
<u>Tana River District</u>	30	0.35	51	0.47	92	0.60

Source: Population Census

N.B. Administrative boundary change was adjusted to that of 1979 Population Census based on information of Central Bureau of Statistics.


PROJECTED POPULATION OF COAST PROVINCE
AS PERCENTAGE OF NATION POPULATION

Unit: %

	Historical	Projected				
	1979	1980	1985	1990	1995	2000
Coast Province	8.72	8.74	8.83	8.89	8.94	8.96
<u>Project Area</u>	<u>7.32</u>	<u>7.33</u>	<u>7.38</u>	<u>7.42</u>	<u>7.46</u>	<u>7.50</u>
Kilifi District ⁽¹⁾	2.42	2.42	2.44	2.45	2.47	2.48
Kwale District	1.87	1.87	1.88	1.89	1.89	1.90
Mombasa District ⁽²⁾	2.23	2.24	2.26	2.28	2.30	2.32
Taita-Taveta District	0.80	0.80	0.80	0.80	0.80	0.80
<u>Non Project Area</u>	<u>1.40</u>	<u>1.41</u>	<u>1.45</u>	<u>1.47</u>	<u>1.48</u>	<u>1.46</u>
Kilifi District	0.37	0.37	0.36	0.34	0.33	0.31
Taita-Taveta District	0.16	0.16	0.16	0.16	0.16	0.16
Ilemu District	0.27	0.27	0.27	0.27	0.27	0.27
Tana River District	0.60	0.61	0.66	0.70	0.72	0.72

Remarks: (1) Excluding Malindi Division of northern bank of the Sabaki River

(2) Excluding Taveta Division



PROJECTED POPULATION OF PROJECT AREA
AS PERCENTAGE OF NATION POPULATION

PROJECTED POPULATION OF THE PROJECT AREA BY DISTRICT

Unit: 10³

	Historical	Projected				
	1979	1980	1985	1990	1995	2000
A. Project Area						
Kilifi District ⁽¹⁾	371	382	457	542	646	765
Kwale "	287	296	352	418	494	587
Mombasa "	342	355	423	505	601	716
Taita-Taveta District ⁽²⁾	123	128	150	177	209	247
Total	1,123	1,161	1,382	1,642	1,950	2,315
B. Non-Project Area						
Kilifi District	57	59	67	75	86	96
Taita Taveta District	25	25	30	35	42	49
Lamu District	42	43	51	60	71	83
Tana River District	92	97	124	156	189	223
Total	216	224	272	326	388	451
C. Coast Province						
Total	1,339	1,385	1,654	1,968	2,338	2,766

Remarks: (1) Including Malindi division of southern bank of the Sabaki River

(2) Excluding Taveta Division

HISTORICAL POPULATION OF URBAN CENTRES

	1962		1969		1979	
	Population	% to Province	Population	% to Province	Population	% to Province
Coast Province	727,844	100	944,082	100	1,339,000	100
Malindi	5,818	0.80	10,757	1.14	23,306	1.74
Voi	2,533	0.35	5,313	0.56	7,329	0.55
Kilifi	2,081	0.29	2,662	0.28	5,861	0.44
Mariakani	1,454	0.20	3,956	0.42	2,853	0.21
Wundanyi	3,717	0.51	4,385	0.46	6,075	0.45
Kwale	1,008	0.14	1,092	0.12	2,193	0.16
Kinango	1,599	0.22	2,450	0.26	3,647	0.27
Total	18,210	2.51	30,615	3.24	51,264	3.82

PROJECTED POPULATION OF URBAN CENTRES


	Historical	Projected				
	1979	1980	1985	1990	1995	2000
<u>Coast Province</u>						
Population (10 ³)	1,339	1,385	1,654	1,968	2,338	2,766
% to Nation (%)	8.72	8.74	8.83	8.89	8.94	8.96
<u>Urban Centers (1)</u>						
Population (10 ³)	51.3	53.6	67.8	84.6	105.0	128.4
% to Province (%)	3.82	3.87	4.10	4.30	4.49	4.64

Remarks: (1) Total of seven urban centres i.e. Malindi, Voi, Kilifi, Kariakani, Kundanyi, Kwale and Kinango

HISTORICAL AND PROJECTED POPULATION OF PROJECT AREA
MEDIUM GROWTH PROJECTION (ADOPTED)

Year	XOMBASA			URBAN CENTER			RURAL			TOTAL PROJECT AREA		
	% to Nation	Population (10 ³)	Growth % to Province Rate	(%)	(10 ³)	Growth % to Nation Rate	(%)	(10 ³)	Growth % to Nation Rate	(%)	Population (10 ³)	% to Nation
<u>Historical</u>												
1962	2.08	180	-	2.52	18	-	0.21	427	-	4.94	625	7.24
1969	2.26	247	4.62	3.24	31	7.70	0.28	537	3.33	4.91	815	7.45
1979	2.23	342	3.32	3.82	52	5.29	0.33	730	3.12	4.76	1,123	7.32
<u>Projected</u>												
1980	2.24	355	3.80	3.87	54	4.54	0.34	752	3.01	4.75	1,161	7.33
1985	2.26	423	3.57	4.10	68	4.82	0.36	891	3.45	4.76	1,382	7.38
1990	2.28	505	3.61	4.30	85	4.53	0.38	1,052	3.38	4.75	1,642	7.41
1995	2.30	601	3.54	4.49	105	4.40	0.40	1,244	3.41	4.76	1,950	7.46
2000	2.32	716	3.56	4.64	128	4.11	0.41	1,471	3.41	4.76	2,315	7.49

Growth (1979-2000) 3.58% p.a. 4.48% p.a. 3.39% p.a. 3.50% p.a.



HISTORICAL AND PROJECTED POPULATION
OF THE PROJECT AREA

POPULATION PROJECTION OF PROJECT AREA
(HIGH AND LOW GROWTH)

Unit: 10 ³					
1. Nation Population					
	<u>1980</u>	<u>1985</u>	<u>1990</u>	<u>1995</u>	<u>2000</u>
A. High Projection ⁽¹⁾	15,880	19,100	23,050	27,910	33,930
B. Medium " "	15,850	18,730	22,140	26,150	30,870
C. Low " " ⁽²⁾	15,840	18,580	21,560	24,730	28,060
2. Population of Project Area					
	<u>1980</u>	<u>1985</u>	<u>1990</u>	<u>1995</u>	<u>2000</u>
% To Nation (%)					
Mombasa	2.24	2.26	2.28	2.30	2.32
Other Urban Area	0.34	0.36	0.38	0.40	0.41
Rural Area	4.75	4.76	4.75	4.76	4.76
Project Area Total	7.33	7.38	7.41	7.46	7.49
A. High Projection					
Mombasa	356	432	526	642	787
Other Urban Area	54	69	88	112	139
Rural Area	754	909	1,095	1,329	1,615
Project Area Total	1,164	1,410	1,709	2,083	2,541
B. Medium Projection					
Mombasa	355	423	505	601	716
Other Urban Area	54	67	84	105	127
Rural Area	753	892	1,052	1,245	1,469
Project Area Total	1,162	1,382	1,641	1,951	2,312
C. Low Projection					
Mombasa	355	420	492	569	651
Other Urban Area	54	67	82	99	115
Rural Area	752	884	1,024	1,177	1,336
Project Area Total	1,161	1,371	1,598	1,845	2,102

Remarks: ⁽¹⁾ Based on Case A projection made by Central Bureau of Statistics, June, 1971

⁽²⁾ Based on Case B projection of the above

HOTELS AND BEDS AVAILABLE BY AREA

	1976		1977		1978	
	No. of Hotels	Beds Available (10 ³)	No. of Hotels	Beds Available (10 ³)	No. of Hotels	Beds Available (10 ³)
1. Beach						
South	14	552.6	14	590.9	14	695.4
North Mombasa	16	945.2	16	992.4	15	1,045.9
Kilifi/Watamu	7	310.8	7	299.8	7	346.9
Malindi/Lamu	11	393.8	12	285.3	15	435.2
Sub-total	48	2,202.5	49	2,268.3	51	2,523.4
2. Mombasa Island	30	506.7	30	509.9	33	531.4
3. Coast Hinterland						
East	5	84.2	4	80.5	5	90.8
West	6	189.8	6	184.3	6	179.8
Sub-total	11	274.0	10	264.8	11	270.6
Total	89	2,983.2	89	3,043.0	95	3,325.4
cf. Total Kenya	228	6,983.1	227	7,028.3	272	7,358.0

HISTORICAL AND PROJECTED HOTEL-BEDS OCCUPIED IN COASTAL AREA

Unit: 10³ night-bed

Year	Hotel Night-beds	Growth (%)	Mombasa	Kilifi/Watamu	Malindi/Lamu
<u>Historical</u>					
1968	508.2	-			
1969	569.0	12.0			
1970	696.7	22.4			
1971	815.4	17.0			
1972	923.9	14.4			
1973	1,008.4	8.1	739.9	122.0	146.5
1974	1,173.6	16.4	868.4	148.3	156.9
1975	1,371.6	16.9	1,051.4	146.6	173.6
1976	1,575.2	14.8	1,242.9	148.6	183.6
1977	1,778.6	12.9	1,415.6	167.8	195.1
1978	1,908.4	7.3	1,508.1	174.7	225.7
1979	2,111.1	10.6			

Growth (1968-79) 13.8% p.a.


Growth (1973-78) 13.6% p.a. 15.3% p.a. 7.4% p.a. 9.0% p.a.

Projected

1980	2,331.4	10.4
1985	3,152.2	6.2
1990	3,632.9	2.9
1995	3,853.7	1.2
2000	3,943.7	0.5

Growth (1979-2000) 3.0% p.a.

N.B. Coastal Area Covers: Mombasa Island, North Mainland, South Mainland
Malindi/Lamu and Kilifi/Watamu



Historical and Projected Trend of Night-Beds of Tourists in Coastal Area

WATER DEMAND PROJECTION OF DOMESTIC USE
IN MOMBASA AND URBAN CENTRES

1. Estimate of Income Group Composition

1.1 Weighting Factor by Income Group

<u>Income Group</u>	<u>1972 KSh/Month</u>	<u>Group Average</u>	<u>Weighting Factors</u>
High income	6,000 +	8,500	0.644
Medium "	2,000 - 6,000	3,500	0.265
Low "	0 - 2,000	1,200	0.091
		13,200	1.000

1.2 Estimated Income

<u>1979</u>			
<u>Income Group</u>	<u>% of Population</u>	<u>Weighting Factors</u>	<u>Total Average Income (Index)</u>
High income	5%	0.644	3.220
Medium "	45	0.265	11.925
Low "	50	0.091	4.550
	100	1.000	19.695

Mombasa Income Total: 19.695×0.342 mil. person = 6.736

<u>2000</u>			
<u>Income Group</u>	<u>% of Population</u>	<u>Weighting Factors</u>	<u>Total Average Income (Index)</u>
High income	10%	0.644	6.440
Medium "	80	0.265	21.200
Low "	10	0.091	0.910
	100	1.000	28.550

Mombasa Income Total: 28.550×0.716 mil. person = 20.442

Growth rate of Mombasa Income in 1979-2000 : 5.43% p.a.

2. Estimate of Daily Per capita Domestic Use

1979

<u>Income Group</u>	<u>% of Population</u>	<u>Per cap. Demand</u> (1)	<u>Average Demand</u>
High income	5%	200 lpcd	10
Medium "	45	100	45
Low "	50	50	25
		100	80 lpcd

(1 Based on "MOWD Design Manual"

Daily maximum demand inclusive of loss and leakage:

High cost housing : 300 lpcd

Medium " " : 150

Low " " : 75

Assuming daily maximum demand being 50% more than annual average demand.

2000

<u>Income Group</u>	<u>% of Population</u>	<u>Per cap. Demand</u>	<u>Average Demand</u>
High income	10 %	240 lpcd	24
Medium "	80	120	96
Low "	10	60	6
		100	126 lpcd

WATER DEMAND BY USE IN MOMBASA IN 1979

(Estimated based on CPWB data)

Unit: CMD

<u>Location</u>	<u>Domestic</u>	<u>Industrial</u>	<u>Tourism</u>	<u>Commercial Public & Others</u>	<u>Total</u>
Mombasa Island	17,490	1,180	-	4,960	23,630
North Mainland	3,560	110	430	1,300	5,400
South Mainland	1,420	30	760	1,090	3,300
West Mainland	2,230	3,350	-	3,720	9,300
Total	24,700	4,670	1,190	11,070	41,630
% to Total	(59)	(11)	(3)	(27)	(100)
Per capita (lpcd)	72	14	3	32	122

WATER DEMAND PROJECTION BY USE OF CATEGORIES

1. Domestic Demand

Unit: CMD

<u>Year</u>	<u>Mombasa</u>	<u>Urban</u>	<u>Rural</u>	<u>Total</u>
<u>Present Potential</u>				
1979	27,360	4,080	18,980	50,420
<u>Projected</u>				
1980	29,110	4,430	20,300	53,840
1985	38,490	6,190	27,620	72,300
1990	51,010	8,590	35,770	95,370
1995	67,910	11,870	48,520	128,300
2000	90,220	16,130	64,720	171,070

Growth (1979/2000)	5.85%	6.76%	6.00%	5.99%
--------------------	-------	-------	-------	-------

Per cap. (2000)	126 lpcd	126 lpcd	44 lpcd
-----------------	----------	----------	---------

2. Industrial Demand

<u>Year</u>	<u>Mombasa</u>	<u>Urban</u>	<u>Rural</u>	<u>Total</u>
1979	4,670	140	-	4,810
<u>Projected</u>				
1980	5,220	160	-	5,380
1985	9,100	270	-	9,370
1990	15,870	480	-	16,350
1995	27,660	830	-	28,490
2000	48,230	1,450	-	49,680

Growth (1979/2000)	12%	12%
--------------------	-----	-----

Per ha (2000)	24 m ³ /d.ha	16 m ³ /d.ha
---------------	-------------------------	-------------------------

3. Tourism Demand

Unit: CMD

<u>Year</u>	<u>Mombasa</u>	<u>Urban</u> ⁽¹⁾	<u>Rural</u>	<u>Total</u>
<u>Present Potential</u>				
1979	4,540	1,520	-	6,060
<u>Projected</u>				
1980	5,010	1,680	-	6,690
1985	6,780	2,270	-	9,050
1990	7,810	2,620	-	10,430
1995	8,290	2,780	-	11,070
2000	8,480	2,840	-	11,320

Growth (1979/2000) 3.02% 3.02% 3.02%

4. Commercial, Public and Other Demand

<u>Year</u>	<u>Mombasa</u>	<u>Urban</u>	<u>Rural</u>	<u>Total</u>
<u>Present Potential</u>				
(Including Livestock Use)				
1979	13,840	2,050	33,000	48,890
<u>Projected</u>				
1980	14,670	2,170	34,140	50,980
1985	19,630	2,900	39,250	61,780
1990	26,270	3,890	44,450	74,610
1995	35,160	5,200	51,330	91,690
2000	47,050	6,960	58,840	112,850

Growth (1979/2000) 6.00% 6.00% 2.80%

Remarks: ⁽¹⁾ Including Coast Hinterland of East and West

5. Total Water Demand Unit: CMD

<u>Year</u>	<u>Mombasa</u>	<u>Other Urban</u>	<u>Rural</u>	<u>Total</u>
<u>Present Potential</u>				
1979	50,410	7,790	51,980	110,180
<u>Projected</u>				
1980	54,010	8,440	54,440	116,890
1985	74,000	11,630	66,870	152,500
1990	100,960	15,580	80,220	196,760
1995	139,020	20,680	99,850	259,550
2000	193,980	27,380	123,560	344,920

Growth (1979/2000) 6.63% p.a. 6.17% p.a 4.2% p.a. 5.58% p.a.

Per cap. 2000 271 lpcd 214 lpcd 84 lpcd

6. Water Demand by Use

6.1 Mombasa


<u>Year</u>	<u>Domestic</u>	<u>Industrial</u>	<u>Tourism</u>	<u>C.P. & Others</u>	<u>Total</u>
1979	27,360 (54)	4,670 (9)	4,540 (9)	13,840 (28)	50,410 (100)
2000	90,220 (47)	48,230 (25)	8,480 (4)	47,050 (24)	193,980 (100)

6.2 Urban Centers

<u>Year</u>	<u>Domestic</u>	<u>Industrial</u>	<u>Tourism</u>	<u>C.P. & Others</u>	<u>Total</u>
1979	4,080 (52)	140 (2)	1,520 (20)	2,050 (26)	7,790 (100)
2000	16,130 (59)	1,450 (5)	2,840 (11)	6,960 (25)	27,380 (100)

6.3 Rural Areas

<u>Year</u>	<u>Domestic</u>	<u>Livestock</u>	<u>Tourism</u>	<u>C.P. & Others</u>	<u>Total</u>
1979	18,980 (37)	25,200 (48)	-	7,800 (15)	51,980 (100)
2000	64,720 (52)	40,310 (33)	-	18,530 (15)	123,560 (100)



Water Demand Projection

HIGH AND LOW GROWTH WATER DEMAND PROJECTION

1. High Growth Water Demand

Unit: CMD

<u>Year</u>	<u>Mombasa</u>	<u>Other</u>	<u>Rural</u>	<u>Total</u>
1980	54,830	8,630	54,600	118,060
1985	78,220	12,240	63,500	158,960
1990	111,640	16,840	86,000	214,480
1995	161,810	23,130	111,100	296,040
2000	241,330	31,720	142,000	415,050

Growth p.a. (1979/2000)	7.7%	6.7%	4.9%	6.5%
----------------------------	------	------	------	------


Per Cap. 2000	307 lpcd	228 lpcd	88 lpcd	
---------------	----------	----------	---------	--

2. Low Growth Water Demand


Unit: CMD

<u>Year</u>	<u>Mombasa</u>	<u>Other</u>	<u>Rural</u>	<u>Total</u>
1980	53,290	8,240	50,900	112,430
1985	70,730	11,070	61,400	143,200
1990	92,740	14,390	70,800	177,930
1995	121,730	18,500	85,900	226,130
2000	158,890	23,110	93,700	280,700


Growth p.a. (1979/2000)	5.6%	5.3%	3.4%	4.7%
----------------------------	------	------	------	------



ANNUAL AVERAGE WATER DEMAND HIGH AND LOW PROJECTION



NET WATER DEMAND PROJECTION




WATER DEMAND VERSUS EXISTING AND ON-GOING SYSTEM SUPPLY CAPACITY


PEAK MONTH DEMAND PROJECTION FOR ALL AREAS

DEMAND AREAS	1980		1985		1990		1995		2000	
	(1)	(2)	(1)	(2)	(1)	(2)	(1)	(2)	(1)	(2)
	Unit: m ³ /day									
1. Kirifi										
(1) Urban center	5,650	7,350	7,680	9,990	10,190	13,200	13,630	17,710	17,160	22,910
(2) Rural	8,500	9,960	12,010	14,180	16,350	19,300	22,870	27,210	31,420	37,650
2. Kwale										
(1) Urban center	640	830	870	1,130	1,150	1,500	1,540	2,000	2,080	2,700
(2) Rural	8,760	9,440	10,410	11,480	12,400	13,670	19,980	22,310	30,550	34,240
3. Taica/Traveta										
(1) Urban center	1,200	1,560	1,640	2,130	2,180	2,800	2,900	3,770	3,920	5,100
(2) Rural	1,760	1,960	2,170	2,450	2,630	2,970	3,230	4,070	3,960	4,620
4. Sub-total										
(1) Urban center	7,490	9,740	10,190	13,250	13,520	17,500	18,070	23,480	23,160	30,110
(2) Rural	19,020	21,360	24,590	28,110	31,380	35,940	46,080	53,590	65,930	76,510
5. Mombasa	53,960	59,360	74,030	81,430	101,000	111,100	138,830	152,710	194,040	213,440
6. Grand-total	80,470	90,460	108,810	122,790	145,900	164,540	202,980	229,780	283,130	320,060
	(0.93m ³ /sec)(1.05m ³ /sec)(1.26m ³ /sec)(1.42m ³ /sec)(1.69m ³ /sec)(1.90m ³ /sec)(2.35m ³ /sec)(2.66m ³ /sec)(3.28m ³ /sec)(3.70m ³ /sec)									


Notes: (1) Annual Average Base
(2) Peak Month Base




CONCEIVABLE PLANS




A Simulation Model to Estimate Reservoir
Capacity Required for the Tsavo Reservoir




Reservoir Capacity Required for the Tsavo Reservoir




Deficit on the Sabaki River by Changing Abstraction to Mombasa without the Tsavo Dam




Reservoir Capacity Required for the Tsavo Reservoir
 (Abstraction is made from the reservoir)



PLAN OF TSAVO DAM SCALE 1:2,000



CROSS SECTION OF TSAVO DAMS SCALE 1:500



PROFILE OF SPILLWAY SCALE 1:1000

FLOOD ESTIMATES AT TSAVO DAM SITE

A. General

1. Monthly mean discharge at the dam site (3G2) is collected for the development of water resources as mentioned in Chapter 6 of the Inventory Report. Flood runoff is estimated for the design of spillway and diversion facilities. The prediction of flood discharge is made based on the relationship between rainfall and discharge, since flood peak is not well estimated by reading the gauge height once a day.

B. Frequency Analysisa. Rainfall

2. There are three rainfall gauging stations in and around the watershed. Those are the stations near the Mzima Springs (93-38-17), Ngulia lodge (93-38-27) and Tsavo gate (93-38-28). Measurement of the first station was started on March 1950 and maximum daily rainfall in a year is available, while measurement of remaining two stations was started on January 1971. Rainfall data for the two stations are not long enough for the frequency analysis. Thus, rainfall data of the only one station are available for the whole basin.

3. Annual maximum daily rainfall data of the three stations are collected from the Hydrology Section of MOWD as tabulated in page 5 of 9 of the ANNEX. Frequency analysis of rainfall is made by the above data.

b. Frequency Analysis

4. Several frequency distributions are adopted for determining the recurrence interval of the hydrologic event of a given magnitude x , because there is no information which distribution is well fitted to the hydrologic event. Frequency distributions applied are extremal distribution type I (Gumbel method), Pearson type III and log-normal (Iwai method).

5. The results of frequency analysis by the three methods are depicted in page 6 of 9 of the ANNEX. The biggest value among ones estimated by the three methods is adopted as the magnitude for each recurrence interval. Though the frequency analysis is made by the data of a station, namely point rainfall, it is assumed that rainfall of the station represents rainfall of this basin.

6. Probable maximum precipitation (PMP) at the station 93-38-17 is estimated based on the empirical method developed by Herschield. The formula is expressed as follows;

$$X_{\max} = \mu + 15\sigma$$

where μ and σ are mean and standard deviation of samples, X_{\max} is the extreme value of 24-hour point rainfall and 15 is empirically derived from records in the United States.

7. The statistical parameters, mean and standard deviation of records at 93-38-17 are 50.5 and 29.0 mm, respectively. The probable maximum precipitation is

$$\begin{aligned} X_{\max} &= 50.5 + 15 \times 29.0 \\ &= 485.5 \text{ mm} \end{aligned}$$

8. The reduction factor which is the parameter to reduce from the point rainfall to the basin average rainfall is assumed to be 0.6, because hyetal maps of rainstorms are not prepared. PMP in the basin is obtained multiplying 0.6 by PMP of the point;

$$\begin{aligned} \text{PMP}_{\text{basin}} &= 485.5 \times 0.6 \\ &= 291.3 \text{ mm} \end{aligned}$$

C. Estimates of Flood

a. Unit Hydrograph

9. For predicting flood discharge from rainfall, the response function between rainfall (input) and discharge (output) is determined. Though there are several mathematical models to express the response function of a basin, the unit hydrograph method is applied for the estimate of flood discharge, because rainfall and flood discharge data are not enough for the identification of parameters included in the mathematical models.

10. The flood recorded on April 14, 1967 is selected as the flood to determine the unit hydrograph as depicted in page 7 of 9 of the ANNEX. The first peak of the flood might be caused by the rainstorm on April 12, 1967 which is shown in page 5 of 9 of the ANNEX. However, there is no information of the rainstorm caused the second peak of the flood. Thus, the second peak of the flood is eliminated by assuming that the recession limb on the first flood is exponentially regressed as shown in the dotted line.

11. For the estimate of rainfall excess on the flood, the drainage area in the upper reaches of the Loolturesh River is excluded, since flood discharge of the Loolturesh River is retained in seasonal swamps.

The drainage area for flood estimate is decided to be $4,050 \text{ Km}^2$, by which the runoff coefficient is calculated to be 0.23 for the flood on April 14, 1967. The rainfall excess is estimated to be 3.8 mm ($0.023 \times 163.3 \text{ mm}$).


12. If the rainfall excess of the unit hydrograph is defined to be 10 mm, the unit hydrograph is obtained as shown in page 8 of 9 of the ANNEX. Hydrographs of 10-year and 200-year recurrence intervals are depicted as shown in page 9 of 9 of the ANNEX assuming that the runoff factor of rainfall for each recurrence interval is 0.4. The 10-year flood is used as the design flood of the diversion facilities. According to the Code of Japan on fill-type dams, the design flood for the spillway is defined as the flood with 1.2 times discharge of the 200-year flood. Applying this Code, the design flood for the spillway and the probable maximum flood estimated from PMP are shown in page 9 of 9 of the ANNEX.

Annual Maximum Daily Rainfall


Year	Station					
	93.38.17		93.38.27		93.38.28	
	max. daily rainfall, mm	date	max. daily rainfall, mm	date	max. daily rainfall, mm	date
1950	31.8	Apr.27				
51	46.0	Apr.16				
52	89.2	Apr.13				
53	36.1	Jan. 1				
54	89.4	Apr. 8				
55	41.9	Dec.13				
56	-	-				
57	79.5	Jan.23				
58	-	-				
59	11.4	Nov.26				
1960	42.7	Jan.21				
61	27.9	Apr. 9				
62	33.3	Dec. 3				
63	39.1	-				
64	34.3	-				
65	37.3	Jan. 4				
66	34.5					
67	163.3	Apr.12				
68	44.7	Dec. 6				
69	53.1	Dec. -				
1970	37.6	Mar. -				
71	39.9	Dec. -	55.8	Dec. -	81.0	Apr. -
72	47.6	Feb. -	60.6	Nov. -	77.2	Dec. -
73	50.8	Apr. -	88.2	Nov. -	30.3	Jan. -
74	33.7	Mar. -	38.5	Apr. -	40.0	Oct. -
75	38.3	Apr. -	30.0	Nov. -	35.2	Nov. -
76	45.5	Apr. -	66.5	Nov. -	47.5	Sep. -
77	60.0	Jan. -	71.3	Dec. -	44.8	Apr. -
78	74.7	Jan. -	59.4	Nov. -	86.3	Dec. -
79	-	-	34.0	May -	60.0	Feb. -

Probable Daily Rainfall


Return period (Year)	Method applied		
	Gumbel	Pearson III	Iwai
2	46	40	45
5	76	66	67
10	95	87	83
20	114	109	99
25	119	116	104
50	138	140	121
100	156	163	138
200	174	188	155
500	198	223	180
1000	215	253	199




Flood Dated April 14, 1967



Unit Hydrograph of Tsovo Dam Site



Design Floods of Tsavo Dam Site



WATER DEMAND VERSUS 2ND MZIMA PIPE LINE SYSTEM SUPPLY CAPACITY

WATER DEMAND AND SUPPLY/SYSTEM CAPACITY

(10⁸ m³/d)

(m³/sec)

Years

Baricho/Sobeki System Phase I
(54,000 m³/d + 4,500 m³/d)
Baricho/Sobeki System Phase II
Extension (18,000 m³/d)

Deficit
000,06

Existing Supply
51,000

Bulk Water Supply
Annual Average Demand

Bulk Water Supply
Peak Month Demand

(2nd MZIMA P/L PLAN)

ESTIMATED 1995 DEMAND AND SOURCES OF SUPPLY


(PEAK MONTH DEMAND)


AREA	Total Demand m ³ /d	SOURCES OF SUPPLY			
		Mzima P/L I&II m ³ /d	Marere P/L m ³ /d	Tiwi B.H. P/L m ³ /d	Sabaki P/L m ³ /d
1. Mombasa Is	55,000	55,000	-	-	-
2. West Mainland	42,710	42,710	-	-	-
3. North Mainland	40,000	8,000	-	-	32,000
4. South Mainland	15,000	15,000	-	-	-
5. Kilifi District	40,000	-	-	-	40,000
6. Kwale District North	500	500	-	-	-
7. Kwale District Central	2,500	2,500	-	-	-
8. Kwale District South	21,310	1,810	12,000	7,500	-
9. Taita District	7,840	7,840	-	-	-
10. Kilifi South	4,920	4,920	-	-	-
	229,780	138,280	12,000	7,500	72,000

(2nd MZIMA P/L PLAN)

ESTIMATED 1990 DEMAND AND SOURCES OF SUPPLY

AREA	Total Demand m ³ /d	SOURCES OF SUPPLY			
		Mzima P/L I&II m ³ /d	Marere P/L m ³ /d	Tiwi B.H. P/L m ³ /d	Sabaki P/L m ³ /d
1. Mombasa	39,000	39,000	-	-	-
2. West Mainland	33,100	33,100	-	-	-
3. North Mainland	28,000	-	-	-	28,000
4. South Mainland	11,000	4,670	6,330	-	-
5. Kilifi District	29,500	-	-	-	29,500
6. Kwale District North	500	500	-	-	-
7. Kwale District Central	1,500	1,500	-	-	-
8. Kwale District South	13,170	-	5,670	7,500	-
9. Taita District	5,770	5,770	-	-	-
10. Kilifi South	3,000	3,000	-	-	-
	164,540	87,540	12,000	7,500	57,500





INDEX

- EXISTING SPRINGS AND BOREHOLES
- EXISTING T. PLANT
- EXISTING RESERVOIRS
- PROPOSED RESERVOIRS
- EXISTING P/L
- PROPOSED P/L
- n PROPOSED SUBSIDIARY P/L
(REFER TO PARA 4410 FOR P/L NUMBERS)

2nd MZIMA P/L PLAN

Design Criteria for the Project

1. Design capacity

General

- (1) Intake facilities including intake pumps:
peakmonth demand x 1.10 (loss of treatment 10%)
- (2) Treatment plant: peakmonth demand x 1.10 (loss of treatment 10%)
- (3) Transmission pumps: peakmonth demand x 1.0
- (4) Transmission P/L: peakmonth demand x 1.0
- (5) Distribution reservoirs:
 - (a) Mombasa area: average annual daily demand x 1 1/2 days
 - (b) For all other areas: average annual daily demand x 2 1/2 days

Capacity of Augmentation Plans

(2nd Mzima P/L)

- (1) Intake: Max. 1.2 m³/sec (103,680 m³/d)
 - (2) Transmission main: ditto
- (Rare P/L)
- (1) Intake: Max. 3.18 m³/sec (275,000 m³/d)
 - (2) Treatment Plant: ditto
 - (3) Transmission main: Max. 2.89 m³/sec (250,000 m³/d)

2. Rare Treatment Plant Design Parameters Used

General

- (1) Design output in 2000: 200,000 m³/d (2.31 m³/sec)
- (2) Maximum design output: 250,000 m³/d (2.89 m³/sec)

Major Facilities

- (1) Intake Pumps:
 - a. @19.1 m³/min x 2 units - 20% to Max.
 - b. @38.2 m³/min x 4 units - 80% to Max.
 - c. Stand by @19.1 m³/min x 1 unit
@38.2 m³/min x 2 units
Stand by Total 50%
- (2) Raw water main: Max. 3.18 m³/sec flow capacity
Dia. 1,500 mm, C=130, v=1.8 m/sec, L=4.8 km
- (3) Receiving/Distributing Tank: Detention time - 2 min.
Effective volume - 300 m³
Diameter - 5 m
Depth of water - 4m
- (4) Mixing chamber: Detention time - 1 min.
Baffle cone type
- (5) Flocculation basin: Detention time - 30 min.
Vertical flocculators
- (6) Sedimentation basins: Surface loading 1.0 m³/m²h
Conventional type 27 m x 85 m x 6 units
(including one unit stand by)
Detention time - 3 hrs
- (7) Filtration: Flow rate 120 m/d (5 m/h)
Rapid sand filters 9.2 m x 10 m x 30 units
Total filter area = 2,760 m²
(including 5 units stand by)
Wash water
 - a. back washing 0.6 m/min
 - b. surface washing 0.2 m/min
 Rate per filter = 0.8 x 92 = 73.6 m³/min
Max. 6 min operation = 442 m³
Wash water storage = 1,000 m³
- (8) Chemical dosing:
 - a. Alum Max. 200 mg/l
Aveg. -
 - b. Chlorine Max. 5 mg/l
Normal 1 mg/l
 - c. Soda ash

- (9) Transmission Pumps:
- a. @17.4 m³/min x 2 units - 20% to Max.
 - b. @34.8 m³/min x 4 units - 80% to Max.
 - c. Stand by
 - @17.4 m³/min x 1 unit
 - @34.8 m³/min x 2 units
 - Stand by Total 50%

STUDY ON FLUCTUATIONS IN WATER DEMAND
AND SYSTEM CAPACITY FOR THE PLAN

1. Demand Fluctuations

Since a water supply system should be designed to meet the peak consumption periods it is important to review the present demand fluctuations throughout a year. It is impossible, however, to determine true demand fluctuations in Mombasa from present consumption, therefore the projection for fluctuations in annual, monthly and daily demands are based on the past study made by consultants in 1972^{/1} and compared with other similar cities in tropical climates.

Peaking factors studied in the said report are quoted and shown in the followings :

<u>Supply System</u>	<u>Average Peaking Factor</u>	
	<u>Peak Month</u>	<u>Peak Day</u>
Mombasa Distribution System	1.075	1.225
North Mainland System (all areas)	1.23	1.50
North Mainland System (excluding industrial consumption)	1.29	1.63
Malindi System	1.30	1.45
Gedi/Watamu System	1.30	1.85
Malindi/Gedi/Watamu System (combined)	1.30	1.55
Kilifi System	1.25-1.30	-


With careful analysis, in this planning, the peaking factors of 1.10 and 1.30, for peak month demands, were adopted for the further study for Mombasa area and other project areas respectively.

^{/1} Scott-Wilson Kirkpatrick and Partners, "Draft Supplementary Report and Alternative Schemes for Supplying Water to Mombasa and the North Coast", July 1972.


2. Design Capacity

Taking into consideration the close relation to the on-going Sabaki P/L system, the capacity for the plan in respect to a bulk water supply system is designed to meet the peak monthly demands. Peak monthly daily demands by area are projected and shown in ANNEX 2444-2.
(ref. ANNEX 4404-1 Design Criteria for the Project.)


SECTION A - A




DETAIL




SECTION B - B




PLAN



SECTIONAL PLAN




SECTIONAL PLAN



2ND MZIMA PIPELINE SPRING INTAKE (NOT TO SCALE)




SCALE: APPROX. 1/7,500



MZIMA SPRINGS INTAKE
VICINITY AND LOCATION MAP

2ND HZIMA P/L GENERAL PLAN & PROFILE




EL	(M)	(KM)	EL
5	+654.8		
10	+640.0		
15	+640.0		
20	+644.4		
25	+645.8		
30	+627.2		
35	+615.8		
40	+610.3		
45	+629.8		
46.959	+638.0		
50	+631.4		
55	+624.0		
60	+606.9		
65	+584.0		
70	+580.0		
75	+571.8		
80	+563.7		


Ø1350 mm

$i = 0.00058$

2ND MZIMA P/L GENERAL PLAN & PROFILE



2ND MZIMA P/L GENERAL PLAN & PROFILE




(2nd MZIMA P/L PLAN)

DISTRIBUTION RESERVOIR CONSTRUCTION SCHEDULE

Location	System	Provision in 1986 m ³	Provision in 1995 m ³	Total
1. Voi	2nd Mzima P/L	20,000	-	20,000
2. Taru	"	20,000	-	20,000
3. Maliakani	"	20,000	-	20,000
4. Nguee Tatu	Sabaki P/L	20,000	20,000	40,000
5. Kaya Bambo	Marere P/L	30,000	30,000	60,000
6. Changamwe	Sabaki P/L	13,600 ^{1/}	-	13,600
7. Balancing	2nd Mzima P/L	30,000	30,000	60,000
Total		153,600	80,000	233,600 m ³

Note: ^{1/} Shall be provided in the Sabaki P/L system in 1984.

Standard @20,000 x 5 = 100,000 m³
 " @30,000 x 4 = 120,000 m³
 Total 220,000 m³




DIMENSIONS

(mm)

CAPACITY	D ₁	D ₂	H ₁	R	c	b	c	d	e
20 000 cum	47600	45000	6030	45000	6430	5330	600	300	400
30 000 cum	57700	55000	7370	55000	7870	6770	650	350	500

DISTRIBUTION RESERVOIR
STANDARD MODEL

(NOT TO SCALE)



PROPOSED SUBSIDIARY PIPELINES, 2ND MZIMA P/L PLAN

SCALE: 1/1,000,000 (km)

LEGEND

- EXISTING P/L
- EXISTING SPRINGS
- EXISTING RESERVOIR
- EXISTING PLANT
- PROPOSED SPRING
- PROPOSED RESERVOIR
- PROPOSED P/L
- 1** PROPOSED SUBSIDIARY P/L (REFER TO PARA 4410 FOR P/L NUMBERS)

Second Muzima P/L with Tsavo Reservoir Plan
Sizes and Capacities of Major Components

<u>Plan Element</u>	<u>Description</u>
Spring Intake	<ul style="list-style-type: none">- Total 2 km long sheet piling and infiltration trench installed with 1,000 mm to 500 mm dia. concrete pipes. A RC made intake chamber with flow control valve and a drain and excess water draining outlet of 600 mm sluice valve.
Main Transmission P/L	<ul style="list-style-type: none">- Pipes 1,350 mm dia; 86,000 m, 1,100 mm dia; 43,310 m, 1,000 mm dia, 88,230 m. Suitable for maximum working pressure of 12.5 kg/cm^2 including surge surplus. Peak capacity of flow would be $1.2 \text{ m}^3/\text{sec}$ and flow control would be done at intake chamber.- Line valves and operating points at about 2 km intervals- Air valves and washouts as required by profile with approx. 10 per 9 km.
Break Pressure Tanks	<ul style="list-style-type: none">- Capacity 720 m^3 each, detention time 10 min at max. flow.- Installed with 600 mm dia by-pass.- Six BPTs in total would be constructed.
Storage Reservoirs	<ul style="list-style-type: none">- Voi Reservoir at $20,000 \text{ m}^3$.- Taru Reservoir at $20,000 \text{ m}^3$.- Mariakani Reservoir at $20,000 \text{ m}^3$.- Balancing Reservoir near existing BPT No. 10 at $60,000 \text{ m}^3$.- Kaya Bombo Reservoirs at $60,000 \text{ m}^3$.- All reservoirs are designed to be circular prestressed concrete construction.- See standard Annex 4480-2.

Subsidiary P/L

- 500 mm dia, 28,000 m
- 400 mm dia, 17,000 m
- 350 mm dia, 3,000 m
- 300 mm dia, 40,000 m

Materials suitable for maximum working pressure 12.5 kg/cm² including surge surplus.

MAIN FEATURES OF 2ND MZIMA P/L WITH TSAVO RESERVOIR PLAN

Development scale: $1.2 \text{ m}^3/\text{sec}$ 1. Dam

Catchment (km^2)	4050 excluding the area of the Loolturesh River
Type	Rockfill
Height above river bed (m)	34
Reservoir, effective storage (10^6 m^3)	21
Fill volume (10^3 m^3)	450
Design flood (m^3/sec)	1,550
Annual mean discharge (m^3/sec)	6.2

2. Water supply facilities

Type of intake	Underground
Trunk main P/L, diameter (mm)	1,350mm - 86,000m
and length (m)	1,100mm - 43,310m
	1,000mm - 88,230m

COST ESTIMATES OF 2ND MZIMA P/L WITH TSAVO RESERVOIR

Unit: US\$10³
Development Scale: 1.2 m³/sec

	Economic Costs			Sales Taxes		Financial Costs		
	L.C.	F.C.	Total	L.C.	Total	L.C.	F.C.	Total
Capital Cost								
A Water Supply Facilities								
1	3,980.4	1,760.0	5,740.4	635.6	4,616.0	1,760.0	4,616.0	6,376.0
2	36,428.4	101,280.0	137,708.4	12,487.6	48,916.0	101,280.0	48,916.0	150,196.0
3	14,572.6	896.0	15,468.6	1,693.8	16,266.4	896.0	16,266.4	17,162.4
4	150.0	400.0	550.0	50	200.0	400.0	200.0	600.0
5	3,965.0	7,420.0	11,385.0	1,058.9	5,023.9	7,420.0	5,023.9	12,443.9
B Dam								
6	2,279.2	1,584.1	3,863.3	335.9	2,615.1	1,584.1	2,615.1	4,199.2
7	8,298.7	5,913.4	14,212.1	1,235.8	9,534.5	5,913.4	9,534.5	15,447.9
8	5,168.5	7,018.0	12,186.5	1,059.7	6,228.2	7,018.0	6,228.2	13,246.2
9	9,290.9	2,746.1	12,037.0	1,046.7	10,337.6	2,746.1	10,337.6	13,083.7
10	34.5	163.3	197.8	17.2	51.7	163.3	51.7	215.0
C Engineering and Administration								
	8,416.8	12,918.1	21,334.9	1,962.1	10,378.9	12,918.1	10,378.9	23,297.0
D Physical Contingency								
Base Cost Total	92,585.0	142,099.2	234,684.2	21,583.3	114,168.3	142,099.2	114,168.3	256,267.5
Physical Contingency	13,887.8	21,315.0	35,203.7	3,237.5	17,125.3	21,315.0	17,125.3	38,440.3
Capital Cost Total	106,472.8	163,415.0	269,887.9	24,820.8	131,293.6	163,415.0	131,293.6	294,708.6
E Price Contingency	-	-	-	-	75,700	51,072	75,700	126,772
F Financial Cost Total	-	-	-	-	206,994	214,487	206,994	421,481

ECONOMIC COSTS ESTIMATED FOR WATER FACILITIES AND
CIVIL WORKS ON 2ND MZIMA P/L WITH TSAVO RESERVOIR

Development Scale: 1.2 m³/sec.

Items	Unit	Quantity	L. C.		F. C.	
			Unit Price (US\$)	Amount (US\$10 ³)	Unit Price (US\$)	Amount (US\$10 ³)
A. Water Supply Facilities						
1. Underground intake	L.S.			3,980.4		1,760.0
2. Transmission main P/L						
∅ 1350	m	87,000	215.90	18,780.0	600.00	52,200.0
∅ 1100	m	43,310	149.90	6,490.7	416.90	18,056.0
∅ 1000	m	88,230	126.50	11,156.9	351.60	31,024.0
Sub-total				36,428.4		101,280.0
3. Break pressure tanks and reservoirs						
Break pressure tanks	No.	6	85x10 ³	510.0	65x10 ³	390.0
30,000 m ³ reservoirs	No.	4	1,600x10 ³	6,400.0	52x10 ³	208.0
20,000 m ³ reservoirs	No.	5	1,400x10 ³	7,000.0	51x10 ³	255.0
Miscellaneous	L.S.			662.6		43.0
Sub-total				14,572.6		896.0
4. Communication system	L.S.			150.0		400.0
5. Subsidiary P/L						
∅ 500	m	28,000	64.5	1,805.6	120.3	3,368.4
∅ 400	m	17,000	45.7	776.9	85.2	1,448.4
∅ 350	m	3,000	37.3	111.8	69.6	208.8
∅ 300	m	40,000	31.8	1,270.7	59.9	2,394.4
Sub-total				3,965.0		7,420.0
B. Dam						
6. General items	L.S.			2,279.2		1,584.1
7. Cofferdam and diversion tunnel						
Excavation in open cut	m ³	153,300	6	919.8	3	459.9
Excavation in tunnel	m ³	40,200	45	1,809.0	75	3,015.0
Embankment	m ³	273,300	5	1,366.5	5	1,366.5
Concrete	m ³	23,400	100	2,340.0	30	702.0
Reinforcement bars	ton	1,000	900	900.0	80	80.0
Miscellaneous	L.S.			963.4		290.0
Sub-total				8,298.7		5,913.4

Items	Unit	Quantity	L. C.		F. C.	
			Unit Price (US\$)	Amount (US\$10 ³)	Unit Price (US\$)	Amount (US\$10 ³)
8. Main dam						
Excavation	m ³	162,400	6	974.4	3	487.2
Embankment	m ³	452,700	5	2,263.5	5	2,263.5
Asphalt concrete facing	m ²	29,600	15	444.0	100	2,960.0
Concrete in cut-off wall	m ³	2,500	100	250.0	20	50.0
Curtain grouting	m	6,000	25	150.0	100	600.0
Miscellaneous	L.S.			1,086.6		657.3
Sub-Total				5,168.5		7,018.0
9. Spillway						
Excavation	m ³	502,500	6	3,015.0	3	1,507.5
Backfill	m ³	10,000	1	10.0	0.50	5.0
Concrete	m ³	49,300	100	4,930.0	20	986.0
Reinforcement bars	ton	1,000	900	900.0	80	80.0
Steel anchor bars	ton	100	1,300	130.0	700	70.0
Miscellaneous	L.S.			305.9		97.6
Sub-Total				9,290.9		2,746.1
10. River outlet facilities						
	L.S.			34.5		163.3
Grand Total				84,168.2		129,180.9

ECONOMIC LIFE OF EQUIPMENT AND MATERIALS

<u>Second Mzima P/L with Tsavo Reservoir</u>		<u>Rare P/L with Rare Reservoir</u>	
<u>Items</u>	<u>Economic Life (Years)</u>	<u>Items</u>	<u>Economic Life (Years)</u>
1. Intake Facilities		1. Intake & Transmission Pumping Facilities	
Valves	30	- Pumps & Elec.	10
R.C.	40	- Pipe & Valves	30
2. Transmission Main		- Structure	50
Pipes	40	2. Raw Water Main	
Valves	30	- Pipes	40
R.C.	30	- Valves	30
3. BPTs & Reservoir		- Ancillary works	30
Valves	30	3. Treatment Plant	
Pipes	40	- Equipment	15
R.C.	30	- Pipes & Valves	30
4. Communication		- Structure	50
Equipment	15	4. Transmission Main	
R.C.	30	- Pipes	40
		- Valves	30
		- Ancillary works	30
		5. Distribution Reservoir	30
		6. Communication Equip.	15

Remarks: R.C. stands for "Reinforced Concrete".

BREAKDOWN OF O&M COST ON SECOND MZIMA P/L


Unit: US\$10³

Year	Proposed System Supply, m ³ /d	Staff Salary	Chemical	Repair	Total
1986	1,990	32.17	0.54	16.2	48.91
1987	5,510	⋮	1.51	⋮	49.88
1988	8,480	⋮	2.29	⋮	50.66
1989	12,000	⋮	3.26	⋮	51.63
1990	18,400	56.44	5.01	⋮	77.65
1991	28,000	⋮	7.64	⋮	80.28
1992	39,890	⋮	10.88	⋮	83.52
1993	52,000	⋮	14.16	⋮	86.80
1994	63,990	⋮	17.42	⋮	90.06
1995	75,990	⋮	20.73	⋮	93.37
1996	89,760	⋮	24.55	⋮	97.19
1997	102,810	⋮	28.03	⋮	100.67
1998	104,000	⋮	28.32	⋮	100.96
1999	⋮	⋮	⋮	⋮	⋮
2000	⋮	⋮	⋮	⋮	⋮
⋮	⋮	⋮	⋮	⋮	⋮
⋮	⋮	⋮	⋮	⋮	⋮
2035	⋮	⋮	⋮	⋮	⋮


SECOND MZIMA P/L WITH TSAVO RESERVOIR PLAN
COST AND WATER VOLUME STREAMS

Unit: US\$ 10⁶
Development scale: 1.2 m³/sec


End of fiscal year	No.	Water volume 10 ⁶ m ³	Capital cost	O & M cost
1983	-3	-	40.5	-
84	-2	-	161.9	-
85	-1	-	67.5	-
86	1	0.73	-	0.05
87	2	2.01	-	0.05
88	3	3.10	-	0.05
89	4	4.38	-	0.08
1990	5	6.57	-	0.08
91	6	10.22	-	0.08
92	7	14.60	-	0.09
93	8	18.98	-	0.09
94	9	23.36	-	0.09
95	10	27.74	-	0.10
96	11	32.85	-	0.10
97	12	37.53	-	0.10
98	13	37.96	-	0.10
99	14	⋮	-	⋮
2000	15	⋮	0.5	⋮
2000-'14	16-29	⋮	-	⋮
2015	30	⋮	31.9	⋮
2016-'24	31-39	⋮	-	⋮
2025	40	⋮	125.9	⋮
2026-'29	41-44	⋮	-	⋮
2030	45	⋮	0.5	⋮
2031-'35	46-50	37.96	-	0.10



Variation of Annual (B - C) by Changing Tariff
on the 2nd Mzima Plan



Return on Investment on the Development
(Mzima Plan) Scale of 1.2 m³/sec



Sensitivity Tests for the Second Mzima Plan

ROI AND WATER RATES (AT CURRENT PRICES) BY VARIOUS ANNUAL
INCREASE RATES OF WATER RATE

(1) Annual Increase for 1980 - 1986	(2) at Current Price		(4) at 1980 Price		(6) 2nd Mzima	(7) Rare
	Water Rate ^{/1} 1980 (KSh/m ³)	Water Rate ^{/1} 1986 (KSh/m ³)	Water Rate ^{/1} 1980 (KSh/m ³)	Water Rate ^{/1} 1986 (KSh/m ³)		
13 %	5.88	12.24 (\$1.63/m ³)	5.60	6.58	6.5 %	9.4 %
15 %	5.88	13.60 (\$1.81/m ³)	5.60	7.31	7.1 %	10.1 %
17 %	5.88	15.08 (\$2.01/m ³)	5.60	8.11	7.7 %	10.8 %
20 %	5.88	17.56 (\$2.34/m ³)	5.60	9.44	8.7 %	11.8 %

(1) Annual Increase for 1980 - 1986	(8) at Current Price	
	Consumer's Water Tariff in 1986 ^{/2} (KSh/m ³)	
13 %	17.49 (\$2.33/m ³)	
15 %	19.43 (\$2.59/m ³)	
17 %	21.54 (\$2.87/m ³)	
20 %	25.09 (\$3.35/m ³)	

^{/1} Evaluated at the outlet of distribution reservoir.

^{/2} (8) = (3)/0.7 Assuming the cost of distribution system constitutes 30% of the consumer's water tariff.

SECOND MZIMA P/L WITH TSAVO RESERVOIR PLAN

FIRR CALCULATION

No.	Fiscal Year	Capital Cost & Replacement		O&M Cost	Gross Revenue	Net Benefit
		F.C.	L.C.			
						Unit: US\$10 ³
1	1983	29,292	25,555	-		-54,847
2	1984	124,139	112,390	-		-236,529
3	1985	54,828	51,522			-106,350
4	1986	-	-	91	1,251	1,160
5	1987	-	-	93	3,463	3,370
6	1988	-	-	94	5,348	5,254
7	1989	-	-	96	7,542	7,446
8	1990	6,228	17,527	144	11,313	-12,586
9	1991	-	-	149	17,604	17,455
10	1992	-	-	155	25,146	24,991
11	1993	-	-	161	32,688	32,527
12	1994	-	-	168	40,230	40,062
13	1995	-	-	174	47,773	47,599
14	1996	-	-	181	56,584	56,403
15	1997	-	-	187	64,633	64,446
16	1998	-	-	188	65,377	65,189
17	1999	-	-	⋮	⋮	65,189
18	2000	(R) 584	186	⋮	⋮	64,419
19	2001	-	-	⋮	⋮	65,189
20	2002	-	-	⋮	⋮	65,189

<u>Discount Rate</u>	<u>Net Benefit</u>
0%	+215,576
3%	+16,588
4%	-28,690

FIRR = 3.4%

(R): Replacement Cost

PROJECTED INCOME STATEMENTS FOR SECOND MZIMA P/L WITH TSAVO RESERVOIR PLAN


Unit: US\$10³

No.	Year	Water Sold (10 ³ m ³)	Average Water Rate (Ksh/m ³)	Operating Revenue		Operating Expense		Income Before Interest	Interest Payment	Net Income
				Water Sales	Depreciation	O & M Cost	Depreciation			
1	1983	-	-	-	-	-	-	-	-	-
2	1984	-	-	-	-	-	-	-	-	-
3	1985	-	-	-	-	-	-	-	-	-
4	1986	690	13.6(\$1.813)	1,251	13,357	91	-12,197	17,152	-29,349	-29,349
5	1987	1,910	..	3,463	..	93	- 9,987	16,617	-26,604	-26,604
6	1988	2,950	..	5,348	..	94	- 8,103	16,057	-24,160	-24,160
7	1989	4,160	..	7,542	..	96	- 5,911	15,425	-21,336	-21,336
8	1990	6,240	..	11,313	..	144	- 2,188	14,768	-16,956	-16,956
9	1991	9,710	..	17,604	..	149	4,098	14,501	-10,403	-10,403
10	1992	13,870	..	25,146	..	155	11,634	13,710	- 2,076	- 2,076
11	1993	18,030	..	32,688	..	161	19,170	12,892	6,278	6,278
12	1994	22,190	..	40,230	..	168	26,705	11,976	14,729	14,729
13	1995	26,350	..	47,773	..	174	34,242	11,010	23,232	23,232
14	1996	31,210	..	56,584	..	181	43,046	9,970	33,076	33,076
15	1997	35,650	..	64,633	..	187	51,089	8,855	42,234	42,234
16	1998	36,060	..	65,377	..	188	51,832	7,667	44,165	44,165
17	1999	6,379	45,453	45,453
18	2000	4,992	46,840	46,840
19	2001	3,506	48,326	48,326
20	2002	1,897	49,935	49,935


PROJECTED CASH FLOW FOR SECOND MZIMA P/L WITH TSAVO RESERVOIR PLAN

Unit: US\$10³


No. Year	Income Before Interest	Depreciation	Foreign Loan	Government Equity	Total Source	Capital Cost		Debt Service		Total Application	Increase in cash	Cash at End	Debt Service Coverage
						Foreign Currency	Local Currency	Interest	Principal				
1 1983	-	-	29,292	25,555	54,847	29,292	25,555	-	-	54,847	0	0	-
2 1984	-	-	124,139	112,390	236,529	124,139	112,390	-	-	236,529	0	0	-
3 1985	-	-	54,828	51,522	106,350	54,828	51,522	-	-	106,350	0	0	-
4 1986	-12,197	13,357	-	-	1,160	-	-	17,152	7,177	24,329	-23,169	-23,169	0.048
5 1987	-9,987	-	-	-	3,370	-	-	16,617	7,712	24,329	-20,959	-44,128	0.139
6 1988	-8,103	-	-	-	5,234	-	-	16,057	8,272	24,329	-19,075	-63,203	0.216
7 1989	-5,911	-	-	-	7,446	-	-	15,425	8,904	24,329	-16,883	-80,086	0.306
8 1990	-2,188	-	6,228	17,527	34,924	6,228	17,527	14,768	9,561	48,084	-13,160	-93,246	0.459
9 1991	4,096	-	-	-	17,435	-	-	14,501	10,451	24,952	-7,497	-100,743	0.700
10 1992	11,634	-	-	-	24,991	-	-	13,710	11,242	24,952	39	-100,704	1.082
11 1993	19,170	-	-	-	32,527	-	-	12,892	12,060	24,952	7,315	-93,129	1.304
12 1994	26,705	-	-	-	40,062	-	-	11,976	12,976	24,952	15,110	-78,019	1.606
13 1995	34,242	-	-	-	47,599	-	-	11,010	13,942	24,952	22,647	-55,372	1.908
14 1996	43,046	-	-	-	56,403	-	-	9,970	14,982	24,952	31,451	-23,921	2.260
15 1997	51,089	-	-	-	64,446	-	-	8,855	16,097	24,952	39,444	15,573	2.583
16 1998	51,832	-	-	-	65,189	-	-	7,667	17,285	24,952	40,237	55,810	2.613
17 1999	-	-	-	-	-	-	-	6,379	18,573	24,952	-	96,047	-
18 2000	-	-	-	-	-	-	-	4,992	19,960	24,952	-	136,284	-
19 2001	-	-	-	-	-	-	-	3,506	21,446	24,952	-	176,521	-
20 2002	-	-	-	-	-	-	-	1,897	23,055	24,952	-	216,758	-




Reservoir Gross Storage and High Water Level of Rare Reservoir




Flow Capacity of Diversion Canal
from the Sabaki to the Rare




PLAN OF RARE DAM SCALE 1:1,000



CROSS SECTION OF RARE DAMS SCALE 1:500



PROFILE OF SPILLWAY SCALE 1:1000



CROSS SECTION OF DIVERSION CANAL FROM THE SABAKI TO THE RARE RESERVOIR (40 Km) SCALE 1:100

FLOOD ESTIMATES AT RARE DAM SITE

A. General

1. For the estimate of flood discharge at the dam site, it is desired to use discharge data at the existing gauging station (3LA2). However, discharge measurement on flood has never been made at the station. Moreover, there is no rainfall gauging station in the watershed except the area of the Voi River. As there is no available information for the prediction of flood in the basin, flood discharge is estimated from specific discharge of other basins.

B. Specific Discharge

2. Specific discharge is defined as the value of peak discharge over the catchment. Flood discharge at the Tsavo dam site has been already discussed in ANNEX 4308. Design floods at the proposed Mwachi dam site have been estimated by the flood on May 14, 1972 and rainfall data at Maji ya Chumbi (93-39-23).

3. The specific discharges for design floods at the dam sites of Tsavo and Mwachi are summarized as below.

	Catchment, Km ²	Specific discharge, m ³ /sec/Km ²		
		Design flood for diversion	Design flood for spillway	PMF / <u>1</u>
Tsavo	4050	0.16	0.38	0.49
Mwachi	2090	0.34	0.87	1.27


1: Probable maximum flood.

4. The catchment of 2,090 Km² on the Mwachi dam site is measured by excluding the area belonging to the seasonal river. The catchment of the Rare dam is measured to be 1,500 Km² excluding the area of upper reaches as mentioned in para. 5201. For the estimate of discharge for the cofferdam and diversion channel, the catchment is made 580 Km² by providing another cofferdam at the point that El.400 ft contour runs across the Goshi River for the purpose of making the diversion facilities small.


5. As the cofferdam near Goshi is only used for retarding the peak discharge of flood, it is allowed for the cofferdam to be over-topped without any diversion facilities. After the completion of the main dam, the cofferdam is removed.

6. It is said that the value of specific discharge exponentially decreases as catchment increases, that is, the specific discharge of the Rare is greater than that of the Mwachi. However, the specific discharge estimated for the Mwachi is applied to predict the flood discharges for the Rare dam, because the Rare River is located in the drier area than the Mwachi River. The peak discharges predicted for the Rare dam are as follows;

Design flood for the diversion facilities;	260 m ³ /sec
Design flood for the spillway;	1,305 m ³ /sec
Probable maximum flood;	1,905 m ³ /sec



PLAN OF THE SABAKI INTAKE TO THE RARE RESERVOIR




UPSTREAM SECTION A - A

SCALE 0 5 10 (1:100)


(RARE PLAN)

ESTIMATED 2000 DEMAND AND SOURCES OF SUPPLY

AREA	Total Demand (m ³ /d)	Mzima P/L (m ³ /d)	SOURCES OF SUPPLY		
			Marere P/L Tiwi B.H. (m ³ /d)	Rare P/L (m ³ /d)	Sabaki P/L (m ³ /d)
1. Mombasa Is.	75,000	-	-	75,000	-
2. West Mainland	64,000	13,780	-	50,220	-
3. North Mainland	53,000	-	-	35,500	17,500
4. South Mainland	21,500	-	-	21,500	-
5. Kilifi District Coast	54,500	-	-	-	54,500
6. Kilifi District South	5,500	5,500	-	-	-
7. Kwal District North	1,500	1,500	-	-	-
8. Kwal District Central	5,500	5,500	-	-	-
9. Kwal District South	30,000	-	19,500	10,500	-
10. Taita District	9,720	9,720	-	-	-
	320,220	36,000	19,500	192,720	72,000




RARE PLAN SYSTEM



INDEX

- EXISTING SPRINGS AND BOREHOLES.
- EXISTING T. PLANT
- ▨ PROPOSED T. PLANT.
- EXISTING RESERVOIRS.
- ▨ PROPOSED RESERVOIRS
- - - EXISTING P/L.
- PROPOSED P/L.
- n PROPOSED SUBSIDIARY P/L (REFER TO PARA 5413 FOR P/L NUMBERS.)




Rare P/L with Rare Reservoir PlanSizes and capacities of major components

<u>Plan Element</u>	<u>Description</u>
Intake Facility and Pumping Station	<ul style="list-style-type: none"> - RC construction intake with two separate gates and intake conduits - 9 vertical turbine pumps: <ul style="list-style-type: none"> 3 @19.1 m³/min with 390 kw motors 6 @38.2 m³/min with 750 kw motors
Raw Water Transmission Main	<ul style="list-style-type: none"> - 4.5 km long, 1,500 mm dia rising main from intake pumping station to treatment plant
Rare Water Treatment Plant	<ul style="list-style-type: none"> - Plant capacity for maximum output is 250,000 m³/day, while in Phase I 100,000 m³/day and 150,000 m³/day in Phase II. - Description of treatment plant elements are in the followings. <ul style="list-style-type: none"> a) Receiving/Distributing Tank <ul style="list-style-type: none"> - An RC circular tank with 1 min detention time for total influent of 250,000 m³/day b) Flocculation and Sedimentation Basins <ul style="list-style-type: none"> - 6 rectangular tanks for the max capacity with one unit of stand-by - Coagulation with aluminum sulphate with provisions for addition of sodium carbonate c) Filters <ul style="list-style-type: none"> - 30 rapid gravity filters with water back/surface washing and with total output capacity of 250,000 m³/day

- d) Chemicals
- Plant would include facilities for storing, preparing, feeding alum, lime, sodium carbonate and chlorine
- e) Administration and Operation Building
- Administration building with wash water tank on the top
- Transmission Pumping Station
- An RC construction pumping station
 - 9 horizontal turbine pumps:
 - 3 @17.4 m³/min with 570 kw motors
 - 6 @34.8 m³/min with 1,100 kw motors
- Transmission Main
- 1,500, 1,200 and 1,000 mm dia pipes with total length about 78 km
 - Line valves and controlling points at about 5 km intervals
 - Air valves and washouts as required by profile with approx. 3 per 2 km
- Break Pressure Tank and One-way Surge tanks
- 2 one-way surge tanks as required on the P/L
 - Rabi balancing tank at 20,000 m³
- Storage Reservoirs
- New Mazeras reservoirs at 30,000 m³
 - Nguu Tatu reservoirs at 170,000 m³
 - Kaya Bombo reservoirs at 100,000 m³
 - Voi reservoir at 20,000 m³
 - Taru reservoir at 20,000 m³
 - Mariakani reservoir at 20,000 m³
- Subsidiary P/L
- 600 mm dia, 28,000 m
 - 450 mm dia, 17,000 m
 - 350 mm dia, 53,000 m
 - Materials suitable for max. working pressure 12.5 kg/cm² including surge surplus


INTAKE PUMPING STATION




INTAKE PUMPS

- Ø600 x 38.2 M³/MIN x 82 M x 750 KW x 980 RPM x 6 UNITS
- Ø400 x 19.1 M³/MIN x 82 M x 390 KW x 1470 RPM x 3 UNITS

RARE INTAKE AND PUMPING STATION GENERAL PLAN (NOT TO SCALE)




SIDE ELEVATION



FRONT ELEVATION

CONDUIT SECTION



CONDUIT SECTION


RARE INTAKE AND PUMPING STATION (NOT TO SCALE)

Water Quality Standard


(WHO and Japanese Standards for Drinking Water)

Substance or characteristic	unit	WHO Standards		Japanese Standards	
		Highest Desirable Level	Maximum Permissible Level		
Color as Pt.Co.	unit	5	50	Max.	5
Turbidity	FTU	5	25	Max.	2
Total Solids	mg/l	500	1500	Max.	500
pH		7-8.5	6.5-9.2	From max.8.6 to min.5.8 as pH value	
Detergents	mg/l	0.2	1.0		
Mineral Oil	mg/l	0.01	0.3		-
Phenol	mg/l	0.001	0.002	Max.	0.005
Total Hardness (as CaCO ₃)	mg/l	100	500	Max.	300
Calcium as Ca	mg/l	75	200		-
Magnesium as Mg	mg/l	30	150		-
Chloride as Cl ₂	mg/l	200	600	Max.	200
Copper as Cu	mg/l	0.05	1.5	Max.	1.0
Total Iron as Fe	mg/l	0.1	1.0	Max.	0.3
Manganese as Mn	mg/l	0.05	0.5	Max.	0.3
Sulfates as SO ₄	mg/l	200	400		-
Zinc as Zn	mg/l	5	15	Max.	1.0
Coliform Groups	/100 ml	-	-	Not to be detected	
Total Bacteria	/1 ml	-	-	Max.	10

Note : The water quality is recommended to conform to criteria established by WHO. These criteria may be superseded by local standards.




RARE TREATMENT PLANT FLOOR DIAGRAM (NOT TO SCALE)



RARE TREATMENT PLANT GENERAL SITE PLAN (NOT TO SCALE)

RARE P/L GENERAL PLAN & PROFILE



EL (M)	0	5	10	15	20	25	30	35	40	45	50	52	55	60	65	70
133.9	133.9	151.6	72.2	66.9	165.3	116.1	108.3	137.8	126.0	110.2	114.0	200.0	152.4	121.9	182.9	150.0

(RARE PLAN)

DISTRIBUTION RESERVOIR CONSTRUCTION SCHEDULE

Location	System Name	Existing m ³	Provision in 2000 m ³	Total m ³
1. Mazeras	Mzima P/L	81,000	-	81,000
2. Changamwe	"	29,600	13,600 ^{1/}	43,200
3. Nguu Tatu	Sabaki P/L	9,100	170,000	270,100
	Rare P/L	18,000		
4. Voi	Mzima	580	10,000	10,580
5. Kaya Bombo	Marere P/L	1,125	100,000	101,125
	Mwachi P/L			
6. Tiwi	Tiwi B.H.	2,250	-	2,250
7. Mazeras II	Mwachi P/L	-	30,000	30,000
8. Taru	Mzima P/L	-	20,000	20,000
9. Mariakani	"	-	20,000	20,000
10. Ribe Tank	Rare P/L	-	20,000	20,000
Total		141,660	383,600	525,260

Note: ^{1/} Sabaki P/L project.

MAIN FEATURES OF RARE RESERVOIR WITH P/L

Item	Development Scale	
	1.5 m ³ /sec	2.5 m ³ /sec
Dam		
Catchment (km ²)	1,500	1,500
Type of dam	rockfill	rockfill
Height (m)	31	33
Reservoir effective storage (10 ⁶ /m ³)	16.8	27.6
Fill volume (10 ³ m ³)	306	380
Design flood (m ³ /sec)	1,305	1,305
Diversion canal		
Length (km)	40	40
Excavation (10 ³ /m ³)	1,084	1,339
Capacity (m ³ /sec)	8.0	13.3
Water supply facilities		
Pumping station (units)	2	2
Intake pumps (units) (@19.1 m ³ /min)	3	3
(@38.2 m ³ /min)	3	6
Transmission pumps (units) (@17.4 m ³ /min)	3	3
(@34.8 m ³ /min)	3	6
Raw water main P/L		
Diameter (mm) and length (km)	1,200mm-4.5km	1,500mm-4.5km
Treatment plant (@55,000 m ³ /d) (units)	3	5
Transmission main P/L		
Diameter (mm) and length (km)	1,200mm-51km	1,500mm-51km
	1,000mm-18km	1,200mm-18km
	800mm- 9km	1,000mm- 9km

COST ESTIMATES OF RARE RESERVOIR WITH P/L

		ECONOMIC COSTS				Unit: US\$10 ³	
		Development scale, m ³ /sec					
		1.5	2.5	L.C.	F.C.	L.C.	F.C.
Capital Cost		L.C.	F.C.	Total	L.C.	F.C.	Total
A. Water Supply Facilities							
1.	Pumping equipments	1,170	3,831	5,001	1,651	5,405	7,056
2.	Raw water main P/L	1,368	2,240	3,608	1,682	3,332	5,014
3.	Treatment plants	19,550	6,436	25,986	24,734	9,654	34,388
4.	Transmission main P/L including trans. pumping st. and distribution res.	31,278	32,533	63,811	49,147	52,056	101,203
5.	Communication equip.	300	800	1,100	300	800	1,100
6.	Subsidiary P/L	4,170	7,467	11,634	5,549	9,936	15,485
B. Dam							
7.	General items	3,003	1,307	4,310	3,282	1,457	4,739
8.	Sabaki intake and diversion canal	17,530	7,195	24,725	19,661	8,175	27,836
9.	Coffer dam and diversion channel	4,501	1,444	5,945	4,501	1,444	5,945
10.	Main dam	3,418	3,130	6,548	4,076	3,649	7,725
11.	Spillway	4,543	1,142	5,685	4,543	1,142	5,685
12.	River outlet facilities	35	163	198	35	163	198
C. Engineering and Adm.		9,087	6,769	15,856	11,916	9,721	21,637
Base Cost Total		99,953	74,457	174,410	131,074	106,934	238,008
D. Physical Contingency		14,993	11,169	26,162	19,661	16,040	35,701
Capital Cost Total		114,946	85,626	200,572	150,735	122,974	273,709

ECONOMIC COSTS ESTIMATED FOR WATER FACILITIES AND
CIVIL WORKS ON RARE RESERVOIR WITH P/L

Development Scale: 2.5 m³/sec

Items	Unit	Quantity	L. C.		F. C.	
			Unit Price (US\$)	Amount (US\$10 ³)	Unit Price (US\$)	Amount (US\$10 ³)
A. Water Supply Facilities						
1. Pumping Equipment (Intake/Transmission)	L.S.			1,651.0		5,405.0
2. Raw Water Main P/L ϕ 1500	m	4,500	373.8	1,682.0	740.5	3,332.0
3. Treatment Plant	L.S.			24,734.0		9,654.0
4. Transmission Main P/L ϕ 1500	m	51,000	373.8	19,063.8	740.5	37,765.5
ϕ 1200	m	18,000	157.6	2,836.8	498.1	8,964.9
ϕ 1000	m	9,000	126.5	1,138.5	351.6	3,164.6
Power Supply Facilities	L.S.			3,112.3		2,160.0
Reservoirs 30,000 m ³	units	8	1600x10 ³	12,800.0		
20,000 m ³	"	6	1400x10 ³	8,400.0		
10,000 m ³	"	1	750x10 ³	750.0		
Miscellaneous	L.S.			1,045.6		
Sub-Total				49,147.0		52,056.0
5. Communication Equipment	L.S.			300.0		800.0
6. Subsidiary P/L ϕ 600	m	28,000	101.8	2,850.4	179.1	5,015.3
ϕ 450	m	17,000	64.4	1,094.7	113.4	1,927.9
ϕ 350	m	43,000	37.3	1,603.9	69.6	2,992.8
Sub-Total				5,549.0		9,936.0
B. Dam						
7. General Item	L.S.			3,282.0		1,457.0
8. Sabaki intake and diversion channel						
Excavation	m ³	1,338,500	6	8,031.0	3	4,015.5
Stone pitching	m ²	722.600	2	1,445.2	1	722.6
Sabaki intake	L.S.			7,000.0		2,500.0
Miscellaneous	L.S.			3,184.8		936.9
Sub-Total				19,661.0		8,175.0

Items	Unit	Quantity	L. C.		F. C.	
			Unit Price (US\$)	Amount (US\$10 ³)	Unit Price (US\$)	Amount (US\$10 ³)
9. Cofferdam and diversion channel						
Excavation	m ³	100,300	6	601.8	3	300.9
Embankment	m ³	51,400	5	257.0	5	257.0
Concrete	m ³	25,200	100	2,520.0	30	756.0
Reinforcement bars	ton	760	900	684.0	80	60.8
Miscellaneous	L.S.			438.2		69.3
Sub-Total				4,501.0		1,444.0
10. Dam						
Excavation	m ³	201,400	6	1,208.4	3	604.2
Embankment	m ³	381,800	5	1,909.0	5	1,909.0
Concrete, in cap for grouting	m ³	1,100	100	110.0	20	22.0
Curtain and blanket grouting	m	7,700	25	192.5	100	770.0
Miscellaneous	L.S.			656.1		343.8
Sub-Total				4,076.0		3,649.0
11. Spillway						
Excavation	m ³	94,000	6	564.0	3	282.0
Backfill	m ³	2,600	1	2.6	0.50	1.3
Concrete	m ³	30,700	100	3,070.0	20	614.0
Reinforcement bars	ton	620	900	58.0	80	49.0
Steel anchor bars	ton	210	1,300	273.0	700	147.0
Miscellaneous	L.S.			75.4		48.1
Sub-Total				4,543.0		1,142.0
12. River outlet facilities						
	L.S.			35.0		163.0
Grand Total				119,161		97,213

BREAKDOWN OF O&M COST ON RARE PLAN

Unit: US\$10³Development Scale: 2.5 m³/sec

Year	Proposed System Supply, m ³ /d	Staff Salary	Chemical	Repair	Electricity	Total
1986	1,990	108.1	12.85	107.0	40.05	268.00
1987	5,510	⋮	35.62	⋮	110.91	361.63
1988	8,480	⋮	55.05	⋮	171.14	441.29
1989	12,000	⋮	77.67	⋮	241.53	534.30
1990	18,400	⋮	119.09	⋮	370.35	704.54
1991	28,000	⋮	193.65	⋮	602.19	1,010.94
1992	39,890	⋮	268.20	⋮	834.03	1,102.23
1993	52,000	⋮	342.76	⋮	1,065.86	1,623.72
1994	63,990	⋮	417.31	⋮	1,297.70	1,930.11
1995	75,990	210.7	491.87	⋮	1,529.54	2,339.11
1996	89,760	⋮	595.48	⋮	1,851.75	2,764.93
1997	106,010	⋮	699.09	⋮	2,173.95	3,190.74
1998	121,990	⋮	802.70	⋮	2,496.16	3,616.56
1999	138,000	⋮	906.31	⋮	2,818.36	4,042.37
2000	155,600	⋮	1,009.92	⋮	3,140.57	4,468.19
2001	170,490	⋮	1,087.56	⋮	3,382.01	4,787.27
2002	186,500	⋮	1,165.19	⋮	3,623.45	5,106.34
2003	202,480	⋮	1,242.83	⋮	3,864.90	5,425.43
2004	214,660	⋮	1,320.46	⋮	4,106.34	5,426.80
2005	216,000	⋮	1,398.10	⋮	4,347.78	6,063.58
⋮	⋮	⋮	⋮	⋮	⋮	⋮
⋮	⋮	⋮	⋮	⋮	⋮	⋮
2035	⋮	⋮	⋮	⋮	⋮	⋮

FINANCIAL COST ESTIMATES OF RARE RESERVOIR WITH RARE P/L

Unit: US\$10³
Development Scale: 2.5 m³/sec

	Economic Costs		Total	Sales Taxes		L.C.	Financial Costs	
	L.C.	P.C.		L.C.	P.C.		P.C.	Total
Capital Cost								
A. Water Supply Facilities								
1. Pumping equipments	1,651	5,405	7,056	634	2,285	5,405	7,690	7,690
2. Raw water main P/L	1,682	3,332	5,014	465	2,147	3,332	5,479	5,479
3. Treatment plants	24,734	9,654	34,388	3,553	28,287	9,654	37,941	37,941
4. Transmission main P/L including trans. pumping st. and distribution res.	49,147	52,056	101,203	9,859	59,006	52,056	111,062	111,062
5. Communication equip.	300	800	1,100	100	400	800	1,200	1,200
6. Subsidiary P/L	5,549	9,936	15,485	1,445	6,994	9,936	16,930	16,930
B. Dam								
7. General items	3,282	1,457	4,739	412	3,694	1,457	5,151	5,151
8. Sabaki intake and diversion canal	19,661	8,175	27,836	2,421	22,082	8,175	30,257	30,257
9. Coffor dam and diversion channel	4,501	1,444	5,945	517	5,018	1,444	6,462	6,462
10. Main dam	4,076	3,649	7,725	672	4,748	3,649	8,397	8,397
11. Spillway	4,543	1,142	5,685	494	5,037	1,142	6,179	6,179
12. River outlet facilities	35	163	198	17	52	163	215	215
C. Engineering and Adm.								
Base Cost Total	11,916	9,721	21,637	2,059	13,975	9,721	23,696	23,696
	131,074	106,934	238,008	22,648	153,722	106,934	260,656	260,656
D. Physical Contingency								
Capital Cost Total	19,661	16,040	35,701	3,397	23,058	16,040	39,098	39,098
	150,733	122,974	273,709	26,045	176,780	122,974	299,754	299,754
E. Price Contingency								
	-	-	-	-	111,487	40,758	152,245	152,245
F. Financial Cost Total								
	-	-	-	-	288,267	163,733	452,000	452,000

RARE RESERVOIR WITH P/L PLAN
COST AND WATER VOLUME STREAMS

Unit: US\$ 10⁶
Development scale: 2.5 m³/sec


End of fiscal year	No.	Water volume 10 ⁶ m ³	Capital cost	O & M cost
1983	-3	-	34.3	-
84	-2	-	137.1	-
85	-1	-	57.1	-
86	1	0.73	-	0.3
87	2	2.01	-	0.4
88	3	3.01	-	0.4
89	4	4.38	-	0.5
1990	5	6.57	5.7	0.7
91	6	10.22	5.7	1.0
92	7	14.60	-	1.3
93	8	18.98	11.3	1.6
94	9	23.36	11.3	1.9
95	10	27.74	-	2.3
96	11	32.85	1.1	2.7
97	12	38.69	-	3.1
98	13	44.53	5.7	3.5
99	14	50.37	5.7	4.0
2000	15	56.21	-	4.5
01	16	62.23	4.3	4.8
02	17	68.07	-	5.1
03	18	73.91	-	5.4
04	19	78.57	-	5.7
05	20	78.84	2.1	6.1
06	21	⋮	3.1	⋮
07	22	⋮	-	⋮
08	23	⋮	-	⋮
09	24	⋮	-	⋮

- to be continued -


Unit: US\$ 10⁶
Development scale: 2.5 m³/sec

End of fiscal year	No.	Water volume 10 ⁶ m ³	Capital cost	O & M cost
2010	25	78.84	5.2	6.1
11	26	⋮	1.1	⋮
12	27	⋮	-	⋮
13	28	⋮	-	⋮
14	29	⋮	-	⋮
15	30	⋮	4.0	⋮
16	31	⋮	44.7	⋮
17	32	⋮	-	⋮
18	33	⋮	-	⋮
19	34	⋮	-	⋮
2020	35	⋮	1.1	⋮
21	36	⋮	3.9	⋮
22	37	⋮	-	⋮
23	38	⋮	-	⋮
24	39	⋮	-	⋮
25	40	⋮	7.8	⋮
26	41	⋮	69.5	⋮
27	42	⋮	-	⋮
28	43	⋮	-	⋮
29	44	⋮	-	⋮
2030	45	⋮	3.9	⋮
31	46	⋮	-	⋮
32	47	⋮	-	⋮
33	48	⋮	-	⋮
34	49	⋮	-	⋮
2035	50	78.84	-	6.1


Discount rate 6%




Movement of Optimal Development Scale
by Changing Tariff




Development by the Rare Plan, m³/sec
**Movement of Optimal Development Scale
 by Changing Tariff**




Movement of Optimal Development Scale by Changing Tariff




Movement of Optimal Development
Scale by Changing Tariff



**Movement of Optimal Development
Scale by Changing Tariff**



Return on Investment on the Development
 (Rare Plan) **Scale of 2.5 m³/sec**



Sensitivity Tests for the Rare Plan

RARE P/L WITH RARE RESERVOIR PLAN
(FIRST PHASE DEVELOPMENT)

FINANCIAL INTERNAL RATE OF RETURN

No.	Fiscal Year	Capital Cost		O&M Cost	Gross Revenue	Net Benefit
		F.C.	L.C.			
1	1983	19,236	27,844	-	-	-47,080
2	1984	81,521	122,447	-	-	-203,968
3	1985	36,004	56,132	-	-	-92,136
4	1986	-	-	498	1,251	753
5	1987	-	-	673	3,463	2,790
6	1988	-	-	821	5,348	4,527
7	1989	-	-	994	7,542	6,548
8	1990	5,352	14,871	1,310	11,313	-10,220
9	1991	5,352	14,871	1,666	17,604	- 4,285
10	1992	-	-	2,118	25,146	23,028
11	1993	-	-	2,692	32,688	29,996
12	1994	-	-	3,422	40,230	36,808
13	1995	-	-	4,351	47,773	43,422
14	1996	(R) 5,859	1,866	4,904	53,846	41,217
15	1997	-	-	4,937	54,209	49,272
16	1998	-	-	⋮	⋮	⋮
17	1999	-	-	⋮	⋮	⋮
18	2000	-	-	⋮	⋮	49,272
19	2001	(R) 12,454	4,261	⋮	⋮	32,557
20	2002	-	-	4,937	54,209	49,272

Unit: US\$10³

<u>Discount Rate</u>	<u>Net Benefit</u>
0%	+110,317
2%	+6,154
3%	-33,195

FIRR = 2.2%

Remarks: (R) stands for Replacement Cost

PROJECTED INCOME STATEMENTS FOR RARE P/L WITH RARE RESERVOIR PLAN
(FIRST PHASE DEVELOPMENT)

Unit: US\$10³

No.	Year	Water Sold (10 m ³)	Average Water Rate(Ksh/m ³)	Operating		Income Before		Interest Payment	Net Income
				Revenue	Expense	Interest	Interest		
		Water Sales	OSM Cost	Depreciation					
1	1983	-	-	-	-	-	-	-	-
2	1984	-	-	-	-	-	-	-	-
3	1985	-	-	-	-	-	-	-	-
4	1986	690	13.6 (\$1.813)	1,251	498	25,351	-24,598	11,264	-35,862
5	1987	1,910	.	3,463	673	.	-22,561	10,912	-33,473
6	1988	2,950	.	5,348	821	.	-20,824	10,545	-31,369
7	1989	4,160	.	7,542	994	.	-18,803	10,129	-28,932
8	1990	6,240	.	11,313	1,310	.	-15,348	9,698	-25,046
9	1991	9,710	.	17,604	1,666	.	- 9,413	9,235	-18,648
10	1992	13,870	.	25,146	2,118	.	- 2,323	9,581	-11,904
11	1993	18,030	.	32,688	2,692	.	4,645	9,029	- 4,384
12	1994	22,190	.	40,230	3,422	.	11,457	8,412	3,045
13	1995	26,350	.	47,773	4,351	.	18,071	7,762	10,309
14	1996	29,700	.	53,846	4,904	.	23,591	7,060	16,531
15	1997	29,900	.	54,209	4,937	.	23,921	6,734	17,187
16	1998	5,921	18,000
17	1999	5,039	18,882
18	2000	4,093	19,828
19	2001	3,076	20,845
20	2002	2,880	21,041

PROJECTED CASH FLOW FOR BARE P/L WITH BARE RESERVOIR PLAN (FIRST PHASE DEVELOPMENT)

Unit: US\$10³

No. Year	Income Before Interest	Depreciation	Foreign Loan	Government Equity	Total Source	Capital Cost		Debt Service		Total Application	Increase in Cash	Cash at End	Debt Service Coverage
						Foreign Currency	Local Currency	Interest	Principal				
1 1983	-	-	19,236	27,844	47,080	19,236	27,844	-	-	47,080	0	0	-
2 1984	-	-	81,521	122,447	203,968	81,521	122,447	-	-	203,968	0	0	-
3 1985	-	-	36,004	56,132	92,136	36,004	56,132	-	-	92,136	0	0	-
4 1986	-24,598	25,351	-	-	753	-	-	11,264	4,713	15,977	-15,224	-15,224	0.047
5 1987	-22,561	-	-	-	2,790	-	-	10,913	5,065	15,977	-13,187	-28,411	0.175
6 1988	-20,824	-	-	-	4,527	-	-	10,545	5,432	15,977	-11,450	-39,861	0.283
7 1989	-18,803	-	-	-	6,548	-	-	10,129	5,848	15,977	-9,429	-49,290	0.410
8 1990	-15,348	-	5,352	14,871	30,226	5,352	14,871	9,698	6,279	36,200	-5,974	-55,264	0.626
9 1991	-9,413	-	5,352	14,871	36,161	5,352	14,871	9,235	6,742	36,200	39	-55,303	0.998
10 1992	-2,323	-	-	-	23,028	-	-	9,581	7,578	17,159	5,869	-49,434	1.342
11 1993	4,645	-	-	-	29,996	-	-	9,029	8,130	17,159	12,837	-36,597	1.748
12 1994	11,457	-	-	-	36,808	-	-	8,412	8,747	17,159	19,649	-16,948	2.145
13 1995	18,071	-	-	-	43,422	-	-	7,762	9,397	17,159	26,263	9,315	2.531
14 1996	23,591	-	-	-	48,942	-	-	7,060	10,099	17,159	31,783	41,098	2.852
15 1997	29,921	-	-	-	49,272	-	-	6,734	11,011	17,745	31,527	72,625	2.777
16 1998	-	-	-	-	-	-	-	5,921	11,824	17,745	-	104,152	-
17 1999	-	-	-	-	-	-	-	5,039	12,706	17,745	-	135,679	-
18 2000	-	-	-	-	-	-	-	4,093	13,652	17,745	-	167,206	-
19 2001	-	-	-	-	-	-	-	3,076	14,669	17,745	31,527	198,733	2.777
20 2002	-	-	-	-	-	-	-	2,880	16,111	18,991	30,281	229,014	2.594

RARE P/L WITH RARE RESERVOIR PLAN
(FULL DEVELOPMENT)

FIRR CALCULATION

No.	Fiscal Year	Capital Cost		O&M Cost	Gross Revenue	Net Benefit
		F.C.	L.C.			
1	1983	19,236	27,844	-	-	-47,080
2	1984	81,521	122,447	-	-	-203,968
3	1985	36,004	56,132	-	-	-92,136
4	1986	-	-	498	1,251	753
5	1987	-	-	673	3,463	2,790
6	1988	-	-	821	5,348	4,527
7	1989	-	-	994	7,542	6,548
8	1990	5,352	14,871	1,310	11,313	-10,220
9	1991	5,352	14,871	1,666	17,604	- 4,285
10	1992	-	-	2,118	25,146	23,028
11	1993	4,067	17,417	2,692	32,688	8,512
12	1994	4,067	17,417	3,422	40,230	15,324
13	1995	-	-	4,351	47,773	43,422
14	1996	(R) 5,859	1,866	4,952	56,584	43,907
15	1997	-	-	5,636	66,646	61,010
16	1998	4,067	8,632	6,415	76,690	57,576
17	1999	4,067	8,632	7,302	86,752	66,751
18	2000	-	-	8,311	96,814	88,503
19	2001	(R) 12,454	4,261	8,834	107,185	81,636
20	2002	-	-	9,390	117,247	107,857

Discount Rate	Net Benefit
0%	+254,455
3%	+39,432
4%	-2,225

FIRR 3.95%

Remarks: (R) stands for Replacement Cost

PROJECTED INCOME STATEMENTS FOR RARE P/L WITH RARE RESERVOIR PLAN
(FULL DEVELOPMENT)


Unit: US\$10³

No.	Year	Water Sold (10 m ³)	Average Water Rate (Ksh/m ³)	Operating		Income Before Interest	Interest Payment	Net Income
				Revenue	Expense			
				Water Sales	O&M Cost	Depreciation		
1	1983	-	-	-	-	-	-	-
2	1984	-	-	-	-	-	-	-
3	1985	-	-	-	-	-	-	-
4	1986	690	13.6 (\$1.813)	1,251	498	29,100	11,264	-39,611
5	1987	1,910	3,463	673	10,912	-37,222
6	1988	2,950	5,348	821	10,545	-35,118
7	1989	4,160	7,542	994	10,129	-32,681
8	1990	6,240	11,313	1,310	9,698	-28,795
9	1991	9,710	17,604	1,666	9,235	-22,397
10	1992	13,870	25,146	2,118	9,581	-15,653
11	1993	18,030	32,688	2,692	9,029	- 8,133
12	1994	22,190	40,230	3,422	8,412	- 704
13	1995	26,350	47,773	4,351	8,414	5,908
14	1996	31,210	56,584	4,952	7,693	14,839
15	1997	36,760	66,646	5,636	7,347	24,563
16	1998	42,300	76,690	6,415	6,514	34,661
17	1999	47,850	86,752	7,302	5,608	44,742
18	2000	53,400	96,814	8,311	5,290	54,113
19	2001	59,120	107,185	8,834	4,228	65,023
20	2002	64,670	117,247	9,390	3,983	74,774

PROJECTED CASH FLOW FOR BARE P/L WITH BARE RESERVOIR PLAN (FULL DEVELOPMENT)

Unit: US\$10³

No. Year	Income Before Interest	Depreciation	Foreign Loan	Government Equity	Total Source	Capital Cost		Debt Service		Total Application	Increase in Cash	Cash at End	Debt Service Coverage
						Foreign Currency	Local Currency	Interest	Principal				
1 1983	-	-	19,236	27,844	47,080	19,236	27,844	-	-	47,080	0	0	-
2 1984	-	-	81,521	122,447	203,968	81,521	122,447	-	-	203,968	0	0	-
3 1985	-	-	36,004	56,132	92,136	36,004	56,132	-	-	92,136	0	0	-
4 1986	-28,347	29,100	-	-	753	-	-	11,264	4,713	15,977	-15,224	-15,224	0.047
5 1987	-26,310	-	-	-	2,790	-	-	10,912	5,065	15,977	-13,187	-28,411	0.175
6 1988	-24,573	-	-	-	4,527	-	-	10,545	5,432	15,977	-11,450	-39,861	0.283
7 1989	-22,552	-	-	-	6,548	-	-	10,129	5,848	15,977	-9,429	-49,290	0.410
8 1990	-19,097	-	5,352	14,871	30,226	5,352	14,871	9,698	6,279	36,200	-5,974	-55,264	0.626
9 1991	-13,162	-	5,352	14,871	36,161	5,352	14,871	9,235	6,742	36,200	-39	-55,303	0.998
10 1992	-6,072	-	-	-	23,028	-	-	9,581	7,578	17,159	5,869	-49,434	1.342
11 1993	896	-	4,067	17,417	51,480	4,067	17,417	9,029	8,130	38,643	12,837	-36,597	1.748
12 1994	7,708	-	4,067	17,417	58,292	4,067	17,417	8,412	8,747	38,643	19,649	-16,948	2.145
13 1995	14,322	-	-	-	43,422	-	-	8,414	9,643	18,057	25,365	8,417	2.405
14 1996	22,532	-	-	-	51,632	-	-	7,693	10,364	18,057	33,575	41,992	2.859
15 1997	31,910	-	-	-	61,010	-	-	7,347	11,296	18,643	42,367	84,359	3.273
16 1998	41,175	-	4,067	8,632	82,974	4,067	8,632	6,514	12,129	31,342	51,632	135,991	3.770
17 1999	50,350	-	4,067	6,632	92,149	4,067	8,632	5,608	13,035	31,342	60,807	196,798	4.262
18 2000	59,403	-	-	-	88,503	-	-	5,290	14,251	19,541	68,962	265,760	4.529
19 2001	69,251	-	-	-	98,351	-	-	4,228	15,313	19,541	78,810	344,570	5.033
20 2002	78,757	-	-	-	107,857	-	-	3,983	16,804	20,787	87,070	431,640	5.189



Development Order and Scale of the Plans

WATER SUPPLY AUGMENTATION PROJECT OF NOMPASA-COASTAL AREA-HINTERLAND

DISCOUNT RATE IN PERCENT 10

TARIFF, KSH (US DOLLAR) 6.50 (0.87)

STAGE DEVELOPMENT

WZIMA PLAN

PARE PLAN

DEVELOP-
MENT SCALE
IN CMS

ANNUAL
NET BENEFIT
MIL. DOL.

	1	2	3	4	1	2	3	4	
3.0	0.	0.	0.	0.	0.5	0.5	0.5	1.0	-1.9
3.5	0.	0.	0.	0.	0.5	0.6	0.9	0.9	-1.1
4.0	0.	0.	0.	0.	0.5	1.8	1.3	0.4	-0.8
4.5	0.	0.	0.	0.	0.5	1.5	1.8	0.4	-0.4
5.0	0.	0.	0.	0.	0.5	1.8	2.3	0.4	-0.3
5.5	0.	0.	0.	0.	0.5	1.8	2.4	0.8	-0.1

WATER SUPPLY AUGMENTATION PROJECT OF MOMBASA-COASTAL AREA-HINTERLAND

DISCOUNT RATE IN PERCENT 10

TARIFF, KSH (US DOLLAR) 7.00 (0.93)

STAGE DEVELOPMENT

ZIWA PLAN

RARE PLAN

DEVELOP- ANNUAL
 MFNT SCALE ***** NET BENEFIT
 IN CMS ***** MIL. DOL.

	1	2	3	4	1	2	3	4	
3.0	0.	0.	0.	0.	0.5	0.4	1.2	0.9	0.5
3.5	0.	0.	0.	0.	0.5	0.4	1.7	0.9	1.2
4.0	0.	0.	0.	0.	0.5	1.6	0.9	1.0	1.8
4.5	0.	0.	0.	0.	0.5	1.6	1.4	1.0	2.3
5.0	0.	0.	0.	0.	0.5	1.6	1.9	1.0	2.5
5.5	0.	0.	0.	0.	0.5	1.6	2.4	1.0	2.5

WATER SUPPLY AUGMENTATION PROJECT OF MOMBASA-COASTAL AREA-HINTERLAND

DISCOUNT RATE IN PERCENT 10

TARIFF, KSH (US DOLLAR) 7.50 (1.00)

STAGE DEVELOPMENT

MZIMA PLAN

PARF PLAN

DEVELOPMENT SCALE IN CMS ***** ANNUAL NET BENEFIT MIL. DOL. *****

DEVELOPMENT SCALE IN CMS	1	2	3	4	1	2	3	4	ANNUAL NET BENEFIT MIL. DOL.
1.5	0.	0.	0.	0.	0.5	0.1	0.	0.9	-1.1
2.0	0.	0.	0.	0.	0.5	0.4	1.1	0.	0.7
2.5	0.	0.	0.	0.	0.5	0.4	1.0	0.6	0.8
3.0	0.	0.	0.	0.	0.5	0.4	1.7	0.9	2.4
3.5	0.	0.	0.	0.	0.5	0.4	1.7	0.9	3.4
4.0	0.	0.	0.	0.	0.5	1.4	0.9	1.2	4.2
4.5	0.	0.	0.	0.	0.5	1.4	1.2	1.4	4.8
5.0	0.	0.	0.	0.	0.5	1.4	1.6	1.5	5.1
5.5	0.	0.	0.	0.	0.5	1.4	2.1	1.5	5.2

WATER SUPPLY AUGMENTATION PROJECT OF KOMBASA-COASTAL AREA-HINTIRLAND

DISCOUNT RATE IN PERCENT 10

TARIFF, KSH (US DOLLAR) 8.00 (1.07)

STAGE DEVELOPMENT

MZIMA PLAN

PAFF PLAN

DEVELOPMENT SCALE IN CMS ***** ANNUAL NET BENEFIT MIL. DOL. *****

DEVELOPMENT SCALE IN CMS	1	2	3	4	1	2	3	4	ANNUAL NET BENEFIT MIL. DOL.
1.5	0.	0.	0.	0.	0.5	0.1	0.1	0.8	0.5
2.0	0.	0.	0.	0.	0.5	0.4	0.7	0.4	2.6
2.5	0.	0.	0.	0.	0.5	0.4	1.0	0.6	2.8
3.0	0.	0.	0.	0.	0.5	0.4	1.2	0.9	4.5
3.5	0.	0.	0.	0.	0.5	0.4	1.7	0.9	5.6
4.0	0.	0.	0.	0.	0.7	1.2	0.9	1.2	6.5
4.5	0.	0.	0.	0.	0.7	1.2	1.2	1.4	7.1
5.0	0.	0.	0.	0.	0.7	1.2	1.6	1.5	7.5
5.5	0.	0.	0.	0.	0.7	1.2	1.7	1.9	7.7

WATER SUPPLY AUGMENTATION PROJECT OF MOMBASA-COASTAL AREA-HINTERLAND

DISCOUNT RATE IN PERCENT 10

TARIFF (KSH (US DOLLAR) 2.50 (1.13)

STAGE DEVELOPMENT

MZIMA PLAN

RARE PLAN

DEVELOPMENT SCALE IN CMS ***** ANNUAL NPT BENEFIT MIL. DOL.

Development Scale (CMS)	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1.5	0.	0.	0.	0.	0.5	0.5	0.1	0.2	0.7	2.0										
2.0	0.	0.	0.	0.	0.5	0.5	0.4	0.5	0.6	4.3										
2.5	0.	0.	0.	0.	0.5	0.5	0.4	1.0	0.6	4.7										
3.0	0.	0.	0.	0.	0.5	0.5	0.4	1.0	1.1	6.6										
3.5	0.	0.	0.	0.	0.5	0.5	0.4	1.3	1.5	7.9										
4.0	0.	0.	0.	0.	0.5	0.5	0.4	1.6	1.5	8.9										
4.5	0.	0.	0.	0.	0.5	0.5	0.4	1.6	2.0	9.5										
5.0	0.	0.	0.	0.	0.5	0.5	0.4	1.2	2.3	9.8										
5.5	0.	0.	0.	0.	0.5	0.5	0.4	2.3	2.5	9.8										

ANNEX 6301-5

WATER SUPPLY AUGMENTATION PROJECT OF KOMPASA-COASTAL AREA-HINTERLAND

DISCOUNT RATE IN PERCENT 10

TARIFF/KSH (KHS DOLLAR) 9.00 (1.20)

STAGE DEVELOPMENT

RARE PLAN

DEVELOPMENT SCALE IN CMS 1 2 3 4 5 6 7 8 9 10
 ANNUAL NET BENEFIT MIL. DOL. 4 6 6 8 10 11 11 12 12 12

YZIMA PLAN

DEVELOPMENT SCALE IN CMS	1	2	3	4	1	2	3	4	ANNUAL NET BENEFIT MIL. DOL.
1.5	0.	0.	0.	0.	0.5	0.6	0.7	0.6	4.6
2.0	0.	0.	0.	0.	0.5	0.6	0.5	0.6	6.1
2.5	0.	0.	0.	0.	0.5	0.6	1.0	0.6	6.6
3.0	0.	0.	0.	0.	0.5	0.6	1.0	1.1	8.7
3.5	0.	0.	0.	0.	0.5	0.6	1.3	1.3	10.2
4.0	0.	0.	0.	0.	0.5	0.6	1.6	1.5	11.2
4.5	0.	0.	0.	0.	0.5	0.6	1.6	2.0	11.9
5.0	0.	0.	0.	0.	0.5	0.6	2.1	2.0	12.1
5.5	0.	0.	0.	0.	0.5	0.6	2.5	2.1	12.1

ANNEX 6301-6

WATER SUPPLY AUGMENTATION PROJECT OF WOMBASA-COASTAL AREA-HINTERLAND

DISCOUNT RATE IN PERCENT 10

TARIFF/KSH (US DOLLAR) 10.00 (1.33)

STAGE DEVELOPMENT

WZIMA PLAN

RARE PLAN

DEVELOPMENT SCALE IN CMS

ANNUAL NET BENEFIT MIL. DOL.

DEVELOPMENT SCALE IN CMS	1	2	3	4	1	2	3	4	ANNUAL NET BENEFIT MIL. DOL.
1.5	0.	0.	0.	0.	0.5	0.4	0.3	0.3	7.6
2.0	0.	0.	0.	0.	0.5	1.5	0.	0.	9.0
2.5	0.	0.	0.	0.	0.9	1.0	0.6	0.	9.8
3.0	0.	0.	0.	0.	0.9	1.7	0.4	0.	11.9
3.5	0.	0.	0.	0.	0.9	2.2	0.4	0.	13.1
4.0	0.	0.	0.	0.	0.9	2.6	0.5	0.	14.0
4.5	0.	0.	0.	0.	0.9	3.0	0.6	0.	14.6
5.0	0.	0.	0.	0.	0.9	5.5	0.3	0.3	14.3
5.5	0.	0.	0.	0.	1.9	2.5	1.5	0.	14.8

ANNEX 6301-7

OBJECTIVE FUNCTION AND DYNAMIC PROGRAMMING^{/1}

1. The problem whether the limited resources available are allocated in efficient ways is arisen in many fields. Though the problem given is quite simple, there are many difficulties encountered in treating this apparently simple and straightforward problem.

2. For tackling the problem mentioned above, it is necessary to express the problem in the precise mathematical form. The problem is expressed as follows;

$$(1) \quad R(x_1, x_2, \dots, x_n) = g_1(x_1) + g_2(x_2) + \dots + g_n(x_n)$$

subject to

$$(2) \quad (a) \quad x_1 + x_2 + \dots + x_n = x,$$

$$(b) \quad x_i \geq 0$$

where x_i denotes the quantity of resources assigned to the i th activity, $g_i(x_i)$ is the return function from the i th activity and $R(\cdot)$ is the objective function. The problem is to maximize Eq.(1) under the constraints of Eq.(2).

3. It can be considered that the above problem is solved by calculus using a Lagrange multiplier or by linear programming. However, in calculus the return function must be expressed in the functional form. Even though the return function can be expressed in the functional form, the problems that are arisen in applications are usually less amenable to route techniques. In linear programming, the objective function and constraints of Eq.(1) and (2) must be expressed in a linear function. As the technique called dynamic programming developed by R.E. Bellman is applicable to the problems which are not solved by calculus or linear programming, dynamic programming is applied to the optimization study.

^{/1} R.E. Bellman, Applied Dynamic Programming, Princeton University Press, Princeton, New Jersey, 1962.

4. Dynamic programming is explained by the classical stagecoach problem. A coward salesman must travel the territory of unfriendly Indian 100 years ago. Though his starting point and destination is fixed, he can travel by some combination of the routes available as shown page 4 of 5 of the ANNEX. He likes to travel the Indian territory by the safest route.

5. The figure written between the numbered blocks is the cost to buy the life insurance policies offered to stagecoach passengers. The safest route is defined as the cheapest route to buy life insurance policy.

6. It is possible to find the cheapest route by evaluating all the possible routes. However, if the problem is large and complex, it takes much time, even though it not impossible to find the cheapest route by evaluating all the possible routes. For saving the computation time, the problem is solved by dynamic programming.

7. The procedures to find the cheapest route by dynamic programming are as follows. First, the numbered blocks are defined as "state" and there are five stage from the starting point to the destination. The cheapest route from the first stage to each state of the second stage is fixed like 1 - 2, 1 - 3 and 1 - 4. The cost to buy the life insurance policy is shown in the block with parenthesis. The cheapest route from the second stage to "state 5" of the third stage is obtained by comparing the sum of the current cost from each state of the second stage to the state 5 and the cheapest cost upto each state of the second stage, so that the cheapest route to come "state 5" is 1 - 2 - 5 and the cost is 5.

8. By the procedure mentioned above, the cheapest route on each state of each stage is obtained. There is only one way to come "state 10" from the fourth stage, so that the cheapest route from "state 1" to "state 10" is exclusively determined and the route is traced back by the arrows of the reverse direction.

9. The objective function to maximize the difference between benefits yielded from the projects and costs charged to the project is mathematically expressed as follows;

$$\max \sum_j \sum_i (B_{ij} - C_{ij})$$

subject to


$$\sum_i X_{ij} \leq X_j,$$

$$\sum_j \sum_i X_{ij} \leq Y, \text{ and}$$

$$X_{ij} \geq 0$$

where X_{ij} is the development scale of i stage on the j plan and X_j is the physical limit of the j plan. For the development scale selected arbitrarily Y , the maximum net benefit is searched. It is quite hard to find the maximum value of the above equation, because the numerical combinations can be conceivable. To overcome this situation, applied is dynamic programming.

10. A computer program of the optimization study is made by dynamic programming. The flow chart of it is shown in page 5 of 5 of the ANNEX.



5

4


3

2


1

Stage: 1


Transportation Routes of Stagecoach



Flow Chart of Dynamic Programming



COAST PROVINCE WATER BRANCH ORGANIZATION



MINISTRIES AND AGENCIES INVOLVED IN
COMMUNITY WATER SUPPLIES

- a. The Nairobi City Council is responsible for the water supply and sewage systems of Nairobi.
- b. Five municipalities and two county councils operate their urban water supply systems under the direction of the Ministry of Local Government.
- c. Several hundred small rural water supply schemes are operated by county councils.
- d. The Kenya Railways operates about 100 water schemes supplying staff houses and adjacent villages.
- e. The President's Office plans and budgets water supplies for new settlement areas, usually with the Water Engineering Department of MOWD as the executing agency.
- f. The Ministry of Cooperative Development administers government grants to all self-help schemes in rural areas.
- g. The Ministry of Health is responsible for potable water supply quality surveillance from the community-health point of view.

MAIN FEATURES OF THE SECOND MZIMA PLAN AND THE RARE PLAN

<u>Items</u>	<u>Second Mzima Plan</u>	<u>Rare Plan</u>
I. Development Scale (m ³ /s)	1.2	2.5
II. Dam and Reservoir		
Catchment Area (km ²)	4,050	1,500
Type of Dam	Rockfill	Rockfill
Height of Dam (m)	34	33
Reservoir Effective Storage (10 ⁶ m ³)	21	27.6
Fill Volume (10 ³ m ³)	450	380
Design Flood (m ³ /s)	1,550	1,305
III. Diversion Canal		
Length (km)	-	40
Excavation (10 ³ m ³)	-	1,339
Capacity (m ³ /s)	-	13.3
IV. Water Supply Facilities		
Raw Water Main P/L		
Diameter (mm) & Length (km)	-	1,500mm - 4.5km
Transmission Main P/L		
Diameter (mm) & Length (km)	{ 1,350mm - 86km 1,100mm - 43km 1,000mm - 88km	{ 1,500mm - 51km 1,200mm - 18km 1,000mm - 9km
Pumping Station (unit)	-	2
Treatment Plant (@55,000m ³ /d)(unit)	-	5
V. Costs ^{/1}		
Economic Cost (US\$ million)	270	274
Foreign Currency Portion	163	123
Local Currency Portion	107	151

<u>Items</u>	<u>Second Mzima Plan</u>	<u>Rare Plan</u>
Financial Cost ^{/2} (US\$ million)	421	452
Foreign Currency Portion	214	164
Local Currency Portion	207	288
O&M Cost ^{/3} (Economic) (US\$10 ³)	101	6,064

VI. Evaluation

Return on Investment ^{/4} (%)	5.5	8.3
FIRR ^{/5} (%)	3.4	4.0

/1 Excluding replacement cost.

/2 Excluding replacement cost and interest during construction.

/3 Under full supply conditions.

/4 When the estimated water rate of 5.6 KSh/m³ is applied to evaluate the water at the outlet of distribution reservoir.

/5 When the water rate of 13.6 KSh/m³ is applied under the same conditions as mentioned in /4.

USA