

Due to the topographic and geological conditions described above, three plans are compared for the penstock layout; the open plan, the tunnel plan and a combination of the open and tunnel plans.

The layout in each plan is shown in Fig. 9-11. The longitudinal section is shown in Fig. 9-12. An extension of each plan is described below. Comparing the construction costs for the three plans above, the tunnel plan of Route-2 provides the best economic factor.

Route	Type of Penstock	Length (m)		Total Length (m)	Adit (m)
		Open	Tunnel		
Route 1	Open	1,595	400	1,995	0
Route 2	Tunnel	0	1,693	1,693	160
Route 3	Tun. Open	450	1,225	1,675	100

(4) Turbine Type

Judging from the plan data (net head 359.4 m, maximum discharge 27 m³/s), either a Francis or Pelton turbine may be considered. As this site was selected to deal with the peak load, a Francis turbine which provides high maximum efficiency and large maximum output is advantageous as shown in Table 9-15.

9.3.4 Optimum Development Plan

The previous study regarding a development plan on the Naranjo River confirmed as follows.

- General layout of Los Llanos hydroelectric project is as shown in Fig. 9-13.
- 62 m high gate type concrete gravity dam is constructed at the downstream axis with effective storage of 653 x 10³ m³ allowing daily regulation as shown in Fig. 9-14.
- Peak running time is 5 hours.
- Maximum discharge is 27 m³/s as shown in Fig. 9-15.
- Power plant with 2 units of 42.5 MW is built on the left bank of the Paquita River.
- Compensation is estimated in the project cost in order to make up a poor African palm harvest owing to the decreased water caused by the project.

(1) **Basic Conditions for Study**

(a) **Annual Cost Method**

In making examinations of the study for optimum development plan, the technique of taking a standard type of thermal power station that would have been constructed if the Project did not exist as an alternative facility and considering the cost of that thermal as the benefit was used.

The alternative facility selected was a combination of gas turbine and diesel engine power plants that could be considered as an alternative to Los Llanos Power Station.

In making the examination, market prices were used with the annual surplus benefit (B-C) and the benefit-cost ratio (B/C) as indices. Cost (C) is the equalized annual cost for the service life (50 years) of the hydro power facilities and Benefit (B) is the equalized cost of the alternative thermal.

The particulars of the alternative thermal power station are given in Table 9-16.

(b) **Annual Cost**

The equalized annual cost of a hydropower facility consists of depreciation, interest and operation and maintenance cost. The cost is obtained by multiplying the construction cost by the annual cost factor.

$$\begin{aligned} \text{Annual Cost} &= \text{Annual Cost Factor} \times \text{Construction Cost} \\ &= \text{Depreciation} + \text{Interest} + \text{Operation and Maintenance Cost} \end{aligned}$$

$$\text{Depreciation} + \text{Interest} = \text{Construction Cost} \times \text{Capital Recovery Factor}$$

$$\text{Capital Recovery Factor} = \frac{i(1+i)^n}{(1+i)^n - 1}$$

where, n: service life,

civil structure 50 yr

hydraulic equipment and facilities 35 yr

electrical equipment and facilities 35 yr

i: discount rate, 12 percent

Capital Recovery Factor:

Civil structure	12.0%
Hydraulic equipment and facilities	12.2%
Electrical equipment and facilities	12.2%

Depreciation + Interest = Construction Cost x 12%

Operation and Maintenance Cost = Construction Cost x 1%

Therefore, Annual Cost = Construction Cost x 13%

(c) Conception of Benefit

The benefit of the Project is to be the total of the overall depreciation, interest, maintenance and administration cost, and fuel cost of the alternative thermal power station. The output and energy production of the Project used for benefit calculations are obtained according to the conditions indicated below. These are respectively defined as effective output and effective electric energy. Transmission line losses are not considered in the study below.

- i) The effective output is the dependable peak output less the station power ratio of 0.3 percent, accident ratio of 0.3 percent, and repair ratio of 2.0 percent. The dependable peak output is the average value of monthly minimum peak outputs during the energy calculation period (25 years).

$$\text{Effective Output} = (1 - 0.003) \times (1 - 0.003) \times (1 - 0.02) \times \text{Dependable Peak Output}$$

- ii) The effective electric energy is the annual energy production less the station service ratio of 0.3 percent.

$$\text{Effective Electric Energy} = (1 - 0.003) \times \text{Annual Effective Energy}$$

Furthermore, firm electric energy is defined as the electric energy produced during the necessary equivalent peak duration. The secondary electric energy is defined as all other electric energy.

- iii) $\text{Benefit} = \text{Effective Output} \times \text{kW Value} + \text{Firm Energy} \times \text{Firm kWh Value} + \text{Secondary Energy} \times \text{Secondary kWh Value}$

(d) Result

Based on project cost, firm power, firm energy and secondary energy estimated for optimum development plan, benefit cost relation (B-C) have been estimated as shown in Table 9-17. The result reveals that Los Llanos Project is feasible.


(2) Optimum Development Plan

The projected outline for optimum development plan is as follows.

High Water Level	EL. 477.4 m
Low Water Level	EL. 470.0 m
Effective Storage Capacity	653 x 10 ³ m ³
Tail Water Level	EL. 84.0 m
Gross Head	389.7 m
Effective Head	359.4 m
Maximum Discharge	27 m ³ /s
Installed Capacity	85 MW
Firm Power Output	82.7 MW
Annual Available Energy	389 GWh
Firm Energy	107 GWh
Secondary Energy	282 GWh


Main Facilities

Dam	Concrete Gravity Type	62.4 m x 114 m
Headrace		3.1 m x 5,540 m
Surge Tank		8.0 m x 58 m
Penstock	Tunnel Type	3.10 m - 1.25 x 1,570 m
Powerhouse	Open Type	
	Francis Turbine	



REPUBLIC OF COSTA RICA
 LOS LLANOS HYDROELECTRIC
 POWER DEVELOPMENT PROJECT
 Naranjo River
 Master Plan Layout

Fig. 9-1



REPUBLIC OF COSTA RICA
 LOS LLANOS HYDROELECTRIC
 POWER DEVELOPMENT PROJECT

Los Llanos
 Alternative Layout

Fig. 9-2

Los Llanos P/S

CA	135.000
CA (1961)	135.000
CA (1962)	135.000
CA (1963)	135.000

Los Llanos (1)

CA	113.100
CA (1961)	113.100
CA (1962)	113.100
CA (1963)	113.100

Los Llanos (A)


CA	157.000
CA (1961)	157.000
CA (1962)	157.000
CA (1963)	157.000


Los Llanos (B)

CA	121.7	31.8
CA (1961)	121.7	31.8
CA (1962)	121.7	31.8
CA (1963)	121.7	31.8

Quepos


CA	118.0	31.8
CA (1961)	118.0	31.8
CA (1962)	118.0	31.8
CA (1963)	118.0	31.8





Reservoir Operation at Los Llanos(2)

(Available Discharge)



Period : May 1988 to Apr. 1989

Fig. 9-3 Reservoir Operation at Los Llanos (2)

Monthly Average Inflow

Storage Capacity 22.5 x 10⁶ m³













Fig. 9-4 Study on Reservoir Storage Volume at Los Llanos

[The page contains extremely faint and illegible text, likely a scan of a document with very low contrast or significant noise. No specific content can be transcribed.]



REPUBLIC OF COSTA RICA
LOS LLANOS HYDROELECTRIC POWER DEVELOPMENT PROJECT
Los Llanos Dam (Case I-2) Plan and Sections
Fig. 9-5



REPUBLIC OF COSTA RICA
LOS LLANOS HYDROELECTRIC POWER DEVELOPMENT PROJECT
Tocarí Supply Water Facility Plan and Sections
Fig. 9-6






Fig. 9-7(1) Area-Capacity Curve 1/2
(Downstream dam site)

11-6






Fig. 9-7 (2) Area-Capacity Curve 2/2
(Downstream dam site)

[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is too light to transcribe accurately.]



Upstream Dam Site



Downstream Dam Site



Middlestream Dam Site



Los Llanos Dam
Cross Section of
Alternative Dam Site

Fig. 9-8

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes that this is crucial for ensuring transparency and accountability in the organization's operations. The records should be kept up-to-date and accessible to all relevant personnel.

2. The second part of the document outlines the various methods and tools used for data collection and analysis. It includes a detailed description of the survey process, the design of the questionnaires, and the statistical techniques employed to analyze the data. The goal is to provide a comprehensive overview of the data and its implications for the organization's strategy.

3. The third part of the document presents the findings of the study. It includes a series of tables and charts that illustrate the key results. The data shows a clear trend towards increased efficiency and productivity, which is attributed to the implementation of the new system. The findings also highlight the importance of ongoing training and support for the staff to ensure the successful adoption of the system.

4. The fourth part of the document discusses the implications of the findings and provides recommendations for future research and action. It suggests that the organization should continue to monitor the performance of the system and make adjustments as needed. Additionally, it recommends that the organization should invest in further training and development to ensure that the staff is fully equipped to handle the challenges of the new system.

5. The final part of the document concludes the report and expresses the author's appreciation for the support and assistance provided by the organization's management and staff. It also includes a list of references and a bibliography of the sources used in the study.

- Upstream Damsite
- - - Middlestream Damsite
- · - · - Downstream Damsite




Fig.9-9 Cross Section Area~Dam Height Curve






Fig. 9-10 Headrace Tunnel Layout





Remarks

==== Open section

----- Tunnel section

Penstock
Alternative Layout

Fig. 9-11





Fig. 9-12(1) PROFILE OF PESTOCK
OPEN TYPE







Fig. 9-12(2) PROFILE OF PENSTOCK TUNNEL TYPE








REPUBLIC OF COSTA RICA
 LOS LLANOS HYDROELECTRIC POWER
 DEVELOPMENT PROJECT


GENERAL PLAN

Fig. 9-13 Date:


P L A N




UPSTREAM ELEVATION




SECTION A-A



SECTION B-B



DIVERSION TUNNEL



REPUBLIC OF COSTA RICA	
LOS LLANOS HYDROELECTRIC POWER DEVELOPMENT PROJECT	
Los Llanos Dam	
Plan and Sections	
Fig.9-14	




Fig. 9-15 Study on Maximum Discharge

Table 9-1 Project Outline of Naranjo River Basin

Item	Reyes	Milagro	Los Llanos	Los Llanos-A	Nara
Catchment Area (km ²)	68.0	27.0	143.7	143.7	28.0
Annual Inflow (m ³ /sec)	6.08	2.94	18.05	18.05	4.08
High Water Level (EL. m)	880	1,310	485	485	615
Low Water Level (EL. m)	840	1,310	475	475	615
Effective Storage Capacity (10 ⁶ m ³)	23.8	0	1.5	1.5	0
Tail Water Level (EL. m)	600	690	84	300	135
Gross Head (m)	280	620	401	185	480
Effective Head (m)	255	577	365	167	432
Maximum Discharge (m ³ /sec)	10.8	6.3	31.0	31.0	6.2
Installed Capacity (MW)	23.3	30.8	95.8	43.7	22.7
Main Facilities					
Dam Type	Rockfill	Concrete Gravity	Concrete Gravity	Concrete Gravity	Concrete Gravity
Height x Length	113 m x 250 m	10 m x 70 m	53 m x 105 m	53 m x 105 m	10 m x 100 m
Headrace (D x L)	2.4 m x 3,600 m	2.4 m x 4,000 m	3.2 m x 5,900 m	3.2 m x 2,400	2.4 m x 2,800 m
Surge Tank (D x H)	9.1 m x 55 m	Head Tank	8.0 m x 92 m	8.0 m x 80 m	Head Tank
Penstock Type	Open	Open	Open	Open	Open
D x L	1.5 m x 600 m	1.2 m x 1,100 m	2.75 m x 1,465 m	2.75 m x 1,160 m	1.2 m x 1,550 m
Powerhouse Type	Open	Open	Open	Open	Open
Type of Turbine	Pelton	Pelton	Pelton	Pelton	Pelton

Table 9-2 Estimation of Electric Energy Generation

Item	Unit	Los Reyes	Milagro	Nara	Los Llanos	Los Llanos-A
Average Inflow	m ³ /s-d	6.08	2.94	4.08	18.05	18.05
Maximum Discharge	m ³ /s	10.80	6.30	6.20	31.00	31.00
Effective Storage Capacity	10 ⁶ m ³	23.80	0	0	1.50	1.50
Available Discharge	m ³ /s-d	6.06	2.85	3.63	16.73	16.73
Over Flow	m ³ /s-d	0.02	0.09	0.45	1.32	1.32
	10 ⁶ m ³	0.6	2.8	14.2	41.6	41.6
Firm Discharge	m ³ /s-d	3.48 [*]	0.62	0.64	3.29	3.29
Firm Power Discharge	m ³ /s	10.80 [*]	0.62	0.64	13.16 [*]	13.16
Maximum Output	MW	23.3	30.8	22.7	95.8	43.7
Firm Power	MW	22.1	2.9	2.3	39.5	18.1
Annual Energy (Monthly base)	GWh	108.9	120.9	115.3	448.7	205.3
Available Energy	GWh	108.9	114.9	109.5	426.3	195.0

Note: The value of firm discharge at Los Reyes is to be regulated by reservoir operation.

Table 9-3 (1) Energy Production of Los Reyes Scheme

Year	Unit : GWh												Average
	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.	
1970	0.0	0.0	0.0	14.3	16.5	16.5	12.9	7.7	6.8	3.6	3.8	4.9	86.9
1971	16.5	16.5	16.5	16.5	16.5	16.5	15.1	7.2	7.2	7.2	7.2	7.2	149.8
1972	9.8	8.1	7.8	9.8	11.7	16.5	13.6	6.3	6.3	6.3	6.3	6.3	108.6
1973	6.3	16.3	14.6	16.5	16.5	16.5	12.3	9.2	8.4	3.4	2.6	2.9	125.4
1974	9.8	16.5	11.1	12.7	16.5	16.5	13.0	4.8	4.8	4.8	4.8	4.8	119.8
1975	10.4	11.5	12.3	16.3	16.5	16.5	16.5	5.6	5.6	5.6	5.6	5.6	127.9
1976	5.0	8.6	6.7	7.3	12.7	15.7	9.6	4.5	2.5	1.9	1.7	2.1	78.2
1977	5.1	8.6	6.0	13.5	15.5	16.5	14.3	6.2	3.0	3.0	3.0	5.1	99.7
1978	7.0	12.2	12.3	14.8	16.5	16.5	13.5	6.5	4.4	4.4	4.4	4.4	116.9
1979	10.9	12.2	11.1	13.5	16.5	16.5	13.3	6.7	5.0	5.0	5.0	5.0	120.4
1980	7.6	11.6	11.8	11.8	13.6	16.1	16.5	7.2	4.0	2.6	2.4	4.6	109.7
1981	16.4	16.5	11.8	15.6	11.5	15.5	13.2	5.4	4.4	3.8	3.8	3.8	121.5
1982	12.3	8.5	8.6	8.6	11.2	13.6	7.1	3.2	2.0	1.9	2.3	2.6	81.8
1983	3.7	8.1	6.2	8.3	14.5	16.5	16.5	8.6	4.1	4.1	4.1	4.1	98.9
1984	10.9	14.0	16.2	13.0	16.2	16.5	14.8	4.9	2.3	2.3	2.3	2.3	115.5
1985	6.3	10.3	10.8	15.6	16.5	16.5	14.8	10.3	4.0	4.4	4.4	4.4	118.2
1986	8.1	10.9	10.3	8.8	11.1	16.5	10.5	4.5	2.5	1.7	2.1	2.4	89.5
1987	7.9	9.3	12.2	15.0	11.1	12.1	9.1	5.0	2.7	1.7	1.5	1.8	89.4
1988	6.2	11.9	12.4	16.5	16.5	16.5	9.5	4.6	5.2	5.2	5.2	5.2	115.1
1989	6.8	8.3	8.4	12.9	16.5	14.3	10.2	9.4	4.2	3.3	3.3	3.3	100.8
1990	9.8	12.3	12.7	12.9	14.1	16.5	13.5	7.9	5.9	3.8	3.8	3.8	116.8
1991	7.5	11.8	11.0	11.1	12.3	14.3	10.2	6.4	3.1	2.6	1.6	1.9	92.7
1993	9.0	7.8	8.4	13.6	16.5	16.5	9.5	4.8	2.7	3.1	3.1	3.1	98.1
Total	193.1	251.6	239.3	284.5	320.0	348.6	276.5	139.0	94.2	82.0	80.3	86.5	2395.7
Average	8.8	11.4	10.9	12.9	14.5	15.8	12.6	6.3	4.3	3.7	3.6	3.9	108.9
Min.	3.7	7.8	6.0	7.3	11.1	12.1	7.1	3.2	2.0	1.7	1.5	1.8	78.2
Max.	16.5	16.5	16.5	16.5	16.5	16.5	16.5	10.3	8.4	7.2	7.2	7.2	149.8

Installed Capacity: 23.3 MW
 Maximum Discharge : 10.80 m³/s
 Effective Head : 249.00 m
 Power Efficiency : 0.84
 Effective Storage Capacity : 23.8 * 10⁶ m³

Table 9-3 (2) Energy Production of Milagro Scheme

Year	Unit : GWhr												Average
	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.	
1970	0.0	0.0	0.0	16.0	20.1	22.3	14.4	8.6	7.6	4.1	4.3	5.5	102.8
1971	19.4	22.3	20.1	22.3	22.3	22.3	16.8	7.3	6.7	3.4	2.3	4.8	169.8
1972	11.0	9.0	8.7	11.0	13.0	18.8	15.2	7.8	3.5	2.4	2.1	3.5	106.1
1973	7.0	18.2	16.4	22.3	22.3	22.3	13.7	10.3	9.4	3.8	2.5	3.3	151.4
1974	11.0	19.5	12.4	14.2	19.7	22.3	14.5	5.5	3.3	2.3	2.3	2.7	129.7
1975	11.6	12.9	13.7	18.3	22.3	22.3	20.7	8.1	4.2	2.2	1.7	2.0	140.0
1976	5.5	9.6	7.4	8.1	14.2	17.6	10.7	5.0	2.8	2.1	1.9	2.4	87.5
1977	5.7	9.6	6.8	15.1	17.3	20.8	15.9	7.0	3.2	2.2	2.1	5.7	111.4
1978	7.9	13.6	12.4	16.5	20.0	22.3	15.1	7.2	3.8	2.6	2.3	4.3	129.3
1979	12.2	13.6	12.4	15.1	21.7	22.3	14.9	7.4	5.0	3.0	2.1	3.4	133.1
1980	8.5	12.9	13.2	13.2	15.2	18.0	19.8	8.0	4.4	3.0	2.6	5.2	123.9
1981	18.4	21.2	13.2	17.4	12.9	17.3	14.8	6.0	4.9	2.9	3.0	4.0	135.9
1982	13.8	9.5	9.6	9.6	12.5	15.2	8.0	3.5	2.3	2.1	2.5	2.9	91.5
1983	4.2	9.0	6.9	9.2	16.2	20.3	20.2	9.6	4.7	3.8	3.1	3.3	110.7
1984	12.1	15.6	18.1	14.5	18.1	20.9	16.6	5.5	2.6	1.9	1.5	1.8	129.1
1985	7.0	11.6	12.1	17.5	19.7	22.3	16.6	11.6	4.5	2.4	1.3	2.5	129.4
1986	9.0	12.1	11.6	9.9	12.5	19.3	11.8	5.0	2.8	1.9	1.5	2.7	100.1
1987	8.8	10.4	13.7	16.8	12.4	13.6	10.2	5.6	3.0	1.9	1.6	2.0	100.0
1988	6.9	13.3	13.9	21.1	22.3	22.3	10.7	5.2	3.0	1.7	1.3	1.8	123.4
1989	7.6	9.3	9.4	14.5	20.8	16.0	11.4	10.5	4.7	2.7	2.4	3.5	112.7
1990	10.9	13.7	14.2	14.4	15.7	22.3	15.1	8.8	6.6	3.0	2.1	3.4	130.3
1991	8.4	13.2	12.3	12.4	13.7	15.9	11.5	7.1	3.4	2.9	1.8	2.1	104.8
1993	10.1	8.8	9.4	15.2	22.3	18.6	10.7	5.3	3.0	2.0	1.8	2.6	109.8
Total	216.9	289.1	269.4	328.6	387.0	432.7	314.6	157.6	91.9	56.2	46.4	69.6	2660.0
Average	9.9	13.1	12.2	14.9	17.6	19.7	14.3	7.2	4.2	2.6	2.1	3.2	120.9
Min.	4.2	8.8	6.8	8.1	12.4	13.6	8.0	3.5	2.3	1.7	1.3	1.8	87.5
Max.	19.4	22.3	20.1	22.3	22.3	22.3	20.7	11.6	9.4	4.1	4.3	5.7	169.8

Table 9-3 (3) Energy Production of Los Llanos Scheme (1)

Year	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Unit : GWh		
												Apr.	Average	
1970	0.0	0.0	0.0	62.0	69.3	69.3	55.9	33.4	29.6	15.8	16.7	21.3	373.4	
1971	69.3	69.3	69.3	69.3	69.3	69.3	65.5	28.5	26.1	13.1	9.0	18.5	576.4	
1972	42.8	35.2	34.0	42.8	50.7	69.3	59.3	30.3	13.5	9.2	8.3	13.5	408.9	
1973	27.3	69.3	63.7	69.3	69.3	69.3	53.3	40.0	36.7	14.9	9.8	12.8	535.6	
1974	42.6	69.3	48.1	55.4	69.3	69.3	56.4	21.3	12.7	9.1	8.9	10.7	473.2	
1975	45.1	50.1	53.3	69.3	69.3	69.3	69.3	31.7	16.5	8.7	6.6	7.8	497.0	
1976	21.5	37.4	28.9	31.5	55.3	68.3	41.6	19.6	10.9	8.3	7.5	9.1	340.1	
1977	22.0	37.5	26.3	58.8	67.3	69.3	62.0	27.1	12.4	8.7	8.1	22.2	421.7	
1978	30.6	53.0	53.6	64.2	69.3	69.3	58.5	28.1	14.7	10.1	8.8	16.8	477.0	
1979	47.3	58.0	48.4	58.7	69.3	69.3	57.8	28.9	19.5	11.6	8.0	13.3	485.2	
1980	33.1	50.3	51.4	51.2	59.1	69.3	69.3	31.2	17.3	11.5	10.1	20.1	473.7	
1981	69.3	69.3	51.2	67.7	50.1	67.3	57.4	23.5	19.2	11.3	11.5	15.4	513.2	
1982	53.6	37.0	37.5	37.4	48.6	59.1	31.0	13.7	8.8	8.2	9.9	11.1	356.0	
1983	16.2	35.1	27.0	35.9	63.2	69.3	69.3	37.4	18.4	15.0	12.2	12.7	411.6	
1984	47.2	60.8	69.3	56.4	69.3	69.3	64.4	21.5	10.0	7.2	5.7	6.8	487.9	
1985	27.3	45.0	47.0	68.0	69.3	69.3	64.4	45.0	17.4	9.3	6.9	9.6	478.5	
1986	35.2	47.2	45.0	38.4	48.4	69.3	45.8	19.6	10.7	7.5	6.0	10.4	383.6	
1987	34.3	40.5	53.2	65.4	48.1	52.8	39.7	21.7	11.7	7.5	6.4	7.7	388.9	
1988	26.9	51.9	54.0	69.3	69.3	69.3	41.5	20.1	11.8	6.5	4.9	6.9	432.3	
1989	29.4	36.0	36.6	56.2	69.3	62.3	44.4	40.8	18.4	10.6	9.1	13.6	426.8	
1990	42.4	53.4	55.4	56.0	61.1	69.3	58.7	34.4	25.7	11.5	8.3	13.3	489.5	
1991	32.6	51.2	48.0	48.4	53.4	62.0	44.6	27.7	13.3	11.2	7.1	8.3	407.7	
1993	39.3	34.1	36.5	59.1	69.3	69.3	41.4	20.8	11.9	7.7	7.2	10.2	406.8	
Total	835.4	1085.9	1037.6	1228.8	1367.7	1480.6	1195.7	612.8	357.4	218.7	180.4	270.8	9871.8	
Average	38.0	49.4	47.2	55.9	62.2	67.3	54.3	27.9	16.2	9.9	8.2	12.3	448.7	
Min.	16.2	34.1	26.3	31.5	48.1	52.8	31.0	13.7	8.8	6.5	4.9	6.8	340.1	
Max.	69.3	69.3	69.3	69.3	69.3	69.3	69.3	45.0	36.7	15.8	16.7	22.2	576.4	

Installed Capacity: 95.8 MW
 Maximum Discharge: 31.00 m³/s
 Effective Head: 365.00 m
 Power Efficiency: 0.84
 Effective Storage Capacity: 1.5 * 10⁶ m³

Table 9-3 (4) Energy Production of Los Llanos Scheme (A)

Year	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Unit : GWh	
												Apr.	Average
1970	0.0	0.0	0.0	28.4	31.7	31.7	25.6	15.3	13.6	7.2	7.6	9.7	170.8
1971	31.7	31.7	31.7	31.7	31.7	31.7	30.0	13.0	11.9	6.0	4.1	8.5	263.7
1972	19.6	16.1	15.6	19.6	23.2	31.7	27.1	13.9	6.2	4.2	3.8	6.2	187.1
1973	12.5	31.7	29.1	31.7	31.7	31.7	24.4	18.3	16.8	6.8	4.5	5.8	245.1
1974	19.5	31.7	22.0	25.4	31.7	31.7	25.8	9.7	5.8	4.1	4.1	4.9	216.5
1975	20.7	22.9	24.4	31.7	31.7	31.7	31.7	14.5	7.5	4.0	3.0	3.6	227.4
1976	9.9	17.1	13.2	14.4	25.3	31.2	19.0	9.0	5.0	3.8	3.4	4.2	155.6
1977	10.1	17.2	12.0	26.9	30.8	31.7	28.4	12.4	5.7	4.0	3.7	10.2	192.9
1978	14.0	24.2	24.5	29.4	31.7	31.7	26.8	12.9	6.7	4.6	4.0	7.7	218.3
1979	21.7	24.2	22.2	26.9	31.7	31.7	26.4	13.2	8.9	5.3	3.7	6.1	222.0
1980	15.1	23.0	23.5	23.4	27.0	31.7	31.7	14.3	7.9	5.3	4.6	9.2	216.7
1981	31.7	31.7	23.4	31.0	22.9	30.8	26.3	10.7	8.8	5.2	5.3	7.1	234.8
1982	24.5	16.9	17.1	17.1	22.2	27.0	14.2	6.3	4.0	3.8	4.5	5.1	162.9
1983	7.4	16.1	12.3	16.4	28.9	31.7	31.7	17.1	8.4	6.8	5.6	5.8	188.3
1984	21.6	27.8	31.7	25.8	31.7	31.7	29.5	9.8	4.6	3.3	2.6	3.1	223.2
1985	12.5	20.6	21.5	31.1	31.7	31.7	29.5	20.6	8.0	4.3	3.2	4.4	218.9
1986	16.1	21.6	20.6	17.6	22.2	31.7	21.0	9.0	4.9	3.4	2.7	4.7	175.5
1987	15.7	18.5	24.3	29.9	22.0	24.1	18.1	9.9	5.4	3.4	2.9	3.5	177.9
1988	12.3	23.7	24.7	31.7	31.7	31.7	19.0	9.2	5.4	3.0	2.2	3.1	197.8
1989	13.5	16.5	16.7	25.7	31.7	28.5	20.3	18.7	8.4	4.9	4.2	6.2	195.3
1990	19.4	24.4	25.3	25.6	28.0	31.7	26.9	15.7	11.7	5.3	3.8	6.1	224.0
1991	14.9	23.4	22.0	22.1	24.4	28.4	20.4	12.7	6.1	5.1	3.2	3.8	186.6
1993	18.0	15.6	16.7	27.1	31.7	31.7	19.0	9.5	5.4	3.5	3.3	4.7	186.1
Total	382.2	496.8	474.7	562.2	625.8	677.4	547.1	280.4	163.5	100.1	82.6	123.9	4516.7
Average	17.4	22.6	21.6	25.6	28.4	30.8	24.9	12.7	7.4	4.5	3.8	5.6	205.3
Min.	7.4	15.6	12.0	14.4	22.0	24.1	14.2	6.3	4.0	3.0	2.2	3.1	155.6
Max.	31.7	31.7	31.7	31.7	31.7	31.7	31.7	20.6	16.8	7.2	7.6	10.2	263.7

Table 9-3 (5) Energy Production of Nara Scheme

Year	Unit : GWh												
	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.	Average
1970	0.0	0.0	0.0	16.4	16.4	16.4	15.0	8.9	7.9	4.2	4.5	5.7	95.4
1971	16.4	16.4	16.4	16.4	16.4	16.4	16.4	7.6	7.0	3.5	2.4	4.9	140.3
1972	11.5	9.4	9.1	11.5	13.6	16.4	15.9	8.1	3.6	2.5	2.2	3.6	107.3
1973	7.3	16.4	16.4	16.4	16.4	16.4	14.3	10.7	9.8	4.0	2.6	3.4	134.1
1974	11.4	16.4	12.9	14.8	16.4	16.4	15.1	5.7	3.4	2.4	2.4	2.9	120.2
1975	12.1	13.4	14.3	16.4	16.4	16.4	16.4	8.5	4.4	2.3	1.8	2.1	124.4
1976	5.8	10.0	7.7	8.4	14.8	16.4	11.1	5.2	2.9	2.2	2.0	2.4	89.1
1977	5.9	10.0	7.0	15.7	16.4	16.4	16.4	7.3	3.3	2.3	2.2	5.9	108.9
1978	8.2	14.2	14.3	16.4	16.4	16.4	15.7	7.5	3.9	2.7	2.4	4.5	122.6
1979	12.7	14.2	13.0	15.7	16.4	16.4	15.5	7.7	5.2	3.1	2.1	3.6	125.6
1980	8.8	13.5	13.8	13.7	15.8	16.4	16.4	8.4	4.6	3.1	2.7	5.4	122.5
1981	16.4	16.4	13.7	16.4	13.4	16.4	15.4	6.3	5.1	3.0	3.1	4.1	129.7
1982	14.3	9.9	10.0	10.0	13.0	15.8	8.3	3.7	2.3	2.2	2.6	3.0	95.2
1983	4.3	9.4	7.2	9.6	16.4	16.4	16.4	10.0	4.9	4.0	3.3	3.4	105.4
1984	12.6	16.3	16.4	15.1	16.4	16.4	16.4	5.8	2.7	1.9	1.5	1.8	123.3
1985	7.3	12.0	12.6	16.4	16.4	16.4	16.4	12.0	4.7	2.5	1.9	2.6	121.1
1986	9.4	12.6	12.0	10.3	13.0	16.4	12.3	5.2	2.9	2.0	1.6	2.8	100.5
1987	9.2	10.8	14.2	16.4	12.9	14.1	10.6	5.8	3.1	2.0	1.7	2.0	103.0
1988	7.2	13.9	14.4	16.4	16.4	16.4	11.1	5.4	3.2	1.7	1.3	1.8	109.3
1989	7.9	9.6	9.8	15.0	16.4	16.4	11.9	10.9	4.9	2.8	2.4	3.7	111.8
1990	11.4	14.3	14.8	15.0	16.4	16.4	15.7	9.2	6.9	3.1	2.2	3.6	128.8
1991	8.7	13.7	12.8	12.9	14.3	16.4	11.9	7.4	3.6	3.0	1.9	2.2	108.9
1993	10.5	9.1	9.8	15.8	16.4	16.4	11.1	5.6	3.2	2.1	1.9	2.7	104.6
Total	219.3	282.0	272.7	314.9	340.3	358.0	310.5	164.0	95.6	58.5	48.3	72.5	2536.5
Average	10.0	12.8	12.4	14.3	15.5	16.3	14.1	7.5	4.3	2.7	2.2	3.3	115.3
Min.	4.3	9.1	7.0	8.4	12.9	14.1	8.3	3.7	2.3	1.7	1.3	1.8	89.1
Max.	16.4	16.4	16.4	16.4	16.4	16.4	16.4	12.0	9.8	4.2	4.5	5.9	140.3

Table 9-4 Study on Project Site

Item	Reyes	Milagro	Los Llanos	Los Llanos-A	Nara
Effective Storage Capacity (10 ⁶ m ³)	23.8	0	1.5	1.5	0
Installed Capacity (MW)	23.3	30.8	95.8	43.7	22.7
Firm Power (MW)	22.1	2.9	39.5	18.1	2.3
Annual Available Energy (GWh)	108.9	114.9	426.3	195.0	109.5
Investment Cost (10 ⁶ ¢)	15,613	4,971	14,139	9,866	4,472
Annual Cost (C) (10 ⁶ ¢)	2,030	646	1,838	1,283	581
Annual Benefit (B1) (10 ⁶ ¢)	621	398	1,839	841	374
" (B2) (10 ⁶ ¢)					
Benefit Cost Ratio (B1/C)	0.306	0.616	1.001	0.655	0.644
" (B2/C)					
Unit Cost of Energy (¢/kWh)	18.64	5.62	4.31	6.58	5.31

Table 9-5 Project Outline of Los Llanos Scheme

Item	Los Llanos	Los Llanos (A)	Los Llanos (B)
Catchment Area (km ²)	143.7	143.7	143.7+31.0
Annual Inflow (m ³ /sec)	18.05	18.05	
High Water Level (EL. m)	485	485	485
Low Water Level (EL. m)	475	475	475
Effective Storage Capacity (10 ⁶ m ³)	1.5	1.5	1.5
Tail Water Level (EL. m)	84	300	200
Gross Head (m)	401	185	285
Effective Head (m)	365	167	242
Maximum Discharge (m ³ /sec)	31.0	31.0	40.0
Installed Capacity (MW)	95.8	43.7	82.0
Main Facilities			
Dam Type	Concrete Gravity	Concrete Gravity	Concrete Gravity
Height x Length	53 m x 105 m	53 m x 105 m	53 m x 105 m
Headrace (D x L)	3.2 m x 5,900 m	3.2 m x 2,400 m	3.2 m x 5,300 m 3.6 m x 2,400 m
Surge Tank (D x H)	8.0 m x 92 m	8.0 m x 80 m	8.0 m x 92 m
Penstock Type	Open	Open	Open
D x L	2.75 m x 1,465 m	2.75 m x 1,160 m	3.0 m x 2,100 m
Powerhouse Type	Open	Open	Open
Type of Turbine	Pelton	Pelton	Pelton

Table 9-6 Basic Development Plan of Los Llanos Project

Item	Los Llanos (1)	Los Llanos (A)	Los Llanos (B)
Effective Storage Capacity (10 ⁶ m ³)	1.5	1.5	1.5
Installed Capacity (MW)	95.8	43.7	82.0
Firm Power (MW)	66.1	30.3	39.1
Annual Available Energy (GWh)	382.8	175.1	308.6
Firm Energy (GWh)	120.7	55.2	83.0
Secondary Energy (GWh)	262.1	119.9	225.6
Investment Cost (10 ⁶ ¢)	14,139	9,866	17,143
Annual Cost (C) (10 ⁶ ¢)	1,838	1,283	2,229
Annual Benefit (B) (10 ⁶ ¢)	1,949	892	1,373
Benefit Cost Ratio (B/C)	1.060	0.695	0.616
Unit Cost of Energy (¢/kWh)	4.80	7.33	7.23

Table 9-7 Project Outline of Los Llanos Projects

Item	Los Llanos (1)	Los Llanos (2)	Los Llanos (3)	Los Llanos (4)
Catchment Area (km ²)	143.7	143.7	143.7	143.7
Annual Inflow (m ³ /sec)	18.05	18.05	18.05	18.05
High Water Level (EL. m)	485	570	540	525
Low Water Level (EL. m)	475	505	475	475
Effective Storage Capacity (10 ⁶ m ³)	1.5	22.5	9.5	5.0
Tail Water Level (EL. m)	84	84	84	84
Gross Head (m)	401	486	456	441
Effective Head (m)	365	447	417	403
Maximum Discharge (m ³ /sec)	31.0	31.0	31.0	31.0
Installed Capacity (MW)	95.8	117.3	109.5	105.9
Main Facilities				
Dam Type	Concrete Gravity	Concrete Gravity	Concrete Gravity	Concrete Gravity
Height x Length	53 m x 105 m	138 m x 275 m	108 m x 215 m	93 m x 190 m
Headrace (D x L)	3.2 m x 5,900 m	3.2 m x 5,900 m	3.2 m x 5,900 m	3.2 m x 5,900 m
Surge tank (D x H)	8.0 m x 92 m	8.0 m x 150 m	8.0 m x 150 m	8.0 m x 131 m
Penstock Type	Open	Open	Open	Open
D x L	2.75 m x 1,465 m	2.75 m x 1,465 m	2.75 m x 1,465 m	2.75 m x 1,465 m
Powerhouse Type	Open	Open	Open	Open
Type of Turbine	Pelton	Pelton	Pelton	Pelton

Table 9-8 (1) Energy Production of Los Llanos Scheme (1)

Year	Unit : GWh												
	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.	Average
1971	49.3	58.1	54.3	66.1	66.5	64.9	50.0	26.2	24.4	12.1	10.3	17.7	500.9
1972	36.3	30.2	30.4	36.6	40.7	54.7	46.2	27.6	14.3	9.5	9.6	13.3	349.5
1973	25.0	53.0	49.7	53.4	65.0	68.7	41.9	34.7	32.2	13.9	11.0	13.2	461.7
1974	36.3	54.7	40.2	43.4	54.9	67.5	43.8	20.7	13.7	9.4	10.2	11.4	406.1
1975	37.3	59.7	43.8	53.7	57.6	66.3	54.3	28.7	16.8	9.4	8.0	8.8	424.4
1976	20.3	31.8	26.7	28.6	42.5	50.8	34.6	19.4	12.0	8.7	8.8	10.0	294.3
1977	20.8	31.5	24.7	46.4	49.5	58.7	48.0	25.2	13.4	9.0	9.5	17.8	354.4
1978	27.8	42.1	44.1	50.8	57.4	62.3	45.6	26.0	15.4	10.2	10.1	16.1	407.9
1979	40.1	41.9	40.5	46.7	55.8	60.1	44.3	26.6	19.1	11.9	9.4	13.5	409.9
1980	29.5	39.0	40.6	42.3	45.7	54.7	56.0	28.4	17.5	11.4	11.3	18.7	395.0
1981	54.8	56.5	42.5	52.2	40.2	53.0	43.2	22.5	19.0	11.2	12.6	15.4	423.2
1982	43.4	31.6	32.8	32.9	38.7	47.2	27.3	14.5	10.1	8.6	11.1	11.8	310.0
1983	16.4	30.1	25.2	31.7	48.7	59.5	54.9	32.6	18.4	14.5	13.2	13.1	358.3
1984	37.6	47.2	54.9	46.0	53.0	61.6	48.7	20.8	11.2	7.8	7.1	7.8	403.7
1985	25.2	37.0	39.4	51.8	57.0	64.5	47.1	38.0	17.6	9.6	8.3	10.4	405.9
1986	27.8	38.4	38.2	33.6	39.3	57.8	57.6	19.4	11.9	8.1	7.4	11.1	330.4
1987	30.6	33.9	43.8	51.9	39.1	43.4	33.2	21.0	12.8	8.4	7.8	8.7	334.5
1988	24.9	40.0	44.3	60.4	63.0	63.2	34.4	19.8	12.8	7.1	6.3	7.9	384.0
1989	27.0	30.8	32.3	45.8	58.7	49.8	36.6	35.0	18.4	16.7	10.5	13.8	369.4
1990	36.3	42.5	44.6	45.4	47.5	62.2	45.4	30.6	24.2	11.4	9.7	13.6	413.4
1991	29.3	41.0	40.3	39.7	42.5	49.2	36.5	25.5	14.2	11.5	8.5	9.3	347.6
1992	15.5	38.7	45.0	55.3	58.0	57.3	42.0	26.2	13.1	9.3	9.2	11.6	359.0
1993	37.8	41.4	38.4	42.5	57.6	49.7	30.6	21.6	13.6	9.6	9.0	8.5	360.2
Total	729.4	931.3	916.5	1,037.0	1,177.2	1,327.1	982.1	590.8	375.9	234.1	218.8	283.6	8,803.8
Average	31.7	40.5	39.8	45.1	51.2	57.7	42.7	25.7	16.3	10.2	9.5	12.3	382.8
Min.	15.5	30.1	24.7	28.6	38.7	43.4	27.3	14.5	10.1	7.1	6.3	7.8	294.3
Max.	54.8	58.1	54.9	66.1	66.5	68.7	56.0	38.0	32.2	14.5	13.2	18.7	500.9

Annual Energy Production

Total Energy = 882.8 GWh
 Firm Energy = 120.7 GWh
 Secondary Energy = 262.1 GWh

Firm Power Output = 66.1 MW (Peak Time 5 hr)

Table 9-8 (2) Energy Production of Los Llanos Scheme (2)

Year	Unit : GWh												
	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.	Average
1971	60.3	71.2	66.5	80.9	81.4	79.5	61.3	32.1	29.9	16.0	12.6	21.7	613.4
1972	44.5	37.0	37.2	44.8	49.9	56.9	56.6	33.8	17.6	11.6	11.8	16.3	428.0
1973	30.6	64.9	50.8	65.4	79.6	84.1	51.3	42.5	39.4	17.1	13.5	16.2	565.4
1974	44.5	67.0	49.2	53.2	67.2	82.7	53.7	25.3	16.7	11.5	12.5	13.9	497.4
1975	45.7	48.7	53.7	65.7	70.6	81.2	66.5	35.2	20.5	11.5	9.8	10.8	519.8
1976	24.8	38.9	32.7	35.0	52.1	62.3	42.4	23.7	14.7	10.7	10.8	12.3	360.4
1977	25.5	38.6	30.2	56.8	60.7	71.9	58.7	30.9	16.4	11.1	11.6	21.8	484.0
1978	34.0	51.6	54.0	62.2	70.3	76.3	55.8	31.8	18.9	12.5	12.4	19.8	499.5
1979	49.1	51.3	49.6	57.2	68.4	78.7	54.2	32.6	23.4	14.5	11.5	16.5	502.0
1980	36.1	47.8	49.7	51.8	56.0	66.9	68.5	34.7	21.4	13.9	13.8	22.9	483.7
1981	67.1	69.2	52.0	63.9	49.3	64.9	52.9	27.5	23.3	13.8	15.4	18.8	518.3
1982	53.2	38.7	40.2	40.3	47.4	57.8	33.5	17.8	12.3	10.6	13.6	14.5	379.7
1983	20.0	38.9	30.8	38.8	59.7	72.9	67.2	39.9	22.6	17.8	16.2	16.0	438.8
1984	46.1	57.8	67.2	56.3	64.9	75.4	59.6	25.5	13.7	9.6	8.7	9.6	494.4
1985	30.8	45.3	48.2	63.5	69.9	79.0	57.7	46.5	21.5	11.7	10.2	12.8	497.1
1986	34.1	47.1	46.8	41.2	48.1	70.7	46.0	23.7	14.5	9.9	9.0	13.6	404.7
1987	37.4	41.5	53.6	63.6	47.9	53.2	40.7	25.8	15.6	10.2	8.5	10.6	409.7
1988	30.5	49.0	54.2	73.9	77.1	77.5	42.1	24.2	15.7	8.7	7.7	9.6	470.2
1989	33.1	37.7	39.6	56.1	71.9	61.0	44.8	42.9	22.5	13.1	12.8	16.9	452.4
1990	44.5	52.1	54.7	55.5	58.2	76.2	55.5	37.5	29.6	13.9	11.8	16.7	506.3
1991	35.9	50.3	49.4	48.7	52.1	60.2	44.7	31.2	17.4	14.1	10.4	11.4	425.7
1992	19.0	47.3	55.1	43.2	68.5	70.2	51.5	32.0	16.0	11.3	11.3	14.2	439.7
1993	46.3	50.7	47.0	52.0	70.6	60.8	37.4	26.4	16.7	11.8	11.0	10.4	441.1
Total	893.3	1,140.6	1,122.5	1,269.9	1,441.6	1,625.2	1,202.7	723.6	460.3	286.7	287.9	347.3	10,781.7
Average	38.8	48.6	48.8	55.2	62.7	70.7	52.3	31.5	20.0	12.5	11.6	15.1	468.8
Min.	19.0	36.9	30.2	35.0	47.4	53.2	33.5	17.8	12.3	8.7	7.7	9.6	360.4
Max.	67.1	71.2	67.2	80.9	81.4	84.1	68.5	46.5	39.4	17.8	16.2	22.9	613.4

Annual Energy Production

Total Energy Et = 468.8 GWh
 Firm Energy Ef = 190.6 GWh
 Secondary Energy Es = 278.2 GWh

Firm Power Output Pf = 104.4 MW (Peak Time 5 hr)

Table 9-8 (3) Energy Production of Los Llanos Scheme (3)

Year	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.	Average	Unit : GWh	
														Apr.	Average
1971	56.3	66.4	62.0	75.5	76.0	74.1	57.2	29.9	27.9	14.9	11.8	20.2	572.2	20.2	11.8
1972	41.5	34.5	34.7	41.8	46.5	62.4	52.8	31.6	16.4	10.8	11.0	15.2	399.3	15.2	11.0
1973	28.6	60.6	56.8	61.0	74.2	78.4	47.9	39.6	35.8	15.9	12.6	15.1	527.4	15.1	12.6
1974	41.5	62.5	45.9	49.6	62.7	77.1	50.1	23.6	15.6	10.7	11.7	13.0	464.0	13.0	11.7
1975	42.6	45.4	50.1	61.3	65.8	75.7	62.0	32.8	19.1	10.7	9.2	10.1	484.9	10.1	9.2
1976	23.2	36.3	30.5	32.6	48.6	58.1	39.5	22.1	13.7	10.0	10.1	11.5	336.2	11.5	10.1
1977	23.8	36.0	28.2	58.0	56.6	67.1	54.8	28.8	15.3	10.3	10.8	20.3	404.9	20.3	10.8
1978	31.7	48.1	50.4	58.0	65.6	71.2	52.1	29.7	17.6	11.6	11.5	18.4	466.0	18.4	11.5
1979	45.8	47.9	46.3	53.4	63.8	68.7	50.6	30.4	21.8	13.5	10.7	15.4	468.3	15.4	10.7
1980	33.7	44.6	46.4	48.4	52.2	62.4	63.9	32.4	20.0	13.0	12.9	21.4	451.3	21.4	12.9
1981	62.6	64.6	48.5	59.6	46.0	60.6	49.3	25.7	21.8	12.8	14.4	17.6	483.5	17.6	14.4
1982	49.6	36.1	37.5	37.6	44.2	53.9	31.2	16.6	11.5	9.9	12.6	13.5	354.2	13.5	9.9
1983	18.7	34.4	28.8	36.2	55.7	68.0	62.7	37.2	21.1	16.6	15.1	15.0	409.4	15.0	15.1
1984	43.0	53.9	62.7	52.6	60.6	70.4	55.6	23.8	12.8	8.9	8.1	8.9	461.2	8.9	8.1
1985	28.8	42.3	45.0	59.2	65.2	73.7	53.8	43.4	20.1	10.9	8.5	11.9	463.8	11.9	8.5
1986	31.8	43.9	43.7	38.4	44.9	66.0	42.9	22.1	13.5	9.2	8.4	12.6	377.5	12.6	8.4
1987	34.9	38.7	50.0	59.3	44.7	49.6	39.0	24.0	14.6	9.5	8.9	9.9	382.2	9.9	8.9
1988	28.4	45.7	50.6	69.0	71.9	72.3	39.3	22.6	14.6	8.1	7.2	9.0	438.7	9.0	7.2
1989	30.9	35.2	36.9	52.3	67.1	56.9	41.8	40.0	21.0	12.2	11.9	15.8	422.0	15.8	11.9
1990	41.5	48.6	51.0	51.8	54.3	71.1	51.8	25.0	27.6	13.0	11.1	15.6	472.3	15.6	11.1
1991	32.5	46.9	46.1	45.4	48.6	56.2	41.7	29.1	16.2	13.1	9.7	10.7	397.1	10.7	9.7
1992	17.7	44.2	51.4	40.3	63.9	65.5	48.0	29.9	14.9	10.6	10.5	13.2	410.2	13.2	10.5
1993	43.2	47.3	43.3	48.5	65.8	56.8	34.9	24.6	15.6	11.0	10.3	9.7	411.5	9.7	10.3
Total	833.3	1,064.0	1,047.1	1,184.7	1,344.9	1,516.1	1,122.0	675.0	429.4	267.4	250.0	324.0	10,058.1	324.0	250.0
Average	36.2	46.3	45.5	51.5	58.5	65.9	48.8	29.3	18.7	11.6	10.9	14.1	437.3	14.1	10.9
Min.	17.7	34.4	28.2	32.6	44.2	49.6	31.2	16.6	11.5	8.1	7.2	8.9	336.2	8.9	7.2
Max.	62.6	66.4	62.7	75.5	76.0	78.4	63.9	43.4	36.8	16.6	15.1	21.4	572.2	21.4	15.1

Annual Energy Production

Total Energy Et = 437.3 GWh
 Firm Energy Ef = 164.8 GWh
 Secondary Energy Es = 272.5 GWh

Firm Power Output Pf = 90.3 MW (Peak Time 5 hr)

Table 9-8 (4) Energy Production of Los Llanos Scheme (4)

Year	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Unit : GWh	
												Apr.	Average
1971	54.4	64.2	60.0	72.9	73.4	71.7	55.3	28.9	26.9	14.4	11.4	19.6	553.0
1972	40.1	32.4	33.5	40.4	45.0	60.4	51.0	30.5	15.8	10.5	10.6	14.7	385.9
1973	27.6	58.5	54.9	59.0	71.7	75.8	46.3	38.2	35.5	15.4	12.2	14.6	509.7
1974	40.1	60.4	44.3	47.9	60.5	74.5	48.4	22.8	15.1	10.3	11.3	12.5	448.4
1975	41.2	43.9	48.4	59.2	63.6	73.2	60.0	31.7	18.5	10.4	8.9	9.7	468.6
1976	22.4	35.1	29.5	31.5	47.0	56.1	38.2	21.4	13.3	9.6	9.7	11.1	324.9
1977	23.0	34.8	27.2	51.2	54.7	64.8	52.9	27.8	14.8	10.0	10.4	19.6	391.3
1978	30.7	46.5	48.7	56.1	62.4	68.8	50.3	28.7	17.0	11.2	11.1	17.8	450.3
1979	44.2	46.3	44.7	51.6	61.6	66.4	48.9	29.4	21.1	13.1	10.4	14.9	452.6
1980	32.6	43.1	44.8	46.7	50.5	60.4	61.8	31.3	19.3	12.5	12.5	20.7	436.1
1981	60.5	62.4	46.9	57.6	44.4	58.5	47.7	24.3	21.0	12.4	13.9	17.0	467.3
1982	47.9	34.9	36.2	36.3	42.8	52.1	30.2	16.0	11.1	9.5	12.2	13.1	342.3
1983	18.1	33.3	27.8	35.0	53.8	65.7	60.6	36.0	20.3	16.0	14.6	14.5	395.6
1984	41.6	52.1	60.6	50.8	58.5	68.0	58.7	23.0	12.4	8.6	7.8	8.6	445.7
1985	27.8	40.8	43.5	57.2	63.0	71.3	52.0	41.9	19.4	10.6	9.2	11.5	448.2
1986	30.7	42.4	42.2	37.1	43.4	63.8	41.5	21.4	13.1	8.9	8.1	12.2	364.9
1987	33.8	37.4	48.3	57.3	43.2	47.9	36.7	23.2	14.1	9.2	8.6	9.6	369.4
1988	27.5	44.2	48.9	66.6	69.5	69.8	38.0	21.3	14.2	7.9	6.9	8.7	424.0
1989	28.9	34.0	35.7	50.6	64.8	55.0	40.4	38.7	20.3	11.8	11.5	15.3	407.8
1990	40.1	47.0	49.3	50.1	52.5	68.7	50.1	33.8	26.7	12.5	10.7	15.0	456.5
1991	32.4	45.2	44.5	43.9	47.0	54.3	40.3	28.1	15.7	12.7	9.3	10.3	383.8
1992	17.1	42.7	49.7	38.9	61.8	63.3	46.4	28.9	14.4	10.2	10.2	12.8	396.4
1993	41.7	45.7	42.4	46.9	63.6	54.9	33.8	23.8	15.0	10.6	9.9	9.4	397.7
Total	805.4	1,028.3	1,012.0	1,144.9	1,299.7	1,465.2	1,084.3	652.3	415.0	258.5	241.6	313.2	9,720.4
Average	35.0	44.7	44.0	49.8	56.5	63.7	47.1	28.4	18.0	11.2	10.5	13.6	422.6
Min.	17.1	33.3	27.2	31.5	42.8	47.9	30.2	16.0	11.1	7.9	6.9	8.6	324.9
Max.	60.5	64.2	60.6	72.9	73.4	75.8	61.8	41.9	35.5	16.0	14.6	20.7	553.0

Annual Energy Production

Total Energy = 422.6 GWh
 Firm Energy = 148.7 GWh
 Secondary Energy = 273.9 GWh

Firm Power Output = 81.5 MW (Peak Time 5 hr)

Table 9-9 Investment Cost (Millions of Colones)

Item	Los Llanos (1)	Los Llanos (2)	Los Llanos (3)	Los Llanos (4)	Los Llanos (A)	Los Llanos (B)
1. Reservoir	16.7	136.4	66.5	55.0	16.7	16.7
2. Access	130.5	138.5	138.5	138.5	138.5	120.7
3. Temporary Installations (Main Civil Works x 0.06)	304.6	1,090.7	663.7	544.1	219.3	379.9
4. Main Civil Works						
Diversion Works	172.8	172.8	172.8	172.8	172.8	172.8
Dam	1,665.5	13,610	6,650	5,501.2	1,665.5	1,665.5
Power Intake	298.3	846	846	323.0	298.3	298.3 + 276.4
Headrace Tunnel	1,826.1	2,215	2,153	1,831.3	751.2	2,619.5
Surge Tank	129.6	195	195	195.0	112.7	120.4
Penstock	245.6	245.6	245.6	245.6	194.5	434.4
Powerhouse and Switchyard	738.0	863.6	799.6	799.6	460.2	738.0
Sub-total	5,075.9	18,178	11,062	9,068.5	3,655.2	6,331.1
5. Hydraulic Equipment						
Spillway gate	149.4	149.4	149.4	149.4	149.4	149.4
Outlet works	34.2	34.2	34.2	34.2	34.2	34.2
Intake gate	34.9	34.9	34.9	34.9	34.9	34.9 + 14.3
Draft gate	6.5	6.5	6.5	6.5	6.5	6.5
Penstock	1,663.2	2,031.8	1,915.2	1,665.6	658.4	2,308.2
Bridge at Spillway	24.3	24.3	24.3	24.3	24.3	24.3
Sub-total	1,912.5	2,281.1	2,164.5	1,914.9	907.7	2,571.8
6. Electromechanical Equipment	2,440.0	2,600	2,550	2,550	1,960	2,550.0
7. Transmission Works	-	-	-	-	-	-
a. Total Direction Cost (DC)	9,888.2	24,424.7	16,645.2	14,271.0	6,897.4	11,970.2
b. Engineering and ADM (0.14 x a)	1,384.3	3,419.5	2,330.3	1,997.5	965.6	1,675.8
c. Contingencies						
Civil Works (0.25 x MC)	1,269.0	4,544.5	2,765.5	2,267.1	913.8	1,582.8
Electromechanical Eq. (0.15 x EX + HE)	652.9	732.2	707.2	669.7	430.2	768.3
Engineering (0.15 x b)	207.6	390.1	349.8	299.7	145.0	251.9
Sub-total	2,129.5	5,666.8	3,822.5	3,236.5	1,409.0	2,603.0
A. Total (a + b + c)	13,402	33,511	22,798	19,509	9,352	16,249
B. Institute Expense (0.055 x A)	737	1,843	1,254	1,073	514	894
C. Grand Total	14,139	35,354	24,052	20,578	9,866	17,143

Table 9-10 Basic Development Plan of Los Llanos Project

Item	Los Llanos (1)	Los Llanos (2)	Los Llanos (3)	Los Llanos (4)
Effective Storage Capacity (10 ⁶ m ³)	1.5	22.5	9.5	5.0
Installed Capacity (MW)	95.8	117.3	109.5	105.9
Firm Power (MW)	66.1	104.4	90.3	81.5
Annual Available Energy (GWh)	382.8	468.8	437.3	422.6
Firm Energy (GWh)	120.7	190.6	164.8	148.7
Secondary Energy (GWh)	262.1	278.2	272.5	273.9
Investment Cost (10 ⁶ ¢)	14,139	35,354	24,052	20,578
Annual Cost (C) (10 ⁶ ¢)	1,838	4,596	3,127	2,675
Annual Benefit (B) (10 ⁶ ¢)	1,949	2,744	2,452	2,281
Benefit Cost Ratio (B/C)	1,060	0.597	0.784	0.853
Unit Cost of Energy (¢/kwh)	4.80	9.80	7.15	6.33

**Table 9-11 Monthly Average Inflow at the Intake Channel Site
(without Project)**

Catchment Area : 230 km²

Unit : m³/s

Year	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.	Average
1971	56.93	89.36	59.22	85.50	102.48	74.61	49.52	21.52	19.73	9.88	6.81	13.97	49.13
1972	32.36	26.58	25.71	32.34	38.36	55.20	44.84	22.93	10.23	6.97	6.25	10.19	26.00
1973	20.64	53.45	48.17	72.48	79.14	91.98	40.31	30.23	27.78	11.24	7.39	9.64	41.04
1974	32.21	57.43	36.39	41.90	57.84	81.70	42.68	16.08	9.52	6.85	6.76	8.05	33.13
1975	34.12	37.84	40.32	53.75	70.54	69.15	60.76	23.95	12.45	6.59	5.02	5.91	35.03
1976	16.29	28.27	21.87	23.85	41.84	51.62	31.44	14.83	8.22	6.29	5.66	6.90	21.42
1977	16.61	28.36	19.86	44.45	50.90	61.08	46.89	20.52	9.38	6.57	6.16	16.76	27.29
1978	23.14	40.06	40.51	48.54	58.90	69.36	44.25	21.25	11.15	7.59	6.65	12.70	32.01
1979	36.25	40.05	36.61	44.39	63.93	69.62	43.68	21.88	14.71	8.78	6.07	10.10	33.01
1980	25.00	38.02	38.87	38.67	44.65	52.83	58.11	23.61	13.08	8.68	7.62	15.17	30.36
1981	54.11	62.29	38.75	51.19	37.86	50.88	43.37	17.74	14.51	8.58	8.71	11.64	33.30
1982	40.51	28.00	28.33	28.31	36.71	44.70	23.46	10.35	6.61	6.22	7.47	8.41	22.42
1983	12.22	26.57	20.37	27.14	47.74	59.80	59.38	28.24	13.91	11.30	9.25	9.63	27.13
1984	35.68	45.96	53.18	42.64	53.12	61.56	48.66	16.26	7.55	5.47	4.28	5.14	31.63
1985	20.64	34.03	35.54	51.39	57.96	74.21	48.72	34.04	13.15	7.05	5.24	7.25	32.44
1986	26.59	35.73	34.01	29.02	36.63	56.89	34.65	14.83	8.09	5.70	4.52	7.83	24.54
1987	25.91	30.64	40.20	49.47	38.39	39.88	30.00	16.39	8.84	5.70	4.84	5.80	24.51
1988	20.37	39.24	40.79	62.18	84.48	73.65	31.40	15.19	8.91	4.90	4.37	5.19	32.50
1989	22.23	27.23	27.66	42.49	61.19	47.14	33.55	30.83	13.87	8.04	6.93	10.32	27.62
1990	32.08	40.36	41.87	42.35	46.21	66.03	44.38	25.99	19.40	8.70	6.29	10.07	31.98
1991	24.67	38.71	36.28	36.57	40.40	46.88	33.68	20.92	10.07	8.44	5.34	6.29	25.69
1992	11.41	36.31	41.54	30.79	58.92	56.53	39.81	21.56	9.09	6.69	6.38	9.38	27.37
1993	29.74	25.78	27.57	44.71	65.47	54.74	31.32	15.69	8.97	5.83	5.42	7.69	26.91
Total	649.72	910.27	833.62	1024.10	1271.69	1410.05	964.87	484.84	279.30	172.04	142.74	214.05	696.44
Average	28.25	39.58	36.24	44.53	55.29	61.31	41.95	21.08	12.14	7.48	6.21	9.31	30.28
Min.	11.41	25.78	19.86	23.85	36.39	39.88	23.46	10.35	6.61	4.90	3.70	5.14	21.42
Max.	56.93	89.36	59.22	85.50	102.48	91.98	60.76	34.04	27.78	11.30	9.25	16.76	49.13

Table 9-12 Monthly Average Inflow at the Intake Channel Site (with Project)

Catchment Area : 230 km²

Unit : m³/s

Year	May	Jun.	Jul.	AUG.	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.	Average
1971	30.87	58.36	32.31	54.50	71.48	43.61	26.26	9.73	8.74	3.62	2.19	5.68	28.95
1972	15.91	12.57	12.08	15.90	19.47	29.79	23.39	10.51	3.80	2.26	1.94	3.77	12.62
1973	9.24	28.70	25.42	41.48	48.14	60.98	20.64	14.67	13.26	4.29	2.45	3.51	22.73
1974	15.83	31.19	18.29	21.60	31.44	50.70	22.08	6.78	3.50	2.21	2.17	2.76	17.38
1975	16.95	19.16	20.65	28.88	39.54	38.62	33.28	11.08	4.90	2.09	1.42	1.79	18.20
1976	6.89	13.54	9.92	11.03	21.56	27.56	15.37	6.12	2.83	1.96	1.69	2.23	10.06
1977	7.06	13.59	8.81	23.15	27.11	33.48	24.64	9.17	3.38	2.08	1.90	7.14	13.46
1978	10.63	20.49	20.76	25.65	32.11	38.75	23.03	9.57	4.25	2.55	2.12	5.03	16.24
1979	18.21	20.48	18.42	23.11	35.29	38.92	22.68	9.93	6.06	3.10	1.87	3.73	16.82
1980	11.67	19.27	19.77	19.65	23.27	28.31	31.61	10.89	5.22	3.05	2.56	6.30	15.13
1981	29.11	34.25	19.70	27.29	19.17	27.10	22.49	7.66	5.95	3.00	3.07	4.49	16.94
1982	20.76	13.38	13.57	13.56	18.48	23.30	10.80	3.85	2.10	1.93	2.49	2.93	10.60
1983	4.78	12.56	9.09	12.89	25.16	32.67	32.41	13.52	5.64	4.32	3.32	3.50	13.32
1984	17.87	24.07	28.53	22.05	28.49	33.79	25.73	6.87	2.53	1.61	1.12	1.47	16.18
1985	9.24	16.89	17.79	27.42	31.52	43.21	25.77	16.90	5.25	2.30	1.51	2.39	16.68
1986	12.57	17.90	16.88	13.97	18.44	30.84	17.26	6.12	2.77	1.70	1.21	2.66	11.86
1987	12.19	14.91	20.57	26.23	18.29	20.38	14.54	6.94	3.13	1.70	1.34	1.75	11.83
1988	9.09	19.99	20.93	34.18	53.48	42.65	15.35	6.31	3.16	1.37	0.89	1.49	17.41
1989	10.12	12.94	13.19	21.96	33.55	24.79	16.61	15.02	5.63	2.75	2.24	3.84	13.55
1990	15.75	20.67	21.58	21.87	24.22	36.63	23.11	12.23	8.56	3.06	1.96	3.72	16.11
1991	11.49	19.68	18.23	18.40	20.69	24.63	16.69	9.39	3.72	2.94	1.55	1.96	12.45
1992	4.38	18.24	21.38	15.00	32.12	30.62	20.34	9.74	3.25	2.14	2.00	3.38	13.55
1993	14.39	12.11	13.14	23.31	36.26	29.50	15.30	6.57	3.19	1.76	1.58	2.59	13.31
Total	314.99	474.95	421.02	543.06	709.32	790.83	499.38	219.59	110.80	57.79	44.58	78.10	355.37
Average	13.70	20.65	18.31	23.61	30.84	34.38	21.71	9.55	4.82	2.51	1.94	3.40	15.45
Min.	4.38	12.11	8.81	11.03	18.29	20.38	10.80	3.85	2.10	1.37	0.89	1.47	10.06
Max.	30.87	58.36	32.31	54.50	71.48	60.98	33.28	16.90	13.26	4.32	3.32	7.14	28.95

Table 9-13 (1) Outline of Los Llanos Project (I)

Item	CASE I-1	CASE I-2	CASE I-3	CASE I-4
High Water Level (EL. m)	475.5	476.8	478.0	479.2
Low Water Level (EL. m)	470.0	470.0	470.0	470.0
Effective Storage Capacity (1) (10 ³ m ³)	484	605	726	847
Effective Storage Capacity (2) (10 ³ m ³)	0	0	0	0
Tail Water Level (EL. m)	84.0	84.0	84.0	84.0
Gross Head (m)	388.8	389.4	390.0	390.6
Effective Head (m)	353.8	354.4	354.9	355.4
Maximum Discharge (m ³ /s)	20	25	30	35
Installed Capacity (MW)	60	75	90	105
Firm Power Output (MW)	60	75	78.7	78.8
Annual Available Energy (GWh)	338	365	379	386
Firm Energy (GWh)	102	102	102	103
Secondary Energy (GWh)	236	263	277	283
Main Facilities				
Dam	Concrete Gravity	Concrete Gravity	Concrete Gravity	Concrete Gravity
Type	60.5 x 107	61.8 x 108	63.0 x 109	64.2 x 110
Height x Length	2.8 x 5,600	3.0 x 5,600	3.2 x 5,600	3.4 x 5,600
Headrace (D x L)	8.0 x 55	8.0 x 55	8.0 x 55	8.0 x 55
Surge Tank (D x H)	Tunnel	Tunnel	Tunnel	Tunnel
Penstock	2.3 x 1,650	2.5 x 1,650	2.7 x 1,650	2.9 x 1,650
Type	Open	Open	Open	Open
D x L	Pelton	Pelton	Pelton	Pelton
Powerhouse				
Type				
Type of Turbine				

Table 9-13 (2) Outline of Los Llanos Project (II)

Item	CASE II-1	CASE II-2	CASE II-3	CASE II-4
High Water Level (EL. m)	523.0	523.4	523.8	524.2
Low Water Level (EL. m)	506.0	506.0	506.0	506.0
Effective Storage Capacity (1) (10 ³ m ³)	484	605	726	847
Effective Storage Capacity (2) (10 ³ m ³)	5,000	5,000	5,000	5,000
Tail Water Level (EL. m)	84.0	84.0	84.0	84.0
Gross Head (m)	430.5	430.7	430.9	431.1
Effective Head (m)	391.8	391.9	392.1	392.3
Maximum Discharge (m ³ /s)	20	25	30	35
Installed Capacity (MW)	66	83	100	116
Firm Power Output (MW)	66	83	93.7	93.7
Annual Available Energy (GWh)	399	426	435	436
Firm Energy (GWh)	120	120	120	120
Secondary Energy (GWh)	279	306	315	316
Main Facilities				
Dam Type	Concrete Gravity	Concrete Gravity	Concrete Gravity	Concrete Gravity
Height x Length	108.0 x 194	108.4 x 195	108.8 x 195	109.2 x 196
Headrace (D x L)	2.8 x 5,520	3.0 x 5,520	3.2 x 5,520	3.4 x 5,520
Surge Tank (D x H)	8.0 x 77	8.0 x 77	8.0 x 77	8.0 x 77
Penstock Type	Tunnel	Tunnel	Tunnel	Tunnel
D x L	2.3 x 1,720	2.5 x 1,720	2.7 x 1,720	2.9 x 1,720
Powerhouse Type	Open	Open	Open	Open
Type of Turbine	Pelton	Pelton	Pelton	Pelton

Table 9-14 Development Plan of Los Llanos Project

Item	CASE I (Regulation Type)				CASE II (Reservoir Type)			
	CASE I-1	CASE I-2	CASE I-3	CASE I-4	CASE II-1	CASE II-2	CASE II-3	CASE II-4
Effective Storage Capacity (10 ³ m ³)	484	605	726	847	484 + 5000	605 + 5,000	726 + 5,000	847 + 5,000
Installed Capacity (MW)	60	75	90	105	66	85	100	116
Firm Power (MW)	60	75	78.7	78.8	66	83	93.7	93.7
Annual Available Energy (GWh)	338.1	365.5	379.4	385.9	399	426	435	436
Firm Energy (GWh)	102.1	102.3	102.4	102.6	120	120	120	120
Secondary Energy (GWh)	236.0	263.2	277.0	283.3	279	306	315	316
Investment Cost (10 ⁶ ₪)	11,623 (16,124)	12,687 (17,188)	13,734 (18,235)	14,590 (19,091)	18,838	19,439	20,641	21,443
Annual Cost (C) (10 ⁶ ₪)	1,604 (2,096)	1,742 (2,234)	1,878 (2,371)	1,990 (2,482)	2,449	2,527	2,683	2,788
Annual Benefit (B) (10 ⁶ ₪)	1,755	1,992	2,075	2,090	1,987	2,267	2,424	2,426
Benefit Cost Ratio (B / C)	1.082 (0.828)	1.144 (0.892)	1.104 (0.874)	1.050 (0.842)	0.811	0.897	0.903	0.870
(B-C) (10 ⁶ ₪)	131 (Δ361)	250 (Δ242)	195 (Δ298)	100 (Δ392)	Δ462	Δ260	Δ259	Δ362
Unit Cost of Energy (₪/kWh)	4.74	4.77	4.95	5.16	6.14	5.93	6.17	6.39

Remark: () means CASE I

Table 9-15 Study on Turbine Type

Item		Pelton Turbine	Francis Turbine
Maximum Discharge	Q (m ³ /s)	27	27
Effective Head	H (m)	356.9	359.4
Installed Capacity P=9.8 QHη _t η _g	(kW)	9.8 x 27 x 356.9 x 0.884 x 0.971 = 81,000	9.8 x 27 x 359.4 x 0.922 x 0.971 = 85,000
Firm Power	(kW)	78.8	82.7
Annual Available Energy	(GWh)	371.1	389.4
Firm Energy	(GWh)	102.3	107.3
Secondary Energy	(GWh)	268.8	282.1
Investment Cost	(10 ⁶ ₺)	12,122	11,652
Main Civil Works	(10 ⁶ ₺)	4,360	4,498 (Surge Tank) 138
Electromechanical Eq	(10 ⁶ ₺)	2,186	1,697
Others	(10 ⁶ ₺)	5,576	5,457
Annual Cost	(10 ⁶ ₺)	1,669	1,608
Annual Benefit	(10 ⁶ ₺)	2,053	2,155
Benefit Cost Ration	(B/C)	1.23	1.34
	(B-C) (10 ⁶ ₺)	384	547
Unit Cost Energy	(₺/kWh)	4.50	4.13

Table 9-16 Standard Alternative Thermal Power Plant

Item	Unit	Description	
		Gas Turbine	Diesel (Slow Speed Internal Combustion Engine)
Type	-	Gas Turbine	Diesel (Slow Speed Internal Combustion Engine)
Installed Capacity	MW	42 MW	40 MW
Annual Plant Factor	%	30	80
Thermal Efficiency	%	27.23	34.32
Annual Energy Production	GWh	110	280
Construction Cost (Interest during Construction included)	\$	25,729,200	74,136,000
Service Life	year	15	25
Construction Period	year	2	2
Capital Recovery Factor	-	0.14682	0.12750
Diesel Calorific Value	kcal/kg	10,248	-
Bunker Calorific Value	kcal/kg	-	10,207
Fuel Consumption Rate	kg/kWh	0.308	0.246
$\left[\frac{860 \text{ kcal / kWh}}{\text{Thermal Efficiency} \times \text{Calorific Value}} \right]$			
O & M Cost	%	3.58	2.02
Unit Fuel Cost	\$/l (1994 CIF)	0.1478 (Diesel)	0.0743 (Bunkeroil)

Type		Gas Turbine		Diesel (Slow Speed Internal Combustion Engine)	
Annual Cost	Unit	Fixed Cost	Variable Cost	Fixed Cost	Variable Cost
Capital Recovery	10 ⁶ \$	3,778	-	9,452	-
O & M Cost	10 ⁶ \$	0.829 (90%)	0.092 (10%)	1.348 (90%)	0.150 (10%)
Fuel Cost	10 ⁶ \$	-	6.019 ¹⁾	-	5.212 ²⁾
Total	10 ⁶ \$	4.607	6.111	10.773	5.362
Annual Cost at Receiving end					
kW Cost	\$/kW ³⁾	kW value		236.14 \$/kW	
kWh Cost	\$/kWh ^{4),5)}	Firm energy value		0.0313 \$/kWh	
		Secondary energy value		0.0204 \$/kWh	

$$1) 110 \times 10^6 \times 0.308 / 0.832 \times 0.1478 = 6.019 \times 10^6 \$$$

$$2) 280 \times 10^6 \times 0.246 / 0.982 \times 0.0743 = 5.212 \times 10^6 \$$$

Adjustment Factor for kW & kWh

Item	kW (%)	kWh (%)
Loss of Station Service	6	6
Loss of Stoppage	4	-
Loss of Repair	12	-
Loss of Transmission	0	0

$$\text{kW Adjustment Factor} = \frac{1}{(1 - 0.06) \times (1 - 0.04) \times (1 - 0.12) \times (1 - 0.0)} = 1.259$$

$$\text{kWh Adjustment Factor} = \frac{1}{(1 - 0.06) \times (1 - 0.0)} = 1.064$$

$$3) \frac{(4.607 + 10.773) \times 10^6}{(42 + 40) \times 1,000} \times 1.259 = 236.14 \$/\text{kW}$$

$$4) \frac{(6.111 + 5.362) \times 10^6}{(110 + 280) \times 10^6} \times 1.064 = 0.0313 \$/\text{kW}$$

$$5) \frac{5.362 \times 10^6}{280 \times 10^6} \times 1.064 = 0.0204 \$/\text{kW}$$

Firm energy value synthesized costs of both the gas turbine generator and the diesel engine generator. The secondary energy value was estimated from the diesel engine generator cost considering reducing the operation during high stream flow season, because in this season, the energy will be produced by the hydroelectric power stations instead of the diesel engine generator plants.

Table 9-17 Result of Optimum Development Plan

High Water Level	EL. 477.4 m
Low Water Level	EL. 470.0 m
Effective Storage Capacity	653 x 10 ³ m ³
Effective Head	359.4 m
Installed Capacity	85 MW
Firm Power Output	82.7 MW
Annual Available Energy	389 Gwh
Firm Energy	107 Gwh
Secondary Energy	282 Gwh
Investment Cost	151,763 x 10 ³ US\$
Annual Cost (C)	19,729 x 10 ³ US\$
Annual Benefit (B)	28,631 x 10 ³ US\$
Benefit Cost Relation (B - C)	8,902
Unit Cost of Energy	0.05 US\$/kwh

Chapter 10 Power Transmission Plan

Chapter 10 Power Transmission Plan


CHAPTER 10 POWER TRANSMISSION PLAN

Contents

10.1	Outline of Power Transmission System	10-1
10.2	Power Transmission Line Route.....	10-1
10.2.1	Project Conditions	10-1
10.2.2	Site Survey	10-2
10.2.3	Selection of Transmission Line Route	10-3
10.2.4	Power Transmission Voltage.....	10-6
10.2.5	Number of Circuits	10-6
10.2.6	Study of Transmission Line Cable Type and Number of Insulators	10-6
10.2.7	Study of Transmission Line Steel Towers.....	10-7
10.2.8	Study of Transmission Line Construction Cost	10-7
10.3	Study and Analysis of ICE System	10-7
10.3.1	Power Flow Calculation	10-7
10.3.2	Short Circuit Capacity	10-8
10.3.3	Stability	10-8
10.3.4	Conclusion	10-9

List of Figures

- Fig. 10-1** **Power Transmission System in Costa Rica**
- Fig. 10-2** **Transmission Developing Plan Adjacent Los Llanos P.H.**
- Fig. 10-3** **Alternatives of Transmission Line Route**
- Fig. 10-4** **Standard Suspension Tower**
- Fig. 10-5** **Power Flow in 2005**
- Fig. 10-6** **Stability Study**



CHAPTER 10 POWER TRANSMISSION PLAN AND POWER SYSTEM ANALYSIS

10.1 Outline of Power Transmission System

The power transmission system of Costa Rica is a 230 kV system interconnected to that of Nicaragua and Panama. The system exchanges power on a mutual basis with certain neighboring countries.

The domestic power transmission system consists of 230 kV and 138 kV transmission lines. As of January 1995, the total lengths were 880 km and 704 km respectively.

The transmission system in the central mountain area surrounding the city of San Jose, which is the largest load area in Costa Rica, is a 138 kV ring system providing high system reliability.

However, there is a plan to form a large 500 kV power transmission system (SIEPAC) interconnecting five central American countries and Panama. This system is projected to come on line somewhere between the years 2000 and 2003.

The projected SIEPAC route would pass along the Costa Rican Pacific coast and connect to a substation to be installed in the San Rafael area at Parrita town near the Los Llanos Hydropower Station. It will then be linked to the metropolitan ring system via the Pirris Power Station (to start operation in 2003).

Fig. 10-1 shows the 230 kV and 138 kV power transmission system (scheduled for 2015) in Costa Rica.

10.2 Power Transmission Line Route

10.2.1 Project Conditions

- (1) The ICE plans to transmit the power generated at the Los Llanos Power Station to the metropolitan area of San Jose, the largest load center in Costa Rica, via the Pirris Hydropower Station (128 MW, scheduled for commissioning around 2003).

(2) The 500 kV Central American Interconnected Power Transmission Line (SIEPAC) is scheduled for completion and interconnection with the Pirris Power Station via a 500 kV substation at San Rafael Sur near Parrita town, around 2003 when the Pirris Power Station is to start operation. As the Los Llanos Power Station is scheduled for commissioning in 2004, completion of the SIEPAC project is expected when the Los Llanos Power Station is in actual operation.

(3) In this way, the power transmission line from Los Llanos Power Station will be connected to the 500 kV Substation at San Rafael (Parrita) because it is nearest to the Los Llanos Power Station Site.

The power transmission from the projected Savegre Power Station (165 MW) is also to be taken into consideration.

Fig. 10-2 shows the power transmission system in the vicinity of the Los Llanos Power Station.

10.2.2 Site Survey

(1) Power Transmission Line Route

For the transmission line route from Los Llanos Power Station to San Rafael (Parrita) Substation, there are three alternatives: One is an almost straight route crossing the Rio Paquita at the power station and traversing the mountain areas (Alternative Route A). Although the shortest, it traverses a mountain area. The other is a route running to the right of the Rio Paquita to the plains and to San Rafael (Parrita) and running parallel to SIEPAC is also conceivable (Alternative Route B).

Another possible route is one that, after arrival at the plains, would traverse the palm plantations, and run along National Highway 239 to San Rafael (Parrita) (Alternative Route C).

(2) Switchyard Site

As the grazing land to the left of the river downstream from the projected power station is sufficiently flat for its construction, a switchyard will be located there.

The transmission line would cross the Río Paquita to the right bank. However, as the river is only about 100 m wide, connection of the transmission line to this station is easy and there are no topographical problems in locating the switchyard there.

(3) Interconnection Substation Site (San Rafael Site)

Located midway between Paquita town and Damas town, this site is presently grazing. It is flat, situated approximately 10 km from the Pacific Ocean and located on the SIEPAC route. It is approximately 2 km from the trunk highway to the mountains site. For this reason, an access road will have to be repaired from that highway, but no special problem is conceivable for transporting heavy objects to the site.

Although the details remain to be determined, the substation will step down the voltage from 500 kV to 230 kV and be connected by two circuits to the Pirris Power Station (128 MW, scheduled for operation start in 2003).

10.2.3 Selection of Transmission Line Route

The following factors were taken into consideration in the selection of the transmission line route in view of the requirement to maintain harmony with the natural and social environments and because of the technical feasibility involved:

a) Harmony with the natural environment

- No damage to the natural view such as natural parks and scenic spots
- No trespassing into the growing areas of valuable animals and plants
- Minimization of tree felling in natural and artificial forests

b) Harmony with the social environment

- No trespassing into residential and public facilities
- No trespassing into cultural properties and historic remains
- No trespassing into high-productivity land and hard to recover land (No trespassing into palm plantations)
- Coordination with regional development schemes

c) Harmony with the technology

- High facility safety
- Low construction cost
- Easy construction work
- Work completion according to schedule
- Easy maintenance
- Short line length

In view of the above factors, considering the natural and social environments along the routes, the following three alternative routes (A, B and C) were studied:

Fig. 10-3 shows the Alternative of Transmission Line Route.

(1) Alternative Route A

This route connects the Los Llanos Power Station to the San Rafael (Parrita) Substation by a straight line.

This route almost entirely traverses steep mountain areas, and the construction involves many problems including the transport of the construction materials and maintenance after operation start.

This route provides the shortest length (approx. 20 km).

(2) Alternative Route B

This route crosses the Rio Paquita at the Los Llanos switchyard and runs to the plains along the right bank of the Rio Paquita. After crossing the Rio Paquita, the route immediately climbs the mountain and runs through mountainous areas for approximately 6 km.

After entering the plains, it runs along the foot of the mountains to San Antonio Village via Parrita, in order to avoid traversing the palm plantation which extends into the plain, to subsequently terminate at the San Rafael (Parrita) Substation.

The route traverses the plains between Parrita and San Rafael in a straight line. These plains are farmland with no palm or banana plantations, or other objects requiring a detour. Although there is no material transport road along the transmission line route, there are many

roads allowing motor vehicle travel, so that both material transportation and maintenance after operation start of the line are considered very easy.

This alternative route provides a length for the transmission line of approximately 22 km.

(3) Alternative Route C

With this alternative, the transmission line comes onto the plains along the same route as Route B. However, upon reaching the plains, it leads straight to trunk highway R239 which it then runs along close to the San Rafael (Parrita) Substation for eventual connection to the San Rafael (Parrita) Substation. Since this route runs along the existing roads, it is the most advantageous for material transportation and maintenance after operation start.

However, it does traverse the palm plantation area and intersects the 500 kV transmission line. With this, its length is approximately 25 km, the longest of the three alternatives.

(4) Comparison of the Alternatives

Comparison of the three alternative routes (A, B and C) is shown below.

	Route A	Route B	Route C
Transmission line length	⊙(20 km)	○(22 km)	△(25 km)
Traversing mountain area	△	○	⊙
Transmission line intersection	○	⊙	△
Traversing palm plantation	⊙	○	△
Material transportation	△	○	⊙
Maintenance convenience	△	○	⊙
Construction cost (relative to Route B)	△ 1.5	⊙ 1.0	○ 1.0
Minimized felling of natural and afforestation trees	△	⊙	△
Short distance	⊙	○	△
Overall evaluation	○	⊙	△

(5) Result of Study

On the basis of the overall study of the three routes, A, B and C, including the technical and economical evaluations, Route B was selected as the route for the projected transmission line.