


JAPAN INTERNATIONAL COOPERATION AGENCY(JICA)

NATSIONALNA ELEKTRICHESKA KOMPANIA(NEK)
REPUBLIC OF BULGARIA

**THE FEASIBILITY STUDY
ON
MARITSA EAST NO.1 REPLACING THERMAL POWER PLANT
FOR
IMPROVEMENT OF THE PERFORMANCE OF THE UNITS
AND
THE ENVIRONMENTAL PROTECTION**

**FINAL REPORT
SUMMARY**

JICA LIBRARY

J 1131622 (1)

SEPTEMBER 1996

ELECTRIC POWER DEVELOPMENT CO., LTD.
TOKYO ELECTRIC POWER SERVICES CO., LTD.

| |
|----------|
| M P N |
| C R (3) |
| 96 - 105 |

JAPAN INTERNATIONAL COOPERATION AGENCY(JICA)

**NATSIONALNA ELEKTRICHESKA KOMPANIA(NEK)
REPUBLIC OF BULGARIA**

**THE FEASIBILITY STUDY
ON
MARITSA EAST NO.1 REPLACING THERMAL POWER PLANT
FOR
IMPROVEMENT OF THE PERFORMANCE OF THE UNITS
AND
THE ENVIRONMENTAL PROTECTION**


**FINAL REPORT
SUMMARY**

SEPTEMBER 1996


**ELECTRIC POWER DEVELOPMENT CO., LTD.
TOKYO ELECTRIC POWER SERVICES CO., LTD.**




1131622 [1]




Maritsa East No.1 Replacing Thermal Power Plant







Maritsa East No.1 Thermal Power Plant and Rozovkladenets Lake
(Artificial Lake for Cooling Water)




Flue Gas from Stack for Boilers Nos.1~6 (FRONT)
and Stack for Coal Drying Facilities (LEFT)




Ash Disposal Area No. 1
(A Site Proposed for Coal and Limestone Storage Yard)




Ash Disposal Area No. 3 A (for Existing Plant 4X50MW)




Removal of Boiler House for Old Nos. 7~10 (INSIDE)




Removal of Boiler House for Old Nos. 7~10 (OUTSIDE)




180m High Stack for Old Boilers Nos.7~10
(removed in April, 1996)





Rotary Kiln for Coal Drying and Cyclone Precipitator
(These Facilities and 120m High Stack for Old Boilers will be removed)



Reusable Crane in Turbine House for Old Nos.5~6 (INSIDE)




Removal of Turbine and its foundation for Old Nos.5~6 (INSIDE)





Troyanovo Coal Mine (Lignite : Open-Cast)




Limestone Mine to be developed (Bratyakunchevi)




Existing Limestone Mine (Yurdere) for Cement Industry




Topsoil Disposal Area
(To be Used for Ash Disposal Area of Replacing Plant, too)



Lignite (Incompletely Carbonized)



Topsoil (Sand, Clay, Lignite, etc.)



Contents

| | <u>Page</u> |
|---|-------------|
| CONCLUSION AND RECOMMENDATION | |
| CHAPTER 1 INTRODUCTION | 1-1 |
| 1.1 Background and Process of the Study | 1-1 |
| 1.2 Purpose, Outline, Scope and Period of the Study | 1-5 |
| 1.3 Relevant Organization | 1-9 |
| 1.4 Acceptance of Trainees | 1-11 |
| 1.5 Provision of Equipment | 1-11 |
| CHAPTER 2 REPLACING PLANT SITE | 2-1 |
| 2.1 Outline of Maritsa East No.1 Thermal Power Plant | 2-1 |
| 2.2 Site Condition | 2-3 |
| CHAPTER 3 ELECTRIC POWER DEVELOPMENT PLAN STUDY | 3-1 |
| 3.1 Electric Power Facilities | 3-1 |
| 3.2 Power Supply and Demand | 3-2 |
| 3.3 Study and Analysis of Power System | 3-7 |
| CHAPTER 4 STUDY ON COAL AND LIMESTONE SUPPLY | 4-1 |
| 4.1 Coal | 4-1 |
| 4.2 Limestone | 4-7 |
| CHAPTER 5 OPTIMUM DEVELOPMENT PLAN | 5-1 |
| 5.1 Matters for Consideration | 5-1 |
| 5.2 Selection of Boiler Type | 5-5 |
| 5.3 Selection of Type of Steam Turbine and Generator | 5-19 |
| 5.4 Existing Equipment and Facilities which can be Reused | 5-19 |

| | | |
|------------------|---|------------|
| CHAPTER 6 | CONCEPTUAL DESIGN | 6-1 |
| 6.1 | Design Specifications | 6-1 |
| 6.2 | Planned Performance | 6-5 |
| 6.3 | Layout | 6-7 |
| 6.4 | Material Balance and Schematic Diagram on Boiler | 6-13 |
| 6.5 | Turbine Cycle Heat Rate | 6-16 |
| 6.6 | Boiler Equipment | 6-19 |
| 6.7 | Steam Turbine | 6-24 |
| 6.8 | Generator Equipment | 6-34 |
| 6.9 | District Heating System | 6-36 |
| 6.10 | Environmental Protection Facilities | 6-38 |
| 6.11 | Ash Handling Facilities | 6-45 |
| 6.12 | Plant Water System | 6-52 |
| 6.13 | Air Service Equipment | 6-54 |
| 6.14 | Storage and Transportation Facilities of Fuel and Limestone | 6-60 |
| 6.15 | Electrical and Control Equipment | 6-72 |
| 6.16 | Switchyard and Substation | 6-83 |
| 6.17 | Buildings and Stack | 6-93 |
| CHAPTER 7 | PLANNING OF PROJECT IMPLEMENTATION | 7-1 |
| 7.1 | Contract Formation | 7-1 |
| 7.2 | Project Schedule | 7-4 |
| CHAPTER 8 | CONSTRUCTION | 8-1 |
| 8.1 | Principle Concept of Cost Estimation | 8-1 |
| 8.2 | Project Cost | 8-3 |
| 8.3 | Disbursement Schedule | 8-3 |
| 8.4 | Generation Cost | 8-6 |
| CHAPTER 9 | ENVIRONMENTAL IMPACT ASSESSMENT | 9-1 |
| 9.1 | Environmental Regulation | 9-1 |
| 9.2 | Present Situations of Environment | 9-2 |
| 9.3 | Prediction and Assessment of Environmental Impacts | 9-3 |
| 9.4 | Study of the Lake Water Temperature | 9-4 |

| | | |
|-----|---------------------------------------|-----|
| 9.5 | Environmental Preservation Plan | 9-4 |
| 9.6 | Environmental Monitoring Plan | 9-5 |
| 9.7 | Overall Evaluation | 9-5 |

CHAPTER 10 ECONOMIC EVALUATION AND FINANCIAL EVALUATION 10-1

| | | |
|------|---|------|
| 10.1 | Economic Evaluation | 10-1 |
| 10.2 | Financial Evaluation | 10-2 |
| 10.3 | Determination of New Electric Tariff System | 10-3 |
| 10.4 | Socio-Economic Influence Evaluation | 10-5 |

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes that this is essential for ensuring transparency and accountability in the organization's operations.

2. The second part of the document outlines the various methods and tools used to collect and analyze data. It highlights the need for consistent and reliable data collection processes to support effective decision-making.

3. The third part of the document focuses on the role of technology in modern data management. It discusses how advanced software solutions can streamline data collection, storage, and analysis, thereby improving efficiency and accuracy.

4. The fourth part of the document addresses the challenges associated with data security and privacy. It provides insights into best practices for protecting sensitive information and ensuring compliance with relevant regulations.

5. The fifth part of the document explores the importance of data quality and how it impacts the overall reliability of the information used for strategic planning and reporting.

6. The sixth part of the document discusses the role of data in driving innovation and identifying new opportunities for growth. It emphasizes the value of data-driven insights in developing competitive advantages.

7. The seventh part of the document concludes by summarizing the key findings and recommendations. It stresses the need for a data-centric culture and continuous investment in data management capabilities.

8. The eighth part of the document provides a detailed overview of the data collection process, including the selection of data sources, the design of data collection instruments, and the implementation of data collection protocols.

9. The ninth part of the document discusses the various methods used for data analysis, including descriptive statistics, inferential statistics, and advanced data mining techniques.

10. The tenth part of the document focuses on the interpretation of data results and the communication of findings to stakeholders. It emphasizes the importance of clear and concise reporting to facilitate informed decision-making.

11. The eleventh part of the document discusses the ethical considerations surrounding data collection and analysis. It highlights the need for transparency, informed consent, and the protection of individual privacy.

12. The twelfth part of the document provides a comprehensive overview of the data management lifecycle, from data collection to data archiving and disposal.

13. The thirteenth part of the document discusses the role of data in supporting organizational performance and the achievement of strategic goals.

14. The fourteenth part of the document concludes by emphasizing the ongoing nature of data management and the need for continuous improvement and adaptation to changing organizational needs and technological advancements.

ABBREVIATIONS

| | | |
|------------------|---|--|
| AD | : | Air Dried Basis |
| AFT | : | Ash Fusion Temperature |
| AH | : | Air Pre-heater |
| AR | : | As Received Basis |
| AVR | : | Automatic Voltage Regulator |
| BOD | : | Biochemical Oxygen Demand |
| Cap. | : | Capacity |
| CB | : | Circuit Breaker |
| CIF | : | Cost, Insurance and Freight |
| COD | : | Chemical Oxygen Demand |
| COE | : | Committee of Energy |
| CW | : | Circulating Water |
| CWP | : | Circulating Water Pump |
| DC | : | Direct Current |
| DD | : | Detail Design |
| DWT | : | Dead Weight Ton |
| ECR | : | Economical Continuous Rating |
| EGP | : | Energoprocket Ltd. |
| EIRR | : | Economic Internal Rate of Return |
| EPDC | : | Electric Power Development Co., Ltd. |
| ESP | : | Electrostatic Precipitator |
| FC | : | Foreign Currency |
| FDF | : | Forced Draft Fan |
| FIRR | : | Financial Internal Rate of Return |
| FL | : | Floor Level |
| FOB | : | Free On Board |
| FS | : | Feasibility Study |
| G | : | Gal |
| Geo. | : | Geothermal |
| GDP | : | Gross Domestic Product |
| GIS | : | Gas Insulated Substation |
| GNP | : | Gross National Product |
| Grid | : | Electric Power System |
| HGI | : | Hard Grove Index (Index of Grindability) |
| H ₂ O | : | Heavy Fuel Oil |

| | | |
|---------------|----------|--|
| HV | : | Heating Value |
| Is. | : | Island |
| IDF | : | Induced Draft Fan |
| JICA | : | Japan International Cooperation Agency |
| LNG | : | Liquefied Natural Gas |
| LC | : | Local Currency |
| Max. | : | Maximum |
| MC | : | Metal Clad Switchgear |
| MCR | : | Maximum Continuous Rating |
| Min. | : | Minimum |
| MOEER | : | The Ministry of Energy and Energy Resources in Bulgaria |
| MSV | : | Main Stop Valve |
| NEK | : | Natsionalna Elektricheska Kompania |
| NOx | : | Nitrogen Oxides |
| NPV | : | Net Present Value |
| PAF | : | Primary Air Fan |
| PF | : | Power Factor |
| R1 | : | Replacing No.1 unit |
| R2 | : | Replacing No.2 unit |
| S | : | Sulfur |
| SCR | : | Short Circuit Ratio |
| SOx | : | Sulfur Oxides |
| SPL | : | Sound Pressure Level |
| SPM | : | Suspended Particulate Matter |
| SS | : | Suspended Solid |
| S/S | : | Substation |
| TEPSCO | : | Tokyo Electric Power Services Co., Ltd. |
| TL | : | Transmission Line |
| TM | : | Total Moisture |
| Tr. | : | Transformer |
| VAT | : | Value Added Tax |
| VM | : | Volatile Matter |

UNITS

Prefixes

| | | | |
|-------|---|--------|-------------|
| μ | : | micro- | = 10^{-6} |
| m | : | milli- | = 10^{-3} |
| c | : | centi- | = 10^{-2} |
| d | : | deci- | = 10^{-1} |
| da | : | deca- | = 10 |
| h | : | hecto- | = 10^2 |
| k | : | kilo- | = 10^3 |
| M | : | mega- | = 10^6 |
| G | : | giga- | = 10^9 |

Units of Length

| | | |
|----|---|------------|
| m | : | meter |
| mm | : | millimeter |
| cm | : | centimeter |
| km | : | kilometer |
| in | : | inch |
| ft | : | feet |
| yd | : | yard |

Units of Area

| | | |
|---------------|---|--------------------|
| cm^2 | : | square centimeter |
| m^2 | : | square meter |
| km^2 | : | square kilometer |
| ft^2 | : | square feet (foot) |
| yd^2 | : | square yard |
| ha | : | hectare |

Units of Volume

| | | |
|--------------|---|-------------|
| m^3 | : | cubic meter |
| l | : | liter |
| kl | : | kiloliter |

Units of Mass

| | | |
|----|---|--------------|
| g | : | gram |
| kg | : | kilogram |
| t | : | ton (metric) |
| lb | : | pound |

Units of Density

| | | |
|---------------------|---|------------------------------------|
| kg/m ³ | : | kilogram per cubic meter |
| t/m ³ | : | ton per cubic meter |
| mg/m ³ N | : | milligram per normal cubic meter |
| g/m ³ N | : | gram per normal cubic meter |
| ppm | : | parts per million |
| µg/scm | : | microgram per standard cubic meter |

Units of Pressure

| | | |
|--------------------------|---|--|
| kg/cm ² | : | kilogram per square centimeter (gauge) |
| lb/in ² | : | pound per square inch |
| mmHg | : | millimeter of mercury |
| mmHg abs | : | millimeter of mercury absolute |
| mAq | : | meter of aqueous |
| lb/in ² , psi | : | pounds per square inches |
| atm | : | atmosphere |
| Pa | : | Pascal |
| bara | : | bar absolute |

Units of Energy

| | | |
|------|---|----------------------|
| kcal | : | kilocalorie |
| kWh | : | kilowatt-hour |
| MWh | : | megawatt-hour |
| GWh | : | gigawatt-hour |
| Btu | : | British thermal unit |

Units of Heating Value

| | | |
|---------|---|--------------------------------|
| kcal/kg | : | kilocalorie per kilogram |
| Btu/lb | : | British thermal unit per pound |

Units of Heat Flux

| | | |
|-----------------------|---|---|
| kcal/m ² h | : | kilocalorie per square meter hour |
| Btu/ft ² h | : | British thermal unit per square feet hour |

Units of Temperature

| | | |
|-----|---|------------------------------|
| deg | : | degree |
| ° | : | degree |
| C | : | Celsius or Centigrade |
| °C | : | degree Celsius or Centigrade |
| F | : | Fahrenheit |
| °F | : | degree Fahrenheit |

Units of Electricity

| | | |
|------|---|-------------------------------------|
| W | : | watt |
| kW | : | kilowatt |
| A | : | ampere |
| kA | : | kiloampere |
| V | : | volt |
| kV | : | kilovolt |
| kVA | : | kilovolt ampere |
| MVA | : | megavolt ampere |
| Mvar | : | megavar (mega volt-ampere-reactive) |
| kHz | : | kilohertz |

Units of Time

| | | |
|-----|---|--------|
| s | : | second |
| min | : | minute |
| h | : | hour |
| d | : | day |
| y | : | year |

Units of Flow Rate

| | | |
|---------------------|---|--|
| t/h | : | ton per hour |
| t/d | : | ton per day |
| t/y | : | ton per year |
| m ³ /s | : | cubic meter per second |
| m ³ /min | : | cubic meter per minute |
| m ³ /h | : | cubic meter per hour |
| m ³ /d | : | cubic meter per day |
| lb/h | : | pound per hour |
| m ³ N/s | : | cubic meter per second at normal condition |
| m ³ N/h | : | cubic meter per hour at normal condition |

Units of Conductivity


| | | |
|-------|---|-----------------------------|
| μS/cm | : | microSiemens per centimeter |
|-------|---|-----------------------------|

Units of Sound Power Level

| | | |
|----|---|-----------|
| dB | : | deci-bell |
|----|---|-----------|

Units of Currency

| | | |
|------|---|--------------|
| L | : | Leva |
| US\$ | : | US Dollar |
| ¥ | : | Japanese Yen |



[List of Tables]

- 2-1-1 Organization and Personnel of ME-1 TPP**

- 3-1-1-1 Development of Installed Capacity in Bulgaria**
- 3-1-1-2 Outline of Thermal Power Plants in Bulgaria**
- 3-1-2-1 Outline of Transmission system in Bulgaria**
- 3-2-2-1 Data for Regression Equation**

- 4-1-1 Coal Mines in Bulgaria**
- 4-1-2 Coal Produced during the Period 1.1.1992 - 31.10.1994 and Utilization Break-down**
- 4-1-3 Coal Mining Forecast in Bulgaria**
- 4-1-4 Specification of Maritsa East Lignite Basin/Troyanovo 2/ After 1998 for Maritsa East 1 TPP**
- 4-2-1 Cement Production Capacity of Each Plant**
- 4-2-2 Properties of Sampled Limestone**

- 5-1-1 Design Lignite Properties**
- 5-1-2 Design Limestone Properties**
- 5-1-3 Heavy Oil Properties**
- 5-2-1 Comparison of Boiler Types**
- 5-2-2 Planned Performance**
- 5-4-1 Results of Diagnosis of Durability**

- 6-1-1 Design Lignite Properties**
- 6-1-2 Design Limestone Properties**
- 6-1-3 Heavy Oil Properties**
- 6-2-1 Planned Performance**
- 6-10-1-1 Dust Collector Comparison**
- 6-14-3-1 Heavy Oil Properties**
- 6-17-1 List of Building**

- 8-3-1 Disbursement Schedule**
- 8-4-1 Operation and Maintenance Cost (2 Units)**
- 8-4-2 Trial Calculation of Generation Cost**

- 9-1-1 Air Quality Standard in Bulgaria**
- 9-1-2 Emission Standard in Bulgaria**

- 9-1-3 SO₂ Emission Level and Its Reduction Percentages in Bulgaria
- 9-1-4 SO₂ Emission Limit from New Plant in the EU (Solid fuels)
- 9-1-5 The Water Quality Standard of Bulgaria
- 9-1-6 Permission Noise Level (BSS 14478-82)
- 9-1-7 Highest Admissible Noise Levels in Different Residential Areas and Zones

- 10-1-1 Initial Investment Cost of ME-1 Replacing Thermal Power Plant (Market price basis)
- 10-1-2 Initial Investment Cost of ME-1 Replacing Thermal Power Plant (Economic price basis)
- 10-1-3 Initial Investment Cost of Alternative Thermal Power Plant (Market price basis)
- 10-1-4 Initial Investment Cost of Alternative Thermal Power Plant (Economic price basis)
- 10-1-5 Basic Condition for Economic Evaluation
- 10-1-6 Basic Factors for Economic Evaluation
- 10-1-7 Net Present Value and Benefit-Cost Ratio
- 10-1-8 Economic Evaluation of ME-1 Thermal Power Plant
- 10-1-9 Sensitivity Analysis
- 10-2-1 Basic Condition for Financial Evaluation
- 10-2-2 Revenue for Sales of Electricity and Heat
- 10-2-3 Financial Evaluation of ME-1 Thermal Power Plant
- 10-2-4 Fund Requirement and Repayment
- 10-2-5 Profit and Loss Statement
- 10-2-6 Cash Flow Sheet

- 10-3-1 Trend of Electricity and Heat Price
- 10-3-2 (1) Financial Evaluation of ME-1 Thermal Power Plant (Case 1)
- 10-3-2 (2) Financial Analysis of ME-1 Thermal Power Plant (Case 1)
- 10-3-3 (1) Financial Evaluation of ME-1 Thermal Power Plant (Case 2)
- 10-3-3 (2) Financial Analysis of ME-1 Thermal Power Plant (Case 2)

[List of Figures]

- 1-2-5 Study Work Flow Chart
- 1-3-1 NEK System

- 2-1-1 Layout of Unit for Maritsa East No.1 Thermal Power Plant

- 3-1-1-1 Outline of Electric Power Facilities in Bulgaria
- 3-2-1-1 Monthly Trend of Energy Consumption in Bulgaria
- 3-2-1-2 Peak and Minimum Consumption Days in 1994
- 3-2-2-1 Relationship between GDP per capita and Energy Consumption
- 3-2-3-1 Energy Demand Forecast

- 4-1-1 Locations of Coal Mines in Bulgaria
- 4-1-2 Locations of Coalfield and Power Stations in Maritsa East
- 4-1-3 General Process Flow Diagram of the Open Cast Pits of the Maritsa East Complex
- 4-2-1 Locations of Limestone Mine and Cement Factory
- 4-2-2 Locations of Limestone Mines

- 5-2-1 CFBC (230MW) Layout
- 5-2-2 BFBC (230MW) Layout
- 5-2-3 PCF+FGD (230MW) Layout
- 5-2-4 Effective Stack Height vs. Adjacent Structure Height on a 120 m High Stack, ME-1 P/S
- 5-4-1-1 Intake and Discharge Tunnel

- 6-3-1 General Layout
- 6-3-2 CFBC (230MW) Layout
- 6-4-1 Fuel Firing System & Air & Gas Draft System Material Balance
- 6-5-1 Turbine Cycle Heat Balance Diagram (230 MW)
- 6-5-2 Turbine Cycle Heat Balance Diagram (200 MW)
- 6-6-1 Side View of C-FBC Boiler Plant
- 6-7-1 General Arrangement Ground Floor (GL+200)
- 6-7-2 General Arrangement of Operating Floor (GL+8,000) and Dearrator Floor (GL+16,000)
- 6-7-3 General Arrangement View A-A
- 6-7-4 Flow Diagram of Condenser Cooling Water System
- 6-7-5 Flow Diagram of Condensate, Feedwater and Main Steam Line
- 6-7-6 Flow Diagram of Auxiliary Cooling Water System
- 6-9-1 Flow Diagram of the District Heating System

- 6-10-2-1 Flow Diagram of Waste Water Treatment System
- 6-11-1 Water Intake and Discharge System in Power Station
- 6-11-2 Ash Handling System Flow
- 6-12-1 Flow Diagram of Water Treatment System
- 6-13-1 Instrument Air Piping Line
- 6-14-1-1 Coal Handling System Flow
- 6-14-2-1 Limestone Handling System Flow
- 6-14-3-1 System of Heavy Oil Receiving and Discharging
- 6-15-1-1 One Line Diagram
- 6-15-2-1 Sophistication of the Roles and Expansion in Application of Computer for Thermal Power Plant
- 6-16-1 Single Line Diagram of Switchyard (ME-1 TPP Side)
- 6-16-2 Switchyard Plan (ME-1 TPP Side)
- 6-16-3 Switchyard Section (ME-1 TPP Side)
- 6-16-4 Single Line Diagram of Switchyard (ME-1 S/S Side)
- 6-16-5 Plan of Switchyard (ME-1 S/S Side)
- 6-16-6 Power System Diagram of Maritsa East No.1 Thermal Power Plant
- 6-16-7 Transmission Lines Route of ME-1 TPP
- 6-17-1 Elevation with the Existing Hall
- 6-17-2 Turbine Hall and Boiler House Ground Floor (GL+200)
- 6-17-3 Turbine Hall and Boiler House Operation Floor (GL+8,000) and Deaerator Floor (GL+16,000)
- 6-17-4 Turbine Hall and Boiler Section Elevation and Section
- 6-17-5 New Stack H=180

- 7-2-1 Maritsa East No.1 Replacing Power Plant [Unit R-1 & R-2] Implementation Schedule
- 7-2-2 Design Stage (For example)
- 7-2-3 Construction Schedule (For example)

- 9-1-1 New Plant Emission Limit Values for SO₂ in the EU in mg/m³N (Solid fuels)
- 9-1-2 Rates of Desulfurization in the EU
- 9-1-3 New Plant Emission Limit Values for SO₂ in the EU in mg/m³N (Liquid fuels)
- 9-1-4 Water Quality Sampling Sites at River Network in Bulgaria
- 9-2-1 Monitoring Record (Galabovo, 1993)
- 9-2-2 Monitoring Record (Galabovo, 1993)
- 9-3-1 Contour Map Based on Replaced Equipment (Daytime)
- 9-3-2 Contour Map Based on Replaced Equipment (Night)
- 9-4-1 Location Map of Lake Water Temperature Measurement Points

- 9-4-2 Forecast of Warm Water Distribution (CASE-I, Summer)
- 9-4-3 Forecast of Warm Water Distribution (CASE-II, Winter)

CONCLUSION AND RECOMMENDATION

CONCLUSION AND RECOMMENDATION

[CONCLUSION]

This survey was conducted as a feasibility study of a replacing project to construct at the area where old unit nos. 5 and 6 (each rated 150MW) in the Maritsa East No.1 Thermal Power Plant new units firing the lignite, main energy resource of the Republic of Bulgaria (hereinafter referred to as Bulgaria), satisfying environmental requirements stipulated in the Bulgaria or EC standard, and having an optimum design from technological and economic point of view.

As a result of studies and evaluations made from technological economic, financial and environmental aspects in the feasibility study, it has been concluded that the proposed replacing project is feasible. The contents of the conclusion are as follows.

1. In Bulgaria, the demand for the electric power for industrial use has been smaller than that for private use since the political change in 1989, or so to speak a sort of reversal of demand structure has been seen, but it has been increasing slowly since 1994. It is predictable that the total demand for electric power will be increasing steadily if the demand for electric power for industrial use increases accompanying the steady economic growth of Bulgaria from now on. The demand for electric power in 2010 is estimated based on the GDP and the change in population (1993 as base year), as follows.
 - (1) Low case (GDP growth rate: 3%)
2,100 US\$ per capita → 4,100 kWh per capita → 37,000 GWh (Increase by 16% more than in 1995)
 - (2) Middle case (GDP growth rate: 4%)
2,400 US\$ per capita → 4,200 kWh per capita → 38,000 GWh (Increase by 19% more than in 1995)
 - (3) High case (GDP growth rate: 5%)
2,700 US\$ per capita → 4,300 kWh per capita → 39,000 GWh (Increase by 22% more than in 1995)

There are many problems relating to the future electric power supply. The import of Ukrainian coal as the fuel for the thermal power plants has been unstable. Besides, the wear

of existing generating facilities has progressed to a considerable extent; for instance, it is anticipated that the superannuated No. 1 and No. 2 units (2 x 440MW) at (Kozloduy) nuclear power plant will be compelled to be dismantled from around 2000. NEK's electric power source development schedule based on the estimate of the demand for electric power (to be completed by around 2005) is as follows:

- (1) Scale of electric power source development: 951MW (Increase by 9%) → Generating facilities: 11,540MW
(Thermalpower) To be increased by 1,275MW → (Thermalpower) 6,130MW (53.1%)
(Hydropower) To be increased by 476MW → (Hydropower) 2,710MW (23.5%)
(Nuclear power) To be decreased by 800MW → (Nuclear power) 2,700MW (23.4%)
- (2) The electric power supply potentiality will be lowest from 2000 through 2001 due to decrease in the capacity of nuclear power plant.

Thus, there is a possibility that the supply-demand relation of electric power in Bulgaria will become considerably tight around 2000, and so there will be very pressing need for early development of new electric power supply sources. Also, in formulating the electric power supply plan in Bulgaria, it is important to incorporate replacing as well as repairing and remodeling of the existing power plants as a means to increase power generation capacity.

The result of analysis of electric power supply system in 2001 when the operation of the replacing plant will be commenced is as follows:

- (1) Electric power current calculation:
No difficulties will be seen in the voltage of bus bar and current of transmission line of each substation.
 - (2) Short-circuit capacity: 535MVA (3-phase short-circuit current: 1.4kA)
 - (3) Transient stability: Stable without difficulty
2. Currently, the coal is supplied to the power station by railway wagon from the north mining area of Maritsa East coal mine (an open cast lignite mine) with the largest domestic deposit (85% or more). The total deposit of the coal is about 520 million tons which is large enough to meet annual consumption of about 5.2 million tons / year for 30 years or more. Besides, the existing mining facilities and railway system therefrom to the power plant can be utilized as it is.

However, the prior arrangement or conference with the coal mining companies concerned at the following points will be required:

- (1) In concluding coal purchasing agreement with the coal supplier, it is important to include a conditions concerning sulfur content in addition to those concerning the contents of ash, water and calorific value.
 - (2) Since the existing coal storage yard is planned to be converted to No.1 ash disposal yard, the additional railway for incoming coal needs to be laid. Also, it is necessary to clarify the scope and responsibility of the construction work to be executed for such railway between the power plant and coal mining company. Furthermore, the construction work for new railway should be coordinated with the work for the replacing plant and operation schedule of the currently operating power plant.
 - (3) The clay content in the coal is the worst hindrance to the coal conveyance and coal crushing processes in power plant, and so the purchasing department of power plant should require the shipping department in the coal mining company to do their best for eliminating the clay content from the coal before loading the freight train with the coal.
3. The limestone to be used as desulfurizing agent is distributed in various locations (4 locations) within the range of 100km from the power plant. Of these limestone fields, two fields (in Yurdere and Chala) are currently exploited as the raw material for the cement by cement plants currently operating there. Other two fields have not been developed yet for the aforementioned purposes, except one located in "Bratyakunchevi" which has been currently exploited as a gravel producing plant. The limestone field located in "Purachakunchebi" not only has a large deposit of about 90 million tons for annual consumption of about 1.1 million tons but also has a railway leading to the power plant, and hence has a potentiality for being developed as a dedicated field for desulfurizing agent.

Development of this limestone field, however, has to be promoted coordinating with the proposed construction plan of a flue-gas desulfurization system at Maritsa East No.2 thermal power plant (No. 8 unit), and geological survey should be conducted again following one conducted about 30 years ago.

4. Principal specifications of the optimum development plan are as follows:

(1) Electric output: 230MW x 2 units

(2) Hot water for local heating: 25 Gcal/h

* Hot water will be supplied from one of two units.

The electric output of a unit supplying hot water will be reduced by a output equivalent to the calorific value thereof.

(3) Steam conditions: Main steam flow = 740 t/h (MCR)
Main steam pressure = 169kg/cm²g (2,400 psig) (at turbine inlet)
Main steam temperature = 538°C (1,000°F) (at turbine inlet)
Reheated steam temperature = 538°C (1,000°F) (at turbine inlet)

(4) Properties of lignite, ash and limestone: Refer to Requirement for Development Survey; (for design) TOR (Terms of Reference) of January 12, 1995

(5) Emission standard: SO₂ = 650mg/m³N (227ppm) or less (Bulgarian Standard),
(O₂ = 6%, dry base) or 90% or more of desulfurizing efficiency
(EC Standard applicable when coal having a high sulfur content is used)
NO_x = 600mg/m³N (292ppm) or less (Bulgarian Standard)
Dust = 100mg/m³N or less (Bulgarian Standard)
CO = 250mg/m³N (200ppm) or less (Bulgarian Standard)

(6) Water quality standard: To conform to Group A Class III of Bulgarian Standards for "Index and standard applicable to evaluation of the quality of surface running water".

(7) Annual use rate of plant: 70%

(8) Minimum load: 40%

(9) Overload: Boiler MCR = ECR x 103% or less
Turbine TMF = Rated output x 105% or less
Generator = Rated output x 105% or less

(10) Deposits of lignite and limestone:

Amount to be consumed to operate the plant for 23 days (as per Bulgarian Standard)

5. The following models are selected as the main equipment in the optimum development plan based on the aforementioned principal specifications.

(1) Boiler: C-FBC (Circulating Fluidized Bed Combustion)

(Reason of Selection)

The three different types, namely, two types of fluidized bed combustion boiler (circulation type and bubbling type) and pulverized coal fired boiler plus flue gas desulfurization equipment (wet type limestone-gypsum method) were compared from technological and economic aspects on the condition that all these three types of boiler have actually been used commercially, are capable of conforming to flue gas standard value and are adaptable to the nature and conditions of the lignite.

As a result, it was found that technologically the circulating type fluidized bed boiler and pulverized coal-fired boiler plus flue-gas desulfurizing system (wet type limestone-gypsum method) are applicable, that economically the circulating fluidized bed boiler is advantageous and that, comprehensively judging a circulating type fluidized bed boiler is advantageous.

(2) Dust collector: Electrostatic type

(Reason of Selection)

For comparison, electrostatic precipitator and bag filter were selected and compared technologically and economically. As a result, a electrostatic precipitator was chosen as having advantages as to maintenance, operation, economy and actual experience in the existing plants over a bag filter of which the performance is largely affected by reliability of bag.

(3) Turbine: TCDF (Tandem Compound Double Flow)

(Reason of Selection)

This type of turbine have been used widely and are characteristic of highly efficient operation and control and easy maintenance. In addition, this type of turbine have been used in Maritsa East No.2 and No.3 thermal power plants.

- (4) Generator: Liquid-hydrogen-cooled, horizontal-shaft, cylindrical, revolving magnetic field, explosion-proof, 3-phase AC, synchronous type

(Reason of Selection)

The same as that for a turbine.

6. The old No.5 and No.6 generators of the existing thermal power plant are being dismantled currently. As a result of study of the existing equipment and facilities as to whether they are reusable or not in order to reduce replacing cost, the following items are found to be reusable, subject to some treatment as the case may be.

(1) Cooling water channel facilities

- (a) Screening pump room needs to be reformed with respect to its guide walls for installation of the screen and concrete slabs of foundation incidental to replacement of the pump.

(b) Water intake channel:

- 1) Existing circular concrete culvert: Good for reuse

- 2) Existing steel pipe section directly laid underground: Required to be reinforced to cover the markedly reduced wall thickness (from 8mm to 5.5 - 7.4mm)

- Where some structure or disturbance exists on the relevant ground, the existing steel pipe should be reinforced by inserting new steel pipe into it, and the gap therebetween should be filled with mortar.
- Where no structure or disturbance exists on the relevant ground, the existing steel pipe should be replaced with new steel pipe and covered with concrete.

- 3) New water line: New steel pipes shall be installed up to the turbine and covered with concrete.

(c) Water discharge channel:

- 1) Existing box culvert: Good for reuse

- 2) New box culvert to be constructed: To be installed up to the turbine and reinstalled.

- 3) New circulating water channel to be constructed: New steel pipe should be laid from the box culvert up to the turbine and covered with concrete.

(2) Turbine room in main building

Concerning the existing turbine room, concrete neutralization is found to have progressed to a certain extent but not to a extent affecting its durability. However, the area where the old No.5 and No.6 turbines were located is not large enough for a layout of equipment to be installed for the replacing plant. Thus, such a space should be obtained by extending part of the existing building.

However, a combination of the existing building and new building will give rise to a problem such as difference in service life of the buildings, and so careful consideration and prior study are required for design of a new building e.g. adjusting the distribution of loads to act on the buildings and giving some restrictions in determining layout of various equipment.

(3) Stack

- a) The existing stack (180m high) for old No.5 and No.6 boilers stands in the space required for the machines and equipment to be installed in a replacing plant, so that this stack cannot be reused.
- b) The existing stack (120m high) for the coal drier cannot be reused because a difficulty of flue gas diffusion will be seen due to the downdraft effect caused by the boiler building and further because its outlet diameter is too small for the flue gas from replacing boilers to pass through.

(4) Machines and equipment

- (a) Total capacity of existing river water supply pumps is not large enough, so that one of the existing pumps should be replaced with a new one. A part of the existing water supply piping can be reused, but the piping section to be reused should be branched for connection to the replacing plant.
- (b) Existing overhead crane itself in the building house can be reused, provided that the additional rails are installed. But the load test shall be conducted prior to reuse of the crane.
- (c) Existing crane for maintenance work in circulating pump room can be reused, provided that its capacity is not less than the weights of new pump and new motor.

- (d) Existing piping for district heating system can be reused, but new piping should be installed, corresponding to extension of the building for turbines.
- (e) Existing fire-fighting facilities can be reused, but new piping should be installed on the ground where the existing piping is interfaced with a replacing plant.
- (f) The existing railway, building and tunnel for receiving old coal for nos. No.7 through 10 can be used.

7. Based on the main equipment selected in the optimum development plan and the result of the study for reusable existing equipment, the conceptual designs have been made for the following item and main equipment for a replacing plant.

- Layout
- Turbine and auxiliaries
- Heat supply facility
- Ash and limestone handling facility
- Compressed air supply facility
- Fuel and limestone storage and transportation facilities (for coal, limestone, crude oil and LPG)
- Switchyard and power substation
- Boiler and auxiliaries
- Generator and auxiliaries
- Environmental equipment (ESP, waste water treatment)
- Water supply equipment for thermal power plant
- Electric, control and instrumentation equipment
- Building and stack

8. The processes of construction work of a replacing plant have been determined, taking into consideration the time by which the need of new power supply source is expected to arise, experiences of local contractors in executing the construction works of a scale similar to the construction work of a replacing plant and the effects of seasonal weather conditions on the progress of the construction work efficiency.

However, the schedule of the proposed plan is probably subject to modification, depending on the time required for budgeting and progress of the work to be performed by NEK.

| | (Unit R1) | (Unit R2) |
|---|------------------------|----------------|
| (1) Completion of feasibility study | End of Aug. 1996 | Same as left |
| (2) Completion of budgeting (That for engineering expenses needs to be completed earlier than others.) | End of Jun. 1997 | Same as left |
| (3) Completion of designation of consultants | Beginning of Jan. 1997 | Same as left |
| (4) Completion of basic design, detail design and preparation of specifications for tendering | End of Aug. 1997 | Same as left |
| (5) Completion of evaluation of bidding and placement of orders | | |
| • Civil/architectural/erection works | Beginning of Apr. 1998 | Same as left |
| • Boiler, turbine, coal/limestone handling | Beginning of Jun. 1998 | Same as left |
| (6) Commencement of civil engineering work | Beginning of Apr. 1998 | Same as left |
| (7) Commencement of equipment installation | Beginning of Aug. 1999 | 6 months later |
| (8) Hydrostatic test on boiler | Beginning of Sep. 2000 | 6 months later |
| (9) Receipt of power supply and commencement of test run | Beginning of Dec. 2000 | 6 months later |
| (10) Initial firing | Beginning of Apr. 2001 | 6 months later |
| (11) Synchronization | Beginning of Jul. 2001 | 6 months later |
| (12) Commencement of commercial operation (Unit R-1) | Beginning of Oct. 2001 | 6 months later |

9. The replacing cost was estimated based on the design, work execution processes, materials, products and technological level expected to be available as in January, 1996, taking into consideration the actual costs of international construction works of a scale similar to that of the proposed replacing plant on the conditions that the machines and equipment are basically to be imported through successful contractors to be decided through a process of international competition tendering and works are to be undertaken by the local contractors through a process of domestic competition tendering.

The construction cost is as follows.

| | | (unit: 10 ⁶ US\$) | |
|--|-------|-------------------------------|-----------------------------|
| [Direct Construction Cost] | | (Foreign currency portion) | (Local currency portion) |
| • Boiler island | 226.0 | 192.1 | 33.9 |
| • Turbine island | 106.0 | 90.1 | 15.9 |
| • Coal and limestone handling island | 89.1 | 75.7 | 13.4 |
| • Civil architecture/erection works island | 144.2 | 62.0 | 82.2 |
| (Subtotal) | 565.3 | 419.9 | 145.4 |
| [Technological Cost] | 20.0 | 20.0 | - |
| [Reserved Budget Cost] | 20.0 | 15.0 | 5.0 |
| (Grand Total) | 605.3 | 454.9 | 150.4 |

The operation maintenance cost and electric power generating cost of the replacing plant are as follows:

[Operation maintenance cost]

- Fuel cost: 30,312 x 10³ US\$/year = 1.1 cent/kWh
- Utility cost such as costs of limestone, labor and repair: 28,141 x 10³ US\$/year = 1.0 cent/kWh

[Electric power generating cost]

- Cost at power generating end: 4.6 cent/kWh
- Cost at power transmission end: 4.9 cent/kWh

10. The effects of the operation of a replacing thermal power plant on the neighboring environment (effects through atmosphere, waste water, noise and heated waste water) were estimated and the following results were obtained.

(1) Air pollution

The substances to be estimated are SO_x, NO_x and dust. The results of estimates of the short-period diffusion (for only the time period immediately after replacement) and long-period diffusion (during operation of No. 1 through No. 6 units, during operation of No. 1 through No. 4 units i.e. current conditions, and after replacement) are as follows:

Note that the effects of the pollution-causing substances from Maritsa East No.2 and No.3 thermal power plants on their neighboring environments are considered to be extremely

large, but the effects of these power plants are not included in this estimate, since their effects will be estimated separately.

[Short-period diffusion estimate]

- Maximum ground concentration:
Estimated values of all the substances satisfy the requirements of the national standards of Bulgaria.
- Distance from the source of pollution-causing substance where its maximum ground concentrations is seen:
About 17.6km away from the stack

[Long-period diffusion estimate]

- During operation of No.1 through No.6 units: Ground concentrations of SO_x and dust largely exceeded the national standards of Bulgaria.
- During operation of No.1 through No.4 units: The same as the above.
- After replacement: The national standards of Bulgaria are supposed to be satisfied.

Furthermore, the emissions of sulfur oxides and dust after the replacing work (for units R1 and R2) are estimated to decrease as follows compared with those during operation of No.1 through No.6 units and during operation of No.1 through No.4 units, respectively.

Sulfur oxides: 54.4 t/h - 5.3 t/h = 49.1 t/h (decrease by about 90%)

32.5 t/h - 5.3 t/h = 27.2 t/h (decrease by about 84%)

Soot and dust: 8.28 t/h - 0.2 t/h = 8.08 t/h (decrease by about 98%)

4.54 t/h - 0.2 t/h = 4.34 t/h (decrease by about 96%)

(2) Pollution caused by waste water

The pollution of river caused by the drainage from the thermal power plant can be expected to be reduced if appropriate waste water treatment facility is provided within the premises of the power plant, but the real solution to this problem will not be possible unless a total pollution control plan and measures covering the whole locality including the controls of other pollution sources are executed.

In addition, it is expected that the effluent control should be made at an early stage, based on the revision of the existing laws and regulations.

(3) Noise

The predicted noise level within the premises of the power plant, if low-noise machines and equipment were adopted and installed in the buildings, would not be so high as to cause problems.

The existing noise control attaches greater importance to the environmental noise level to which the workers in the power plant are exposed rather than the noise level along the boundary of the plant.

On a long-term basis, however, if the noise control measures are taken after noise problem actually occurs, it would require greater cost and works of greater scales. Therefore, it would be wise to take appropriate noise control measures for the machines and equipment which are considered to be the sources of noise, at the planning stage.

(4) Hot waste water

Concerning the possibility of rise of the water temperature in Rozovkuladenet Lake caused by discharge of the condenser cooling water, the hot waste water diffusion analysis was conducted assuming that the difference in water temperature between intake channel and discharge channel is 7°C. The result of analysis indicates that the water temperature tends to be higher near the outlet of the cooling water discharge channel, but the area of higher water temperature is limited in the vicinity of the outlet of discharge channel. Therefore, the lake was found to be capable of functioning as the cooling water source. Also, there will be little influence on the environment, as the warm discharged water can be used for the fish farm.

11. It is revealed that the replacing project is better in economic evaluation than the alternative plan; construction of the coal-fired thermal power plant using the imported coal, and that the former proposed project has advantages over the latter in terms of all the indexes.

Also, the result of sensitivity analysis (sensitivity to affect the construction cost, equivalent discount rate and fuel cost) indicates that the replacing project has advantages over the alternative project.

- (1) Considering the two indexes, namely, net present value (benefit minus cost) and benefit/cost ratio (benefit/cost), the construction cost, maintenance cost and fuel cost for the replacing

project has economic advantage over those of alternative coal-fired thermal power plant using the imported coal.

- (2) The equivalent discount rate (economic internal rate of return or EIRR), in terms that the investment in the replacing project and the investment in the alternative project are equal in the first year of the replacing project, is 25.3%, which is larger than the opportunity cost (set to 10.0%) of the capital. Therefore, it is revealed that the proposed project is feasible.
12. For the purpose of financial evaluation, the revenues from the sales of the electric power and steam for district heating, to be compared with the investment cost (construction cost and operation maintenance cost), are calculated on the conditions that the standard electric power rate (4.5 cents/kWh) and steam rate (31.4 dollars/Gcal) as in 2001 will remain unchanged, that the interest rate of borrowing in foreign currency is 8.0% for 20 years, and that the interest rate of borrowing in domestic currency is 10% for 15 years. As a result, the financial internal rate of return (FIRR) is 8.8%, indicating that there will be no problem for the repayment of the borrowing in foreign currency, but the repayment will be difficult if the discount rate of 10% prevailing in the domestic financing market.

Thus, the feasibility of adopting new electric power rate system is currently studied. If the unit price of the electric power rate in 2001 is revised to 5.0 cents/kWh based on the present rate, the FIRR will exceeds 10% assuring better financial conditions.

13. The socioeconomic effects of the proposed replacing project are as follows:
- (1) Favorable effects of increase in investment on economy and opportunity of employment can be expected.
 - (2) The replacing project introduces for the first time a circulation type fluidized bed thermal power plant to Bulgaria, contributing to the development of new electric power source utilizing domestic lignite and spread of related technology.
 - (3) Vitalization and growth of construction, mining, iron and steel, electric machine, transportation, communication and other industries relating to electric power generating industry can be expected.
 - (4) A method for macroeconomically evaluating the socioeconomic effects of the execution of environmental protection measures has not been well established yet, but the favorable effects of such measures on the health, declining of disease, living environment, social

environment and natural environment of the local inhabitants can be expected judging from the favorable effects that the environmental protection measures actually proved in other countries.

[Recommendations]

The proposed replacing project is not only technologically and economically feasible but also capable of contributing greatly to the solution of the local environmental problems. And, this project should be executed as soon as possible judging from the prediction of the supply-demand relation of the electric power around 2001.

For earlier materialization of the project, the following matters should be considered.

1. For the successful execution of the replacing project, the financing for the project will play a vital role. For this purpose, it is important that involving the coal mining and limestone industries, the replacing project to be promoted substantially as one of the national projects by seeking the positive effort of the Bulgarian government in winning the cooperation of the international financing institutions.
2. Scheduling of repayment is equally important to the borrowing plan. It is preferred for the costs relating to the investment construction cost, operation maintenance cost to be surely recovered by the electric power rate. For this purpose, it is necessary to reconsider the existing electric power tariff system as soon as possible in order to establish the schedule for the repayment of borrowing.
3. In order to reduce the replacing cost as much as possible, it is necessary not only to use the domestic materials, machines and equipment but also to employ local contractors for the execution of the works to the largest possible extent. For this purpose, it is also necessary to conduct prior detailed investigation and evaluation of the capacities, experiences and potentialities of major domestic manufacturers and contractors who are expected to participate in the replacing project.

In view of the importance of this project, as well as in order to make the project feasible, the application of the preferential tax rates is essential. Thus, it is necessary to have prior conferences with the governmental organizations concerned with regard to the exemptions of taxes on the salaries and allowances to be paid to the instructors and trainers of foreign nationals, and simplification of the related procedures.

4. Sincere technical consultants who have adequate experiences and are familiar not only with domestic regulations but also with various local situations in Bulgaria should be employed as soon as possible. Various matters and problems should be discussed or solved in promoting and implementing this project.

Furthermore, some local consultant has the custody of and controls all the drawings, data, etc. relating to the designs and executions of works for the retrofit and dismantling of all the existing electric power generating facilities owned by NEK. Further he has undertaken all the engineering works relating to the retrofit and dismantling of the existing facilities at the start of this project. In order to reflect on the new designs the solutions to the problems which have caused various troubles experienced in Maritsa East No. 1 thermal power plant and neighboring No. 2 and No. 3 thermal power stations, as far as the principle formation of contract is not jeopardized, close involvement of such a company would be contributory to effective and successful project implementation.

5. This study comprises the initial environmental evaluation (IEE) and environmental influence assessment (EIA) on Maritsa East No.1 thermal power plant. However, it is necessary for an environmental influence assessment report to be prepared in accordance with the form specified in the regulations of Bulgaria, consulting with the Environment Ministry prior to its publication, further for monitoring of environmental condition to be executed, if necessary, and for approval of the Environment Ministry and local inhabitants to be obtained prior to the publication of the report.

Furthermore, it is desirable to prepare for and maintain necessary system for the future need of environmental influence assessment on Maritsa East complex as the whole (including Maritsa East No.2 and No.3 thermal power plants), since such need seems to arise in the future.

6. Before commencing the execution of the proposed project, conference with coal mining companies and limestone mining companies concerned should be made on the following subjects.

(1) Subjects of conference with coal mining companies:

- Adjustment of the conditions concerning the properties of coal stipulated by the sales agreement.
- Agreement to severer quality control against the clay ingress to the coal.
- Agreement to conditions for the use and operation schedule of freight wagons to be used for the transportation of coal.

- Agreement to use of the surface soil disposal yard owned by the coal mine as ash yard of the power plant and the conditions for the use and operation schedule of the freight wagons for this purpose.
- Agreement to sharing of the responsibility for the work execution processes relating to the modification of existing railway or laying new railway incidental to the construction of new coal yard of the power plant.

(2) Subjects of conference with limestone mining companies:

- Since the limestone deposit expected for use for the power plant is still left undeveloped, the limestone mining company concerned should draw up its development plan and take necessary measures for financing the development plan in order to meet the progress of the replacing project.
The limestone mining company should also consider alternative measures against possible delay of limestone mining development.
- Agreement to conditions for the use and operation schedule of freight wagons to be used for the transportation of the limestone.

7. The circular and box concrete culverts of the existing intake and discharge channels have been used as common facility to all units in the thermal power plant. The soundness test of these culverts have never been conducted, and the progresses of the deteriorations of individual culverts are not known.

Thus, in this feasibility study, those culverts are assumed to be in sound condition judging from that the power plants has been operated without troubles. For this reason, it is necessary to examine the soundness of these existing culverts prior to the start of the execution of this project.

CHAPTER 1. INTRODUCTION

CHAPTER 1 INTRODUCTION

1.1 Background and Process of the Study

1.1.1 Outline of Power Demand in the Republic of Bulgaria

The power demand in Bulgaria increased and reached its peak in 1989. Since the national revolution toward democratization and introduction of a market economy in 1989, however, a reverse phenomenon occurred; power demands fell at an annual average of 8% in the industrial field as a transient phenomenon and with this, the industrial demand fell below that for public services. However, considering the movement toward a market economy as promoted by the Bulgarian Government, it is certain that power demands will increase in the future.

1.1.2 Power Supply in the Republic of Bulgaria

Regarding the power supply in the Republic of Bulgaria, the installed capacity is approx. 12,000MW; 51.7% by thermal power, 29.5% by nuclear power, and 18.8% by hydro power. This proportion ratio has remained almost the same for the last few years.

The majority of thermal power plant facilities were manufactured in the former U.S.S.R. or other East European countries. These facilities are now aged. In the case of nuclear power plants, the initial two units (440MW each) of the Kozloduy Nuclear Power Plant will be forced to shutdown in the near future.

Regarding the seasonal demand/supply balance, the supply capacity in winter is especially severe although its reinforcement is expected in the future in line with an ongoing economic recovery.

1.1.3 Outline of Energy Conditions in the Republic of Bulgaria

The major share of energy consumed in the country depends on imports. Natural gas and petroleum were previously acquired from the former U.S.S.R. and coal from the Ukraine, due to the close relationship with the former U.S.S.R. In response to the market economy, however, a stable supply from other countries has become difficult, and such a situation has already begun to affect the thermal power plants which use Ukrainian coal.

Dependency of Bulgaria on other countries for the primary energy source was 74% in 1995. It is predicted that this will reach 75.3% in 2000, 77.2% in 2010, and soar to 84% in 2020.

Today's most important measure is, therefore, to promote the effective use of domestic energy resources, namely the effective use of lignite which represents almost 85% of Bulgaria's entire domestic coal production. Domestic lignite is characterized with a low calorific value, a high moisture content and a high sulfur content.

1.1.4 Present Environmental Problems in the Republic of Bulgaria

Lignite produced in the Maritsa Region is the main and relatively sufficiently acquired domestic energy resource in the Republic of Bulgaria. At this time, its reserve is believed to be approx. 1.7 billion tons.

Regarding the fuel used at NEK's thermal power plants with a total of 6,415MW installed capacity, coal overwhelms all other fuels; 4,118MW or 64% by domestic coal, 1,847MW or 29% by imported coal, and 450MW or 7% by petroleum.

The Bulgarian Government has promoted the construction of coal-fired power plants as well as the development of nuclear power plants. Due to a high sulfur and high ash content, however, air pollution and other environmental problems have now become matters of serious concern.

Currently, various data estimate the following air pollutive substance generation: SO₂; 2.38 million ton/year, NO_x; 0.42 million ton/year, and dust; 0.65 million ton/year. Approx. 25% - 50% of this is believed to be generated by thermal power plants. In comparison to other east European countries, air pollution in Bulgaria is, however, relatively low although Bulgaria's SO₂ level is higher among all European countries.

The Ministry of Environment issued an 'Urgent Environmental Improvement Program in the Republic of Bulgaria' in April, 1990. The anti-air pollution project in this Program is regarded as an important move toward water quality improvement and forest protection.

The Bulgarian Government has also indicated that they follow the guidelines of the EC toward joining the EC. Following talks between the Bulgarian Government and the EC concerning air pollution and the reduction of sulfur oxide, a reduction goal has been determined based on the record of 1980. Sulfur oxide will be reduced by 33% in 2000, 40% in 2005, and by 45% in 2010.

In this Program, all anti-pollution measures for thermal power plants are practiced under the responsibility of 'the Committee of Energy'.

1.1.5 Environmental Restrictions for Thermal Power Plants

According to the Environment Protection Law of the Republic of Bulgaria, all new power plants installed in and after 1993 must meet the environmental standards of the Republic of Bulgaria.

The existing power plants installed prior to 1993 continue operation and pay a penalty for SO₂ and dust emissions exceeding the standard values.

1.1.6 Maritsa East Power Plant Group

The Maritsa Region is located approx. 40km southeast of Stara Zagora, Bulgaria's 6th largest city and approx. 250km east of the capital city, Sofia. The Toroyanovo Coal Mine which produces lignite, is situated in this region. The Maritsa East Power Plant Group is located nearby and is operated with this fuel.

The existing power plants are the Maritsa East 1, Maritsa East 2, and Maritsa East 3 with a total generation capacity of 2,280MW; 200MW, 1,235MW, and 840MW respectively. Approx. 35% of the Republic of Bulgaria's thermal power generation facilities are concentrated in this area.

1.1.7 Maritsa East No.1 Thermal Power Station

This power plant has operated for approx. 35 years since 1960 and its aging is significant. Especially, the service lives of its major components, the boiler/turbine have almost expired due to advancing metal fatigue. This situation is extremely critical in the continuance of the plant's operation.

This power plant is also equipped with a lignite drying plant which reduces the moisture of lignite from 55% to 40%. The efficiency of the dust collector is now only 60% due to its being of cyclone type. Also, with no desulfurizer, SO₂, NO_x, and dust emissions from this plant exceed the environmental standards by more than 10 times.

Two 150MW units were shut down approx. 5 years ago and are currently in the final stage of removal. Four 50MW units are presently in operation. Shutdown of this plant is difficult as it is obliged to supply 450t/h steam to a neighboring briquet plant as a public service.

This power plant was the first plant to use lignite from the Maritsa Region. Because of this, the plant has been well used to train a great number of high level engineers who are very experienced in all aspects related to lignite. The skills of these engineers are utilized in the construction and maintenance of other two power plants.

This power plant has approx. 1,200 employees including 110 experienced engineers, together with many skilled workers such as mechanics, electricians and welders.

1.1.8 Request for this Project

Considering the conditions described herein, on January 12, 1994, the Bulgarian Government requested the Japanese Government to conduct a study concerning the development.

1.1.9 Preliminary Study

JICA dispatched a Preliminary Study Group in November, 1994, as the Request from the Republic of Bulgaria included many unspecified factors. The preliminary study was conducted for the framework regarding the scope of F/S prior to an S/W agreement with the NEK which is the counterpart in the Republic of Bulgaria.

1.1.10 Preparatory Study

Based on the agreement after the Preliminary Study in November, 1994, JICA dispatched a Preparatory Study Group to the Republic of Bulgaria in January through February, 1995 to discuss the on-site study, consignment, and other matters related to the S/W agreement with the NEK. Both parties reached a unanimous agreement and an S/W and M/M were signed and exchanged on February 9, 1994.

1.1.11 Feasibility Study (F/S)

F/S was conducted over two fiscal years. The primary year F/S (fiscal 1995) started in June, 1995. All studies at the Preliminary Study and Detailed Study stages, and the major part at the Feasibility Design stage were conducted.

In the secondary year (fiscal 1996), study is conducted for the economic/financial analysis in the Feasibility Design stage. The result of this study is summarized in the Draft Final Report. The Final Report shall be submitted within one month after explanation/discussion to/with the counterpart in July, 1996. In the meantime, two technical transfer seminars were provided for related personnel of the Republic of Bulgaria.

1.2 Purpose, Outline, Scope and Period of the Study

1.2.1 Purpose

The purpose of this Study is to re-develop the optimum power generation facility at the area of the former Units 5 and 6 (150MW x 2) in Maritsa East 1.

1.2.2 Outline, Scope and Period

The main subject area of this Study is the Maritsa East 1 site in Galabovo approx. 40km southeast of Stara Zagora located approx. 250km east of the capital city, Sofia, and neighboring the coal mine(s).

The relevant facilities include the Toroyavo 1, 2 and 3 coal mines which lie to the northeast of Maritsa East 1, the Maritsa East Coal Mine Management Company, Maritsa East 2 and 3 where the lignite from these local mines is used, the Energoremont machinery plant, and limestone mine, etc.

This Study is based on the Scope of Works (S/W) signed on February 9, 1995, and the Minutes/Memorandum (M/M) regarding the S/W.

The main points of this study are to make examination and evaluation of technology for replacement of optimum power generation facilities based on the technical and economical factors in response to the environmental standards of Bulgaria or the EC and to execute Feasibility Design and F/S including the economic/financial analysis.

The Study was conducted in the following three stages.

(1) Stage 1:

Preliminary Study stage; June - October, 1995

(2) Stage 2:

Detailed Study stage; November - December, 1995

(3) Stage 3:

Feasibility Design stage; January - June, 1996

Job sections and Name of person of JICA team

| | |
|---|----------------------|
| * Management (Team Leader) | : Juro INOUE |
| * Co-management (Assistant leader, Power generation development plant) | : Zenjiro TSUTSUI |
| * Thermal power generation facilities (Boiler and Environment Protection Facilities) | : Koichi KOBAYASHI |
| * Thermal power generation facilities (Boiler and Auxiliary Facilities) | : Masanori MORISHITA |
| * Environmental protection facilities (Facilities/Chemical Engineering) | : Ryoichi SAKANISHI |
| * Thermal power generation facilities (Turbine Generator and Auxiliary Facilities) | : Hideyuki OKANO |
| * Thermal power generation facilities (Electrical Instrumentation and Control) | : Shunichi KIYOSAWA |
| * Power generation architecture | : Yasushi ISHIKAWA |
| * Power generation civil engineering | : Naoto AKIKUNI |
| * Environment | : Masayoshi ONO |
| * Transmission plan | : Takaya NOMURA |
| * Economical/financial analysis | : Hirohito ARAKI |
| * Measurement/analysis | : Jun MITSUHASHI |
| * Project coordinator | : Yusaku YOKOYAMA |

1.2.3 On-site Study

The following study was conducted in response to the precision level in each stage. The study was conducted by a Study Group consisting of experts in each field.

(1) Preliminary Study Stage

- (a) Collection and analysis of necessary data and information
- (b) Coal/petroleum/gas supply
- (c) Limestone supply
- (d) Power development projects
- (e) Power plant operation standards
- (f) Initial environment (IEE)
- (g) Existing fluidized bed (FBC) boiler and lignite fired boiler
- (h) Existing facilities to be reused for a replacing plant
- (i) Possibility of local procurement of fabrication and installation

- (j) Transmission lines and substations
- (k) Local consignment
- (l) Transportation procedures of lignite for combustion test
- (m) Existing power plants

(2) Detailed Study Stage

- (a) Detailed site survey
- (b) Environmental impact assessment (EIA)
- (c) Equipment and materials
- (d) Construction cost, etc.
- (e) Design related restrictions
- (f) Restrictions in interfacing with the operating facilities
- (g) Lignite combustion test and analysis
- (h) Progress state of local consignment

(3) Feasibility Design Stage

Economy/finance related supplementary study

1.2.4 Study in Japan

The following major items were studied from different aspects based on the information and data acquired from the on-site study and in Japan.

- (1) Power development plan
- (2) Fuel and limestone supply plan
- (3) Lignite combustion test on bench scale fluidized bed
- (4) Optimum replacement plan
- (5) Conceptual design
- (6) Construction plan
- (7) Replacing plant construction
- (8) Environmental impact assessment
- (9) Economic/financial analysis

1.2.5 Study Flow Chart

The study was conducted according to the flow chart in Figure 1-2-5.

Work by JICA Study Team Work by NZX Study Team




Figure 1-2-5. Study Work Flow Chart

1.3 Relevant Organization

The Nationala Elektrieska Kompania (NEK) was established on November 7, 1991, in accord with a Cabinet Act. Its operation started in January, 1992.

The NEK is a stock company owned by the Government. It conducts an integrated operation ranging from power generation to transmission and distribution. Heat supply is also included in the operation.

The NEK mainly owns and operates the thermal power plants, hydro-power plants (pumped storage included) and the Kozloduy Nuclear Power Plant as well as all sub-stations, transmission lines and distribution network nationwide distributed.

The NEK has 41 branches; 10 in the power generation division, 28 local power supply companies in the distribution division and 3 branches in the construction division.

As of 1996, the NEK employees approx. 32,000 people. Staffed by approx. 80 employees, the Command Center is located next to the NEK Head Office. The NEK Head Office is staffed by approx. 120 employees, which is rather a small number.

The NEK is supervised by the Committee of Energy which controls the entire electric utility industry. Electric charges are, however, controlled by the State Energy Regulatory Committee, established in June, 1993.

The National Assets, Privatization, and Finance Department was established within the Committee of Energy in June, 1993. This section is dedicated to the reform strategies of 1993-1997 and the privatization of energy related industries.

The government organization to which the NEK belongs is currently managed by the Ministry of Industry.

The NEK system is introduced in Figure 1-3-1.




Figure 1-3-1 NEK System

* The Committee of Energy was reorganized into "the Ministry of Energy and Energy Resources" under the date of June 14th, 1996.

1.4 Acceptance of Trainees

As the counterpart, the NEK dispatched Mr. Dimitre Lubomirov Petrinski and Mr. Penio Jekov Penev to Japan as trainees. They were in Japan from March 23, 1996, to April 13, 1996.

1.5 Provision of Equipment

Equipment for atmospheric measurement and flue gas measurement listed below required for this Study were provided to the NEK by JICA. The equipment provided is listed in the Supplement.

| | | |
|-----|--|--------|
| 1. | Stack gas measuring instrument | |
| 1-1 | Portable NO _x , SO ₂ , O ₂ gas analyzer | 1 set |
| 1-2 | Dust sampling equipment | 1 set |
| 2. | Air pollution measuring instrument | |
| 2-1 | SO ₂ monitor | 1 set |
| 2-2 | NO _x monitor | 1 set |
| 2-3 | Dust sampler and deposit gauge | 4 sets |

CHAPTER 2. REPLACING PLANT SITE

CHAPTER 2 REPLACING PLANT SITE

2.1 Outline of Maritsa East No.1 Thermal Power Plant

2.1.1 Outline

(1) Power Generating Facilities

This power plant has reached the limit of its service life so that it is in serious condition for further continued operation, because it has passed about 36 years since it started operation in 1959 and its major components such as boiler and turbine are seriously aged.

Additionally, the importance of this plant also exists in the fact that it is responsible for supplying drying vapor (450t/h) to a private briquette factory and heating vapor (50-60t/h) to nearby area. Environmental protection measure for this plant is urgent because combustion gas (containing SO_x, NO_x, Dust, etc.) produced and exhausted from combustion of domestic lignite exceeds national environmental standard extremely.

Figure 2-1-1 shows a layout and unit configuration of this power plant.

(a) Unit Nos. 1 through 4 unit (started in 1959 through 1962)

- 1) Boiler (210 t/h) x 6 → Common steam header + turbine generator (50 MW) x 4
Turbine extraction steam → Steam supply equipment (for briquette: 450 t/h, for area heating: 50 to 60 t/h)
- 2) Main facilities: All of them were made in ex-Soviet and the electrostatics precipitators were made in ex-East Germany.

(b) Unit Nos. 5 and 6 (started after 1964 and currently being removed)

- 1) Boiler x 4 + turbine generator (150 MW) x 2
- 2) Main facilities: All of them were made in ex-Soviet

(c) Lignite drying facilities

These facilities are a preliminary stage for putting in coal bunker and lower water contents from about 55 % (on arrival basis) to about 40 %. However, drying equipment for old boiler Nos. 7 through 10 are currently being removed like the boilers.

(d) Stack (made of concrete)

For boilers in operation (unit Nos. 1 to 6) = x 1 (150 m high), for boilers under removal (unit Nos. 7 to 10) = x 1 (180 m high), for drying coal = x 2 (120 m high). However, the stacks for the boilers currently being removed will be removed.

(e) Other special matters

The main equipment now in operation (unit Nos. 1 to 4) is near the end of its useful life due to metallic fatigue, but its operations continue by making repairs because steam supply is needed for briquette and area heating.

(2) History and accumulated result of the operation

(a) Unit Nos. 1 through 4 (In operation: from the beginning of operation to October 1994)

- Total operation time: 190,000 to 210,000 hours for boiler 240,000 to 250,000 hours for turbine/generator
- Number of starts and stops: 600 to 950 times for boiler 360 to 450 times for turbine/generator

(b) Unit Nos. 5 and 6 (Under removal: Stopped their operations in 1991.)

- Total operation time: 160,000 hours
- Number of starts and stops: 500 to 550 times

(c) Generated power amount and amount of supplied heat (1993/1994)

- Generated power amount (10^6 kWh): 1,118/980
- Amount of supplied heat (10^3 Gcal): 1,553/1,102

2.1.2 Organization System

The total personnel in the power plant is 1,234 and its organization and distribution of personnel is shown in Table 2-1-1.

2.2 Site Condition

2.2.1 Location

This plant is located at the town "Galabovo" in the vicinity of lignite mine (open cut mine) at the Maritsa area about 40km southeast of Stara Zagora (population about 300,000), which is the sixth largest city of Bulgaria, about 250km east of its capital city Sofia.

Maritsa East No. 2 thermal power plant (1,450MW) and No. 3 thermal power plant (840MW) exit around this mine and about 38% of the thermal power generating equipment in this country (including private power generation) are concentrated on this area.

2.2.2 Access

The accesses from the capital city Sofia to Maritsa East No. 1 thermal power plant are gained by vehicles through a highway leading to Stara Zagora (about 250km) main road (17km) running from south-east, ordinary road (20km) and return again to main road (3km). A main road running before this plant is an important truck line for industry connecting Turkish with Rumania.

A railway siding in is installed in the power plant and railway is used for transportation of coal and construction material. This railway network is effectively used for this replacing plan.

2.2.3 Climate

(1) The climate of Bulgaria is relatively mild and four seasons are clearly seen. In a region in which this plant is located, the climate is of the Mediterranean type having mild temperature and high humidity but no violent storm.

(2) The yearly average temperature, rainfall days and relative humidity, etc. observed for 10 years from 1983 to 1992 in a weather observation station located on the Lozoflanets lake 1km to the southwest of this plant are as follows.

- Temperature: 12.5°C {Monthly Ave. Max 23.8°C(July), Min 1.8°C (January, December)}
- Atmospheric pressure: 1003.5 hPa [Monthly Ave. Max 1007.9hPa (December), Min 998.9hPa (June)]
- Rainfall days: 42 days [Monthly Ave. Max 8 days (January, November, December)]
- Snowfall days: 14 days [Monthly Ave. Max 4 days (January, February)]

- Relative humidity: 73% [Monthly Ave. Max 84% (December), Min 63% (June)]
- Wind direction, velocity: North east, 2.5m/s

2.2.4 Topography and geology

(1) Topography

- (a) The project site is located on the Thracia Plain 100 m above the sea level, surrounded by moderately sloped hill area where lands are used as farmland (for wheat, potato, orchard and etc.) and, therefore, less forested.

- (b) The Sazlika River flows north of the Maritsa East No.1 Power Station. As a tributary of the Sazliika River, the Ovcharitza River runs out of the Sazliika River adjacent to the Maritsa East No.2 Power Station.

From the direction of the Maritsa East No.3 Power Station, the Sokoritza River flows into the Sazliika River.

The Rozovkladenets Lake located south of the Maritsa East No.1 Power Station was constructed artificially by damming up the Sokoritza River to obtain cooling water for the power station.

- (c) The underground water is used for irrigation of farmland and not for drinking water. The drinking water in the Galabovo District is taken in from the Sazliika River.
- (d) Within the project site, there is no specified nature preservation zone or other particular area except one spot where the Thracia remains during the second through third century before Christ are located, and have been enclosed by protective palisade and preserved carefully after its explorative inspection was completed.

(2) Geology

The geological section within the power plant site is composed of alluvial deposits of the Sokolitza River. The surface layer being 4m deep consists of deposits of sand, clay, coal etc. and a layer under it up to GL-6m ~ -11m constituted with sandy clay and sand is formed on the hard clay layer of 30 ~ 40m in depth which has a N value of around 21 ~ 33 and plays a role of supporting layer of foundations.

The foundation of heavy structures in the existing power plant such a turbine house is of a direct supporting type utilizing the hard clay layer.

The underground water level in the area of a turbine house is GL-6m (101.2m above the sea water level) in average.

Underthere, a hard clay layer with N value 21 - 33 exists throughout the thickness of 30 - 40m, thereby acting as plantUs foundation supporting layer.

The foundation of the heavy construction of this power plant is directly based on this layer. The average underground water of the main building of this plant is GL -6m (101.2m at allitude).

Table 2-1-1 Organization and Personnel of ME-1 TPP

| Division | Description of Division | Personnel | Remarks |
|---|--|-----------|---------|
| Manager of this plant | Administration of the entire plant | 1 | |
| 1. Reception and supply of coal | Reception of coal, storage, transportation and crushing | 145 | |
| 2. Drying of coal | Drying of coal | 105 | |
| 3. Operation and maintenance of boiler equipment | Operation, management and repair of boiler equipment, ash treatment, operation, management and repair of heavy oil equipment | 230 | |
| 4. Repair of boiler related equipment | Disassembly, inspection, repair and daily light repair of coal drying furnace, boiler and auxiliary equipment | 97 | |
| 5. Welding correction | Welding correction of the above mentioned equipment | 39 | |
| 6. Operation and maintenance of turbine equipment | Operation, management and repair of turbine equipment | 116 | |
| 7. Operation and maintenance of electric equipment | Operation, management and repair of electric equipment | 97 | |
| 8. Operation and maintenance of instrumentation equipment | Operation, management and repair of instrumentation equipment | 47 | |
| 9. Operation and maintenance of water equipment | Operation, management and repair of water equipment | 42 | |
| 10. Repair of rotatory machines | Repair of pump, valve and motor, etc. and production of reserved parts | 57 | |
| 11. Operation and maintenance of heat supply and drainage equipment | Operation, management and repair of heat supply equipment and construction of related buildings Management and repair of drainage equipment (including sewage work) | 31 | |
| 12. Transportation and procurement | Transportation of machine and equipment in the plant and procurement of consumption materials, reserved parts and materials | 30 | |
| 13. Accounting, personnel affair and welfare | Accounting, personnel affair and management of other general matters Operation and management of welfare facilities | 197 | |

(Total) 1,234




Figure 2-1-1 Layout of Unit for Maritsa East No.1 Thermal Power Plant

CHAPTER 3. ELECTRIC POWER DEVELOPMENT PLAN STUDY

CHAPTER 3 ELECTRIC POWER DEVELOPMENT PLAN STUDY

3.1 Electric Power Facilities

3.1.1 Power Generating Facilities

Outline of electric power facilities in Bulgaria is indicated as Figure 3-1-1-1.

Table 1-1-1 shows the transition of installed generating capacity between 1985 - 1995.

In 1995, the total generating capacity was 12,751 MW, of which 11,112 MW is owned by NEK, and the remaining 1,639 MW by industry.

The power source percentages are 6,589 MW (51.7%) by thermal, 3,760 MW (29.5%) by nuclear, 2,402 MW (18.8%) by hydroelectric.

Regarding the thermal power plants, the fuel composition of thermal power plants owned by NEK was lignite 64.09%, imported coal 20.69%, bituminous coal 14.21%, natural gas 1.01% as of 1993.

Of a total of 87 hydroelectric power plants, 58 are of run-off-river type (total output 176 MW), and the 29 are balance of poundage type (total output 2,226 MW).

In 1994, Chaira pumped-storage power plant Stage 1 with 2 units x 216 MW was commissioned and Stage 2 with 2 units x 216 MW is under construction.

Bulgaria's sole nuclear power plant, the Kozloduy nuclear power plant has 6 Russian-made nuclear reactors (VVER); 3,760 MW (440 MW x 4, 1,000 MW x 2).

Repair work for the aged unit Nos. 1 to 4 started in 1991. This work was completed for No. 2 unit in 1992, for No.1 unit in 1993, and for unit Nos. 3 and 4 in 1994.

The Bulgarian government has decided to put the aged unit Nos. 1 and 2 (440 MW x 2 out of service), but the date of outage is not fixed up yet.

3.1.2 Transmission Lines and Substation Facilities

Bulgaria's trunk transmission system is 400 kV and 220 kV.

The 750 kV transmission line is used only for interconnection with the Ukraine via Rumania.

Table 3-1-2-1 shows an outline of the transmission line.

As of 1995, there was one substation in the 750 kV system, 10 in the 400 kV system, 16 in the 220 kV system, and 269 in the 110 kV system. The installed capacity was 31,527 MVA.

3.2 Power Supply and Demand

3.2.1 Power Demand Analysis

(1) Power Demand Transition

The energy consumption declined from 1989 onward and decreased significantly in 1991, being only 14.4% less, compared with the previous year. Since then, however, the decline has been small. In 1994, the energy consumption increased only 0.3% compared with the previous year, but it indicated a major increase under influence of intense cold in 1995, amounting to 32,015 GWh.

On the other hand, however, in 1993, the annual energy consumption was 3,429 kWh/capita. The peak power demand reached the highest level (8,332 MW) in 1989 and declined since then to 7,520 MW in 1995.

Figure 3-2-1-1 shows the monthly energy consumption for 1994 and 1995. The maximum energy demand came out in December and January and the minimum energy demand in July and August.

(2) Energy Generation Transition

Energy generation decreased from 1989 but began to increase in 1993. Energy generation for 1995 was 42,003 GWh, a major increase of 10.2% over the previous year.

(3) Past Records of Power Interchange

When examining the net imported energy, which is derived from subtraction of the exported energy from the imported energy, it is seen that Bulgaria was a power importing country. Recently, however, the percentages of imported and exported energy are almost equal.

(4) Load Characteristics

Power demands for the industry, construction, and agriculture sectors are decreasing considerably. The constitution ratio for 1993 is 45.4% for the industry sector, 1.6% for the construction sector, 2.7% for the agriculture sector, 4.8% for the transportation and communications, 11.0% for the public sector and 34.6% for the household sector, respectively.

The annual load factor shifts around 50%. The loss factor is practically stable. The average loss for the 11 years 1985 to 1995 is 4,474 GWh for auxiliaries and 4,680 GWh for network. On the other hand, auxiliary loss for 1995 was 4,353 GWh and the network loss, 5,415 GWh. The ratio of auxiliary loss to the gross generation is 10.4%, and a ratio of transmission loss to the sending end energy of 14.4%. The total energy loss is 23.3% to the gross generation.

Figure 3-2-1-2 shows the maximum and minimum daily load curves for 1994.

3.2.2 Power Demand Forecast

(1) Forecast Method

A macro forecast method which forecasts the demand for the entire nation was applied. A long range energy demand for the entire nation is estimated by finding a fixed law or trend line in the past energy demand records.

The following five methods are generally known as forecast methods.

- (a) A trend line is found in the logarithmic trend of past demands and this will be extrapolated.
- (b) Linear regression forecasting is used when a linear relationship is recognized between the GDP and the power demand.
- (c) Quadratic regression forecasting is used when a curved relationship is recognized between the GDP and the power demand.
- (d) Multiple regression forecasting using selling cost and population (or number of customers) other than GDP as explanatory variable (independent variable).
- (e) Forecasting using the correlation between GDP/capita and kWh/Capita found in international statistics.

In method (a), the trend line derived from past records is simply extrapolated. This method can be used only for forecasting for the near future.

On the other hand, past records show that energy consumption increased from 1985 to 1989, then decreased from 1990 to 1993 and again increased from 1994. As seen, there are three trend line patterns and it would, therefore, be very difficult to use methods (b) - (d).

For the above reasons, method (e) will be used to make the demand forecast. The relation between Bulgaria's GDP/capita and kWh/capita from 1985 to 1993 will be used.

(2) Forecast Conditions

(a) Explanatory variable

The energy consumption record, and transition of GDP and population (1985 - 1993) which are the explanatory variables are shown in Table 3-2-2-1. The relation between the GDP/Capita and kWh/capita is shown in Figure 3-2-2-1.

The power demand forecast term is limited to 14 years, from 1996 to 2010.

(b) Economic scenario

The economic growth scenario is decided as follows. Bulgaria's GDP increased steadily up to 1989. From 1990, it started to decrease remarkably. However, this decrease stopped by 1991. The GDP started to increase again from 1991 and increased 2.5% in 1995, compared with previous year.

Assuming that the GDP is flat in 1994, and then increase from 1995 onward, three cases are studied; low case (3% GDP growth), middle case (4% GDP growth) and high case (5% GDP growth).

The population was 8.472 million as of 1993 and is expected to be 8.897 million in 2000 and 8.902 million in 2010, respectively.

(3) Power Demand Forecast Results

Using the above conditions, based upon the data in 1993, the relation between the GDP and population is anticipated as follows.

(a) Low case (3% GDP growth)

GDP : $10,812 \times (1+0.03)^{16} = 18,000$ (US\$ million)

Population : 8.902 million

GDP/capita : $18,000/8.902 = 2,100$ (US\$/Capita)

From Figure 3-2-2-1, kWh/capita is 4,100 (kWh/capita), and the energy consumption in 2010 will be $4,100 \times 8.902 = \underline{37,000}$ (GWh)

(b) Middle case (4% GDP growth)

GDP : $10,812 \times (1+0.04)^{16} = 21,000$ (US\$ million)

Population : 8.902 million

GDP/capita : $21,000/8.902 = 2,400$ (US\$/capita)

From Figure 3-2-2-1, kWh/capita is 4,200 (kWh/capita) and the energy consumption in 2010 will be $4,200 \times 8.902 = \underline{38,000}$ (GWh)

(c) High case (GDP growth 5%)

GDP : $10,812 \times (1+0.05)^{16} = 24,000$ (US\$ million)

Population : 8.902 million

GDP/capita : $24,000/8.902 = 2,700$ (US\$/capita)

From Figure 3-2-2-1, the kWh/capita is 4,300(kWh/capita), and the energy consumption in 2010 will be $4,300 \times 8.902 = \underline{39,000}$ (GWh)

3.2.3 Power Demand Forecast by NEK

NEK has made an energy supply forecast up to 2010, based on three scenarios, low, middle and high. In the middle case it is predicted that the energy supply will recover to the 1989 level in the year 2005.

NEK's power demand forecast is made for the energy supply and will, therefore, be converted to energy consumption which is obtained by subtracting auxiliary loss and network loss from energy supply. The average auxiliary loss and network loss for the 11 years between 1985 to 1995 which are 4,474 GWh and 4,680 GWh respectively, is used. The amount of imported and exported energy has been balanced for several years and will, therefore, be ignored in forecasting in these scenarios.

Figure 3-2-3-1 compares the demand forecasts of NEK and JICA Study Team. JICA's case locates between NEK's low case and middle case. An energy demand growth from 1995 to 2000 in NEK's middle case and high case is predicted to be so big, as much as 20% and 30%.

In the JICA forecast, the energy demand growth in 2010, compared with 1995 is, 16% low case, 19% middle case and 22% high case, respectively. While in the NEK forecast it is, 9% low case, 34% middle case, and 46% high case.

In the low case of NEK, demand from 1995 to 2000 declines. This trend is opposite to recent trend. On the other hand, the high case of NEK indicates the growth rate of demand from 1995 to 2000 is very high. This is not realistic. From the above, the middle case of NEK which indicates same trend as JICA study team's forecast is adopted.

3.2.4 Electric Power Development Plan, and the Balance of Supply and Demand

Table 3-2-4-1 shows the electric power development plan (1995 -2005) and power demand forecast prepared by NEK in 1994. This power demand forecast is for the middle case.

The scale of electric power development from 1995 is 951 MW (a 9% increase), of which thermal will be increased 1,275 MW, hydroelectric will be increased 476 MW and nuclear decreased 800 MW, respectively.

As a result, the installed capacity in 2005 will be 11,540 MW in total which is broken down to. The breakdown is 6,130 MW (53.1%) thermal, 2,710 MW (23.5%) hydroelectric, and 2,700 MW (23.4%) nuclear, respectively.

When the supply reserve to peak power demand is examined, it is seen that it will be at the lowest level between 2000 and 2001 when the installed capacity of the nuclear power plant is decreased.

In the future, Bulgaria's power demand is expected to certainly increase even if the lowest economic growth were to be the case. When the demand structure is examined, industry power demand is currently decreasing greatly. However, as economic growth progresses and industrial power demand increases, it is possible that power demand will grow rapidly. Also, the expected shutdown of unit Nos. 1 and 2 at the Kozloduy nuclear power plant from 2000 will make power supply tight. The necessity to develop a new power source will, therefore, be high.

Furthermore, in view of energy resources, the effective use of lignite, Bulgaria's main energy resource, is essential.

Also, in formulating the electric power supply plan in Bulgaria, it is important to incorporate replacing as well as repairing and remodeling of the existing power plants as a means to increase power generation capacity.

For the above reasons, the replacing plan of the Maritsa East No. 1 thermal power plant is extremely important.

3.3 Study and Analysis of Power System

3.3.1 Study Conditions

Study and analysis of power system (Power Flow Calculation, Short Circuit Capacity, Stability) in Bulgaria was studied under below conditions.

- (1) Year to be studied: 2001 when replacing plants will start to operate.
- (2) As for power system composition and impedance, NEK's data were used. Figure 3-3-1-1 indicates Impedance Map.
- (3) Total demand in 2001 is 8,470 MW.
- (4) Assuming that a 3-phase grounding short circuit (3LG) failure takes place at the bus of Maritsa East No.1 Substation (Galabovo), transient stability of power system was studied.
- (5) Operation condition of power system is as follows.
Voltage regulation target: within 95 to 105%
Load power factor: 95% (delay)

3.3.2 Study Results

(1) Power Flow Calculation

As the results of the power flow diagram from calculation, it is found that there is no problem in bus voltage in each substation and power flow in transmission line.

(2) Short Circuit Capacity

The 3-phase short circuit current is 1.4 kA and short circuit capacity is 535 MVA.

(3) Stability

As the results of simulation study. The system is found stable in this case.

Table 3-1-1-1: Development of Installed Capacity in Bulgaria (Unit:MW)

| Years | NEK | | | | | Total | Increase (%) |
|-------|---------|---------|---------------|----------------|-------|--------|--------------|
| | Thermal | Nuclear | Hydroelectric | Sub Total | | | |
| | | | | Industry-Owned | Total | | |
| 1985 | 4,820 | 1,760 | 1,975 | 8,555 | 1,681 | 10,236 | 0.0 |
| 1986 | 4,820 | 1,760 | 1,975 | 8,555 | 1,681 | 10,236 | 9.8 |
| 1987 | 4,820 | 2,760 | 1,975 | 9,555 | 1,725 | 11,280 | 0.4 |
| 1988 | 4,820 | 2,760 | 1,975 | 9,555 | 1,725 | 11,490 | 1.9 |
| 1989 | 5,030 | 2,760 | 1,975 | 9,765 | 1,664 | 11,132 | -3.1 |
| 1990 | 4,735 | 2,760 | 1,975 | 9,468 | 1,639 | 11,104 | -0.3 |
| 1991 | 4,735 | 2,760 | 1,970 | 9,465 | 1,639 | 11,104 | 0.0 |
| 1992 | 4,735 | 2,760 | 1,970 | 9,465 | 1,639 | 12,104 | 9.0 |
| 1993 | 4,735 | 3,760 | 1,970 | 10,465 | 1,639 | 12,536 | 3.6 |
| 1994 | 4,735 | 3,760 | 2,402 | 10,897 | 1,639 | 12,751 | 1.7 |
| 1995 | 4,950 | 3,760 | 2,402 | 11,112 | 1,639 | | |

Table 3-1-1-2: Outline of Thermal Power Plants in Bulgaria

| Power Plants | Commissioning Date | Installed Capacity (MW) | Energy Generation in 1994 (GWh) | Fuel Type |
|----------------|--------------------|-------------------------|---------------------------------|----------------------------|
| Varna | 1968,69,70,77,79 | 1,260 | 2,308 | Imported Coal, Natural Gas |
| Maritsa East 2 | 1966,69,85,90,95 | 1,450 | 6,091 | Lignite |
| Maritsa East 3 | 1978,79,80,81 | 840 | 4,437 | Lignite |
| Bobob Dol | 1973,74,75 | 630 | 2,075 | Brown |
| Russe | 1964,66,67,84,85 | 400 | 638 | Imported Coal |
| Maritsa East 1 | 1959,60,61,62 | 200 | 980 | Lignite |
| Maritsa 3 | 1951,52,54 | 170 | 232 | Lignite |

Table 3-1-2-1: Outline of Transmission System in Bulgaria (Unit:km)

| Years | 750kV | 400kV | 220kV | 110kV | |
|-------|-------|-------|-------|----------|-------|
| | | | | Overhead | Cable |
| 1985 | | 1,509 | 2,197 | 7,382 | 34 |
| 1986 | | 1,671 | 2,242 | 7,519 | 39 |
| 1987 | | 1,680 | 2,288 | 7,576 | 39 |
| 1988 | 85 | 1,718 | 2,282 | 7,795 | 44 |
| 1989 | 85 | 1,844 | 2,283 | 7,809 | 44 |
| 1990 | 85 | 1,844 | 2,283 | 7,922 | 44 |
| 1991 | 85 | 1,844 | 2,283 | 7,929 | 44 |
| 1992 | 85 | 1,844 | 2,308 | 7,937 | 44 |
| 1993 | 85 | 1,862 | 2,296 | 8,026 | 44 |
| 1994 | 85 | 1,862 | 2,296 | 8,026 | 44 |
| 1995 | 85 | 1,862 | 2,296 | 8,165 | 44 |

Table 3-2-2-1: Data for Regression Equation

| Year | GDP | | Energy Consumption | | Population | | GDP/Capita | | kWh/Capita |
|------|--------------|------------|--------------------|---------|------------|------------|-------------|-------|------------|
| | Million US\$ | Increase % | GWh | Million | Million | Increase % | US\$/Capita | | |
| 1985 | 32,277 | | 37,376 | 8,961 | 8,961 | | 3,602 | 4,171 | |
| 1986 | 31,569 | -2.2 | 37,027 | 8,958 | 8,958 | 0.0 | 3,524 | 4,133 | |
| 1987 | 28,786 | -8.8 | 38,643 | 8,971 | 8,971 | 0.1 | 3,209 | 4,308 | |
| 1988 | 26,197 | -9.0 | 39,483 | 8,980 | 8,980 | 0.1 | 2,917 | 4,397 | |
| 1989 | 24,294 | -7.3 | 39,336 | 8,885 | 8,885 | -1.1 | 2,734 | 4,427 | |
| 1990 | 15,982 | -34.2 | 36,854 | 8,669 | 8,669 | -2.4 | 1,844 | 4,251 | |
| 1991 | 7,068 | -55.8 | 31,561 | 8,596 | 8,596 | -0.8 | 822 | 3,672 | |
| 1992 | 8,608 | 21.8 | 29,259 | 8,485 | 8,485 | -1.3 | 1,014 | 3,448 | |
| 1993 | 10,812 | 25.6 | 29,048 | 8,460 | 8,460 | -0.3 | 1,278 | 3,434 | |




Figure 3-1-1-1 Oneline of Electric Power Facilities in Bulgaria




Figure 3-2-1-1: Monthly Trend of Energy Consumption in Bulgaria




Figure 3-2-1-2: Peak and Minimum Consumption Days in 1994




Figure 3-2-2-1: Relationship between per capita GDP and Energy Consumption





Figure 3-2-3-1: Energy Demand Forecast.

CHAPTER 4. STUDY OF COAL AND LIMESTONE SUPPLY



CHAPTER 4 STUDY ON COAL AND LIMESTONE SUPPLY

4.1 Coal

4.1.1 Present Conditions and Plans in Bulgaria

(1) Coal mine locations

In Bulgaria, there are 12 coal mines in the East and West sides largely divided. Figure 4-1-1 shows the locations of the coal mines.

(2) Reserve, coal type and mining method

Reserve of lignite is large. The Maritsa East coal mine has more than 85% its reserve. Table 4-1-1 shows the reserves of respective mines, coal types and mining methods.

(3) Actual mining results of respective mines

Table 4-1-2 shows the actual mining results of the respective mines from January 1, 1992 to October 31, 1994.

(4) Mining schedule of the respective mines

Table 4-1-3 shows the mining schedule of the respective mines from 1995 to 2020.

4.1.2 Maritsa East Coal Mine

(1) Location of the coal mine

This mine is the largest lignite open-cast mine in Bulgaria and divided to three areas (Trojanovo-North, Trojanovo-1, Trojanovo-3). Maritsa East No. 1 to No. 3 thermal power plants exit in the periphery of the mine.

Figure 4-1-2 shows approximate locations of the mine and power plants.

(2) Present conditions and features

- (a) Management corporation: Trojanovo Mining Company (Radnevo) administers the operation of this mine and comprises No. 1 to No. 3 branches, Lemontech (machinery repair) and an investment company.

(b) Production amount

- 1) The actual production of 1993 was approximately 23×10^6 ton/year while production for Maritsa East No. 1 to No. 3 power plants was 19×10^6 ton/year and that for briquette was 4×10^6 ton/year.
- 2) Due to financial difficulties, the coal-mining company has been finding it difficult to devise periodic inspection and repair plans in recent years. There has been in consequence a shortage of replacement parts, and machinery and equipment have not been in good working order. However, the company assesses that the individual sites will be able to operate without trouble up until 2025.


(c) Coal property

(sulfur content, ash content = air-dried base, moisture content = as-received base)

- Bulgarian standard : Lower heating value (LHV) = more than 1,300kcal/kg,
Ash content = less than 36%
- For power plants : LHV = 1,300 ~ 1,350kcal/kg, Ash content = 34 ~ 35%,
Moisture = 52 ~ 60%
- For briquette : LHV = 1,300 ~ 1,750kcal/kg, Ash content = less than 22%
- Sulfur (S) content = 5-6% (air-dried base)
- C = 15%, H₂ = 1.6%, O₂ = 5.5%, N₂ = 0.34% (as-received base)

(d) Supply destinations of the respective mining areas and transportation methods

A 24-hour operating system can be maintained. The current situation and future schedule for destination and transportation method are as follows.



(e) Features of coal seam

1) Structurally, there are 3 seams of coal, with a seam of clay in-between, as diagrammatically shown below:

| (Seam thickness) | (Surface) | |
|------------------|--|---|
| 50 ~ 60 m | Top soil | |
| 0.7 ~ 0.9 m | No.1 Coal seam: Disuse | Ash content 30% |
| 0 ~ 4 m | Clay (so-called blue clay) | Ash content 60 ~ 70% |
| 20 m | No.2 Coal Seam { For power generation For briquette For power generation } | Ash content 20 ~ 30% * Clay content (0.5 ~ 2m) is contained in the seam (so-called black clay) |
| 3 m | Clay (so-called blue clay) | Ash content 60 ~ 70% |
| 3 m | No. 3 Coal seam: For power generation | Ash content 30 ~ 35% |
| 1 ~ 2 m | Clay (so-called blue clay) | Ash content 60 ~ 70% |

2) Although S content is currently 2.0 ~ 2.6% (air dried base), there is no difference between the medium seam (No.2 seam) and bottom seam (No.3 seam), it changes depending on digging direction.

- North → South: S = 2.5 → 1.7%
- East → West: S = 4.55 → 6.0%

Additionally, ash content (32 ~ 33% on an air-dried basis) changes depending on digging direction and depth.

- East → West: 1 ~ 2% increase
- Medium seam (No. 2 seam) → Bottom seam (No. 3 seam): 2 ~ 3% increase

(f) Operation management

1) Operation management is conducted according to the Bulgarian standard. Because current power generating equipment sometimes undergoes trouble in transportation and combustion of coal particularly when ash content is $34 \pm 12\%$, ash content 33-34% is strictly kept.

2) As for the mining of No.2 coal seam, reclaimers are used to mine the coal seam along with the upper and lower seams of clay, measuring 50 cm each in thickness, so as to prevent the breakage of coal. Since clay is contained in that coal seam, coal to be transported to the power plants contains clay without exception.

- 3) Surface soil is disposed at special areas near the mine by means of special trains and belt conveyor.

Related transportation equipment and disposal equipment are possessed by the mining company and the operation is managed by it. Figure 4-1-3 shows the disposal sites.

- (g) Contract condition with the power plant

Although ash content and moisture were conditions in the contract until March 1995, a calorific value has been added to the conditions in the contract unit price has been fixed up since 1995.

- (h) Transportation problems

- 1) When the atmospheric temperature drops below -5°C , there are cases where coal adheres to the inside walls of freight cars by the binding action of ice. However, adfrozen coal is thawed at the time of receipt.

For information, during the past (35) years, there was an instance where transportation was suspended for three to four days due to frozen railroad points and the like.

- 2) In the case of installation of railway, a responsibility division point against the power plant acts as a power plant boundary and rails up to the power plant is placed by the mining company.

- (i) Outline of Troyanovo North area

- 1) There is a plan to increase production to 12 to 13×10^6 tons per annum by the year 2,000.

- 2) Sampling is conducted as required in the Bulgarian standard and DIN standard (3kg/time).

- 3) S content is obtained according to correlation between moisture and ash content.

$$S(\%) = 6.03 [1 - 0.253 (A\%/100)](100 - W\%) \div 100$$

- 4) The capacities of mine excavators and belt conveyors are as follows.

- Excavator capacity : 1,000t/h, 3,000t/h (made in Germany, purchased 3 years)
- Belt conveyor : 2,250mm wide (made in Holland or Czecho)
1,600 ~ 1,800mm wide (made by Bridgestone & Bando)

5) The number of employees including those of railroad and drilling machine is 12,400.

4.1.3 Coal Mining and Transportation Plan

(1) Coal mining plan

(a) Study parameters

- 1) Mining area : Troyanovo North mining area
- 2) Reserve : $512,855 \times 10^3$ ton (as of January 1994)
- 3) Excavator capacity : 1,000 t/h, 3,000 t/h
- 4) Operating system : A 24-hour (2 shifts x 12 hours) operating system is possible
- 5) Coal consumption of a replacing plant : 840 t/h (420 t/h x 2 units)
= 20,200 t/d (\cong 840 t/h x 24h)
5.160 x 10^8 t/y
(2 units, annual utilization factor: 0.7)
- 6) A 10-hour operation per day is assured in average for daylight hour and labor safety in winter season.

(b) Study result

The coal mining capacity mentioned above in (a) 1) ~ 4) sufficiently allows coal consumption in a replacing plant, the following mining plan will be executed taking excavator inspection/repair timing into consideration.

Mining amount : 20,200 ton per day
1,000t/h excavator = 505 t/h
3,000t/h excavator = 1,515t/h Total = 2,020 t/h
(approximation) 20,200t/d = 10 hours x (Q₁ + 3Q₁)
 $\therefore Q_1 = 505 \text{ t/h} \rightarrow \text{Total } 2,020 \text{ t/h}$

(2) Transportation plan

(a) Study parameters

- 1) Transportation method : Coal specialized freight of railways
- 2) Freight capacity : 1 train (10 wagons: 55t(coal)/freight)
- 3) Mining amount : 20,200 t/d, 2,020 t/h

(b) Study result

- 1) No. of train: 37 every day. [37 \cong (20,200) \div (55) \div (10)]

(b) Study result

- 1) No. of train: 37 every day. [$37 \doteq (20,200) \div (55) \div (10)$]
- 2) Assuming that coal loading time for a train (10 freights) is 40 minutes (including come-in and out), the operation time needs 25 hours per day. Thus, basically 2 trains (10 freights + 10 freights) are operated at the same time and the operation time per day is determined to be about 13 hours. [$25 \doteq (37) \times (40) \div (60)$]

4.1.4 Properties of coal to be used in the replacing plant

Table 4-1-4 shows the properties of coal to be used for a replacing plant.

4.1.5 Items to be studied for carry out the plan

- (1) Since the sulfur (S) content becomes an important factor among the properties of the fuel for the replacing plant, it is necessary to add S-content specifications to the existing ash-content, moisture-content, and calorific-value specifications, through prior consultation with the coal mining company (for the devising of contract conditions, or the like).
- (2) It is desirable that S-content values be determined from actual measurement data obtained at coal sampling time, rather than the currently used moisture-and-ash-content correlation table.
- (3) Since the power plant's coal storage is planned to be constructed in the current ash dumping ground No. 1, it is necessary to establish a clear-cut point of demarcation for responsibilities to be shouldered between the power plant and the coal-mining company in advance of the commencement of work on the construction of the additional railroad section leading to the planned coal storage. Furthermore, the process of constructing that section necessitates coordination with the construction process of the re-designed plant as well as the present operating conditions of the existing power plant.
- (4) Since coal's clay content represents the largest hindrance to the transportation and crushing of coal at the power plant, it is desirable that operation control (quality control) be stepped up on the part of the coal-mining company to remove clay from coal in advance of loading onto cars as much as possible.