


THE REPUBLIC OF GUATEMALA
 GUATEMALA MUNICIPAL WATER
 SUPPLY PUBLIC CORPORATION
 (EMPAGUA)


THE STUDY ON
 THE IMPROVEMENT OF WASTEWATER
 MANAGEMENT IN THE GUATEMALA
 METROPOLITAN AREA
 JAPAN INTERNATIONAL COOPERATION AGENCY

TITLE
 LONGITUDINAL SECTION OF
 MAIN COLLECTOR SEWER
 FOR EAST 1 REGION (7/10)



<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LONGITUDINAL SECTION OF MAIN COLLECTOR SEWER FOR EAST 1 REGION (8/10)</p>
---	---	---

Fig. L - 61



THE REPUBLIC OF GUATEMALA

GUATEMALA MUNICIPAL WATER
SUPPLY PUBLIC CORPORATION
(EMPAGUA)

THE STUDY ON
THE IMPROVEMENT OF WASTEWATER
MANAGEMENT IN THE GUATEMALA
METROPOLITAN AREA

JAPAN INTERNATIONAL COOPERATION AGENCY

TITLE

LONGITUDINAL SECTION OF
MAIN COLLECTOR SEWER
FOR EAST 1 REGION (9/10)

SUPPORTING REPORT M
TREATMENT PLANT DESIGN

**SUPPORTING REPORT M
TREATMENT PLANT DESIGN
TABLE OF CONTENTS**

M1 INTRODUCTION M - 1

LIST OF TABLES

Table M - 1 Outline of Treatment Facilities for Master Plan M - 5
 Table M - 2 Design Calculation for Master Plan (Central WWTP) M - 9
 Table M - 3 Design Calculation for Master Plan (North 1 WWTP)..... M - 17
 Table M - 4 Design Calculation for Master Plan (South 1 WWTP)..... M - 24
 Table M - 5 Design Calculation for Master Plan (South 2 WWTP)..... M - 33
 Table M - 6 Design Calculation for Master Plan (South 3 WWTP)..... M - 41
 Table M - 7 Design Calculation for Master Plan (East 1 WWTP)..... M - 49
 Table M - 8 Outline of Treatment Facilities for First Stage Project
 (Alternative 1 and Alternative 2) M - 57
 Table M - 9 Design Calculation for First Stage Project (Alternative 1 :
 Central WWTP)..... M - 61
 Table M - 10 Design Calculation for First Stage Project (Alternative 2 :
 South 3 WWTP) M - 73

LIST OF FIGURES

Fig. M - 1 Layout Plan for Master Plan (Central WWTP) M - 91
 Fig. M - 2 Layout Plan for Master Plan (North 1 WWTP, East 1 WWTP) M - 93
 Fig. M - 3 Layout Plan for Master Plan (South 1 WWTP, South 2 WWTP,
 South 3 WWTP) M - 95
 Fig. M - 4 Layout Plan for First Stage Project (Alternative 1: Central WWTP)..... M - 99
 Fig. M - 5 Layout Plan for First Stage Project (Alternative 2: South 3 WWTP) M - 101



M TREATMENT PLANT DESIGN

M1 INTRODUCTION

This Supporting Report contains preliminary design calculations and layout plan of wastewater treatment plants (WWTPs) for Master Plan and Feasibility Study. Layout plans for Feasibility study namely Central Region WWTP and South 3 Region WWTP are based on topographical survey results, which are described in Supporting Report Q.

Table M-1, M-8 show outline of treatment facilities based on preliminary design calculations. Table M-2 to M-7 show the treatment process flow diagram and the design calculations to size the facilities at each treatment plant for Master Plan. Table M-9, M-10 show the same for Feasibility Study.

The preliminary proposed layout plan for each treatment plants are shown in Fig. M-1 to M-3 for Master Plan. At Master Plan stage, detailed topography of wastewater treatment plant sites are not known. Therefore the layout plans have been prepared based on the assumption that the WWTP site slope at a constant gradient and of rectangular shape. Fig. M-4, M-5 show proposed layout plan for Feasibility study.

DESIGN CALCULATION FOR MASTER PLAN

Table M-1 Outline of Treatment Facilities

Facility	Central		North1		South1		South2		South3		East1	
	Dimensions	No.	Dimensions	No.	Dimensions	No.	Dimensions	No.	Dimensions	No.	Dimensions	No.
Primary Sedimentation Tank	φ 13.00m × h 11.89m	40	φ 12.50m × h 11.46m	16	φ 13.50m × h 12.33m	10	φ 13.50m × h 12.33m	8	φ 12.50m × h 11.46m	12	φ 13.00m × h 11.89m	20
Trickling Filter (First Step)	φ 39.00m × h 2.00m	40	φ 38.00m × h 2.00m	16	φ 41.00m × h 2.00m	10	φ 40.00m × h 2.00m	8	φ 38.00m × h 2.00m	12	φ 39.00m × h 2.00m	20
Intermediate Clarifier	φ 13.00m × h 11.89m	40	φ 12.50m × h 11.46m	16	φ 13.50m × h 12.33m	10	φ 13.50m × h 12.33m	8	φ 12.50m × h 11.46m	12	φ 13.00m × h 11.89m	20
Trickling Filter (Second Step)	φ 39.00m × h 2.00m	20	φ 38.00m × h 2.00m	8	φ 41.00m × h 2.00m	5	φ 40.00m × h 2.00m	4	φ 38.00m × h 2.00m	6	φ 39.00m × h 2.00m	10
Final Clarifier	φ 18.00m × h 16.22m	40	φ 17.50m × h 15.79m	16	φ 18.50m × h 16.66m	10	φ 18.50m × h 16.66m	8	φ 17.50m × h 15.79m	12	φ 18.00m × h 16.22m	20
Sludge Digester Tank	φ 17.50m × h 9.75m	40	φ 17.50m × h 9.75m	16	φ 18.00m × h 10.00m	10	φ 18.00m × h 10.00m	8	φ 17.00m × h 9.50m	12	φ 18.00m × h 16.00m	20
Sludge Drying Bed	W 40.00m × L100.00m	20	W 40.00m × L100.00m	8	W 40.00m × L110.00m	5	W 40.00m × L110.00m	4	W 40.00m × L 95.00m	6	W 40.00m × L105.00m	10
Design Flowrate												
Daily Average	238,000		89,000		64,000		51,000		66,000		121,000	
Daily Maximum	261,000		97,000		70,000		55,000		72,000		131,000	
Hourly Maximum	390,000		144,000		103,000		86,000		107,000		196,000	
Hourly Maximum Wet Weather	1,087,000		—		—		—		—		—	
Sludge Generation	90.0		49.8		24.3		19.3		25.0		45.8	

Source : Study Team

**Design Calculation
for
Central Region Wastewater Treatment Plant
(Master Plan)**

Table M-2 (1/6) Design Calculation for Master Plan (Central WWTP)

Item	Calculation
Design Flowrate	Daily Average 238,000 m ³ /d
	Daily Maximum 261,000 m ³ /d
	Hourly Maximum 390,000 m ³ /d
	Hourly Maximum Wet Weather 1,087,000 m ³ /d
Treatment Process Flow Diagram	
	<div data-bbox="667 1458 1294 1711" style="border: 1px solid black; padding: 5px;"> <p>Legend S G C - Screen Grit Chamber P S T - Primary Sedimentation Tank T F (I) - Trickling Filter (First Step) I C - Intermediate Clarifier T F (II) - Trickling Filter (Second Step) F C - Final Clarifier S D T - Sludge Digester Tank S D B - Sludge Drying Bed</p> </div> <p style="margin-top: 20px;">* Primary Treated Excess Wet Weather Flow (3x Hourly Maximum Flow - 1x Hourly Maximum Flow)</p>

Table M-2 (2/6) Design Calculation for Master Plan (Central WWTP)

Item	Calculation
I. Primary Sedimentation Tank	
a) Required Capacity	
Design Flowrate	261,000 m ³ /d (D.M.), 1,087,000 m ³ /d (H.M.W.W.F.)
Overflow Rate	50.0 m ³ /m ² ·d
Retention Time	2.0 h (D.M.) 0.5 h (H.M.W.W.F.)
	D.M. : Daily Maximum H.M.W.W.F. : Hourly Maximum Wet Weather Flow
Required Surface Area	$\frac{261,000}{50.0} = 5,220 \text{ m}^2$
b) Dimensions	
Diameter	R = 13.00 m
Depth	D = 11.89 m
Angle	$\theta = 60^\circ$
Number	40 Tanks
	(h ₁ = 1.50 m, h ₂ = 10.39 m)
c) Check	
Overflow Rate (D.M.)	$\frac{261,000}{5,309} = 49.2 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time (D.M.)	$\frac{23,840}{261,000} \times 24 = 2.2 \text{ h}$
Retention Time (H.M.W.W.F.)	$\frac{23,840}{1,087,000} \times 24 = 0.5 \text{ h}$
Sludge Generation	$= 261,000 \times 154 \times 10^{-6} \div 0.01 = 4,019 \text{ m}^3$ = 100 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 100 \text{ m}^3/\text{tank}$ (h ₃ = 5.74 m, r ₁ = 0.50 m, r ₂ = 3.81 m)
Effective Volume	$V_1 = \frac{\pi \times h_4}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 397 \text{ m}^3/\text{Tank}$ (h ₄ = 4.65 m, r ₂ = 3.81 m, r ₃ = 6.50 m)
	$V_2 = \frac{\pi \times h_1}{4} \times R^2 = 199 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 13.00 m)
	V = V ₁ + V ₂ = 596 m ³ /tank
	$\Sigma V = V \times \text{Number of Tanks} = 596 \times 40 = 23,840 \text{ m}^3$




Table M-2 (3/6) Design Calculation for Master Plan (Central WWTP)

Item	Calculation
2. Trickling Filter	
1) First Step	
a) Required Capacity	
Design Flowrate	261,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 261,000 \times 182 \times 10^{-3} = 47,502 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{47,502}{1.0} = 47,502 \text{ m}^2$
b) Dimensions	
Diameter	39.00 m
Bed Depth	2.00 m
Number	40 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 39.00^2 \times 40 = 47,784 \text{ m}^2$
BOD Loading	$= \frac{47,502}{47,784} = 1.0 \text{ kg·BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{261,000}{47,784} = 5.5 \text{ m/d}$
2) Intermediate Clarifier	Intermediate clarifier is the same size as primary sedimentation tank.
3) Second Step	
a) Required Capacity	
Design flowrate	261,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 261,000 \times 91 \times 10^{-3} = 23,751 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{23,751}{1.0} = 23,751 \text{ m}^2$
b) Dimensions	
Diameter	39.00 m
Bed Depth	2.00 m
Number	20 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 39.00^2 \times 20 = 23,892 \text{ m}^2$
BOD Loading	$= \frac{23,751}{23,892} = 1.0 \text{ kg·BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{261,000}{23,892} = 10.9 \text{ m/d}$

Table M-2 (4/6) Design Calculation for Master Plan (Central WWTP)

Item	Calculation
3. Final Clarifier	
a) Required Capacity	
Design Flowrate	261,000 m ³ /d
Overflow Rate	25.0 m ³ /m ² ·d
Retention Time	3.0 h
Required Surface Area	$= \frac{261,000}{25.0} = 10,440 \text{ m}^2$
b) Dimensions	
Diameter	R = 18.00 m
Depth	D = 16.22 m
Angle	θ = 60°
Number	40 Tanks
	(h ₁ = 1.50 m, h ₂ = 14.72 m)
c) Check	
Overflow Rate	$= \frac{261,000}{10,179} = 25.6 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{66,280}{261,000} \times 24 = 6.1 \text{ h}$
Sludge Generation	$= 261,000 \times 70 \times 10^{-6} \div 0.01 = 1,827 \text{ m}^3$ = 46 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 46 \text{ m}^3/\text{Tank}$ (h ₃ = 4.25 m, r ₁ = 0.50 m, r ₂ = 2.95 m)
Effective Volume	$V_1 = \frac{\pi \times h_4}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 1,275 \text{ m}^3/\text{Tank}$ (h ₁ = 10.47 m, r ₂ = 2.95 m, r ₃ = 9.00 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 382 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 18.00 m) V = V ₁ + V ₂ = 1,657 m ³ /Tank ΣV = V × Number of Tanks = 1,657 × 40 = 66,280 m ³




Table M-2 (5/6) Design Calculation for Master Plan (Central WWTP)


Item	Calculation
4. Sludge Digester Tank (Open Tank)	
a) Required Capacity Design Flowrate	238,000 m ³ /d (Daily Average)
Retention Time	47 days (Unheated Anaerobic Digestion)
Influent Solid Quantity	= Raw Sludge + Septage from Sanitation Facility = 238,000 × 280 × 0.8 × 10 ⁻⁶ + 0.84 = 53.3 + 0.84 = 54.1 t/d
Influent Sludge Volume	= $\frac{53.3}{0.06} + 12.0 = 900$ m ³ /d (Raw Sludge Concentration 6%)
Required Volume	= 900 × 47 = 42,300 m ³
b) Dimensions	<div style="display: flex; align-items: flex-start;"> <div style="flex: 1;"> <p>Diameter R = 17.50 m Depth D = 9.75 m Angle θ = 45° Number 40 Tanks</p> <p>(h₁ = 1.50 m, h₂ = 8.25 m)</p> </div> <div style="flex: 1; text-align: center;">  </div> </div>
	$V_1 = \frac{\pi \times h_2}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 701 \text{ m}^3/\text{Tank}$ <p>(h₂ = 8.25 m, r₁ = 0.50 m, r₂ = 8.75 m)</p> $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 361 \text{ m}^3/\text{Tank}$ <p>(h₁ = 1.50 m, R = 17.50 m)</p> <p>V = V₁ + V₂ = 1,062 m³/Tank</p> <p>ΣV = V × Number of Tanks = 1,062 × 40 = 42,480 m³</p>
c) Check	
Retention Time	$= \frac{42,480}{900} = 47 \text{ days}$

Table M-2 (6/6) Design Calculation for Master Plan (Central WWTP)

Item	Calculation
5. Sludge Drying Bed	
a) Required Capacity	
Influent Solid Quantity	= Digested Solids
	= $53.3 \times (1 - (0.65 \times 0.5)) = 36.0 \text{ t/d}$
	<p style="text-align: right;">Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %</p>
Dried Sludge Quantity	= $\frac{36.0}{1 - 0.6} = 90.0 \text{ t/d}$
	(Moisture Content of Dried Sludge: 60 %)
Solids Loading	160 kg·SS/m ² ·yr.
Required Area	= $\frac{36.0 \times 365}{0.16} = 82,125 \text{ m}^2$
b) Dimensions	
Width	40.00 m
Length	100.00 m
Number	20 tanks
c) Check	
Area	= $40.00 \times 100.00 \times 20 = 80,000 \text{ m}^2$
Solids Loading	= $\frac{36.0}{80,000} \times 365 \times 10^3 = 164.3 \text{ kg·SS/m}^2\cdot\text{yr}$

**Design Calculation
for
North 1 Region Wastewater Treatment Plant
(Master Plan)**

Table M-3 (1/6) Design Calculation for Master Plan (North1 WWTP)


Item	Calculation						
Design Flowrate	<table border="0"> <tr> <td>Daily Average</td> <td>89,000 m³/d</td> </tr> <tr> <td>Daily Maximum</td> <td>97,000 m³/d</td> </tr> <tr> <td>Hourly Maximum</td> <td>144,000 m³/d</td> </tr> </table>	Daily Average	89,000 m ³ /d	Daily Maximum	97,000 m ³ /d	Hourly Maximum	144,000 m ³ /d
Daily Average	89,000 m ³ /d						
Daily Maximum	97,000 m ³ /d						
Hourly Maximum	144,000 m ³ /d						
Treatment Process Flow Diagram	 <pre> graph TD Influent --> SGC SGC --> PST PST --> TF1[TF(I)] PST --> SDT TF1 --> IC IC --> TF2[TF(II)] IC --> SDB TF2 --> FC FC --> Effluent FC --> SDT SDT --> SDB SDB --> Disposal FC --> TF1 </pre> <p style="text-align: center;">※</p>						
	<div style="border: 1px solid black; padding: 5px;"> <p>Legend</p> <p>S G C - Screen Grit Chamber</p> <p>P S T - Primary Sedimentation Tank</p> <p>T F (I) - Trickling Filter (First Step)</p> <p>I C - Intermediate Clarifier</p> <p>T F (II) - Trickling Filter (Second Step)</p> <p>F C - Final Clarifier</p> <p>S D T - Sludge Digester Tank</p> <p>S D B - Sludge Drying Bed</p> </div>						

Table M-3 (2/6) Design Calculation for Master Plan (North1 WWTP)

Item	Calculation
I. Primary Sedimentation Tank	
a) Required Capacity	
Design Flowrate	97,000 m ³ /d
Overflow Rate	50.0 m ³ /m ² ·d
Retention Time	2.0 h
Required Surface Area	$= \frac{97,000}{50.0} = 1,940 \text{ m}^2$
b) Dimensions	
Diameter	R = 12.50 m
Depth	D = 11.46 m
Angle	θ = 60°
Number	16 Tanks
	(h ₁ = 1.50 m, h ₂ = 9.96 m)
c) Check	
Overflow Rate	$= \frac{97,000}{1,963} = 49.4 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{8,528}{97,000} \times 24 = 2.1 \text{ h}$
Sludge Generation	$= 97,000 \times 154 \times 10^{-6} \div 0.01 = 1,494 \text{ m}^3$ = 93 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 93 \text{ m}^3/\text{tank}$ (h ₃ = 5.58 m, r ₁ = 0.50 m, r ₂ = 3.72 m)
Effective Volume	$V_1 = \frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 319 \text{ m}^3/\text{tank}$ (h ₁ = 4.38 m, r ₂ = 3.72 m, r ₃ = 6.25 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 184 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 12.50 m) V = V ₁ + V ₂ = 533 m ³ /tank Σ V = V × Number of Tanks = 533 × 16 = 8,528 m ³




Table M-3 (3/6) Design Calculation for Master Plan (North1 WWTP)

Item	Calculation
2. Trickling Filter	
1) First Step	
a) Required Capacity	
Design Flowrate	97,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 970,000 \times 182 \times 10^{-3} = 17,651 \text{ kg/d}$
	17,654
Required Cross-Sectional Area	$= \frac{17,654}{1.0} = 17,654 \text{ m}^2$
b) Dimensions	
Diameter	38.00 m
Bed Depth	2.00 m
Number	16 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 38.00^2 \times 16 = 18,146 \text{ m}^2$
	17,654
BOD Loading	$= \frac{17,654}{18,146} = 1.0 \text{ kg} \cdot \text{BOD} / \text{m}^2 \cdot \text{d}$
	18,146
Hydraulic Loading	$= \frac{97,000}{18,146} = 5.3 \text{ m/d}$
	18,146
2) Intermediate Clarifier	Intermediate clarifier is the same size as primary sedimentation tank.
3) Second Step	
a) Required Capacity	
Design flowrate	97,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 97,000 \times 91 \times 10^{-3} = 8,827 \text{ kg/d}$
	8,827
Required Cross-Sectional Area	$= \frac{8,827}{1.0} = 8,827 \text{ m}^2$
	1.0
b) Dimensions	
Diameter	38.00 m
Bed Depth	2.00 m
Number	8 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 38.00^2 \times 8 = 9,073 \text{ m}^2$
	8,827
BOD Loading	$= \frac{8,827}{9,073} = 1.0 \text{ kg} \cdot \text{BOD} / \text{m}^2 \cdot \text{d}$
	9,073
Hydraulic Loading	$= \frac{97,000}{9,073} = 10.7 \text{ m/d}$
	9,073

Table M-3 (4/6) Design Calculation for Master Plan (North1 WWTP)

Item	Calculation
3. Final Clarifier	
a) Required Capacity	
Design Flowrate	97,000 m ³ /d
Overflow Rate	25.0 m ³ /m ² ·d
Retention Time	3.0 h
Required Surface Area	$= \frac{97,000}{25.0} = 3,880 \text{ m}^2$
b) Dimensions	
Diameter	R = 17.50 m
Depth	D = 15.79 m
Angle	θ = 60°
Number	16 Tanks
	(h1 = 1.50 m, h2 = 14.29 m)
c) Check	
Overflow Rate	$= \frac{97,000}{3,848} = 25.2 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{24,528}{97,000} \times 24 = 6.1 \text{ h}$
Sludge Generation	$= 97,000 \times 70 \times 10^{-6} \div 0.01 = 679 \text{ m}^3$ = 42 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 42 \text{ m}^3/\text{Tank}$ (h3 = 4.09 m, r1 = 0.50 m, r2 = 2.86 m)
Effective Volume	$V_1 = \frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 1,172 \text{ m}^3/\text{Tank}$ (h1 = 10.20 m, r2 = 2.86 m, r3 = 8.75 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 361 \text{ m}^3/\text{Tank}$ (h1 = 1.50 m, R = 17.50 m) V = V1 + V2 = 1,533 m ³ /tank ΣV = V × Number of Tanks = 1,533 × 16 = 24,528 m ³




Table M-3 (5/6) Design Calculation for Master Plan (North1 WWTP)


Item	Calculation
4. Sludge Digester Tank (Open Tank)	
a) Required Capacity	
Design Flowrate	89,000 m ³ /d (Daily Average)
Retention Time	47 days (Unheated Anaerobic Digestion)
Influent Solid Quantity	= Raw Sludge + Septage from Sanitation Facility
	= 89,000 × 280 × 0.8 × 10 ⁻⁶ + 1.25
	= 19.9 + 1.25 = 21.2 t/d
Influent Sludge Volume	= $\frac{19.9}{0.06} + 17.9 = 349.9$ m ³ /d (Raw Sludge Concentration 6%)
Required Volume	= 349.9 × 47 = 16,445 m ³
b) Dimensions	
Diameter	R = 17.50 m
Depth	D = 9.75 m
Angle	θ = 45°
Number	16 Tanks
	(h ₁ = 1.50 m, h ₂ = 8.25 m)
	
	$V1 = \frac{\pi \times h2}{3} (r1^2 + r1 \times r2 + r2^2) = 701 \text{ m}^3/\text{Tank}$
	(h ₂ = 8.25 m, r ₁ = 0.50 m, r ₂ = 8.75 m)
	$V2 = \frac{\pi \times h1}{4} \times R^2 = 361 \text{ m}^3/\text{Tank}$
	(h ₁ = 1.50 m, R = 17.50 m)
	V = V ₁ + V ₂ = 1,062 m ³ /Tank
	Σ V = V × Number of Tanks = 1,062 × 16 = 16,992 m ³
c) Check	
Retention Time	= $\frac{16,992}{350} = 49$ days

Table M-3 (6/6) Design Calculation for Master Plan (North1 WWTP)

Item	Calculation
5. Sludge Drying Bed	
a) Required Capacity	
Influent Solid Quantity	= Digested Solids = $19.9 \times (1 - (0.65 \times 0.5)) = 19.9 \text{ t/d}$
Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %	
Dried Sludge Quantity	$= \frac{19.9}{1 - 0.6} = 49.8 \text{ t/d}$
(Moisture Content of Dried Sludge: 60 %)	
Solids Loading	160 kg•SS/m ² •yr.
Required Area	$= \frac{19.9 \times 365}{0.16} = 45,397 \text{ m}^2$
b) Dimensions	
Width	40.00 m
Length	100.00 m
Number	8 Tanks
c) Check	
Area	= $40.00 \times 100.00 \times 8 = 32,000 \text{ m}^2$
Solids Loading	$= \frac{19.9}{32,000} \times 365 \times 10^3 = 227 \text{ kg•SS/m}^2\text{•yr}$

**Design Calculation
for
South 1 Region Wastewater Treatment Plant
(Master Plan)**




Table M-4 (1/6) Design Calculation for Master Plan (South1 WWTP)


Item	Calculation
Design Flowrate	<p>Daily Average 64,000 m³/d</p> <p>Daily Maximum 70,000 m³/d</p> <p>Hourly Maximum 103,000 m³/d</p>
Treatment Process Flow Diagram	 <pre> graph TD Influent --> SGC[SGC] SGC --> PST[PST] PST --> TF1[TF(I)] PST --> SDT[SDT] TF1 --> IC[IC] IC --> TF2[TF(II)] IC --> SDB[SDB] TF2 --> FC[FC] TF2 --> SDB FC --> Effluent[Effluent] FC --> SDB SDB --> Disposal[Disposal] Effluent --> Effluent </pre> <p>The flow diagram illustrates the wastewater treatment process. It begins with 'Influent' entering a 'SGC' (Screen-Grit Chamber). The flow then proceeds to a 'PST' (Primary Sedimentation Tank). From the PST, the main line goes to 'TF(I)' (Trickling Filter - First Step), while a side line goes to 'SDT' (Sludge Digester Tank). From 'TF(I)', the flow goes to 'IC' (Intermediate Clarifier). From 'IC', the main line goes to 'TF(II)' (Trickling Filter - Second Step), and a side line goes to 'SDB' (Sludge Drying Bed). From 'TF(II)', the flow goes to 'FC' (Final Clarifier). From 'FC', the main line goes to 'Effluent', and a side line goes to 'SDB'. Finally, 'SDB' leads to 'Disposal'. A recirculation line with an asterisk (*) returns flow from the bottom of 'FC' back to the bottom of 'TF(I)'. All units are represented by rectangular boxes.</p>
	<p>Legend</p> <p>S G C - Screen-Grit Chamber</p> <p>P S T - Primary Sedimentation Tank</p> <p>T F (I) - Trickling Filter (First Step)</p> <p>I C - Intermediate Clarifier</p> <p>T F (II) - Trickling Filter (Second Step)</p> <p>F C - Final Clarifier</p> <p>S D T - Sludge Digester Tank</p> <p>S D B - Sludge Drying Bed</p>

Table M-4 (2/6) Design Calculation for Master Plan (South1 WWTP)

Item	Calculation
1. Primary Sedimentation Tank	
a) Required Capacity	
Design Flowrate	70,000 m ³ /d
Overflow Rate	50.0 m ³ /m ² ·d
Retention Time	2.0 h
Required Surface Area	$= \frac{70,000}{50.0} = 1,400 \text{ m}^2$
b) Dimensions	
Diameter	R = 13.50 m
Depth	D = 12.33 m
Angle	θ = 60°
Number	10 Tanks
c) Check	
	(h ₁ = 1.50 m, h ₂ = 10.83 m)
Overflow Rate	$= \frac{70,000}{1,431} = 48.9 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{6,640}{70,000} \times 24 = 2.3 \text{ h}$
Sludge Generation	$= 70,000 \times 154 \times 10^{-6} \div 0.01 = 1,078 \text{ m}^3$ = 108 m ³ /Tank
	(Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 108 \text{ m}^3/\text{Tank}$ (h ₃ = 5.91 m, r ₁ = 0.50 m, r ₂ = 3.91 m)
Effective Volume	$V_1 = \frac{\pi \times h_4}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 449 \text{ m}^3/\text{Tank}$ (h ₄ = 4.92 m, r ₂ = 3.91 m, r ₃ = 6.75 m)
	$V_2 = \frac{\pi \times h_1}{4} \times R^2 = 215 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 13.50 m)
	V = V ₁ + V ₂ = 664 m ³ /Tank
	ΣV = V × Number of Tank = 664 × 10 = 6,640 m ³




Table M-4 (3/6) Design Calculation for Master Plan (South1 WWTP)

Item	Calculation
2. Trickling Filter	
1) First Step	
a) Required Capacity	
Design Flowrate	70,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	= 70,000 × 182 × 10 ⁻³ = 12,740 kg/d
Required Cross-Sectional Area	= $\frac{12,740}{1.0}$ = 12,740 m ²
b) Dimensions	
Diameter	41.00 m
Bed Depth	2.00 m
Number	10 Tanks
c) Check	
Cross-Sectional Area	= $\frac{\pi}{4} \times 41.00^2 \times 10$ = 13,203 m ²
BOD Loading	= $\frac{12,740}{13,203}$ = 1.0 kg·BOD/m ² ·d
Hydraulic Loading	= $\frac{70,000}{13,203}$ = 5.3 m/d
2) Intermediate Clarifier	Intermediate clarifier is the same size as primary sedimentation tank.
3) Second Step	
a) Required Capacity	
Design flowrate	70,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	= 70,000 × 91 × 10 ⁻³ = 6,370 kg/d
Required Cross-Sectional Area	= $\frac{6,370}{1.0}$ = 6,370 m ²
b) Dimensions	
Diameter	41.00 m
Bed Depth	2.00 m
Number	5 Tanks
c) Check	
Cross-Sectional Area	= $\frac{\pi}{4} \times 41.00^2 \times 5$ = 6,601 m ²
BOD Loading	= $\frac{6,370}{6,601}$ = 1.0 kg·BOD/m ² ·d
Hydraulic Loading	= $\frac{70,000}{6,601}$ = 10.6 m/d

Table M-4 (4/6) Design Calculation for Master Plan (South1 WWTP)

Item	Calculation
3. Final Clarifier	
a) Required Capacity	
Design Flowrate	70,000 m ³ /d
Overflow Rate	25.0 m ³ /m ² ·d
Retention Time	3.0 h
Required Surface Area	$= \frac{70,000}{25.0} = 2,800 \text{ m}^2$
b) Dimensions	
Diameter	R = 18.50 m
Depth	D = 16.66 m
Angle	θ = 60°
Number	10 Tanks
	(h ₁ = 1.50 m, h ₂ = 15.16 m)
c) Check	
Overflow Rate	$= \frac{70,000}{2,688} = 26.0 \text{ m}^3/\text{m}^2\cdot\text{d}$
Retention Time	$= \frac{17,890}{70,000} \times 24 = 6.1 \text{ h}$
Sludge Generation	$= 70,000 \times 70 \times 10^{-6} \div 0.01 = 490 \text{ m}^3$ = 49 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 49 \text{ m}^3/\text{Tank}$ (h ₃ = 4.35 m, r ₁ = 0.50 m, r ₂ = 3.01 m)
Effective Volume	$V_1 = \frac{\pi \times h_4}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 1,386 \text{ m}^3/\text{Tank}$ (h ₄ = 10.81 m, r ₂ = 3.01 m, r ₃ = 9.25 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 403 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 18.50 m) V = V ₁ + V ₂ = 1,789 m ³ /tank ΣV = V × Number of Tanks = 1,789 × 10 = 17,890 m ³




Table M-4 (5/6) Design Calculation for Master Plan (South1 WWTP)


Item	Calculation
4. Sludge Digester Tank (Open Tank)	
a) Required Capacity	64,000 m ³ /d (Daily Average)
Design Flowrate	47 days (Unheated Anaerobic Digestion)
Retention Time	= Raw Sludge + Septage from Sanitation Facility
Influent Solid Quantity	= 64,000 × 280 × 0.8 × 10 ⁻⁶ + 0.02
	= 14.3 + 0.02 = 14.3 t/d
Influent Sludge Volume	= $\frac{14.3}{0.06} + 0.3 = 238.3$ m ³ /d (Raw Sludge Concentration 6%)
Required Volume	= 238.3 × 47 = 11,200 m ³
b) Dimensions	Diameter R = 18.00 m Depth D = 10.00 m Angle θ = 45° Number 10 Tanks (h ₁ = 1.50 m, h ₂ = 8.50 m)
	
	$V_1 = \frac{\pi \times h_2}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 763 \text{ m}^3/\text{Tank}$ (h ₂ = 8.50 m, r ₁ = 0.50 m, r ₂ = 9.00 m)
	$V_2 = \frac{\pi \times h_1}{4} \times R^2 = 382 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 18.00 m)
	$V = V_1 + V_2 = 1,145 \text{ m}^3/\text{Tank}$
	$\Sigma V = V \times \text{Number of Tanks} = 1,145 \times 10 = 11,450 \text{ m}^3$
c) Check	
Retention Time	$= \frac{11,450}{238} = 48 \text{ days}$

Table M-4 (6/6) Design Calculation for Master Plan (South1 WWTP)

Item	Calculation
5. Sludge Drying Bed	
a) Required Capacity	
Influent Solid Quantity	= Digested Solids
	= $14.3 \times (1 - (0.65 \times 0.5)) = 9.7 \text{ t/d}$
	Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %
Dried Sludge Quantity	= $\frac{9.7}{0.4} = 24.3 \text{ t/d}$
	(Moisture Content of Dried Sludge: 60 %)
Solids Loading	160 kg·SS/m ² ·yr.
Required Area	= $\frac{9.7 \times 365}{0.16} = 22,128 \text{ m}^2$
b) Dimensions	
Width	40.00 m
Length	110.00 m
Number	5 Tanks
c) Check	
Area	= $40.00 \times 110.00 \times 5 = 22,000 \text{ m}^2$
Solids Loading	= $\frac{9.7}{22,000} \times 365 \times 10^3 = 160.9 \text{ kg·SS/m}^2\text{·yr}$

**Design Calculation
for
South 2 Region Wastewater Treatment Plant
(Master Plan)**



Table M-5 (1/6) Design Calculation for Master Plan (South2 WWTP)


Item	Calculation
Design Flowrate	Daily Average 51,000 m ³ /d
	Daily Maximum 55,000 m ³ /d
	Hourly Maximum 86,000 m ³ /d
Treatment Process Flow Diagram	 <pre> graph TD Influent --> SGC[SGC] SGC --> PST[PST] PST --> TF1[TF(I)] PST --> SDT[SDT] TF1 --> IC[IC] IC --> TF2[TF(II)] IC --> SDB[SDB] TF2 --> FC[FC] FC --> Effluent[Effluent] FC --> SDB FC --> TF1 SDB --> Disposal[Disposal] </pre> <p>Legend</p> <ul style="list-style-type: none"> S G C - Screen-Grit Chamber P S T - Primary Sedimentation Tank T F (I) - Trickling Filter (First Step) I C - Intermediate Clarifier T F (II) - Trickling Filter (Second Step) F C - Final Clarifier S D T - Sludge Digester Tank S D B - Sludge Drying Bed

Table M-5 (2/6) Design Calculation for Master Plan (South2 WWTP)

Item	Calculation
1. Primary Sedimentation Tank	
a) Required Capacity	
Design Flowrate	55.000 m ³ /d
Overflow Rate	50.0 m ³ /m ² ·d
Retention Time	2.0 h
Required Surface Area	$= \frac{55.000}{50.0} = 1.100 \text{ m}^2$
b) Dimensions	
Diameter	R = 13.50 m
Depth	D = 12.33 m
Angle	θ = 60°
Number	8 Tanks
c) Check	
	(h1 = 1.50 m, h2 = 10.83 m)
Overflow Rate	$= \frac{55.000}{1.145} = 48.0 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{5.336}{55.000} \times 24 = 2.3 \text{ h}$
Sludge Generation	$= 55,000 \times 154 \times 10^{-6} \div 0.01 = 817 \text{ m}^3$ = 106 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 106 \text{ m}^3/\text{Tank}$ (h3 = 5.86 m, r1 = 0.50 m, r2 = 3.88 m)
Effective Volume	$V_1 = \frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 452 \text{ m}^3/\text{Tank}$ (h1 = 4.97 m, r2 = 3.88 m, r3 = 6.75 m) $V_2 = \frac{\pi \times h_2}{4} \times R^2 = 215 \text{ m}^3/\text{Tank}$ (h2 = 1.50 m, R = 13.50 m) V = V1 + V2 = 667 m ³ /Tank ΣV = V × Number of Tanks = 667 × 8 = 5,336 m ³




Table M-5 (3/6) Design Calculation for Master Plan (South2 WWTP)

Item	Calculation
2. Trickling Filter	
1) First Step	
a) Required Capacity	
Design Flowrate	55.000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 55.000 \times 182 \times 10^{-3} = 10.010 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{10.010}{1.0} = 10.010 \text{ m}^2$
b) Dimensions	
Diameter	40.00 m
Bed Depth	2.00 m
Number	8 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 40.00^2 \times 8 = 10.053 \text{ m}^2$
BOD Loading	$= \frac{10.010}{10.053} = 1.0 \text{ kg·BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{55.000}{10.053} = 5.5 \text{ m/d}$
2) Intermediate Clarifier	Intermediate clarifier is the same size as primary sedimentation tank.
3) Second Step	
a) Required Capacity	
Design flowrate	55.000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 55.000 \times 91 \times 10^{-3} = 5.005 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{5.005}{1.0} = 5.005 \text{ m}^2$
b) Dimensions	
Diameter	40.00 m
Bed Depth	2.00 m
Number	4 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 40.00^2 \times 4 = 5.027 \text{ m}^2$
BOD Loading	$= \frac{5.005}{5.027} = 1.0 \text{ kg·BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{55.000}{5.027} = 10.9 \text{ m/d}$

Table M-5 (4/6) Design Calculation for Master Plan (South2 WWTP)

Item	Calculation
3. Final Clarifier	
a) Required Capacity	
Design Flowrate	55,000 m ³ /d
Overflow Rate	25.0 m ³ /m ² ·d
Retention Time	3.0 h
Required Surface Area	$= \frac{55,000}{25.0} = 2,200 \text{ m}^2$
b) Dimensions	
Diameter	R = 18.50 m
Depth	D = 16.66 m
Angle	θ = 60°
Number	8 Tanks
	(h1 = 1.50 m, h2 = 15.16 m)
c) Check	
Overflow Rate	$= \frac{55,000}{2,150} = 25.6 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{14,320}{55,000} \times 24 = 6.2 \text{ h}$
Sludge Generation	$= 55,000 \times 70 \times 10^{-6} \div 0.01 = 385 \text{ m}^3$ = 48 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h3}{3} (r1^2 + r1 \times r2 + r2^2) = 48 \text{ m}^3/\text{Tank}$ (h3 = 4.32 m, r1 = 0.50 m, r2 = 2.99 m)
Effective Volume	$V1 = \frac{\pi \times h4}{3} (r2^2 + r2 \times r3 + r3^2) = 1,387 \text{ m}^3/\text{Tank}$ (h4 = 10.84 m, r2 = 2.99 m, r3 = 9.25 m) $V2 = \frac{\pi \times h1}{4} \times R^2 = 403 \text{ m}^3/\text{Tank}$ (h1 = 1.50 m, R = 18.50 m) V = V1 + V2 = 1,790 m ³ /Tank ΣV = V × Number of Tanks = 1,790 × 8 = 14,320 m ³




Table M-5 (5/6) Design Calculation for Master Plan (South2 WWTP)

Item	Calculation
4. Sludge Digester Tank (Open Tank)	
a) Required Capacity	
Design Flowrate	51,000 m ³ /d (Daily Average)
Retention Time	47 days (Unheated Anaerobic Digestion)
Influent Solid Quantity	= Raw Sludge + Septage from Sanitation Facility = 51,000 × 280 × 0.8 × 10 ⁻⁶ + 0.06 = 11.4 + 0.06 = 11.5 t/d
Influent Sludge Volume	= $\frac{11.4}{0.06} \div 0.9 = 190.9 \text{ m}^3/\text{d}$ (Raw Sludge Concentration 6%)
Required Volume	= 190.9 × 47 = 8,972 m ³
b) Dimensions	<div style="display: flex; align-items: flex-start;"> <div style="flex: 1;"> <p>Diameter R = 18.00 m Depth D = 10.00 m Angle $\theta = 45^\circ$ Number 8 Tanks</p> <p>(h1 = 1.50 m, h2 = 8.50 m)</p> </div> <div style="flex: 1; text-align: center;"> </div> </div>
	$V1 = \frac{\pi \times h2}{3} (r1^2 + r1 \times r2 + r2^2) = 763 \text{ m}^3/\text{Tank}$ <p>(h2 = 8.50 m, r1 = 0.50 m, r2 = 9.00 m)</p> $V2 = \frac{\pi \times h1}{4} \times R^2 = 382 \text{ m}^3/\text{Tank}$ <p>(h1 = 1.50 m, R = 18.00 m)</p> <p>V = V1 + V2 = 1,145 m³/Tank</p> <p>$\Sigma V = V \times \text{Number of Tanks} = 1,145 \times 8 = 9,160 \text{ m}^3$</p>
c) Check	
Retention Time	= $\frac{9,160}{191} = 48 \text{ days}$

Table M-5 (6/6) Design Calculation for Master Plan (South2 WWTP)

Item	Calculation
5. Sludge Drying Bed	
a) Required Capacity	
Influent Solid Quantity	= Digested Solids $= 11.4 \times (1 - (0.65 \times 0.5)) = 7.7 \text{ t/d}$ Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %
Dried Sludge Quantity	$= \frac{7.7}{0.4} = 19.3 \text{ t/d}$ (Moisture Content of Dried Sludge: 60 %)
Solids Loading	160 kg-SS/m ² ·yr.
Required Area	$= \frac{7.7 \times 365}{0.16} = 17,566 \text{ m}^2$
b) Dimensions	
Width	40.00 m
Length	110.00 m
Number	4 Tanks
c) Check	
Area	$= 40.00 \times 110.00 \times 4 = 17,600 \text{ m}^2$
Solids Loading	$= \frac{7.7}{17,600} \times 365 \times 10^3 = 159.7 \text{ kg-SS/m}^2\cdot\text{yr}$

**Design Calculation
for
South 3 Region Wastewater Treatment Plant
(Master Plan)**



Table M-6 (1/6) Design Calculation for Master Plan (South3 WWTP)


Item	Calculation
Design Flowrate	Daily Average 66,000 m ³ /d
	Daily Maximum 72,000 m ³ /d
	Hourly Maximum 107,000 m ³ /d
Treatment Process Flow Diagram	 <pre> graph TD Influent --> SGC SGC --> PST PST --> TF1[TF(I)] PST --> SDT TF1 --> IC IC --> TF2[TF(II)] TF2 --> FC FC --> Effluent FC --> TF1 SDT --> SDB SDB --> Disposal </pre> <p>※</p> <div data-bbox="689 1480 1279 1751" style="border: 1px solid black; padding: 5px;"> <p>Legend</p> <p>S G C - Screen-Grit Chamber</p> <p>P S T - Primary Sedimentation Tank</p> <p>T F(I) - Trickling Filter (First Step)</p> <p>I C - Intermediate Clarifier</p> <p>T F(II) - Trickling Filter (Second Step)</p> <p>F C - Final Clarifier</p> <p>S D T - Sludge Digester Tank</p> <p>S D B - Sludge Drying Bed</p> </div>

Table M-6 (2/6) Design Calculation for Master Plan (South3 WWTP)

Item	Calculation
I. Primary Sedimentation Tank	
a) Required Capacity	
Design Flowrate	72,000 m ³ /d
Overflow Rate	50.0 m ³ /m ² ·d
Retention Time	2.0 h
Required Surface Area	$= \frac{72,000}{50.0} = 1,440 \text{ m}^2$
b) Dimensions	
Diameter	R = 12.50 m
Depth	D = 11.46 m
Angle	θ = 60°
Number	12 Tanks
c) Check	
	(h ₁ = 1.50 m, h ₂ = 9.96 m)
Overflow Rate	$= \frac{72,000}{1,473} = 48.9 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{6,408}{72,000} \times 24 = 2.1 \text{ h}$
Sludge Generation	$= 72,000 \times 154 \times 10^{-6} \div 0.01 = 1,109 \text{ m}^3$ = 92 m ³ /Tank
	(Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 92 \text{ m}^3/\text{Tank}$ (h ₃ = 5.56 m, r ₁ = 0.50 m, r ₂ = 3.71 m)
Effective Volume	$V_1 = \frac{\pi \times h_4}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 350 \text{ m}^3/\text{Tank}$ (h ₄ = 4.40 m, r ₂ = 3.71 m, r ₃ = 6.25 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 184 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 12.50 m) V = V ₁ + V ₂ = 534 m ³ /Tank Σ V = V × Number of Tanks = 534 × 12 = 6,408 m ³




Table M-6 (3/6) Design Calculation for Master Plan (South3 WWTP)

Item	Calculation
2. Trickling Filter	
1) First Step	
a) Required Capacity	
Design Flowrate	72,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 72,000 \times 182 \times 10^{-3} = 13,104 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{13,104}{1.0} = 13,104 \text{ m}^2$
b) Dimensions	
Diameter	38.00 m
Bed Depth	2.00 m
Number	12 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 38.00^2 \times 12 = 13,609 \text{ m}^2$
BOD Loading	$= \frac{13,104}{13,609} = 1.0 \text{ kg·BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{72,000}{13,609} = 5.3 \text{ m/d}$
2) Intermediate Clarifier Intermediate clarifier is the same size as primary sedimentation tank.	
3) Second Step	
a) Required Capacity	
Design flowrate	72,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 72,000 \times 91 \times 10^{-3} = 6,552 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{6,552}{1.0} = 6,552 \text{ m}^2$
b) Dimensions	
Diameter	38.00 m
Bed Depth	2.00 m
Number	6 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 38.00^2 \times 6 = 6,805 \text{ m}^2$
BOD Loading	$= \frac{6,552}{6,805} = 1.0 \text{ kg·BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{72,000}{6,805} = 10.6 \text{ m/d}$

Table M-6 (4/6) Design Calculation for Master Plan (South3 WWTP)

Item	Calculation
3. Final Clarifier	
a) Required Capacity	
Design Flowrate	72,000 m ³ /d
Overflow Rate	25.0 m ³ /m ² ·d
Retention Time	3.0 h
Required Surface Area	$= \frac{72,000}{25.0} = 2,880 \text{ m}^2$
b) Dimensions	
Diameter	R = 17.50 m
Depth	D = 15.79 m
Angle	θ = 60°
Number	12 Tanks
	(h ₁ = 1.50 m, h ₂ = 14.29 m)
c) Check	
Overflow Rate	$= \frac{72,000}{2,886} = 24.9 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{18,396}{72,000} \times 24 = 6.1 \text{ h}$
Sludge Generation	$= 72,000 \times 70 \times 10^{-6} \div 0.01 = 504 \text{ m}^3$ = 42 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 42 \text{ m}^3/\text{Tank}$ (h ₃ = 4.09 m, r ₁ = 0.50 m, r ₂ = 2.86 m)
Effective Volume	$V_1 = \frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 1,172 \text{ m}^3/\text{Tank}$ (h ₁ = 10.20 m, r ₂ = 2.86 m, r ₃ = 8.75 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 361 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 17.50 m) V = V ₁ + V ₂ = 1,533 m ³ /Tank ΣV = V × Number of Tanks = 1,533 × 12 = 18,396 m ³




Table M-6 (5/6) Design Calculation for Master Plan (South3 WWTP)


Item	Calculation
1. Sludge Digester Tank (Open Tank)	
a) Required Capacity Design Flowrate	66.000 m ³ /d (Daily Average)
Retention Time	47 days (Unheated Anaerobic Digestion)
Influent Solid Quantity	= Raw Sludge + Septage from Sanitation Facility = 66.000 × 280 × 0.8 × 10 ⁻⁶ + 0.02 = 14.8 + 0.02 = 14.8 t/d
Influent Sludge Volume	= $\frac{14.8}{0.06} + 0.3 = 247.3$ m ³ /d (Raw Sludge Concentration 6%)
Required Volume	= 247.3 × 47 = 11.623 m ³
b) Dimensions	<div style="display: flex; align-items: center;"> <div style="flex: 1;"> <p>Diameter R = 17.00 m Depth D = 9.50 m Angle θ = 45° Number 12 Tanks</p> <p>(h1 = 1.50 m, h2 = 8.00 m)</p> </div> <div style="flex: 1;">  </div> </div>
	$V1 = \frac{\pi \times h2}{3} (r1^2 + r1 \times r2 + r2^2) = 643 \text{ m}^3/\text{Tank}$ <p>(h2 = 8.00 m, r1 = 0.50 m, r2 = 8.50 m)</p> $V2 = \frac{\pi \times h1}{4} \times R^2 = 310 \text{ m}^3/\text{Tank}$ <p>(h1 = 1.50 m, R = 17.00 m)</p> <p>V = V1 + V2 = 983 m³/Tank</p> <p>Σ V = V × Number of Tanks = 983 × 12 = 11.796 m³</p>
c) Check	
Retention Time	= $\frac{11.796}{247} = 48$ days

Table M-6 (6/6) Design Calculation for Master Plan (South3 WWTP)

Item	Calculation
5. Sludge Drying Bed	
a) Required Capacity	
Influent Solid Quantity	= Digested Solids
	= $14.8 \times (1 - (0.65 \times 0.5)) = 10.0 \text{ t/d}$
	Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %
Dried Sludge Quantity	= $\frac{10.0}{0.4} = 25.0 \text{ t/d}$
	(Moisture Content of Dried Sludge: 60 %)
Solids Loading	160 kg-SS/m ² ·yr.
Required Area	= $\frac{10.0 \times 365}{0.16} = 22,813 \text{ m}^2$
b) Dimensions	
Width	40.00 m
Length	95.00 m
Number	6 Tanks
c) Check	
Area	= $40.00 \times 95.00 \times 6 = 22,800 \text{ m}^2$
Solids Loading	= $\frac{10.0}{22,800} \times 365 \times 10^3 = 160.1 \text{ kg-SS/m}^2\cdot\text{yr}$

**Design Calculation
for
East 1 Region Wastewater Treatment Plant
(Master Plan)**



Table M-7 (1/6) Design Calculation for Master Plan (East1 WWTP)


Item	Calculation
Design Flowrate	Daily Average 121,000 m ³ /d
	Daily Maximum 131,000 m ³ /d
	Hourly Maximum 196,000 m ³ /d
Treatment Process Flow Diagram	 <pre> graph TD Influent --> SGC[SGC] SGC --> PST[PST] PST --> TF1[TF(I)] PST --> SDT[SDT] TF1 --> IC[IC] IC --> TF2[TF(II)] IC --> SDB[SDB] TF2 --> FC[FC] TF2 --> SDB FC --> Effluent[Effluent] FC --> SDB SDB --> Disposal[Disposal] Effluent -.-> * TF1 </pre> <p>The flow diagram illustrates the wastewater treatment process. It begins with 'Influent' entering a 'SGC' (Screen-Grit Chamber). The flow then proceeds to a 'PST' (Primary Sedimentation Tank). From the PST, the flow splits: one path goes to 'TF(I)' (Trickling Filter - First Step), and another path goes to 'SDT' (Sludge Digester Tank). From 'TF(I)', the flow goes to 'IC' (Intermediate Clarifier). From 'IC', the flow splits: one path goes to 'TF(II)' (Trickling Filter - Second Step), and another path goes to 'SDB' (Sludge Drying Bed). From 'TF(II)', the flow goes to 'FC' (Final Clarifier). From 'FC', the flow splits: one path goes to 'Effluent', and another path goes to 'SDB'. Finally, 'SDB' leads to 'Disposal'. A feedback loop marked with an asterisk (*) connects 'Effluent' back to 'TF(I)'.</p>
<p>Legend</p> <ul style="list-style-type: none"> S G C - Screen-Grit Chamber P S T - Primary Sedimentation Tank T F (I) - Trickling Filter (First Step) I C - Intermediate Clarifier T F (II) - Trickling Filter (Second Step) F C - Final Clarifier S D T - Sludge Digester Tank S D B - Sludge Drying Bed 	

Table M-7 (2/6) Design Calculation for Master Plan (East1 WWTP)

Item	Calculation
I. Primary Sedimentation Tank	
a) Required Capacity	
Design Flowrate	131.000 m ³ /d
Overflow Rate	50.0 m ³ /m ² ·d
Retention Time	2.0 h
Required Surface Area	$= \frac{131.000}{50.0} = 2,620 \text{ m}^2$
b) Dimensions	
Diameter	R = 13.00 m
Depth	D = 11.89 m
Angle	$\theta = 60^\circ$
Number	20 Tanks
c) Check	(h1 = 1.50 m, h2 = 10.39 m)
Overflow Rate	$= \frac{131.000}{2,655} = 49.3 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{11,920}{131,000} \times 24 = 2.2 \text{ h}$
Sludge Generation	$= 131,000 \times 154 \times 10^{-6} \div 0.01 = 2,017 \text{ m}^3$ = 101 m ³ /Tank
Sludge Storage Volume	(Solid Concentration 1%) $= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 101 \text{ m}^3/\text{Tank}$ (h3 = 5.75 m, r1 = 0.50 m, r2 = 3.82 m)
Effective Volume	$V_1 = \frac{\pi \times h_4}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 397 \text{ m}^3/\text{Tank}$ (h4 = 4.61 m, r2 = 3.82 m, r3 = 6.50 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 199 \text{ m}^3/\text{Tank}$ (h1 = 1.50 m, R = 13.00 m) V = V1 + V2 = 596 m ³ /Tank $\Sigma V = V \times \text{Number of Tanks} = 596 \times 20 = 11,920 \text{ m}^3$




Table M-7 (3/6) Design Calculation for Master Plan (East WWTP)

Item	Calculation
2. Trickling Filter	
1) First Step	
a) Required Capacity	
Design Flowrate	131,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 131,000 \times 182 \times 10^{-3} = 23,842 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{23,842}{1.0} = 23,842 \text{ m}^2$
b) Dimensions	
Diameter	39.00 m
Bed Depth	2.00 m
Number	20 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 39.00^2 \times 20 = 23,892 \text{ m}^2$
BOD Loading	$= \frac{23,842}{23,892} = 1.0 \text{ kg·BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{131,000}{23,892} = 5.5 \text{ m/d}$
2) Intermediate Clarifier	Intermediate clarifier is the same size as primary sedimentation tank.
3) Second Step	
a) Required Capacity	
Design flowrate	131,000 m ³ /d
BOD Loading	1.0 kg·BOD/m ² ·d
Influent BOD Load	$= 131,000 \times 91 \times 10^{-3} = 11,921 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{11,921}{1.0} = 11,921 \text{ m}^2$
b) Dimensions	
Diameter	39.00 m
Bed Depth	2.00 m
Number	10 Tanks
c) Check	
Cross-Sectional Area	$= \frac{\pi}{4} \times 39.00^2 \times 10 = 11,946 \text{ m}^2$
BOD Loading	$= \frac{11,921}{11,946} = 1.0 \text{ kg·BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{131,000}{11,946} = 11.0 \text{ m/d}$

Table M-7 (4/6) Design Calculation for Master Plan (East1 WWTP)

Item	Calculation
3. Final Clarifier	
a) Required Capacity	
Design Flowrate	131,000 m ³ /d
Overflow Rate	25.0 m ³ /m ² ·d
Retention Time	3.0 h
Required Surface Area	$= \frac{131,000}{25.0} = 5,240 \text{ m}^2$
b) Dimensions	
Diameter	R = 18.00 m
Depth	D = 16.22 m
Angle	θ = 60°
Number	20 Tanks
	(h ₁ = 1.50 m, h ₂ = 14.72 m)
c) Check	
Overflow Rate	$= \frac{131,000}{5,089} = 25.7 \text{ m}^3/\text{m}^2 \cdot \text{d}$
Retention Time	$= \frac{33,140}{131,000} \times 24 = 6.1 \text{ h}$
Sludge Generation	$= 131,000 \times 70 \times 10^{-6} \div 0.01 = 917 \text{ m}^3$ = 46 m ³ /Tank (Solid Concentration 1%)
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 46 \text{ m}^3/\text{Tank}$ (h ₃ = 4.25 m, r ₁ = 0.50 m, r ₂ = 2.95 m)
Effective Volume	$V_1 = \frac{\pi \times h_4}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 1,275 \text{ m}^3/\text{Tank}$ (h ₄ = 10.47 m, r ₂ = 2.95 m, r ₃ = 9.00 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 382 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 18.00 m) V = V ₁ + V ₂ = 1,657 m ³ /Tank ΣV = V × Number of Tanks = 1,657 × 20 = 33,140 m ³




Table M-7 (5/6) Design Calculation for Master Plan (East1 WWTP)


Item	Calculation
1. Sludge Digester Tank (Open Tank)	
a) Required Capacity Design Flowrate	121,000 m ³ /d (Daily Average)
Retention Time	47 days (Unheated Anaerobic Digestion)
Influent Solid Quantity	= Raw Sludge + Septage from Sanitation Facility = 121,000 × 280 × 0.8 × 10 ⁻⁶ + 0.46 = 27.1 + 0.46 = 27.6 t/d
Influent Sludge Volume	$= \frac{27.1}{0.06} + 6.6 = 458.6 \text{ m}^3/\text{d}$ (Raw Sludge Concentration 6%)
Required Volume	= 458.6 × 47 = 21,554 m ³
b) Dimensions	Diameter R = 18.00 m Depth D = 10.00 m Angle θ = 45° Number 20 Tanks (h ₁ = 1.50 m, h ₂ = 8.50 m)
	 $V_1 = \frac{\pi \times h_2}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 763 \text{ m}^3/\text{Tank}$ (h ₂ = 8.50 m, r ₁ = 0.50 m, r ₂ = 9.00 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 382 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 18.00 m) $V = V_1 + V_2 = 1,145 \text{ m}^3/\text{Tank}$ $\Sigma V = V \times \text{Number of Tanks} = 1,145 \times 20 = 22,900 \text{ m}^3$
c) Check	
Retention Time	$= \frac{22,900}{459} = 50 \text{ days}$

Table M-7 (6/6) Design Calculation for Master Plan (East1 WWTP)

Item	Calculation
5. Sludge Drying Bed	
a) Required Capacity	
Influent Solid Quantity	= Digested Solids $= 27.1 \times (1 - (0.65 \times 0.5)) = 18.3 \text{ t/d}$ Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %
Dried Sludge Quantity	$= \frac{18.3}{0.4} = 45.8 \text{ t/d}$ (Moisture Content of Dried Sludge: 60 %)
Solids Loading	160 kg-SS/m ² ·yr.
Required Area	$= \frac{18.3 \times 365}{0.16} = 41,747 \text{ m}^2$
b) Dimensions	Width 40.00 m Length 105.00 m Number 10 Tanks
c) Check	
Area	$= 40.00 \times 105.00 \times 10 = 42,000 \text{ m}^2$
Solids Loading	$= \frac{18.3}{42,000} \times 365 \times 10^3 = 159 \text{ kg-SS/m}^2\text{-yr}$

**DESIGN CALCULATION FOR FIRST STAGE
PROJECT**



Table M-8 Outline of Treatment Facilities for the First Stage Project (Alternative 1 and Alternative 2)

FACILITY	CENTRAL				SOUTH 3 (PINULA COLLECTOR)				SOUTH 3 (HERMOSA COLLECTOR)			
	Dimensions	No.		Dimensions	No.		Dimensions	No.				
		Ultimate	First Stage		Ultimate	First Stage		Ultimate	First Stage			
Primary Sedimentation Tank	B10.0m x L30.0m x h10.0m	20	15	φ11.0 m x h 10.0 m	12	8	φ9.5 m x h 9.0 m	4	-			
Trickling Filter (First Step)	φ 39.0 m x h 2.0 m	40	-	φ 34.0 mx h 2.0 m	12	8	φ 29.0 m x h 2.0 m	4	-			
Intermediate Clarifier	B10.0 m x L30.0 m x h10.0 m	20	-	φ11.0 m x h 10.0 m	12	8	φ 9.5 m x h9.0 m	4	-			
Trickling Filter (Second Step)	φ 39.0 m x h 2.0 m	20	-	φ 34.0 m x h 2.0 m	6	4	φ 29.0 mx h 2.0 m	2	-			
Final Clarifier	B10.0 m x L30.0 m x h 1.0 m	40	-	φ11.0 m x h 1.0 m	24	16	φ 9.5 m x h 9.0 m	8	-			
Sludge Digester Tank	φ 17.5 m x h10.0 m	40	-	φ 15.5 m x h 9.0 m	12	-	φ 14.0 m x h 8.0 m	4	-			
Sludge Drying Bed	W 40.0 m x L 100.0 m	20	15	W 40.0 mx L 80.0m	6	5	W 30.0 m x L 80.0 m	2	-			
Anaerobic Pond (h = 3.0 m)	BA 13.0 m x 13.0 m	2	1	BA 1.0 m x 1.0 m	2	1	BA 1.0 m x 1.0 m	1	-			
	SA 31.0 m x 31.0 m	2	1	SA 19.0 m x 19.0 m	2	1	SA 19.0 m x 19.0 m	1	-			
Facultative Ponds (h = 2.0 m)	BA 120.0 m x 60.0 m	2	1	BA 52.0 m x 26.0 m	2	1	BA 20.0 m x 40.0 m	1	-			
	SA 132.0 m x 72.0 m	2	1	SA 64.0 m x 38.0 m	2	1	SA 32.0 m x 52.0 m	1	-			
DESIGN BASIS												
Design Flowrate	Ultimate	First Stage	First Stage	Ultimate	First Stage	First Stage	Ultimate	First Stage	First Stage			
Daily Average, m ³ /d	238,000	179,000	179,000	52,700	33,000	33,000	13,300	-	-			
Daily Maximum, m ³ /d	261,000	196,000	196,000	57,500	36,000	36,000	14,500	-	-			
Hourly Maximum, m ³ /d	390,000	293,000	293,000	85,500	53,500	53,500	21,500	-	-			
Hourly Maximum Wet weather, m ³ /d	1,087,000	879,000	879,000	-	-	-	-	-	-			
Sludge Generation, /d	90	71	71	20	19	19	5	-	-			

Note : BA.....Bottom Area, SA.....Surface Area
Source: Study Team



**Design Calculation
for
Central Region Wastewater Treatment Plant
(First Stage)**



Table M-9 (1/10) Design Calculation for First Stage Project (Alternative 1: Central WWTP)



Item	Ultimate	First Stage
Design Flowrate	Daily Average 238,000 m ³ /d Daily Maximum 261,000 m ³ /d Hourly Maximum 390,000 m ³ /d Hourly Maximum Wet Weather 1,087,000 m ³ /d	Daily Average 179,000 m ³ /d Daily Maximum 196,000 m ³ /d Hourly Maximum 293,000 m ³ /d Hourly Maximum Wet Weather 879,000 m ³ /d
Treatment Process Flow Diagram	 <p>The flow diagram for the ultimate stage shows influent entering a Screen-Grit Chamber (SGC), followed by a Primary Sedimentation Tank (PST). The flow then splits into two paths: one through a Tricking Filter (TF(I)) and another through an Intermediate Clarifier (IC). Both paths merge and go through a Tricking Filter (TF(II)) and a Final Clarifier (FC). The FC output goes to a Sludge Drying Bed (SDB), then to an Aerobic Pond (A.P.), and finally to a Facilitative Pond (F.P.) before disposal. A note with an asterisk (*) indicates that the flow to the SDB is the Primary Treated Excess Wet Weather Flow (3x Maximum Hourly Flow - 1x Maximum Hourly Flow).</p>	 <p>The flow diagram for the first stage shows influent entering a Screen-Grit Chamber (SGC), followed by a Primary Sedimentation Tank (PST). The flow then splits into two paths: one through an Aerobic Pond (A.P.) and another through a Sludge Drying Bed (SDB). Both paths merge and go to a Facilitative Pond (F.P.) before disposal.</p>
Legend	<ul style="list-style-type: none"> SGC - Screen-Grit Chamber PST - Primary Sedimentation Tank TF(I) - Tricking Filter (First Step) IC - Intermediate Clarifier TF(II) - Tricking Filter (Second Step) FC - Final Clarifier SDB - Sludge Drying Bed A.P. - Aerobic Pond F.P. - Facilitative Pond 	
Footnote	* Primary Treated Excess Wet Weather Flow (3x Maximum Hourly Flow - 1x Maximum Hourly Flow)	

Table M-9 (2/10) Design Calculation for First Stage Project (Alternative 1: Central WWTP)

Item	Ultimate	First Stage
1. Primary Sedimentation Tank		
a) Required Capacity		
Design Flowrate	261,000 m ³ /d (C.M.),	879,000 m ³ /d (H.M.W.V.F.)
Overflow Rate	50.0 m ³ /m ² ·d	50.0 m ³ /m ² ·d
Retention Time	2.0 h (C.M.)	0.5 h (H.M.W.V.F.)
	D.M. : Daily Maximum	D.M. : Daily Maximum
	H.M.W.V.F. : Hourly Maximum Wet Weather Flow	H.M.W.V.F. : Hourly Maximum Wet Weather Flow
Required Surface Area	261,000 / 50.0 = 5,220 m ²	196,000 / 50.0 = 3,920 m ²
b) Dimensions	R = 10.00 m L1 = 30.00 m D = 10.00 m θ = 62.1° 20 Tanks	R = 10.00 m L1 = 30.00 m D = 10.00 m θ = 62.1° 15 Tanks
c) Check	(h1 = 1.50 m, h2 = 8.50 m, L2 = 20.00 m)	(h1 = 1.50 m, h2 = 8.50 m, L2 = 20.00 m)
Surface Area	$(\pi \times r^2 \times R \times L2) \times \text{Number of Tanks} = 5,571 \text{ m}^2$	$(\pi \times r^2 \times R \times L2) \times \text{Number of Tanks} = 4,178 \text{ m}^2$
Overflow Rate (D.M.)	261,000 / 5,571 = 46.8 m ³ /m ² ·d	196,000 / 4,178 = 46.9 m ³ /m ² ·d
Retention Time (D.M.)	20,980 / 261,000 × 24 = 1.9 h	15,735 / 196,000 × 24 = 1.9 h
Retention Time (H.M.W.V.F.)	20,980 / 1,037,000 × 24 = 0.5 h	15,735 / 879,000 × 24 = 0.4 h
Sludge Generation	261,000 × 154 × 10 ⁻⁶ ÷ 0.01 = 4,019 m ³ (Solid Concentration 1%)	196,000 × 154 × 10 ⁻⁶ ÷ 0.01 = 3,018 m ³ (Solid Concentration 1%)
Sludge Storage Volume	$\frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 87.5 \text{ m}^3$ $\frac{(r_1 + r_2) \times 2}{2} \times h_3 \times L2 = 463.8 \text{ m}^3$ = 87.5 + 463.8 = 551 m ³ /Tank (h3 = 5.74 m, r1 = 0.50 m, r2 = 3.54 m, L2 = 20.00 m)	$\frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 87.5 \text{ m}^3$ $\frac{(r_1 + r_2) \times 2}{2} \times h_3 \times L2 = 463.8 \text{ m}^3$ = 87.5 + 463.8 = 551 m ³ /Tank (h3 = 5.74 m, r1 = 0.50 m, r2 = 3.54 m, L2 = 20.00 m)

Table M-9 (3/10) Design Calculation for First Stage Project (Alternative 1 : Central WWTP)

Item	Ultimate	First Stage
Effective Volume	$\frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 159.6 \text{ m}^3$ $\frac{(r_2 + r_3) \times 2}{2} \times h_1 \times L_2 = 471.4 \text{ m}^3$ $V1 = 159.6 + 471.4 = 631 \text{ m}^3/\text{Tank}$ <p>(h₁ = 2.76 m , r₂ = 3.54 m , r₃ = 5.00 m , L₂ = 20.00 m)</p> $V2 = \frac{\pi \times h_1}{4} \times R^2 + R \times L_2 \times h_1 = 418 \text{ m}^3/\text{Tank}$ <p>(h₁ = 1.50 m , R = 10.00 m , L₂ = 20.00 m)</p> $V = V1 + V2 = 631 + 418 = 1,049 \text{ m}^3/\text{Tank}$ $\Sigma V = V \times \text{Number of Tanks} = 1,049 \times 15 = 20,980 \text{ m}^3$	$\frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 159.6 \text{ m}^3$ $\frac{(r_2 + r_3) \times 2}{2} \times h_1 \times L_2 = 471.4 \text{ m}^3$ $V1 = 159.6 + 471.4 = 631 \text{ m}^3/\text{Tank}$ <p>(h₁ = 2.76 m , r₂ = 3.54 m , r₃ = 5.00 m , L₂ = 20.00 m)</p> $V2 = \frac{\pi \times h_1}{4} \times R^2 + R \times L_2 \times h_1 = 418 \text{ m}^3/\text{Tank}$ <p>(h₁ = 1.50 m , R = 10.00 m , L₂ = 20.00 m)</p> $V = V1 + V2 = 631 + 418 = 1,049 \text{ m}^3/\text{Tank}$ $\Sigma V = V \times \text{Number of Tanks} = 1,049 \times 15 = 15,735 \text{ m}^3$

Table M-9 (4/10) Design Calculation for First Stage Project (Alternative 1: Central WWTP)

Item	Ultimate	First Stage
2. Trickling Filter		
a) Required Capacity		
Design Flowrate	261,000 m ³ /d	
BOD Loading	1.0 kg-BOD/m ² -d	
Influent BOD Load	$= 261,000 \times 182 \times 10^{-3} = 47,502 \text{ kg/d}$	
Required Cross-Sectional Area	$= \frac{47,502}{1.0} = 47,502 \text{ m}^2$	
b) Dimensions		
Diameter	R = 39.00 m	
Depth	D = 2.00 m	
Number	40 Tanks	
c) Check		
Cross-Sectional Area	$= 19.50^2 \times \pi \times 40 = 47,784 \text{ m}^2$	
BOD Loading	$= \frac{47,502}{47,784} = 1.0 \text{ kg-BOD/m}^2\text{-d}$	
Hydraulic Loading	$= \frac{261,000}{47,784} = 5.5 \text{ m/d}$	
2) Intermediate Clarifier is the same size as primary sedimentation tank.		
3) Second Step		
a) Required Capacity		
Design Flowrate	261,000 m ³ /d	
BOD Loading	1.0 kg-BOD/m ² -d	
Influent BOD Load	$= 261,000 \times 91 \times 10^{-3} = 23,751 \text{ kg/d}$	
Required Cross-Sectional Area	$= \frac{23,751}{1.0} = 23,751 \text{ m}^2$	
b) Dimensions		
Diameter	R = 39.00 m	
Depth	D = 2.00 m	
Number	20 Tanks	
c) Check		
Cross-Sectional Area	$= 19.50^2 \times \pi \times 20 = 23,892 \text{ m}^2$	
BOD Loading	$= \frac{23,751}{23,892} = 1.0 \text{ kg-BOD/m}^2\text{-d}$	
Hydraulic Loading	$= \frac{261,000}{23,892} = 10.9 \text{ m/d}$	

Table M-9 (S/10) Design Calculation for First Stage Project (Alternative 1 : Central WWTP)



Item	Ultimate	First Stage
a) Final Clarifier a) Required Capacity Design Flowrate Overflow Rate Retention Time Required Surface Area Dimensions Diameter Diameter Depth Angle Number Check Overflow Rate (D.M.) Retention Time (D.M.) Sludge Generation Sludge Storage Volume	$\frac{261,000 \text{ m}^3/\text{d}}{25.0 \text{ h}} = 10,440 \text{ m}^3/\text{m}^2\cdot\text{d}$ $\frac{261,000}{25.0} = 10,440 \text{ m}^3$ Diameter R = 10.00 m Diameter L1 = 30.00 m Depth D = 10.00 m Angle $\theta = 62.1^\circ$ Number 40 Tanks $(h_1 = 1.50 \text{ m}, h_2 = 8.50 \text{ m}, L_2 = 20.00 \text{ m})$ $\frac{261,000}{11,142} = 23.4 \text{ m}^3/\text{m}^2\cdot\text{d}$ $\frac{41,950}{261,000} \times 24 = 3.9 \text{ h}$ $= \frac{261,000 \times 70 \times 10^{-6} \div 0.01}{(Solid \text{ Concentration } \%)} = \frac{1,827 \text{ m}^3}{46 \text{ m}^3/\text{Tank}}$ $\frac{\pi \times h_3}{3} \frac{(r_1^2 + r_1 \times r_2 + r_2^2)}{2} = 87.5 \text{ m}^3$ $\frac{(r_1 + r_2) \times 2}{2} \times h_3 \times L_2 = 463.8 \text{ m}^3$ $= 87.5 + 463.8 = 551 \text{ m}^3/\text{Tank}$ $(h_3 = 5.74 \text{ m}, r_1 = 0.50 \text{ m}, r_2 = 3.54 \text{ m}, L_2 = 20.00 \text{ m})$	 

Table M-9 (6/10) Design Calculation for First Stage Project (Alternative 1 : Central WWTP)

Item	Ultimate	First Stage
Effective Volume	$\frac{\pi \times h_1}{3} (r^2 + r^2 + r^3 + r^3) = 159.6 \text{ m}^3$ $\frac{(r_2 + r_3) \times 2}{2} \times h_1 \times L_2 = 471.4 \text{ m}^3$ $V_1 = 159.6 + 471.4 = 631 \text{ m}^3/\text{Tank}$ $(h_1 = 2.76 \text{ m}, r_2 = 3.54 \text{ m}, r_3 = 5.00 \text{ m}, L_2 = 20.00 \text{ m})$ $V_2 = \frac{\pi \times h_1}{4} \times R^2 + R \times L_2 \times h_1 = 418 \text{ m}^3$ $(h_1 = 1.50 \text{ m}, R = 10.00 \text{ m}, L_2 = 20.00 \text{ m})$ $V = V_1 + V_2 = 631 + 418 = 1,049 \text{ m}^3/\text{Tank}$ $\Sigma V = V \times \text{Number of Tanks} = 1,049 \times 40 = 41,960 \text{ m}^3$	

Table M-9 (7/10) Design Calculation for First Stage Project (Alternative 1: Central WWTP)


Item	Ultimate	First Stage
4. Sludge Digester Tank (Open Tank)		
a) Required Capacity Design Flowrate	238,000 m ³ /d (Daily Average)	
Retention Time	47 days (Unheated Anaerobic Digestion)	
Influent Solid Quantity	= Raw Sludge + Septage from Sanitation Facility = 238,000 × 280 × 0.8 × 10 ⁻⁶ + 0.84 = 53.3 + 0.84 = 54.1 t/d	
Influent Sludge Volume	= $\frac{53.3}{0.06} + 12.0 = 900$ m ³ /d (Raw Sludge Concentration 6%)	
Required Volume	= 900 × 47 = 42,300 m ³	
b) Dimensions	 <p>Diameter R = 17.50 m Depth D = 10.00 m Angle $\theta = 45.87^\circ$ Number 40 Tanks (h1 = 1.50 m, h2 = 8.50 m)</p>	
e) Check	$V_1 = \frac{\pi \times h_2}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 723 \text{ m}^3/\text{Tank}$ $(h_2 = 8.50 \text{ m}, r_1 = 0.50 \text{ m}, r_2 = 8.75 \text{ m})$ $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 361 \text{ m}^3/\text{Tank}$ $(h_1 = 1.50 \text{ m}, R = 17.50 \text{ m})$ $V = V_1 + V_2 = 1,084 \text{ m}^3/\text{Tank}$ $\Sigma V = V \times \text{Number of Tanks} = 1,084 \times 40 = 43,360 \text{ m}^3$	
Retention Time	= $\frac{43,360}{900} = 48$ days	

Table M-9 (S/10) Design Calculation for First Stage Project (Alternative 1: Central WWTP)

Item	Ultimate	First Stage
3. Sludge Drying Bed		
a) Required Capacity		
Influent Solid Quantity	= Digested Solids	= Raw Sludge + Septage from Sanitation Facility
	= $53.3 \times (1 - (0.65 \times 0.5)) = 36.0 \text{ t/d}$	= $176,000 \times 280 \times 0.55 \times 10^{-6} + 0.81$
	Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %	= $27.6 + 0.81 = 28.4 \text{ t/d}$
Dried Sludge Quantity	= $\frac{36.0}{1 - 0.6} = 90.0 \text{ t/d}$	= $\frac{28.4}{1 - 0.6} = 71.0 \text{ t/d}$
Solids Loading	(Moisture Content of Dried Sludge: 60 %) 160 kg-SS/m ² ·yr.	(Moisture Content of Dried Sludge: 60 %) 160 kg-SS/m ² ·yr.
Required Area	= $\frac{36.0 \times 365}{0.16} = 82,125 \text{ m}^2$	= $\frac{27.6 \times 365}{0.16} = 82,962 \text{ m}^2$
b) Dimensions	Width 40.00 m Length 100.00 m Number 20 tanks	Width 40.00 m Length 100.00 m Number 15 tanks
c) Check		
Area	= $40.00 \times 100.00 \times 20 = 80,000 \text{ m}^2$	= $40.00 \times 100.00 \times 15 = 60,000 \text{ m}^2$
Solids Loading	= $\frac{36.0}{80,000} \times 365 \times 10^3 = 164.3 \text{ kg-SS/m}^2\cdot\text{yr}$	= $\frac{27.6}{60,000} \times 365 \times 10^3 = 167.9 \text{ kg-SS/m}^2\cdot\text{yr}$

Table M-9 (9/10) Design Calculation for First Stage Project (Alternative 1 : Central WWTP)

Item	Ultimate	First Stage
6. Waste Stabilization Pond (for Supernatant Liquor) 1) Anaerobic Ponds a) Required Capacity Design Flowrate	<p>= Supernatant Liquor from Digester Tank and Sludge Drying Bed + Influent Sludge Volume from Digester Tank + Digested Sludge Volume - Dried Sludge Volume (Digested Sludge Volume = Influent Sludge Volume for Sludge Drying Bed)</p> $= 90 + \frac{36.0}{0.06} - 90 = 1,410 \text{ m}^3/\text{d}$	<p>= Supernatant Liquor from Sludge Drying Bed + Influent Sludge Volume to Sludge Drying Bed - Dried Sludge Volume</p> $= \frac{27.0}{0.06} + 12 - 71 = 401 \text{ m}^3/\text{d}$
Volumetric Loading Rate(BOD)	$= 20T - 100 = 20 \times 17 - 100 = 240 \text{ g/m}^2/\text{d}$	$= 20T - 100 = 20 \times 17 - 100 = 240 \text{ g/m}^2/\text{d}$
Water Quality (BOD)	<p>= 500 mg/L</p>	<p>= 500 mg/L</p>
Required Pond Volume	$= \frac{500 \times 1,410}{240} = 2,938 \text{ m}^3$	$= \frac{500 \times 401}{240} = 835 \text{ m}^3$
b) Dimensions	<p>Cross-sectional Shape Trapezoid Bottom Area 13m x 13m (169 m²) Surface Area 31m x 31m (961 m²) Water Depth D = 3.0 m Side Slope 1:3 Number 2 Ponds Effective Volume 1,583 m³/Pond</p>	<p>Cross-sectional Shape Trapezoid Bottom Area 13m x 13m (169 m²) Surface Area 31m x 31m (961 m²) Water Depth D = 3.0 m Side Slope 1:3 Number 1 Ponds Effective Volume 1,583 m³/Pond</p>
e) Check	<p>Retention Time $= \frac{1,583 \times 2}{1,410} = 2.2 \text{ days}$</p>	<p>$= \frac{1,583}{401} = 3.8 \text{ days}$</p>
Volumetric Loading Rate(BOD)	$= \frac{500 \times 1,410}{1,583 \times 2} = 229 \text{ g/m}^2/\text{d}$	$= \frac{500 \times 401}{1,583} = 131 \text{ g/m}^2/\text{d}$
f) Effluent Quality(BOD) Removal Rate	$= 2T + 20 = 2 \times 17 + 20 = 54 \%$	$= 2T + 20 = 2 \times 17 + 20 = 54 \%$
Effluent Quality	$= (1 - 0.54) \times 500 = 230 \text{ mg/L}$	$= (1 - 0.54) \times 500 = 230 \text{ mg/L}$

Table M-9 (10/10) Design Calculation for First Stage Project (Alternative 1 : Central WWTP)

Item	Ultimate	First Stage
2) Facultative Ponds a) Required Capacity Design Flowrate	$= 1,410 \text{ m}^3/\text{d}$ $= 350 \times (1.107 - 0.002T)^{-T-25}$ $= 350 \times (1.107 - 0.002 \times 17)^{-17-25}$ $= 199 \text{ kg/ha/day}$	$= 401 \text{ m}^3/\text{d}$ $= 350 \times (1.107 - 0.002T)^{-T-25}$ $= 350 \times (1.107 - 0.002 \times 17)^{-17-25}$ $= 199 \text{ kg/ha/day}$
Surface Loading Rate(BOD)	$= 1,410 \times 230 \times 10^{-3} = 324 \text{ kg/day}$	$= 401 \times 230 \times 10^{-3} = 92 \text{ kg/day}$
Influent BOD Load	$\frac{324}{199} = 1.63 \text{ ha} = 16,300 \text{ m}^2$	$\frac{92}{199} = 0.46 \text{ ha} = 4,600 \text{ m}^2$
Required Surface Area		
b) Dimensions	<p>Cross-sectional Shape Trapezoid</p> <p>Bottom Area $120\text{m} \times 60\text{m}$ (7,200 m²)</p> <p>Surface Area $132\text{m} \times 72\text{m}$ (9,504 m²)</p> <p>Mid depth Area $126\text{m} \times 66\text{m}$ (8,316 m²)</p> <p>Water Depth $D = 2.0 \text{ m}$</p> <p>Side Slope 1:3</p> <p>Number 2 Ponds</p> <p>Effective Volume 16,656 m³/Pond</p>	<p>Cross-sectional Shape Trapezoid</p> <p>Bottom Area $120\text{m} \times 60\text{m}$ (7,200 m²)</p> <p>Surface Area $132\text{m} \times 72\text{m}$ (9,504 m²)</p> <p>Mid depth Area $126\text{m} \times 66\text{m}$ (8,316 m²)</p> <p>Water Depth $D = 2.0 \text{ m}$</p> <p>Side Slope 1:3</p> <p>Number 1 Ponds</p> <p>Effective Volume 16,656 m³/Pond</p>
c) Check	$\frac{16,656 \times 2}{1,410} = 23.6 \text{ days}$	$\frac{16,656}{401} = 41.5 \text{ days}$
Retention Time		
Surface Loading Rate (at Mid depth)	$\frac{324}{1.26 \times 0.66 \times 2} = 195 \text{ kg/ha/day}$	$\frac{92}{1.26 \times 0.66} = 111 \text{ kg/ha/day}$
d) Effluent Quality (BOD)	$\frac{230}{1 + 0.26 \times 23.6} = 32.2 \text{ mg/L}$	$\frac{230}{1 + 0.26 \times 41.5} = 19.5 \text{ mg/L}$
	<p>WHERE</p> $KT = 0.3 \times (1.05)^{T-20}$ $= 0.3 \times (1.05)^{17-20}$ $= 0.26$	<p>WHERE</p> $KT = 0.3 \times (1.05)^{T-20}$ $= 0.3 \times (1.05)^{17-20}$ $= 0.26$

**Design Calculation
for
South 3 Region Wastewater Treatment Plant
(First Stage)**



Table M-10 (1/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 a) Facilities for Pinula Collector



Item	Ultimate	First Stage
Design Flowrate	Daily Average 52,700 m ³ /d Daily Maximum 57,500 m ³ /d Hourly Maximum 86,500 m ³ /d	Daily Average 53,000 m ³ /d Daily Maximum 56,000 m ³ /d Hourly Maximum 53,500 m ³ /d
Treatment Process Flow Diagram	 <p style="text-align: center;">*</p> <div data-bbox="1101 1254 1324 1702" style="border: 1px solid black; padding: 5px;"> <p>Legend</p> <ul style="list-style-type: none"> S G C - Screen-Grit Chamber P S T - Primary Sedimentation Tank T F (I) - Trickling Filter (First Step) I G - Intermediate Clarifier T F (II) - Trickling Filter (Second Step) F C - Final Clarifier S D T - Sludge Digester Tank S D B - Sludge Drying Bed A P - Anaerobic Pond F P - Facultative Pond </div>	
* Primary Treated Excess Wet Weather Flow (3X Maximum Hourly Flow - 1X Maximum Hourly Flow)		

Table M-10 (2/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 a) Facilities for Pinula Collector

Item	Ultimate	First Stage
1. Primary Sedimentation Tank		
a) Required Capacity		
Design Flowrate	57,500 m ³ /d (D.M.)	36,000 m ³ /d (D.M.)
Overflow Rate	50.0 m ³ /m ² -d	50.0 m ³ /m ² -d
Retention Time	2.0 h (D.M.)	2.0 h (D.M.)
	D.M. : Daily Maximum	D.M. : Daily Maximum
	II.M.V.W.F. : Hourly Maximum Wet Weather Flow	II.M.V.W.F. : Hourly Maximum Wet Weather Flow
Required Surface Area	57,500 / 50.0 = 1,150 m ²	36,000 / 50.0 = 720 m ²
b) Dimensions		
Diameter	R = 11.00 m	R = 11.00 m
Depth	D = 10.00 m	D = 10.00 m
Angle	θ = 59.5°	θ = 59.5°
Number	12 Tanks	8 Tanks
e) Check		
Overflow Rate	(h1 = 1.50 m, h2 = 8.50 m) 57,500 / 1,140 = 50.4 m ³ /m ² -d	36,000 / 780 = 47.4 m ³ /m ² -d
Retention Time	4,128 / 57,500 × 24 = 1.7 h	2,752 / 36,000 × 24 = 1.8 h
Sludge Generation	57,500 × 154 × 10 ⁻⁶ ÷ 0.01 = 886 m ³ (Solid Concentration 1%) = 74 m ³ /Tank	36,000 × 154 × 10 ⁻⁶ ÷ 0.01 = 554 m ³ (Solid Concentration 1%) = 69 m ³ /Tank
Sludge Storage Volume	$\frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 95 \text{ m}^3/\text{Tank}$ (h3 = 5.56 m, r1 = 0.50 m, r2 = 3.77 m)	$\frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 95 \text{ m}^3/\text{Tank}$ (h3 = 5.56 m, r1 = 0.50 m, r2 = 3.77 m)
Effective Volume	$V_1 = \frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 201 \text{ m}^3/\text{Tank}$ (h1 = 2.94 m, r2 = 3.77 m, r3 = 5.50 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 143 \text{ m}^3/\text{Tank}$ (h1 = 1.50 m, R = 11.00 m) V = V1 + V2 = 344 m ³ /Tank ΣV = V × Number of Tanks = 344 × 12 = 4,128 m ³	$V_1 = \frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 201 \text{ m}^3/\text{Tank}$ (h1 = 2.94 m, r2 = 3.77 m, r3 = 5.50 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 143 \text{ m}^3/\text{Tank}$ (h1 = 1.50 m, R = 11.00 m) V = V1 + V2 = 344 m ³ /Tank ΣV = V × Number of Tanks = 344 × 8 = 2,752 m ³

Table M-10 (3/16) Design Calculation for First Stage Project (Alternative 2 - South3 WWTP)
 a) Facilities for Pinula Collector

Item	Ultimate	First Stage
2. Trickling Filter		
1) First Step		
a) Required Capacity		
Design flowrate	57,500 m ³ /d	36,000 m ³ /d
BOD Loading	1.0 kg-BOD/m ² ·d	1.0 kg-BOD/m ² ·d
Influent BOD Load	$= 57,500 \times 182 \times 10^{-3} = 10,465 \text{ kg/d}$	$= 36,000 \times 182 \times 10^{-3} = 6,552 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{10,465}{1.0} = 10,465 \text{ m}^2$	$= \frac{6,552}{1.0} = 6,552 \text{ m}^2$
b) Dimensions		
Diameter	R = 34.00 m	R = 34.00 m
Depth	D = 2.00 m	D = 2.00 m
Number	12 Tanks	8 Tanks
c) Check		
Cross-Sectional Area	$= 17.00^2 \times \pi \times 12 = 10,895 \text{ m}^2$	$= 17.00^2 \times \pi \times 8 = 7,263 \text{ m}^2$
BOD Loading	$= \frac{10,465}{10,895} = 1.0 \text{ kg-BOD/m}^2\cdot\text{d}$	$= \frac{6,552}{7,263} = 0.9 \text{ kg-BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{57,500}{10,895} = 5.3 \text{ m/d}$	$= \frac{36,000}{7,263} = 5.0 \text{ m/d}$
2) Intermediate Clarifier	Intermediate clarifier is the same size as primary sedimentation tank.	Intermediate clarifier is the same size as primary sedimentation tank.
3) Second Step		
a) Required Capacity		
Design flowrate	57,500 m ³ /d	36,000 m ³ /d
BOD Loading	1.0 kg-BOD/m ² ·d	1.0 kg-BOD/m ² ·d
Influent BOD Load	$= 57,500 \times 91 \times 10^{-3} = 5,233 \text{ kg/d}$	$= 36,000 \times 91 \times 10^{-3} = 3,276 \text{ kg/d}$
Required Cross-Sectional Area	$= \frac{5,233}{1.0} = 5,233 \text{ m}^2$	$= \frac{3,276}{1.0} = 3,276 \text{ m}^2$
b) Dimensions		
Diameter	R = 34.00 m	R = 34.00 m
Depth	D = 2.00 m	D = 2.00 m
Number	6 Tanks	4 Tanks
c) Check		
Cross-Sectional Area	$= 17.00^2 \times \pi \times 6 = 5,448 \text{ m}^2$	$= 17.00^2 \times \pi \times 4 = 3,632 \text{ m}^2$
BOD Loading	$= \frac{5,233}{5,448} = 1.0 \text{ kg-BOD/m}^2\cdot\text{d}$	$= \frac{3,276}{3,632} = 0.9 \text{ kg-BOD/m}^2\cdot\text{d}$
Hydraulic Loading	$= \frac{57,500}{5,448} = 10.6 \text{ m/d}$	$= \frac{36,000}{3,632} = 9.9 \text{ m/d}$

Table M-10 (4/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 a) Facilities for Pinula Collector

Item	Ultimate	First Stage
3. Final Clarifier a) Required Capacity		
Design Flowrate	57,500 m ³ /d	36,000 m ³ /d
Overflow Rate	25.0 m ³ /m ² ·d	25.0 m ³ /m ² ·d
Retention Time	3.0 h	3.0 h
Required Surface Area	57,500 / 25.0 = 2,300 m ²	36,000 / 25.0 = 1,440 m ²
b) Dimensions		
Diameter	R = 11.00 m	R = 11.00 m
Depth	D = 10.00 m	D = 10.00 m
Angle	θ = 59.5°	θ = 59.5°
Number	24 Tanks	16 Tanks
(h1 = 1.50 m, h2 = 8.50 m)		(h1 = 1.50 m, h2 = 8.50 m)
c) Check		
Overflow Rate	57,500 / 2,281 = 25.2 m ³ /m ² ·d	36,000 / 1,521 = 23.7 m ³ /m ² ·d
Retention Time	9,504 / 57,500 × 24 = 4.0 h	6,336 / 36,000 × 24 = 4.2 h
Sludge Generation	57,500 × 70 × 10 ⁻⁶ + 0.01 = 403 m ³	36,000 × 70 × 10 ⁻⁶ + 0.01 = 252 m ³
(Solid Concentration 1%)		(Solid Concentration 1%)
Sludge Storage Volume	$\frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 44 \text{ m}^3/\text{Tank}$	$\frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 44 \text{ m}^3/\text{Tank}$
(h3 = 4.09 m, r1 = 0.50 m, r2 = 2.91 m)		(h3 = 4.09 m, r1 = 0.50 m, r2 = 2.91 m)
Effective Volume	$V1 = \frac{\pi \times h1}{3} (r2^2 + r2 \times r3 + r3^2) = 253 \text{ m}^3/\text{Tank}$	$V1 = \frac{\pi \times h1}{3} (r2^2 + r2 \times r3 + r3^2) = 253 \text{ m}^3/\text{Tank}$
(h1 = 4.41 m, r2 = 2.91 m, r3 = 5.50 m)		(h1 = 4.41 m, r2 = 2.91 m, r3 = 5.50 m)
	$V2 = \frac{\pi \times h1}{4} \times R^2 = 143 \text{ m}^3/\text{Tank}$	$V2 = \frac{\pi \times h1}{4} \times R^2 = 143 \text{ m}^3/\text{Tank}$
(h1 = 1.50 m, R = 11.00 m)		(h1 = 1.50 m, R = 11.00 m)
V = V1 + V2 = 396 m ³ /Tank		V = V1 + V2 = 396 m ³ /Tank
ΣV = V × Number of Tanks = 396 × 24 = 9,504 m ³		ΣV = V × Number of Tanks = 396 × 16 = 6,336 m ³

Table M-10 (S/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 a) Facilities for Pinula Collector


Item	Ultimate	First Stage
4) Sludge Digester Tank (Open Tank)		
a) Required Capacity	52,700 m ³ /d (Daily Average)	
Design Flowrate	47 days (Unheated Anaerobic Digestion)	
Retention Time	= Raw Sludge + Septage from Sanitation Facility	
Influent Solid Quantity	= $52,700 \times 280 \times 0.8 \times 10^{-6} + 0.02$	
	= $11.8 + 0.02 = 11.8 \text{ t/d}$	
Influent Sludge Volume	= $\frac{11.8}{0.06} + 0.3 = 197.0 \text{ m}^3/\text{d}$	
Required Volume	(Raw Sludge Concentration 6%) = $197.0 \times 47 = 9,259 \text{ m}^3$	
b) Dimensions	 <p>Diameter R = 15.50 m Depth D = 9.00 m Angle $\theta = 46^\circ$ Number 12 Tanks (h1 = 1.50 m, h2 = 7.50 m)</p>	
	$V1 = \frac{\pi \times h2}{3} (r1^2 + r1 \times r2 + r2^2) = 504 \text{ m}^3/\text{Tank}$ (h2 = 7.50 m, r1 = 0.50 m, r2 = 7.75 m)	
	$V2 = \frac{\pi \times h1}{4} \times R^2 = 283 \text{ m}^3/\text{Tank}$ (h1 = 1.50 m, R = 15.50 m)	
	V = V1 + V2 = 787 m ³ /Tank	
c) Check	$\Sigma V = V \times \text{Number of Tanks} = 787 \times 12 = 9,444 \text{ m}^3$	
Retention Time	= $\frac{9,444}{197} = 48 \text{ days}$	

Table M-10 (6/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 a) Facilities for Pinula Collector

Item	Ultimate	First Stage
5. Sludge Drying Bed		
a) Required Capacity		
Influent Solid Quantity	= Digested Solids = $11.8 \times (1 - (0.05 \times 0.5)) = 8.0 \text{ t/d}$ Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %	= Raw Sludge + Septage from Sanitation Facility = $33,000 \times 280 \times 0.8 \times 10^{-6} + 0.02$ = $7.4 + 0.02 = 7.4 \text{ t/d}$
Dried Sludge Quantity	$\frac{8.0}{0.4} = 20.0 \text{ t/d}$	$\frac{7.4}{0.4} = 18.5 \text{ t/d}$
Solids Loading	(Moisture Content of Dried Sludge: 60 %)	(Moisture Content of Dried Sludge: 60 %)
Required Area	$\frac{160 \text{ kg-SS/m}^2\text{-yr.}}{0.16} = 18,250 \text{ m}^2$	$\frac{160 \text{ kg-SS/m}^2\text{-yr.}}{0.16} = 16,881 \text{ m}^2$
b) Dimensions	Width 40.00 m Length 80.00 m Number 6 Tanks	Width 40.00 m Length 80.00 m Number 5 Tanks
c) Check		
Area	$40.00 \times 80.00 \times 6 = 19,200 \text{ m}^2$	$40.00 \times 80.00 \times 5 = 16,000 \text{ m}^2$
Solids Loading	$\frac{8.0}{19200} \times 365 \times 10^3 = 152.1 \text{ kg-SS/m}^2\text{-yr}$	$\frac{7.4}{16000} \times 365 \times 10^3 = 168.8 \text{ kg-SS/m}^2\text{-yr}$

Table M-10 (7/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 a) Facilities for Pinula Collector

Item	Ultimate	First Stage
6. Waste Stabilization Pond (for Supernatant Liquor) 1) Anaerobic Ponds a) Required Capacity Design Flowrate	= Supernatant Liquor from Digester Tank and Sludge Drying Bed = Influent Sludge Volume from Digester Tank + Digested Sludge Volume - Dried Sludge Volume (Digested Sludge Volume = Influent Sludge Volume for Sludge Drying Bed) $= \frac{8.0}{0.06} - 20 = 310 \text{ m}^3/\text{d}$	= Supernatant Liquor from Sludge Drying Bed = Influent Sludge Volume to Sludge Drying Bed - Dried Sludge Volume $= \frac{7.4}{0.06} + 0.3 - 18.5 = 105 \text{ m}^3/\text{d}$
Volumetric Loading Rate(BOD)	$= \frac{310}{20 \times 17} = 100 = 240 \text{ kg/m}^2/\text{d}$	$= \frac{105}{20 \times 17} = 100 = 240 \text{ kg/m}^2/\text{d}$
Water Quality (BOD)	$= 500 \text{ mg/L}$	$= 500 \text{ mg/L}$
Required Pond Volume	$= \frac{310}{240} = 646 \text{ m}^3$	$= \frac{105}{240} = 219 \text{ m}^3$
b) Dimensions	Cross-sectional Shape Bottom Area Surface Area Water Depth Side Slope Number Effective Volume Trapezoid 1m x 1m 19m x 19m D = 3.0 m 1:3 2 Ponds 381 m ³ /Pond (1 m ²) (361 m ²)	Cross-sectional Shape Bottom Area Surface Area Water Depth Side Slope Number Effective Volume Trapezoid 1m x 1m 19m x 19m D = 3.0 m 1:3 1 Ponds 381 m ³ /Pond (1 m ²) (361 m ²)
c) Check	$= \frac{381 \times 2}{646} = 1.2 \text{ days}$	$= \frac{381}{105} = 3.6 \text{ days}$
Retention Time	$= \frac{500 \times 646}{381 \times 2} = 424 \text{ kg/m}^2/\text{d}$	$= \frac{500 \times 105}{381} = 138 \text{ kg/m}^2/\text{d}$
Volumetric Loading Rate(BOD)	$= 2T + 20 = 2 \times 17 + 20 = 54 \%$	$= 2T + 20 = 2 \times 17 + 20 = 54 \%$
Effluent Quality(BOD) Removal Rate	$= (1 - 0.54) \times 500 = 230 \text{ mg/L}$	$= (1 - 0.54) \times 500 = 230 \text{ mg/L}$
Effluent Quality		

Table M-10 (8/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 a) Facilities for Pinula Collector

Item	Ultimate	First Stage
2) Calculative Ponds a) Required Capacity Design Flowrate	$= 310 \text{ m}^3/\text{d}$	$= 105 \text{ m}^3/\text{d}$
Surface Loading Rate(BOD)	$= 350 \times (1.107 - 0.002T)^{-1.25}$ $= 350 \times (1.107 - 0.002 \times 17)^{-1.25}$ $= 199 \text{ kg/ha/day}$	$= 350 \times (1.107 - 0.002T)^{-1.25}$ $= 350 \times (1.107 - 0.002 \times 17)^{-1.25}$ $= 199 \text{ kg/ha/day}$
Influent BOD Load	$= 310 \times 230 \times 10^{-3} = 71 \text{ kg/day}$	$= 105 \times 230 \times 10^{-3} = 24 \text{ kg/day}$
Required Surface Area	$= \frac{71}{199} = 0.36 \text{ ha} = 3,600 \text{ m}^2$	$= \frac{24}{199} = 0.12 \text{ ha} = 1,200 \text{ m}^2$
b) Dimensions	<p>Cross-sectional Shape Trapezoid Bottom Area $52\text{m} \times 26\text{m}$ (1,352 m^2) Surface Depth $64\text{m} \times 38\text{m}$ (2,432 m^2) Mid depth Area $58\text{m} \times 32\text{m}$ (1,856 m^2) Water Depth $D = 2.0 \text{ m}$ Side Slope 1:3 Number 2 Ponds Effective Volume 3,736 m^3/Pond</p>	<p>Cross-sectional Shape Trapezoid Bottom Area $52\text{m} \times 26\text{m}$ (1,352 m^2) Surface Depth $64\text{m} \times 38\text{m}$ (2,432 m^2) Mid depth Area $58\text{m} \times 32\text{m}$ (1,856 m^2) Water Depth $D = 2.0 \text{ m}$ Side Slope 1:3 Number 1 Ponds Effective Volume 3,736 m^3/Pond</p>
c) Check		
Retention Time	$= \frac{3,736 \times 2}{310} = 24.1 \text{ days}$	$= \frac{3,736}{105} = 35.6 \text{ days}$
Surface Loading Rate (at Mid depth)	$= \frac{71}{0.58 \times 0.32 \times 2} = 191 \text{ kg/ha/day}$	$= \frac{24}{0.58 \times 0.32} = 129 \text{ kg/ha/day}$
d) Effluent Quality (BOD)	$= \frac{230}{1 + 0.26 \times 24.1} = 31.7 \text{ mg/L}$	$= \frac{230}{1 + 0.26 \times 35.6} = 22.4 \text{ mg/L}$
	<p>WHERE $KT = 0.3 \times (1.05)^{T-20}$ $= 0.3 \times (1.05)^{17-20}$ $= 0.26$</p>	<p>WHERE $KT = 0.3 \times (1.05)^{T-20}$ $= 0.3 \times (1.05)^{17-20}$ $= 0.26$</p>

Table M-6 (9/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 b) Facilities for Hermosa Collector

Item	Ultimate	First Stage
Design Flowrate	Daily Average 13,500 m ³ /d Daily Maximum 14,500 m ³ /d Hourly Maximum 21,500 m ³ /d	
Treatment Process Flow Diagram	<p style="text-align: center;">*</p> <div style="border: 1px solid black; padding: 5px; width: fit-content; margin: 10px auto;"> <p>Legend</p> <ul style="list-style-type: none"> S G C - Screen-Crit Chamber P S T - Primary Sedimentation Tank T F (I) - Trickling Filter (First Step) I C - Intermediate Clarifier T F (II) - Trickling Filter (Second Step) F C - Final Clarifier S D T - Sludge Digester Tank S D B - Sludge Drying Bed A P - Anaerobic Pond F P - Facultative Pond </div> <p style="text-align: right;">* Primary Treated Excess Wet Weather Flow (X) Maximum Hourly Flow - (I) Maximum Hourly Flow</p>	

Table M-6 (10/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 b) Facilities for Hermost Collector

Item	Ultimate	First Stage
1. Primary Sedimentation Tank a) Required Capacity Design Flowrate Overflow Rate Retention Time	$14,500 \text{ m}^3/\text{d}$ (D.M.), $50.0 \text{ m}^3/\text{m}^2\cdot\text{d}$ 2.0 h (D.M.) D.M. II. M. R. F. : Hourly Maximum Wet Weather Flow	
Required Surface Area	$\frac{14,500}{50.0} = 290 \text{ m}^2$	
b) Dimensions	Diameter $R = 9.50 \text{ m}$ Depth $D = 0.00 \text{ m}$ Angle $\theta = 60.3^\circ$ Number 4 Tanks $(h1 = 1.50 \text{ m}, h2 = 7.50 \text{ m})$	
c) Check Overflow Rate	$\frac{14,500}{284} = 51.1 \text{ m}^3/\text{m}^2\cdot\text{d}$	
Retention Time	$\frac{856}{14,500} \times 24 = 1.4 \text{ h}$	
Sludge Generation	$14,500 \times 154 \times 10^{-6} \div 0.01 = 449 \text{ m}^3$ (Solid Concentration 1%)	
Sludge Storage Volume	$\frac{\pi \times h3}{3} (r1^2 + r1 \times r2 + r2^2) = 90 \text{ m}^3/\text{Tank}$ $(h3 = 5.56 \text{ m}, r1 = 0.50 \text{ m}, r2 = 3.65 \text{ m})$	
Effective Volume	$V1 = \frac{\pi \times h1}{3} (r2^2 + r2 \times r3 + r3^2) = 108 \text{ m}^3/\text{Tank}$ $(h1 = 1.94 \text{ m}, r2 = 3.65 \text{ m}, r3 = 4.75 \text{ m})$ $V2 = \frac{\pi \times h1}{4} \times R^2 = 106 \text{ m}^3/\text{Tank}$ $(h1 = 1.50 \text{ m}, R = 9.50 \text{ m})$ $V = V1 + V2 = 214 \text{ m}^3/\text{Tank}$ $\Sigma V = V \times \text{Number of Tanks} = 214 \times 4 = 856 \text{ m}^3$	




Table M-6 (11/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 b) Facilities for Hermosa Collector

Item	Ultimate	First Stage
2. Trickling Filter		
1) First Step		
a) Required Capacity		
Design Flowrate	14,500 m ³ /d	
BOD Loading	1.0 kg-BOD/m ² ·d	
Influent BOD Load	$= 14,500 \times 182 \times 10^{-3} = 2,639 \text{ kg/d}$	
Required Cross-Sectional Area	$= \frac{2,639}{1.0} = 2,639 \text{ m}^2$	
b) Dimensions		
Diameter	R = 29.00 m	
Depth	D = 2.00 m	
Number	4 Tanks	
c) Check Cross-Sectional Area	$= 14.50^2 \times \pi \times 4 = 2,642 \text{ m}^2$	
BOD Loading	$= \frac{2,639}{2,642} = 1.0 \text{ kg-BOD/m}^2\cdot\text{d}$	
Hydraulic Loading	$= \frac{14,500}{2,642} = 5.5 \text{ m/d}$	
2) Intermediate Clarifier	Intermediate clarifier is the same size as primary sedimentation tank.	
3) Second Step		
a) Required Capacity		
Design Flowrate	14,500 m ³ /d	
BOD Loading	1.0 kg-BOD/m ² ·d	
Influent BOD Load	$= 14,500 \times 91 \times 10^{-3} = 1,320 \text{ kg/d}$	
Required Cross-Sectional Area	$= \frac{1,320}{1.0} = 1,320 \text{ m}^2$	
b) Dimensions		
Diameter	R = 20.00 m	
Depth	D = 2.00 m	
Number	2 Tanks	
c) Check Cross-Sectional Area	$= 14.50^2 \times \pi \times 2 = 1,321 \text{ m}^2$	
BOD Loading	$= \frac{1,320}{1,321} = 1.0 \text{ kg-BOD/m}^2\cdot\text{d}$	
Hydraulic Loading	$= \frac{14,500}{1,321} = 11.0 \text{ m/d}$	

Table M-6 (12/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 b) Facilities for Hermosa Collector

Item	Ultimate	First Stage
3) Final Clarifier		
a) Required Capacity		
Design Flowrate	14,500 m ³ /d	
Overflow Rate	25.0 m ³ /m ² ·d	
Retention Time	3.0 h	
Required Surface Area	14,500 / 25.0 = 580 m ²	
b) Dimensions		
Diameter	R = 9.50 m	
Depth	D = 9.00 m	
Angle	θ = 60.5°	
Number	8 Tanks	
e) Check		
Overflow Rate	14,500 / 567 = 25.6 m ³ /m ² ·d	
Retention Time	2.104 / 14,500 × 24 = 3.5 h	
Sludge Generation	14,500 × 70 × 10 ⁻⁶ ÷ 0.01 = 102 m ³ (Solid Concentration 1%)	
Sludge Storage Volume	$= \frac{\pi \times h_3}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 41 \text{ m}^3/\text{Tank}$ (h ₃ = 4.09 m, r ₁ = 0.50 m, r ₂ = 2.82 m)	
Effective Volume	$V_1 = \frac{\pi \times h_1}{3} (r_2^2 + r_2 \times r_3 + r_3^2) = 157 \text{ m}^3/\text{Tank}$ (h ₁ = 3.41 m, r ₂ = 2.82 m, r ₃ = 4.75 m) $V_2 = \frac{\pi \times h_1}{4} \times R^2 = 106 \text{ m}^3/\text{Tank}$ (h ₁ = 1.50 m, R = 9.50 m) V = V ₁ + V ₂ = 263 m ³ /Tank Σ V = V × Number of Tanks = 263 × 8 = 2,104 m ³	




Table M-6 (13/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 b) Facilities for Hermonax Collector


Item	Ultimate	First Stage
4. Sludge Digester Tank (Open Tank)		
a) Required Capacity	13,300 m ³ /d (Daily Average)	
Design Flowrate	47 days (Unheated Anaerobic Digestion)	
Retention Time	= Raw Sludge	
Influent Solid Quantity	= 13,300 × 280 × 0.8 × 10 ⁻⁶	
	= 3.0 t/d	
	= 3.0	
Influent Sludge Volume	= 50.0 m ³ /d (Raw Sludge Concentration 0%)	
Required Volume	= 50.0 × 47 = 2,350 m ³	
b) Dimensions	 <p>Diameter R = 14.00 m Depth D = 8.00 m Angle θ = 45° Number 4 Tanks (h1 = 1.50 m, h2 = 6.50 m)</p>	
	$V_1 = \frac{\pi \times h_1}{3} (r_1^2 + r_1 \times r_2 + r_2^2) = 359 \text{ m}^3/\text{Tank}$ (h2 = 6.50 m, r1 = 0.50 m, r2 = 7.00 m)	
	$V_2 = \frac{\pi \times h_2}{4} \times R^2 = 231 \text{ m}^3/\text{Tank}$ (h1 = 1.50 m, R = 14.00 m)	
	V = V1 + V2 = 590 m ³ /Tank	
e) Check	Σ V = V × Number of Tanks = 590 × 4 = 2,360 m ³	
Retention Time	= 2,350 / 50 = 47 days	

Table M-6 (14/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 b) Facilities for Hermosa Collector

Item	Ultimate	First Stage
5. Sludge Drying Bed		
a) Required Capacity		
Influent Solid Quantity	$= \text{Digested Solids}$ $= 2.0 \times (1 - (0.65 \times 0.5)) = 2.0 \text{ t/d}$ <p style="text-align: center;">Volatile Solid Concentration of Raw Sludge : 65 % Volatile Solid Removal Rate : 50 %</p>	
Dried Sludge Quantity	$= \frac{2.0}{0.4} = 5.0 \text{ t/d}$ <p style="text-align: center;">(Moisture Content of Dried Sludge: 60 %)</p>	
Solids Loading	160 kg-SS/m ² -yr.	
Required Area	$= \frac{2.0 \times 365}{0.16} = 4,563 \text{ m}^2$	
b) Dimensions	Width 30.00 m Length 80.00 m Number 2 Tanks	
c) Check		
Area	$= 30.00 \times 80.00 \times 2 = 4,800 \text{ m}^2$	
Solids Loading	$= \frac{2.0}{4,800} \times 365 \times 10^3 = 152.1 \text{ kg-SS/m}^2\text{-yr}$	


Table M-6 (15/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 b) Facilities for Hermosa Collector

Item	Ultimate	Final Stage
6. Waste Stabilization Pond (for Supernatant Liquor) 1) Anaerobic Ponds a) Required Capacity Design Flowrate	$= \frac{2.0}{0.06} - 5 = 78 \text{ m}^3/\text{d}$ $= 20 \times 100 = 20 \times 17 = 100 = 240 \text{ g/m}^3/\text{d}$ <p> = Supernatant Liquor from Digester Tank and Sludge Drying Bed + Influent Sludge Volume from Digester Tank + Digested Sludge Volume - Dried Sludge Volume (Digested Sludge Volume = Influent Sludge Volume for Sludge Drying Bed) </p>	
Volumetric Loading Rate(BOD)	$= \frac{500 \text{ mg/L}}{240} = 2.08 \text{ g/m}^3/\text{d}$	
Water Quality (BOD)	$= 500 \text{ mg/L}$	
Required Pond Volume	$= \frac{500 \times 78}{2.08} = 183 \text{ m}^3$	
b) Dimensions	<p> Cross-sectional Shape Trapezoid Bottom Area 16×16 (1 m^2) Surface Depth $10 \text{ m} \times 10 \text{ m}$ (100 m^2) Water Depth $D = 3.0 \text{ m}$ Side Slope 1:3 Number 1 Ponds Effective Volume $381 \text{ m}^3/\text{Pond}$ </p>	
c) Check	$= \frac{381}{78} = 4.9 \text{ days}$	
Retention Time	$= \frac{381}{78} = 4.9 \text{ days}$	
Volumetric Loading Rate(BOD)	$= \frac{500 \times 78}{381} = 102 \text{ g/m}^3/\text{d}$	
d) Effluent Quality(BOD) Removal Rate	$= 2T + 20 = 2 \times 17 + 20 = 54 \%$	
Effluent Quality	$= (1 - 0.54) \times 500 = 230 \text{ mg/L}$	




Table M-6 (16/16) Design Calculation for First Stage Project (Alternative 2 : South3 WWTP)
 b) Facilities for Hermosa Collector

Item	Ultimate	First Stage
2) Facultative Ponds		
a) Required Capacity		
Design Flowrate	= 78 m ³ /d	
Surface Loading Rate(BOD)	= $350 \times (1.107 - 0.002T)^{-1.05}$ = $350 \times (1.107 - 0.002 \times 17)^{-1.05}$ = 199 kg/ha/day	
Influent BOD Load	= $78 \times 230 \times 10^{-3} = 18 \text{ kg/day}$	
Required Surface Area	= $\frac{18}{199} = 0.09 \text{ ha} = 900 \text{ m}^2$	
b) Dimensions	<p>Cross-sectional Shape Trapezoid</p> <p>Bottom Area 20m x 40m (800 m²)</p> <p>Surface Depth 32m x 52m (1,664 m²)</p> <p>Mid depth Area 26m x 46m (1,196 m²)</p> <p>Water Depth D = 2.0 m</p> <p>Side Slope 1:3</p> <p>Number 1 Ponds</p> <p>Effective Volume 2,416 m³/Pond</p>	
c) Check		
Retention Time	= $\frac{2,416}{78} = 31.0 \text{ days}$	
Surface Loading Rate (at Mid depth)	= $\frac{18}{0.26 \times 0.46} = 151 \text{ kg/ha/day}$	
d) Effluent Quality (BOD)	= $\frac{230}{1 + 0.26 \times 31.0} = 25.4 \text{ mg/L}$	
	<p>WHERE</p> <p>$KT = 0.3 \times (1.05)^{T-20}$ = $0.3 \times (1.05)^{17-20}$ = 0.26</p>	

LAYOUT PLAN FOR MASTER PLAN







Layout Plan for Master Plan (Central WWTP)



CAUTION: The Layout Plan shown above was prepared assuming uniformly sloping topography and rectangular site. The detailed topography and shape of the proposed treatment plant site is not known at this stage of planning. The actual layout shall be decided at a later stage to suit the selected site.

<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LAYOUT PLAN FOR MASTER PLAN (CENTRAL WWTP)</p>
---	---	--






Layout Plan for Master Plan (North1 WWTP, East1 WWTP)



CAUTION: The Layout Plan shown above was prepared assuming uniformly sloping topography and rectangular site. The detailed topography and shape of the proposed treatment plant site is not known at this stage of planning. The actual layout shall be decided at a later stage to suit the selected site.

<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LAYOUT PLAN FOR MASTER PLAN (NORTH1 WWTP, EAST1 WWTP)</p>
---	---	---


Layout Plan for Master Plan (South1 WWTP, South2 WWTP, South3 WWTP)




CAUTION: The Layout Plan shown above was prepared assuming uniformly sloping topography and rectangular site. The detailed topography and shape of the proposed treatment plant site is not known at this stage of planning. The actual layout shall be decided at a later stage to suit the selected site.

<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LAYOUT PLAN FOR MASTER PLAN (SOUTH1 WWTP, SOUTH2 WWTP, SOUTH3 WWTP)</p>
---	---	---

LAYOUT PLAN FOR FIRST STAGE




Layout Plan for First Stage Project (Alternative 1: Central WWTP)



: FIRST STAGE


<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p style="text-align: center;">LAYOUT PLAN FOR FIRST STAGE PROJECT (ALTERNATIVE 1: CENTRAL WWTP)</p>
---	---	---

Layout Plan of Wastewater Treatment Plant (Alternative 2: South3 WWTP)



EST.	P.O.	RUMBO	DIST.
6	7	S 47° 17' 00" W	89.76
7	8	S 68° 35' 20" W	164.32
8	BM	S 89° 54' 00" W	13.90

EST.	P.O.	RUMBO	DIST.
E-8	Central Axis G+900	N 21° 42' 00" W	5.94
Central Axis G+900	Central Axis G+715	S 21° 42' 00" E	715.00



1:4000

: FIRST STAGE

<p>THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <hr/> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE LAYOUT PLAN FOR FIRST STAGE PROJECT (ALTERNATIVE 2: SOUTH3 WWTP)</p>
--	---	--

SUPPORTING REPORT N
SANITATION SYSTEM

**SUPPORTING REPORT N
SANITATION SYSTEM**

TABLE OF CONTENTS

N1	GENERAL.....	N - 1
N2	SETTLEMENTS TO BE COVERED BY SANITATION SYSTEM.....	N - 1
N3	SANITATION COLLECTION SYSTEM.....	N - 12
N4	SANITATION TREATMENT SYSTEM.....	N - 43

LIST OF TABLES

Table N - 1	Settlements to be provided with Sanitation System	N - 2
Table N - 2	Length of Sewers Required for Each Settlement	N - 13
Table N - 3	Design Criteria of Septic Tank and Upflow Anaerobic Filter	N - 44
Table N - 4	Treated Water Quality from Sanitation Treatment System.....	N - 44
Table N - 5	Details of Community Treatment Plant	N - 45
Table N - 6	Design Calculation for Community Plant to Serve 1000 people.....	N - 46
Table N - 7	Quantity of Septage to be Desludged in the First Stage.....	N - 47

LIST OF FIGURES

Fig. N - 1	Location of Sanitation Area in Central Region	N - 3
Fig. N - 2	Location of Sanitation Area in South 3 Region	N - 10
Fig. N - 3	Main Sewer Network Plan for Bethania I.....	N - 15
Fig. N - 4	Profile of Main Sewer for Bethania I.....	N - 17
Fig. N - 5	Main Sewer Network Plan for Loma Blanca II	N - 21
Fig. N - 6	Profile of Main Sewer for Loma Blanca II	N - 23
Fig. N - 7	Main Sewer Network Plan for Scis de Octubure.....	N - 27
Fig. N - 8	Profile of Main Sewer for Scis de Octubure.....	N - 29
Fig. N - 9	Main Sewer Network Plan for Quintanal	N - 31
Fig. N - 10	Profile of Main Sewer for Quintanal	N - 33
Fig. N - 11	Main Sewer Network Plan for El Pilar.....	N - 37
Fig. N - 12	Profile of Main Sewer for El Pilar	N - 39
Fig. N - 13	Design Details of Community Treatment Plant for Bethania I.....	N - 49
Fig. N - 14	Design Details of Community Treatment Plant for Loma Blanca II	N - 51

Fig. N - 15 Design Details of Community Treatment Plant for Bethania II..... N - 53
Fig. N - 16 Design Details of Community Treatment Plant for Seis de Octubure N - 55
Fig. N - 17 Design Details of Community Treatment Plant for Quintanal N - 57

N SANITATION SYSTEM

N1 General

To improve environmental conditions in high risk and medium risk settlements as identified in UNICEF survey "Caracterization de Las Areas Precarias En La Ciudad De Guatemala (1991), wastewater generated should be collected and treated before discharging to river bodies. Most of these settlements lack drainage facilities and are located close to the ravine and have poor accessibility. Hence these settlements are difficult to connect to the proposed sewerage system and are considered to be covered by Sanitation System. Sanitation system consists of (1) a collection system to convey the wastewater from the community and (2) treatment and effluent disposal system.

Sanitation system of Central Region and South 3 Region are identified among the priority projects in Chapter 11. Further financial Evaluation showed that it is recommendable to cover sanitation system in second stage, however this chapter intends to give an idea of sanitation system of South 3 Region and Central Region (first stage).

N2 Settlements to be Covered by Sanitation System

Settlements which are proposed to be implemented in first stage of Central region project and second stage of south 3 region project are mentioned below in Table N - 1 and their location is shown in Fig. N - 1 (a-g) and Fig. N - 2 (a-b) respectively.

Population of these settlements have been adapted from UNICEF survey and future population in 2015 is assumed to be same as that of present population. Further it is important to comment that most of these settlements are slum or high risk areas and the above assumption holds good but some settlements have possibility of population expansion. Loma Blanca which is located in the suburbs of South 3 Region has lot of unutilized land in the settlement which will be occupied by houses in future. Hence sanitation system is designed for the population forecasted in the year 2015.

Also possibility of illegal invasion in slums can not be ruled out. For example it was reported in the Newspaper "Prensa Libre" dated 29 February 1996 that about 150 families invaded the settlement Incienso.

Table N - 1 Settlements to be Provided with Sanitation System


S. No.	Name of settlement	Zone	Population ^a	Estimated Area (ha) ^b
CENTRAL REGION				
1	Final	14	500	16
2	El Pilar	14	1,500	48
3	El Cambary	14	300	7
4	Campo Seco	16	1,200	6
5	Finca El Carmen	6	1,000	6
6	Modrno San Antonio	6	1,000	6
7	Jocotales	6	2,600	17
8	Quintanal	6	3,700	24
9	Santa Faz	6	600	4
10	El Tuerto	1	500	4
11	Colinas I y II	1	900	7
12	Bethania Sec I	1	1,400	11
13	Bethania Sec III	7	1,600	11
14	Bethania Sec IV	7	400	3
15	Seis de Octubre	7	1,500	10
16	Joya I	7	2,500	16
17	Joya II	7	2,500	16
18	Joya III	7	2,500	16
19	La Joya IV	7	1,500	10
20	Colon. Argueta	2	2,000	26
21	Incienso	3	4,200	19
	Total		33,900	283
SOUTH 3 REGION				
1	Loma Blanca I	12	900 ^c	9
2	Loma Blanca II	12	1000 ^c	9
3	Plaza de Toros	13	1,000	24
	Total		2900	42

^a Adapted from UNICEF Survey "Caracterizacion De Las Areas Precarias En La Ciudad De Guatemala", (1991) and population in the year 2015 is assumed to be same as that of present.

^b Estimated Area = (Population / Population Density of the respective Zone)


^c Population expansion is taken into account and is mentioned for the year 2015.

Fig. N - 1 (a)



Scale 1 : 15,000


Legend



Sanitation Area

<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LOCATION OF SANITATION AREA IN CENTRAL REGION</p>
---	---	---

Fig. N - 1 (b)



Scale 1 : 15,000


Legend



Sanitation Area

<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LOCATION OF SANITATION AREA IN CENTRAL REGION</p>
---	---	---

Fig. N - 1 (c)



Scale 1 : 15,000


Legend



Sanitation Area

<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LOCATION OF SANITATION AREA IN CENTRAL REGION</p>
---	---	---

Fig. N - 1 (d)



Scale 1 : 15,000

Legend



Sanitation Area

THE REPUBLIC OF GUATEMALA

GUATEMALA MUNICIPAL WATER
SUPPLY PUBLIC CORPORATION
(EMPAGUA)


THE STUDY ON
THE IMPROVEMENT OF WASTEWATER
MANAGEMENT IN THE GUATEMALA
METROPOLITAN AREA

JAPAN INTERNATIONAL COOPERATION AGENCY

TITLE

LOCATION OF SANITATION
AREA IN CENTRAL REGION

Fig. N - 1 (c)



Scale 1 : 15,000


Legend



Sanitation Area

<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LOCATION OF SANITATION AREA IN CENTRAL REGION</p>
---	---	---

Fig. N - 1 (f)



Scale 1 : 15,000

Legend



Sanitation Area

THE REPUBLIC OF GUATEMALA

GUATEMALA MUNICIPAL WATER
SUPPLY PUBLIC CORPORATION
(EMPAGUA)


THE STUDY ON
THE IMPROVEMENT OF WASTEWATER
MANAGEMENT IN THE GUATEMALA
METROPOLITAN AREA

JAPAN INTERNATIONAL COOPERATION AGENCY

TITLE

LOCATION OF SANITATION
AREA IN CENTRAL REGION

Fig. N - 1 (g)



Scale 1 : 15,000


Legend



Sanitation Area


<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LOCATION OF SANITATION AREA IN CENTRAL REGION</p>
---	---	---

Fig. N-2 (a)



Scale 1 : 15,000


Legend



Sanitation Area

<p>THE REPUBLIC OF GUATEMALA</p> <p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p> <p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE</p> <p>LOCATION OF SANITATION AREA IN SOUTH 3 REGION</p>
---	---	---

Fig. N - 2 (b)



Scale 1 : 15,000

Legend



Sanitation Area

<p>THE REPUBLIC OF GUATEMALA</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA</p>	<p>TITLE LOCATION OF SANITATION AREA IN SOUTH 3 REGION</p>
<p>GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>JAPAN INTERNATIONAL COOPERATION AGENCY</p>	

N3 Sanitation Collection System

A Conventional Gravity sewerage system is proposed for collecting and transporting the wastewater to the community sanitation treatment facility. The design criteria are briefly summarized below.

- Minimum cover between the top of the sewer and road surface should be one meter.
- Minimum diameter of sewer considered (excluding house connection) is 200mm.
- Minimum flow velocity allowed in the sewer is 0.6 m/sec.
- Maximum flow velocity allowed in the sewer is 3.0 m/sec.
- Manning equation is used to determine the sewer capacity.
- Manhole should be provided at each change in direction, change in grade and change in sewer diameter, and should not exceed the maximum spacing shown below:


Sewer diameter (mm)	Maximum Manhole Spacing (m)
300 or less	50
600 or less	80



Table N - 2 describes length of sewer required in each settlement for Central and South 3 Region. Most of the settlements require sewer even less than 200 mm, however in this report minimum diameter considered is 200 mm. Sewer network plan and profile of main sewer for the typical settlements are shown from Fig. N - 3 to Fig. N - 12.

Table N - 2 Length of Sewers Required for Each Settlement

S. No.	Name of Settlement	Zone	Dia of main Sewer (mm)	Length (Km)
CENTRAL REGION				
1	Final	14	200	3.7
2	El Pilar	14	200	11.1
3	El Cambary	14	200	1.7
4	Campo Seco	16	200	1.4
5	Finca El Carmen	6	200	1.5
6	Modrno San Antonio	6	200	1.5
7	Jocotales	6	200~250	3.8
8	Quintanal	6	200~300	5.5
9	Santa Faz	6	200	0.9
10	El Tuerto	1	200	0.9
11	Colinas I y II	1	200	1.6
12	Bethania Sec I	1	200	2.5
13	Bethania Sec II	7	200~250	3.0
14	Seis de Octubre	7	200	2.2
15	Joya I	7	200~250	3.8
16	Joya II	7	200~250	3.8
17	Joya III	7	200~250	3.8
18	La Joya IV	7	200	2.3
19	Colon. Argueta	2	200~250	5.9
20	Incienso	3	200~400	4.3
	Total			65.2
SOUTH 3 REGION				
1	Loma Blanca I	12	200	2.0
2	Loma Blanca II	12	200	2.0
5	Plaza de Toros	13	200	5.6
	Total			9.6


Note Bethania III and IV are considered as one community and is mentioned as Bethania II






Note : Sewer Diameter = 200 mm (unless otherwise specified) Scale 1 : 2000

Legend



<p>THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)</p>	<p>THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA JAPAN INTERNATIONAL COOPERATION AGENCY</p>	<p>TITLE MAIN SEWER NETWORK PLAN FOR BETHANIA I</p>
--	--	--

Bethania - I




THE REPUBLIC OF GUATEMALA
GUATEMALA MUNICIPAL WATER
SUPPLY PUBLIC CORPORATION
(EMPAGUA)


THE STUDY ON
THE IMPROVEMENT OF WASTEWATER
MANAGEMENT IN THE GUATEMALA
METROPOLITAN AREA
JAPAN INTERNATIONAL COOPERATION AGENCY

TITLE
PROFILE OF MAIN SEWER
FOR BETHANIA I

Bethania - I




THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)	THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA	TITLE PROFILE OF MAIN SEWER FOR BETHANIA I
	JAPAN INTERNATIONAL COOPERATION AGENCY	




Note : Sewer Diameter = 200 mm (unless otherwise specified) Scale 1 : 3000

Legend




THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)	THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA JAPAN INTERNATIONAL COOPERATION AGENCY	TITLE MAIN SEWER NETWORK PLAN FOR LOMA BLANCA II
--	---	---

Loma Blanca - II




THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)	THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA JAPAN INTERNATIONAL COOPERATION AGENCY	TITLE PROFILE OF MAIN SEWER FOR LOMA BLANCA II
--	---	---

Loma Blanca - II




THE REPUBLIC OF GUATEMALA
 GUATEMALA MUNICIPAL WATER
 SUPPLY PUBLIC CORPORATION
 (EMPAGUA)
 THE STUDY ON
 THE IMPROVEMENT OF WASTEWATER
 MANAGEMENT IN THE GUATEMALA
 METROPOLITAN AREA
 JAPAN INTERNATIONAL COOPERATION AGENCY

TITLE
**PROFILE OF MAIN SEWER
 FOR LOMA BLANCA II**



Note : Sewer Diameter = 200 mm (unless otherwise specified) Scale 1 : 1000




LOCATION MAP
Mapa de Localizacion

Legend

- Sewer line
- Slope (Length)


THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)	THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA JAPAN INTERNATIONAL COOPERATION AGENCY	TITLE MAIN SEWER NETWORK PLAN FOR SEIS DE OCTUBRE
--	---	--

Octubre



THE REPUBLIC OF GUATEMALA
 GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (ENPAGUA)
 THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA
 JAPAN INTERNATIONAL COOPERATION AGENCY


TITLE
PROFILE OF MAIN SEWER FOR SEIS DE OCTUBRE



Creek Quebrado
 Note : Sewer Diameter = 200 mm (unless otherwise specified) Scale 1 : 1000
 D1 to D4 sewer pipe has diameter of 250 mm.
 D-5 to D-11 sewer pipe has diameter of 300 mm.

Legend


- Sewer line
- Slope
- (Length)



LOCATION MAP
 Mape de Localizacion

THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)	THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA	TITLE MAIN SEWER NETWORK PLAN FOR QUINTANAL
	JAPAN INTERNATIONAL COOPERATION AGENCY	

Quintanal




THE REPUBLIC OF GUATEMALA
GUATEMALA MUNICIPAL WATER
SUPPLY PUBLIC CORPORATION
(EMPAGUA)

THE STUDY ON
THE IMPROVEMENT OF WASTEWATER
MANAGEMENT IN THE GUATEMALA
METROPOLITAN AREA
JAPAN INTERNATIONAL COOPERATION AGENCY



TITLE
PROFILE OF MAIN SEWER
FOR QUINTANAL

Quintanal



Sewer Line No.	D-12	D-13	D-14	D-15	D-16	D-17	D-18
V=1/200 Dia. (mm)	200	200	200	200	200	200	200
H=1/1500 Slope (%)	30	30	30	30	30	30	30
Length (m)	16.69	15.00	42.88	48.05	40.35	15.51	24.57
Ground Elevation (m)	1461.58	1458.05	1454.87	1453.97	1451.34	1450.45	1450.92
Earth Cover (m)	4.27	1.24	1.01	1.40	1.71	2.03	2.97
Invert Elevation (m)	1457.08	1456.58 1454.08	1453.63	1452.34 1450.84	1449.40	1448.19	1447.72
Cu. Length (m)	0.00	16.69	31.69	74.57	122.62	162.97	178.48
							203.43

THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)	THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA JAPAN INTERNATIONAL COOPERATION AGENCY	TITLE PROFILE OF MAIN SEWER FOR QUINTANAL
--	---	---



LOCATION MAP
Mapa de Localizacion


Note : Sewer Diameter = 200 mm (unless otherwise specified) Scale 1 : 1000

Legend

- Sewer line
- Slope (Length)

THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)	THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA JAPAN INTERNATIONAL COOPERATION AGENCY	TITLE MAIN SEWER NETWORK PLAN FOR EL PILAR
--	--	--

El Pilar




THE REPUBLIC OF GUATEMALA
GUATEMALA MUNICIPAL WATER
SUPPLY PUBLIC CORPORATION
(EMPAGUA)

THE STUDY ON
THE IMPROVEMENT OF WASTEWATER
MANAGEMENT IN THE GUATEMALA
METROPOLITAN AREA
JAPAN INTERNATIONAL COOPERATION AGENCY

TITLE
PROFILE OF MAIN SEWER
FOR EL PILAR

El Pilar



THE REPUBLIC OF GUATEMALA GUATEMALA MUNICIPAL WATER SUPPLY PUBLIC CORPORATION (EMPAGUA)	THE STUDY ON THE IMPROVEMENT OF WASTEWATER MANAGEMENT IN THE GUATEMALA METROPOLITAN AREA	TITLE PROFILE OF MAIN SEWER FOR EL PILAR
	JAPAN INTERNATIONAL COOPERATION AGENCY	

N4 Sanitation Treatment System

a) Treatment Process

The wastewater collected from the settlement is proposed to be treated at community plant. The sanitation treatment system consist of treatment and effluent disposal system. In Master plan following two alternatives were described:

- Septic tank followed by soil absorption well
- Septic tank with upflow anaerobic filter and effluent to be discharged to the river.

At present soil absorption system is being used for disposal of septic tank effluent in the study area, however in future most of the area is basically to be covered by sewerage system and settlements to be covered by sanitation system are located on the steep slope and are closer to the valley. Limited area is available for the treatment site in these settlements. Most of the settlements have river nearby.

Further soil percolation test conducted at five locations showed that soil is predominantly clay/clayey silt. And as the proposed septic tank system is closed to the valley, possibility of underground channel of porous materials can not be ruled out as found in Bethania II. (Ref. Supporting Report III for more details)

Based on the above site conditions, treatment system consisting of septic tank with upflow filter and effluent discharged to the river is preferred. By treating septic tank effluent through upflow anaerobic filter and then discharging into the river, possibility of contamination of ground water can be avoided. However for settlement Final and El Pilar, where Pinula river is used for domestic purposes at the downstream, septic tank effluent is proposed to be disposed by means of soil absorption system.

b) Design Criteria

Design criteria of sanitation treatment system are summarized below in the Table N - 3.

Table N -3 Design Criteria of Septic Tank and Upflow Anaerobic Filter

Facility	Item	Unit	Design Range	Applied
Septic Tank	Detention Time (Start up)	days	3	3
	Sludge accumulation rate	l/c/d	30-40	40
	Max.. sludge accumulation allowed before desludging		1/2-1/3 of tank	1/3 of tank
	Length : Width		2-3 : 1	2 : 1
	Clearance above liquid level	m	0.2-0.4	0.4
Upflow Anaerobic Filter	Detention time	hrs	6-8	8
	Max.. hydraulic loading	m ³ /d/m ²	3.4	1.7
	Max.. height	m	0.9-1.5	1.2

References :

- Appropriate Technology for Water Supply and Sanitation : A Planner's Guide, World Bank 1980.
- Sewage Treatment in Hot Climates, Duncan Mara, (1976)
- Wastewater Engineering; Treatment, Disposal and Reuse, Metcalf & Eddy, Third Edition, (1991)
- Anaerobic Wastewater treatment-Attached growth and sludge Blanket Process, ENSIC, AIT (1986)
- Design Criteria Development of RBC and Anaerobic Filter system for Sewage Treatment, AIT (1983)

c) Treated Water Quality

Treated water Quality from sanitation treatment system is described below in the Table N - 4.

Table N - 4 Treated Water Quality from Sanitation Treatment System

Parameter	Removal Rate	Influent (mg/l)	Effluent (mg/l)
BOD5	75 %	330	83
SS	75 %	330	83

d) Design Details of Treatment System

Table N - 5 shows details of community plants for Central and South 3 Region. Design calculations for the community plant to serve 1000 people are shown in Table N -6 and details for typical settlements of Central and South 3 Region are shown from Fig. N - 13 to Fig. N - 17.

Table N - 5 Details of Community Treatment Plant

No	Name of Settlement	Zone	Daily Maximum Flowrate m ³ /d	Septic Tank (LxWxD) m	Upflow Filter (LxWxD) m
CENTRAL REGION					
1	Final	14	90	17.0x8.5x2.0	-
2	El Pilar	14	270	28.0x14.5x2.0	-
3	El Cambaro	14	60	13.0x7.0x2.0	5.5x7.0x1.2
4	Campo Seco	16	220	25.5x13.0x2.0	10.5x13.0x1.2
5	Finca El Carmen	6	180	23.5x11.5x2.0	10.0x11.5x1.2
6	Modrno San Antonio	6	180	23.5x11.5x2.0	10.0x11.5x1.2
7	Jocotales	6	470	37.5x19.0x2.0	15.5x19.0x1.2
8	Quintanal	6	670	45.0x22.5x2.0	18.5x22.5x1.2
9	Santa Faz	6	110	18.5x9.0x2.0	7.5x9.0x1.2
10	El Tuerto	1	90	17.0x8.5x2.0	6.5x8.5x1.2
11	Colinas I y II	1	170	22.0x11.5x2.0	9.5x11.5x1.2
12	Bethania Sec I	1	260	28.0x14.0x2.0	11.5x14.0x1.2
13	Bethania Sec II	7	360	33.0x16.5x2.0	13.5x16.5x1.2
14	Seis de Octubre	7	270	28.0x14.5x2.0	11.5x14.5x1.2
15	Joya I	7	450	36.5x18.5x2.0	15.0x18.5x1.2
16	Joya II	7	450	36.5x18.5x2.0	15.0x18.5x1.2
17	Joya III	7	450	36.5x18.5x2.0	15.0x18.5x1.2
18	La Joya IV	7	270	28.0x14.5x2.0	11.5x14.5x1.2
19	Colon. Argueta	2	360	33.0x16.5x2.0	13.5x16.5x1.2
20	Incienso	3	760	47.5x24.0x2.0	20.0x24.0x1.2
SOUTH 3 REGION					
1	Loma Blanca I	12	170	22.0x11.5x2.0	9.5x11.5x1.2
2	Loma Blanca II	12	180	23.5x11.5x2.0	10.0x11.5x1.2
3	Plaza de Toros	13	180	23.5x11.5x2.0	10.0x11.5x1.2

Note 1. Bethania III and IV are considered as one community and is mentioned as Bethania II.

Note 2. Effective dimensions of septic tank and upflow filter are mentioned above.

Note 3. LxWxD = Length x Width x Depth

Table N - 6 Design Calculations for Community plant to serve 1000 people

Item	Calculation
Design Flowrate	Daily Average 165 lpcd = 165 m ³ /day Daily Maximum 180 lpcd = 180 m ³ /day
1. Septic tank	
A) Required Capacity	
Design flowrate	180 m ³ /day
Detention time	3 days
Effective Tank Volume	540 m ³
B) Check for sludge accumulation	
Sludge accumulation rate	0.04 m ³ /capita/year
Frequency of desludging (including factor of safety)	3 years
Sludge accumulation	120 m ³
Volume reserved for sludge accumulation	1/3 of tank Volume = 180 m ³
C) Dimensions	
Depth	2.0m
Area	270 m ²
length : Width	2 : 1
length	23.5 m
Width	11.5 m
2. Upflow Filter	
A) Required Capacity	
Filter media (void ratio)	20 - 25 mm broken stones (0.45)
Detention time	8 hrs
Design flow	180 m ³ /day
Required void volume	60 m ³
Required filter volume	134 m ³
B) Dimensions	
Depth	1.2 m
Area	112 m ²
Width	11.5 m
length	10.0 m
C) Check for Hydraulic loading.	
Hydraulic loading to the filter	1.61 m ³ /m ² /d
Recommended Hydraulic loading	1.7 m ³ /m ² /d

e) Septage Treatment

It is proposed that septage be treated at the sludge treatment facility of the wastewater treatment plant to be constructed in the respective region. The quantity of septage is calculated based on a sludge accumulation rate of 0.04 m³/capita/year. The quantity of

septage to be desludged from each settlement in Central region and South 3 region are described below in the Table N - 7.

Table N -7 Quantity of Septage to be Desludged in the First Stage

S. No.	Name of Settlement	Zone	Septage to be desludged (m ³ /year)
CENTRAL REGION			
1	Final	14	20
2	El Pilar	14	60
3	El Cambary	14	12
4	Campo Seco	16	48
5	Finca El Carmen	6	40
6	Modrno San Antonio	6	40
7	Jocotales	6	104
8	Quintanal	6	148
9	Santa Faz	6	24
10	El Tuerto	1	20
11	Colinas I y II	1	36
12	Bethania Sec I	1	56
13	Bethania Sec II	7	80
14	Seis de Octubre	7	60
15	Joya I	7	100
16	Joya II	7	100
17	Joya III	7	100
18	La Joya IV	7	60
19	Colon. Argueta	2	80
20	Incienso	3	168
	Total		1,356
SOUTH 3 REGION			
1	Loma Blanca I	12	36
2	Loma Blanca II	12	40
3	Plaza de Toros	13	40
	Total		116

