

## TABLE



TABLE-1 WATER QUALITY OF EXISTING WELL

Description	Unit	Syrian Standard	Jarajir	Harasta	Urbin	Yabroud	Qara	Ruheibe	Dier Atiya	Nabek	Domair	Qodsaya
Collection Date			95.08.27	95.03.19	95.03.07	95.04.03	95.08.27	95.08.27	95.08.27	95.02.18	95.10.24	95.02.18
Test Date			95.08.28	95.03.19	95.03.07	95.04.03	95.08.28	95.08.28	95.08.28	95.02.18	95.10.24	95.02.18
Turbidity	NTU	5.00	0.90	1.80	1.60	0.40	1.90	1.20	3.40	1.40	0.60	1.50
Electro Conductivity	µs/cm		335.00	877.00	952.00	580.00	532.00	822.00	718.00	765.00	1,506.20	1,512.00
P H		6.5~8.5	7.40	7.96	7.53	8.05	7.90	7.90	8.10	7.90	6.95	7.79
Total Dissolved Solids	mg/l	1,000.00	193.00	440.00	477.00	291.00	265.00	412.00	360.00	383.00	927.05	
NH4+	mg/l	0.05	0.03	0.00	0.00	0.03	0.01	0.06	0.13	0.03	0.02	0.00
Na+	mg/l	200.00	6.21	11.96	38.41	2.30	9.20	5.98	44.16	28.75	100.05	87.17
K+	mg/l		1.00	3.00	1.75	0.50	4.75	1.50	0.50	2.75		3.25
Ca++	mg/l		60.00	112.00	128.00	96.00	48.00	100.00	104.00	96.00	156.00	140.00
Mg++	mg/l		56.30	36.48	34.05	17.02	24.32	34.05	12.16	36.48	56.09	53.50
Fet++	mg/l		0.03	0.02	0.01	0.02	0.02	0.04	0.29	0.01	0.12	0.05
Total Positive Ion	mg/l		124.07	163.16	202.22	115.87	86.30	141.63	161.24	164.02	312.28	283.97
F-	mg/l	0.70	0.10	0.14	0.18	0.30	0.20	0.60	0.29	0.50	1.08	
Cl-	mg/l	250.00	14.20	49.70	49.70	28.40	14.20	42.60	48.70	42.60	347.90	142.00
SO4--	mg/l	250.00	7.00	42.00	30.00	7.00	8.00	65.00	65.00	85.00	125.00	200.00
CO3--	mg/l		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HCO3-	mg/l		256.20	300.40	438.00	305.00	244.00	329.40	317.20	366.00	244.00	390.40
NO3-	mg/l	40.00	7.07	30.94	53.04	19.90	19.89	7.07	10.61	7.51	18.56	41.99
NO2-	mg/l	0.01	0.00	0.03	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00
PO4---	mg/l		1.26	0.50	0.38	0.80	0.78	0.49	1.19	0.21	0.23	0.90
Total Negative Ion	mg/l		285.85	513.71	621.30	361.40	287.07	444.56	443.70	501.33	736.77	775.29
Total Salt	mg/l		409.90	677.17	823.52	477.27	373.37	586.19	604.94	665.35	1,049.05	1,059.26
Hardness	mg/l	500.00	230.00	430.00	460.00	310.00	220.00	390.00	310.00	390.00	620.00	570.00
CO2	mg/l		7.30	4.40	4.40	4.40	4.40	4.40	4.40	8.80	8.80	8.80
Hg	mg/l	0.001	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.
Pb	mg/l	0.010	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.
Cd	mg/l	0.005	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.
Cr	mg/l	0.050	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.
Colon Bacillus	/100NL	0.00	40.00	24.00	36.00	Nil	N.A.	N.A.	Negative	Negative	N.A.	N.A.
Total Bacillus	/100NL	200 or 2000colon	Layer of colonies	Layer of colonies	Layer of colonies	3colonies	N.A.	N.A.	Negative	Negative	N.A.	N.A.

TABLE-2 WATER QUALITY OF PROPOSED WELL

Description	Unit	Syrian Standard	Jarajir	Harastia	Yabroud		Qara	Rubeibe	Dier Atiyeh	Nabek		Domair		Qodsaya		
					Coraine	Basalain				(1)	(2)	(1)	(2)	(1)	(2)	
																(1)
Collection Date			94	95.03.19	95.04.03	94	94.06.22	94	95.03.29	95.02.20	95.03.18	95.08.27	94.07.09	95.02.18	94.13	94
Test Date			94	95.03.19	95.04.03	94	94.06.23	94	95.03.29	95.02.21	95.03.18	95.08.28	94.07.09	95.02.18	93.04.13	94
Turbidity	NTU	5.00	0.00	2.00	0.40	0.50	1.90	1.00	1.00	1.00	1.40	0.60	1.60	1.00	3.50	
Electro Conductivity	µs/cm		663.00	663.00	580.00	593.00	265.80	662.00	518.00	660.00	765.00	691.00	551.00	667.00	186.00	884.00
P H		6.5~8.5	8.02	8.22	8.05		8.58	8.03	7.90	8.02	7.90	7.20	7.89	8.02	7.70	7.15
Total Dissolved Solids	mg/l	1,000.00	330.00	323.00	291.00	297.00	196.51	331.00	260.00	330.00	383.00	349.00	372.87	334.00	166.66	441.00
NH4+	mg/l	0.05	0.00	0.00	0.03	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00	0.00	0.00	0.05
Na+	mg/l	200.00	6.44	7.59	2.30	22.77	9.89	6.42	23.69	6.44	28.75	28.75	3.22	6.44	2.30	24.61
K+	mg/l		4.00	3.00	0.50	0.50	3.00	4.00	0.50	9.00	2.75	0.50	15.50	4.00		
Ca++	mg/l		72.00	80.00	96.00	80.00	52.00	70.00	72.00	72.00	96.00	112.00	68.00	72.00	36.00	72.00
Mg++	mg/l		41.30	29.18	17.02	24.32	7.30	41.20	7.30	41.34	36.48	24.32	38.91	41.34	17.07	17.02
Fett+	mg/l		0.03	0.01	0.02	0.01	0.02	0.02	0.01	0.04	0.01	0.02	0.02	0.04	0.01	0.18
Total Positive Ion	mg/l		123.77	119.78	115.87	127.60	72.21	121.64	103.50	128.82	164.02	165.59	125.65	123.82	55.38	113.86
F-	mg/l	0.70		0.28	0.30	0.32			0.30		0.50	0.33	0.52		0.30	0.36
Cl-	mg/l	250.00	28.40	28.40	28.40	14.20	7.10	28.20	28.40	28.40	42.60	35.50	28.40	28.40	3.55	14.20
SO4---	mg/l	250.00	70.00	50.00	7.00	10.00	9.50	69.00	9.50	70.00	85.00	62.00	53.00	70.00	5.00	15.00
CO3---	mg/l		0.00	0.00	0.00	0.00	3.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HCO3-	mg/l		310.00	292.80	305.00	366.00	183.00	309.00	244.00	305.00	366.00	390.40	305.00	305.00	170.80	317.20
NO3-	mg/l	40.00	6.50	9.23	15.90	22.10	12.82	6.40	13.26	6.60	7.51	8.40	12.38	6.60	16.79	8.80
NO2-	mg/l	0.01	0.00	0.01	0.00	0.01	0.00	0.00	0.01	0.00	0.01	0.00	0.02	0.00	0.00	0.06
PO4---	mg/l		0.60	0.61	0.80	0.30	0.38	0.50	0.36	0.65	0.21	0.54	0.40	0.65	0.24	0.69
Total Negative Ion	mg/l		415.50	381.38	361.40	412.93	215.80	413.10	295.53	410.65	501.33	497.17	399.72	410.65	196.68	356.31
Total Salt	mg/l		539.27	501.16	477.27	540.53	288.01	524.74	399.03	539.47	665.35	662.76	525.37	534.47	252.06	470.17
Hardness	mg/l	500.00	350.00	320.00	310.00	300.00	150.00	300.00	210.00	400.00	390.00	360.00	330.00	350.00	160.00	250.00
CO2	mg/l		4.20	2.20	4.40	4.40	0.00	4.00	4.40	4.30	3.80	4.40	4.40	4.40	4.40	4.40
Hg	mg/l	0.001	0.00087	0.00043	N.A.	N.A.	0.00040	0.00066	0.00049	0.00055	0.00045	N.A.	0.00095	N.A.	0.00064	N.A.
Pb	mg/l	0.010	0.00012	0.00052	N.A.	N.A.	0.00150	0.00037	0.00009	0.00089	0.00060	N.A.	0.00003	N.A.	0.00036	N.A.
Cd	mg/l	0.005	0.00023	0.00002	N.A.	N.A.	0.00008	0.00062	0.00007	0.00039	0.00003	N.A.	0.00060	N.A.	0.00006	N.A.
Cr	mg/l	0.050	0.00021	0.00038	N.A.	N.A.	0.00170	0.00049	0.00026	0.00001	0.00010	N.A.	0.00030	N.A.	0.00012	N.A.
Colon Bacillus	/100ML	0.00	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.
Total Bacillus	/100ML	2000 or	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.

TABLE-3 GUIDELINES FOR DRINKING WATER QUALITY

(Syrian Standard No.45 (Ameded) and WHO Guidline)

Description	Unit	Syrian Standard	WHO Guidline
Colour	TCU	Below 5	Below 15
Taste		Shuld be acceptable	Shuld be acceptable
Odour		Shuld be acceptable	Shuld be acceptable
Turbidity	NTU	2	Below 5
PH		6.5~8.5	-
Total Disolved Soids (TDS)			
	mg/l	1,000	1,000
Hardness	mg/l	500	
NO2-	mg/l	0.01	3
NO3-	mg/l	N<10, NO3-<40	50
PO4---	mg/l		
F-	mg/l	1.5	1.5
Cl-	mg/l	250	250
SO4--	mg/l	250	
Fe	mg/l	0.3	0.3
Mn	mg/l	0.1	0.5
Cu	mg/l	1.0	1.0
Pb	mg/l	0.01	0.01
Zn	mg/l	2.0	3.0
Hg	mg/l	0.001	0.001
Cr	mg/l	0.05	0.05
Cd	mg/l	0.005	0.003
NH4+	mg/l	0.05	
Na+	mg/l	200	200

NOTE; TCU : True Colour Unit

NTU : Nephelometric Turbidity Unit

WHO : Guidline : 1993

TABLE-4 YEARLY DESIGN POPULATION AND DESIGN DEMAND

DESCRIPTION	UNIT	HARASTA		HARASTA		AVERAGE DAILY DEMAND	JARAJIR	YABROUD	QARA	RUHEIBE	DIER ATIYA	NABEK	DOMAIR	QODSAYA	TOTAL OR AVERAGE
		HARASTA	URBIN	HARASTA	TOTAL										
DESIGN DAILY DEMAND	l/man·day	200	200	200	200	-	110~125	110~125	110~125	110~125	110~125	110~125	110~125	200	-
GROWTH RATE	%	4.00	4.00	4.00	4.00	-	3.35	3.35	3.35	3.35	3.35	3.35	3.35	4.00	-
DESIGN POPULATION	Person	70,192	40,945	111,137		-	3,928	51,241	17,500	25,099	24,201	43,562	27,598	N.A.	192,129
	Person	88,815	51,808	140,624		-	4,787	62,443	21,326	30,586	29,491	53,085	33,631	N.A.	235,348
	Person	108,057	63,033	171,090		-	5,644	73,626	25,145	36,064	34,774	62,593	39,655	N.A.	277,500
	Person	131,468	76,689	208,158		-	6,655	86,813	29,649	42,523	41,002	73,803	46,757	N.A.	327,201
	Person	159,951	93,304	253,255		-	7,847	102,362	34,959	50,139	48,345	87,022	55,131	N.A.	385,805
DESIGN DEMAND	m <sup>3</sup> /D	14,038	8,189	22,227		110	432	5,637	1,925	2,761	2,662	4,792	3,036	N.A.	43,472
	m <sup>3</sup> /D	17,763	10,362	28,125		110	527	6,869	2,346	3,364	3,244	5,839	3,699	N.A.	54,013
	m <sup>3</sup> /D	21,611	12,607	34,218		115	649	8,467	2,892	4,147	3,999	7,198	4,560	N.A.	66,131
	m <sup>3</sup> /D	26,294	15,338	41,632		120	799	10,418	3,558	5,103	4,920	8,856	5,611	N.A.	80,896
	m <sup>3</sup> /D	31,990	18,661	50,651		125	981	12,795	4,370	6,257	6,043	10,878	6,891	N.A.	98,877

TABLE-5 EXISTING CONSUMPTION AND ESTIMATED POPULATION

Project Description	Unit	Jarajir		Harasta		Yabroud	Qara	Ruheibe	Dier Atiya	Nabek	Domair	Qodsaya	Total or Average
		Harasta	Urbin	Harasta	Urbin								
Population in 1994	P	3,928	40,945	70,192	17,500	25,099	24,201	43,562	27,598	(159,000)	304,266		
Consumption in 1994	m3/Y	146,000	1,218,000	3,000,000	603,000	796,000	625,000	1,392,000	964,000	N.A	10,044,000		
Daily Consumption	m3/D	400	3,337	8,219	1,652	2,181	1,712	3,814	2,641	N.A	27,518		
M/D Consumption in 1994	l/M/D	102	81	70	94	87	71	88	96	N.A	90		
Seasonal Consumption in 1994													
1st season (J.F.W)	m3	15,000	25,000	60,000	105,000	125,000	100,000	250,000	175,000		1,370,000		
Effectiveness	%	42	33	82	78	54	65	73	74		76		
2nd season (A.M.J)	m3	40,000	350,000	700,000	160,000	221,000	150,000	392,000	250,000		2,563,000		
Effectiveness	%	110	115	94	93	111	96	113	104		102		
3rd season (J.A.S)	m3	71,000	368,000	1,000,000	228,000	300,000	250,000	450,000	339,000		3,506,000		
Effectiveness	%	193	120	132	153	150	159	128	140		138		
4th season (O.N.D)	m3	20,000	250,000	700,000	110,000	150,000	125,000	300,000	200,000		2,105,000		
Effectiveness	%	54	81	93	76	75	79	86	82		83		
Total	m3/Y	146,000	1,218,000	3,000,000	603,000	796,000	625,000	1,392,000	964,000		10,044,000		
Daily Average Consumption	M3/D	400	3,337	8,219	1,652	2,181	1,712	3,814	2,641		27,518		
Estimated Population													
1981	P	N.A	N.A	N.A	7,484	N.A	N.A	N.A	N.A	N.A	N.A	N.A	
1990	P	3,450	35,000	60,000	10,063	22,000	N.A	N.A	N.A	N.A	N.A	N.A	
1991	P	3,564	36,400	62,400	10,405	22,737	N.A	N.A	25,000	N.A	N.A	N.A	
1992	P	3,681	37,856	64,896	10,753	23,499	N.A	N.A	25,338	N.A	N.A	N.A	
1993	P	3,803	39,370	67,492	11,114	24,286	N.A	N.A	26,703	N.A	N.A	N.A	
1994	P	3,928	40,945	70,192	11,486	25,099	N.A	43,562	27,598	159,000	457,252		

TABLE-6 DESIGN WATER VOLUME

PROJECT: HARASTA

DESCRIPTION	YEAR	1994	2000	2005	2010	2015	REMARKS
GROWTH RATE (A) R=4.00%	man	111,137	140,624	171,090	208,158	253,255	
DESIGN POPULATION							
DESIGN MAN/DAY CONSUMPTION	1/M/D	200	200	200	200	200	
DESIGN AVERAGE							
DAILY CONSUMPTION	m <sup>3</sup> /D	22,227	28,125	34,218	41,632	50,651	
DESIGN MAXIMUM							
DAILY CONSUMPTION	m <sup>3</sup> /D	33,341	42,187	51,327	62,447	75,977	
DESIGN TOTAL DEMAND EXISTING WELL	m <sup>3</sup> /H	1,389	1,758	2,139	2,602	3,166	
CAPACITY	m <sup>3</sup> /H	1,205	1,205	1,205	1,205	1,205	700 + 505
DESIGN DEMAND	m <sup>3</sup> /H	184	553	934	1,397	1,961	
DESIGN WELL CAPACITY	m <sup>3</sup> /H	600	600	600	600	600	120 x 5
DEFERENCE	m <sup>3</sup> /H	416	47	-334	-797	-1,361	
DESIGN SUPPLY WATER VOLUME	m <sup>3</sup> /H	184	553	600	600	600	
MAXIMUM YEAR	YEAR		2000.62				

Note: MAXIMUM YEAR is the year to reach maximum demand by proposed facilities.



TABLE-7 DESIGN WATER VOLUME

PROJECT: JARAJIR

DESCRIPTION	YEAR	1994	2000	2005	2010	2015	REMARKS
GROWTH RATE (A) R=3.35%	man	3,928	4,787	5,644	6,655	7,847	
DESIGN POPULATION							
DESIGN MAN/DAY CONSUMPTION	l/M/D	110	110	115	120	125	
DESIGN DAILY CONSUMPTION	m <sup>3</sup> /D	432	527	649	799	981	
DESIGN MAXIMUM DAILY CONSUMPTION	m <sup>3</sup> /D	648	790	974	1,198	1,471	
DESIGN TOTAL DEMAND EXISTING WELL CAPACITY	m <sup>3</sup> /H	27	33	41	50	61	
	m <sup>3</sup> /H	0	0	0	0	0	
DESIGN DEMAND DESIGN WELL CAPACITY	m <sup>3</sup> /H	27	33	41	50	61	
	50x1 Case	50	50	50	50	50	50 x 1
DEFERENCE DESIGN SUPPLY WATER VOLUME	m <sup>3</sup> /H	23	17	9	0	-11	
	m <sup>3</sup> /H	27	33	41	50	50	
MAXIMUM YEAR	YEAR				2010		
DESIGN WELL CAPACITY	m <sup>3</sup> /H	50x2 Case 100	100	100	100	100	50 x 2
DEFERENCE DESIGN SUPPLY WATER VOLUME	m <sup>3</sup> /H	73	67	59	50	39	
	m <sup>3</sup> /H	27	33	41	50	61	
MAXIMUM YEAR	YEAR					2015	

Note: MAXIMUM YEAR is the year to reach maximum demand by proposed facilities.

TABLE-8 DESIGN WATER VOLUME

PROJECT: YABROUD

DESCRIPTION	YEAR	1994	2000	2005	2010	2015	REMARKS
GROWTH RATE (A)R=3.35%	man	51,241	62,443	73,626	86,813	102,362	
DESIGN POPULATION							
DESIGN MAX/DAY CONSUMPTION	l/M/D	110	110	115	120	125	
DESIGN AVERAGE							
DAILY CONSUMPTION	① = A x B m <sup>3</sup> /D	5,637	6,869	8,467	10,418	12,795	
DESIGN MAXIMUM							
DAILY CONSUMPTION	② = 1.5 x ① m <sup>3</sup> /D	8,455	10,303	12,701	15,626	19,193	
	③ = ① / 16						
DESIGN TOTAL DEMAND	③ = ② / 24 m <sup>3</sup> /H	352	429	529	651	800	
EXISTING WELL		120	120	120	120	120	60 x 2
CAPACITY	④ m <sup>3</sup> /H	180	180	180	180	180	45 x 4
DESIGN DEMAND	⑤ = ③ - ④ m <sup>3</sup> /H	52	129	229	351	500	
DESIGN WELL							Asalain
CAPACITY	⑥ m <sup>3</sup> /H	200	200	200	200	200	100 x 2
DEFERENCE	⑦ = ⑥ - ⑤ m <sup>3</sup> /H	148	71	-29	-151	-300	
DESIGN SUPPLY							
WATER VOLUME	⑧ = ⑤ or ⑥ m <sup>3</sup> /H	52	129	200	200	200	
MAXIMUM YEAR	⑨ YEAR		2004				

Note: MAXIMUM YEAR is the year to reach maximum demand by proposed facilities.

TABLE-9 DESIGN WATER VOLUME

PROJECT: QARA

DESCRIPTION	YEAR	1994	2000	2005	2010	2015	REMARKS
GROWTH RATE							
DESIGN POPULATION	man	17,500	21,326	25,145	29,649	34,959	
DESIGN MAX/DAY CONSUMPTION	l/M/D	110	110	115	120	125	
DESIGN AVERAGE DAILY CONSUMPTION	m <sup>3</sup> /D	1,925	2,346	2,892	3,558	4,370	
DESIGN MAXIMUM DAILY CONSUMPTION	m <sup>3</sup> /D	2,888	3,519	4,338	5,337	6,555	
DESIGN TOTAL DEMAND EXISTING WELL CAPACITY	m <sup>3</sup> /H	120	147	181	222	273	
DESIGN DEMAND	m <sup>3</sup> /H	16	16	16	16	16	7 x 1 + 9 x 1
DESIGNING WELL CAPACITY	m <sup>3</sup> /H	104	131	165	206	257	
DEFERENCE	m <sup>3</sup> /H	135	135	135	135	135	50 x 2 + 35 x 1
DESIGN SUPPLY WATER VOLUME	m <sup>3</sup> /H	31	4	-30	-71	-122	
MAXIMUM YEAR	YEAR		2000.47				

Note: MAXIMUM YEAR is the year to reach maximum demand by proposed facilities.

TABLE-10 DESIGN WATER VOLUME

PROJECT: RUHEIBE

DESCRIPTION	YEAR	1994	2000	2005	2010	2015	REMARKS
GROWTH RATE (A) R=3.35%	MAN	25,099	30,586	36,064	42,523	50,139	
DESIGN POPULATION CONSUMPTION (B)	l/M/D	110	110	115	120	125	
DESIGN AVERAGE DAILY CONSUMPTION ① = A x B	m <sup>3</sup> /D	2,761	3,364	4,147	5,103	6,267	
DESIGN MAXIMUM DAILY CONSUMPTION ② = 1.5 x ①	m <sup>3</sup> /D	4,141	5,047	6,221	7,654	9,401	
DESIGN TOTAL DEMAND EXISTING WELL CAPACITY ③ = ① / 16 ④ = ② / 24	m <sup>3</sup> /H	173	210	259	319	392	50 + 7 + 17 + 15 + 16
DESIGN DEMAND DESIGN WELL CAPACITY ⑤ = ③ - ④	m <sup>3</sup> /H	105	105	105	105	105	
DEFERENCE DESIGN SUPPLY WATER VOLUME ⑥	m <sup>3</sup> /H	180	180	180	180	180	45 x 4
⑦ = ⑥ - ⑤	m <sup>3</sup> /H	112	75	26	-34	-107	
⑧ = ⑤ or ⑥	m <sup>3</sup> /H	68	105	154	180	180	
⑨	YEAR			2007.17			

Note: MAXIMUM YEAR is the year to reach maximum demand by proposed facilities.

TABLE-11 DESIGN WATER VOLUME

PROJECT: DIER ATIYA

DESCRIPTION	YEAR	1994	2000	2005	2010	2015	REMARKS
GROWTH RATE (A) R=3.35%	man	24,201	29,491	34,774	41,002	48,345	
DESIGN POPULATION							
DESIGN MAN/DAY CONSUMPTION	l/M/D	110	110	115	120	125	
DESIGN AVERAGE							
DAILY CONSUMPTION	m <sup>3</sup> /D	2,662	3,244	3,999	4,920	6,043	
DESIGN MAXIMUM							
DAILY CONSUMPTION	m <sup>3</sup> /D	3,993	4,866	5,998	7,380	9,065	
DESIGN TOTAL DEMAND	m <sup>3</sup> /H	166	203	250	308	378	
EXISTING WELL CAPACITY	m <sup>3</sup> /H	147	147	147	147	147	35 x 1 + 15 x 1 + (35 + 20 + 42) x 1
DESIGN WATER VOLUME	m <sup>3</sup> /H	19	56	103	161	231	
DESIGN WELL CAPACITY	m <sup>3</sup> /H	45	45	45	45	45	45 x 1
DEFERENCE	m <sup>3</sup> /H	26	-11	-58	-116	-186	
DESIGN SUPPLY WATER VOLUME	m <sup>3</sup> /H	-	-	-	-	-	By existing pipe
MAXIMUM YEAR	YEAR	1998					

Note: MAXIMUM YEAR is the year to reach maximum demand by proposed facilities.

TABLE-12 DESIGN WATER VOLUME

PROJECT: NABEK

DESCRIPTION	YEAR	1994	2000	2005	2010	2015	REMARKS
GROWTH RATE: (A) R=3.35%	A	43,562	53,085	62,593	73,803	87,022	
DESIGN MAN/DAY CONSUMPTION (B)	l/M/D	110	110	115	120	125	
DESIGN AVERAGE DAILY CONSUMPTION	① = A x B m <sup>3</sup> /D	4,792	5,839	7,198	8,856	10,878	
DESIGN MAXIMUM DAILY CONSUMPTION	② = 1.5 x ① m <sup>3</sup> /D	7,188	8,759	10,797	13,285	16,317	
DESIGN TOTAL DEMAND EXISTING WELL	③ = ① / 16 m <sup>3</sup> /H	299	365	450	554	680	
CAPACITY	④	115	115	115	115	115	50 x 2 + 15 x 1
DESIGN DEMAND	⑤ = ③ - ④ m <sup>3</sup> /H	184	250	335	439	565	
DESIGN WELL CAPACITY	⑥	220	220	220	220	220	55 x 4
DEFERENCE	⑦ = ⑥ - ⑤ m <sup>3</sup> /H	36	-30	-115	-219	-345	
DESIGN SUPPLY WATER VOLUME	⑧ = ⑤ or ⑥ m <sup>3</sup> /H	-	-	-	-	-	By existing pipe.
MAXIMUM YEAR	⑨	1997					

Note: MAXIMUM YEAR is the year to reach maximum demand by proposed facilities.

TABLE-13 DESIGN WATER VOLUME

PROJECT: DOMAIR

DESCRIPTION	YEAR	1994	2000	2005	2010	2015	REMARKS
GROWTH RATE (A) R=3.35%	MAN	27,598	33,631	39,655	46,757	55,131	
DESIGN POPULATION							
DESIGN MAN/DAY CONSUMPTION	l/M/D	110	110	115	120	125	
DESIGN AVERAGE							
DAILY CONSUMPTION	m <sup>3</sup> /D	3,036	3,699	4,560	5,611	6,891	
DESIGN MAXIMUM							
DAILY CONSUMPTION	m <sup>3</sup> /D	4,554	5,549	6,840	8,416	10,337	
DESIGN TOTAL DEMAND EXISTING WELL	m <sup>3</sup> /H	190	231	285	351	431	
CAPACITY	m <sup>3</sup> /H	30	30	30	30	30	15 x 2
DESIGN DEMAND	m <sup>3</sup> /H	160	201	255	321	401	
DESIGN WELL							
CAPACITY	m <sup>3</sup> /H	200	200	200	200	200	100 x 2
DEFERENCE	m <sup>3</sup> /H	40	-1	-55	-121	-201	
DESIGN SUPPLY							
WATER VOLUME	m <sup>3</sup> /H	-	-	-	-	-	By existing pipe.
MAXIMUM YEAR	YEAR	1999.85					

Note: MAXIMUM YEAR is the year to reach maximum demand by proposed facilities.

TABLE-14 TEST RECORD OF WELL

Description	Unit	Jarajir	Harasta	Yabroud	Qara	Ruheibe	Dier Attiya	Nabek	Domair	Qodsaya
Date		93.08.10	93.09.05	92.05.12	93.10.02	95.09.20	92.	93.08.25	93.10.15	
Test capacity	m <sup>3</sup> /D	50.00	90.00	59.00	50.00	60.00	45.00	55.00	94.00	N. A.
Depth of well	m	370.00		257.00	325.00		320.00	400.00		
Depth of pump	m	180.00	110.00		270.00	260.00	240.00	364.00	125.00	
Pump Output	Hp	60.00	120.00		90.00	100.00	50.00	120.00	70.00	
① Initial WL	GL-(m)	171.00	85.00	23.30	260.00	180.00	180.00	320.00	90.80	
② Balance WL	GL-(m)	172.00	85.91	25.95	263.01	240.10	220.00	340.00	104.37	
③ Draw down WL	(②-①)m	1.00	0.91	2.65	3.01	60.10	40.00	20.00	13.57	
④ Initial Time	ti Hr	8.00	8.00		8.00	8.00	6.00	6.00	6.00	
⑤ Balanced Time	tb Hr	52.00	58.00		46.00	44.00	30.00	60.00	72.00	
⑥ Draw down Time	(⑤-④)Hr	44.00	50.00		38.00	36.00	24.00	54.00	66.00	
⑦ Recovery WL	GL-(m)	171.00	85.00		260.00	180.00	180.00	320.00	90.80	
⑧ Operation Hour	tp Hr	70.00	70.00		70.00	36.00	72.00	72.00	72.00	
⑨ W.L Recovery Time	tr Hr	75.00	72.00		84.00	46.00	84.00	77.00	75.00	
⑩ Recovery Time	(⑨-⑧)Hr	5.00	2.00		14.00	10.00	12.00	5.00	3.00	
⑪ Unit Capacity	m <sup>2</sup> /hr	50.00	98.90	22.30	16.60	1.00	1.13	2.75	6.93	



TABLE-15 DESIGN DIAMETER OF PIPE, WELL CAPACITY AND PUMP UNIT

Description	Unit	Jarajir	Harasta			Yabroud	Qara	Ruheibe	Dier Atiya	Nabek	Domair	
			Upstream	Harasta	Urbin						Upstream	Downstream
Target Year		33	553	410	142	129	131	105	56(45)	250(220)	200	200
Discharge	l / s	9.2	153.6	113.9	39.7	35.8	36.4	29.2	-	-	55.6	55.6
Design Diameter	mm	125	400	350	200	200	200	200	-	-	300	250
Velocity	m/s	0.75	1.22	1.18	1.26	1.14	1.16	0.93	-	-	0.79	1.13
Hydraulic Slope	m/Km	5.84	3.73	4.10	8.92	7.38	7.59	5.04	-	-	2.30	5.60
Length	Km	7.100	5.475	1.620	2.839	2.000	11.350	2.300	-	-	19.000	3.480
Loss Head	m	41.48	20.40	27.05	45.74	14.75	85.13	11.59	-	-	43.78	19.49
Dynamic Head	m	186	(77)	59	72	44	490	102	-	-	50	-72
Judgement:	-	OK	OK	OK	OK	OK	OK	OK	-	-	OK	-
Request Diameter	mm	150	500	400	250	250	250	250	-	-	300	300
Design Capacity	m <sup>3</sup> /hr	33	553	-	-	180	131	105	56(45)	250(220)	200	200
Requested Pump		50 x	(120 x)			45 x	50 x 2 +	45 x	45 x	55 x	(100 x)	
Capacity X Set No.	m <sup>3</sup> /hr x S	2	(5)	-	-	4	35 x 1	4	1	4	(2)	-
Designed Pump		33 x	(110 x)			45 x	50 x 2 +	35 x	45 x	55 x	(100 x)	
Capacity X Set No.	m <sup>3</sup> /hr x S	1	(5)	-	-	4	31 x 1	3	1	4	(2)	-


TABLE-16 PUMP DIMENSION FOR PROPOSED WELL

Description	Unit	Jarajir	Harasta	Yabroud	Qara	Ruheibe	Dier Atia	Nabek	Domair
Design Capacity	m <sup>3</sup> /時	33	110	45	50	31	35	45	55
	m <sup>3</sup> /分	0.55	1.83	0.75	0.83	0.52	0.58	0.75	0.92
Pump Size	mm	80	125	100	100	80	100	100	100
Length	m	185.00	115.00	65.00	270.00	270.00	265.00	245.00	355.00
Velocity	m/s	1.82	2.49	1.59	1.77	1.71	1.93	1.59	1.95
Hydraulic Slope	m/m	0.05134	0.05418	0.03074	0.03735	0.04573	0.03724	0.03074	0.04456
Loss Head	m	9.50	6.23	2.00	10.09	12.35	15.17	7.53	15.82
Pipe Size	mm	125	200	150	150	125	150	150	150
Length	m	50.00	150.00	50.00	50.00	50.00	250.00	50.00	50.00
Velocity	m/s	0.75	0.97	0.71	0.79	0.70	0.55	0.71	0.86
Hydraulic Slope	m/m	0.00584	0.00549	0.00427	0.00519	0.00520	0.00268	0.00427	0.00619
Loss Head	m	0.29	0.82	0.21	0.26	0.26	0.67	0.21	0.31
Total Loss Head	m	9.79	7.05	2.21	10.34	12.61	15.84	7.74	16.13
Well W.L	m	172	86	172	265	265	245	220	340
Outlet W.L	m	5	50	5	5	5	5	5	5
Actual Depth	m	177	136	177	270	270	250	225	345
Total Depth	m	187	143	179	280	283	266	233	361
Mortor Capacity	KW	30	75	37	75	45	45	55	90

**FIGURE**



FIGURE-1 DISCHARGE AND PIPE DIAMETER



PIPE DIAMETER - ALLOWABLE VELOCITY

PIPE d (mm)	WA Criteria			MOA Criteria		WA Criteria			MOA Criteria	
	V1 (m/s)	V1Min (m/s)	V1Max (m/s)	V2Min (m/s)	V2Max (m/s)	Q1 (l/s)	Q1Min (l/s)	Q1Max (l/s)	Q2Min (l/s)	Q2Max (l/s)
75	0.570	-	0.595	0.700	1.000	2.52		4.67	3.00	4.00
100	0.620	0.595	0.640	0.700	1.000	4.88	4.67	7.85	5.00	8.00
125	0.660	0.640	0.680	0.700	1.000	8.14	7.85	12.02	9.00	12.00
150	0.700	0.680	0.730	0.700	1.000	12.37	12.02	22.93	12.00	18.00
200	0.760	0.730	0.785	0.900	1.600	23.94	22.93	38.53	28.00	50.00
250	0.810	0.785	0.835	0.900	1.600	39.96	38.53	59.02	44.00	78.00
300	0.860	0.835	0.880	0.900	1.600	60.79	59.02	84.67	64.00	113.00
350	0.900	0.880	0.920	0.900	1.600	86.59	84.67	115.61	87.00	154.00
400	0.940	0.920	0.955	0.900	1.600	117.62	115.61	151.89	113.00	201.00
450	0.970	0.955	0.985	1.200	1.800	154.11	151.89	193.40	191.00	286.00
500	1.000	0.985	1.030	1.200	1.800	196.35	193.40	291.23	235.00	353.00
600	1.060	1.030		1.200	1.800	298.29	291.23		339.00	509.00

NOTE WA Criteria: Allowable velocity by Water Facility Criteria in Japan  
 MOA Criteria: Allowable velocity by Ministry of Agriculture in Japan

FIGURE - 2 ORGANIZATION CHART OF THE MINISTRY OF HOUSING AND UTILITIES




FIGURE - 3 ORGANIZATION CHART OF THE ESTABLISHMENT OF DRINKING WATER AND SEWERAGE IN RURAL PROVINCE OF DAMASCUS




FIGURE - 4 PROJECT EXECUTING ORGANIZATION











FIGURE-6 LOCATION MAP OF THE PROJECT






## **DRAWINGS**

# GENERAL PLAN

## CONTENTS OF PROCUREMENT



<b>Jarajir</b>		
- Ductile Iron Pipe	ø150mm	7,597 m
- Submersible Pump	(33m <sup>3</sup> /h, 177m)	1 unit
- Diesel Generator	(150KVA)	1 unit
<b>Harasta</b>		
- Ductile Iron Pipe	ø200mm	3,038 m
- Ductile Iron Pipe	ø350mm	1,734 m
- Ductile Iron Pipe	ø400mm	5,859 m
- Submersible Pump	(110m <sup>3</sup> /h, 136m)	5 unit
- Diesel Generator	(600KVA)	1 unit
<b>Yabroud</b>		
- Ductile Iron Pipe	ø150mm	749 m
- Ductile Iron Pipe	ø200mm	2,140 m
- Submersible Pump	(45m <sup>3</sup> /h, 177m)	4 unit
<b>Qara</b>		
- Ductile Iron Pipe	ø200mm	12,145 m
- Submersible Pump	(50m <sup>3</sup> /h, 270m)	2 unit
- Submersible Pump	(31m <sup>3</sup> /h, 270m)	1 unit
- Diesel Generator	(440KVA)	1 unit
- Transformer	(400KVA)	1 unit
<b>Ruheibe</b>		
- Ductile Iron Pipe	ø150mm	214 m
- Ductile Iron Pipe	ø200mm	2,782 m
- Submersible Pump	(35m <sup>3</sup> /h, 250m)	3 unit
- Diesel Generator	(280KVA)	1 unit
<b>Domair</b>		
- Ductile Iron Pipe	ø250mm	3,724 m
- Ductile Iron Pipe	ø300mm	20,330 m
<b>Dier Atiya</b>		
- Submersible Pump	(45m <sup>3</sup> /h, 225m)	1 unit
- Diesel Generator	(280KVA)	1 unit
<b>Nabek</b>		
- Submersible Pump	(55m <sup>3</sup> /h, 345m)	4 unit
- Diesel Generator	(640KVA)	1 unit
And other procurement for hole project are:		
4WD Pick up		2 unit
Spar parts		1 lot

LEGEND	
●	WELL
■	DERIVERY TANK
—	PROPOSED PIPELINE
- - - -	EXISTING PIPELINE


THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS


GENERAL PLAN

DRW. NO.



1

JAPAN INTERNATIONAL COOPERATION AGENCY






NEW WELL



DL + 274.00






DIP 1:150 K = 8


PRESENT CONDITION	PIPE SPECIFICATIONS	
	PIPE CENTER	HYDRALIC ELEVATION
GROUND ELEVATION	274.00	274.00
ACCUMULATED DISTANCE	0	0
DISTANCE	0	0
NUMBERAGE	0	0
ALIGNMENT		

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS

<b>JARAJIR PROJECT</b>	DRW. NO.
<b>PLAN &amp; PROFILE (1/3)</b>	2
JAPAN INTERNATIONAL COOPERATION AGENCY	



DL = 114.00




PRESENT CONDITION	PIPE SPECIFICATIONS	
	PIPE CENTER	HYDRALIC ELEVATION
GROUND ELEVATION	158.85	158.48
ACCUMULATED DISTANCE	0	0
DISTANCE	50	50
NUMBERAGE	102.30	102.30
ALIGNMENT		



THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS

<b>JARAJIR PROJECT</b> <b>PLAN &amp; PROFILE (2/3)</b>	DRW. NO. <b>3</b>
JAPAN INTERNATIONAL COOPERATION AGENCY	





Jarajir Town  
GROUND RESERVOIR  
V = 300 M<sup>3</sup>




1:200

DL = 90.00

		DIP @ 150m K=9	
PLAN	PIPE SPECIFICATIONS		
	HYDRALIC ELEVATION	102.70	102.70
PRESENT CONDITION	PIPE CENTER	102.00	102.70
	GROUND ELEVATION	102.00	102.70
	ACCUMULATED DISTANCE	0.000	102.70
	DISTANCE	50	102.70
	NUMBERAGE	102.00	102.70
	ALIGNMENT		

THE SYRIAN ARAB REPUBLIC THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN RURAL PROVINCE OF DAMASCUS	
JARAJIR PROJECT PLAN & PROFILE (3/3)	DRW. NO. 4
JAPAN INTERNATIONAL COOPERATION AGENCY	



1:3000  
1:200

DL = 104.00

PLAN		PIPE SPECIFICATIONS	
		D.P. 440mm X=9	
PRESENT CONDITION	HYDRAULIC ELEVATION		
	PIPE CENTER	143.88	143.88
	GROUND ELEVATION	113.00	113.00
	ACCUMULATED DISTANCE	0	0
	DISTANCE	0	0
	NUMBERAGE	NO. 0	NO. 0
	ALIGNMENT	IP 1	IP 18


THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS

**HARASTA PROJECT**  
**PLAN & PROFILE (1/4)**

JAPAN INTERNATIONAL COOPERATION AGENCY

DRW. NO.  
**5**








PLAN	PIPE SPECIFICATIONS	DIP 1200mm K=9																					
		HYDRALIC ELEVATION	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	71.400	
PRESENT CONDITION	PIPE CENTER	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14	87.14		
	GROUND ELEVATION	88.27	88.35	88.43	88.51	88.59	88.67	88.75	88.83	88.91	88.99	89.07	89.15	89.23	89.31	89.39	89.47	89.55	89.63	89.71	89.79		
	ACCUMULATED DISTANCE	0.00	40.00	80.00	120.00	160.00	200.00	240.00	280.00	320.00	360.00	400.00	440.00	480.00	520.00	560.00	600.00	640.00	680.00	720.00	760.00	800.00	
	DISTANCE	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	
	NUMBERAGE	NO. 60	NO. 61	NO. 62	NO. 63	NO. 64	NO. 65	NO. 66	NO. 67	NO. 68	NO. 69	NO. 70	NO. 71	NO. 72	NO. 73	NO. 74	NO. 75	NO. 76	NO. 77	NO. 78	NO. 79	NO. 80	
	ALIGNMENT		IP 32 12'30"	IP 33 35'00"	IP 34 49'00"	IP 35 52'00"																	

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS

HARASTA PROJECT PLAN & PROFILE (3/4)	DRW. NO.  7
JAPAN INTERNATIONAL COOPERATION AGENCY	





DL = 10.00

PLAN	PIPE SPECIFICATIONS	DIP 1:200m K=3	
	HYDRALIC ELEVATION	+10.00	
PRESENT CONDITION	PIPE CENTER	46.48	46.48
	GROUND ELEVATION	50.84	50.34
	ACCUMULATED DISTANCE	0	18
	DISTANCE	0	18
	NUMBERAGE	0	18
	ALIGNMENT	17+1	17+18
		17+2	17+3
		17+4	17+5
		17+6	17+7
		17+8	17+9
		17+10	17+11
		17+12	17+13
		17+14	17+15
		17+16	17+17
		17+18	17+19
		17+20	17+21
		17+22	17+23
		17+24	17+25
		17+26	17+27
		17+28	17+29
		17+30	17+31
		17+32	17+33
		17+34	17+35
		17+36	17+37
		17+38	17+39
		17+40	17+41
		17+42	17+43
		17+44	17+45
		17+46	17+47
		17+48	17+49
		17+50	17+51
		17+52	17+53
		17+54	17+55
		17+56	17+57
		17+58	17+59
		17+60	17+61
		17+62	17+63
		17+64	17+65
		17+66	17+67
		17+68	17+69
		17+70	17+71
		17+72	17+73
		17+74	17+75
		17+76	17+77
		17+78	17+79
		17+80	17+81
		17+82	17+83
		17+84	17+85
		17+86	17+87
		17+88	17+89
		17+90	17+91
		17+92	17+93
		17+94	17+95
		17+96	17+97
		17+98	17+99
		17+100	17+101



THE SYRIAN ARAB REPUBLIC  
 THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
 RURAL PROVINCE OF DAMASCUS

**YABUROUD**  
 PLAN & PROFILE (1/1)


DRW. NO.  
 9

JAPAN INTERNATIONAL COOPERATION AGENCY

GROUND RESERVOIR  
V=500M<sup>3</sup>



DL=960.00



DIP #200M K=3


PLAN	PIPE SPECIFICATIONS	
	HYDRALIC ELEVATION	PIPE CENTER
PRESENT CONDITION	GROUND ELEVATION	ACCUMULATED DISTANCE
	DISTANCE	NUMBERAGE
	ALIGNMENT	

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS


**QARA PROJECT  
PLAN & PROFILE (1/4)**

DRW. NO.  
**10**

JAPAN INTERNATIONAL COOPERATION AGENCY



CL = 784.00




PRESENT CONDITION	PLAN	
	PIPE SPECIFICATIONS	HYDRALIC ELEVATION
GROUND ELEVATION	PIPE CENTER	HYDRALIC ELEVATION
ACCUMULATED DISTANCE		
DISTANCE		
NUMBERAGE		
ALIGNMENT		

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS


<b>QARA PROJECT</b>	DRW. NO.
<b>PLAN &amp; PROFILE (2/4)</b>	11

JAPAN INTERNATIONAL COOPERATION AGENCY





DL=664.00



DIP 1:200 K=0


PLAN	PIPE SPECIFICATIONS	DIP 1:200 K=0																											
	HYDRALIC ELEVATION	[Hydraulic Elevation Data]																											
PRESENT CONDITION	PIPE CENTER	[Pipe Center Data]																											
	GROUND ELEVATION	[Ground Elevation Data]																											
	ACCUMULATED DISTANCE	[Accumulated Distance Data]																											
	DISTANCE	[Distance Data]																											
	NUMBERAGE	[Numberage Data]																											
	ALIGNMENT	[Alignment Data]																											
		30	40	50	60	70	80	90	100	110	120	130	140	150	160	170	180	190	200	210	220	230	240	250	260	270	280	290	300

THE SYRIAN ARAB REPUBLIC  
 THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
 RURAL PROVINCE OF DAMASCUS


**QARA PROJECT**  
**PLAN & PROFILE (3/4)**

DRW. NO.  
 12

JAPAN INTERNATIONAL COOPERATION AGENCY



DL = 53400





PLAN	PIPE SPECIFICATIONS	
	OIP 2008 K 9	
HYDRALIC ELEVATION	[Elevation values]	
PIPE CENTER	[Elevation values]	
GROUND ELEVATION	[Elevation values]	
ACCUMULATED DISTANCE	[Distance values]	
DISTANCE	[Distance values]	
NUMBERAGE	[Number values]	
ALIGNMENT	[Alignment values]	

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS


QARA PROJECT PLAN & PROFILE (4/4)	DRW. NO. 13
JAPAN INTERNATIONAL COOPERATION AGENCY	



GROUND RESERVOIR V = 2000 M<sup>3</sup>  
UNIFIED PROJECT  
OF AORA



DL = 157.00



DIP 4.3005 K.E.S


PRESENT CONDITION	PIPE SPECIFICATIONS	
	HYDRALIC ELEVATION	PIPE CENTER
GROUND ELEVATION	196.33	196.33
ACCUMULATED DISTANCE	0	0
DISTANCE	70	70
NUMBERAGE	NO. 1	NO. 1
ALIGNMENT	IP.1	IP.1
	0°50'	0°50'
	IP.2	IP.2
	0°19'	0°19'
	IP.3	IP.3
	55°12'	55°12'
	IP.4	IP.4
	58°57'	58°57'
	IP.5	IP.5
	25°34'	25°34'

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS


**DOMAIR PROJECT**  
**PLAN & PROFILE (1/8)**

JAPAN INTERNATIONAL COOPERATION AGENCY

DRW. NO.  
15



DL-77.00





PRESENT CONDITION	PLAN	PIPE SPECIFICATIONS	
		HYDRALIC ELEVATION	PIPE CENTER
GROUND ELEVATION		107.10	107.10
ACCUMULATED DISTANCE		0	0
DISTANCE		45	50
NUMBERAGE		NO.30	NO.31
ALIGNMENT		IP.6	IP.7
		40°40'	39°54'
			9°20'

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS

<b>DOMAIR PROJECT</b>	DRW. NO.
<b>PLAN &amp; PROFILE (2/8)</b>	16
JAPAN INTERNATIONAL COOPERATION AGENCY	


IP. 8  
9'20"




PRESENT CONDITION	PIPE SPECIFICATIONS	
	HYDRALIC ELEVATION	PIPE CENTER
GROUND ELEVATION	8000	8000
ACCUMULATED DISTANCE	0	0
DISTANCE	50	50
NUMBERAGE	8000	8000
ALIGNMENT	IP. 8 9'20"	

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS

DOMAIR PROJECT PLAN & PROFILE (3/8)	DRW. NO. 17
JAPAN INTERNATIONAL COOPERATION AGENCY	



D<sub>s</sub> = 74.00




O I P 3 3 0 0 m K 1 9


PRESENT CONDITION	PIPE SPECIFICATIONS	
	PIPE CENTER	HYDRALIC ELEVATION
ALIGNMENT		
NUMBERAGE		
DISTANCE		
ACCUMULATED DISTANCE		
GROUND ELEVATION		
PIPE CENTER		
HYDRALIC ELEVATION		
PIPE SPECIFICATIONS		

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS

DOMAIR PROJECT PLAN & PROFILE (4/8)	DRW. NO.  18
JAPAN INTERNATIONAL COOPERATION AGENCY	



DL = 74.00



DIP 2300m K=9

PRESENT CONDITION	PLAN	PIPE SPECIFICATIONS
		HYDRALIC ELEVATION
GROUND ELEVATION	PIPE CENTER	
ACCUMULATED DISTANCE		
DISTANCE		
NUMBERAGE		
ALIGNMENT		

THE SYRIAN ARAB REPUBLIC  
 THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
 RURAL PROVINCE OF DAMASCUS


**DOMAIR PROJECT**  
**PLAN & PROFILE (5/8)**

DRW. NO.  
 19

JAPAN INTERNATIONAL COOPERATION AGENCY







1:3000  
1:200

DL = 134.00




PLAN	PIPE SPECIFICATIONS	
	DIP 430mm K=9	DIP 250mm K=9
HYDRALIC ELEVATION	167.00	176.00
PIPE CENTER	167.00	176.00
GROUND ELEVATION	167.00	176.00
ACCUMULATED DISTANCE	0	21000
DISTANCE	50	50
NUMBERAGE	160.000	160.000
ALIGNMENT	75°02'    65°07'    10°44'    10°15'    13°45'    9°40'    4°50'	

THE SYRIAN ARAB REPUBLIC  
THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
RURAL PROVINCE OF DAMASCUS

**DOMAIR PROJECT**  
PLAN & PROFILE (7/8)

DRW. NO.  
21

JAPAN INTERNATIONAL COOPERATION AGENCY



DL = 164.00

PLAN	PIPE SPECIFICATIONS	DIP 9.250m K=8	
	HYDRALIC ELEVATION		
PRESENT CONDITION	PIPE CENTER	1763.5	1764.6
	GROUND ELEVATION	1763.5	1764.6
	ACCUMULATED DISTANCE	0	50
	DISTANCE	50	100
	NUMBERAGE	1	2
	ALIGNMENT	14'40"	13'50"
		16'22"	54'00"

THE SYRIAN ARAB REPUBLIC  
 THE PROJECT FOR WATER SUPPLY DEVELOPMENT IN  
 RURAL PROVINCE OF DAMASCUS

**DOMAIR PROJECT**  
 PLAN & PROFILE (8/8)

DRW. NO.  
 22

JAPAN INTERNATIONAL COOPERATION AGENCY





JICA