



- Legend**
- Boundary of 1968 Master Plan
 - Administrative Boundary of The City
 - Railway
 - Railway Station
 - Bus Station
 - Airport
 - Residential & Commercial Area
 - Administrative Area
 - Industrial Zone
 - Special Area Zone
 - Quarry Area
 - Rural Agglomeration Area
 - Farmland
 - Grassland/Meadow
 - Reserved Area/Others
 - Afforestation Area

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
Figure 3.2.2 Present Land Use
 NIPPON KOEI CO., LTD.

(Source : Damascus Municipality)



JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
 Figure 3.3.1
 Cumulative Discharge and Rainfall for Barada Spring
 NIPPON KOEI CO., LTD.



Hydrogeological Map

LEGEND


- 20— Upper Quaternary Pebble Beds Isopachites
- Water Courses
- Geological Boundaries
- - - International Boundaries
- - - DAWSSA served area proposed in City plan

Symbol

- [Pattern] Quaternary Alluvium
- [Pattern] Quaternary Sand & Gravel
- [Pattern] Quaternary, Lacustrine Deposits
- [Pattern] Neogene, Conglomerates
- [Pattern] Paleogene, Limestones & Marls
- [Pattern] Paleogene, Marls & Limestones
- [Pattern] Cretaceous, Limestone, Dolomite, Sandstone
- [Pattern] Jurassic, Limestone & Dolomite
- [Pattern] Neogene to Quaternary, Basalt

Aquifer Productivity

- [Pattern] Good
- [Pattern] Medium
- [Pattern] Poor
- [Pattern] Unproductive




Grid: Universal Transverse Mercator

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

THE STUDY ON THE DEVELOPMENT OF WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY


Figure 3.3.2
Hydrogeological Map

NIIPPON KOGI CO., LTD.




**Piezometric Map
September
1995**

- Water course
- International border
- 900 Water Level in Cretaceous & Jurassic
- 640 Water Level in Quaternary
- ⊕ Observation Well
With reference number
and Water level elevation (metres)



Grid: Universal Transverse Mercator
 JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
 Figure 3.3.3
 Piezometric Map
 NIPPON KOEI CO., LTD.

Isodrawdown Map
June-November 1994
Drawdowns in metres




| Legend | |
|--------|------------------|
| | DAWSSA Wellfield |
| | Observation Bh |
| | Fringe Bh |
| | Emergency Bh |
| | Other Bh |

Key to DAWSSA Wellfields


| | |
|---|---------------|
| A | Kaboon |
| B | Jobar |
| C | Mazraa |
| D | Ibn Assaker |
| E | Kadam Railway |
| F | Kadam Store |
| G | Oumawiyyin |
| H | University |
| I | Jaramana |
| J | Takadom |
| K | Kywan |
| L | Tishreen |
| M | Dummar |

Contour Interval Variable
UTM Grid
North at top of map
Scale 1:50,000


JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
THE STUDY ON THE DEVELOPMENT OF
WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
Figure 3.3.4
Isodrawdown Map for Damascus 1994
NIPPON KOEI CO., LTD.




JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
Figure 3.4.1a
Sampling Locations (Damascus)
 NIPPON KOEI CO., LTD.




- location of well/spring
- Damascus



JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
Figure 3.4.1b
Sampling Locations (Mountains)
 NIPPON KOEI CO., LTD.





4. PRESENT CONDITIONS OF WATER SUPPLY SYSTEM

4.1 General

Damascus Governate consists of two Mohafazas, Damascus city and Damascus rural. Water supply is managed generally by the water supply and sewerage authorities under the Ministry of Housing and Utilities. In Damascus, there are four kinds of waterworks according to the waterworks law.

- i) Public Urban Water Supply : with Damascus City and seven villages to be served (managed by DAWSSA)
- ii) Public Rural Water supply : with rural area out of Damascus city to be served (managed by Damascus Rural Water Supply)
- iii) Bulk Water Supply : to supply raw water for water supply bodies (managed by the Ministry of Housing and Utilities)
- iv) Bulk Water Supply : to supply raw water for irrigation (managed by the Ministry of Irrigation)
- v) Private Water Supply : for private use, such as factories, farms and sanitarium

The main source of drinking water is the Figh spring. Other water sources, such as underground water in the Barada spring and Damascus city, are utilized as required to supplement. The water is conveyed to three service reservoirs after being chlorinated at the Figh dispersion basin, and stored at each reservoir. Water to the villages in the Damascus Rural area is supplied from Figh and Jamraya reservoirs. Water is conveyed to Wali reservoir in Damascus City, through a transmission pipeline consisting of a box culvert with a length of 16 km and a new tunnel with a length of 15 km. From Wali reservoir water is distributed to several service reservoirs located throughout the city.

Several production well sites are located throughout the city. Groundwater is pumped up to a service reservoir located in the vicinity of each borehole and chlorinated for being delivered to house connections through the net work.

4.2 Present Service Area and Population

4.2.1 Present Service Area

DAWSSA supplies water to eight villages, Figh, Al Khadra, Bassime, Ashrafye Wadi, Judayde with the military area, Jemraya Hame with slum area, Kudasaya with a new residential area, and Takadom in Damascus Rural. Special Area Zones are serviced by a bulk water supply system connected to the transmission tunnel from Figh. The existing service area of villages is estimated at 5.12 km².

Damascus City consists of fifteen districts. DAWSSA has responsibility for water supply to the whole area with 106 km² and 103 wells managed by Damascus municipality.

4.2.2 Population Served in Present Service Area

The existing population served is estimated at 1,150,950 based on the billing data and 1994 Census as follows:

| | |
|-------------------|-----------|
| Total Population | 1,557,950 |
| Population Served | 1,150,950 |
| Informal Resident | 407,000 |
| Service Level (%) | 74 % |

Excepting for the large number of informal residents, DAWSSA system provides 100 % coverage in 1995. The total population in informal areas is estimated tentatively at 407,000 persons based on the Census and the results of the interview survey.

4.3 Existing Water Supply System and Facilities

4.3.1 Source of Supply

The existing source for drinking water supply consists of three water sources, wells at Barada Spring, Ain Figh area and wellfields/fringe wells in Damascus City. The existing water supply system is illustrated in Figure 4.3.1. The record of water production in 1995 are as follows.

| | Amount of Water Supplied (Million m ³ /year) | Ratio (%) |
|------------------------|--|--------------|
| Wells at Barada Spring | 6.8 | 3.1 |
| Ain Fiegh area | 177.4 | 81.3 |
| Wellfields in Damascus | 30.1 | 13.8 |
| Fringe wells | 4.0 | 1.8 |
| Total | 218.3 | 100.0 |

(Source : Data for 1995 from DAWSSA)

4.3.2 Production Wells

There are 3 existing production wells areas: Barada spring area, Ain Fiegh area and Damascus city well field. Pumped water from the wells of Barada and Fiegh is conveyed into Wali service reservoirs through the two transmission tunnels by gravity flow. The wells in Damascus city are used mostly during water shortage periods from June to February. Well water is boosted into the distribution network by pumping stations located at the production well centers.

The annual average operation rate of well pumps was 44 % and the operation period was mainly from July to February, according to the operation record in 1995. During no pump operation period, the periodical maintenance for pumps and motors was carried out by the mechanical department of production directorate of DAWSSA. Equipment appears to be well maintained, however it seems there is a shortage of vehicles, tools and equipment necessary for maintenance and in general most of the tools are outdated and in need of replacement.

(a) Barada spring area

The operation of well pumps in this area started in September 1995. Pumped water from each well is once storage into the collecting reservoir and conveyed to Wali service reservoir through Barada transmission main to Fiegh energy dissipation basin and two tunnels. As of July 1996, 15 wells located around the perimeter of Barada spring are in service and operational. Electrical power for the existing operating wells is supplied from both a transmission line from the national grid and a diesel generator with a rated capacity of 1000 KVA.

(b) Fiegh spring area

In Fiegh area, there are four well groups : Deir Moukaren, Ain Haroush, Fiegh side spring and Fiegh main spring. The well groups are operated actually from June to February when Fiegh spring flow decrease and become insufficient to cover the demand. Pumped

water from each well group is joined at Figh energy dissipation basin and chlorinated in front of the entrance to the tunnels feeding Wali service reservoir.

Seven submersible pumps with a total capacity of 1,104 m³/h are installed in the deep wells located at Deir Moukaren. Installed pumping capacity at Ain Haroush spring is 4,500 m³/h with five pumps. Installed capacity at Figh main spring and side spring is 26,100 m³/h with a total of seventeen pumps.

As of July 1996, three wells with a total pump capacity of 6,000 m³/h and transmission main feeding Barada conduction main were under construction at Ain Haroush and scheduled to complete by end of year 1997.

(c) Damascus city

As of July 1996, there are 101 wells in total at 8 separate production well fields in Damascus city. In addition, there are 23 fringe wells and 58 emergency wells located in Damascus city.

The production well fields are having with a total pump capacity of 9,940 m³/h. Each well field is consisted of several deep wells and production well center which equipped with a collecting reservoir, several booster pumps, a hypo chlorite dosing equipment, control room, power receiving apparatus and stand-by diesel generator. Pumped water is collected to a reservoir in each production well center and feeding into the network by booster pumps.

The fringe wells have with a total pump capacity of 1,160 m³/h and each well is equipped with a motor driven vertical shaft type well pump, a stand-by diesel generator, a motor driven horizontal shaft type booster pump, a hypo chlorite dosing pump and a 25 m³ steel made spherical elevated tank. The operation of the fringe wells feeding the network are operated for 16 hours (two 8 hour shifts per day with two operators). DAWSSA has scheduled to replace all vertical shaft type well pump to submersible motor pumps within the next five years.

The emergency wells are located in parks, schools and hospitals for back-up of main water supply system from Wali service reservoir and having with a total pump capacity of 2,320 m³/h. The pump type is engine driven vertical shaft. The pump set maintenance department of emergency well check the well pumps twice a week for fifteen minutes to three hours operation at one time.

4.3.3 Pumping Stations

The two main functions of the existing pumping stations are to convey water from reservoir to reservoir, and to supply water into the distribution network. There are 15 pumping stations in total, 7 stations are located at service reservoirs and the others are located at the production well centers. A schematic diagram showing pipe connections between pumping stations and reservoirs is illustrated in Figure 4.3.2. and locations are shown in Figure 4.3.3. The number of installed pumps and their capacity are as follows;

| Location of Pumping Stations | No. of Stations | No. of Pumps | Installed Capa. (x 10 ³ m ³ /h) |
|------------------------------|-----------------|--------------|--|
| Service Reservoirs | 7 | 59 | 14.4 |
| Production Well Centers | 8 | 40 | 10.8 |
| Total | 15 | 99 | 25.2 |

All pumping stations are equipped with a step-down transformer and a stand-by diesel generator for emergency use. However some of the diesel generators installed do not have enough capacity for all pumps to operate at the same time. Chlorine dosing equipment is provided at the production well centers for disinfecting water before it is distributed. Pumping station operators are on site 24 hours (3 x 8 hour shift per day).

The two types of pumps installed in the existing system are single suction horizontal volute pump and submersible pump. The volute pumps are mainly used at service reservoirs for boosting water to other reservoirs and the submersible pumps are used at production well centers to supply water into the distribution network.

4.3.4 Transmission and Distribution Mains

The total length of the existing transmission and distribution mains is around 1,221 km. DAWSSA has replaced a total of 479 km length (44 %) of cast iron pipe transmission and distribution mains with ductile iron pipes during the period from 1982 to 1992.

(1) Transmission mains

Transmission mains between Figh Spring and Wali reservoirs consist of a new tunnel about 15 km long with an inside diameter 2,550 mm and an older horseshoe-shaped tunnel about 16 km long, 1,360 mm wide and 1,880 mm most current height. Tunnel transmission capacities are 11.3 m³/s (new) and 3.5 m³/s (old) for a total combined capacity of 14.8 m³/s. Transmission mains between reservoirs are mainly ductile iron pipes laid underground and their

diameters vary between 80 mm to 1,200 mm. Total lengths of the transmission main are summarized as follows:

| | | | | (unit : km) |
|--------------|-----------|---------|----------|-------------|
| Ductile iron | Cast iron | Steel | Concrete | Total |
| 62.5 | 0.7 | 6.2 | 33.0 | 102.4 |
| (61.0 %) | (0.7 %) | (6.1 %) | (32.2 %) | |

(Source : DAWSSA)

(2) Distribution main

The existing water distribution system covers the villages along Barada river valley and Damascus city. The system in Damascus city is divided into the four service districts of Damascus Center, Berze, Berze East and Mezze. Each service district is classified into pressure zones based on five pressure ranges as illustrated in Figure 4.3.4. The pressure classifications are low, medium, high I, high II and superior high on the basis of the elevations of the district served as follows. DAWSSA's design criteria specifies a minimum service pressure for distribution mains of 30 m (water head) and a maximum of 60 m.

| Classification of Pressure Zone | Elevation (m) |
|---------------------------------|---------------|
| Low | less than 690 |
| Medium | less than 730 |
| High I | less than 780 |
| High II | less than 830 |
| Superior High | less than 935 |

(Source : DAWSSA)

Distribution mains are mostly made of ductile iron pipe and their diameters vary between 60 mm to 1,200 mm. Most of the water for the center of Damascus is supplied through one 800 mm line and one 600 mm line from the Eastern reservoir and two 1,200 mm lines from the Western reservoir. Distribution mains are provided with a total 5,337 numbers of control and sectionalizing valves for optimizing distribution network operations. There are a total of 541 fire hydrants with a 4 inches bore. The hydrants are typically located in utility boxes below grade. Total lengths of the distribution main are summarized as follows:

| | | | (unit : km) |
|--------------|-----------|---------|-------------|
| Ductile iron | Cast iron | Steel | Total |
| 927.8 | 124.4 | 66.7 | 1,118.9 |
| (82.9 %) | (11.1 %) | (6.0 %) | |

(Source : DAWSSA)

About 124 km (12 %) of existing distribution mains as shown in Table 4.3.1, from nominal diameter 80 mm to 600 mm, are made of cast iron pipe and the connections are lead joint method. Many water leakage occur caused by these cast iron pipes and joints and valves.

4.3.5 Service Reservoirs

There are 30 reservoirs providing a total capacity of about 0.2 million m³. Existing service reservoirs are classified into the following 8 different types:

- | | |
|--|----------|
| - Reservoirs fed directly from the Figh main spring | 1 only |
| - Reservoirs fed directly from the tunnels by gravity or by pumping | 5 total |
| - Reservoirs fed from other reservoirs by gravity | 3 total |
| - Reservoirs fed from other reservoirs by pumping | 10 total |
| - Reservoirs feeding other reservoirs through the distribution network | 2 total |
| - Reservoirs fed only from local wells, supplying distribution network | 6 total |
| - Reservoirs fed only from local wells, supplying local networks | 3 total |
| - Reservoirs for regulating the pressure of transmission mains | 4 total |

In general, reservoirs are constructed under ground and provided with pumping station, control house, transformer house and diesel generator house. At production well centers, hypo chlorite dosing pumps are provided to disinfect stored water before distributing it into network. The dosing rate for hypo chlorite is determined by the results of water quality tests carried out with laboratory at DAWSSA headquarters. Water sampling is scheduled every morning except on Fridays and National holidays. Water from Figh Spring, is a chlorinated at the plant located in a separate building in front of the entrance to the tunnels feeding Wali reservoirs. This chlorinating plant uses chlorine gas, with cylinders having a capacity of 800 kg each.

As for measuring water flow at reservoirs, flow measurement devices are located at the entrance of both tunnels in Figh spring, Western service reservoir and production well centers in Damascus city. Other service reservoirs and principal distribution mains need flow metering to establish a plan of operation and analysis for water leakage.

4.3.6 House Connection and Water Meters

According to the DAWSSA's standard specifications, the service pipe from the distribution main to the individual premises is generally made of polyvinyl chloride pipe (PVC), or galvanized steel pipe. Saddles, brass union sockets and stop cocks are used for branch

connection. A typical connection diagram is illustrated in Figure 4.3.5. The size of the service line depends on the number of dwellings being serviced as follows:

| Number of dwellings | (unit : inch) | |
|---------------------|----------------------|--|
| | Size of service pipe | |
| 1 | 1/2 | |
| 2 ~ 3 | 3/4 | |
| 4 ~ 6 | 1 | |
| 6 ~ 11 | 1-1/4 | |
| 11 ~ 16 | 1-1/2 | |
| 16 ~ 50 | 2 | |

(Source : DAWSSA)

There are two methods for connecting individual subscribers in multiple unit dwellings. The preferred method consists of individually metering each subscriber. A second more commonly used method consists of providing one metered connection for all consumers. DAWSSA is responsible for all aspects of the service from the distribution main to the meter box. The meter box is the responsibility of the subscriber. Water meters for individual house connection are generally of the multi jet type, half inch pipe size, and of Syrian make. Meters above a half inch diameter are imported from France, Germany and other countries. According to DAWSSA's records for 1994 and 1995, there is a total of 1,833 water meters for large consumption users and 235,975 meters for normal subscribers.

According to water meter reading in 1995, 84,112 meters (36.5 %) recorded less than 5 m³ consumption per quarter. DAWSSA has carried out replacement and install in total of 7,546 water meters of half inch pipe size. The meter checking department of consumer affairs directorate has a capacity to carry out 10 meter repairs a day at the meter repair shop located at DAWSSA headquarters, staff consists of one technician for repairing and nine workers for dismantling/mounting meters. The meter repair shop is equipped with a meter test bench, a small size lathe and a drilling machine, and those are seemed to be in well operation condition.

4.3.7 SCADA System

The SCADA system (Supervisory Control And Data Acquisition system) is to ensure optimum water production and distribution operations of the Damascus City Water Supply. The contract for supply and installation of the SCADA system, which started in 1994 is being carried out by the Italian contractor Nuovo Pignone. The total project cost is 12 million dollars including 7.5 million dollars in foreign currency covered by a loan from the Arab Fund (6 million dollars) and the Syrian Government (1.5 million dollars).

The project is scheduled to be completed in April 1997, however actual progress as of July 1996 is about 6 months behind the original schedule due to delays in supplying communication equipment. Overseas training of the DAWSSA operation and maintenance staff will start at the contractor's factory in Italy this October for a total of 600 man-day according to the contract. After the completion of installation work, the contractor has an obligation to supervise the DAWSSA staff for operation and maintenance of the system during the 30 month guarantee period.

The system consists of three control centers with Wali reservoir being the main control center, DAWSSA headquarters the alternative control center and Figh Spring the secondary control center. Remote terminal units are provided at each reservoir, pumping station and control valve in the distribution network. The system has two main functions: firstly, to collect data from each facility through remote terminal units and secondly, to provide remote control capabilities for each facility from the main control center (or the alternative control center). The system schematic is shown in Figure 4.3.6 and a summary of the main functions is provided as follows:

| Data collection | Remote control |
|-------------------------------------|-------------------------------|
| - Water level in reservoirs | - Pumps (on/off) |
| - Pump status (on/off) | - Valves (open/close) |
| - Valves status (open/close) | - Penstock gates (open/close) |
| - Penstock gate status (open/close) | |
| - Pressure | |
| - Water flow (velocity) | |

In addition to the above covered area, DAWSSA has a plan to expand the SCADA system to Barada spring area.

4.4 Present Water Use and Customer Consciousness

4.4.1 General

An interview survey was carried out to identify water supply service conditions in the City and areas facing water shortages. A total of 650 families were surveyed covering 15 districts in the city including the informal areas. The survey was carried out in July and August in 1996.

The interview survey was conducted in person using a questionnaire, written in both English and Arabic attached hereinafter. The effective number of the samples used for this study was reduced to 600 by screening out questionnaires which were incomplete or had obviously been answered incorrectly.

Interviewees were selected on the assumption that they were representative one of the following four income classes. The number of families for each class was determined as follows ;

| | Number of Samples | Assumed Monthly Income |
|----------------------|-------------------|------------------------|
| 1) High Class | 100 families | more than SL 50,000 |
| 2) Middle Class | 100 families | SL 10,000 to 50,000 |
| 3) Low Class | 200 families | less than SL 10,000 |
| 4) Informal resident | 200 families | |
| Total | 600 families | |

Data obtained from the interview survey was analyzed by data processing and the main results are summarized in Table 4.4.1.

4.4.2 Family Size and Number of Households

The average family size based on the survey is 6.01 persons per family as summarized in Table 4.4.1. This figure is almost similar to the result of 1994 Census. The number of households including informal households is estimated at 237,000 (total population of 1,422,000 persons \div 6 persons). Approximately 42,000 (18 %) of households in the City are assumed to be either unbilled consumers or unconnected households , since the total number of the billed domestic connections recorded in 1995 was about 195,000.

Family size appears to vary significantly by district. For example, family size in Kadam and Kafar Souseh is the highest at 7.26 and 7.25 respectively, while in Kaboon and Mezze it is the lowest at 4.83 and 4.86 respectively. Family size also varies by income level. The middle and informal classes show the highest figure with 6.33 persons.

4.4.3 Monthly Average Income per Household

Monthly average income per family in the City is approximately SL 16,400 as shown in Table 4.4.1. Income level classification in the City is summarized from the result of the interview survey as follows;

| (Unit : % to the Total Population) | |
|------------------------------------|--------|
| High Class | 16.7 |
| Middle Class | 18.0 |
| Low Class | 39.3 |
| Informal Residents | (26.0) |
| - Middle Class | 4.5 |
| - Low Class | 21.5 |
| Total | 100.0 |

In consequence of the above classification in the City, the existing population including informal areas consists of 16.7 % of High class, 22.5 % of Middle class and 60.8 % of Low class.

4.4.4 Consumption and Source for Domestic Water

(1) Monthly water consumption

Average monthly water consumption per household is 32 m³/m (177 lpcd) in Damascus. The highest consumption occurs in Rukn Aldyn with 50 m³/m and Kadam with 46 m³/m. The lowest consumption is Midan with 22 m³/m. Monthly water consumption for each income class is estimated below;

- High Class : 35 m³/m (194 lpcd)
- Middle Class : 33 m³/m (183 lpcd)
- Low Class : 32 m³/m (177 lpcd)
- Informal Residents : 31 m³/m (172 lpcd)

Although the demand is not always met, 95% of formal users are satisfied with the present quantity of water available for consumption. Only 5% of users want 1.5 times of the present amount and only 1% of users desire 2 times. The percentage of respondents that indicated a need for 50% more water is shown for the following areas: Yarmouk (32%), Kadam (18%), Midan (9%), and Sarouja, Kafar Souse (7%).

(2) Water source

Just over 90% of residents in the City use water supplied from DAWSSA as shown in Table 4.4.1. In the low pressure zones, such as Kadam, Kaboon, Yarmouk and Midan, the residents rely heavily on bottled water, springs and wells for drinking and cooking.

As suspected, a rather large 78.5% of informal residents use water supplied from informal connection to DAWSSA's system. Informal connections are made as follows: 69% with a valve, 13% without a valve and 18% with a booster pump. The availability of water in informal areas is variable. Only 53% of residents get water 24 hours per day, 21% get water for less than 4 hours per day, 12% for less than 8 hours per day and 14% for less than 12 hours per day. Almost all residents surveyed in informal areas indicated a desire to have stable and safe drinking water supply.

4.4.5 Customer Satisfaction

Table 4.4.1 shows that 70 % of residents are satisfied with DAWSSA's existing water supply services. Results for Jobar, Kadam, Midan, Yarmouk, Kafar Souse and Mezze show that the percentage of unsatisfactory responses is spatially distributed. The reasons for unsatisfactory service from the existing water supply are distributed poor water quality 13.5 % and low pressure 9.3 %. These areas belong to the Low Pressure Zone in the distribution system and are supplied with water mainly from DAWSSA's wells in the City. About 85 % of the residences have water storage devices with 1 m³ capacity.

Results of household water use condition are summarized as follows;

- a) 90 % of residents drink water directly from the tap without boiling except in Jobar where 75 % of resident use boiled water. Results show that quality of supplied water is good enough for drinking.
- b) 73 % of residents consider that water pressure is adequate to meet their needs, while 11 % said it was too high and 13 % said it was too low. Low pressure is reported mainly in Midan (46 %), Yarmouk (43 %) and Kafar Souse (30 %).
- c) 92 % of residents do not use water purifiers. 12 % of high income class and informal residents use purifiers. The limited use of purifiers indicates that water quality is satisfactory to most households.
- d) House pumps are used by 29 % of residents on average. Residents in the low pressure zones, such as Yarmouk (79 %), Midan (62 %), Kadam (46 %) and Kafar Souse (43 %) show a high percentage of use. Informal residents are the highest users with 45 %.

As for availability of DAWSSA Water Supply, the majority of consumers get water everyday (83 %). However, only 55 % of consumers are supplied water over 12 hours per day during the dry season. 5 % get water for less than 4 hours per day, 5 % for less than 8 hours per day and 35 % for less than 12 hours per day. About 9 % of residents took counter measures against the shortage of water in the dry season as shown in Table 4.4.1. Kafar Souse, Kaboon and Mezze seem to have the least daily water availability. Almost all residents installed water storage devices as a coping against water service interruptions.

4.4.6 Waterborne Diseases

Table 4.4.1 indicates that not many residents got, in spite of drinking unboiled water, waterborne diseases with 109 reported cases. Total percentage of water related diseases is 18.2 % consisting of Typhoid (2.5 %), Cholera (0.2 %) and 15 % for other diseases. Other diseases seem to occur from a lack of hygiene based on the observations of the interviewers. It is a proof water is supplied with good hygienic standard.

Cases of typhoid are reported in Rukn Aldyn, Kadam, Midan and Kafar Souse, and Cholera in Mezze. As for waterborne diseases at each class, Low (40 cases) and Informal (36 cases) show higher than High (15 cases) and Middle (18 cases).

4.4.7 Water Cost per Household and Willingness to Pay

Monthly average payments for water, sewerage and electricity are reported by surveyed families as follows;

| | | |
|---------------|-------|---|
| - Water | : 147 | SL/month/family (0.9 % to Average Income) |
| - Sewerage | : 75 | SL/month/family (0.5 % to Average Income) |
| - Electricity | : 450 | SL/month/family (2.8 % to Average Income) |

On average 72 % of official consumers for water consider that the present payments are reasonable as shown in Table 4.4.1. It should be noted that 40 % residents in Kadam, Kafar Souse, Jobar, Shagour and Midan complained that water charges are too high for poor service conditions and payments are too expensive compared to their incomes. Residents in Yarmouk claim that existing payments should be lower because they receive less quantity and lower pressure. The level of customer satisfaction by income Class drops from 84 % for high income class to 65 % for low income class.

As for willingness to pay for water in the informal areas, 93 % of informal residents show their willingness to pay for water supplied from DAWSSA. Only 7 % of residents in the informal areas indicated they would not pay tariff because they considered their income unaffordable.

The interview survey asked consumers their opinion on affordable tariffs if the infrastructures are improved such as water supply, sewerage system and electricity supply. Affordable tariffs to the following infrastructures is summarized below ;

- Water Tariff : 151 SL (147 SL/month at present)
- Garbage Tariff : 77 SL (75 SL/month at present)
- Electricity Tariff : 433 SL (450 SL/month at present)

4.5 Unaccounted for Water (UFW)

4.5.1 General

The unaccounted for water study was carried out to assess the current situation in Damascus, and formulate recommendations for reducing the unaccounted for water figure.

The objectives of the study were to :

- i) Identify the present condition of unaccounted for water in Damascus
- ii) Make recommendations and set achievable targets for the reduction of UFW
- iii) Make recommendations of measures to be used for the reduction of UFW

Detailed analysis of the unaccounted for water in DAWSSA's water supply system has been made and is presented in Appendix F.

4.5.2 Components of UFW

Unaccounted for Water (UFW) can be described as, that water which is the difference between that supplied and that which is accounted for. The water balance of DAWSSA as at 1995 is shown below :

| Economic | Number | Description | MCM/Year | Percentage | Revenue | Technical |
|-------------|---------------|------------------------|----------|------------|------------|-----------|
| Billed | 1 | Domestic Use | 46.1 | 21.1% | Meter | Delivered |
| | 2 | Government | 13.6 | 6.2% | | |
| | 3 | Commercial | 2.8 | 1.3% | | |
| | 4 | Industrial Use | 0.5 | 0.2% | | |
| | 5 | Water rights | 14.9 | 6.8% | | |
| Un - Billed | 6 | Religious & Public Use | 3.8 | 1.7% | Un metered | |
| | 7 | Meter Malfunction | 31.4 | 14.4% | | |
| | 8 | Informal Use | 29.7 | 13.6% | | |
| | 1 to 8 | Sub Total | 142.8 | | | |
| | 9=10-subtotal | System Losses | 75.5 | 34.7% | | Losses |
| Production | 10 | Total | 218.3 | 100% | | |

The unaccounted for water study was carried out, and assessed the current situation in Damascus, where 64% of the total water production in 1995 was attributed as being unaccounted for water.

UFW consist of four main components which are :

| | | |
|----|-----------------------------------|---------------------|
| a) | Meter Malfunction | (14.4%) |
| b) | Religious and Public Fountain Use | (1.7%) |
| c) | Informal Use | (13.6%) |
| d) | System Losses | (34.7%) |
| | | Total UFW = (64.4%) |

4.5.3 Field Survey

Field surveys were conducted in the following areas :

| | |
|-----------------------------------|------------------|
| Berzze Village | (Reservoir Zone) |
| Esh Al Warwar | (Informal Area) |
| Mahadi Bin Barakeh & Malki Street | (Leak Detection) |
| Dar Al Moalimat & Ruku Aldyn | (Meter Survey) |
| The Army Camp at Tishreen | (Leak Detection) |
| 20 Mosques | (Meter Survey) |

Major findings of the survey are as follows :

i) Informal use

There are 14 informal housing areas scattered throughout Damascus. The population in these areas exceeds 407,000 and there is a substantial leakage problem at most sites. None of the residents pay for any water consumed and in the unaccounted for water calculation, the informal areas are a major contributory factor.

ii) Old water mains

In the city of Damascus there are many pipes which have a history of leakage and are in urgent need of replacement. Many of these pipes are old cast iron pipes with lead joints that frequently leak . Replacing these water mains will strengthen supplies and further reduce the amount of leakage in the system.

iii) Domestic Water Meters

Meter malfunction in Damascus is very high with over 84,000 meters currently awaiting repairs resulting in a figure of 14.4% for un-billed water. The most common meter in use is a locally made meter called the Doris meter which is of the multijet variety and does not record accurately at low flows.

iv) Religious and Public Fountain Use

Water which is used at the mosques and public fountain is un-billed water and as such is a constant source of misuse and general waste. In the unaccounted for water figure they account for 1.7% of water produced and unless precautions are taken this figure will rise.

4.5.4 Strategic Plan of Reduction of UFW

In order to reduce the unaccounted for water figure, various countermeasures have been proposed. All of these countermeasures are technically and economically possible. They would also provide for better management of the system and information about the system which is not available at this moment. A reasonable target of 25% has been suggested for the year 2015 which should be achievable. If one compares this figure to typical English targets, then they are very similar and in Jakarta a target figure of 25% has also been set.

These targets are seen as realistic targets and ones that can be achieved. It is therefore important that this goal is maintained by DAWSSA otherwise, there would be serious shortfalls in the supply of water to the detriment of both the customer and DAWSSA.

The table below shows the target reduction and timetable of events.

* This does not include the Religious or Public Fountain Use

| Items | Present 1995 | 2000 | 2005 | 2010 | 2015 |
|-----------------------------|--------------|------|------|------|------|
| Informal Use | 13.6% | 4% | 1% | 0% | 0% |
| Meter malfunction | 14.4% | 3% | 0% | 0% | 0% |
| System Leakage | 34.7% | 32% | 30% | 28% | 25% |
| Total Unaccounted for water | 62.7% | 39% | 31% | 28% | 25% |

4.5.5. Recommended Countermeasures for Reducing UFW

(1) Water supply improvements for informal areas

It is proposed to transfer all of these informal housing areas from informal status to formal status. The reason for this is to save water from leakage and encourage the residents to pay their due water rates for water consumed. By transferring all of these connections, the ratio of un-billed customers should be reduced by the year 2006 and the high leakage rates that exist at present at these informal housing areas will eventually be eliminated.

(2) Leakage control and supply improvement

The alternative plan for leakage control falls into 4 main groups. They are as follows :

i) A program of mains renewal to reduce the level of leaking lead joints on cast iron mains and reinforce the existing distribution system thus safeguarding supplies. Many of the pipes are old cast iron mains with lead run joints which frequently leak and by replacing these pipes the frequency of leakage will be reduced. The oldest pipes to be replaced date back to the early part of this century from 1906 dating to the late 60s and are cast iron pipes.

Each year, there are many instances where these pipes leak and rapid attention is called for. In addition to the leaking joints, other fittings such as sluice valves and air valves are constantly leaking. Each time a leak develops, there is quite a substantial loss of water. The repairs of such leaks can be expensive, as roads have to be excavated and the mains have to be emptied of water so as repairs can be carried out.

ii) A program for setting up approximately 67 district meter areas which will enable DAWSSA to monitor the distribution system and identify areas of high leakage. The size of these areas would be determined by a number of factors, such as the size of the pipe supplying the zone or its geographical boundaries. As a rough guide, District meter areas with medium scale should be no more than 6000 properties and no less than 2000 properties. Consumption into these areas should be measured at night when leakage is assumed to be a major element because of low domestic and industrial use.

After allowances have been made for these uses (normally 1.9 liters/Property/Hour) the difference is assumed to be leakage. However, in Damascus, consideration will have to be given to the fact that in some areas, there is a possibility that overhead storage tanks might be filling during the night, therefore allowances will have to be made, such information will become known once measurements have been carried out at each district meter area. Once information from the system becomes available, it will be possible to generate monthly reports. Comparisons can then be made with former monthly reports and present monthly reports and calculations of leakage rates will be possible. As each area is completed, then the condition of leakage, the pressure range and consumption figures will become available, and in those areas of high leakage, the leakage teams could then be directed to investigate and find the leaks. Having completed the leakage survey and repair of leaks, it will then be possible to determine a leakage trigger level, whereby, once a certain level is reached, then it would make economic

sense to investigate the area for leakage (see Table 4.5.1). Therefore, it is recommended that the leakage from the distribution system is obtained by measurements of night time flows and night consumption. This method can be used to obtain a measure of the absolute level of leakage, but to do so, it would be necessary to make a deduction for night time consumption.

iii) A program of setting up pressure regulated zones which will reduce the levels of leakage in high pressure zones. A critical element of leakage control is the maximum use of pressure control. This will have an effect of reducing the level of leakage, the rate at which leaks happen and further reduce the actual loss when a leak does develop. Advantage should be taken, where appropriate, to use the latest available pressure control valves that automatically adjust to varying demand patterns. Reducing the pressure will not only reduce the level of leakage, but will also reduce the quantity of water used in what can be described as open tap use (widespread in Damascus) and it will also reduce the frequency of pressure type burst.

iv) Increased leak detection surveys to locate and report leakage from the distribution system. At the start of 1996, there was only one leakage team for the whole of DAWSSA's distribution system. Clearly, this was insufficient and following recommendations in June, the section was increased to three teams. The information regarding leaks is now being stored in a computer database and it is expected that the DAWSSA staff will be able to produce monthly reports for higher management. With such information available, management at DAWSSA will have a valuable tool at their disposal which will enable them to make sound decisions based on factual information in the future.

(3) Meter replacement scheme

The study and provisional conclusions of the meter replacement program is that the supply of qualified water meters would be advantageous to DAWSSA and would reduce the exceptionally high proportion of unaccounted for water caused by meter error & malfunction.

It is therefore recommended that the Doris meter be eventually phased out in preference to better quality meter which must have a higher degree of accuracy and are less likely to malfunction. These recommendations are made on the grounds that it would help reduce the unaccounted for water figure and that it would make economic sense.

(4) Implementation schedule

The implementation schedule for each program is shown in Tables 4.5.2 to 4.5.6.

4.6 Organization and Institutional Status

4.6.1 Institutional Setting of DAWSSA

DAWSSA is legally designated an autonomous unit within the public sector under the sponsorship of the Minister of Housing and Utilities. In reality, all of DAWSSA's activities are State controlled and it has little freedom on budgets, wages, tariffs, and direction.

The Authority came into being in 1984 taking over responsibilities from EPEF (L'Etablissement Public des Eaux de Damas (Figh)) for water supply and with a requirement also to take over responsibility for wastewater from the Municipality of Damascus.

For the development of water resources, other than Figh, outside the city boundaries DAWSSA is required to seek licenses from the Ministry of Irrigation who have responsibilities for water planning and regulation; within the city boundary that Ministry, DAWSSA, and the Municipality all have varying rights and responsibilities for water but no-one has overall control.

Only now, with the setting up of a DAWSSA subsidiary 'Company', are moves being made for taking over responsibilities for wastewater from the Municipality (involving the transfer of some seven hundred staff).

4.6.2 Present Organization

DAWSSA is managed through a Board of Directors comprising required executive directors - the General Director and his Deputy plus the Directors of Finance and Planning, one other selected director - currently the Director of Consumer Affairs, and two nominated worker representatives - currently one from finance and one technical directorate.

DAWSSA comprises 16 main directorates, the General Directorate, and two service departments (see Figure 4.6.1). The recent response by DAWSSA to the Minister regarding his proposed 'model' structure could imply a reduction to just eight main directorates.

Overall there are some 1,340 staff (including a small proportion who are either temporary or contract); staff remuneration and tenure of position are regulated by legislation (the Labor Laws). The current 'manning ratio' of 5.4 staff / 1,000 connections is reasonable by international standards.

4.6.3 Problems of the Present Organization

Paramount among DAWSSA's current problems are excessive water losses and low revenue income, at the same time as deteriorating levels of service to customers.

Organizationally, judged against 'best modern practice', there are problems of an over fragmented organization structure; absence of functions for personnel, training, and information technology; inadequate remuneration and motivation of staff; excessive bureaucracy; and lack of customer orientation.

It would also benefit DAWSSA considerably if institutional changes could be made to enhance their autonomy in respect of constitution, finances, and manpower and to improve water resources planning and regulation.

4.7 Financial Affairs

A summary statement of incomes and expenditures for the 1990-95 period is shown below with further details contained in Appendix I of the supporting report. In terms of revenue growth, financial performance has improved significantly from a pre-tax net income of SL 5.5 million in 1990 to SL 252.5 million in 1995. Water sales reached SL 293.5 million and accounted for 80% of total 1995 revenues. This large improvement is due to substantial tariff increases and growth in the number of metered connections.

Summary Revenue and Expenditure Statement (SL millions)

| | 1990 | 1991 | 1992 | 1993 | 1994 | 1995 |
|----------------------|-------|-------|-------|-------|-------|-------|
| Revenue | 135.6 | 221.8 | 209.2 | 225.1 | 379.8 | 353.2 |
| Operating expenses | 97.6 | 113.8 | 138.5 | 146.1 | 179.6 | 216.4 |
| Operating income | 38.0 | 108.0 | 70.7 | 79.0 | 200.2 | 136.8 |
| Depreciation | 32.4 | 36.1 | 40.0 | 39.7 | 50.2 | 54.1 |
| Income | 5.6 | 71.9 | 30.6 | 39.3 | 150.0 | 82.6 |
| Profit tax | 4.7 | 53.2 | 29.3 | 33.7 | 87.5 | 48.3 |
| Net income | 0.9 | 18.7 | 1.3 | 5.6 | 62.5 | 34.3 |
| Financial Indicators | | | | | | |
| Working ratio (%) | 72 | 51 | 66 | 65 | 47 | 61 |
| Operating ratio (%) | 96 | 68 | 85 | 83 | 61 | 77 |
| Profit margin (%) | 4 | 32 | 15 | 17 | 39 | 23 |

Substantial increases in pre-tax revenues have not resulted in a corresponding improvement in the overall financial position. Accounts receivable have remained unacceptably high at 190% of total revenue in 1995, equivalent to 23 months of water sales.

Although production increased over the 1990-95 period the percentage of water sold decreased from 34% to 29%. Meanwhile, unmetered water use increased from 56% to 64% over the same period, possibly indicating increased losses in an aging distribution network, or an increase in informal use or both. Revenue generation is seriously undermined by a large proportion of malfunctioning meters and a high proportion of unmetered informal use. A review of 1995 billings reveals that as many as 33% of domestic meters could be malfunctioning. Approximately 30% of the domestic population (407,000 users) are connected informally to DAWSSA's system and account for an estimated unmetered consumption of 29.7 MCM per year. The potential revenue lost to these two sources is conservatively estimated at SL 157 million (\$US 3.7 million)

A review of expense statements for the 1990-95 period reveals the following:

- a) Staffing and Salaries: While staffing levels have remained more or less constant at around 1300 employees, salary costs have increased by 220% over the 1990-95 period. Salary costs are the largest component of direct operating expenses representing 50% of the total.
- b) Energy: Energy is the second largest component of direct operating expenses, accounting for 21% of the total in 1995. This relatively small amount is due to the extensive use of diesel generators for pumping at remote well sites and low, preferential electricity tariffs. In line with the development of a free market economy there will likely be a significant increase in electricity tariffs in the near future. Because DAWSSA will become increasingly dependent on pumped water supplies it is clear that improving the efficiency of pumping operations and equipment is of the utmost importance to reduce future energy costs.
- c) Maintenance: Maintenance costs associated with various operational activities are difficult to identify because there is no cost accounting. Estimated maintenance expenditures for 1995, were about SL 33 million which is only 15% of annual direct operating expenses. The amount of maintenance related to the water distribution system alone is about 10% of the total. This relatively low proportion indicates a significant level of deferred maintenance.

- d) Service fees. Service fees in 1995 reached a high of SL 36 million and accounted for 16% of direct operating expenses. Service fees included approximately SL 15 million for maintenance contract services, SL 6 million for equipment and transportation rentals, SL 1.5 million for insurance and SL 14 million classified as "miscellaneous services" expenses. Without accurate cost accounting it is difficult to explain this significantly high level of expenditure.

A review of the balance sheet for the 1990-95 period indicates that fixed asset values appear to be considerably lower than replacement costs. For example the estimated replacement cost for the water distribution network is approximately SL 5,200 million (\$US 124 million). However, the asset book value is only SL 445 million (\$US 10.6 million). Fixed assets have never been re-valued since DAWSSA's inception and current annual depreciation allowances are insufficient to provide for the on-going rehabilitation and replacement of the distribution system.

In terms of overall financial management there are three significant factors that impede good performance:

- (a) DAWSSA has no clearly defined financial objectives. Historically the main aim of the utility has been to provide safe drinking water to domestic consumers at affordable levels. Heavy government subsidy has discouraged the concept of providing cost effective service. Management's efforts to operate on a more commercial basis is hampered by politically determined tariffs which undercharge consumption by a large margin, and a relatively high profit tax.
- (b) The accounting of income is substantially delayed by an inefficient billing and collection process. Meters reading has slipped from 3 to 6 month intervals. The total billing and collection process takes about 11 months from the time the meter is read to the time the payment is received. The lack of timely financial information seriously hampers management's ability to control costs, prepare budgets and provide accurate forecasts of future financial needs.
- (c) The accounting system is based on the cash accounting principle and lacks the ability to provide the cost accounting typically needed by utility managers to control operating and maintenance expenditures. All income and expenses are accounted for centrally and entered manually in ledgers. The system does not facilitate accountability of public funds. For example, funds collected from network improvement charges are not segregated from other funds and may be used to cover any kind of expense.

Water tariffs are set uniformly by the Central Government for the whole country and variations to reflect the individual operating costs of each water supply utility are not permitted. Domestic consumption is charged on the basis of a stepped tariff structure where unit rates become progressively higher with increased consumption. Other consumers pay on the basis of a fixed tariff structure. Domestic users account for 80% of the total metered water consumption and 63% of total water sales. The industrial/commercial tariff is higher than the domestic tariff and is intended to provide a cross subsidy to domestic consumers. Unfortunately industrial/commercial use is only 4 % of the total metered consumption and as a result generates only a small 14% of the total revenues. There is a strong internal cross subsidy between domestic consumers. For example, large volume domestic consumers (over 30 m³/month) who account for 20% of the total consumption generate a substantial 40% of the total income while low volume consumers (less than 20 m³/month) who account for a relatively large 32 % of the total consumption only generate 16% of the total income.

Until 1986, domestic users could purchase, for a one time lump sum payment, a perpetual water right for the consumption of an agreed upon monthly volume of water not subject to water tariffs. Water consumed under water right agreements represents 20% of the total metered consumption. Although these water right agreements served to generate needed capital funds, they unfortunately created a situation where a substantial proportion of the water delivered by DAWSSA is consumed without generating revenue.

A summary of the source and application of funds for the 1990-95 period indicates that operating income before taxes accounted for only 12.5 % of all available funding while loans accounted for 90 %. This relatively high proportion indicates a large dependency on government subsidy and foreign loans. There is an obvious need to increase water tariffs to cover the costs of investment spending and increasing debt service charges associated with investment loans.

Capital investment reached a high of SL 334 million (\$ 8 million US) in 1993 and has decreased since then to SL 240 million (\$5.7 million US) in 1995. The amounts invested in new capital projects has fluctuated over the 1990-95 period, however spending as a proportion of funding sources has increased steadily from 28% in 1990 to a high of 43% in 1995. This trend indicates management's continued commitment to meet the demands of a growing population. Most of the efforts to date have focused on providing new infrastructure. More emphasis will be required in the near future on maintenance and rehabilitation expenditures in order to protect this extensive investment in infrastructure.

Table 4.3.1 Distribution Mains in Damascus City

| Materials | D25 | D40 | D50 | D60 | D80 | D100 | D125 | D150 | D200 | D250 | D300 | D350 | D400 | D450 | D500 | D600 | D700 | D800 | D1000 | D1200 | Total |
|--------------------|------|------|-------|------|--------|--------|------|--------|-------|-------|-------|------|-------|------|-------|-------|------|-------|-------|-------|-------------|
| Ductile Iron Pipe | 0.00 | 0.00 | 0.00 | 8.03 | 150.40 | 451.81 | 0.00 | 93.71 | 34.80 | 47.71 | 18.91 | 2.83 | 12.16 | 0.60 | 36.11 | 23.61 | 0.90 | 10.19 | 1.09 | 1.20 | 897.97 km |
| Cast Iron Pipe | 0.00 | 0.00 | 0.00 | 0.00 | 0.89 | 22.58 | 0.25 | 16.33 | 22.03 | 31.90 | 0.55 | 0.00 | 9.56 | 0.00 | 6.83 | 13.46 | 0.00 | 0.00 | 0.00 | 0.00 | 124.38 km |
| Steel Pipe | 0.18 | 3.17 | 23.09 | 0.20 | 1.14 | 2.03 | 1.76 | 0.19 | 1.70 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 35.05 km |
| Total Length (km) | 0.18 | 3.17 | 23.09 | 8.23 | 152.33 | 476.43 | 2.01 | 110.23 | 62.53 | 79.61 | 19.46 | 2.83 | 21.72 | 0.60 | 42.94 | 37.07 | 0.90 | 10.19 | 1.09 | 2.78 | 1,057.40 km |
| (%) | 0.0% | 0.3% | 2.2% | 0.8% | 14.4% | 45.1% | 0.2% | 10.4% | 5.9% | 7.5% | 1.8% | 0.3% | 2.1% | 0.1% | 4.1% | 3.5% | 0.1% | 1.0% | 0.1% | 0.3% | |
| Cast Iron Pipe (%) | 0% | 0% | 0% | 0% | 1% | 5% | 12% | 15% | 35% | 40% | 3% | 0% | 44% | 0% | 16% | 36% | 0% | 0% | 0% | 0% | 12% |

(Source: DAWSSA)




Table 4.4.1 Summary of Interview Survey (Average)

| Designation | Number Of Family Members | Monthly Income s.l./m | Monthly Water Consumption m ³ /m | Percentage ¹ Of Using Deyssa water % | Percentage ² Of Using Major Water Except DAWSSA in Dry Season % | Percentage ³ Of Informal Connections % | Number Of Waterborne Diseases | Ratio Of Water Availability | | Present Payment Of Water s.l./m | Feeling Of Satisfaction For Water Supply % | Reasonability Of Present Payment % | Affordable Tariff for Water s.l./m |
|-----------------|--------------------------|-----------------------|---|---|--|---|-------------------------------|-----------------------------|---------------|---------------------------------|--|------------------------------------|------------------------------------|
| | | | | | | | | Every Day % | Over 12 hrs % | | | | |
| Damascus | | | | | | | | | | | | | |
| 1 Dummar | 6.01 | 16423 | 32 | 91 | 3 | 33 | 109 | 85 | 59 | 147 | 70 | 71 | 148 |
| 2 Mouhajreen | 6.12 | 20840 | 25 | 94 | 6 | 32 | 0 | 100 | 100 | 118 | 88 | 88 | 116 |
| 3 Rukn Aldyn | 5.98 | 29111 | 28 | 100 | 0 | 9 | 5 | 98 | 78 | 155 | 80 | 93 | 166 |
| 4 Berze | 5.32 | 15411 | 50 | 100 | 0 | 34 | 9 | 46 | 22 | 162 | 84 | 70 | 160 |
| 5 Jobar | 6.04 | 11385 | 39 | 100 | 0 | 38 | 2 | 17 | 10 | 165 | 93 | 73 | 177 |
| 6 Sarouja | 6.45 | 8795 | 31 | 96 | 4 | 41 | 13 | 92 | 73 | 123 | 27 | 54 | 124 |
| 7 Old City | 5.24 | 26402 | 33 | 100 | 0 | 0 | 5 | 95 | 61 | 166 | 93 | 80 | 173 |
| 8 Kanawat | 6.27 | 18467 | 33 | 100 | 0 | 0 | 0 | 100 | 80 | 147 | 73 | 73 | 160 |
| 9 Kadam | 5.72 | 16724 | 31 | 98 | 2 | 7 | 1 | 93 | 67 | 133 | 93 | 89 | 133 |
| 10 Shaghour | 7.26 | 13057 | 46 | 89 | 11 | 51 | 21 | 82 | 76 | 171 | 24 | 41 | 166 |
| 11 Midan | 6.35 | 13809 | 27 | 100 | 0 | 41 | 10 | 95 | 75 | 130 | 80 | 60 | 128 |
| 12 Mezze | 6.33 | 16913 | 22 | 86 | 14 | 35 | 9 | 97 | 35 | 140 | 41 | 62 | 131 |
| 13 Kabon | 4.86 | 19310 | 28 | 98 | 2 | 36 | 11 | 94 | 69 | 161 | 66 | 72 | 168 |
| 14 Cafarsouse | 4.83 | 8733 | 34 | 84 | 16 | 47 | 3 | 94 | 69 | 134 | 94 | 88 | 133 |
| 15 Yarmouk | 7.25 | 18238 | 27 | 75 | 25 | 30 | 9 | 82 | 21 | 143 | 61 | 50 | 148 |
| HC High | 6.43 | 9143 | 26 | 40 | 60 | 66 | 11 | 84 | 42 | 161 | 47 | 68 | 143 |
| MC Middle | 5.50 | 50000 | 35 | 98 | 2 | 0 | 15 | 88 | 52 | 162 | 72 | 84 | 171 |
| LC Low | 6.33 | 20500 | 33 | 94 | 6 | 0 | 18 | 78 | 54 | 152 | 74 | 73 | 156 |
| IR Informal | 5.79 | 5665 | 32 | 97 | 3 | 0 | 40 | 83 | 58 | 142 | 69 | 65 | 141 |
| | 6.33 | 7820 | 31 | 71 | 29 | 100 | 36 | 0 | 0 | 0 | 0 | 0 | 146 |

SPECIMEN COPY ONLY

Table 4.5.1 Typical Net Night Flow Analysis

| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 |
|-------------------------|----------------------------|------------------|----------------|------------------|------------------------------|--------------------------|--------------------------|---------------------------|-------------------------|----------------------------------|-----------------------|--------------------------|----|
| Zone No | DMA Site Location Of Meter | Total Properties | M.N.F. m3 Hour | M.N.F.C. m3 Hour | Domestic Night Allow m3/Hour | Therefore N.N.F. m3/Hour | Leakage Litres Prop/Hour | Target Night Flow m3/Hour | Target Litres Prop/Hour | Difference Actual/Target m3/Hour | Assumed Service Leaks | Cost of Leakage Per Year | |
| 1 | 3 Akrad B2 | 1,350 | 97.54 | 1.34 | 2.31 | 93.89 | 69.55 | 24.71 | 18.30 | 69.18 | 88 | £46,987 | |
| 2 | 8 Mezze #86 | 3,476 | 82.18 | 3.41 | 5.94 | 72.83 | 20.95 | 10.16 | 2.92 | 62.67 | 79 | £44,374 | |
| 3 | 5 Naher Eshah | 2,778 | 82.63 | 0.00 | 4.75 | 77.88 | 28.03 | 16.92 | 6.09 | 60.96 | 77 | £43,166 | |
| 4 | 5 Kassioun #1 | 5,942 | 74.51 | 0.00 | 9.13 | 65.38 | 12.24 | 20.15 | 3.77 | 45.23 | 57 | £32,024 | |
| 5 | 7 Kafarsouseh | 934 | 45.19 | 2.25 | 1.60 | 41.34 | 44.26 | 3.82 | 4.09 | 37.52 | 47 | £26,570 | |
| 6 | 1 East Tabbaleh | 4,524 | 56.45 | 26.20 | 7.74 | 22.51 | 4.98 | 6.83 | 1.51 | 15.68 | 20 | £11,106 | |
| 7 | 6 Somareya | 1,411 | 31.56 | 3.81 | 2.41 | 25.34 | 17.96 | 12.55 | 8.89 | 12.79 | 16 | £9,055 | |
| 8 | 2 Shagoor Basateen | 3,871 | 37.60 | 2.12 | 6.62 | 28.86 | 7.46 | 18.60 | 4.80 | 10.26 | 13 | £7,266 | |
| 9 | 4 Jober #1 | 2,895 | 29.98 | 0.00 | 4.95 | 25.03 | 8.65 | 16.52 | 5.71 | 8.51 | 11 | £6,026 | |
| 10 | 7 Tishreen #1 | 3,620 | 27.45 | 0.00 | 6.19 | 21.26 | 5.87 | 19.60 | 5.41 | 1.66 | 2 | £1,175 | |
| Zonal Statistics | | | Total | Ave | Ave | Ave | Ave | Ave | Ave | Ave | Ave | Total | |
| | | | 30201 | 56.51 | 3.91 | 47.43 | 21.99 | 14.99 | 6.15 | 32.45 | 41.07 | £229,747 | |


| | |
|--|-------------|
| 1) Zone Number | 149.86 m3/d |
| 2) District Meter Area Number (DMA) | 474.32 m3/d |
| 3) Site Location Of Meter | |
| 4) Total Numbers of Properties in DMA | |
| 5) Minimum Night Flow m3/Hour | |
| 6) Minimum Night Flow (Commercial) m3/Hour | |
| 7) Domestic Night Time Allowance m3/Hour | |
| (based on 1.71 Lts/Prop/Hour) | |
| Total Projected Savings = £28,147 | |

| | |
|-----------------------------------|-------------------------|
| 8) Net Night Flow m3/Hour | |
| 9) Leakage/Property/Hour | |
| 10) Target Night Flow m3/Hour | |
| 11) Target Litres/Property/Hour | |
| 12) Difference/Target/Actual | |
| 13) Assumed Leaking service pipes | |
| 14) Annual Cost Of Water Losses | (based on £1.94_per m3) |

Table 4.5.2 Program for Replacement of Mains

| Diameter mm | 1998 | 1999 | 2000 | 2001 | 2002 | 2003 | Total Length Kilometres |
|----------------|--------|--------|--------|--------|--------|--------|----------------------------|
| 600 | 6,100 | 960 | 1,250 | 4,800 | 1,000 | | 14,110 |
| 500 | | 1,700 | 2,200 | | | | 3,900 |
| 400 | 1,975 | | 1,900 | | 1,000 | 2,600 | 7,475 |
| 300 | | | | | | | 0 |
| 250 | 6,950 | 7,670 | 2,400 | 4,150 | 3,420 | 2,400 | 26,990 |
| 200 | | 5,050 | 2,700 | 4,800 | 3,000 | 1,000 | 16,550 |
| 150 | 700 | 2,000 | 1,900 | | 3,600 | 3,500 | 11,700 |
| 125 | | 250 | | | | | 250 |
| 100 | 940 | 400 | 3,800 | 1,560 | 3,600 | 5,700 | 16,000 |
| 80 | | | | 600 | | | 600 |
| | 16,665 | 18,030 | 16,150 | 15,910 | 15,620 | 15,200 | 97,575 |

Table 4.5.4 Proposed Program for Pressure Reduction



** Properties covered is a provisional figure only
 Pressure Control to Follow District Meter Installations

Table 4.5.5 Implementation Program for Annual Leakage Surveys

| Number of House Connections Sounded Each Year | | | | | | | | | | | | | | | | | | | | | |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|------|
| | 1996 | 1997 | 1998 | 1999 | 2000 | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2007 | 2007 | 2009 | 2010 | 2011 | 2012 | 2013 | 2015 | |
| Leak team 1 | 20,072 | 82,239 | 60,017 | 61,474 | 62,967 | 64,497 | 66,064 | 67,669 | 69,313 | 70,997 | 71,100 | 71,599 | 72,000 | 72,500 | 73,000 | 73,500 | 74,000 | 74,500 | 75,000 | 75,500 | |
| Number of House Connections Sounded Each Year | | | | | | | | | | | | | | | | | | | | | |
| Leak team 2 | 22,339 | 88,799 | 60,017 | 61,474 | 62,967 | 64,497 | 66,064 | 67,669 | 69,313 | 70,997 | 71,100 | 71,599 | 72,000 | 72,500 | 73,000 | 73,500 | 74,000 | 74,500 | 75,000 | 75,500 | |
| Number of House Connections Sounded Each Year | | | | | | | | | | | | | | | | | | | | | |
| Leak team 3 | 27,115 | 83,333 | 60,017 | 61,474 | 62,967 | 64,497 | 66,064 | 67,669 | 69,313 | 70,997 | 71,100 | 71,599 | 72,000 | 72,500 | 73,000 | 73,500 | 74,000 | 74,500 | 75,000 | 75,500 | |
| Number of House Connections Sounded Each Year | | | | | | | | | | | | | | | | | | | | | |
| Leak team 4 | 1996 | 1997 | 1998 | 1999 | 2000 | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2007 | 2007 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 |
| Leak team 5 | 1996 | 1997 | 1998 | 1999 | 2000 | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2007 | 2007 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 |




Table 4.5.6 Meter Replacement Program

| Meter Sizes | Status @ 1995 ave | 1997 Replaced | Backlog End 1997 | 1998 Replaced | Backlog End 1998 | 1999 Replaced | Backlog End 1999 |
|----------------------------|-------------------|---------------|------------------|---------------|------------------|---------------|------------------|
| Domestic Meters 15mm | 39,687 | 5,979 | 35,268 | 7,000 | 29,828 | 7,000 | 24,388 |
| Water Rights 15mm | 27,448 | 8,000 | 21,008 | 7,000 | 15,368 | 7,000 | 10,128 |
| Commercial 15mm | 15,000 | 0 | 15,000 | 2,000 | 13,000 | 2,000 | 11,000 |
| Commercial 20mm | 2,585 | 0 | 2,585 | 0 | 2,585 | 0 | 2,585 |
| Industrial 20mm | 612 | 612 | 0 | 0 | 0 | 0 | 0 |
| Industrial 32mm | 300 | 300 | 0 | 0 | 0 | 0 | 0 |
| Industrial 40mm | 200 | 200 | 0 | 0 | 0 | 0 | 0 |
| Governmental 20mm | 609 | 609 | 0 | 0 | 0 | 0 | 0 |
| Governmental 32mm | 200 | 200 | 0 | 0 | 0 | 0 | 0 |
| Governmental 40mm | 100 | 100 | 0 | 0 | 0 | 0 | 0 |
| Backlog of Meters = | 86,741 | | 73,961 | | 60,981 | | 48,101 |


| | | | |
|-----------------------|--------|-----------------------|--------|
| Total Meters Replaced | 16,000 | Total Meters Replaced | 16,000 |
| Total Meters Replaced | 16,000 | Total Meters Replaced | 16,000 |

| Meter Sizes | 2000 Replaced | Backlog End 2000 | 2001 Replaced | Backlog End 2001 | 2002 Replaced | Backlog End 2002 | 2003 Replaced | Backlog End 2003 |
|------------------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|
| Domestic Meters 15mm | 7,000 | 18,948 | 9,312 | 11,196 | 12,756 | 0 | 0 | 0 |
| Water Rights 15mm | 7,000 | 4,688 | 4,688 | 1,560 | 1,560 | 0 | 0 | 0 |
| Commercial 20mm | 2,000 | 9,000 | 2,000 | 7,000 | 1,694 | 5,316 | 7,901 | 0 |
| Industrial 20mm | 0 | 2,585 | 0 | 2,585 | 0 | 2,585 | 2,585 | 0 |
| Industrial 32mm | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Industrial 40mm | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Governmental 20mm | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Governmental 32mm | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Governmental 40mm | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total Meters Replaced | 16,000 | 35,221 | 16,000 | 22,341 | 16,000 | 7,901 | 10,486 | 0 |

| | | | |
|-----------------------|--------|-----------------------|--------|
| Total Meters Replaced | 16,000 | Total Meters Replaced | 16,000 |
| Total Meters Replaced | 16,000 | Total Meters Replaced | 16,000 |

BARADA Spring *
 No. of wells : 19 + 2 (under construction)
 Pumping water yield : 14.30 million m³/year

* Current Situation (Jan. 1996)
 9 Wells
 12.2 million m³/7 months



LEGEND

Q : Average flow (m³/sec)
 (Max. Flow m³/sec)


Cap. : Capacity

○ : Reservoir in Damascus City


K.I : Official code of Reservoir


JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
 Figure 4.3.1 Existing Water Supply System in Damascus
 (on Jan. 1996)
 NIPPON KOEI CO., LTD.

(Source : DAWSSA)




JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
 Figure 4.3.2 Schematic Diagram of Water Supply System
 NIPPON KOEI CO., LTD.






(Source : DAWSSA)


| | |
|---|--------------------------------------|
| JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) | |
| THE STUDY ON THE DEVELOPMENT OF WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY | |
| Figure 4.3.4 | Pressure Zones and Official Area No. |
| NIPPON KOEI CO., LTD. | |



House connection type for new building




House connection type for tall building



JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY

Figure 4.3.5 Typical House Connection


NIPPON KOEI CO., LTD.



Legend :
 ← --- → Micro Wave
 ← ····· → UHF
 ← ——— → Optical Fiber Glass Cable in New Tunnel

Note : Existing PABX (private automatic branch exchanger) will be used for back-up system.

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
 Figure 4.3.6 Schematic Diagram of SCADA System
 NIPPON KOEI CO., LTD.



JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 THE STUDY ON THE DEVELOPMENT OF
 WATER SUPPLY SYSTEM FOR THE DAMASCUS CITY
 Figure 4.6.1
 DAWSSA Organization Structure
 NIPPON KOEI CO., LTD.