5. PLAN FORMULATION

5.1 Basic Concepts for the Formulations of Plans

The plan was made up to the year 2015 based on the deficiencies in the existing system, the results of water resources development potentials for DAWSSA examined, and considering the level of urgency for water requirements identified through the study.

The basic concepts for the formulations of plans are as follows:

- i) Reducing unaccounted for water (UFW) in the existing distribution system,
- ii) Maximizing the use of all existing water resources,
- iii) Looking for opportunities to increase available water by sharing existing resources with others before developing new resources,
- iv) Consisting with the Proposed Damascus City Urban Development Master Plan.

5.2 Service Area

The areas to be served in the future by the water supply system are determined, as described below taking into account following information and data from DAWSSA, and by the field investigation carried by the Study Team.

(1) Master Plan and Land Use Plan

Damascus Municipality has been preparing the New Damascus City and Regional Master Plan for the targeted year 2020. The conceptual development plan for the Damascus City (the City) is proposed by the Damascus Municipality as shown in Figure 3.2.1.

According to the Master Plan, the administrative area of the City will expand from 106 km² in 1995 to 180 km² in the year 2020. The Master Plan has prepared a general land use plan for the year 2020 which covers the city administrative area as shown in Table 3.2.3. While this land use plan is not approved yet by the Government, this is considered to provide a basic guideline for identifying future service area requirements.

The service areas to be supplied by DAWSSA will be dependent on the implementation plan for the enlargement and development of the City. The implementation plan, however, has not yet been prepared by Damascus Municipality. The Study Team and DAWSSA, have proposed a tentative implementation schedule for the enlargement and development of the City, considering the probability of water resource development within the area of DAWSSA's future

(2) Informal areas

Informal connection areas were identified with the survey conducted by the Study Team and DAWSSA as shown in Figure 5.2.1. Total informal area is estimated 10.5 km² with approximately 10 % of total area of the City (106 km²), as shown in Table 5.2.2. The Damascus Municipality has been started to improve infrastructures in the informal areas, such as water supply, electricity supply and sewerage. The future service area shall include the informal areas according to the improvement schedule to be prepared by the Damascus Municipality and DAWSSA.

(3) Service area

Based on the City Master Plan, Land Use Plan in the Future, and Tentative Implementation Schedule, together with consideration on the improvement of informal areas, the projection of the future service area up to the year 2015 is proposed as shown in Table 5.2.3. The served area up to the year 2015 is summarized below;

| | 1 1 | | | | (Unit: km²) |
|----------------------|--------|--------|--------|--------|-------------|
| | 1995 | 2002 | 2005 | 2010 | 2015 |
| Villages | 5.12 | 5.12 | 5.12 | 5.12 | 5.12 |
| New development Area | 0.25 | 1.49 | 4.49 | 12.10 | 23.80 |
| The Existing City | 106.25 | 106.25 | 106.25 | 106.25 | 106.25 |
| Total | 111.62 | 112.86 | 115.86 | 123.49 | 135.17 |

Land use in the water supply service area is classified by Damascus Municipality as described in the Section 3.2. Land use of the existing city and villages served by DAWSSA will not be changed so much from the existing conditions according to the New Damascus City Master Plan.

5.3 Population Projection

This section presents the population projections for Damascus City Governate, areas along the Barada river valley serviced by DAWSSA and new development areas which will require servicing in the future. The projections are based on census data obtained from the Central Bureau of Statistics (CBS). Reference is also made to the Master Plan being prepared by the Municipality of Damascus for new development areas. The population projections are used to estimate domestic water consumption demands and plan for the appropriate

Ħ

development of the water supply system until the year 2015. Census data and population estimates are presented in detail in Appendix G of the supporting report.

5.3.1 Central Bureau of Statistics (CBS) Population Projections

In 1994 the CBS conducted a detailed census across the nation. The country's average annual growth rate over the 1981-94 period was 3.3%. The average annual growth rate in Damascus has not followed the national trend and has declined steadily over the past 15 years to an average of 1.75% per annum over the 1981-94 period. This is one of the lowest in the country for large urban centers. The total population located within DAWSSA's current jurisdiction reached 1.57 million in 1995. This population includes all inhabitants of informal settlements and rural areas along the Barada river served by DAWSSA. While growth rates for Damascus City have declined, growth rates in rural Damascus have increased rapidly over the same period by an average of about 5% per year. Population projections provided by CBS are summarized as follows:

| Year | Population | % Growth rate** |
|------|------------|-----------------|
| 1995 | 1,414,000 | |
| 2000 | 1,539,000 | 1.71 |
| 2005 | 1,673,000 | 1.68 |
| 2010 | 1,802,000* | 1.50 |
| 2015 | 1,942,000* | 1.50 |
| 2020 | 2,092,000* | 1.50 |

population projections are not officially published and based on discussion

The CBS forecasts declining growth rates for Damascus City until the year 2005 when the population is expected to reach 1.673 million. Projections beyond the year 2005 are not published, however discussions with CBS officials indicates they expect the average growth rate to continue declining to 1.5% and hold steady until the year 2015 when the population of Damascus City would reach 1.942 million.

5.3.2 Damascus Municipality Master Plan Population Projections

The Municipality of Damascus is currently preparing a new master plan to guide urban development up to the year 2020. The basic concept is to provide new development areas along the pattern of the existing City, and extend the administrative boundary to include existing informal areas. New residential developments located on the outskirts of Damascus City are proposed to accommodate future growth. The plan assumes average growth rates in

^{**} rate based on compound growth formula Pt=Po (1+r)'

Damascus City will decline to 0.6 % per year by 2015 when the population is expected to reach 1.934 million as shown below:

| Year | Population | % Growth rate** |
|------|------------|-----------------|
| 1995 | 1,468,000 | |
| 2000 | 1,621,000 | 2.00% |
| 2005 | 1,772,000 | 1.80% |
| 2010 | 1,878,000 | 1.17% |
| 2015 | 1,934,000 | 0.59% |
| 2020 | 2,000,000 | 0.67% |

^{**} rate based on compound growth formula Pt=Po (1+r)*

Based on the results of the previous master plan, it is not unreasonable to expect that population densities inside the City Governate will increase, especially if unauthorized construction continues. Therefore, the lower growth rates anticipated by the Municipal Master appear to be slightly optimistic. For these reasons, the Water Supply Master Plan assumes a slightly higher growth rate scenario for Damascus City based on an average of 2% per annum.

The Municipal Master Plan projects that growth rates for population centers outside Damascus will increase from 4.5% in 1995 to 5.78% in 2015. The master plan does not yet identify populations projections for the proposed residential development areas. Based on the rural growth rates developed in the Municipal Master Plan the service population outside of the existing administrative boundary is estimated to the year 2015 as follows:

| Year | Population in Rural Governate* | Average growth rate % | DAWSSA Service Population Outside Damascus City |
|------|-----------------------------------|-----------------------|---|
| 1994 | | | 138,526** |
| 1995 | 375,000 | 4.50 | 144,760 |
| 2000 | 468,000 | 4.53 | 180,660 |
| 2005 | 600,000 | 5.09 | 231,615 |
| 2010 | 770,000 | 5.12 | 297,240 |
| 2015 | 1,020,000 | 5.78 | 393,746 |
| 2020 | 1,260,000 | 4.32 | 486,392 |

^{*} obtained from Municipal Master Plan

^{**} based on population census and JICA study team estimates refer to Table 5.3.1

5.3.3 Informal Population

In order to estimate water demand, and rationalize unaccounted for water it is important to estimate how many people are informally connected to the distribution system. Unfortunately official statistics identifying this component of the population are unavailable. The JICA study team has, with DAWSSA's assistance, estimated the informally connected population based on two calculation methods.

The first method compares the total number of households reported by the census for all of Damascus City to the total number of domestic subscribers reported by DAWSSA. Taking the difference between the two provides 42,512 unmetered households. Assuming an average of 8 persons per informal dwelling yields an estimated informally connected population of 340,096. When adjusted to include the informal areas of Takadom and Kudsaya which are not included in census figures the informally connected population becomes 400,000.

The second calculation method, preferred by DAWSSA, consists of calculating the ratio of informal dwellings to the total number of dwellings in a district reported by census. This ratio is then applied to the total population in the district to estimate the proportional number of informally connected people. This method yields an informal population of 398,922 based on 1994 census data. Applying a growth factor of 2% for 1995 gives a total informal service population of 407,000. This figure is adopted for the Water Supply Master Plan.

5.3.4 Population Projections for Water Supply Master Plan

The total service population for water demand projections is estimated for existing and future development sites proposed by the Municipality Master Plan. It is assumed that DAWSSA's mandate will expand to include the new development sites proposed by the plan. This study examines three possible population growth scenarios:

- Scenario 1. A high growth forecast based on the population momentum created by a young age distribution. This scenario forecasts a service population increasing along an exponential growth curve. The result is a total service population of 3.2 million by the year 2015.
- Scenario 2. A moderate growth forecast which shows de-concentration to other urban centers outside Damascus City Governate. A stable average annual growth rate of 2 % is assumed for Damascus City Governate and growth rates established by the municipal master plan are assumed for new development areas and existing rural service areas along the Barada river. This forecast results in a

total service population of 2.5 million by the year 2015.

Scenario 3. A slightly lower growth forecast based on the municipal master plan which assumes a high level of migration to new development sites outside Damascus City and a sharply declining growth rate for Damascus City. This forecast results in a slightly lower total service population of 2.3 million by the year 2015.

There is no strong indication from current trends that population growth rates in Damascus City will suddenly increase over the study period. Past urban growth trends indicate stable or slightly declining growth rates in large urban centers are likely to continue. Therefore the exponential growth scenario of scenario 1 does not appear to be likely.

The population forecast provided by the Municipal Master Plan is based on annual growth rates which decline sharply from 2% to 0.6% within a 20 year period. This reduction is considered slightly optimistic. Although birth rates will likely continue to decline in response to rising education levels, the momentum created by the relatively young population distribution makes a continued sharp decline in growth rates highly unlikely. Therefore the present study assumes that scenario 2 with it's moderately distributive growth forecast is the most likely growth scenario. This growth forecast results in a service population of 2.5 million by the year 2015.

- 5.4 Water Requirement
- 5.4.1 Water Use Condition
- (1) Service area and population served

The service area in the year 2015 will reach an estimated 135.17 km² including the existing villages as described in the above-mentioned Section 5.2. The future service area at 5 years intervals is shown in Figure 5.2.2.

The existing population served is estimated at 1,150,000 multiplying the total number of billed domestic connections by the average number of persons per domestic connection (6 persons per family from the result of the interview survey carried out by the JICA Study Team). Targeted population to be served in 2015 is estimated at 2,501,000. Population and population density in the service area is summarized in Table 5.2.3.

Total population in the informal areas is estimated at approximately 407,000 persons in 1995 as shown in Table 5.2.2. The informally connected population will decrease according to the improvement projects identified in the master plan for the informal areas as follows:

| | 1995 | 2000 | 2005 | 2010 | 2015 |
|---|------|------|------|------|------|
| Number of Informal Residents (1000 persons) | 407 | 157 | 17 | 0 | 0 |
| Percentage of Informal residents to Total population (%) | 26 | 10 | 1 | 0 | 0 |

The existing population in the service area based on Census data is 1,239,000 as described in the Section 5.3. Targeted population served and proportion of population served are follows:

| | 1995 | 2000 | 2005 | 2010 | 2015 |
|----------------------------------|-------|-------|-------|-------|-------|
| Service Level (%) | 74 | 90 | 100 | 100 | 100 |
| Population Served (1000 persons) | 1,150 | 1,563 | 1,949 | 2,205 | 2,501 |

Almost 100 % of the population are served by the DAWSSA water supply with the exception of some of the number of the informal residents, in 1995.

(2) Water consumption

DAWSSA, at present classifies their consumers into 5 water categories, Water Right Obligations, Public & Religious Use, Domestic Use, Governmental Use and Commercial & Industrial Use mainly as shown in Table 5.4.1. Public & Religious consumption appears to include Uncounted for Water (UFW), since most mosques and churches have no meter or no meter reading. Domestic Use in the past 5 years accounted for almost 70 % to the total water consumption excluding Public & Religious Use as shown in Table 5.4.1. Table 5.4.2 shows the existing water consumption without UFW in 1995 from the billing records. Billed water consists of Domestic Use with 73 %, Commercial Use with 4 %, Industrial Use with 1 % and Government Use with 22 %.

Since 70 % in total water consumption is domestic users, it is proposed, for the purpose of projecting future water consumption to classify consumers into 2 major categories, Domestic Use and Non-Domestic Use. Non-Domestic Use is further classified into 14

categories as described below. For this Study, the projection of future water consumption is forecasted by the classified water use method instead of the past trend method.

1

(3) Domestic use

1) Classification of income level

The population served is classified into three income groups and one informal group. The informal group is divided into two income groups, Middle income (17.5 %) and Low income (82.5 %). All groups are able to afford a service connection and are willing to pay for water according to the result of the interview survey. It is assumed that all groups will receive water from properly connected and metered services.

Future distribution of income level in the year 2020 is forecast in the Damascus Municipal Master Plan with High income (20 %), Middle income (40 %) and Low income (40 %). As detail information on this distribution is not available, the Study Team and DAWSSA has assumed the future distribution of income level based on the interview survey and economic trends as follows;

| | | | (Unit: % | to the Total | Population) |
|--------------------|------|------|----------|--------------|-------------|
| | 1995 | 2000 | 2005 | 2010 | 2015 |
| High Class | 16.7 | 17.5 | 18.4 | 19.2 | 20.0 |
| Middle Class | 18.0 | 23.5 | 29.0 | 34.5 | 40.0 |
| Low Class | 39.3 | 49.0 | 52.7 | 46.3 | 40.0 |
| Informal Residents | 26.0 | 10.0 | 0.0 | 0.0 | 0.0 |

The assumed population distribution for the low income class has a tendency to increase until 2005, because the majority of informal residents that will be connected officially with the network are in the low income class. Socio-economic conditions are assumed to improve after the year 2005 when the improvement project for the informal areas are completed. This will mean a corresponding increase in the middle income earners after the year 2005.

2) Existing unit water consumption

Unit water consumption per capita was studied by the interview survey, the meter reading survey, and a review of billing records. The resulting average unit domestic water consumption for each group is summarized below;



(Unit: Iped)

| Class | Interview Survey | Meter Reading | Billing Records |
|---------|------------------|---------------|-----------------|
| High | 194 | 212 - 236 | <u> </u> |
| Middle | 183 | 143 - 173 | · <u>-</u> |
| Low | 177 | - | |
| Average | 177 | | 110 |

Taking into account an average consumption per residential connection of 674 l/connection/day which is derived from billing record for the year 1995, per capita consumption is estimated as 110 lpcd by assuming 6 persons per household. Table 5.4.3 shows the ratio of water supply suspension from 1991 to 1995. On average, service is interrupted 4 days per month. The interview survey also indicated that 45 % of residents were supplied with water for less than 12 hours per day. The actual water demand is largely unmet and therefore expected to be higher than the per capita consumption of 110 lpcd. Considering water supply conditions and water meter malfunctions (see Table 5.4.2), the existing average water demand is probably closer to 170 lpcd and is applied as the base for establishing future domestic unit water consumption.

3) Future unit water consumption

Ø

The following general assumptions are made in order to forecast future water consumption;

- Based on past economic trends and current economic indicators, regional economy will continue to grow rapidly.
- At the present, the problems of informal areas has interrupted the economic development in the City.
- Socio-economic conditions will improve after the year 2005, when most of the informal areas will be formally serviced. This will result a large middle income class and a corresponding increase in water demand.
- Unit consumption for each income class is estimated base on the results of the interview survey, meter reading and billing data.
- The percentage in each income class to the total population is based on forecasts providing by Damascus Municipality.

Three alternatives scenarios for the development of future unit domestic water consumption were considered: Alternative I assumes continuing economic development based on recent trends, Alternative 2 assumes increasing water consumption according to high

economic development, and Alternative 3 assumes increasing water consumption after 2005. The alternatives are described as follows:

1

(Alternative 1 - low growth in demand)

- Water demand increases gradually from 1995 up to 2015 according to population projections.
- Unit consumption for both the Middle and Low income classes is estimated considering potential water demand and willingness to pay.
- Unit consumption for each income class does not change over time.

(Alternative 2 - rapid growth in demand)

- Water demand increases rapidly from 1995 up to 2015 according to population projections.
- Potential unit water consumption for Middle and Low income classes is higher than the willingness to pay level.
- Unit consumption each income class does not changed all the time.

(Alternative 3 - moderate growth in demand)

- Water demand increase gradually based on population projections from 1995 up to 2005 and increases rapidly after 2005, when informal areas are improved.
- Potential unit water consumption for Middle and Low income classes is estimated considering potential water demand and willingness to pay from 1995 to 2005. After 2005, unit water consumption is higher than the willingness to pay level.
- Unit consumption of Middle and Low income class increase gradually after 2005 based on assumed improvements in socio-economic conditions.

The unit consumption by income class for tree alternatives are described as follows:

| | | | | | · | | (Unit: lpcd) |
|---------|---------------|---------------|----------|------------|----------|------|--------------|
| ; | Alternative 1 | Alternative 2 | <u> </u> | A 1 | ternativ | e 3 | |
| Class | 1995-2015 | 1995-2015 | 1995 | 2000 | 2005 | 2010 | 2015 |
| High | 250 | 250 | 250 | 250 | 250 | 250 | 250 |
| Middle | 200 | 220 | 190 | 200 | 200 | 210 | 220 |
| Low | 170 | 190 | 160 | 170 | 170 | 180 | 190 |
| Average | | | 170 | 180 | 193 | 204 | 214 |

Water demand projection in this study are based on the unit consumption described for Alternative 3. The proposed unit water consumption per capita assumes the upper limit of unit domestic water consumption per capita is 250 lpcd. This upper limit is considered to be conservative since per capita consumption in the other developed countries is generally less than 250 lpcd as compared with domestic water consumption. Unit water consumption in the future is summarized in Table 5.4.4.

(4) Non-domestic use

Future water demand for non-domestic use will be projected based on the analytical results of records, questionnaire survey and information provided by DAWSSA and other relevant data collected, such as the Future Urban Development Plan (conceptual Plan), land use plan and statistical data. The details of projection for non-domestic use are described in the following.

1) Billing records

1

Table 5.4.2 summarizes water consumption per connection per day for three categories, Commercial, Industrial and Governmental in 1995. The estimated unit water consumption per connection is 0.61 m³/connection/day for Commercial Use, 1.29 m³/connection/day for Industrial Use and 17.59 m³/connection/day for Governmental Use, considering malfunction loss. It should be noted that the unit water consumption calculated from billing record does not represent actual demand because a lack of production capacity resulted in frequent and lengthy interruption in service.

2) Questionnaire survey

A questionnaire survey was issued to the major water consumers, Hotels, Hospitals, Schools, Factories and Governmental Offices including Sports Facilities through DAWSSA. The results of the questionnaire survey are summarized as average unit water consumption per connection below;

| a) Governmental Offices & Facilities | es : | 51 m ³ /d |
|--------------------------------------|------|----------------------------|
| b) Schools | : | $14 \text{ m}^3/\text{d}$ |
| c) University | : | 254 m ³ /d |
| d) Hospitals | : | $370 \text{ m}^3/\text{d}$ |
| e) Sports Facilities | : | 176 m ³ /d |
| f) Hotels | : | 148 m³/d |

g) Large Commercial users 10 m3/d $1 \text{ m}^3/\text{d}$ h) Others (commercial users) $44 \text{ m}^3/\text{d}$ i) Theaters i) Factories 128 m3/d $0.60 \, \text{m}^3/\text{d}$ k) Manufacturing

3) Religious & public facilities from meter reading and information

Meter reading survey was carried out to some of the Religious Facilities. of meter reading are 44 m³/day for the Um-Ayad Mosque, 4 m³/day for other mosques and churches. Based on the information from Damascus Municipality, water consumption per public tap is estimated about 40 m³/day to 50 m³/day. Water to public fountains is supplied by the Municipality. Special uses, such as airport in the City, military division and others, are estimated about 3,000 m³/day as bulk water supply.

4) Future unit water consumption and number of facilities

Future unit water consumption are proposed as shown in Table 5.4.4, considering the above results and information from DAWSSA. Basic factors for water demand projections are summarized as shown in Table 5.4.5. The number of main users are estimated based on the area to be expanded according to the Urban Development Plan, since Damascus Municipality has no detailed information about the main facilities. However, the conceptual plan for the City development and the land use plan indicates that the future land use pattern in the City and surrounding area of the City will not be changed from the existing land use pattern, except for Residential and Commercial areas. The non-domestic water demand projection is therefore estimated based on the present water consumption and land use pattern.

5.4.2 Water Demand Projection

(1)Classified water use method

The water consumption forecast was determined by using the water use classification method instead of the past trend method as described in the previous section. classified as follows;

- a) Accounted Water
 - (i) Billed Water
 - Domestic

- Governmental (office, school, University, Hospital and others)
- Commercial (commercial users with large water consumption, hotels and Theaters)
- Industrial (factory and manufacturing)
- (ii) Un-billed Water
- Water right obligation
- Religious & Public Use (mosques & churches and public taps & special area zone)
- b) Un-accounted For Water (UFW)
 - (i) Meter Malfunction (under estimation of meters & no meter reading)
 - (ii) Informal use including Domestic and Non-domestic uses
 - (iii) System Losses including leakage from the informal areas
- (2) Assumptions for water demand projections

Water demand projections are based on the following assumption;

- a) The population served is estimated based on the census, the number of persons per family from the interview survey and the number of billed water connections in 1995.
- b) The service area is based on the Urban Development Plan.
- c) Water consumption for religious & public use is estimated based on the results of the interview survey and the water meter reading survey, carried out for this Study. Data provided by DAWSSA for the water consumption for the religious & public use includes the UFW and was therefore not used.
- d)Unit domestic water consumption is based on Alternative 3 described in the previous section.
- e) Unaccounted For Water (UFW) is estimated based on the data from the leakage survey, the interview survey and billing record.

(3) Unaccounted For Water (UFW)

1

The overall unaccounted for water at present is estimated at 63 % of water production and consists of 14.4 % for Meter Malfunction, 13.6 % for Informal Use and 34.7 % for System Losses. For the developing estimates of water production required, it is assumed that the following figures are, at present, most realistic, and are adopted for projecting required water production.

- a) Target unaccounted for water in the year 2015 is 25 %.
- b) Target annual reduction rate of UFW at every five years are shown below;

| Year | Annual Reduction Rate of UFW | Percentage of UIW |
|------|------------------------------|-------------------|
| 1995 | | 63 % |
| 2000 | 24 % | 39 % |
| 2005 | 8 % | 31 % |
| 2010 | 3 % | 28 % |
| 2015 | 3 % | 25 % |

c) Amount of UFW is estimated as follow;

| | | | | (Unit | : 1000 m ³ /d) |
|-------------------|-------|-------|-------|-------|---------------------------|
| Type of UFW | 1995 | 2000 | 2005 | 2010 | 2015 |
| Meter Malfunction | 88.6 | 23.5 | 0 | 0 | 0 |
| Informat Use | 81.4 | 31.0 | 8.1 | 0 | 0 |
| System Losses | 204.0 | 241.3 | 241.6 | 254.8 | 248.7 |
| Total | 374.0 | 295.8 | 249.7 | 254.8 | 248.7 |

Meter malfunction including no meter reading is estimated based on the review of 1995 billing data. Informal use is estimated at 200 lpcd per capita water demand.

(4) Seasonal load factor

A seasonal load factor of 1.14 is assumed based on a review DAWSSA's historical records. The peak demand is in August, based on observed correlation between climatic changes and fluctuations of billed consumption in 1995, average water production of the past 10 years.

(5) Water demand projection

Water demand projections are prepared for the three unit water consumption alternatives, as shown in Tables 5.4.6, 5.4.7, and 5.4.8 and summarized as follows:

| | | | | (Uni | t: 1,000 m³/d) |
|---------------|---------|-------|-------|-------|----------------|
| | 1995 | 2000 | 2005 | 2010 | 2015 |
| Alternative | 1 678.0 | 741.7 | 802.9 | 863.7 | 928.1 |
| Alternative : | 2 678.0 | 788.3 | 859.2 | 925.2 | 994.8 |
| Alternative: | 3 678.0 | 750.8 | 813.3 | 900.4 | 994.8 |

As previous discussed, Alternative 3 is selected as the most likely economic growth scenario and recommended for planning the future water supply system, as shown in Table 5.4.8. Classified water demand projection at 5 year intervals are summarized as follows;

| \$ | • | | | (Unit: 1 | 000 m³/d |
|---|-------|-------|-------|----------|----------|
| Classification | 1995 | 2000 | 2005 | 2010 | 2015 |
| A. Domestic Use | 126.1 | 272.1 | 376.9 | 449.4 | 535.2 |
| B. Non-Domestic Use | | | | | |
| B.1 Governmental Use | 37.3 | 99.7 | 102.4 | 109.2 | 119.6 |
| B.2 Commercial Use | 7.8 | 23.9 | 24.6 | 26.2 | 28.7 |
| B.3 Industrial Use | 1.5 | 6.2 | 6.3 | 6.7 | 7.4 |
| B.4 Water Right Obligation | 40.7 | 42.5 | 42.5 | 42.5 | 42.5 |
| B.5 Religious & Public Use | 10.5 | 10.6 | 10.9 | 11.6 | 12.7 |
| Total | 223.9 | 455.0 | 563.6 | 645.6 | 746.1 |
| Effective Ratio of Total Water Requirement (%) | 37 | 61 | 69 | 72 | 75 |

^{*:} Water consumption in 1995 is estimated from billing record.

5.4.3 Forecasted Water Requirement

(1) Daily water requirement

Daily water requirements is projected below:

| | | | | (Unit | : 1000 m³/d) |
|---|-------|-------|-------|---------|--------------|
| | 1995* | 2000 | 2005 | 2010 | 2015 |
| 1. Accounted Water Demand | 224.1 | 455.0 | 563.6 | 645.6 | 746.1 |
| 2. UFW | 374.0 | 295.8 | 249.7 | 254.8 | 248.1 |
| 2.1 Meter Malfunction | 88.6 | 23.5 | 0.0 | 0.0 | 0.0 |
| 2.2 Informal Use | 81.4 | 31.0 | 8.1 | 0.0 | 0.0 |
| 2.3 System Losses | 204.0 | 241.3 | 241.6 | 254.8 | 248.7 |
| 3. Average Water Requirement | 678.0 | 750.8 | 813.3 | 900.4 | 994.8 |
| 4. Maximum Water Requireme (Load Factor: 1.14) | | 855.9 | 927.2 | 1,026.5 | 1,134.1 |
| 5. Water requirement per capit (lpcd) | a 285 | 291 | 289 | 293 | 298 |

^{*} Data in 1995 are provided by DAWSSA and JICA.

(2) Annual water requirement

Based on the projected water demand, monthly and annual water requirements are estimated as shown in Table 5.4.9. Water requirement at 5 year intervals is estimated respectively as 274.0 MCM/year in 2000, 296.9 MCM/year in 2005, 328.6 MCM/year in 2010 and 363.1 MCM/year in 2015.

(3) Water supply for new development areas

The schedule for providing water supply services to the new development areas is shown in Table 5.4.10. The schedule was formulated considering to availability of water resource capacity, the selection of priority schemes by DAWSSA and the conceptual plan for the Urban development in the City prepared by Damascus Municipality. Water requirement estimates assuming the ratio of water losses is 25 % even in the newly constructed areas.

According to the schedule, Dummar Extension Area (1st phase) and the residential area in Special Area Zone (State Factory) will be require water supply in 2000, Kudsaya New Suburb will need require water supply by 2005. After the year 2005, a deficit will occur between DAWSSA's improved water production capacity and the water demand.

It is assumed that the development of new residential areas proposed by Damascus Municipality can only proceed if new water resources are developed. Assad Suburb (1st phase and 2nd phase), however, can be supplied in 2010, because this area has its own water supply wells located in the rural area. By 2010, DAWSSA, will not be able to supply water to Dummar Extension Area (2nd phase), Assad Suburb Extension Area and Assad City, since the estimated water production from new water resources schemes will not be able to meet the water demand of these new development areas.

(4) Water requirements in proposed service areas

Service Areas are proposed as shown in Figure 5.2.2. Water supply to the proposed service areas is estimated as shown in Tables 5.4.10, from the year 2000 up to the year 2015. Figures 5.4.1 and 5.4.2 respectively show water requirements to proposed service areas in the year 2005 and 2015. The estimated water requirement takes into consideration that the land use pattern in the existing service areas will not change significantly.

Water requirement in proposed Service areas is summarized at 5 year intervals as follows;

| Migraphy magniphing and apply of the state o | | الإوسىيات الراجع الإوسال المالية الإوسال المالية المالية المالية المالية المالية المالية المالية المالية المالية | (1) | 000 m³/day) |
|--|-------|--|-------|-------------|
| Year | 2000 | 2005 | 2010 | 2015 |
| Villages | 53.7 | 56.9 | 60.5 | 65.3 |
| New Development Areas | 8.5 | 21.5 | 43.6 | 73.3 |
| Existing City | 688.6 | 737.9 | 796.3 | 856.2 |
| Total | 750.8 | 816.3 | 900.4 | 994.8 |

(5) Proposed water production

Raw water production is proposed as shown in Figure 5.4.3. Production and conveyance losses are assumed to be low at less than 1 %, since Figeh spring, the main water resource, is conveyed through the tunnel and the other water resources are groundwater. In this figure, the past average water requirement in 1986 and 1990 is assumed based on the average water requirement in 1995. Daily maximum water requirement is calculated by using the load factor of 1.14.

It is supposed that a water deficit will occur after the year 2005, since the capacity of water resource is limited to 296.9 MCM/year (9.4 m³/sec) based on DAWSSA's existing water rights. Therefore DAWSSA must develop new water resources after the year 2005 to meet increases in demand. Efforts to save water and reduce consumption should be coordinated with Damascus Municipality and the Ministry of Irrigation (MOI) to reduce the need for new resources.

Cooperation with the MOI will be requested to resolve the water deficit after the year 2005. The MOI has the overall responsibility for authorizing water rights and the development of water resources development in the rural areas where a potentiality of water resources is identified in this study.

5.5 Water Resources Development Plan

5.5.1 Water Resources Issues

(1) Water resources organization in Syria

The Ministry of Irrigation (MOI) is the governmental body within Syria that is designated the responsibility for coordinating water usage and planning future water resources development. The Ministry has the authority to issue licenses for the abstraction of water

from surface and underground sources. Due to the historical development of the EPEF it was given the right to the water from Figeh and groundwater within the municipality of Damascus. These rights have been carried over to EPEF's successor establishment, DAWSSA. Within the municipality, the management of water resources, other than those utilized by DAWSSA, is under the overall control of the MOI. However the licensing of abstractions has been delegated to the Damascus Municipality. Possibly as a result of these three organizations all having an interest in Damascus, water resources planning and abstraction licensing is somewhat haphazard.

F

(2) Water resources studies

(a) Observation well network rehabilitation

DAWSSA has a network of 19 observation wells within the City. They are mainly located within the existing wellfields. Recently 7 new observation wells have been drilled in locations remote from DAWSSA wellfields. These holes can provide information on the citywide changes in water levels away from the direct influence of the main centers of pumping. However it has been reported by the water resources directorate that all but one of these holes can not be used for their intended purpose because they are 'full of sand'. It is proposed to rehabilitate the new observation wells to make them suitable for inclusion in a citywide monitoring scheme.

The rehabilitation program should comprise two parts. In the first instance the nature of the problem should be identified, each hole should be plumbed to measure the total depth. Secondly any material in the holes should be removed by airlift pumping, if unsuccessful by redrilling the collapse material. It is recommended that slotted easing should be installed into the holes to guard against further collapse. Should it not be possible to rehabilitate the hole then the drilling of a replacement hole in the same area should be undertaken.

The Master Plan proposes to increase the groundwater abstraction from under Damascus. The extra abstraction will be introduced progressively, during this period it is imperative that the behavior of the groundwaters are studied to ascertain whether the extra pumping exceeds the capacity of the aquifer. This knowledge will be used in the of later stages of the Master Plan.

(b) Hydrological and hydrogeological study and modeling of the city

The objective of this study should be a better understanding of the water fluxes within the City, the relationship between surface water and groundwater, the relationship between waste water, surface and groundwater. This understanding is important in the formulation of plans for the use of the City groundwaters and to establish the likely influence of the future waste water schemes. The changes in flow along the many surface canals should be investigated from El Hame to the eastern boundary of the City urban area. The understanding

of the hydraulic systems may be assisted by the construction of a mathematical model of the groundwater system. Such a model is a useful way of focusing on difficult areas that deserve further investigations. The final model can become a powerful predictive and managerial instrument that would enable the determination of future response of the aquifer system to different pumping scenarios.

(c) Water resources information and analysis systems

A

The data collected by DAWSSA from its various monitoring networks and on the operational details of the sources is stored on the main establishment technical computer system. Although a useful tool for the day to day management of water extraction and supply it is less adaptable to the diverse requirements and analytical capabilities needed for water resources studies. The data that may be called upon for water resources work is various and will include meteorological, hydrological, geological, hydrogeological sources. A more flexible approach is desirable to cope with data on time scales from minute to minute during aquifer testing to decades when looking for long term groundwater and meteorological trends. The capacity of the system to be able to represent information graphically and cartographically would be employed extensively in water resources studies.

Information and analytical systems are widely available for the disciplines that constitute water resources. Most of such software is directed towards the personal computer or network of personal computers, either working under DOS or a Windows environment. Systems may be either standard packages, or customized versions. A need is perceived for software systems to cover the following areas, Pumping Test Analysis, Hydrological / Hydrogeological Database, and, Groundwater Modeling.

Work undertaken on water resources in the preparation of the master plan used 'Ground Water for Windows' (GWW) for storage and reporting purposes. The inventory of almost a thousand wells from DAWSSA, the Municipality and the Ministry of Irrigation has been collated. A copy of the files has been provided to the Water Resources Directorate.

(d) Long term study of Barada spring behavior

Apart from Figeh the sources in the Zabadani Valley represent the largest resource that DAWSSA uses. The understanding of the behavior of the spring-aquifer system to pumping is critical in the future planning of possible schemes. It is opportune to gather data that will help with the through study of the source. Currently one on site observation well is monitored every two weeks and the Barada River at Tekieh is flow gauged. It is proposed that this monitoring is intensified and broadened. The level in the lake and the observation well should both be monitored on a continuous basis with autographic float recorders. The water level in the aquifer at a distance could be monitored in the three wellfields that belong to DAWSSA. The measurement of the actual discharge from the lake should be given the highest priority. Until such time as a proper rated channel section is available at Ramleh

attempts should be made to measure the flow over the penstock and into the irrigation channels.

5.5.2 Alternative Future Water Sources for DAWSSA

(1) Water resources available to DAWSSA

The water resources that are available for use in the vicinity of Damascus are already almost fully committed to water supply and irrigation uses. In the preparation of the Master Plan the maximum utilization of the existing sources is proposed together with limited development of new sources. The rough estimate of the resources is given in the following table.

| Source | Total Replenished Resource with acceptable water Quality (MCM/y) | Estimated Resource available to DAWSSA (MCM/y) |
|----------------------|--|--|
| Figeh Source | 220 | 220 |
| Barada Source | 100 | 34 |
| Sergaya Area | 9 | 3 |
| Deir al Ashayer Area | 7 | 3 |
| Damascus Quaternary | 50 | 50 |

At present about 130 to 185 MCM/y are used from Figeh Source and up to 35 MCM/y from Damascus. The unused portion of the Figeh source over flows into the Barada River during the flood season when the quantity of water from this single spring exceeds the requirement of Damascus. The natural flow of the Barada is about 100 MCM/y, however not all of this is available for use. The flow has reduced to about 70 MCM/y, the water probably being intercepted by irrigation wells before reaching the spring. The MOI has allocated a 34 MCM tranche for use by DAWSSA. The estimates of the resources in the Jurassic aquifer east of Sergaya and the Cretaccous around Deir al Ashayer is based upon water balances for the aquifer units. The water in these two areas is already used for local water supply and irrigation the amount that may be taken is therefore limited. The source of Wadi Marwan is the Cretaccous aquifer block that also supplies Figeh spring. It is anticipated that the use of Wadi Marwan will not create any new resources but will share those that naturally discharge from Figeh. For that reason it is not included in the list of water resources.

The groundwater resources under Damascus are not clearly quantified. Broadly, the resources in the mountainous areas comprise the rainfall less evapotranspiration. Whereas on the plains and foothills the quantification of resources is more complicated. The rainfall less evapotranspiration is much less or negative, and the water resources are those that enter the area either by groundwater flow, surface water streams or conveyed by public water supply distribution systems. The water balance of the whole catchment has been estimated for natural conditions and for the mid 1980's. This balance has been updated with data as is available for the mid 1990's. The zone where the water balance is most different to those pertaining to natural conditions is the city of Damascus and the Ghouta. It is this region where large and

un-measured fluxes occur. The groundwater resources usable by DAWSSA have been set at 50 MCM/y that would be derived from groundwater flow into the area from the Cretaceous, less through-flow of groundwater towards the Ghouta. To this should be added a very small contribution from infiltrated winter rainfall, and then a significant quantity due to leakage from the distribution system, canals, river bed, and, waste water systems. From the groundwater DAWSSA has taken 35 MCM/y and other abstractors an unknown amount. The maximum exploitable quantity is higher than that used at the present. The value of 50 MCM is approximately half the estimated storage in the Pebble Beds, this is assumed to be the safe limit.

Within the duration of the Master Plan schemes will be implemented may reduce recharge to the aquifer. Firstly the leakage from the distribution system is to be reduced especially in the informal areas of the city. Secondly connection to the sewerage system will become more wide spread. This will reduce seepage from soak-aways and for those settlements upstream of Damascus reduce the flow in the river and irrigation canals through the city. If these schemes are successful and there is an overall reduction in absolute amounts of water losses, groundwater recharge quantity will reduce even though the quality will be safeguarded.

(2) Current water sources capacity

The current water resources available to DAWSSA to serve the population in Damascus are summarized below, the details of individual sources are provided in Table 5.5.1.

| Source Name | | Seasonal | | | |
|---------------------|-----------|----------|-------|---------|----------|
| and | Installed | Minimum | Ave | rage | Capacity |
| Туре | (1/s) | (l/s) | (l/s) | (m³/d) | (MCM) |
| Damascus Wellfields | 3,073 | 1,585 | 1,900 | 164,020 | 41.47 |
| Figeh Sources | | | | | |
| Average Year | 12,400 | - i - · | 5,800 | 507,000 | 185.00 |
| Dry Year | • | 2,880 | 3,870 | 334,000 | 122.00 |
| Barada Spring | 1,100 | 1,100 | 1,100 | 95,000 | 23.27 |
| TOTAL | | | | | |
| Average Year | 16,573 | - | 8,860 | 771,220 | 249.74 |
| Dry Year | | 5,565 | 6,930 | 598,220 | 186.74 |

(3) Existing schemes in progress

(a) Figeh Side Spring

The water intake structure at Figeh side spring consists of a sump about 8 m deep. It is equipped with 13 pumps with a theoretical total capacity of 3.25 m³/s, however during operation they produce from a peak of 1.8 to a minimum of 1 m³/s. A scheme to replace the existing water intake structure for Side Spring is under construction. A planned total of 20

new wells each 50 m deep and 762 mm (30") diameter are to be built. The new structure will be able to create a larger drawdown in the wells and it is anticipated that a larger yield will be available. It is anticipated by DAWSSA that a further 500 l/s could be added to the site capacity.

(b) Ain Haroush.

The existing wells at this site are to be replaced by new deeper wells. The additional yield that will be available is expected to be about 800 l/s (69,000 m³/d), or 13.8 MCM over a 200 day pumping period. Two wells have been drilled, each 800 mm internal diameter and 40 m deep, a third well is due to be constructed. The new wells are awaiting testing to evaluate their performance before the installation of pumps and commissioning the source. For the Master Plan there is assumed to be no increase in yield from Figeh from the work in Side Spring or in Ain Haroush.

(c) Barada Group 1, 2 & 3 Wellfields

There are three wellfields north of Barada Spring that were drilled in the 1980's by the Ministry of Irrigation. They are referred to as Groups 1, 2 and 3, and are separate to Barada Spring Wellfield. The right to use these sources has been given to DAWSSA and they are in the process of commissioning the wellfields. The wells that have been designated for inclusion in the new wellfields are itemized in Table 5.5.2. The design capacities are 230, 150 and 70 l/s for the three groups with an achievable average seasonal production for the groups used for the Master Plan are 185, 120 and 60 l/s respectively.

(d) Wellfield at Takadom

The wellfield lies in the South of the City and was drilled in 1989. The wells were performance tested with step tests and the aquifer was tested with a constant rate test. A summary of the step test results is provided in Table 5.5.3. The wells divide into two groups one with small drawdown that are suitable for use as production wells (1, 4, 6, 7, 9, 12 & 13) and the remainder that have high well losses, large drawdowns and a rapid increase in drawdown at high pumping rates (5, 8, 10, 11). It is planned by DAWSSA to install 10 pumps, 3 with 120 m³/hr capacity and 7 with 100 m³/h capacity at this site. For the Master Plan the wellfield has been rated at an average capacity of 140 1/s or 2.96 MCM in 8 months.

(e) Wellfield at Kadam Store

The wellfield lies in the southern area of the City about 500 m to the North West of the Kadam Railway wellfield. The wells in this wellfield are closer together than on other wellfields in Damascus. As a consequence the interference drawdowns can be more significant here than on the other wellfields. Three of the holes are in use and it is planned by DAWSSA to equip all the remaining holes on the site with pumps with a 30 m head and

100 m³/hr capacity. An estimate of the anticipated drawdowns is provided for each well in Table 5.5.4. For the Master Plan the output from the site is estimated as an average of 170 l/s for 8 months.

(f) Wellfield in Wadi Marwan

DAWSSA is working on the commissioning of a wellfield, pipeline and associated works to provide a water supply to the new development area of Kudsaya. The wellfield is located approximately 19 km west of the center of the City. The wellfield comprises 16 wells, three drilled by the Ministry of Irrigation in the 1980's and 13 constructed between May 1990 and September 1992. The wells are all about 300 m deep with 9" or wider casing with a rest water level about 180 m below the surface. The capacity of each hole is in excess 15 l/s and quite possibly as much as 30 l/s could be pumped from each hole. This would give an overall wellfield capacity of 450 l/s or 14.2 MCM over a full year. DAWSSA plans to install 13 pumps each with a capacity of 18 l/s, however for the Master Plan the achievable quantity is taken to be 185 l/s or 5.84 MCM over a full year if pumping.

(g) New Wellfield at Kaboon

A scheme for increasing the abstraction from the area of the existing wellfield is due to start in 1996. In the first phase two deep wells will be drilled, subject to these being successful in obtaining an acceptable yield a further 8 holes are planned for a second phase. For the purpose of the Master Plan it has been assumed that the wells will all be constructed and have an overall yield of 120 1/s, or 2.54 MCM in 8 months.

(h) Wellfield at Dummar

The wellfield at Dummar has not been used since 1991. The wells are due to be recommissioned to supply the local area. Five pumps with a capacity of 30 Vs are to be installed into the wells. For the Master Plan these wells are assumed to operate throughout the year at a rate of 100 Vs, 3.14 MCM/y.

(4) Future water sources for DAWSSA

(a) Options

The future water sources that may be used by DAWSSA are located on Figure 5.5.1. The anticipated capacities are summarized in Table 5.5.5.

(i) Option 1

The first option proposed comprises developing sources to which DAWSSA has been assigned Water Rights. The Rights exist for all the groundwater sources within the Municipality plus Figeh Spring, Wadi Marwan, Deir al Ashayer, Rimeh and the Al Sahl

wellfields near Barada Spring. The quantity that may be taken from Damascus wellfields and from Figeh is limited only by the physical availability of water. Whereas at Barada Spring the Prime Minister has granted a Right to abstract up to 34 MCM per year from the combined wellfields. The MOI has reported on the available water and assigned quantities of 4.1 MCM at Deir al Ashayer and 4.5 MCM at Rimeh for use by DAWSSA.

The schemes that are included in option 1 are; new, equipped and upgraded wellfields in Damascus, a completion of the ongoing schemes near Barada Spring, Wadi Marwan, Figeh and Damascus, and, the development of the Deir al Ashayer wellfield. The use of Rimeh is excluded on economic and financial grounds from the first option.

(ii) Option 2

This option includes all the schemes that are in option 1 plus the promotion of schemes in areas for which DAWSSA has not been assigned Water Rights. These areas are the springs on the Awaj River at Beit Jenn and Tabibiyeh, and also the Rimch wellfield, all which lies south west of Damascus. In the option is also the use of new wellfields at Sergaya and El Irk north east of Zabadani.

(iii) Option 3

Like option 2 this option envisages the use of all the schemes proposed in option 1. In addition a greater exploitation of the Barada Wellfields in excess of the assigned water Right of 34 MCM. An extension of the wellfield around Barada Lake and Spring is considered the best means to increase the abstraction.

(iv) Option 4

The fourth option comprises the combination of all the is the previous options and involves the development of all the water resources identified.

(b) Selection of the most desirable option

The choice of an option of use in the Master Plan is a balance between what will provide sufficient water to the city and yet will not adversely affect the environment, the economic livelihoods of the local population and be a politically acceptable solution. The selection must also be economically and financially attractive to both DAWSSA and to lending agencies. All the schemes proposed are thought to be technically feasible so this is not a consideration for the screening process.

At the time of the Master Plan formulation only option 1 is politically acceptable. The other options have to be approved and accepted by government, something that can not be guaranteed and used for planning purposes. The economic analysis has shown that the scheme at Rimeh has a very low viability and therefore has been excluded from any option. All the options will affect the local availability of water for other uses.

In option 1 this will be confined to the farmers in the Deir al Ashayer area who use groundwater for irrigation. Water levels will be lowered by the proposed wellfield and some of the irrigation wells will be de-watered while in others the pumps will need to be lowered. The scheme at Sergaya and El Irk will intercept water that otherwise would discharge through springs from where it is channeled and used in irrigation. The use of water by EDWSSR from the adjacent areas has already had this effect. The farmers have started to look for other means to irrigate their lands, the drilling of private wells seams to be the most common solution.

The social effect of the Hermon area schemes is likely to be large furthermore there will be an environmental impact on the upper reaches of the Janani River. The spring water is now used in flood irrigation of the land. If all this water is piped to Damascus there will be no viable source of irrigation water in some areas. Within the Awaj basin there is a switch to groundwater for irrigation, this is not always technically feasible for all farmers.

Option 3, the further exploitation of the Barada Spring source, will have an effect upon farming in the Zabadani Valley. The Barada River, whose headwaters are Barada Spring, is used as a source of irrigation water, albeit illegally. The existing quantity taken from Zabadani Valley wellfields reduces the stream flow, as also do private irrigation wells within the spring catchment. The further development of DAWSSA's water use will need to take these factors into account. The substitution of the river as a source of irrigation with another source is one possible solution, but this lies outside the jurisdiction of DAWSSA.

The use of options 2, 3 and also 4 are ruled out on socio-economic and/or political grounds, even though they may be able to satisfy the demand in the year 2015. The choice of option 1 permits the reduction and at times elimination of the seasonal deficit of water currently suffered by the inhabitants of Damascus. The option will achieve these improvements up to the year 2005, by which time all the schemes will have been commissioned and there is a forecast deficit that grows to 46.7 MCM by the year 2015. The deficit in option 2 is 20.8 MCM and for option 3 it is 16.9 MCM at the end of the Master Plan period. Option 4 removes the deficit completely. For the Master Plan, option 1 is the most desirable option and so it is adopted for use. The water production plan and the water sources development plan are base upon this option.

(5) Water sources development plan (Option 1)

The plan is able to increase the capacity of sources from Damascus and Deir al Ashayer to meet the anticipated requirements until the year 2005. The schemes that are quick and will give a proven source of water will be implemented first while the more costly and longer term schemes are programmed to start later. The year when each source will be finished and the extra capacity available is listed below.

| Source | Year | Source | Year |
|---------------------------------------|--------|----------------------------|------|
| Wadi Marwan | 1997 | Kafar Sousch | 2000 |
| Barada Spring Group 2 | 1997 | Tishreen & Kywan Phase II | 2000 |
| Kadam Store | 1997 | Deir al Ashayer | 2000 |
| New Kaboon Phase I | 1998 | Barada Group 3 | 2001 |
| Takadom | 1998 | Shokry al Qouwatly | 2001 |
| Tishreen & Kywan Phase I | 1998 | Ibn Assaker | 2002 |
| Dummar | ∮ 1999 | Fringe Wells | 2002 |
| Jaramana | 1999 | Tishreen & Kywan Phase III | 2002 |
| | 2000 | Kanawat Gardens | 2003 |
| Barada Group 1 New Kaboon Phase II | 2000 | Kadam Railway | 2003 |

The water resources projects can be divided into four types;

- Equipping existing, tested, but unused wellfields. This comprises the installation of pumps, well headworks, reservoir, chlorination and control equipment and site pipeworks. The wellfields to be equipped are at Takadom, Tishreen, Jaramana, Kadam Store, Wadi Marwan, Dummar, Barada Group 1,2 & 3.
- Re-equipping existing wells to increase their production. At these sites the wells are able to produce more water the limiting factor is the capacity of the submersible pumps or the booster pumps. The schemes are at Ibn Assaker, Kadam Railway and the Fringe Wells
- Construction of new wellfields in Damascus. Three of these are at totally new sites, Kafar Souseh, Shokry al Qouwatly and Kanawat Gardens, the third, Kaboon, involves the drilling of more holes at an existing wellfield.
- Construction of new wellfields outside the city. The wellfield at Deir al Ashayer is proposed to use some existing Ministry of Irrigation some new holes.

(6) Water production plan (Option 1)

The key objectives in water production planning for DAWSSA are firstly to be able to satisfy a demand that peaks in August while the sources have their maximum capacity in March-April, and secondly, to meet the demands when the principle source is very variable year to year. To meet these two objectives production plans must be constructed on a monthly basis and also for various hydro-meteorological conditions. A schedule of production is devised for each source for each year of the Master Plan for three hydro-meteorological scenarios. For these three conditions a month by month plan is produced for the years 2000, 2005, 2010 and 2015. See Tables 5.5.6 to 8 for the annual production program. The information for both annual and monthly plans is summarized pictorially in Figures 5.5.2 to 4.

To represent different hydro-meteorological conditions three reference years have been chosen for comparison. These reference years represent average wet and dry conditions. The average conditions are conveniently similar to those experienced in 1995. Dry conditions in 1990 (water year 1989-90) produced a total flow of 141 MCM a flow that is exceeded 90% of

years. For the wet conditions the year 1992 is selected (water year 1991-92) during which an annual flow of 334 MCM occurred, an event that is exceeded less than 5% of years. The reference years were selected to be in the recent past when the measurements are the most reliable and the source was modified by pumping. The total flow from Figeh in future years, is taken to be the same as the total flow in the comparison year, either that by gravity discharge or by pumping. The ongoing schemes at Figeh are assumed for the purpose of the plan to have no effect upon the discharge regime. This is a worst case scenario, since the effect can only be to increase the low flows and reduce the flood of the spring. Making this assumption is therefore a conservative measure, the actual situation achievable being possibly slightly better than that assumed in the production plan. The monthly production from Figeh is either all the flow or that part of the flow that is needed to satisfy the requirements of Damascus:

The total flow from Figeh under the three scenarios does not change for the duration of the Master Plan. It may however be noted that it becomes possible to take a larger proportion of the flow each year in the wet and average scenarios. This is not due to any increase in resources, but a result of higher demand during the flood period when more of the flow can be used. The ceiling on the capacity is however reached in the low rainfall scenario when all the water from Figeh is required to meet the demand and there is no overflow to the river even in a normal year.

At certain times during the Master Plan period there is surplus capacity. When this has arisen preference is made to use Jurassic and Cretaceous sources to permit the groundwater under Damascus to recover. The use of the Quaternary aquifer under Damascus is limited by the area that has acceptable water quality and by the anticipated total resource assessment of 50 MCM/y. The plan anticipates being able to exceed this amount due to the additional, but un-quantifiable recharge from leaking distribution system, waste water system and canals. At the end of the period during an average year 69 MCM are abstracted from Damascus. However during a dry year water use is much more intensive with wellfields operated for 11 months. Storage in the aquifer will be heavily drawn upon during these years that should be offset against years with lower abstraction when recharge will replace the used resource. It is stressed that the volume of storage of good water in the aquifer is comparatively small. The ability of the aquifer to buffer a long period of abstraction with low recharge is small. Thus, with the build-up of abstraction in the lifetime of the plan studies are recommended to monitor the groundwater and hydrological conditions.

Water quality is generally good under the city, however there is a slug of poor water quality that lies roughly north west of the Mezze autostrada. The known poor water quality at the University wellfield has led to its planned abandonment.

- 5.5.3 Outline of Most Promising Schemes for New Water Resources
- (1) New groundwater resources schemes outside Damascus
- (a) Cretaceous aquifer at Deir al Ashayer

Deir al Ashayer lies within an intermontain valley about 25 km west of Damascus and 7 km south west of Tekieh, immediately west of Jabel Mazar and adjacent to the Lebanese border, Figure 5.5.5. To the South east of Mazraat Deir al Ashayer, and just over the border in Lebanon lies a dried lake bed covering almost 2 km². The lake bed and the bottoms of the valleys are intensively used for irrigated agriculture.

The geology of the area comprises limestones of Cretaceous and Jurassic age. The wells penetrate a north-south trough of Cretaceous limestone that lies between higher mountains of Jurassic limestone to the West and east. The eastern side of the Cretaceous is faulted against the Jurassic. The Cretaceous is hydrogeologically isolated from the Jurassic to the West and east with a high permeability zone only about 1 km wide running south to north. The aquifer productive zone is only about 60 to 70 m thick at a depth of between 75 and 135 m below ground surface.

Regionally groundwater flow is from west to east in the Jurassic and Cretaceous strata, but in the Deir al Ashayer area groundwater in the Cretaceous flows to the North towards Wadi Barada. Although the water levels in the Jurassic to west and east are respectively higher and lower than the Cretaceous, the faulted zones act as low permeability barriers. It is considered (by MOI) that very little groundwater flows between the Cretaceous and the Jurassic.

The aquifer properties are quite variable as is illustrated by the range of specific capacities in the tested wells. The transmissivity of well 308K is reported to be 5800 m²/d from a 26 hour airlift pumping test (MOI 1986). A group pumping test was undertaken to assess the hydrogeological conditions in the Dier al Ashayer area. The test used three wells, numbers 844, 846 and 854, pumping at a combined rate of 165.5 l/s for a 44 day period starting in August 1990. Analysis of the testing indicated a transmissivity for the area of 620 to 1000 m²/d and a storativity of between 0.007 and 0.04. These figures together with the geometry of the aquifer and positioning of the wellfield were used to calculate the theoretical drawdowns in a wellfield pumped at a higher rate and for a longer period of time than the group pumping test.

The scheme proposed for the Master Plan is a modified and version of the earlier MOI design. The total scheme operational quantity is revised downwards from 255 to 200 Vs on the basis of use for 6 months in the year. The recharge into the aquifer, rather than well hydraulies, is the limiting factor on water resource utilisation in this area. The yield is based on assessment of the aquifer block in which the long term recharge may be only 7 MCMy.

Construction of a large scale wellfield with a large pumping capacity would be possible, but, after the initial use of aquifer storage, would not be able to be used at an annual rate greater than the recharge. To abstract the water three of the existing MOI wells are proposed plus a further purpose drilled well. The drilling of a further production well to make a wellfield of four holes is recommended, for a number of reasons; Firstly it would enable the wells to be operated at or near to the rates that are known to have been achieved during the group pumping test, secondly, high capacity operation at 80 l/s is ruled out since this would require a pump larger than can be fitted into the easing, and thirdly the overall drawdowns in each well are reduced.

The location for the new well is about 200 m north east of the existing well number 854. This would place it along a track at an elevation of about 1180 masl. The depth of 150 m is chosen to fully penetrate the productive zone of the Cretaceous limestone between 70 and 135 m depth. The hole when drilled may prove to have a low yield, in such a case it another hole should be drilled. The proposed design for the new well is a 150 m deep hole drilled at 12.25" diameter incorporating 70 m of plain and 80 m of perforated 9" casing. The conductor pipe of 13" casing should be 20 m long for a good sanitary seal.

The drawdowns have been calculated based upon the hydraulic properties of the region determined by the group pumping test. The values were used in a well interference calculation. The transmissivity was taken to be uniform and 960 m²/d while a value of 0.03 was used for storativity. To represent the elongate aquifer block image wells pumping were used. They were placed so as to create a 1 km wide high productive aquifer strip, with the pumped wells centrally located. The proposed pumping equipment for the wellfield is listed in Table 5.5.9.

- (2) Groundwater schemes in Damascus, existing wellfields
- (a) Wellfield at Jaramana.

The wellfield consists of one observation and 10 production wells. The holes were mainly drilled in 1990 but were not equipped. The testing shows that the aquifer is highly productive in this area, with a transmissivity of 3800 m²/d causing individual well drawdowns of about 1 m at the tested pumping rate of 30 Vs. The well performance equations determined from the step tests are summarized in the Table 5.5.10. It is proposed that 9 of the wells be installed with pumps with a 40 Vs capacity and all the associated equipment for a pumping station. The site will have peak site capacity of 360 Vs, if an allowance is made for one of the wells to be undergoing maintenance over a 245 day pumping season a yield of 290 Vs or 6.12 MCM is available.

The water quality is typical of the Damascus wellfields. In operation the wellfield may tap poorer water that lies to the East, it is therefore possible that in the medium to long term water quality of the site will deteriorate. To continue using the site it may be necessary to blend water from Figeh to obtain a satisfactory water quality for consumers.

The rest water level at the beginning of the pumping season in May is about 12 m below ground. By November the level will be around 24 m below ground, the drawdown caused by 1.4 m in the well plus 7.6 m of interference effects plus about 3 m of regional recession.

(b) Wellfield in Tishreen and Kywan

This wellfield lies to the West of the current operational source at Oumawiyin. It comprises two parts, Kywan lies to the South of the road to Dummar and beside the course of the Barada River, and the second part lies within Tishreen on higher ground north of the road, Figure 5.5.6.

The five wells in Kywan were drilled in 1989 and tested in April 1990. The tests mainly comprised a 3 day constant rate test and a one hour period of pumping at a similar rate. The results are not amenable to conventional pumping test analysis, however radial flow modeling of wells 2 and 3 can give transmissivities of 3900 and 2300 m²/d respectively. These hydraulic properties would indicate that high yields might be obtainable from the area. However the wells have high drawdowns due to head losses in the immediate vicinity of the hole, thereby reducing the quantities of water that may be produced from the wellfield, Table 5.5.11. Only wells numbers 2 and 3 are really suitable for use as production wells, the remaining holes have very low yields. The two holes can each reliably produce 30 l/s without excessive drawdowns.

The Tishreen part of the wellfield consists of ten wells drilled in 1993 but as yet they also have not been equipped. Only three of the holes at the site are hydraulically efficient and possibly suitable for use as production holes, (nos 3, 4 & 8). Both well losses and aquifer losses are high in the other wells.

To use the wellfield it is proposed that a phased approach be adopted. Initially the best wells should be equipped secondly the lower capacity wells may be used and lastly two new wells may be constructed. The production from the wellfield should be piped to Oumawiyin pumping station for chlorination and addition to the distribution system. The planned capacity of the wells to be equipped in the first phase is 135 l/s, Table 5.5.12. If used operationally for 80% of the time during an 8 month season the production would be 110 l/s and 2.33 MCM. In the second phase smaller capacity and higher head pumps are to be installed. The extra capacity is 120 l/s or an average of a further 100 l/s and 2.03 MCM. The final phase the capacity could be increased by the addition of two wells that could produce a total of 50 l/s. The final potential total installed capacity would be 260 l/s from 16 wells, an average of 210 l/s or 4.44 MCM in an 8 month year.

(c) Fringe Wells

1

1

There are 23 Fringe Wells operate by DAWSSA on the perimeter of the city. The wells are equipped with pumps with 50 m³/h capacity. The wells are used at a typical total output of 9,000 m³/d in the winter months and 12,500 m³/d in the summer. This equates to an average use of 8 and 11 hours per day for each well in the winter and summer respectively. Certain of the wells could produce more water by equipping them with more powerful pumps and possibly increasing the capacity of the network in the vicinity of the source. Wells that have a specific yield of greater than 2 ½/m and do not have records of high nitrates or total dissolved solids are selected for re-equipping. The wells with the revised capacities are listed in Table 5.5.13. An interference plus seasonal regional recession of groundwater levels is assumed to be 5 m.

The estimated net effect of the change would be an overall increase in production of 1.76 MCM in a year. The estimate is based on the newly equipped sources operating 18 hours per day for a six month period each year. During the rest of the year when demand is lower they will operate for fewer hours to produce a similar amount to that produced in the other wells. The unchanged fringe wells are assumed to operate at the existing rates.

(d) Increased abstraction from the existing wellfields

The capacity of the existing wellfields is limited by the storage in the aquifer, the ability of the water to move towards the well and the hydraulic properties of the well. It is considered by DAWSSA that there is still available capacity in the aquifer that may be abstracted by the wellfields and that the limiting factor is the ability of the wells to remove the water from the ground. The wells can be used to pump water from the aquifer so long as the water level within the structure does not fall too far. For the purposes of the evaluation it is considered that the water level should not decline below 25 % of the perforated length of the casing. Using step test data and records from the observation wells the pumping rates that will produce the maximum acceptable drawdown were calculated. The current water levels and the future proposed water levels are listed in Table 5.5.14, together with the data used in the determination.

At Mazraa there is scope to increase the pumping by a small quantity from this site up to about 31,700 m³/d (367 l/s). This could be achieved by increasing the existing overall pumping capacity by 10%. The most favorable wells for the use of larger capacity pumps are operational numbers 8, 10, 12, 13 and 15. Increase in available resources of 33.3 l/s or 0.58 MCM/y. Due to the turbidity known at this wellfield an increase in pumping is not recommended.

The abstraction at 1bn Assaker may be increased to 40,000 m³/d. The lift pumps in the reservoir may be have an increased capacity so as to enable the well pumps to be utilized more efficiently. The wells on the site are used typically only 65 % of the time, by increasing this

utilization to about 90% the site can increase the output by 10,000 m³/d.

The hydraulics of Kaboon do not permit the abstraction of a greater quality from the five existing wells that are currently used. On the contrary it would appear that the water level in the wells may be lowered by more than 25 % of the screen length in some instances.

1

Kadam Railway could yield more water, though there may be long term water quality problems in this area. It is proposed to increase the average capacity of the pumps from 100 to 135 m³/hr. With the current utilization rate this would result in an increase of about 115 1/s.

The capacity of the Oumawiyin pumping station will be increased with the supply from Tishreen and Kywan wellfields amounting to sum 5 to 7 wells with a combined output of up to 195 l/s. It is not proposed to further increase the abstraction from the aquifer in this wellfield.

The University wellfield lies on the interface between good water quality that is actively recharged from the Barada and a poor water area lying to the West towards Mezze. As a consequence the wells on the West of the site have elevated chlorides, sulfates, lead and another determinands compared to the East side of the site. In view of the water quality constraints at this site and the laudable desire from DAWSSA to not induce the migration of poor water quality from the East the site should be considered the last to be utilized. No change to the capacity of the site is recommended. The production plan does not use output from this site.

The well hydraulics of Jobar indicate that no more may be taken from this site without de-watering the aquifer.

- (3) Groundwater schemes in Damascus, new wellfields
- (a) Shoukry al Qouwatly Street

The proposed location is within the parks adjacent to the Barada River opposite the International Fair and the National Museum, see Figure 5.5.7. There are existing wells along the river bank that are used by the Municipality for garden irrigation and fountains.

The zone along the river is anticipated to have hydraulic properties suitable for the construction of high yield wells for a wellfield. In this area the pebble beds are better developed than the rest of Daniascus being over 40 m thick. A transmissivity of over 1000 m²/d can be expected in this area, and individual well drawdowns may be less than 5 m at a pumping rate of 100 m³/hr. In addition the water chemical quality is likely to be good with the total dissolved solid less than 400 mg/l. The rest water level is likely to be about 10 m lower in clevation than at Oumawiyin in May or June, that is an absolute elevation of 685 m in 1994 or about 5 m below ground level.

The natural groundwater flow direction is from the north west, whereas the Barada is aligned east to west. The abstracted water will be derived from a radius around the wellfield and may in addition induce leakage from the Barada River. River water quality is an important consideration in the viability of this scheme. However, the effective 'filtering' of river water through the aquifer will improve some of the river water chemical characteristics. The fountains in the Barada are supplied by wells adjacent to the river, a sample of this water has an electrical conductivity of 620 µS/cm and does not have any problems with the major ions chemistry.

To utilize the groundwater at the site an exportation cum observation well and five high yield wells are proposed. It is anticipated that the holes will need to be 75 to 80 m deep to fully penetrate the highly productive sediments. The first hole should be tested to check the aquifer properties and water quality prior to the establishment committing it's self to the location. Subject to the exploration hole having a transmissivity of greater than 1500 m²/d and producing water of a drinking water standard the five production wells may be drilled. The productions holes will be drilled at a diameter of 20" to permit the installation of 17" casing and slotted casing. A large diameter is recommended to enable the well to have a specific yield of more than 10 l/s/m, this could permit each hole to abstract 150 m³/h with a drawdown of less than 4.3 m. An additional drawdown of 7 m can be anticipated from other wellfields plus an interference between the wells of up to 17 m through a typical pumping season from May to the beginning of the natural recharge in November or December. A pumped water level of up to 33 m below ground level is expected here.

(b) Kanawat Gardens wellfield

The proposed location for a new wellfield is within the triangle of land at the junction between Abu Baker as Swddik Street and 17th April Street, see Figure 5.5.8. The land is now used for small farms in the center of the plot, but the wellfield is planned to be constructed on the perimeter of the area to minimize the effects on the existing land users. The site is chosen to be in an area where the aquifer is good, the highly productive pebble beds are about 30 m thick under the site and the rest water level about 10 m below the surface. The location is also a balance between poor water quality to the West in Mezze with elevated sulfates and chlorides and higher nitrate water towards Kadam.

The proposed wellfield will have 5 production and one observation hole. Each will be 70 m deep to fully penetrate the aquifer. The design should allow for 20 m of plain and 50 m of perforated 9" diameter casing to be installed into a 12.25" hole, and 10 to 20 m of 13" casing for the conductor pipe. The anticipated capacity of the wells will permit the installation of a 25 l/s pump, giving an average site production of 80 l/s or 1.69 MCM over an eight month period.

(c) Kafar Souseh wellfield

The wellfield, proposed by DAWSSA is of a very similar type to the Kanawat Gardens wells. The location is beside the Municipality offices, Figure 5.5.9. The wellfield is to the South east of the proposed Kanawat Gardens wellfield, as such the hydrogeology and the hydrochemistry is expected to be similar. The well design and capacity are the same as the Kanawat Gardens site for the planning in the Master Plan.

-

83

5.6 Comparison and Selection of Master Plan Projects

5.6.1 Approach

Several projects have been proposed to improve existing water supply conditions and meet future water demands. In order to assess if a project will be included in the master plan, it is evaluated and compared to other alternative projects using technical, economic and environmental criteria. The principal approach used for comparing the various candidate projects is described as follows:

- i) Countermeasures for unaccounted-for water (UFW) are generally the least costly way of increasing water available for consumption since they defer the need for expensive water resources development schemes. Therefore these projects are preferred for immediate implementation.
- ii) Improving water supply conditions in the informal areas has been identified as a priority by municipal authorities. Projects to extend the distribution network and provide proper service connections are selected for the master plan except where DAWSSA has already initiated a feasibility study.
- iii) Water supply projects required for new development areas identified in the Municipal Master Plan are selected if they needed before the target year of 2015 identified in the Water Supply Master Plan.
- iv) Water resources development projects are screened on the basis of availability of water

All the projects identified as candidates for the master plan are listed in Table 5.6.1 and described in detail in the sections that follow. The projects are classified into one of the following three groups:

i) Rehabilitation and Supply Improvements: Schemes in this group include rehabilitation

projects to reduce system losses and unaccounted for water, and improvements in water quality testing.

- ii) Ongoing and Planned Water Supply Improvements: Schemes in this group have already been identified by DAWSSA and are either under construction or in the planning stage. Projects in this group include supply improvements for informal areas.
- iii) Proposed Water Supply Schemes: Schemes in this group are proposed by the JICA-DAWSSA study team based on the proposed Damascus City Master Plan (2020), results of water resources study by Ministry of Irrigation, and a hydrogeological assessment carried out by JICA-DAWSSA study team.

5.6.2 Rehabilitation and Supply Improvement Schemes

(1) Water main replacement

1

The total length of distribution mains in 1996 is about 1,000 km. A variety of materials have been used over the years. In general the older mains are east iron pipe and the younger mains are ductile iron pipe, and steel pipe (see Chapter 4.5).

The cast iron pipes, most of which are 80 years old, inferior lead joints which are susceptible to high leakage rates. Leakage is also high at connection points and valves in comparison to other pipe materials. Therefore, the replacement of cast iron pipes is one of the measures proposed to effectively reduce water losses in the distribution system. The total length of cast iron pipe is about 124 km. Only 22 % of the cast iron pipes were installed in the 1970's. These are considered to have some useful life remaining and do not need to be replaced. The balance of the cast iron pipes, approximately 98 km (78%), were installed before the 1970s, and should be replaced ductile pipes. The implementation schedule for water main replacement program is shown in Table 4.5.2.

(2) Water meter replacement

There is a huge backlog of defective or unreadable meters waiting to be repaired (more than 86,000 or 30% of house connection) and a substantial amount of revenue is being lost to malfunctioning meters. The most common domestic consumption meter in use is the Syrian made Doris multi-jet meter. Testing revealed that as many as 22.73 % of these meters fail to record at minimum flow levels although—they perform very well under specified maximum and normal flow conditions. In addition to above, the multi-jet design requires that the meter be

installed in a horizontal plane to prevent distorted readings.

There are two meter replacement options that are considered. One option is to retain the existing Syrian made meter and increase the level of replacement and repairs. The second option is to import foreign made rotary piston type meters which have a high degree of accuracy at minimum flow of +/- 1.5%. The rotary piston meter facilitates installation in the horizontal or vertical plane which is seen as an advantage. Based on technical and economic evaluation it is recommended that existing Doris meters be replaced with a more reliable and accurate rotary piston type meter.

(3) Improvement in meter testing and repairing

Currently, DAWSSA has only one meter repair facility which is staffed with only one meter repair man. There is a large backlog in meters waiting for repair. This backlog will likely increase since meter failure rates appear to be holding steady at 30% and the number of service connections is increasing. Replacement of Syrian made meters with imported meters will require the installation of new test bench. More staff will likely be required regardless of which option is selected however, selecting imported meters will require a separate specially trained repair team until the old meters are phased out.

(4) District Meter Area

The implementation of District Meter Areas (DMA) is an essential requirement for an effective leakage control strategy as mentioned in Chapter 4.5. Without any information on district flows, it is impossible to determine accurate leakage levels or pin-point where maintenance and leakage should focus their efforts. The DMA system is required to reach the targets identified for reduction of system leakage.

(5) Leakage survey (Active leakage detection program)

The leak detection section currently has three teams who are systematically working their way through Damascus looking for leaks. It is important that when leaks are found they be repaired in as short a time as possible. It is proposed that staffing in the leakage detection section be increased from three teams to four teams by the year 1998. Combined with the implementation of the DMA system, proposed staffing levels will enable full coverage of Damascus. The section will need to be further expanded by the year 2010 to cope with expansion and an aging system.

(6) Pressure control

1

The effectiveness of leakage control efforts can be greatly enhanced by controlling system pressure. Pressure control is critical since it significantly reduces leakage rates and therefore the quantity of water lost when a leak develops. Where possible, advantage of the latest pressure control pressure control valve technology should be used to automatically regulate pressures in response to varying water demand patterns. Reducing the pressure will not only reduce the level of leakage, but will also reduce the quantity of water used in what can be described as open tap use (widespread in Damascus). Pressure reduction will also reduce the frequency of pressure related mains breaks.

(7) Improvements in master metering

The recording of water flow from reservoirs and pumps, daily and hourly water supply amounts, is helpful to identify yearly, seasonal and hourly trends in water production and water use. Master metering is essential for optimizing system operation and providing the information required by management to formulate future operational plans. In the present condition, only 28% of the total requirement for water flow measurement at service reservoirs and booster pump stations is adequately covered. Another 24% of the requirement is covered by non-functional meters and the balance of 48 % has no provision for metering. A total of 59 master meters are required including the replacement of 20 non-functional meters as listed in Table 5.6.2.

There are four types of flow meters available: (i) turbine, (ii) a venturi tube, (iii) a electromagnetic and (iv) a ultrasonic. The electromagnetic flow meter offers the most advantages in terms of accuracy, ease and flexibility of installation, and minimal maintenance requirements. The ultrasonic flow meter is the second best choice. It is therefore recommended that electromagnetic flow meters be used for applications on pump discharge piping and the ultrasonic flow meter be used in gravity flow applications from service reservoirs.

(8) Water quality testing improvement

The quality of the water supplied by DAWSSA, discussed in section 3.4, is less than ideal in the dry season. Parameters of concern include high levels of nitrate and hardness. Surface water in Damascus is already heavily contaminated, and may deteriorate the groundwater quality in the future. In spite of these alarming facts and potential problems, potable water in Damascus is being consumed virtually untested. DAWSSA's water quality

testing laboratory has a limited capacity and can only analyze 30 samples/day for general water quality analysis. The lab does not analyze for pesticides, disinfection by-products, and pathogens. Many of the analytical instruments are old, and unreliable, and in general, repair services and replacement parts are unavailable.

It is an essential requirement—for every water supply authority to ensure public health and safety. The laboratory must be upgraded in order to provide regular and comprehensive water quality testing. Under the proposed project, the capacity of the laboratory will be increased by 3 to 5 times. Programs to test for toxic organic chemicals, heavy metals, and pathogens are also included in the project. Achieving these improvements will require a corresponding reinforcement in human resources, training, space, and equipment.

(9) Water quality control in South Damascus

In South Damascus, the levels of nitrate and hardness in groundwater are as high as the allowable maximum specified by the Syrian Drinking Water Standard (section 3.4). The water quality in this area may even worsen in the future. This pollution related water quality problem appears to be widespread on a regional scale. There appears to be no effective measure that DAWSSA can take to stop the pollution of groundwater. If the water quality becomes unacceptable, the pumping from this region will have to be stopped. This event would have a serious impact on the water supply condition since well fields in South Damascus contribute a significant amount of water which is strategic to meeting growing demands. The economic and technical feasibility of treating this water to bring it back to acceptable standards would then have to be re-assessed in light of other available options.

Taking Kadam Railway well field as a model case, five different approaches were considered to make maximum use of low quality water resources in South Damascus. They are based on : blending (mixing of low quality south Damascus water with high quality Figeh water), water treatment (softening and nitrate removal), and suppression of pumping from contaminated wells.

(10) Reinforcement of existing water resources

The sources at Figeh; Side Spring and Ain Haroush are both under re-development. New wells have been drilled near to the existing sources that allow for much greater drawdowns than are currently achievable. The up-graded sources are hoped to increase the total Figeh output during peak demand months. There are no changes planned for the Main spring and the Deir Moukaren wellfield.

Barada wellfields groups 1, 2 and 3 are ongoing projects, the group 2 wellfield is nearing completion, the other groups have yet to be developed. The sources together have a capacity of 450 l/s which will be pumped via a pipeline to Damascus via Pigeh. The Jurassic that feeds Barada Spring is estimated to have a long term natural recharge of about 100 MCM/y. DAWSSA has been allocated 34 MCM/y. It is considered that with careful management an additional 20 MCM/y may be available from the aquifer for use in Damascus without deleterious effects on local water users and the Barada River.

The study of the sources operated by DAWSSA has shown that there are three wellfields that have undeveloped potential for further water abstraction, (Ibn Assaker, Kadam Railway and the Fringe Wells). Ibn Assaker wellfield is under utilized, and an additional 120 l/s may be pumped from the wells. The limiting factor constraining usage is the ability of the reservoir pumps to get the water into the distribution system. By up-grading the capacities of these pumps the quantity that may be produced from the site as a whole can be increased. Kadam Railway may also produced more, the limiting factor being the capacity of the submersible pumps. By upgrading these it should be possible to obtain an average of 115 l/s extra from the whole site.

The other existing wellfields in the City; Mazraa, Jobar, Kaboon, Oumawiyin are used at near optimal rates, no changes in the operation of these sites are made in the Master Plan. The University wellfield is on the interface between good and poor water quality. The continued operation of the site is liable to result in the water quality not meeting the Syrian drinking water standards. It is therefore proposed that this site is not used in the future. Kadam Store wellfield is to be fully equipped with submersible pumps, this will add water to the distribution network in south Damascus.

An existing wellfield at Dummar is to be re-equipped after period of idleness while new reservoirs and pumping station were built. It is intended that the water will be used for the local distribution network in Dummar, releasing the supply that currently comes from Figeh to other parts of the network. The fringe wells have different specific capacities, however they are all equipped with the same pumps. Those wells that are in higher yielding parts of the aquifer could be used at a higher rate. The re-equipping of just 8 sites could give an extra 1.76 MCM in a typical year. The emergency wells continue to be a back-up source for DAWSSA in times of unprecedented water shortage if the main sources can not be used. No change in the use of these sources are planned.

5.6.3 On going and Planned Water Supply Improvements

The following projects are identified in DAWSA's five year plan for the 1996-2000 period:

(1) Distribution schemes for informal areas (Formalizing informal areas)

There are currently 14 informally populated sites in and around Damascus and these sites are a major contributing factor to unacceptably high levels of unaccounted for water. There is an estimated population of 407,000 persons with a daily water consumption of 78,580 m³/d. Besides the fact that no revenue is generated from this informal water consumption, there are also substantial losses through leaks at informal connection points. Clearly, there are many benefits to be gained by providing properly connected and metered services in these areas. The location of the informal connection areas is illustrated in Figure 5.2.1. The status and progress of on going projects to provide proper service connections is summarized as follows:

1) Esh - Al Warwar informal area:

Location: in the north part of Berze district

Implementation Schedule: completed at the end of 1997

Area to be improved: 31.9 ha Estimated Population: 15,180

Water Demand: 3,036 m³/d estimated

Construction cost for distribution: US\$ million 0.443 approximately Work Items: 7,300 m main pipe length of 80 mm to 150 mm diameter

1,845 m service pipe

Remarks: The scheme is under construction by DAWSSA

2) Kassioun Mountains Foot informal area:

Location: spread over both Mouhajreen and Ruku Aldyn districts

Implementation Schedule: completed at the end of 2004

Area to be improved: 30.9 ha Estimated Population: 33,977

Water Demand: 6,562 m³/d estimated

Construction cost for distribution: US\$ million 0.806 approximately Work Items: 3,550 m main pipe length, service pipe and 5,660 meters

Remarks: Informal dwelling are scattered randomly throughout the area among

formal residences.

3) Tishreen informal area

Location: in Kaboon district

Implementation Schedule: completed at the end of 2002

Area to be improved: 36.2 ha Estimated Population: 33,977

Water Demand: 15,488 m3/d estimated

Construction cost for distribution: US\$ million 1.117 approximately Work Items: 3,550 m main pipe length and 2,580 meters, service pipe

4) Jobar Surrounding - Al Aksab Mosque area

Location: in Jobar district

Implementation Schedule: completed at the end of 2001

Area to be improved: 63.7 ha Estimated Population: 25,704

Water Demand: 4,964 m³/d estimated

Construction cost for distribution: US\$ million 1.944 approximately Work Items: 3,550 m main pipe length and 4,280 meters, service pipe

5) East - West Tabbaleh area

Location: in Shaghour district and outside of the city

Implementation Schedule: completed at the end of 2005 for out of city

Area to be improved: 135.2 ha (remaining area is 40.6 ha)

Estimated Population: 12,669

Water Demand: 2,447 m³/d estimated

Construction cost for distribution: US\$ million 1.024 approximately Work Items: 8,330 m main pipe length, service pipe and 630 meters

Remarks: about 70 % of the informal area in Shagour has been improved, and the remaining area is out of the City.

6) Mokhayam Al Yarmouk (Tadamun & Zahera) area:

Location: in Yarmouk district and outside of the city

Implementation Schedule: completed at the end of 2003 for outside of city

Area to be improved: 118.0 ha Estimated Population: 86,068

Water Demand: 16,621 m³/d estimated

Construction cost for distribution: US\$ million 1.279 approximately

Work Items: 7,260 m main pipe length, service pipe and 14,340 meters

Remarks: Tadamun area has been improved by DAWSSA: the improvement works at Zahera area are planned to start within 1996. Yarmouk are is required to be improved.

7) Naher - Eshah - Dahhadil & Asalie Kadam area

Location: in Kadam district

Implementation Schedule: completed at the end of 1999

Area to be improved: 170.4 ha Estimated Population: 37,005

Water Demand: 7,146 m3/d estimated

Construction cost for distribution: US\$ million 4.656 approximately Work Items: 7,260 m main pipe length and 6,170 meters, service pipe

Remarks: The improvement scheme is proposed to start at the same time as Zahera

within 1996.

8) Al Qazzaz & Shagour Bassateen area

Location: in Shagour district and outside of the city

Implementation Schedule: completed at the end of 2001 for outside of city

Area to be improved: 64.2 ha (remaining area is 44.9 ha)

Estimated Population: 10,692

Water Demand: 2,065 m³/d estimated

Construction cost for distribution: US\$ million 1.698 approximately

Work Items: 7,260 m main pipe length and 1,250 meters, service pipe

Remarks: About 30 % of the informal area in Shagour has been improved, and the

remaining area is out of the City.

9) Mezze - Razy & Kafar Souseh - Lawan area

Location: in Kafar Souseh district

Implementation Schedule: completed at the end of 2000

Area to be improved: 170.3 ha Estimated Population: 46,786

Water Demand: 6.322 m³/d estimated

Construction cost for distribution: US\$ million 4.656 approximately

Work Items: 7,260 m main pipe length and 7,800 meters, service pipe

Remarks: this is one of the areas with the largest leakage losses.

10) Mezze # 86 area

Location: in the north part of Mezze district

Implementation Schedule: completed at the end of 1997

Area to be improved: 95.7 ha Estimated Population: 46,390

Water Demand: 9,278 m3/d estimated

Construction cost for distribution: US\$ million 0.681 approximately Work Items: 20,250 m main pipe length of 80 mm to 400 mm diameter,

Elevated service reservoir with capacity of 500 m³

Remarks: The scheme is now under construction by DAWSSA

11) Somareyeh area

Location: along the Konaytera Road in the southern east of Mezze district

Implementation Schedule: completed at the end of 2004

Area to be improved: 37.6 ha Estimated Population: 45,90

Water Demand: 918 m³/d estimated

Construction cost for distribution: US\$ million 0.877 approximately Work Items: 6,950 m main pipe length and 770 meters, service pipe

12) Dummar - Wadi Al Mashare area

Location: in the south part of Dummar district

Implementation Schedule: completed at the end of 1999

Area to be improved: 41.9 ha Estimated Population: 14,841

Water Demand: 2,866 m³/d estimated

Construction cost for distribution: USS million 1.242 approximately Work Items: 6,950 m main pipe length and 2,470 meters, service pipe

13) Takadom area

Location: outside of the city in the south of Yarmouk district

Implementation Schedule: completed at the end of 1998

Area to be improved: 54.5 ha Estimated Population: 36,750

Water Demand: 7,350 m³/d estimated

Construction cost for distribution: US\$ million 0.738 approximately Work Items: 6,950 m main pipe length and 2,470 meters, service pipe

Remarks: about 25 % of the area surrounding Takadom well field has already been

improved by DAWSSA.

14) Kudsaya area

Location: in the southern part of Kudsaya village

Implementation Schedule: completed at the end of 2005

Area to be improved: 50.0 ha Estimated Population: 20,800

Water Demand: 4,017 m³/d estimated

Construction cost for distribution: US\$ million 1.536 approximately Work Items: 6,950 m main pipe length and 3,470 meters, service pipe

(2) New well centers for the informal area

New wellfield sites are identified in DAWSSA's plan to supply existing informal areas. The capacity of the existing Kaboon wellfield will be increased with, new and deeper wells. In the first phase two are planned, if they prove to be successful than another eight will be constructed. Jaramana wellfield is located in a highly productive area. This wellfield will be equipped to serve the distribution network in the area of South Damascus. Water supply in the informal area of Takadom will be enhanced by the Takadom wellfield. The site has 10 production wells that were drilled in 1989 but were not immediately equipped for production. DAWSSA plans the commission the wellfield in the next couple of years.

(3) New well centers for formal area

DAWSSA's development plan identifies several projects to increase the capacity of water sources supplying the City. A new wellfield is planned for Kafar Souseh, this will be a small source with approximately 5 wells. The wellfield at the Faculty of Agriculture between Mazraa and Kaboon is not viable since DAWSSA can not been able to find any suitable land for locating the wells. Tishreen and Kywan wellfields have been drilled but not equipped with pumps. It is planned to develop this source is a phased sequence by firstly equipping the high yield wells, followed by the low yield wells and finally by drilling another pair of wells. The wellfield will be controlled from the existing Oumawiyin center located close by.

(4) New water resources schemes in the Hermon area

DAWSSA's five year plan identifies a number of potential water resources development schemes described as follows:

A wellfield near Rinsch in the southern part of the Hermon area consists of existing wells drilled by the MOI during hydrogeological investigations. The limited capacity of the source (285 l/s for 6 months of the year) and the distance to Damascus have made scheme economically unattractive.

The Kudsaya residential development north west of Damascus will be supplied by a wellfield in Wadi Marwan. The wellfield, pipeline and associated works are designed for a capacity of 20,000 m³/d.

An existing wellfield in the Cretaceous limestone at the north end Hermon near the village of Deir al Ashayer is identified as a potential new water source. Three existing MOI wells and a fourth to be drilled by DAWSSA, make up a small wellfield. The water would be supplied to Damascus via a new pipeline to Huseiniyeh, where it would join other existing

pipelines.

(5) Water supply distribution schemes for new development areas inside Damascus city.

The need to extend the distribution of water supply into new development areas of Kudsaya New Suburb, Dummar is identified in the DAWSSA's plan. The system in Kudsaya is currently under construction. A project is also planned to install more transmission line with capacity of 500 m³/d for the Special Area Zone (residential area for State Factory). The location of each distribution scheme is shown in Figure 5.2.2. The various distribution schemes are outlined as follows:

a) Kudsaya New Suburb

Location: in the east to Kudsaya village

Implementation Schedule: completed the settlement in the year 2010 Total Area: 400 ha (Net area for residential & commercial: 300 ha)

Population Projection: 52,000 persons in 2010 (density: 130 persons/ha) Water Supply: 20,000 m³/day from Well Field (13 wells) at Wadi Marwan

Water Demand: 12,000 m³/day in 2010

Distribution: work on installation of distribution mains is in progress

b) Dummar Extension Area (1st Phase)

Location: in the east to Dummar New Town

Implementation Schedule: completed the settlement in the year 2000 Total Area: 124 ha (Net area for residential & commercial: 100 ha)

Population Projection: 6,000 persons in 2000 (density: 60 persons/ha)

Water Supply: planned to supply through Kudsaya New Suburb from Wadi Marwan

and new Dummar Well Field

Water Demand: 7,600 m³d in 2000

Distribution: Distribution main is under construction

c) Special Area Zone (residential area for State Factory)

Location: in the north to Hame village

Implementation Schedule: completed the new transmission pipe in the year 2000

Total Area: 25 ha for residential area

Population Projection: 3,500 persons in 2000 (density: 140 persons/ha) Water Supply: planned to install one more pipeline along the existing pipe

Bulk water (Net): 500 m³/d in 2000 from 100 m³/d at present

Distribution: Distribution system is existing

5.6.4 Proposed Water Supply Schemes

The following schemes are proposed by the DAWSSA-JICA study team to develop water resources required for population growth and new residential areas identified in the municipal master plan.

(1) Rural areas

According to the City Master Plan for the year 2020, the existing Maraba village and Assad Suburbs will be annexed to the Damascus City by 2020. Maraba village is supplied by the Establishment of Drinking Water and Sewerage in the Rural Province of Damascus from the 2 wells with capacity of 35 m³/hr. Assad suburb has its own water resource of well field located in rural area. It is proposed that these existing water supply systems be incorporated into DAWSSA's system after the year 2010. Location of each system is shown in Figure 5.2.2. These systems are outlined as follows;

a) Maraba water supply system

Location: near the planned Kassioun New Town in the north of the Kassioun Mountain

Exiting population: 4,680 in 1995 based on the 1994 Census

Area: 75 ha

Water Supply: supplied by the Establishment of Drinking Water and Sewerage in the Rural Province of Damascus

Water Demand: 840 m³/d (per capita water demand is estimated as 180 lpcd)

Distribution: Distribution system is existing

b) Assad Suburb

Location: along Homes Road in the east of the City

Exiting population: 7,800 in 1995 estimated based on the 1994 Census

Area: 40 ha for 1st Phase, 193 ha for 2nd Phase and 298 ha for Extension area

Water Supply: supplied by itself with Wells located at rural area (no detail

information)

Water Demand: 2,220 m³/d estimated as 285 lpcd

Distribution: Distribution system is existing

Implementation Schedule: under construction for 1st Phase

: no information for 2nd Phase and Extension area

(2)Distribution schemes for new development areas

As described Section 3.2, Damascus Municipality proposes in it's master plan to extend the administrative boundary of Damascus City and develop new residential suburbs to accommodate population growth. DAWSSA's existing water rights of 296.9 MCM/year will be insufficient to meet the estimated water demands in the year 2005 even if system losses are reduced significantly. Distribution schemes required for the proposed extension of Damascus To provide water for the new development areas, reallocation of city are summarized below. water from other resources, for example those used for irrigation will be required in the future.

a) Proposed Kudsaya New Suburb

Location: in the east of Kudsaya New Suburb

Implementation Schedule: development completely populated after 2015

Development Area: 200 ha for residential & commercial

Population Projection: 25,000 in 2020 with proposed unit consumption

Water Demand: 10,000 m³/d estimated

Construction cost for distribution: US\$ million 3.4 approximately

b) Dummar Extension Area (2nd Phase)

Location: in the east of Dummar Extension Area (1st Phase)

Implementation Schedule: development completely populated in 2015

Development Area: 216 ha for residential & commercial

Population Projection: 25,000 in 2015

Water Demand: 8,000 m³/d estimated with proposed unit consumption

Construction cost for distribution: US\$ million 3.6 approximately

c) Kassioun New Town

Location: in the north of the Kassioun Mountain

Implementation Schedule: development completely populated after 2015

Development Area: 650 ha for residential, commercial, Industrial, etc.

Population Projection: 12,000 in 2020

Water Demand: 4,800 m³/d estimated with proposed unit consumption Construction cost for distribution: US\$ million 10.9 approximately

d) Assad Suburb (2nd Phase & Extension Area)

Location: along Homes Road in the east of the City

Implementation Schedule: development completely populated after 2015 Development Area: 193 ha for 2nd Phase and 298 ha for Extension area

Population Projection: 25,000 for 2nd Phase in 2010

: 14,000 for Extension area in 2015

Water Demand: 4,800 m³/d estimated with proposed unit consumption

Construction cost for distribution: US\$ million 3.2 (2nd Phase) and 5.0

(Extension Area) approximately

e) Kaboon Green Area: reserved area for greenery with area of 530 ha

f) Assad City & Proposed Assad City Extension Area No. 1, 2, 3

Location: along Quneita Road in the southern west of the City

Implementation Schedule: development completely populated after 2015

Development Area: 655 ha for Assad City, 200 ha for No.1, 124 ha for No.2

575 ha for No.3

Population Projection: 25,000 for Assad City in 2015

: 12,000 for Proposed Assad City Extension Area No. 1

in 2020

No.2 & 3 are no information

Water Demand: 9,950 m³/d for Assad City in 2015 and 4,800 m³/d for Proposed Assad City Extension Area No.1 estimated with proposed unit

Assid City Exension first from Commissa with proposes our

consumption

Construction cost for distribution: US\$ million 11.0 (Assad City), 3.4 (No.1), 2.1

(No.2) & 9.7 (No.3) approximately

툁

(3) Water resources schemes in Damascus (new stations)

Three new wellfields are proposed; one in the center of the city on Shokry al Qouwatly street, another in Kanawat Gardens and a final one in Kafar Souseh. A wellfield is planned to be located in gardens along Shokry al Qouwatly street and opposite the National Museum. The water quality and yields from the ground are both anticipated to be good in this part of the City. A potential water source that is not put forward for the Master Plan is the area north of Al Shouhada Square near the Yalbuga Center. The groundwater is known to be shallow depth and the pebble beds known to be highly productive. Although for quality reasons it may not be suitable as potable water, it may be a substitute source for the Municipality.

A third phase of the development of the Tishreen wellfield comprises the construction of two new wells in that part of the site where existing holes have already demonstrated the potential for high well yields. The Kanawat Gardens wellfield is planned for an area of small market gardens between Kanawat and Kafar Souseh. The area was selected to be distant from existing wellfields yet still have reasonable well yields and good water quality. A small wellfield of 5 holes is anticipated for this site.

(4) Water resources schemes in Hermon and Zabadani area

Three sources in the Hermon area would all require long pipelines if the water where allocated for use in Damascus. In the Awaj basin a spring source at Beit Jenn and Tabibiyeh could provide a seasonally variable supply. The Jurassic aquifer east of Sergaya and north east of Zabadani has only limited recharge. It has some development potential, but is economically unattractive. A pair of wellfields at Ain el Irk and Sergaya could have a potential yield of about 3 MCM/y.

5.6.5 Cost Estimates

This section describes how the project cost estimates are developed. These cost estimates are used to evaluate the economic viability of each project which is one of the screening criteria used to select the master plan projects. Costs estimates include the direct construction costs and the operation & maintenance costs for each project alternative described in Section 5.6.2, 5.6.3 and 5.6.4. Estimated costs for each project are shown in Table 5.6.3. The following assumptions are applied to the cost estimate:

- i) Cost for transmission main and distribution network are estimated based on work quantities calculated for each project and corresponding unit prices,
- ii) Costs for reservoirs are estimated by applying a unit rate of SL 6,300/m³ based on Barada collecting reservoir,
- iii) Costs for building are estimated by applying a unit rate of \$1.7,600/m² based on the Kadam store training center,
- iv) Estimated costs for annual operation of pumps is based on operating hours and annual electricity consumption calculated for respective pumping station and a unit rate of SL 0.75/kWH, and
- v) Annual maintenance costs for pumps and distribution network is 3.0 % and 0.3 % of the direct construction cost for economic evaluation.

5.6.6 Economic Evaluation

One of the criteria used to screen proposed master plan projects was economic evaluation. The Economic Internal Rate of Return (EIRR) for each project was calculated on the basis of the estimated economic benefits and economic costs. Details of the economic evaluation are provided in Appendix J of the supporting report.

The main benefit is the incremental water delivered to the consumer generated by each candidate project. The benefit is evaluated by taking the difference between the "with" and "without" project case. Many of the candidate projects contribute to the general well being of the public, however, health benefits, and other social benefits from improved services are not considered in the economic evaluation since only increased water sales are quantifiable.

The estimated construction costs for each candidate project are converted to the economic costs by applying the shadow exchange rate of SL 50 = US\$ 1 to the local cost components. Economic costs include engineering, administration and contingency allowances. Incremental operation and maintenance costs were also estimated on the "with" and "without" project basis and added to the investment cost to obtain the cost stream of each candidate project over it's expected economic life.

Each candidate project is evaluated by calculating the internal rate of return based on the discounted cash flows produced from the estimated economic costs and incremental water sales. The various components of the leakage control program such as district metering, pressure control and master metering were grouped together and evaluated as a whole.

In general, the economic life for most of the candidate projects is assumed to be 25 years. Replacement of pumps and rehabilitation of conveyance components is assumed to occur after 15 years. The three Hermon Spring scenarios include significant conveyance elements and therefore are assumed to have a longer economic life of 35 years. Economic assessment of the cast iron pipe replacement program assumes a 75 year economic life based on the longevity of ductile iron mains.

In general, projects with a rate of return higher than 10% (assumed opportunity cost of capital in Syria) are deemed economically viable. Candidate projects are ranked according to their EIRR as summarized in Table 5.6.4. A sensitivity analysis indicates that estimated EIRR's are robust to variations in costs, benefits and delays in implementation.

5.6.7 Environmental Evaluations

(1) Objectives

The projects proposed in this chapter are expected to bring positive environmental impacts (e.g., improved public health condition through safe drinking water supply) to Damascus. However, they may also bring negative environmental impacts. Therefore,

I

master plan level environmental impact assessment (Initial Environmental Examination, IEE) was conducted as a part of comprehensive project evaluation of proposed projects. The objectives of IEE are:

- i) assessment of environmental impacts by the proposed projects
- ii) environmental screening of the proposed projects

(2) 1EE

The criteria for IEE were selected based on the Syrian EIA guideline, JICA Environmental Consideration guideline, and characteristics of the area. The following 5 aspects of environmental impacts were considered important.

| Criteria | Examples of environmental impacts considered |
|------------------------|--|
| 1. Natural Environment | water: exhaustive exploitation of water resources |
| | other: destruction of local vegetation and wild life |
| 2. Public Health and | construction: noise, vibration, increase in traffic, dust |
| Pollution | operation: quality of supplied water, increase in hygiene, health standard, subsidence |
| 3. Waste | disposal of various waste produced by the project, increase in waste water |
| 4. Social Environment | water right, change in life style, local economy, and other factors |
| 5. Cultural Asset | damage to historical and cultural asset |
| Overall Assessment | overall environmental impact |

The results of the assessment is given in Table 5.6.5 . In general, the environmental impacts by the proposed projects seem to be small, and the proposed projects have significantly large positive environmental impact on public health. Among the most important environmental factors are water quality of supplied water and environmentally irresponsible exploitation of water resources.

(3) Projects with high environmental impacts

- Water Quality Control in South Damascus, option 2: This option considers the blending of water from Kadam Railway at Eastern Reservoir. Any project that involves transport of contaminant is considered undesirable. In addition, this scheme has the risk of contaminating the entire water supply system of Eastern Reservoir.
- Reinforcement of Existing Water Resources, Damascus Well, Kadam Railway: Water from Kadam Railway contains elevated level of hardness and nitrate. If the water quality

becomes unacceptable, countermeasures suggested in 1.9 Water Quality Control in South Damascus have to be considered.

- Reinforcement of Existing Water Resources, Damascus Well, Oumawiyin: There is a potential of pesticide pollution in Oumawiyin. Further investigation is strongly recommended.
- Reinforcement of Existing Water Resources, Damascus Well, University: Water from University well field contains high level of hardness and sulfate. Increased production from this side will decrease the overall water quality of supplied water.
- Reinforcement of Existing Water Resources, Damascus Wells, Dummar: Water from Dummar contains high levels of hardness and sulfate. Increased production from Dummar will decrease the overall water quality of supplied water.

Table 5.2.1 Implementation Schedule of New Development Schemes (Tentative)

| | Year | Total | 2000 | 2005 | 2010 | 2015 | 2020 |
|----|--|-------|----------|---|--|----------------|---------|
| | | Arca | 1997 | | | | - |
| | Name of Area | (ha) | • | | | | |
| | Proposed New Development Arca | | | | | | |
| 1 | Kudsaya New Suburb | 8 | | 300 | | | |
| | Proposed Kudsaya New Suburb | 8 | | 6. | Q/Q | | 200 |
| | Dummar Extension Area (1st phase) | 124 | 124 | | | | |
| 4 | Dummar Extension Area (2nd phase) | 216 | d | 20000000000000000000000000000000000000 | C/G | 216 | |
| S | Kassioun New Town (Total area: 650 ha) | 340 P | | | | G/Q | 340 |
| v | Assad Suburb (1st phase) | 04 | | Q/Q | 40.0 | | |
| | Assad Suburb (2nd phase) | 193 | P | CI/CI | 193 | | |
| ∞ | Assad Suburb Extension Area | 298 | | ď | | D/D 298 | |
| 6 | Kaboon Green Area | 530 | | | 530 | | |
| 2 | Assad City | 655 P | A | | D/D | monuments. 655 | |
| = | Proposed Assad City Extension Area (1) | 8 | | 4 | 6000000000000000000000000000000000000 | | 200 |
| 17 | Proposed Assad City Extension Area (2) | 124 | | *************************************** | | D/D | 124 |
| 5 | Proposed Assad City Extension Area (3) | 575 | | | ×××××××××××××××××××××××××××××××××××××× | | STS STS |
| 7 | Special Area Zone (State Factory) | 25 | | | f | | |
| | Total (ha) | 2.540 | <u>:</u> | 300 | 763 | 1,169 | 1.439 |
| | | | | 5 | | | |

Approval of The Damascus City Master Plan by The Government in 1997

Planning (P) / Detail Design (D/D)

(Remarks)

Land Acquisition

»»»»

Construction

Table 5.2.2 List of Informal Connection Areas

| No. | Name of Area | Population | Area | Existin | g Conditions |
|--------------|---|------------------|-----------------|---|---|
| | | 1995 | (ha) | Distribution Main & Water Meter | Remarks |
| 1 | Esh - Al Warwar | 15,180 | 31.9 | under construction (Kaboon Wells) used Booster Pump | 1845 Connections, 1 Reservoir 7300 m (D80-150) pipe length |
| 2 | Kassioun Mountains Foot (Akrad) (Mouhaireon) | 33,977 | | partially installed, no meter (KH & K2) | , |
| 3 | Tichreen | 15,448 | 36.2 | partially installed No meter | (planning) |
| 4 | Johar Surounding - Al Aksah Mosque | 25,704 | 63.7 | partially installed | (planning) |
| 5 | East - West Tabbaich (map) | 12,669 | 135.2 | partially installed | |
| 6 | Mokhayam Al Yarmouk (Tadamon & Zahera) | 86,068 | 118.0 | partially used Private Wells | (planning) project is on starting by the end of 199 |
| 7 | Naher Eshah - Dabhadil & Asalie Kadam | 37,005 | | partially installed | (planning) |
| | A1 Kadam A | | 60.5 | | project is on starting by the end of 199 |
| | Al Kadam B | | 31.5 | i | |
| | A1 Kadam C | | 78.4 | | |
| 8 | Kafar Sousch Organisation | Non | | Re-developping Area under constru- (not informal area) | ction by Damascus Municipality |
| 9 | A) Qazzaz & Shagour Bassateen | 10,692 | | partially installed Partially used Private Wells | |
| 10 | Mezze - Razy Kafar Souseh - Lawan | 32,786 14,000 | 110.5 - 59.8 | partially installed | |
| 11 | Mezze #86 (map) | 46,390 | | under construction (M1 & M2) used Booster Pump | constructed Elevated Tank:500 m3 |
| 12 | Somarcya (map) | 4,590 | 37.6 | partially installed used Booster Pump at each bilding | (Military Housing Area) |
| 13 | Dunumar - Wadi At Mashare | 14,841 | 41.9 | Non | (planning) caonstructed 5 wells & installed 3 pun |
| 14 | (map) Takadom | 36,750 | 54.5 | partially installed (Takadom Well Field) | (planning) |
| 15 | Kudsaya | 20,800 | 50.0 | Non | |
| | Total | 407,000 | 1,050.5 | | |

(Source : JICA & DAWSSA)

Table 5.2.3 Service Area and Population (1995 to 2015)

| | т | 1995 | | | 2000 | | | 2005 | - | r | 2010 | | ı | 2015 | |
|--|------------------|--------|---------|------------|--------|-------------|-------------|--------|---------------|------------|--------|---------|------------|--------|------------|
| | J | Arca | Density | Population | | Density | Served | Area | Density | Served | Area | Density | Served | Aica | Dens |
| Name of Area | Population (***) | (ha) | Density | (***) | (ha) | Excusity | Population: | (ha) | Lecusity | Population | (ha) | Leasily | Population | | LACHS |
| Villages* | | | | | | | | | | | L | | | | |
| lgeh | 3,975 | 44 | 90 | 4,389 | 4.1 | 99 | 4.845 | 44 | 109 | 4,968 | 41 | 112 | 5,093 | 41 | 1 |
| Al Khadra | 2.231 | 12 | 191 | 2,463 | 12 | 211 | 2.719 | 12 | 232 | 2.788 | 12 | 238 | 2,858 | 12 | 2 |
| Bassime | 468 | 18 | 27 | 517 | 18 | 30 | 570 | 18 | 33 | 585 | . 18 | 33 | 600 | 16 | |
| Ashrafye Wadi | 3,311 | 27 | 123 | 3,656 | 27 | 136 | 4,037 | 27 | 150 | 4.138 | 27 | 154 | 4,243 | 27 | |
| ludayde | 4,454 | 53 | 8-1 | 4,928 | 53 | . 93 | 5,441 | 53 | 102 | 5,579 | 53 | 105 | 5,719 | 53 | 1 |
| Hame | 21,570 | 56 | 384 | 23,815 | 56 | 424 | 26,291 | 56 | 468 | 26,958 | 56 | 480 | 27,638 | 56 | |
| lemarya | 2,034 | . 5 | 384 | 2,246 | 5 | 424 | 2,479 | 5 | 468 | 2,542 | 5 | 480 | 2,606 | 5 | 1 |
| Kudsaya | 43,398 | 158 | 275 | 46,134 | 158 | 293 | 49,109 | 158 | 311 | 55,951 | 158 | 355 | 63,412 | 158 | 1 |
| Fakadom | 36,750 | 55 | 674 | 40.575 | 55 | 741 | 41,798 | 55 | 822 | 49,461 | 55 | 908 | 54,609 | 55 | 10 |
| Military Area 4 (Residential) | 14,040 | 85 | 165 | 14,040 | 85 | 165 | 14,040 | 85 | 165 | 14,040 | 85 | 165 | 14,040 | 8,5 | |
| Maaraba | | | | 0 | | 1 | : | | T | | | [| | | |
| Sub-total : | 132,241 | 512 | 258 | 142.763 | 512 | 279 | 154,332 | 512 | 301 | 167,010 | 512 | 326 | 180,818 | 512 | |
| Proposed New Development Area | | | | | | | | | İ . | l | l | | | | L |
| Kudsaya New Suburb | | | | | | 1 | 30,000 | 300 | 100 | 43,315 | 300 | 161 | 53,344 | 300 | li |
| Proposed Kudsaya New Subarb | | | | | | | | | | | | ļ |] | | |
| Dummar Extension Area (1st phase) | | | | 20,500 | 124 | 165 | 26,793 | 124 | 216 | 35,017 | 124 | 282 | 38,662 | 124 | |
| Dummar Extension Azea (2nd phase) | [| | | | | · · · · · · | | | | | | | 25,000 | 216 | 1 |
| Kassioun New Town (650 ha) | | | | | | : | | | I | | | | i | | l |
| Assad Suburb (1st phase) | | | | | | | | | | 11.849 | 40 | 296 | 13,082 | 40 | |
| Assad Suborb (2nd phase) | | | | | | | | | l | 25,000 | 193 | 130 | 33,456 | 193 | |
| Assad Suburb Extension Area | | | | | : | | | | | | | | 14,000 | 298 | |
| Kaboon Green Area | | | | | | | | | | | 530 | 0 | | 530 | |
| Assad City | | | | | 1 | 17.77.5 | | | | | | | 25,000 | 655 | |
| Proposed Assad City Extension Area (1) | | | | | 7.7 | | | | | | | l | | | l |
| Proposed Assad City Extension Area (2) | | | | | | | | | | | | 1 | l | | |
| Proposed Assad City Extension Area (3) | | | | | : | | | |] | | | l | | | |
| Special Area Zone (State Factory) ** | 3,500 | 25 | 140 | 3.500 | 25 | 140 | 4,000 | 2.5 | 160 | 4.204 | 25 | 168 | 4,418 | 25 | |
| Others (not classified) | | | | | | | | | 1 | | | I | | | |
| Sub-total | 3,500 | 25 | 140 | 24,000 | 149 | 161 | 60,793 | 419 | 135 | 124.385 | 1,212 | 103 | 206,962 | 2.380 |) |
| Existing Damascus City | 1 | | | | | | | | | | | Γ | [| 1 | |
| Ruko Aldyn | 166,768 | 437 | 382 | 184,125 | 437 | 421 | 203,289 | 437 | 465 | 224,448 | 437 | 513 | 247,808 | 437 | |
| Mouhaireen | 77,461 | 363 | 213 | 85,523 | 363 | 235 | 94,424 | 363 | 260 | 104.252 | 363 | 287 | 115,103 | 163 | |
| Mezze - | 110,002 | 1.328 | 83 | 121,451 | 1,328 | | 134,092 | 1,328 | 101 | 149,048 | 1,328 | 111 | 163,457 | 1.328 | |
| Kafar Sousch | 96,021 | 1.200 | 80 | 106,015 | 1,200 | | 117,049 | 1,200 | 98 | 129,231 | 1,200 | 108 | 142,682 | 1.200 | |
| Kanawat | 66,761 | 269 | 248 | 73,710 | 269 | 274 | 81,331 | 269 | 302 | 89,852 | 269 | 334 | 99,203 | 269 | |
| Kadam | 64,175 | 300 | 214 | 70.855 | 300 | 235 | 78,229 | 300 | 261 | 86,372 | 300 | 288 | 95,351 | 300 |) |
| Midan | 143,579 | 296 | | 158.523 | 296 | | 175,022 | 296 | 591 | 193,239 | 296 | 653 | 213,351 | 296 | 5 |
| Old City | 1B,493 | 145 | 128 | 20,417 | 145 | 111 | 22,542 | 145 | 155 | 24,689 | 145 | 172 | 27,479 | 145 | ۱ <u> </u> |
| Shaghour | 65,631 | 470 | 14() | 72,452 | 470 | | 80,001 | 470 | 170 | 88,331 | 470 | 188 | 97,524 | 470 |) : |
| Sarouja | 117.617 | 349 | 337 | 129,859 | 349 | · · | 143,375 | 319 | 411 | 158,297 | 349 | 454 | 174,773 | 3.49 |) : |
| Yannouk | 214,669 | 227 | 948 | 237,034 | 227 | 1.017 | 261,704 | 227 | | 288,943 | 227 | 1,276 | 319,016 | 227 | 1 |
| Jobat | 104,106 | 642 | 162 | 114,932 | 64? | 179 | 126.905 | 612 | 198 | 140,113 | 642 | 218 | 154,696 | 642 | 2 |
| Berze | 75.899 | 67.3 | 113 | 83,799 | 673 | 125 | 92,521 | 673 | 137 | 102,150 | 673 | 152 | 112,782 | 673 | |
| Kaboon | 51.592 | 497 | 104 | 56,961 | 497 | 115 | 62,890 | 497 | 127 | 69,435 | 497 | 140 | 76,662 | 497 | |
| Dummar | 49,415 | 473 | 104 | 54,558 | 473 | | 60,231 | 473 | . 127 | 66,506 | 473 | 141 | 73,428 | 473 | |
| Kassious Mountain | 1 | 2,956 | | 1 | 2.956 | 1 | | 2,956 | 4 | I | 2.956 |] | | 2,956 | <u> </u> |
| Sub-total | 1,422,209 | 10.524 | 134 | 1.570.234 | 10.624 | 145 | 1,733,664 | 10.624 | 163 | 1,914,107 | 10,624 | 180 | 2,113,325 | 10.624 | |
| Total | 1,557,950 | 11.162 | 140 | | 11.286 | | 1.948,789 | 11.585 | | | 12,349 | 179 | <u> </u> | | + |

(Source : Damascus Governate, DAWSSA and the Study Team)

(Remarks) * : Area of Villages is water served area.

** : It is a bulk water system to supply water from DAWSSA.

***: Service level to the total population is estimated 74 % in 1995 and 90 % in 2000.

Table S.4.1 Annual Water Consumption of Past 5 Years and The 8th 5 Years Plans for Water Supply by DAWSSA

| | | | | | | | | - | | | T. O. T. V | | |
|----------|---|----------|---------|---------|---------|----------------|-----------|---------|----------|------------|------------|---------------|---------|
| | 657 | į | 2 | .00. | | Ine /the Iears | ,00. | 300. | 1000 | 1001 | 1006 | 0001 | 500 |
| I | | | | 1881 | 7441 | CKS. | 1996 | | 26 | | | | |
| | Un-billed (Free) | MCV/year | 62.520 | 65.165 | 84.792 | 39,000 | 87.168 | 102.965 | 102.785 | 106.752 | 110,720 | 114,637 | 118.655 |
| | (Percentage) | | 75. | | %9% | 88 | 8. | %29 | 62% | 62% | 62% | 61% | 9719 |
| - | Water Right Obligations | | 14.020 | 15.750 | 15.154 | 15.750 | 15.028 | 14.859 | 15,500 | 15.500 | 15:300 | 15.500 | 15.500 |
| | (Percentage) | * | 12% | 4571 | 201 | 10% | 10% | 36 | 56 | % 6 | 9%6 | 3.74 | 8% |
| 13 | Public & Meligious Use | | 48.500 | 515.04 | 859.69 | 73,250 | 041.47 | 88.106 | 87.285 | 91.252 | 05:20 | 99.187 | 103,155 |
| | (Percentage) | ę. | 42% | 38% | 46% | ×97 | %9 | 88 | 23% | 23.75 | 53% | 23% | 23% |
| ~ | Mosque & Church* | | | | | | | | | | | _ | |
| | Public fountains & Tap." | | | | | | | | : | | | | |
| | | | | | | | | | : ::- | | | | <u></u> |
| 1. | Rilled | NOW Y | 83.280 | 64.515 | 857.88 | 70,000 | 582-09 | 62.218 | 512.39 | 65.748 | 082.69 | 72.813 | 76,345 |
| | (Percentage) | | 70.07 | ٠, | ** | ×; | 2.7 | 38% | 38% | 38% | 38% | 20% | 30% |
| 13 | Domestiv Use | | 36.524 | | 45,468 | 47.985 | 47.698 | 45.454 | 44.708 | 47,247 | 49,785 | 52.323 | 55.86.2 |
| | (Percentage) | ¥ | 32.70 | | 30% | 30% | 30% | 28% | 275. | 27% | 28% | 28% | 28% |
| 11 | Governmental Use (Public Use) | | 12,025 | 14,561 | 14.970 | 15.799 | 15.705 | 13.418 | 13.096 | 378,61 | 14.590 | 15,335 | 16.078 |
| . | (Percentage) | 8 | 10% | 11% | 10% | 10% | 10% | 8% | 8% | 8% | 8% | 8.80 | 8% |
| - | Office & Public Facilities* | : . | | | | | | | | - | | | |
| | Schools | | | | | | | | : | | - 1 . | | |
| | Hospitals* | | | | | | | | | | | | |
| | | | | : | | | | | | | | | |
| _ : . | Special & Amport Use | | | | 1 1 | | | | : | | : | | : |
| 3 | Commercial, Tourism & | | 4.731 | 5.729 | \$.390 | 6.216 | 6.179 | 33.66 | 4.411 | 4,655 | 4.905 | \$31.5 | 5,405 |
| | Industrial Use (Percenatge) | ą. | 476 | 47€ | 4% | 40.4 | 474 | 2% | 3% | 3% | 3% | 3% | 37% |
| : 2 | Commercial* | ÷. | | | | | | | : | | | | |
| | | | | | | • | | | | | | : | |
| <u>.</u> | Hotels* | | | | | | | , | | | | : | |
| | Industrial* | : | •. | | | | : : | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | : | | | | | | |
| | Counted Water Consumption without Leakage | MCMyrea | 115.500 | 129,680 | 151.120 | 159.000 | 156.750 | 165.183 | 165.000 | 172.500 | 180.000 | 187,500 | 195.000 |
| | (Source : DAWSKA) | | | | | | | | | | | | |

(Source : DAWSNA)

Remark *: Data is not availab

Table 5.4.2 (1/2) Summary of Seasonal Water Consumption from Bill in 1995

| 2 | Unit | Yan. | Feb. | Mar. | Apr. | Mav | June | , vluř. | Aug. | Seo. | र्ड | Nov. | 2 | Average | Total | Percentage |
|--------------------------------------|----------------|---------|---------------|---------|---------|-------------|---------|---------|-------------|---------|---------|-----------|---------|---------|--------|------------|
| | | | 1st Ouarter | | | 2nd Ouarter | | | 3rd Ouarter | | 404 | h Quarter | | | MCM/v | (€ |
| 1 Billod Consumption | MCM/m | | | | 3 . | | | | | | | | | | | |
| Domestic | | 4.127 | 4.127 | 4.127 | 4.127 | 4.127 | 4.127 | 3.542 | 3.542 | 3.542 | 3.356 | 3.356 | 3.356 | 3.788 | 45.454 | 73 |
| without Water Rights | - | 1.976 | 1.976 | 1.975 | 1.976 | 1.976 | 1.976 | 1.582 | 1.582 | 1.582 | 1.682 | 1.681 | 1.681 | 1.804 | 21.642 | 35 |
| with Water Rights | | 2.151 | 2.151 | 2.151 | 2.151 | 2.151 | 2.151 | 1.9% | 1.960 | 8. | 1.675 | 1.675 | 1.675 | 1.984 | 23.812 | 38 |
| Commercial | | 0.251 | 0.251 | 0.251 | 0.251 | 0.251 | 0.251 | 0.225 | 0.225 | 0.225 | 0.203 | 0.203 | 0.203 | 0.233 | 2.792 | 4 |
| Industrial | | 0.051 | 0.051 | 0.051 | 0.051 | 0.051 | 0.051 | 0.042 | 0.042 | 0.042 | 0.041 | 0.041 | 0.02 | 0.046 | 0.554 | -1 |
| Government | | 1.093 | 1.093 | 1.093 | 1.093 | 1.093 | 1.093 | 1.109 | 1.109 | 1.109 | 1.178 | 1.178 | 1.178 | 1.118 | 13.418 | 23 |
| Sub-total | | 5.521 | 5.521 | 5.521 | 5.521 | 5.521 | 5.521 | 4.917 | 4.917 | 4.917 | 4,779 | 4.779 | 4.779 | 5.185 | 62.218 | 100 |
| 2 Number of Connections | x 1000 | | - | - | | | | | W | | | | | | | |
| Domestic | | 180.158 | 180.158 | 180.158 | 180.158 | 180.158 | 180.158 | 194.842 | 194.842 | 194.842 | 198.912 | 198.912 | 198.912 | 188.518 | | 35 |
| withour Water Rights | | 101.893 | 101.893 | 101.893 | 101.893 | 101.893 | 101.893 | 102.575 | 102.575 | 102.575 | 103.940 | 103.940 | 103.940 | 102.575 | | \$ |
| with Water Rights | | 78.265 | 78.265 | 78.265 | 78.265 | 78.265 | 78.265 | 92.267 | 92.267 | 92.267 | \$4.972 | 94.972 | 94.972 | 85.942 | | 38 |
| Commercial | | 29.046 | 29.046 | 29.046 | 29.046 | 29.046 | 29.046 | 30.539 | 30.539 | 30.539 | 33.525 | 33,525 | 33.525 | 30.539 | | 7. |
| Industrial | | 2,310 | 2.310 | 2.310 | 2.310 | 2.310 | 2.310 | 2.310 | 2.310 | 2.310 | 2.306 | 2.306 | 2.306 | 2.309 | | |
| Government | | 3.019 | 3.019 | 3.019 | 3.019 | 3.019 | 3.019 | 3.065 | 3.065 | 3.065 | 3.065 | 3.065 | 3.065 | 3.042 | | - |
| Sub-total | | 214.533 | 214.533 | 214.533 | 214.533 | 214.533 | 214.533 | 230.756 | 230.756 | 230.756 | 237.808 | 237,808 | 237.808 | 224.408 | | 100 |
| 3 Unit Consumption per Connection | m3/d | | | | | | _ | | | | | | | | | |
| Domestic | | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.606 | 0.606 | 0.606 | 0.562 | 0.562 | 0.562 | 0.674 | | |
| without Water Rights | | 0.646 | 0.646 | 0.646 | 0.646 | 0.646 | 0.646 | 0.514 | 0.514 | 0.514 | 0.539 | 0.539 | 0.539 | 0.586 | | - |
| with Water Rights | | 0.916 | 0.916 | 0.916 | 0.916 | 0.916 | 0.916 | 0.708 | 0.708 | 0.708 | 0.588 | 0.588 | 0.588 | 0.782 | | |
| Commercial | | 0.288 | 0.288 | 0.288 | 0.288 | 0.288 | 0.288 | 0.245 | 0.245 | 0.245 | 0.202 | 0.202 | 0.202 | 0.256 | | |
| Industrial | | 0.730 | 0.730 | 0.730 | 0.730 | 0.730 | 0.730 | 0.605 | 0.605 | 0.605 | 0.598 | 0.598 | 0.598 | 0.666 | | |
| Government | | 12.064 | 12.054 | 12.064 | 12.064 | 12.064 | 12.064 | 12.059 | 12.059 | 12.059 | 12.816 | 12.816 | 12.816 | 12.251 | | |
| - | x 1000 | | | | : | | | | | | | ; ; | | ÷ | | |
| (6 persons per Domestic Connection) | | 1.081 | 1.081 | 1.081 | 1.081 | 1.081 | 1.081 | 1.169 | 1.169 | 1.169 | 1.193 | 1.193 | 1.193 | 1.131 | | |
| Damascus City | × 1000 | | | | | | | | | | | | | • | | |
| (from Census) | | | | | | | | | | | | | | 1,422 | | |
| 6 Percentage of Population Steved | _ક ્ | 92 | 76 | 76 | 76 | 76 | 92 | 8 | 8 | \$ | * | 33 | 3 | 8 | | |
| (without Informal residents) | | | | | | | | - | | | | | | | | |
| 7 Water Consumption per capita (1/5) | <u> </u> | 129 | 129 | 129 | 129 | 129 | 129 | 11.5 | 115 | 115 | | 112 | 112 | 122 | | |
| | | | | | | | | | | | | | | | | |

Table 5.42 (2/2) Summary of Seasonal Water Consumption from Bill in 1995

| | Unit | Jan. | Feb. | Mar. | Apr. | May | June J | July | Aug. | Seo. | <u>ا</u> ق | Nov | 200 | Average | Total | Percentage |
|------------------------------------|----------|--|------------|------------|-------------|-------------|-----------|-------------|---------------|-----------|---------------|--------|--------|---------------|------------|--|
| | | | St Oughton | - - | | 2nd Quarter | | 1 | 3rd Ouarter | | 1 | 1 2 | | : | X X X | (%) |
| 8 Percentage of Meter Maifunction* | tķ | | | | i | , | | | _ | <u> </u> | | | 7 | | | |
| Donxestic | | 35 | 35 | 35 | 35 | 35 | 35 | 38 | 38 | 38 | 봈 | × | 3. | 35.597 | | |
| without Water Rights | | 8 | 36 | 36 | 8 | 36 | 38 | 45 | 45 | 45 | 88 | 38 | 38 | 38.683 | en Cital | |
| with Water Rights | | X | * | አ | × | * | त | 90 | 30 | 8 | 8 | ጽ | 30 | 32,118 | | |
| Commercial | | LS | 57 | 57 | 57 | 22 | S7 | 63 | 63 | 63 | द्र | K | ĸ | 57.645 | | |
| Industrial | | 47 | 7.4 | 47 | 127 | 47 | 1.7 | φ? | 3 | 84 | S | 8 | 8 | 48.171 | | A TOTAL OF SECTION AND ADDRESS OF SECTION ADDRESS |
| Government | | 52 | 26 | 52 | 92 | 56 | 56 | 4 | \$ | 8 | 83 | ä | 83 | 29.859 | | |
| Avenge | | 38 | 38 | 38 | 85 | 38 | 88 | . 42 | 42 | 42 | 37 | 37 | 375 | 38.64 | | |
| 9 Unit Consumption per Connection | | | | | | | | | | : : | - | : | | - | | |
| (without Inefficient WAter Meter) | т3/д | | : | ÷ | | | | | | <u>-i</u> | | | | rinde, side 4 | | 4 664 |
| Domestic | | 1.175 | 1.175 | 1.175 | 1.175 | 1.175 | 1.175 | 0.979 | 626.0 | 0.979 | 0.855 | 0.855 | 0.855 | 1.0.6 | | |
| without Water Rights | | 1.005 | 1.005 | 1.005 | 1.005 | 1.005 | 1.005 | 0.938 | 0.938 | 0.938 | 0.871 | 0.871 | 0.871 | 0.955 | | |
| with Water Rights | | 1.391 | 1.391 | 1.391 | 1.391 | 1.391 | 1.391 | 1.015 | 1.015 | 1.015 | 0.840 | 0.840 | 0.840 | 1.159 | | |
| Commercial | | 0.666 | 0.666 | 0.666 | 0.666 | 0.666 | 0.666 | 0.663 | 0.663 | 0.663 | 0.440 | 0.440 | 0.440 | 0.609 | | |
| Industrial | | 1.386 | 1.386 | 1.386 | 1.386 | 1.386 | 1.386 | 1.166 | 1.166 | 1.166 | 1.195 | 1.195 | 1.195 | 1.2% | | |
| Government | | 16.245 | 16.245 | 16.245 | 16.245 | 16.245 | 16.245 | 20.012 | 20.012 | 20.012 | 17.855 | 17.855 | 17.855 | 17.589 | | |
| 10 Domestic per Served Population | | /************************************* | | | | - | | | | | | | | * est-com | 3- NC 85-4 | |
| (without Inefficient WAter Meter) | | | | | | : | | | - | | | - | | | | |
| Domestic Consumption | p N | 161 | 161 | 191 | 161 | 161 | 191 | 120 | 159 | 159 | 140 | 3 | 140 | 170 | | |
| without Water Rights | 3 | 3 | इ | 8 | 72 | द्र | ढ़ | 153 | 153 | 153 | 142 | 142 | 142 | 156 | | erane. |
| with Water Rights | lcd | 227 | 227 | 227 | 227 | 227 | 227 | 166 | 166 | 991 | 137 | 137 | 137 | 189 | | - |
| 11 Sesonal Load Factor | % | | | | | | | | | | | | -ca-r | | | |
| Domestic | | 109 | 109 | 109 | 801 | 109 | 801 | ä | ま | ĸ | 68 | 63 | 68 | 100,000 | | |
| without Water Rights | | 110 | 110 | 110 | 110 | 110 | 110 | 88 | 88 | 88 | 83 | 6 | 8 | 100.000 | | er yezirel |
| with Water Rights | | 801 | 38 | 108 | 108 | 108 | 108 | 8 | 8 | \$ | द्ध | Z | 35 | 100.000 | | |
| Commercial | | 108 | 108 | 108 | 108 | 108 | 108 | 2.6 | 1.6 | .65 | 82 | 83 | 87 | 100.000 | | |
| Industrial | | 110 | 110 | 110 | 110 | 110 | 110 | 91 | 91 | 16 | 8 | 8 | 8 | 100.000 | | |
| Government | | 86 | 86 | 8 | 8 | 86 | 8 | 8 | 8 | \$ | 105 | 105 | 105 | 100.000 | | |
| Average | | 106 | 106 | 100 | 106 | 108 | 106 | 95 | 95 | 95 | 92 | 8 | દ્ધ | 100,000 | | : |
| (Source : DAWSSA) R | Remark ' | Remark *: Meter Malfunction includs number of meter under extimation and no meter reading. | alfunction | includs nu | moer of r | octer unde | restimati | ou pue uc | meter read | ing. | | ; | | | | |

Remark *: Meter Malfunction includs number of meter under estimation and no meter reading.

Table 5.4.3 Suspension of The Water Supply (1991 - 1995)

| : | : | | | - | | | | | | | | Citte : Month / Inchite | S / INDIAN |
|---------|------------------|--------|------|-------|------|------|------|------|------|------|-------|-------------------------|------------|
| Year | Jan. | Feb. | Mar. | Apr. | May | June | July | Aug. | Sep. | Oct. | Nov. | Dec. | Average |
| 1991 | 0 | 0 | 0 | 0 | 0 | 0 | 240 | 240 | 240 | 240 | 240 | 240 | 120 |
| 1992 | 240 | 200 | 0 | 0 | 0 | 0 | 0 | 0 | 80 | 180 | 210 | 240 | 96 |
| 1993 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 70 | 150 | 180 | . 180 | 210 | 99 |
| 1994 | 8 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 08 | 200 | 200 | 210 | 63 |
| 1995 | 100 | 9 | 0 | 0 | 0 | 0 | 150 | 150 | 150 | 180 | 225 | 250 | 105 |
| Average | 8 | 52 | 0 | 0 | 0 | 0 | 78 | 6 | 140 | 196 | 211 | 230 | 06 |
| Day | 3.33 | 2.17 | 00.0 | 00.00 | 0.00 | 0.00 | 3.25 | 3.83 | 5.83 | 8.17 | 8.79 | 9.58 | 3.75 |
| | (Source: DAWSSA) | AWSSA) | | | | | | | | | | | |

5-59

Table 5.4.4 Unit Water Consumption by DAWSSA's Classification

| | Unit | Un | it Water Consu | mption |
|---------------------------------|-----------------|--------------|--|------------------|
| Classification | | (Daniascus)* | (Japan) | (Recommendation) |
| 1 Doniestic Use | lped | (170)** | | |
| High Income | | 212 -236 | 160 - 250 | 250 |
| Middle Income | | 163 - 191 | y | 200/210/220 |
| Low Income | | 120 - 184 | <u> 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 </u> | 170 / 180 / 190 |
| 2 Governmental Use | | (18)** | | |
| Government Offices & Facilities | m3/d/connection | 51 | | 51 |
| | l/d/worker | 266 | 100 - 200 | |
| School | m3/d/connection | 14 | | 24 |
| | 1/d/student | 26 | 40 - 50 | |
| University | m3/d/connection | 254 | | 500 |
| | I/d/student | 53 | 100 - 200 | |
| Hospital | m3/d/connection | 370 | | 800 |
| | 1/d/bed | 340 | 1,000 | |
| Sport Facilities | m3/d/connection | 176 | Required | 176 |
| | l/d/worker | 486 | survey | |
| 3 Commercial Use | m3/d/connection | (0.609)** | | |
| Hotel | | 148 | | 148 |
| | I/d/bed | 371 | 250 - 300 | |
| General Commercial User | m3/d/connection | | Required | 15 |
| - Large Commercial User | | 10 | survey | - 14 |
| - Others | | 1 | | 1 |
| Theater | m3/d/connection | 44 | Required | 44 |
| | | | survey | |
| 3 Industrial Use | m3/d/connection | (1.3)** | | |
| Factories | m3/d/connection | | Required | 128 |
| - Large | : | 287.5 | survey | |
| - Medium | | 84.4 | - | |
| - Smalt | | 12.6 | | |
| Manufacturing | m3/d/connection | 0.603 | | 0.600 |
| 1 Religious & Public Facilities | | | | |
| Um-Ayad Mosque | m3/d/connection | 44 | | 44 |
| Other Mosques & Church | m3/d/connection | . 4 | | 4 |
| Public Tap/Pountain | m3/d/connection | 72 | 1 | 72 |

(Remark)

Unit water consumption in Damascus are data from the results of the Interview survey and the water meter reading survey.

^{**} Average unit water consumption based on the billed consumption in 1995.

Table 5.4.5 Basic Factor of Water Use Classification

| | | 3001 | 0000 | > 000 | 2010 | 2015 |
|---|--------|--------|--------|-----------------|--------|--------|
| rear | | 2 | 3 | 3 | 207 | 2017 |
| Factor for Basic Frame | Unit | 0 | . 5 | 10 | 15 | 20 |
| 1 Income Classification (Domestic) | | | | | | |
| 1) High | 8 | 16.7 | 17.5 | 18.4 | 19.2 | 20.0 |
| Medium | ૪ | 18.0 | 23.5 | 29.0 | 34.5 | 40.0 |
| \overline{\chi_{\text{v}}} | 8 | 39.5 | 49.0 | 52.7 | 46.3 | 0.04 |
| Informal | સ્થ | 26.0 | 10.0 | 0.0 | | |
| 2) Average Domestic Demand per capita (3) | pod : | 170.0 | 180.0 | 193.0 | 204.0 | 214.0 |
| 2 Connection of Main Water Users | Number | 37.475 | 37,895 | 38,912 | 41.494 | 45,453 |
| 1) Governmental Users | Number | 166 | 1,002 | 1.029 | 1.097 | 1,202 |
| Government Offices & Facilities | | 650 | 657 | 519 | 720 | 788 |
| Schools | ٠. | 235 | 238 | 244 | 260 | 285 |
| Universities | | 42 | 42 | 4 | 47 | 51 |
| Hospitals | | 97 | 47 | 48 | 51 | 99 |
| Sport Facilities | | 18 | 18 | 19 | 20 | 22 |
| 2) Industrial Users | Number | 2,310 | 2,336 | 2,399 | 2.558 | 2,802 |
| Factories | | 38 | 38 | 39 | 42 | 46 |
| Manufacturing | | 2,272 | 2,297 | 2,359 | 2,516 | 2,756 |
| 3) Commercial Users | Number | 33,525 | 33,901 | 34,810 | 37.121 | 40,662 |
| Hotels | | 68 | 06 | 92 | 66 | 108 |
| Large Commercial Users | | 659 | 999 | 684 | 730 | 799 |
| Other Commercial Users | | 32,722 | 33,089 | 33,977 | 36,232 | 39.6 |
| Restraints | | 41 | 41 | 43 | 45 | 80 |
| Theaters | | 14 | 14 | 15 | 16 | 17 |
| 4) Public Use (Un-billed) | Number | 679 | 929 | 674 | 719 | 787 |
| Mosques & Church | | 534 | 540 | 554 | 591 | 648 |
| Public Taps/Fountains | : | 115 | 116 | 119 | 127 | 139 |
| | | | | | | |

Table 5.4.6 Water Demand Forecast by Water Use Classified Analysis (Alternative 1)

| | | : | | | | |
|---|--------------|---------|-----------|---------------------------------------|---------|-----------|
| Year | | 1995 | 2000 | 2005 | 2010 | 2015 |
| Factor for Basic Frame | Unit | 0 | 5 | 10 | 15 | 20 |
| 1 Area (km2) | km2 | 111.62 | 112.86 | 115.86 | 123.49 | 135.17 |
| 1.1 Existing City | | 106.25 | 106.25 | 106.25 | 106.25 | 106.25 |
| 1.2 Villages & New Developed Area | | 5.37 | 6.61 | 9.61 | 17.24 | 28.92 |
| 2 Population | 1000 persons | 1,554 | 1,737 | 1,949 | 2,205 | 2,501 |
| 2.1 City | | 1,422 | 1,570 | 1,734 | 1,914 | 2,113 |
| 2.2 Villages & New Development Area | | 132 | 167 | 215 | 291 | 388 |
| 3 (Billed) Population Served | 1000 persons | 1,150 | 1,563 | 1,949 | 2,205 | 2,501 |
| 4 Percentage of Population Served (3/2) | Ą. | 74 | 90 | 100 | 100 | 100 |
| 5 Daily Average Water Demand | m3/d | 310,600 | 448,200 | 555,100 | 618,000 | 694,500 |
| 5.1 Water Deficits* | m3/d | 86,500 | | | 1 | |
| 5.2 (Billed Consumption) | m3/s | 224,100 | | | | |
| 1) Domestic | m3/a | 126,300 | 266,600 | 369,700 | 423,100 | 485,200 |
| 2) Governmental Use | m3/3 | 37,300 | 98,800 | 101,400 | 108,200 | 118,500 |
| Gövernment Offices & Facilities | m3/d | | 33,209 | 34,100 | 36,363 | 39,832 |
| Schools | m3/d | | 1,010 | 1,037 | 1,106 | 1,211 |
| Universities | m3/d | 1 · | 21,038 | 21,602 | 23,036 | 25,233 |
| Hospitals | m3/d | | 36,866 | 37,855 | 40,367 | 44,218 |
| Sport Facilities | m Wi | | 6,672 | 6,851 | 7,306 | 8,003 |
| 3) Commercial Use | m3/d | 7,800 | 23,700 | 24,400 | 26,000 | 28,400 |
| Hotels | m Mi | | 13,196 | 13,550 | 14,449 | 15,827 |
| Commercial Users | m3/d | | 9,903 | 10,168 | 10,843 | 11,878 |
| Theaters | m3Ai | | 617 | 634 | 676 | 740 |
| 4) Industrial Use | m3/d | 1,500 | 6,100 | 6,300 | 6,700 | 7,300 |
| Factories | m3/4 | . : | 4,720 | 4,847 | 5,169 | 5,662 |
| Manufacturing | m3/3 | 1 | 1,372 | 1,409 | 1,503 | 1,646 |
| 5) Water Right Obligations | m3/3 | 40,700 | 42,500 | 42,500 | 42,500 | 42,500 |
| (Un-billed Consumption) | | | · | | | |
| 6) Religious & Public Use | m3/d | 10,500 | 10,500 | 10,800 | 11,500 | 12,600 |
| Mosques & Churches (500 m2) | m3AJ | 2,176 | 2,180 | 2,237 | 2,383 | 2,607 |
| Public Taps/Special Area | m3A1 | 8,280 | 8,295 | 8,517 | 9,083 | 9,949 |
| 6 Uncounted for Water | | 3,73,33 | | | · | |
| 6.1 (% of Production Water Required) | 94 | 37 | 61 | 69 | 72 | 75 |
| 62 % of UFW | g . | 62.7 | 39 | 31 | 28 | 25 |
| 1) Meter Malfunction | 9, | 14.4 | 3 | 0 | 0 | 0 |
| 2) Informal Use | 97, | 13.6 | 4 |] | 0 | 0 |
| 3) System Losses | 9, | 34.7 | 32 | . 30 | 28 | 25 |
| 7 Daily Average Water Requirement** | m3/3 | 678,000 | 739,600 | 801,000 | 861,900 | |
| 7.1 Average Flow | (l/s) | 7,800 | 8,600 | | | |
| 7.2 Yearly Water Requirement | MCM/y | 247.5 | 270.0 | | 314.6 | |
| 7.3 Yearly Water Production Amount | MCM/y | 218.3 | | | | |
| 8 Saving Water | m3/d | 2,0.7 | 462,000 | 115,000 | 29,900 | 42,600 |
| Losses in case of the former % of UFW | m3AJ | | 1,201,609 | 916,007 | | |
| 9 Daily Maximum Water Requirement | m3/3 | 668,800 | | | | |
| (Load Factor: 1.14) | 1113/0 | 000,000 | 043,100 | 212,100 | 700,000 | 1,000,000 |
| 10 Unit Domestic Demand per capita | 1004 | 110 | 171 | 190 | 192 | 194 |
| 11 Unit Water Demand per capita | lood | 270 | 287 | 285 | 280 | 278 |
| (Remark) * : Estimated on the assumption of the | Iped | | | · · · · · · · · · · · · · · · · · · · | 1 200 | 1 |

(Remark) *: Estimated on the assumption of the water consumption per capita with 185 lpcd.

^{**:} Effective water Requirement based on data of production on April.

[:] UFW in 1995 is estimated from water production amount (598,100 m3/d)

Table 5.4.7 Water Demand Forecast by Water Use Classified Analysis (Alternative 2)

| Year | : | 1995 | 2000 | 2005 | 2010 | 2015 |
|---|--------------|---------|-----------|---------|---------------|---------|
| Factor for Basic Frame | Unit | 0 | 5 | 10 | 15 | 20 |
| 1 Area (km2) | km2 | 111.62 | 112.86 | 115.86 | 123,49 | 135 |
| 1.1 Existing City | | 106.25 | 106,25 | 106.25 | 106.25 | 106.3 |
| 1.2 Villages & New Developed Area | | 5.37 | 6.61 | 9.61 | 17.24 | 28.9 |
| 2 Population | 1000 persons | 1,554 | 1,737 | 1,949 | 2,205 | 2,50 |
| 2.1 City | | 1,422 | 1,570 | 1,734 | 1,914 | 2,1 |
| 2.2 Villages | · | 132 | 167 | 215 | 291 | 38 |
| 3 (Billed) Population Served | 1000 persons | 1,150 | 1,563 | 1,949 | 2,205 | 2,50 |
| 4 Percentage of Population Served (3/2) | 74 | 74 | 90 | 100 | 100 | 100 |
| 5 Daily Average Water Demand | m3/J | 322,100 | 476,400 | 594,100 | 662,100 | 744,50 |
| 5.1 Water Deficits* | m3/d | 98,000 | | | | |
| 5.2 (Billed Consumption) | m3/J | 224,100 | | | | |
| 1) Domestic | m3/d | 126,300 | 294,800 | 408,700 | 467,200 | 535,20 |
| 2) Governmental Use | m3/d | 37,300 | 98,800 | 101,400 | 108,200 | 118,50 |
| Government Offices & Facilities | m3/d | | 33,209 | 34,100 | 36,363 | 39,8 |
| Schools | m3/d | | 1,010 | 1,037 | 1,106 | 1,2 |
| Universities | m3/d | i | 21,038 | 21,602 | 23,036 | 25,2 |
| Hospitals | m3/3 | | 36,866 | 37,855 | 40,367 | 44,2 |
| Sport Facilities | m3/s | | 6,672 | 6,851 | 7,306 | 8,00 |
| 3) Commercial Use | m3/J | 7,800 | 23,700 | 24,400 | 26,000 | 28,40 |
| Hotels | m3/J | | 13,196 | 13,550 | 14,449 | 15,8 |
| Commercial Users | m3/d | 1 | 9,903 | 10,168 | 10,843 | 11,8 |
| Theaters | m3AI | . | 617 | 634 | 676 | 74 |
| 4) Industrial Use | m3At | 1,500 | 6,100 | 6,300 | 6,700 | 7,30 |
| Factories | m3/d | : | 4,720 | 4,847 | 5,169 | 5,66 |
| Manufacturing | m3/s | · · I | 1,372 | 1,409 | 1,503 | 1,6 |
| 5) Water Right Obligations | m3/d | 40,700 | 42,500 | 42,500 | 42,500 | 42,50 |
| (Un-billed Consumption) | 7777 | | 2715.77 | | | |
| 6) Religious & Public Use | m3/d | 10,500 | 10,500 | 10,800 | 11,500 | 12,60 |
| Mosques & Churches (500 m2) | m3/d | 2,176 | 2,180 | 2,237 | 2,383 | 2,6 |
| Public Taps/Special Area | m3/d | 8,280 | 8,295 | 8,517 | 9,083 | 9,9. |
| 6 Uncounted for Water | 711,000 | 0,200 | | | | |
| 6.1 (% of Production Water Required) | · | 37 | 61 | 69 | 72 | 75 |
| 6.2 % of UFW | 7 | 62.7 | 39 | 31 | 28 | 25 |
| 1) Meter Malfunction | 94 | 14,4 | 3 | 0 | 0 | 0 |
| 2) Informal Use | A A | 13.6 | 4 | ΐΙ | ő | 0 |
| | A K | 34.7 | 32 | 30 | 28 | 25 |
| System Losses Daily Average Water Requirement** | m3/3 | 678,000 | 786,100 | 857,300 | 923,400 | 992,70 |
| | | 7,800 | 9,100 | 9,900 | 10,700 | 11,50 |
| 7.1 Average Flow | (1/s) | 247.5 | 286.9 | 312.9 | 337.0 | 362 |
| 7.2 Yearly Water Requirement | MCM/y | 218.3 | 280.9 | 312.9 | 337.0 | 302 |
| 7.3 Yearly Production Amount | MCM/y | 210.3 | 491,100 | 123,100 | 32,000 | 45,7 |
| 8 Saving Water | m3/d | | 1,277,212 | | 955,411 | 1,038,3 |
| Losses in case of the former % of UFW | m Wd | (40 000 | | 980,363 | | |
| 9 Daily Maximum Water Requirement | m3/d | 668,800 | 896,200 | 977,300 | 1,052,700 | 1,131,7 |
| (Load Factor: 1.14) | | | 100 | | | 214 |
| 10 Unit Domestic Demand per capita | 1pcd | 110 | 190 | 210 | 212 | 214 |
| 11 Unit Water Demand per capita Remark) * Estimated on the assumption of the v | lped | 280 | 305 | 305 | <u> 300 </u> | 298 |

(Remark) *: Estimated on the assumption of the water consumption per capita with 195 lpcd.

^{**:} Effective water Requirement based on data of production on April

[:] UFW in 1995 is estimated from water production amount (598,100 m3/d)

Table 5.4.8 Water Demand Forecast by Water Use Classified Analysis (Alternative 3)

| | Year | 1995 | 2000 | 2005 | 2010 | 2015 |
|--|---------------|---------|-----------|---------|---------|-----------|
| Factor for Basic Frame | Unit | 0 | 5 | 10 | 15 | 20 |
| 1 Area (km2) | km2 | 111.62 | 112.86 | | 123.49 | 135.17 |
| 1.1 Existing City | , <u>-</u> | 106.25 | 106.25 | 106.25 | 106.25 | 106.25 |
| 1.2 Villages & New Developed Area | | 5.37 | 6.61 | 9.61 | 17.24 | 28.92 |
| 2 Population | 1000 persons | 1,554 | 1,737 | 1,949 | 2,205 | 2,501 |
| 2.1 City | 1000 (CISCII) | 1,422 | 1,570 | 1,734 | 1,914 | 2,113 |
| 2.2 Villages | | 132 | 167 | 215 | 291 | 388 |
| 3 (Billed) Population Served | 1000 persons | 1,150 | 1,563 | 1,949 | 2,205 | 2,501 |
| 4 Percentage of Population Served (3/2 | | 74 | 90 | 100 | 100 | 100 |
| 5 Daily Average Water Demand | m3/d | 327,900 | | | 644,300 | 744,500 |
| 5.1 Water Deficits* | m3/J | 103,800 | 435,700 | 502,500 | 011,500 | 177,500 |
| ■ | m3/J | 224,100 | | | | |
| 5.2 (Billed Consumption) | n13/0 | 126,300 | 272,100 | 376,900 | 449,400 | 535,200 |
| 1) Domestic | | 37,300 | | 101,400 | 108,200 | 118,500 |
| 2) Governmental Use | m3AJ | 37,300 | | | 36,363 | 39,832 |
| Government Offices & Facilities | m3AI | | 33,209 | 34,100 | 1,106 | 1,211 |
| Schools | m3AJ | | 1,010 | | | |
| Universities | m3/d | | 21,038 | 21,602 | 23,036 | 25,233 |
| Hospitals | m3/d | | 36,866 | 1 1 1 | 40,367 | 44,218 |
| Sport Facilities | m3/d | | 6,672 | 6,851 | 7,306 | 8,003 |
| 3) Commercial Use | m Vd | 7,800 | 23,700 | 24,400 | 26,000 | 28,400 |
| Hotels | m3/d | | 13,196 | | 14,449 | 15,827 |
| Commercial Users | m3/d | 4 | 9,903 | 10,168 | 10,843 | 11,878 |
| Theaters | m3VJ | | 617 | 634 | 676 | 740 |
| 4) Industrial Use | m3/J | 1,500 | 6,100 | 6,300 | 6,700 | 7,300 |
| Factories | t\£m | | 4,720 | 4,847 | 5,169 | 5,662 |
| Manufacturing | m3/s | | 1,372 | 1,409 | 1,503 | 1,646 |
| 5) Water Right Obligations | m3/d | 40,700 | 42,500 | 42,500 | 42,500 | 42,500 |
| (Un-billed Consumption) | | | | | | |
| 6) Religious & Public Use | m3/d | 10,500 | 10,500 | 10,800 | 11,500 | 12,600 |
| Mosques & Churches (500 m2) | ni3/3 | 2,176 | 2,180 | 2,237 | 2,383 | 2,607 |
| Public Taps/Special Area | m3/d | 8,280 | 8,295 | 8,517 | 9,083 | 9,949 |
| 6 Uncounted for Water | | | | 1.1 | | |
| 6.1 (% of Production Water Required) | 92 | 37 | 61 | 69 | 72 | 75 |
| 6.2 % of UFW | 94 | 62.7 | 39 | 31 | 28 | 25 |
| 1) Meter Malfunction | 9. | 14.4 | 3 | 0 | 0 . | 0 |
| 2) Informal Use | 94 | 13.6 | 4 | 1 | 0 | 0 |
| 3) System Losses | 54 | 34.7 | 32 | 30 | 28 | 25 |
| 7 Daily Average Water Requirement** | m3/d | 678,000 | 748,700 | 811,400 | 898,600 | 992,700 |
| 7.1 Average Flow | (1/s) | 7,800 | 8,700 | 9,400 | 10,400 | 11,500 |
| 7.2 Yearly Water Requirement | MCM/y | 247.5 | 273.3 | 296.2 | 328.0 | 362.3 |
| 7.3 Yearly WAter Production Amount | MCM/y | 218.3 | | | | |
| 8 Saving Water | tv3/3 | | 467,700 | 116,500 | 31,100 | 45,700 |
| Losses in case of the former % of UFW | | | 1,216,354 | 927,888 | | |
| 9 Daily Maximum Water Requirement | | 759,400 | 853,500 | | | 1,131,700 |
| (Load Factor : 1.14) | | | | | | |
| 10 Unit Domestic Demand per capita | iped | 110 | 180 | 193 | 204 | 214 |
| 11 Unit Water Demand per capita | iped | 285 | 290 | 289 | 292 | 298 |

Sales Sales


(Remark) * : Estimated on the assumption of the potential water consumption per capita with 200 lpcd.

^{** :} Effective water Requirement based on data of production on April

[:] UFW in 1995 is estimated from water production amount (598,100 m3/d)

| (Alternative | |
|------------------|--|
| eut | |
| Requirem | |
| Water | |
| > | |
| ٠ | |

| ear | Jan. | Feb. | Mar. | Apr. | May | June | July | Aug. | Sep. | O t | Nov. | Dec | Total |
|--------|------|------|------------|------|-----|----------|------|------|------|--------|------|------|-------|
| 2000 | 21 | | 12 | 22 | 23 | 23 | 25 | 26 | 24 | 23 | 23 | 22 | 274.0 |
| 2002 | 23 | 23 | <u></u> 83 | 22 | 23 | <u> </u> | 27 | 82 | 38 | 23 | 77 | ձ | |
| 2010 | IJ | n | | 25 | 27 | 28 | 8 | | 53 | | 27 | 52 | - 1 |
| 2015 | 28 | : . | 28 | / | 8 | 31 | | 4, | 32 | 30 | 30 | 29. | |
| Factor | 0.92 | 0.92 | 0.93 | 76.0 | 1.8 | 1.03 | 1.10 | 1.14 | 1.05 | 10.1 | 66.0 | 0.97 | 12.00 |



| Numa of Acres | | | | | | | | | | | | | | | | | | | |
|--|------------------|----------|-----------------------|--------------------|--------------------|----------|-------------|-----------|----------------------------------|-------------|----------|--------------|---------------------------------|------------|------------|-----------------|--------|---------------------------------|---|
| CALLIE OF THE | Paυγ | | Density Water Require | guirement (m.Vd | #Y | Area | Density | Water Reg | Density Water Requirement (m. Vd | Scroot | ₩ | Density | Danaty Water Requirement (m3/d) | ment (m.Wd | Served | Area | Denmiy | Density Water Requirement (m3/6 | ent (m3/d |
| | Population (ha) | | Average | e Maximum | Population | ŝ | | Average | Average Maximum | Poyulation | ê | | Average | Maximum | Pomilation | ê | | Average | Meximum |
| Villages | | _ | - | | 7.7 | | | | | | | | | - | | | | | |
| Figeh | * 0×6* | Ē | 26 | 1,700 | | | | 1 | 81.6.1 | | 4 | | 1 | 2,020 | 5,003 | 44 | 115 | 1,808 | 1.08 |
| AJ Khadra | | <u>.</u> | | 000111100 | | | 233 | | | 1,788 | 53 | | 766 | 1,134 | 2,858 | ũ | 4 | 1,005 | 1.146 |
| Вазяте | | | | | | | L | | S.C. | | 8: | | Ř | £. | 8 | × | ż | 501 | ======================================= |
| Ashrafye Wadi | | 1 | S | 1,400 | 4,037 | | _ | | | 4.138 | 1 | | 1,476 | 1.683 | 4.34 | | 35 | 1.503 | 1.71 |
| Judayde | | v. | | 1,900 | | | | | 0,57 | | | | 066'1 | 3,269 | | · · | 8 | 2,033 | 1317 |
| Yarre | | \$. | | 00100 | | \$. | 4 | 006.6 | | `` | | | 0,840 | 0.5.1 | 5 | \$. | 8 | 10,123 | 2. |
| Jemarya | | L | 424 | 01.1 | 0 2475 | | | | 920'1 | 3 | | | 936 | 1,055 | | • | 5 | 616 | 8 |
| Kudsava | - | | | | Ì | - | | - | | " | 1.5 | l | 20.505 | 27.75 | 63.412 | × | 104 | 23.001 | 8 |
| Takadom | | Ŀ | | Ì | Í | * | L | | | | 8 | ŝ | 17.727 | 20,00 | 2,00 | 35 | 00 | 085.01 | 2 |
| Military Area & (Remidential) | | L | | 000 9 | 40.4 | | L | 00. | ľ | 020 21 | | ١. | Š | 27.0 | 14 040 | ¥ | ž | .65 | ţ |
| Meansha | | - | | | | | L | | | L | | | č | | | | - | ē | |
| 1 | 1 | 1 | 1 | ı | П | | Š | | | L | 1 | l | 2000 | 14007 | 012.03 | : | | 100 | , |
| ALT-CAR | r 14/ 76 | - | | מאטיים מאטיים | 7 | 7 | ŀ | 200 | e i | 010.701 | 7 | ē. | 00.4001 | Š | X X XX | 2 | | , v - c | /4 A |
| Proposed New Development Area | | 4 | - | | ij | | 1 | ļ | | ۱. | i | | | | - | - | | - † | |
| Kudsaya New Suburb | - | _ | | ō | 0 30,000 | 8 | 80 | 00:11 | 0 12.540 | 48.315 | နွ | :0 | 17,234 | 19,646 | 41 144 | 300 | 178 | 10,1151 | 13. |
| Proposed Kudsaya New Suhurb | | | | 0 | 0 | 1 | \$1 d miles | | 77. | | | - | ¢ | ٥ | ~ | - | | Ó | ٥ |
| Dummar Extension Area (1st phase) | 20,500; 124 | _ | 7 1651 | 7.500 X,600 | 0 26.793 | 124 | 216 | ò | 271.11 1008. | 35.017 | 124 | 23.2 | 12,518 | 14.771 | 38,662 | 7.1 | 21.5 | 13,862 | 15.803 |
| Oummer Extension Area (2nd obase) | | L | | 200.00 | | | L | | | ĺ | | | Ċ | 0 | 34,000 | 216 | 91 | ×.946 | 10.210 |
| Kamiono New Town (650 ha) | | _ | | | 5 | | | _ | | | | | o | 0 | | | - | ō | |
| Assed Subset (last object) | | - | - | | - | | | - | 0 | 07% 11 | | 1 | 1900 1 | 4 818 | 13.057 | 9 | | 4.677 | 15 |
| Account State of Confession | | - | - | 1 | | | | | | L | ž | 1 | 100 | 991 01 | 77 456 | 5 | 1 | 100 | 13.674 |
| Compa Construct (- to Compa) | | 1 | | | | | | | | L | | - | 1 | 8017 | 200 | 2 3 | | 385 | 1000 |
| Asset Mirelly Chicheles Area | | 1 | | | 1 | 1 | | | | | 900 | ľ | 5 | | * | 1 | 1 | | |
| A STRONG CITICAL ARCH | | 1 | | | 5 4 | | | | | | ć | > | 5 6 | ^ | 1 | | 5 | 5 | 3 |
| (A) | | - | | | | | | | |)) | | | | | *** | • | ; | | 2 |
| Proposed Assad City Extension Area (1) | | - | - | | 5 0 | | | | 0 | | | | ٥ | 0 | | 1 | - | | |
| Proposed Assad City Extension Area (2) | | 4 | 1 | | | | | | | | | | o · | 0 | | Ī | + | o | 3 |
| Proposed Assad City Extension Area (.) | | 1 | | | Ţ | ļ | - | | | | | ì | D ' | 0 | - | - | | ò | ٠ ا |
| Special Area Zone (State Pactory) | 8 | | 190 | 2 | 4 080 | | 3 | | (W | 9 | | ž | 200 | 82 | 44:X | 7.† | 12. | 2 | 92 |
| Others (not classified) | | | | | 1. | ŀ | 1 | | | _L | Ţ | 1 | ٥ | ° | | | | 0 | |
| Sub-tokai | 24 000 | G. | X | X 200 | 10.00 | Ofmy | | 49. | 171 | 124 7K4 | - | 101 | 2 | 40,66 | 8 | 340 | × | 73.243 | 5 |
| Extrating Dammeus City | | L | | | . 1 | Ī | | : | : | | | 1 | + | ٧ | | | | | |
| Kuku Aldyn | ¥ 27. | _ [| j | 75.700 86.285 | \$ 203.299 | | | × × | 00.10 | 1 | į | | XX,1651 | 100.00 | 247.808 | 437 | \$ | 709'50 | ě |
| Mouhajrocn | 85.523 | 9 | 235 35 | - | 5.424 | | . | 37.907 | _ | 104.35 | 8 | CX. | 41 SKK | 47.410 | 501,211 | £9. | 717 | 182 | 50.61 |
| Merze | 121,451 1,328 | | - | | . 1 | | | 67.115 | - 1 | | X2X. | į | 72,048 | 82,135 | 163.457 | 1,328 | £1 | 97.2.39 | X 0. |
| Kafar Sousch | 106,015 | | | 44,900 51,185 | | - | | 4X,0X | 0.x.1 | 13 | 8 | | 818.28 | 1905 | 142.682 | 8 | 611 | 56.172 | 64,0,36 |
| Kamwa | 73,710 20 | \$ | 274 40 | | 5 XI.381 | 3 | ğ | | | | 921 | | 45,507 | \$1,878 | 100.00 | \$ | 89. | 0+C'XT | \$ 000 |
| Kadam | 70,XSS 30 | _ | | 30,100 N.2KS | : 1 | İ | 1 | | | 86.17. |] | | 35,361 | 40,312 | 198,36 | 300 | 318 | 37.535 | 42.790 |
| Midan | 158.523 | Ş, | 5.16 66 | 66,900 76,185 | | i | Ş | 72,017 | ì | 04.230 | | | 77,641 | 88.511 | 213.351 | 8 | נַז | E.00.34 | 95,763 |
| Old City | | 14.5 | | 600 9,785 | | | | 8,807 | | | | | 10,835 | 12,35 | 27.479 | 145 | 8 | 10,583 | 8 |
| Shejthour | | 470 | 25. | 30,700 34,085 | | | | ĺ . | 37,404 | | | | \$.1.85 1.85 | 41,195 | 47.524 | 9 | 8 | 3x,3x7 | 43.76 |
| Servaja | <u>.</u> | <u>.</u> | | | ١., | | | | | 58.297 | | | 163.531 | 71.38 | - | ĺ | Ş | 67.421 | 76,860 |
| Yarmouk | 237.034 | - | .047 07 | 97,300 150,8K\$ | | 133 | _ | 917'501 | | 1 | | 1,276 | 780,111 | 136,60.5 | | | 1.408 | 123.066 | 140,395 |
| Jobar | 114,942 642 | | | | | | | 52.163 | | | | | 56.623 | 95.50 | 25. 26. | | ā | 106,003 | \$ 43 |
| Berne | 81,799 6 | 673 | 125 45 | | 1 | | | 47,083 | è | 1 | | | 116.0% | \$8.038 | | 12.0 | 3 | 54,147 | 61,73 |
| Kaboon | 76,961 497 | 7 | 115 | 200 27.5%5 | | | - | 24,749 | | | 497 | | 2X,66 | 32,674 |] | | 3. | 70.171 | \$. |
| Dummar | 27 855 75 | £ | | \$89'5T 009'5T | | | 1.7 | | 10 | ! | | 141 | 196.90 | 30,736 | ۲ | 473 | 155 | 28,314 | 32. 27 |
| Kassioun Mountain | 366 | S | _ | | | 360 | | | | | 2.956 | | | | | 3.956 | _ | _ | |
| Nub-total | 1,570,234 10,624 | | 148 689 | 689,000 784,875 | 5 1,733,664 | 10,624 | 163 | 734,884 | 14 ×17,768 | 8 1.914,107 | 10,624 | 180 | 706.343 | 907.X31 | 2113.324 | 10,624 | 661 | 856,190 | 976 056 |
| Total | 976 11 160 911 1 | | 154 iPS. | 250 x00 x x 45 000 | A95 11 087 810 1 0 | 785 11 1 | 071 | 1.000 | 100 | | 41.00 | | 1000 | | **** | | | | |

(Remarks)

1. Area of Villages is water served area.

1. It is a bulk water system to supply water from DAWSSA.

Table 5.5.1 Existing Resources - Canacities Used for Planning Purposes

| | | Capaci | ity | j | Seasonal |
|--|------------------------|----------------------|-------|------------------|-----------------------|
| Source Name | Installed ² | Minimum ³ | Ave | age ⁴ | Capacity ⁵ |
| | (l/s) | (l/s) | (l/s) | (m³/d) | (MCM) |
| Mazraa Welltield | 665 | 290 | 335 | 28,800 | 7.06 |
| Jobar Wellfield | 390 | 220 | 350 | 30,200 | 7.40 |
| Kaboon Wellfield | 83 | est 80 | 65 | 5,620 | 1.38 |
| Ibn Assaker Wellfield | 455 | 280 | 345 | 29,800 | 7.30 |
| Kadam Railway Wellfield | 350 | 200 | 305 | 26,500 | 6.49 |
| Oumawiyin Wellfield | 390 | 175 | 175 | 15,000 | 3.67 |
| University Wellfield | 420 | est 215 | 200 | 17,300 | 4.24 |
| Fringe Wells | 320 | 125 | 125 | 10,800 | 3.93 |
| Figeh Main Spring Average Year (1995) | 12,400 ¹ | • | 5,800 | 507,000 | 185.00 |
| Dry Year (1990) | - | 2,880 | 3,870 | 334,000 | 122.00 |
| Barada Spring Wellfield | 1,100 | 1,100 | 1,100 | 95,000 | 23.27 |
| TOTAL | | | | | |
| Average Year (1995) | 16,573 | | 8,800 | 766,020 | 249.74 |
| Dry Year (1990) | | 5,565 | 6,870 | 593,020 | 186.74 |

Notes:

- 1.
- Capacity limited to that of the supply tunnels during flood period Capacity of well sources is that of the current pumping equipment 2.
- 3. Minimum capacity is that produced in December 1990, at the lowest capacity of Figeh during a drought year. For sources not commissioned at that time or which have been subsiquently changed an estimate is made based upon December 1995.
- Average capacity is based upon operating the source at an achievable rate based on conditions in 1996. 4.
- Seasonal Capacity is the average rate applied for the abstraction season. This is taken as 365 days for Figeh and the Fringe Wells and 245 days (8 months) for other sources. 5.

Table 5.5.2 Barada (Al Sabl) Wellfield Details

| Well | Design | Q/s | RWL | Depth | Anticipated |
|---------|----------------|---------|--------|--------------|--------------|
| Number | Capacity (I/s) | (l/s/m) | (mbgl) | (m) | Drawdown (m) |
| Group 1 | | , | | | |
| 21K | 60 | 12.83 | 3.61 | 1020 | 4.7 |
| 215K | 30 | 3.13 | 4.20 | 250 | 9.6 |
| 243K | 60 | 5.76 | 2.65 | 343 | 10.4 |
| 244K | 80 | 22.98 | 2.77 | 232 | 3.5 |
| Group 2 | | | | | |
| 240K | 30 | 10.60 | 37.08 | 220 | 2.8 |
| 20/2 | 60 | 18.77 | 21.10 | 213 | 3.2 |
| 25/2 | 60 | 142.86 | 21.15 | 115 | 0.4 |
| Group 3 | | | | | |
| 247K | 30 | 7.92 | 21.30 | 243 | 3.8 |
| 227K | 20 | 8.31 | 18.23 | 250 | 2.4 |
| 23/3 | 10 | | - | ļ - . | - |
| 24/3 | 10 | 0.95 | 21.50 | 225 | 10.5 |

Table 5.5.3 Anticipated Behaviour for Takadom and Kywan Wellfield

| Well | A | В | P | Static Water Level (m) | Pumping Water Level (m) | Pump Capacity (m³/hr) |
|------|----------|-------------------------|-----|------------------------------|-------------------------------|-----------------------------|
| 1 | 0.0405 | 3.94 x 10 ⁻⁵ | 2 | 8 | 23.0 | 120 |
| 4 | . | - | - | 8 | 23.2 | 100 |
| 5 | 0.0126 | 3.15×10^{-4} | 2 | 8 | 23.1 | 100 |
| 6 | 0.0406 | 4.27×10^{-5} | 2 | 8 | 23.1 | 120 |
| 7 | 0.0406 | 4.27×10^{-5} | 2 | 8 | 23.8 | 120 |
| 8 | 0.0330 | 1.06×10^{-3} | 2 | 8 | 31.8 | 100 |
| 9 | 0.0255 | 2.44×10^{-5} | 2 | 8 | 18.5 | Obs Well |
| 10 | 0.0552 | 3.68×10^{-17} | 8.7 | 8 . | 33.2 | 100 |
| 11 | - | • | • | 8 | 23.7 | 100 |
| 12 | 0.0418 | 4.19×10^{-5} | 2 | 8 | 23.4 | 100 |
| 13 | 0.0422 | 3.83×10^{-5} | 2 | 8 | 22.7 | 100 |

Notes: $s = A \times Q + B \times Q^{P}$

Where: Q Pumping rate in m3/hr.

s WellDrawdown in m A,B,P Parameters in table above.

Pump Water level includes interfearance effects plus 3 m or regional recession

Table 5.5.4 Anticipated Behaviour for Kadam Store Wellfield

| Well Drilling Number | Q/s (1/s/m) | Static Water Level (m) | Pumping Water Level (m) | Pump Capacity (m³/hr) |
|----------------------------|----------------|------------------------------|-------------------------|-----------------------------|
| 1 | 8.8 | 6 | 21.1 | 100 |
| 2 | 9.9 | 6 | 20.8 | 100 |
| 3 | 8.9 | 9, 2 9 1 2 6 2 4 | 21.1 | 100 |
| 4 | 8.8 | 6 | 21.1 | 100 |
| 5 | 14.6 | 6 | 19.9 | 100 |
| 6 | 5.8 | 6 | 22.8 | 100 |
| 7 | 6.5 | 6 | 22.3 | 100 |
| 8 | 10.5 | 6 | 20.6 | 100 |
| 9 | 8.5 | 6 | 21.3 | 100 |
| 10 | 26.5 | 6 | 19.0 | 100 |

Notes: Pumping water level includes for a total of 9 m interfearance effects plus 3 m regional recesssion Well 5 is operational number 1 and wells 2 and 3 are operational numbers 2 and 3

| Table 5.5.5 C | Capacities of P | roposed Wat | er Sources 🐇 | |
|--|--------------------|------------------|-------------------------|----------------------|
| Source Name | Design Capacity | | e Capacity | Seasonal Capacity |
| | (l/s) | (Vs) | (m³/d) | (MCM) |
| Existing Resources Average Year (1995) Dry Year (1990) | 16,070 9,830 | 8,800 6,870 | 766,020 593,020 | 249.74 186.74 |
| On going schemes | | | | |
| Wadi Marwan Wellfield | 235 | 185 | 16,000 | * 5.84 |
| 2. Barada Group 1 Wellfield | 230 | 185 | 16,000 | 3.92 |
| 3. Barada Group 2 Wellfield | 150 | 120 | 10,400 | 2.55 |
| 4. Barada Group 3 Wellfield | 70 | 60 | 5,200 | 1.27 |
| 5. Takadom Wellfield | 295 | 140 | 12,100 | 2.96 |
| 6. New Kaboon Wellfield Phase I Phase II | 30 120 | 25 95 | 2,200 8,200 | 0.54 2.00 |
| 7. Kadam Store Wellfield | 275 | 170 | 14,700 | 3.60 |
| 8. Dommar Wellfield | 125 | 100 | 8,600 | * 3.14 |
| 8. Figeh Side Spring | + 5001 | 0 | 0 | 0 |
| 9. Ain Haroush | 1500² | 0 | 0 | 0 |
| Master Plan Schemes | | | | |
| 1. Ibn Assaker Wellfield | 75 | 120 | 10,200 | 2.50 |
| 2 Kadam Railway Wellfield | 135 | 115 | 9,300 | 2.28 |
| 3. University Wellfield | no change | -200 | -17,300 | -4.24 |
| 4. Fringe Wells | 100 | 110 | 9,600 | 1.76 |
| 5. Tishreen and Kywan Wfd Phase I Phase II Phase III | 135 130 50 | 110 100 40 | 9,500 8,600 3,500 | 2.33 2.12 0.85 |
| 6. Jaramana Wellfield | 360 | 290 | 25,000 | 6.12 |
| 7. Kafar Souseh Wellfield | 125 | 80 | 6,900 | 1.69 |
| 8. Kanawat Gardens Welifield | 125 | 80 | 6,900 | 1.69 |
| 9. Shokry al Qouwatly Wfd | 210 | 170 | 14,700 | 3,60 |
| 10. Deir al Ashayer | 200 | 200 | 17,280 | ** 3.16 |
| Schemes not in the Master Plan | | | | |
| I. Sergaya and El Irk Wfds | 180 | 140 | 12,000 | 2.94 |
| 2. Rimeh Wellfield | 285 | 285 | 24,500 | ** 4.48 |
| Beit Jenn Spring Average Year Dry Year | 500 483 | 485 335 | 42,000 29,000 | 10.30 7.09 |
| 4. Tabibiyeh Spring Average Year Dry Year | 500 449 | 440 225 | 38,400 19,400 | 9.40 4.75 |
| Barada Wellfield Reinforcement | 1,400 | 950 | 81,600 | 20.00 |

Notes

Season of 245 days assumed unless indicated otherwise

* Season of 365 days operation

** Season of 183 days operation

1 Net increase in capacity for Figeh Side Spring

2 Will replace the existing pumps at Ain Haroush



| | Table 5.5.6 Summary of Water Production | 6 Sum | maar 1 A | v of v | Vate | r Pro | Sec. | dor re | lan | Avor | O O O | Caditions | tions Ewerk | a: Wor | . • : | Option | on 1 | | | | | | | | | | 1. | | | | |
|---|---|----------|-------------|------------|-------------|-----------|----------|-------------------|------------|--------------|-------|------------|-------------------|------------------|----------|--------|----------|---|-------------------|-------------|-----------------|------------|-------|------|-----------|------------|-------------------|-------------------------|------------|----------|---------------------------------------|
| Source | Type 1967 1967 1968 1960 1960 1991 | Celend | X X | 88 | 8 | , s | 8 8 | | 30 | ¥ | 3 | 1095 | 30, | 8 | 1800 | 2000 | 2031 | 2002 | ğ | Š | 8 | 300 | 2007 | 2008 | 2009 2010 | 201 | 1 2012 | 2013 | ΙÖ | 2015 | ر رو <u>ن</u> |
| Ain Pigeh Area. Pigeh Source Overflow | SpringWells | | | | | | .* | | | | | *** - | 27. 21. 31. | 25 25 8 | หล หล | äs | 52 28 | 55 85 | ដូន | ងួន | 32 | ងួន | ង្កដ | 558 | 213 | 22.21 | ं रहे स इ.स. | ្តអូន | ្ដឹង | | · · · · · · · · · · · · · · · · · · · |
| Piggeh Total to Supply | Alega. | 1.20.4 | 1663 | 174.6 | 131 | 1312 1223 | 2 1.10 | 9.9 | S. 48 | 5.5 | 30 | 1.4 | 3. | Si Si | 18 | 3 | 8 | 183 | æ | 3 | 5 | S. | 3 | ş | 6 | × × | 8 | 202 | ä | 200 | lo! |
| Bernda & Al Sabl | 7.53,570 | · · · | , | | . • | • | | • | • | . 1 | | , sc 51 | | | | • | | | 24.6 | 253 | 26.9 | 260 | | • | - | | | | | • | |
| Croup : | Wellfald | i i | | 1 | t | • | į | \$ | t : | 1 | | • | | , < | X GE | 4 | 4. | 4 6 | 3. | * 0 | 0.0 | 4.4 | ₩ Y | 4,4 | 4,4 | 4.4 | 4 4 | 4 4 | 4 4 | 4 6 | 4. |
| Group 2 | Welfers | i F | | E E | i, i |)) |) 1 | ξ I - - | <u> </u> | 1 M | | Tay. | | N 1 20 . 1 | . 1 | - 2 | | | 13 | 18 | 18 | 38 | | | | | | | | | 7 O |
| Sub Total | | 0 | ြ | 0 | | | o | ٥ | 0 | 0 | c · | 6. B 22 | e | l'I | 1 1 | | 11 | ľΪ | 323 | 32.0 | 33.0 | 33.8 | 17 | | 1 | i 1 | | 111 | ľ | 11 | آه! |
| 5 | (Eriefing Stations) | | | | | | | ٠., | | 2 - | | | | | | | , | • | | ŕ | Ç | | | ç | | | | | | | |
| Mazona Ibn Amaker | Weiffeld | 13 | 2.2 | 8 | 3 3 | 7 8 7 | | 0 % 8 % | 0 4 80 | 28 | 9.5 | 2 2 | 15 0 | 15 15 | 95 | 35 | . 3 | 3.0 | 3 | 3 % | 33 | 3 % | 3 % | 3.5 | 3.5 | 30 | 3 (2) 3 (2) | 3 to 1 | | 3.5 | 2 6 |
| Ibn Amakor | Re-equiped Wellfold | . 5 | , 5 | . 6 | 1 2 2 2 3 3 | , S | 1.1 | . 9 | ` | | | | | | | • | X | 9 % | ၀ ရ ၀ စ | 9 | 99 | 8 4 | 87 | 97 | | | | | | | Q w |
| Nacam Railway | Welfold | - | , | : | | | | | 1.98 | 300 | | | - 7 | | | | | 3 | 3. | 3 | 3 | * | \$ | 9 | | | | | | | |
| Kadam Kailway | Ke-equiped Wellfeld | , 8 | 8 | , 8 , 8 | | 1.18 | | 3. | | | | | 1 | | | • | 1. | 2 2 3 3 3 3 3 3 3 | 2 5 2 8 3 8 | 0 4 0 % | ું ⁷ | 95 | 38 | 3.7 | _ | | | | | | Q 1~ |
| Xaboon | Welffold | 8 | 8 | | ٠. | ٠. | 1 | | 0.88 | 0.87 | | المدا | | : | | | | 7 5 | 38 | 17 | ٠, د در | 3 8 | # C | 4. C | | | | | | | * < |
| University Kadam Store | Wellfeld | , , | : | i 1 | t [| i i | F 1 | 6 f : | <i>.</i> 1 | ٠. | | Σ | | | | | | 3 % | 35 | 3 % | 3.5 | 3 % | 3 % | 3 % | | | | | | | |
| Duranar | Welfeld | 88.0 | 0.78 | | | | | - 4F0 | | | | | | × | | | | 35 | S S | 4 | 7 9 | 7 | 7 | 9 | | | | | | | 66 |
| Pringe Wells | S No-equiped | d (| 9 | ê | ริเ | ń | | | ò | 5 1. 9 : | | 1 | } | | | | × | 8 | 3 | 9 | 00 | 9 | 8 | 8 | | | | | | | 0 |
| Emergency Wells | 55 wells | 17.70 | 12.61 | 1526 | Š | 32.7 | ۲, | A.18 23 | 0 27 | 0 85 S | , Y | 00 | 0.0 | 0 2 | 0 40.0 | 40.2 | 36.8 | 0.0 | 203 | 40,4 | 0 0 | 3.8 | 2) B | 3.8 | 3.8 43 | 0 % C | 1 | | 11 | 7 | င့် ဆ |
| | | | 1 | 1 | 1 | ı | 1 | | 1 | | | | | | | | | | | | | | | | | | | | | | , |
| Demastus (New Stations) | Stations) 2 weak Phase I | 1 | : 1 | . 1 | . 1 | . ! | 1 | : 1 | | . [| | ስ | X X | | | 0.0 | 3 | | S | . 0 | 3 | 50 | 3 | | | | | | | | ····· |
| New Kaboon | 8 wells Phose II | 1 1 | 1 (| 1 (| 1 (| 1 1 | 1 1 | 1 1 | 6 1 | . 1 | | , 1 |) (| | | 41 | 7 7 | | 6.1 | ۵ د جا ج | 20 | (1 0 4 | 25 | | | | | | | | 4.0 |
| Tahreen & Nyman | | 1 | 1 | 1 | : H | - 1, | | .1 | | . • | | X. | | | • | 13 | a | | 13 | រា | 13 | ล | 13 | | | | | | | | - 17 |
| Tahroon & Nyaon Tahroon & Xwon | 2 wells Phase II | 1 1 | • | į 1 | 1 6 | 1 1 | E | . ! | 1 | 1 1 | | , , | | 1 1 | X X | 3, | X SE | 38 | 33 | - 0 - 0 | | 9 9 | 38 | 9 9 | 98 | 0.6 0.6 | 0.6 0.6 0.5 | 8 0.0 8 0.0 8 0.0 | 2 % 2 % | | Q Q |
| Zwamana | 6 weils | 1 | 1 | ı | 1 | 1 | 1 | 1 | | | | | , | - | | 5.4.0 | 4 | | 3 | 8,6 | 1.0 | 7. | 77 | | | | | | | | 47 |
| Takadom Sholery of Couwaity | | 1 1 | 1 1 | | t , t | 1 1 | r d | . 1 | 1 1 | | | | | | | X K | 12 | 12 | ici | 15 | 11. | 4 Ki | S O | | | | | | | 3.5 | |
| Yalbuga Control | 10 wells | | 1 1 | 1 1 | ı ı | • • | F JI | 1 1 | | | | : ' | 1 1 | i i | ii | ā | MEE | 0 | , O | 1 3 | , : | 11 | | 9 | | | 1 7 | , i | 1 - | 1. | |
| Sub Toral | | ٥ | 9 | ٥ | | | 0 | .s | 0 | 0 | | | 8 | 500 | 20.0 | 11 | = | 2 | ş | 20 20 | Š | 30.8 | 3.5 | | 2 | 2 0 | χ 0 | ر ا | E | Si Ci | ō |
| Hermon & Zabadani Area | leni Area | : : | | | | • • • | : | | | | : | | 1 : | | | ٠. | | | | | | | | | | | | | | | |
| Lab Day | Syrang Inface | | 1 1 | ŧ I | 1 1 | 1 | (1 | | 1 ! | | | 1 | | L i | 1 3 | | 1 1 | ı | ı ı | I F | ú | 1 (| , , | | | | 1 (| 1 (| 1 1 | | |
| Rmer | S wells | <u>.</u> | . ' | Ė | t | | | | • | r | | , | | 1 5 | | 1 8 | 1 6 | | 1 5 | 1 8 | , ; | 1 5 | | : | | | | | | | |
| Sorgaya Wellfeld | S wells | ł į | i į | ı i | . 1 | 1.1 | 1 1 | , 1 | • • | ' , ' | | ž . | ` | * I | 1 | ŀ | 1 i | | , 5 | 1 | 2 , | | | | | | _ | | | | ว |
| Die Al Ashayer | 4 wells | 1 | 1 | ١ | 1 | | | | اً | ٠ | | | ء ا | | N.SE | 3 | 3 | 1 8 | 3 5 | | 201 | 202 | 21.0 | 202 | 27.0 | 222 | 25 25 | 200 | | 2 0 | ~ - |
| - AV AVIA. | | | | | | | | | | | | | | | | | | ł | | | | | ı | 1 | ľ | 1 | 1 | 1 | 1 | Ϊ | T |
| TOTAL SOURCES (MCM) | ES (MCM) | 146,7 | 146,7 178.9 | 167.1 | 161.5 | 5 134.0 | 0. 173.7 | 3.7 200 | 212 | 2.3 208 | | 218.3 | 11.5 | . 37 E | 88 | 274 | 83.5 | 85.5 | 88 8 | 8 8 | 206 | ğ Ş | ខ្លួន | 8 | 88.5 | 300 | 311 342 | 2 313 | 3. 5 | 5 516 | • |
| Definit (MCM) | ont (much) | | | | | | | | | | " | 1 | П | | 11 | 11 | | | 9 | 00 | 7 | 6, | П | | 1 | 24 | S. | n | 1 | 1 1 | 7.7 |
| | | | | | | | - | | | | | | | | | | | | | | | | | | | | | | | | 1. |

| . ! | 1986-95 Actual | 1996-20 | SE SIC | -ter194 | WH 0001 | dro-me | mecrolo | or made | "Giftons | X SE | Ž, | S) Collin | Electric | | | | | | | | | | | | | | | | | |
|----------------------------|--|-----------------|---------------|--------------|------------|----------|---------------|---------------------|----------------|--------|----------|-------------|----------------|---------|---|-------------|---|-------------|------------|-----------|--------------|-----------|-------------------|-------------------|------|--------------|------------|------------------|---------------|------------|
| Source | Type 1966 1967 1988 1989 1960 | Calenda 1986 | = ¥98 1967 | 1881 1881 | 1080 | 0501 6 | 6 10 | × 1 | 3 | Ş | 2 | 202 | 100 | 88 | 8 | 2000 | ğ | 202 | 2007 | 8 | 8 | 38 | 230 | Š | 2010 | 2011 | 2012 | ğ | 100 | 3 |
| Ain Fireh Area | | | | | | | | | -1. | | | | | | : | | | | | | | | | | | | | ٠ | | |
| Figeh Sources | Spring/Wells Loss to River | | | · | | | | | | | | -4 . | 81 -7 81 -7 | 2 · | 37 | £1 ₹1 | ဒ္ဌ | S 0 | हु °. | ္က င္က | 250 | မ ပ္ကင | 551 551 501 | မှုင ဗင် | 닭 0 | <u>ह्य</u> क | 3; ° | 33°° | မ္မင | 80 |
| Piget Total to Supply | Ajdd: | 120.4 | 1,00 | 171.6 | 0 131.2 | 2 122.2 | <u> </u> | 0.0 | \$ 5 2.5 | 5.5 | 5.0 17 | 1. | 13 | [3] | 171 | Ξ | 132 | 83 | 132 | 132 | 25 | 32 T | 51 | 133 | 32 | 133 | 23 | 132 | 5. | [2] |
| D-14 P 4 G.L | | | | | | | | | | : | | ٠. | | | 31 : 1 | | | | | | | | | | | | • | | | |
| Spring Wolls | | 1 | • | 1 | .! | 1 | 1 | : T . | | . I | | 6.8 26.7 | 5.7 26.7 | | 26.7 | 26.7 | 56.9 | 595 | | 269 2 | 26.0 | 260 26 | 260 260 | 0 200 | | 26.0 | 280 | 35 | 350 | 8 |
| Group 1 | Wellfold | 1 1 | | 1 1 | i 1 | 1 : | 1 1 | | | | | > | - 1 | | KARE S | 4 0 | 0 0 | 0.0 | | | | | | | | | 4 C | 4 6 | | |
| Croup's | Wellfold | ; | | () | 1 1 | , | | | | . 1 | | | . 1 | 0.7 | 1 | KÆE | 10 | 0,0 | 3 | | | | | | 3 | - 1 | 9.0 | 13 | | 13 |
| Sub Tota | | 9 | | | | ٥ | 0 | | ြ | 6 | | 3.0 | 20 | ı | 8 | ŝ | o X | 3 | П | ľì | П | | П | П | 1"} | П | 2 | 8 | 11 | |
| Demande (Printing Stations | ine Stations) | : | | | | : | : | | : . | | | : | | | | | | | | | | | | | 1 | | | | | |
| Marn | Welffeld | 2 | 2.78 | | | | 19 7 | 8 | 8 | 8 25.0 | | | 70 70 | 7.67 | 7.0 | 6.0 | 6.5 | 5.5 | 50 | 66 | 2.6 | 6 | 7.6 | | 26. | | 6 | 6.6 | 6.5 | 33 |
| Dr. Assarker | Vellfold | 3 | 1.71 | 8 | ξ, | 00/ | 8 | · · | i j | | - ; | _ | | ÷ | | 3 2 1 | 3 5 2 5 2 5 | 3∶ | 3 % | ٠. | - | | | • | ٠. | ٠. | 3 % | 3,2 | 3 7 | 3. |
| John | Wellford | ÷ ; | F | | | | <u>থ</u> ম | 91 | 81 | | 6.37 . 5 | 5.80 10 | | = | | 101 | 101 | ő | ត្ត | | | | | | • | | 0 | ខ្មែ | 3 | ۱ <u>۵</u> |
| Machan Railmy | Nollow X | ı | • | i | 3.14 | 高 | 8 | ? ? | 8 | | | | | | | 8,0 | C. | 80 | 0 | _ : | | | | | | _ | 8 | 0.8 | 8 | 3 |
| Kadam Kailway | No Longupod Wellfeld | 000 | 18 | 000 | 0.33 | | 1.18 | . N | 8 | | | ٠ | | ÷ . | | , 7 | , ₁ | | 3 .7 | | | | | , | | | 2.2 | 2.2 | 2.2 | 7.7 |
| Naboon. | Wellfox | 8 | 8 | i | | | 8 | <u>ं</u> इ | 88 | | | | | | _ | 0 | 0 | 0 | 3 | - : | | | | | | _ | 0.1 | 3 | o. | ĭ |
| University | Wellferd | • | į | | 4 | | ļ | • | | | ٠ | | | _ | _ | 00 | 0 | 0.0 | o o | _ | | | | | ÷ | | 00 | 8 | 8 | ŏ |
| Kadam Store | Welfed | . 8 | 1 0 | ٠, | ; c | | ; C | | . (| . : | | X. | | _ > | | \$ C | 9 6 | 0 (| 4 C | | | | | | | _ | 4 4 4 4 | ام و ج ج د | ٠ م در | 4 . |
| Tringo Wolls | 23 wells | 3 | : ' | 8 | | 3 | 3 | 8 | 3 | 7 | 4. 00 | - 4 | | ١. | 1 | 10 | | 2 | 0 | | | | | | | _ | 3 | 9 | 2 | , |
| Pringe Wells | 8 Ro-equiped | 1 | 1 | | | ı | ١, | •; | | • | | , , | 11.5 1.5 | : 6 | , 6 | , 4 | MARE | 8 6 | सः (| : . | | 4 6 | . (| 22.5 | 7 | 달 S | e 6 | સ લ (| 3.2 | 3 |
| Supergentry Wells | 25 weils | 2 5 | 12.0 | * | þ | | 2 2 2 | 2 18 18 18 | {{\bar{2}}{2}} | | 7 7 | 8 | | | | 200 | × | 3 2 | 3 | |] } `@ |] ` | 8 | 3 | 18 | S e | ફ | 18 | 18 | કુંડુ |
| | | | 1 | 1. | Į. | 1 | | | | | | | | | | | | | | | | | | | | | | | | |
| Demander (New Stations) | Stations | | | | - | | . | . ! | | | | Ċ | 200 | _ | 1 | • | t | 0 | ť | | | | | | | | 1 | , | 7 | Č |
| New Androon | TO SECURITY OF THE PARTY OF THE | 173 | ا ا | | . 1 | ;) | | , I | • . ! | • 1 | | . | | | | 2 6 | - 60 - 71 | , c | 3 6 | | | | | | | |) (i | 9 6 | ; eq | 3.7 |
| Xate South | S weigh | 1 | ņ. | . 1 | | | | | | | | 1 | į, | | | រា | 1 | 3 | 23 | | | | | | | | 1 | 1 | 3 | 2 |
| Thirteen & Kwen | | ·, | 1 | 1 | 1 | 1 | , | • | | 1 | | ž | KE | | ٠. ' | 9 | 9 | 2.5 | 3 | | | | | | | | gi e | () | 23 | 3 |
| Tahroon & Kwen | o wells Phase II | j 1 | 1 | 1 1 | • | 1 1 | 1 ! | • • | | • • | • ' | • | 1;* .:. | ļ į | 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 | ri I | 7 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 | 7 7 7 | 0, 7, | O; C; | 7.7 | 3 C | ri ri N H | 8 G 8 G | 2.7 | 5, 7 | O (1 | G (1 | 0, Eq F+ ⊟ | |
| Jaramana | | ; ; | ı | • | 1 | 1 | 1 | ! | | | | 1 | i : | | | 8.4 | 8, | 4, | , 35 25 | | | | | | ٠. | | 3 | 3 | 2 | 35 |
| Takadom | | 1 | ı | ì | 1 | ı | | 1 | 1 | • | • | | X | | · ' | 3.8 | Q. | 0 | ó. | | | | | | | | 4 O | Q. | đ, | 7 |
| Shorey al Couracty | y Swells | 1 1 | () | () | () | 1 1 | 1 1 | | | | | | | 1 | Ē, | N N | 4 | , | 4 I | 13 | - 1 | t | | .,+ | | | 4) G | 4 | 4 ! 3 | 4 1 |
| Sarawa Cardens | Start's | | | 2 | | . 1 | - 1 | | | | | | 1 | | | E A | X, E | 23 | 2.3 | 2,00 | 2.5 | 2 | | 7 | 23 | 2.3 | 7 | 2 | 3 | |
| Sub Tofa | | | | | | 0 | 5 | 3 | 2 | ا. | | 5 | 3 | ે સ્ | OG T | ?* | 300 | 76 | , | ,,, | 14 | 3 | , | | 74 | 77 | ,,,, | 7 | 757 | |
| Harmon & Zabedani Ares | dani Aras | | 3 | | | | | | - | | | | | | : | | | | | | | | | | | | | | | |
| (Ber Jens | Spring Intake | 1, 1 | I I | 1 1 | 1 1 | s, s | | | | | | · 1 | | I (| 1 1 | 1 1 | , | : | 1 1 | | ' .' 1 '1 | | 1 1 | i t | | į i | 1 1 | ii | į į | l I |
| R.meh | S wells | | 1 | 1 | ٦. | 1 | . 1 | ٠. | | | | | 1 | 1 | í | ŧ | í | ŀ | i | , | • | 1 | • | 1 | | • | (| 1 | : | į |
| Wasi Marwan | | ı | ì | 1 | 1 | • | . 1 | | | • | • | ž | n) | 27. | 3 73 | 7.3 | 2, | 7. | ٤, | 7. | 7. | | 7.3. 7 | 3 | _ | | 73 | 2 | | 7, |
| Sergaya Welffeld | 19 mg | } | 1 | 5) | • • | | 1 ,1 | • :' | , , | , , | | ; | ! . I | Ė | TO W | 1 2 | 3 | 8.0 | 5 | : 3 | , | | . 5 | 1 6 | , 3 | • | 1 8 | 3 | | į |
| Sub Total | 1 | 0 | | | 0 | 0 | 0 | 0 | ٥ | ٥ | Ü | ٥ | 7, 0,0 | 3 | د | 13.0 | 13.0 | 13.5 | 13.9 | 13.6 1 | 3.6 | 3,0 13 | 3.5 13. | 5,13 | | ľ | 13.6 | 13.0 | 13.6 | 3 |
| | | - | | : | | | : | | | | | | . i | | | : | | | | | : | | | | | | | | | |
| TOTAL SOURCES (MCM) | WS (MCM) | 146.7 | 146,7 178,9 | 187.1 | 101.5 | 0.41 4 | | 2 7 2 | 209.7 21 | | 2004 22 | 5 | . ន | 722 | 241 | 2.5 | 265 | 276 | 279 | 230 | 270 | | | | | _ | 37. | ą. | 279 | 7 |
| Water Requirement (MCM) | Tent (MCM) | | . | | | | | ı | | 1 | 1 | 248 | 61 5 64 5 | 200 | 2 28 | 22 | <u> </u> | Ę, | , 33 | 1 | 1 | ğ, | 300 | ह्य . ड | Š | 3 | रू इ | 3 | ž | 3 |
| Deleti (MCP.) | | | | | | | | | | | | | 2 | | 1 | | 1 | | | | | | | 1 | 1 | | | 2 | 1 | P) |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| | Table 5.5.8 Summary of Water Producti | 8 Sun | nma: | 17.00 | Wat | or P | rodu | CLIOI | Pla Pla | n, Wot | | Conditions | 100S | e de la constant de l | Ö | Option | | : . | | | | | | | | | | | | | |
|-----------------------------|---------------------------------------|----------------|-------------------------|--------------|---------------------|--------|---------|------------|-------------|-------------|---------|------------|------------------|--|-----------------|-------------|-------------|--------|------|--------|-------------------|------|-----------|-------------------------|---------|----------|--|------|----------|------------|----------------|
| Source | Type 1986 1987 1988 1980 1960 1991 | Calend 1985 | lender Tee 1986 1987 | 1988 | 10 | 1090 | 1960 | 8. | 8 | <u> </u> | 8 | 188 | 189 | .87 | 1908 | 1000 | 2002 | į | 3 | 333 | 2 2 | 30 | 02 × | 2008 | 20 | 2010 | 201 | 2012 | 2013 | 2014 | 2015 |
| Air Place Area | | | | · · | | | | | | | : | | | | | | ; | | | | | | : | | | 1 . | | | | | |
| Figeh Source | Spring/Wells Loss to Reser | | | : | | | | | | Ì | | | 8 4 | 200 | 8 ¥ | 8 3 | 88 H | 8 8 | 22 | 8 8 | 380 | 8 H | 8 H | 360 360 118 114 | 8 4 | 2 360 | 88 | 88 | ន័ន៍ | 88 | 98 |
| Pageh Total to Supply | Alda | 120.4 | 1963 | 171.9 | 9 33.2 | | 222 | 39.6 | 186.5 | 84.7 | 0.47 | 177.4 | 85 | 됝 | ř | 228 | 220 | នី | 123 | ह | 230 | 238 | 239 24 | 202 24 | 16 246 | 8 249 | 22 | 4 | 252 | 290 | 262 |
| | | | | | | | | . : | | | : | : | | :: | | | | | | | | | | | | | | | | | |
| Spring Wells | | · · | 1 | 5 | | | , | i, | | t | | 80 | 13.8 | 15.8 | 13.8 | 1.5.8 | 15.8 | 16.5 | 17.1 | 17.8 1 | _ | - | • | ٠, | ••• | ••• | ••• | • | 23.5 | ž, | Z, |
| Croup 1 | WellSold | 5 | ŧ |) , | t : | | : | . i | • | ; } | ; | \$ | | | | सक्र | 3 | 5.0 | 2.5 | 0.0 | | | | | | | | | 7 | 3 | *. |
| Group? | Wellfold | 174 | , 4 | 1. | 1 1 | | 1 (| 1 1 | .: | : 1 | į 1 | j (| ¥ . | | <u>.</u> | Ť | 1.4 | 9 0 | 9 6 | ° 6 | 9 6 9 6 9 6 | 9.6 | 710 | 5. 5. 5. 5. 5. 5. | 20 21 | - 55 | ;; : : :: : : : : : : : : : : : : : : : | 검표 | 점 = | 었구 | 7 - |
| Sub Total | | ¢ | ٥ | | | ٥ | ٥ | ٥ | o | 0 | ¢ | 9. | 15.8 | 4.74 | 17.2 | 17.2 | 38.6 | 20.R | 22.0 | 33.2 | 171 | 1`1 | ľ | [] | FΊ | ľ | 117 | 111 | 30.0 | <u>ئې</u> | X 11 |
| Demanda (Existing Stations) | ve Statione) | | | | | | | | | | | | | 1 | | | : | - 1 | | | | : | | : | | | | | : | | |
| Marin | Welfeld | 2 | 7.5 | S. S. | | 00.5 | 61.6 | 7.30 | 2 | 4. | 8.35 | 7 | 3.6 | | | 6 | 2.6 | 30 | 3.5 | 0,4 | | | | | | | | | | 7.0 | 7.0 |
| I'm Amaker | Wellfold | 5 | 7 | | | | | 4. | Ş | 8 | 9,4 | 8 | 4 | | - 1 | 4 | Ĵ | • | 3.8 | 3.7 | | | | | | | | | | 5 | , |
| . On Assurem | No-equiped | į į | 1 - | , 4 | | | . 8 | ; | , 5 | | , , | , 1 | 1 5 | | | , 6 | | 18.E | 9 6 | 9 | | | | | | | | | | 0.0 | 0,1 |
| Natham Railbean | Negligit. | و . د د | Ì., | - | | 1 5 | | 9 10 | 3 % | č | į | 3 5 | 3 S | | | e C | 4 C | 3 = | , c | , , | | | | | | | | | | 3 3 | |
| Kadam Railumy | Ro-equiped | į | ŧ | | | | | | ŧ | 1 | f | | } , | | | } | · : | , A | F | 3 | | | | | | | | | | 3 | 0 |
| Oumawayan | Welfeld | 8 | 8 | | ٠ | | | 3. | 8 | ម | ¥. | วั | 0.0 | | | ò | Ö | 7 7 | 3 | 9 | | | | | | | | | | 2,8 | 7 |
| National Threeway | Weiffeld | 8 | 8 | S 0 | | 8. | g H | 3 | 8 | 6 6 8 | 40 | 9 6 | 88 | | | 0 0 | 0 0 | 7 C | 9 6 | 38 | | | | | | | | | | 3 8 | 7 9 |
| Kadam Store | Wellfink | 1 | 1 | | | | | | i | ; 5 i | 8 | 1 | MAR | | | 80 | 0 | 3 | 0.7 | 3 | õ | | 1.8 | | | | | | | 8.1 | 1.8 |
| Outmone | Welfeld | 88.0 | 0.73 | - 1 | | | | 0.17 | | 4 | ı | i | 1 | | X | स | 7. | 7 | 3.0 | 77 | | | | | | | | | | (<u>†</u> | 7 |
| Fringe Welk | 10 Web. | 3 | 8 | 85 | | 8 9 | ง หา | 8 . | 600 | Č. | 9 | ğ, | 9 (| - چ (| | | 0 | 0,9 | 9 6 | 9.0 | | | | | | | | | | 9 0 | 0 6 |
| al a | Sourch aquiper | | ١ | i . | .0 | | | , c | je I | ج ا | ج. ا | Ů | 00 | Š | 0.0 | , 2 | 0 | 9 | 33 | 3 8 | | 30 | | 38 | 36 | 38 38 | 38 | 58 | 38 | 3 | 0 |
| Н | | 17.30 | 12.01 | 33 | 26 30.32 | H | 32.71 | æ ₹ | 23.17 | 33.85 | 30.41 | \$ | 2.5 | Š | ll | 182 | 18.2 | 19,7 | 21.1 | 22.5 | 3.2 | 3, | 5. | [1 | [] | 17 | ٠, | n | [" | 41.2 | 7 |
| Damages (New Stations) | (artione) | | | | | | | | | | | | | | -: | | .: : | | ٠. | | | | | | | | | | 1 | | - - |
| New Xaboon | 2 wells Plane 1 | · . | ٠, | 1 | • | | | ٠. • | į | į | i | 1 | ក្ត | N.O.E | | 90 | 0 | 00 | 9 | 8 | | | | | | | | | | 8 | 0 |
| New Kalboon | S wells Pluse | 1 1 | j : 1 | 1 1 | 1 1 | • • | | 1 4 | 1, 4 | ! 1 | i j | 1 | 1 | f d | | 23 2 | 8 | 96 | 36 | 88 | | | | | | | | | | 7: | ។: |
| acm. | Street Phase I | | 1 |) } | | | | I I | , | ŧ ŧ | i i | i i | N.S. | X | | 0.0 | 3 8 | 3 6 | | 33 | | | | | | | | | | | , 5 5 |
| | Il osella Phose II | | ŀ | 1 | * * * | 7 1 | , | | | ŧ. | į. | 1 | F ₂ 1 | • | 3 | N.SE | 00 | 7.6 | 0 0 | 3 8 | 36 | 36 | 0.8.0 | 80 | 8.0 8.0 | 80.4 | 33 | 77 | 1 (| 7 | 10 |
| | o smile | ı : | i ‡ | | 1 1 | . 1 | | | | 1 1 | 1 1 | i 1 | 1 1 | . 1 | | i d | , 6 | | 3 8 | 3 9 | | | | | | | | | | 3 3 | 7 0 |
| Takadom | 7 wells | .) | ı | ì | 3 | | | į | ı | ì | 1 | i | 1 | MARE | | 0 | 8 | 8 | 9 | 8 | | | | | | | | | | 7 | : : |
| Stokey at Commany | 5 440(kg | 1 | r) | 1 | 1 | ١. | | ı | 1 - | 1 | 1 | í | i | Ţ | - Д : | 주. 공 | (SEE | 0, | 00 | g | | | | | | | | | | ä | ** |
| Nanawa Cardans | A wells | i i | | 1 | ۱ : | ' . ' | 1 (| 13 (| } | 1 | 1 | 1 | i i | 1 1 | I (| Н | A 記 大 | 필 | 0 | 3 | | | • | ٠. | | | | င် | ိ | l o | 80 |
| Sub Total | | | | | | | | | | | | | ြိ | ိ | 8 | ိ | ŝ | | 9 | 9 | H | 1 | П | 1 | 11 | 11 | 1 | ខ្លី | 12.8 | 9 | 3 |
| (Hormon & Zabadani Arm | ani Arm | | | ٠. | | | | | | | | | | ŀ | | | | ÷ | | | | | | | | | | | | | |
| Beit Jan | Sprang Intake | 1 | 1 | 1 | • | | | 1 | į | , | • | • 1 | | 1 | • | 1 | 1 | ı | 1 | 1 | 1 | | | | | | | | ı | i | ı |
| Tableyer | Spring Intake | 1 :1 | 1 | (;) | 1. | | 1 | 1 | : • ! | 1 | į. | i | | 1 | | 1 | ŧ | 1 | | 1 | • | • | | | • | ŧ | ı | 1 | t | i | 1 |
| Wadi Marwan | 13 welk | , ¦ | ı 'ı | įŧ | 1 1 | | | I t | : 1 : 1 | I I | ı i | 1 1 | X X | | . 3 | | 7.5 | 7.5 | | | ٠. | | | | | | | | . 5 | . 52 | , 17 |
| Sergnya Welffield | 9 weils | 1 | 1 | (| 1 | | • | ď | 1 | 1 | í | ı | 1 | Ċ, | ŧ | į | 1 | 1 | | 1 | 1 | | | | | | . ' | | 1 | ı | 1 |
| Die A. Ashmer | 4 we)[s | | • | 1 | 1 | | | | , | | | <u>י</u> ן | • | , | • | 뜅 | 0 | 4 | 2 | | - 1 | -1 | - | -1 | -1 | _1 | 1 | -1 | 7 | | 7 |
| Sub Total | | ٥ | 9 | | | | | o l | ا [٥ | c | | ٥ | S | | 2 | | | 2 | | | 1 | Ή | 1 | - | 1 | ٦ | 1 | 1 | 즼 | | Š |
| | | | | | | | | | | | : | 5 | | | | ÷ | | | | | | | | | | | | | | | - |
| Water Requirement (MCM) | IN CHOCK) | 146.7 | 178.9 | | 1671 1615 1540 1783 | າ | ٠ • | 6 | 5 5 7 | 212. | 8 | 3 % | នួន | អ្នក | ¥ 8 | 8 8 | 3 5 | 3.8 | 8 8 | 8 % | 7 7 8 8 | 28.2 | 3 S | 38 | 15 SE | 2 2 | 33 | 88 | 33 | 2.2 | ă š |
| Deficit OXOX | | | : | | | | | | | | • | 202 | | [| 0 | 0 | 0 | 0 | S | - [| ١ | 4 | 1 | J | - 1 | _1 | - | - 1 | 0 | ន | 1.5 |
| | | | | | | | | | | | | | | | | 1 | | | | | | | | ٠ | | | | | | | |

Table 5.5.9 Pumping Details for Deir al Ashayer Wellfield

| Well | Static Water Level (mbgl)* | Drawdown (m)** | Dynamic Water Level (mbgl)*** | Pump Capacity (1/s) | Installation Depth (m) | |
|------|-------------------------------|----------------|----------------------------------|---------------------|---------------------------|--|
| 844 | 16 | 24.2 | 46.2 | 50 | | |
| 846 | 15 | 23.0 | 44.0 | 50 | 65 | |
| 854 | 19 | 24.2 | 49.2 | 50 | 65 | |
| new | 20 | 23.0 | 49.0 | 50 | 65 | |

Notes:

Typical level anticipated for beginning of pumping period, using May 1995 as the reference year, Using determined by comparison with well 809.

After 6 months pumping

Lowest expected level based on drawdowns plus 6 m of regional recession from an inial static water level in May

Table 5.5.10 Well Performance Equations for Jaramana Welifield

| Well | Λ | В | P | Comments | |
|------|--------|---------------------------|-----|---------------------|-------|
| 1 | 0.0092 | $2.5.82 \times 10^{-6}$ | 2 | <u>-</u> | |
| 2 | 0.0096 | 5 2.09 x 10 ⁻⁶ | 2 | | |
| 3 | 0.0097 | 7 8.48 x 10 ⁻⁶ | 2 | | : |
| 4 | 0.0238 | $3 2.36 \times 10^{-15}$ | 7.6 | Breakaway drawdown | 4. 1 |
| 510 | 0.0096 | $5.2.09 \times 10^{-6}$ | 2 | Identical Test Data | |

Notes:

 $s = A \times Q + B \times Q^{P}$

Where:

Pumping rate in m3/hr.

Drawdown in m

Parameters in table above.

| Well | A | В | P | Q/s (l/s/m) | Comments |
|-------------|----------------|-------------------------|-----|----------------|-----------------------|
| Tishreen 1 | 0.497 | 4.80 x 10 ⁻³ | 2 | • | i- 4 |
| Tishreen 2 | 0.581 | 1.46 x 10 ⁻³ | 2 | | |
| Tishreen 3 | 0.0198 | 2.14×10^{-10} | 5.2 | | Very high well losses |
| Tishreen 4 | 0.0268 | 1.08×10^{-15} | 8.0 | | Very high well losses |
| Tishreen 5 | 0.158 | 8.22×10^{-8} | 4.2 | | - |
| Tishreen 6 | - | • | - | - | Very low yield |
| Tishreen 7 | _ | | | <u>-</u> | Very low yield |
| Tishreen 8 | 0.072 | 1.17×10^{-3} | 2 | . - | |
| Tishreen 9 | 0.126 | 1.34×10^{-7} | 3.9 | | _ |
| Tishreen 10 | 0.429 | 1.78 x 10 ⁻² | 2 | | i - |
| Kywan 1 | - · · , | | - | 0.12 | Very large drawdown |
| Kywan 2 | - | | | 11.57 | |
| Kywan 3 | | | | 12.63 | |
| Kywan 4 | • | <u>-</u> | · · | 0.52 | Very large drawdown |
| Kywan 5 | - · . | | . i | 0.32 | Very large drawdown |

Notes:

 $s = A \times Q + B \times Q^{P}$

Where:

Pumping rate in m3/hr. Q

Drawdown in m

A,B,P Parameters in table above.