

## Chapter 10 Technical Study for Dev Blok

## Chapter 10 Technical Study for Dev Blok

This chapter contains various kinds of information confidentially disclosed to EIE and JICA only and is not eligible to disclosure to the general public.

**CONFIDENTIAL**

## Chapter 11 Technical Study of Textile Factory

## Chapter 11 Technical Study of Textile Factory

### 11-1 Characteristics of the Textile Industry

This chapter concerns the energy audit of Izmir Basma Fabrikasi A.S. (IBF). The JICA study team intended to conduct a major audit of IBF and a minor one of its sister spinning and weaving company, Izmir Pamuk Mensucati T.A.S. (IPM), as has been agreed among EIE, the factory management and the study team. At the kick-off meeting for the energy audit with EIE, IBF and the study team, the IBF management said that they wished to concentrate on IBF and to cancel the audit of IPM, because IPM completed construction of a new spinning mill on a new site in a suburb of Izmir, and is now in the process of moving some machines from the present site; the conditions of the factory did not permit auditing. Accordingly, the audit of IPM was canceled.

IPM is a spinning and weaving mill, starting from cotton raw material and producing gray cloth, all of which goes to IBF. IBF is a printing, dyeing, and finishing factory, processing the gray cloth from IPM and other sources for commission printing. The amount of the commission printing accounts for two-thirds of the IPM products. The main products are fabrics for dress, nightwear, sheeting for bedsets, and curtains. Both companies are owned by the Giraud family; IPM was founded in 1912 and IBF in 1957. The factories emphasize good quality of their products as company's motto. Both factories are old and plan to move outside of Izmir in two to five years. From the energy audit point of view, spinning and weaving mills and dyeing, printing, and finishing factories are fairly different. In the absence of adequate data for the Turkish industry, Table 11-1 shows estimated unit energy consumption of major processes of a typical Japanese textile plant.

It may be noted from comparison between the spinning and weaving mills on one hand, and the dyeing, printing and finishing factories on the other, that:

1. The former is an industry of mass production and continuous operations are the rule. The latter produces many kinds of goods in small quantities in a number of steps, the combination of which varies depending upon the required quality of the products. Operations of processes are intermittent and batchwise.
2. The former consumes more electricity while the latter consumes more fuel. The total energy consumption is larger in the latter.

From these differences, the need for rationalizing energy use is more urgent in the latter than in

the former.

**Table 11-1 Estimated Unit Energy Consumption in the Japanese Textile Industry  
(Cotton, 1990)**

Process	Case	Unit: 10 <sup>6</sup> kcal/ton-product		
		Electricity	Fuel	Total
Spinning	20 Ne	2.1	0.4	2.5
	40 Ne	3.8	0.7	4.5
Weaving	Mean of Light and Heavy Weight	0.9	1.0	1.9
Dyeing-- Finishing	Shirt (Fabric Weight 130 g/m <sup>2</sup> )	1.3	11.7	13.0
	Casual Pants (250 g/m <sup>2</sup> )	0.8	9.9	10.7
Printing-- Finishing	Lady's Dress Fabric (130 g/m <sup>2</sup> )	2.3	15.3	17.6
	Home Textiles (200 g/m <sup>2</sup> )	1.6	16.1	17.7

## 11-2 Outlines of Factory, Facilities and Flowsheet of Major Products

### 11-2-1 Factory

#### (1) General

Outline of IBF is as follows:

- |                         |  |
|-------------------------|--|
| 1. Name of the factory: | Izmir Basma Fabrikasi A.S.                               |
| 2. Address:             | 1201 Sokak No. 3/E Halkapinar-Izmir<br>Tel (232) 4339810 |
| 3. President:           | Mr. Frederick Giraud                                     |
| 4. Factory manager:     | Mr. Enver Oktay  |
| 5. Energy manager:      | Mr. Muzaffer Tomruk                                      |
| 6. Type of industry:    | Textile Fabric   |
| 7. Capital, billion TL: | 119.5  |

*The information given here is withheld from public disclosure because of its confidential nature.*

**(2) Outline of Major Products**

**Table 11-2 Production Amounts of IBF**

---

---

---

*The information given here is withheld from public disclosure because of its confidential nature.*

## 11-2-2 Production Facilities and Flowsheet

Figure 11-3 shows the production flow diagram of IBF, and Table 11-3 shows their energy consumption.

### (1) Singeing

The factory uses LPG. The cloth speed is 80 meters per minute; or the contact time is 1/20 second.

### (2) Bleaching

The factory has two types of bleaching machines, rope bleaching and open width bleaching. They use hydrogen peroxide, sodium hypochlorite and sodium hydroxide as bleaching agents. This process is one of the most steam consuming processes. The washing temperature is from 30 to 95°C and the bleaching temperature is from 30 to 100°C.

### (3) Mercerizing

Cloth is treated in a caustic soda solution at room temperature for 30 to 50 seconds.

### (4) Printing

Five rotary screen type printing machines are installed. These are the main facilities in the factory. The factory considers themselves skilled in printing roller preparation and pattern design. The factory simultaneously prints a maximum of 15 colors. Width of the machines is from 185 to 240 centimeters. Colton fabrics are used mainly for printing.

### (5) Dip dyeing

The factory has five jiggers. They are used for plain dyeing, bleaching, washing and other purposes. The plain dyeing temperature is from 60 to 90°C.

### (6) Fixing

The fixing temperature is different according to the recipe.

### (7) Finishing

The number of finishing machines is four. Their finishes are water repellent, soil repellent, flame retarding, crease free, soft feeling, etc. The temperature applied is from 100 to 180°C.




Figure 11-1 Organization Chart of IBF






Figure 11-2 Process Layout of IBF




Figure 11-3 IBF Production Flow Diagram

Table 11-3 Major Utility Consuming Facilities

No.	Name of Facility	Steam (kg/h)	Utility Consumption		Hot Oil (kcal/h)	Connected Transformer
			Electricity (kW)	Normal Start-up		
1	Rope Bleaching Range	1,250	108			No.1
2	Open Width Bleaching Range	1,750	157			No.4
3	Mergerization	600	34			No.2 & No.3
4	Small Bleaching Machines (Jigger)	600	10			No.2 & No.3
5	Washing Range (Kleine Wefers)	1,500	85			No.1
6	Washing Range (Max Goller)	1,600	170			No.2 & No.3
7	Cotton Flannel Machines (Raizing)	150	25			No.2 & No.3
8	Drying Machines (Flash Ager)	300	25			No.1
9	Drying Machines	900	25			No.1
10	Boiler House	900	90			No.2 & No.3
11	Water Treatment Unit		212			No.2 & No.3
12	Calendering Machine (Carsat)		22			No.2 & No.3
13	Calendering Machine (5 Cylinder)		52	125,000		No.2 & No.3
14	Calendering Machine (Nipco)		51	90,000		No.4
15	Printing Machines (Stork 1)		170	1,100,000	1,600,000	No.1
16	Printing Machines (Stork 2)		128	1,100,000	1,600,000	No.1
17	Printing Machines (Stork 3)		190	1,100,000	1,600,000	No.4
18	Printing Machines (Stork 4)		204	1,100,000	1,600,000	No.4
19	Printing Machines (Zimmer)		238	1,100,000	1,600,000	No.1
20	Finishing Machines (No.3)		140	1,300,000	1,600,000	No.1
21	Finishing Machines (No.4)		140	1,300,000	1,600,000	No.1
22	Finishing Machines (No.5)		257	1,400,000	2,000,000	No.4
23	Finishing Machines (No.6)		257	1,400,000	2,000,000	No.4
24	Compressor		75			No.4

### 11-2-3 Energy Supply Facilities

#### (1) Steam Boiler

IBF has four boilers horizontally-fired type, burning 35 tons a day of lignite from Soma. The specifications of the steam boilers are shown in Table 11-4. The steam is supplied to the processes of bleaching, mercerization, washing, drying, etc. Their nominal consumption is shown in Table 11-3.

**Table 11-4 Specifications of Steam Boilers in IBF**

No.	Built Year	Evaporation Capacity (ton/h)	Pressure		Temperature Normal (°C)	Heating Area (m <sup>2</sup> )	Economizer Area (m <sup>2</sup> )	Stoker Area (m <sup>2</sup> )	Maker
			Maximum (bar)	Normal (bar)					
1	1954	5.0	10	8	169	Lignite 160	85	5.3	Walther Cie and Josef Martin
2	1954	5.0	10	8	169	Lignite 160	85	5.3	
3	1954	5.0	10	8	169	Lignite 160	85	5.3	
4	1976	6.0	10	8	169	Lignite 285	-	6.0	Sungurfar

The features of the boilers may be summarized as follows:

1. Horizontal smoked tube type
2. Economizer installed (Flue gas - Feed water heat exchange type in the convection section)
3. Coal-firing type
4. Small capacity at 5 tons/h
5. IDF and FDF installed
6. Screw feeder for coal
7. Air preheat (Ash - Supply air heat exchange)

#### (2) Hot Oil Heater

IBF has nine hot oil heaters for heating of the printing, finishing and calendering machines, because IBF's steam boilers cannot easily generate the high temperature necessary for the processes. The factory burns fuel oil and diesel oil. Normally the temperature of outgoing and returning oil at the heaters is 240°C and 220°C, respectively. The machines using heat and specifications of the hot oil heaters are shown in Tables 11-3 and 11-5, respectively. The factory constructed a new heater of a large capacity to replace the present Nos. 1 to 3 heaters, which are connected to the printing machines.

**Table 11-5 Specifications of Hot Oil Heaters in IBF and Heat User Machines**

No.	Built Year	Heating Capacity (kcal/h)	User Machine (estimated from H.O. Heater List)	Pressure		Temperature	Fuel	Maker
				Maximum (bar)	Normal (bar)	Normal (°C)		
1	1986	1,720,000	Printing Machine (Stork 3)	10	6	240	Fuel Oil	Wiesloch
2	1989	2,000,000	Printing Machine (Stork 4)	10	6	240	Fuel Oil	Termostandard
3	1983	2,500,000	Printing Machine (Stork 1&2)	10	6	240	Fuel Oil	HTI
4	1973	1,600,000	Finishing Machine (No.3)	10	6	260	Fuel Oil	Wiesloch
5	1973	1,600,000	Finishing Machine (No.4)	10	6	240	Fuel Oil	Wiesloch
6	1987	2,300,000	Finishing Machine (No.5)	10	6	240	Fuel Oil	Termostandard
7	1987	2,300,000	Finishing Machine (No.6)	10	6	240	Fuel Oil	Thermtechnik
8	1988	125,000	Calender Machine (5 cylinder)	10	6	240	Diesel Oil	AURA
9	1990	90,000	Calendering Machine (Nipco)	10	6	240	Diesel Oil	AURA
New	1996	7,500,000	Printing & Fixation Machines	10	6	240	Fuel Oil	Termostandard

The features of the hot oil heater systems are as follows:

1. The furnaces are all of radiation type; Nos. 5 and 6 heaters and the new heater have horizontal furnaces and Nos. 3 and 4 heaters have vertical furnaces.
2. There are two mini heaters for each calendering machine and two old heaters as standby for the new heater.
3. Each heater supplies heat by circulating hot oil to given grouped machines.
4. The heat in each hot oil system is consumed by machines freely according to their operation. These machines operate batchwise as dictated by the production plan. Naturally, the operation of the hot oil system fluctuates as demand for heat fluctuates.
5. Liquid fuel is used. No. 6 Fuel Oil is used for the new hot oil heater, the special fuel oil for Nos. 1 to 7 heaters and Diesel Gas Oil for the mini hot oil heaters.
6. Control system of the hot oil system is as follows:
  - (1) Hot oil is fed to the heaters without flow control; flows are determined by the capacities of the pumps.
  - (2) Each machine receives hot oil with a temperature-indicating controller, TIC, equipped with a three-way valve. The temperature of the hot oil returning to the heaters fluctuates widely depending upon the load of the users.
  - (3) Fuel oil is fed to the heaters, in such a way that the outlet temperature of the hot oil remains constant, by manual operation.
  - (4) The amount of combustion air to the new heater is controlled by the opening of the

dampers which is also manually controlled. The flue gas temperature is watched but the oxygen content of the flue gas is not. Other heaters do not have dampers.

7. A waste heat recovery system is installed in the new hot oil heater. Heat is recovered by heating the combustion air from the flue gas.
8. An automatic emergency shutdown system is installed.

### **(3) Electricity**

Electric power is received from the City Electricity Network. IBF receives 3-phase 10.5 kV electricity. The price of electricity is divided into three classes according to duration of consumption. Three power meters count the sum of consumption in each class. IBF also has a special meter to measure excess and reactive power to be charged with a penalty rate. The four transformers reduce the received voltage to 400 Volts. The capacities of Nos. 1 to 4 transformers are 1,000 kVA, 500 kVA, 500 kVA and 1,600 kVA, respectively. Nos. 2 and 3 transformers are connected in parallel in the transformer facility, and electricity is distributed via three feed lines in the factory. Each feed branch has a condenser to improve power factor. The outline of the IBF electricity system is shown in Table 11-6 and Figure 11-4.

### **(4) Major Utility Consuming Facilities in IBF**

Table 11-3 shows the major production facilities, their nominal utility consumption and the connected electric transformers.

Table 11-6 IBF Electric System

Electric Receiving Facilities					
Receiving Voltage, Volt	10,500				
Maximum Demand, kW	2,100				
Power Factor	0.95				
Number of Transformer	4 Stations ( Each receives city electricity directly.)				
Transformer	No.1	No.2	No.3	No.4	Total
Capacity, kVA	1,000	500	500	1,600	3,600
Load, %	63	48		68	
kVA	630	480		1,088	2,198

Sections Connected to Transformer Stations

Sections are parallel connected to No.2 & No.5 transformer stations.

Transformer	No.1	No.2	No.3	No.4	Total
Dyeing Machines (Jigger)			5		5
Washing (Kleine, Max Goller, Flash Ager)	1	1			2
Rope Bleaching	1				1
Open Width Bleaching				1	1
Steamer (Drying)	1				1
Mercerization		1			1
Cotton Flannel Machines (Raizing)		5			5
Dye Preparation		1			1
Printing Pattern Material Preparation	1	1			2
Printing Machines ( Stork )	2			2	4
( Zimmer )	1				1
Calendering Machines		2		1	3
Finishing Machines	2			2	4
Water Treatment Filter (Ion Exchange)		1			1
Waste Water Treatment				1	1
Steam Boilers	1	3			4
Hot Oil Heaters for Printing Machines ( Old )	2			1	3
Hot Oil Heaters for Calendering Machines		1		1	2
Hot Oil Heaters for Finishing Machines				4	4
Centralized New Hot Oil Heater (in 1996)				1	1
Compressor Room				1	1
Office Building			X		X
Plant Lighting			X		X

Hot Oil Heater User Detail	No.1	No.2	No.3	No.4
for Printing Machine ( Stork 1 & 2 )	X			
for Printing Machine ( Stork 3 )	X			
for Printing Machine ( Stork 4 & Zimmer )				X
for Printing Machines ( Centralized HO Heater )				X
for Finishing Machine ( No.3 )				X
for Finishing Machine ( No.4 )				X
for Finishing Machine ( No.5 )				X
for Finishing Machine ( No.6 )				X
for Calendering Machine ( Nipco )				X
for Calendering Machine ( 5 Cylinder )		X		




Figure 11-4 Single Connection Diagram of IBF Electric System



### **11-3 Outline of Operating Conditions**

The operating condition of major production facilities and of energy supply facilities are described in Sections 11-2-2 and 11-2-3, together with their specifications. The operation mode is continuous, working 20 to 24 hours a day and 330 days a year. The factory has an annual maintenance schedule, and normally shuts down for maintenance for two weeks in August.

### **11-4 Trends of Consumption and Unit Consumption of Energy**

#### **11-4-1 Energy Consumption**

Table 11-7 shows the energy consumption trend.

##### **(1) Lignite**

Lignite is the fuel for the steam boilers. It comes from Soma and normally has a heating value of 3,500 to 4,500 kcal/kg and 34 percent ash.

##### **(2) Fuel Oil and Diesel Oil**

The factory uses hot oil as a heating medium for printing, finishing and calendering machines. Fuel oil and Diesel oil are burned in hot oil heaters.

##### **(3) LPG**

LPG is burned in the singeing process.

##### **(4) Electricity**

Electricity is the power source for all motors and lighting.

**Table 11-7 Trends of Energy Consumption in IBF**

Name of Utility	1992	1993	1994	1995	1996 (Aug.)
Lignite, tons	7,299	15,918	16,306	13,428	8,063
Price, TL/t				1,238,000	2,501,000
Fuel Oil for Oil Heaters, tons	3,598	3,430	3,267	3,486	2,607
Price, TL/kg	1,528	2,243	5,520	10,633	14,702
Diesel Oil for Oil Heaters, tons			70	86	77
Price, TL/kg			11,900	19,950	39,830
LPG for Singeing, tons	59	95	100	105	71
Price, TL/kg				15,800	28,700
Electricity, MWh	11,752	12,219	12,433	11,403	7,553
Price, TL/kWh				3,254	

#### 11-4-2 Unit Consumption of Energy

The unit consumption of energy is calculated as follows.

##### (1) Annual Production

IBF's record shows production of fabric in meters. The width and weight of fabrics varies from one lot to another, the following numbers are assumed.

Fabric weight, gram/m <sup>2</sup> :	140
Width of fabric, cm:	160

##### (2) Annual Consumption of Energy

IBF consumes various kinds of energy as shown in Table 11-7. To facilitate comparison with other factories and with the data of Japanese counterparts, amounts of energy are converted into kilocalorie. The following conversion factors are used.

Lignite for steam boiler, kcal/kg	4,385
Fuel oil for hot oil heater, kcal/kg	10,000
Diesel oil for hot oil heater, kcal/kg	9,500
LPG for singeing, kcal/kg	11,000
Electricity, kcal/kWh	860

**Table 11-8 Trends of Unit Consumption of Energy in IBF**

	1992	1993	1994	1995	1996 (Aug.)
Production, 10 <sup>3</sup> m	33,047	32,013	26,979	27,215	16,885
tons	7,402	7,171	6,043	6,096	3,782
<b>Energy Consumption</b>					
Lignite, tons	7,299	15,918	16,306	13,428	8,063
10 <sup>6</sup> kcal	32,006	69,800	71,502	58,882	35,356
Fuel Oil, tons	3,598	3,430	3,267	3,486	2,607
10 <sup>6</sup> kcal	35,980	34,300	32,670	34,860	26,070
Diesel Oil, tons			70	86	77
10 <sup>6</sup> kcal			665	817	732
LPG, tons	59	95	100	105	71
10 <sup>6</sup> kcal	649	1,045	1,100	1,155	781
Electricity, 10 <sup>3</sup> kWh	11,752	12,219	12,433	11,403	7,553
10 <sup>6</sup> kcal	10,107	10,508	10,692	9,807	6,496
<b>Total</b>					
10 <sup>6</sup> kcal	78,742	115,653	116,629	105,521	69,435
<b>Unit Consumption of Energy</b>					
10 <sup>6</sup> kcal/ton-Fabric	10.64	16.13	19.30	17.31	18.36

The unit consumption of energy in the years from 1994 to 1996 remained almost constant. The consumption increased from 1992 to 1993.

#### **11-5 Current Condition and Problems with Energy Management and Conservation**

The current practice of energy management may be expressed as follows against the generally accepted recommended practices.

1. Target for energy conservation: The factory does not have a target.
2. Systematic activities for energy management in the organization: Every Wednesday, an outside consultant comes. The factory has no such organization as an energy saving committee with participation by production managers.
3. Energy management utilization of data and records: The factory records the consumption of electricity and coal every month, but the records are used only for accounting.

4. Education, training of employees for energy management: Education on energy conservation has not been given to the workers.
5. Schedule of annual maintenance: The factory shuts down once a year and has an annual maintenance schedule.
6. Measures carried out for energy conservation and their effects: Energy conservation is achieved mostly by replacement of old machines by newer ones.

Planning for energy conservation and expected effects: The factory is moving to a new site in 2 to 5 years. New investment in the present factory has been suspended. Natural gas is intended for the main fuel for the new factory, because the factory considers LNG more economical. The factory also considers reducing hot oil use and introducing a co-generation system.

7. Problems in promotion of energy conservation: Yes
8. Environmental pollution management:
  - (1) Waste gas: Flue gas is used for water treatment. The flue gas from the stack is an environmental problem.
  - (2) Waste water: Waste water is neutralized by the flue gas.
  - (3) Waste disposal: Apparently no problem. There is a disposal site owned by the municipality. The factory is charged for the disposal by the city.

## **11-6 Current Condition and Problems with Facilities**

### **11-6-1 Common Items**

The following items commonly apply to major energy consuming and supply facilities.

#### **(1) Lack of Measuring Meters of Energy Supply and Consumption**

Flow meters of heating media such as steam and hot oil are not installed. Although a few water consumption, temperature, pressure meters are installed, meters are insufficient for energy management.

#### **(2) Insufficient Thermal Insulation**

Steam lines, hot oil lines and related equipment such as steam boilers, hot oil heaters and production machines are fully insulated; however, some parts of thermal insulation do not use good materials and/or do not have enough thickness. This causes undue heat loss.

### **(3) Excessive Electricity Consumption**

Some motors are operated at higher rotations than required. The transformer capacity in the electric supply system is too large compared with the electric load of the group users. They are causing electricity loss.

## **11-6-2 Items for Production Facilities**

### **(1) Intermittent Operation**

Some facilities operate intermittently. This causes unnecessary energy loss. A production schedule should consider rational use of energy as a high priority target.

### **(2) Heat Loss from the Bleaching Range**

Gray cloth is bleached and washed in the bleaching machines by water and steam to make white cloth, and they release heat to the atmosphere and drain hot water to the canal.

### **(3) Heat Loss in the Washing Range**

White cloth is treated by printing, steaming, washing and finishing in the system to produce printed fabric. Some heat is lost to the atmosphere and to hot waste water, especially at the washing machine.

## **11-6-3 Items for Energy Supply Facilities**

### **(1) Low Efficiency Operation of the Boiler and Hot Oil Heater**

The existing steam boilers and hot oil heaters are small in capacity and operate independently of each other. Therefore, they are operated at low load levels compared with the design capacities. The operation of the entire energy supply system, including circulation of heating media, should be streamlined.

### **(2) Lower Steam Condensate Recovery**

Only a small portion of the steam condensate is recovered. At present, the recovery rate is 30 percent. Recovery of steam condensate should have a high priority.

### **(3) Steam Loss from the Steam Lines**

There is some steam loss through steam traps. Some leakage of steam to the atmosphere was observed.

#### **(4) Steam Boiler**

##### **1) Measuring Equipment and Control**

Few measuring instruments are installed on the boilers. The control is manually done by hand. The boilers originally had steam flow meters and flue gas composition indicators. They are not operational as a result of lack of maintenance and lack of chemicals required for measurements.

Operation procedure is as follows:

1. Steam pressure: Maintained at 7 Kg/cm<sup>2</sup>.
2. Coal feed rate: The rotation of the coal feeder is controlled by hand.
3. Water level in boiler:
  - (1) Nos. 1 and 3 Boilers: Manual control with the help of an alarm device
  - (2) No. 2 Boiler: Controlled by a level controller
4. Air supply:
  - (1) FDF: The dampers are fully open.
  - (2) IDF: The opening of the dampers and rotation of the motor are controlled according to the combustion conditions inside the furnace and smoke in flue gas from the stack.. Sometimes, the content of O<sub>2</sub> in the flue gas is analyzed, but no action is taken to correct the observed results.

##### **2) Operation**

The data are recorded every hour. The recorded data do not vary with time. This could mean either that boiler operation is very stable or that measuring equipment does not work properly. Demand for steam fluctuates depending upon the consumption of the steam users. It follows then that the measuring equipment does not work properly. The factory records the following items:

1. Steam flow: There is no meter and therefore this is not recorded.
2. Water temperature at the inlet and outlet of the economizers
3. Exhaust gas temperature at the inlet and the outlet of the economizers
4. Pressure at the FDF outlets and the IDF inlets
5. Suction pressure: mm H<sub>2</sub>O at some positions of the stokers
6. Damper position on ducts for controlling the air flow at each stoker
7. Position of gear change devices of the coal screw conveyers
8. Coal type and consumption quantity: One bucket carries approximately 420 kg.
9. Smoke pipe cleaning operation by steam

## **11-7 Method and Procedure of Energy Audit**

Generally, an energy audit is carried out by the following procedure. For more details reference should be made to Section 11-14-2.

1. The information related to energy use of the factory including both management and facilities is collected.
2. The flowsheets and specifications of facilities are investigated from the technical point of view.
3. Operation variables are measured on energy related points.
4. Operating conditions and data are observed.
5. The results of measurements and observations are analyzed.
6. Heat balance calculation is done.
  - (1) Heat inputs
  - (2) Heat outputs
  - (3) Heat losses
7. The resultant heat balance is analyzed and conclusions are drawn.

An energy audit has to examine the energy supplying side and the energy consuming side. In the case of IBF, the following items were selected as important and were audited. EIE, IBF, and the study team agreed on the selection of items to be measured and measurements were done accordingly.

### **(1) Energy Supplier Side**

#### **1) Steam Boiler**

Three of the four boilers under operation were audited.

#### **2) Hot Oil Heater**

All hot oil heaters and circulation systems were audited.

#### **3) Steam Distribution System and Condensate Recovery System**

IBF made by-passes on the steam lines to temporarily install eddy current flow meters for flow measurement. One such by-pass was made on the main steam delivery pipe, and the other on the distribution pipe to the bleaching machine. Along with this, the condensate recovery system was audited.

#### **4) Water Supply and Drainage System**

The amounts of water supply to the production facilities and the drainage were measured.

#### **5) Electricity System**

The electricity consumption in the whole factory and those of the main facilities were investigated.

##### **(2) Energy Consumer Side**

###### **1) Bleaching Machines**

IBF has two bleaching machines, a rope bleaching machine built in 1974 and an open width bleaching machine built in 1987. The latter was audited, because this bleaching machine is operated continuously and is more important to the factory. IBF plans to bring this bleaching machine to the new site. The nominal consumption of steam is 1,750 kg/h and that of electricity is 157 kW.

###### **2) Washing Machines**

IBF also has two washing machines, new and old. The new one, built in 1996 by Max Goller, was selected for the same reasons as that for the open width bleaching machine. The nominal consumption of steam and electricity is 1,600 kg/h and 170 kW, respectively. The older washing machine was built in 1974.

Table 11-9 presents the detailed plan for energy audit of IBF. The analytic tests shown in Table 11-9 were done by the temporary laboratory of the study team, the Mining Research Institute in Ankara, Bati Cement Incorporated and Turkish Petroleum Refinery in Izmir. Additional analyses were done by Chugai Technos Laboratory and Nippon Oil Company in Japan. In Table 11-9 "Measure or Estim", "C", and "ASTM Dist" stand respectively for "Measurement or Estimation", "C", and "ASTM Distillation."



Table 11-9 Detailed Plan for Energy Audit of IBF (1/4)

Major items of energy audit	Subject	Measurement item	Measurement Range	Measurement Points	Equipment of Analysis and Measurement		Factory	EIE	Study Team	Addi- normal	Local Labo. to Japan	Carry back	Remarks	
					Modification of Equipment / Estima.	Equipment								
1. Steam Boiler 3 out of 4 Boilers were operated. They were studied.	Boiler body	Surface temp.	Max 150C	20	No	M		X	X				"Additional" is contact type.	
	Boiler feed water	Flow rate	Max 6 t/h	1	No	M			X	X				
		Temperature	Max 150C	1	No	M			X	X				
		Quality		1	No	M			X	X				
	Generated steam	Flow rate	Max 6 t/h	1	No	E								
		Temperature	Max 200C	1	No	M			X	X				
		Pressure	Max 5 bar	1	No	M			X	X				
	Blowing drain	Flow rate		1	No	M			X	X				
		Blowing time		1	No	M			X	X				
		Temperature	Max 200C	1	No	M			X	X				
		Quality		1	No	M			X	X				
	Fuel (Lignite)	Consumption rate	1.3 t/h	1	No	M			X	X				
		Industrial analysis		1	No	M						X		
		Elemental analysis		1	No	M			X	X				
		Calorific value	3500 - 4500 kcal/kg.	1	No	M			X	X				HHV
	Ash of lignite	Temperature	Max 500C	1	No	M			X	X				
		Residual carbon		1	No	M						X		
		Calorific value		1	No	M			X	X				HHV
	Combustion air	Flow rate		1	No	E								
		Temperature	Max 150C	1	No	M			X	X				
Exhaust gas	Flow rate		1	No	E									
	Temperature	Max 300C	3	No	M			X	X					
	Component		3	No	M			X	X					

Table 11-9 Detailed Plan for Energy Audit of IBF (2/4)

Major items of energy audit	Subject	Measurement Item	Measurement Range	Measurement Points	Equipment of Analysis and Measurement		Factory	EIE	Study Team	Additional	Local Labo.	Carry back to Japan	Remarks	
					Modification of Equipment / Estimal.	Measure. Equipment								
2. Steam System Main 5 groups were Measured.	Steam lines	Flow rate		2	Yes	M	Eddy current flow meter		X					
		Temperature	Max 200C	2	Yes	M	ditto		X					
		Pressure	Max 8 bar	2	Yes	M	ditto		X					
	Condensate lines	Surface temp.	Max 150C	20	No	M	Surface temp. meter		X					
		Flow rate		3	No	M	Ultrasonic flow meter		X					
		Surface temp.	Max 100C	3	No	M	Surface temp. meter		X					
	Steam traps	Temperature	Max 100C	3	No	M	Water quality meter		X					
		Quality		3	No	M	ditto		X					
		Working condition		50	No	M	Computerized management system		X					
	Heater body	Flow rate	Max 100C	50	No	M	ditto		X					
		Temperature	Max 100C	50	No	M	ditto		X					
		Surface temp.	Max 150C	20	No	M	Surface temp. meter		X					
	3. Hot oil system 7 Heaters were operated. Main 5 Heaters were studied.	Hot oil	Flow rate	Max 500 kL/h	1	Not possible	M	Pump capacity data		X				
			Temperature	Max 300C	3	Not possible	M	Thermometer		X				
			Pressure	Max 10 bar	2	Not possible	M	Pressure gauge		X				
Fuel oil		Specific heat		1	No	E	Estimated from SpGr and ASTM Dist.		X				X	
		Flow rate	Max 0.5 kL/h	1	Not possible	M	Tank gauge		X					
		Temperature	Max 150C	1	Not possible	M	Thermometer		X					
Combustion air		Elemental analysis		1	No	M	Elemental analyzer		X				X	
		Calorific value	Max 10000 kcal/kg	1	No	M	Bomb calorimeter		X				X	HHV
		Flow rate		1		E								
Exhaust gas		Temperature	Max 150C	3	No	M	Thermometer		X					
		Flow rate		1	No	E								
		Temperature	Max 300C	2	No	M	Stack gas analyzer		X				X	
Hot oil lines		Component		2	No	M	ditto		X				X	
		Flow rate	Max 100 kL/h	5	Not possible	M	Specifications of machine		X				X	
		Surface temp.	Max 200C	20	No	M	Surface temp. meter		X				X	
User facilities	Surface temp.	Max 200C	20	No	M	Surface temp. meter		X				X		

Table 11-9 Detailed Plan for Energy Audit of IBF (3/4)

Major items of energy audit	Subject	Measurement item	Measurement Range	Measurement Points	Equipment of Analysis and Measurement		Factory	EIE	Study Team	Addi-tional	Local Labo.	Carry back to Jagan	Remarks
					Modification of Equipment	Measure. / Extns.							
4. Water supply and drainage system	Fresh water to major processes	Flow rate		6	No	M	X		X	X			or flow meter of factory
		Temperature		1	No	M				X			
	Waste water from major processes	Flow rate		6	No	M			X	X			
		Temperature		6	No	M				X			
5. Electricity system	Receiving transformers	Electric current		3	No	M	X						
		Voltage		3	No	M	X						
	Power factor	Power factor meter		3	No	M	X						
		Electric power		3	No	M	X						
Main users of electricity	Electric current	Electric current		11	No	M	X		X				
		Voltage		11	No	M	X		X				
	Power factor	Energy analyzer		11	No	M	X		X				
		Electric power		11	No	M	X		X				
6. Open Width Bleaching Machine Body Range (Balboek, 1974)	Cloth	Surface temp.	Max 100C	20	No	M		X					
		Flow rate		1	No	M	X						
	Temperature	Factory speed controller		2	No	M	X						
		Surface temp. meter		2	No	M		X					
	Moisture	Balance		2	No	M			X				
		Flow rate	Max 2000kg/h	1	Yes	M				X			
	Temperature	Eddy current flow meter		1	Yes	M				X			
		Pressure	Max 200C	1	Yes	M				X			
	Steam condensate	Flow rate	Max 8 bar	1	Yes	M				X			
		Temperature	Max 100C	1	No	M		X					
	Fresh water	Flow rate	Max 50 t/h	3	No	M		X					
		Temperature	Max 100C	6	No	M		X			X		
Warm Water	Flow rate	Max 150C	3	No	M		X						
	Temperature	Max 150C	3	No	M		X						
Electricity	Electric current	Flow meter		1	No	M	X						
		Voltage		1	No	M	X						
	Power factor	Energy analyzer		1	No	M	X						
		Electric power		1	No	M	X						

Table 11-9 Detailed Plan for Energy Audit of IBF (4/4)

Major items of energy audit	Subject	Measurement item	Measurement Range	Measurement Points	Modification of Equipment / Estimate		Equipment		Factory	EIE	Study Team	Additional Labo.	Local Carry back to Japan	Remarks
					No	M	No	M						
7. Washing Range (Max Goller 1995)	Machine Body	Surface temp.	Max 100C	20	No	M	Surface temp. meter			X				
	Cloth	Flow rate		1	No	M	Factory speed controller	X						
		Temperature			2	No	M	Surface temp. meter		X				
		Moisture			2	No	M	Balance			X			
	Steam	Flow rate	Max 2000kg/h		1	Yes	M	Eddy current flow meter				X		
		Temperature	Max 200C		1	Yes	M	ditto				X		
		Pressure	Max 8 bar		1	Yes	M	ditto				X		
	Steam condensate	Flow rate			1	No	M							
		Temperature	Max 100C		1	No	M	Flow meter	X			X		
		Quality			1	No	M	Water quality meter			X			
	Washing water	Flow rate	Max 50 t/h		3	No	M							
		Temperature	Max 100C		6	No	M	Flow meter	X				X	
								Glass bar thermometer				X		
	Waste water	Flow rate			3	No	M							
		Temperature	Max 150C		3	No	M	Flow meter	X			X		
	Electricity	Electric current						Glass bar thermometer						
		Voltage			1		M							
		Power factor			1		M	Armmer, Clampmeter	X			X		
		Electric power			1		M	Energy analyzer	X			X		
								ditto				X		
							ditto				X			

## 11-8 Execution Procedure of Measurement

The equipment used for the energy audit is shown in Table 11-9, with the measuring ranges, approximate numbers of measuring points, proprietors, etc. Table 11-10 shows personnel assignments to the measurement, and the schedule outline.

Table 11-10 Detailed Plan and Schedule for Energy of IBF (1/2)

Analyzing and Measuring Item	Personnel Allocation		August							September							Remarks										
	JICA Number	EIE Number	Days							Days																	
	2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		1	1	1	1	1	1	1	1		
1. Steam Boiler 3 out of 4 Boilers were operated. They were studied.	Boiler body	Surface Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		
	Boiler feed water	Flow rate, Temperature, Quality	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Generated steam	Flow rate, Temperature, Pressure	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Blowing drain	Flow rate, Blowing time, Quality	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Fuel (Lignite)	Consumption rate	Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Industrial analysis	Elemental analysis	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
		Calorific value	Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
	Ash of lignite	Residual carbon, Calorific value	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Combustion air	Flow rate	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Exhaust gas	Temperature	Flow rate	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Temperature, Component	Temperature, Component	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	2. Steam System Main 5 groups were Measured.	Steam lines	Flow rate, Temperature, Pressure	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Condensate lines	Surface Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
			Flow rate, Temperature, Quality	Flow rate, Temperature, Quality	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
Steam traps		Surface Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Working condition	Working condition	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
Flow rate, Temperature		Flow rate, Temperature	Flow rate, Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Flow rate, Temperature	Flow rate, Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
3. Hot oil system 7 Heaters were operated. Main 5 Heaters were studied.	Heater body	Surface Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		
	Hot oil	Flow rate, Temperature, Pressure	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Specific heat	Specific heat	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Fuel oil	Flow rate, Temperature	Flow rate, Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Elemental analysis, Calorific value	Elemental analysis, Calorific value	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Combustion air	Flow rate	Flow rate	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Temperature	Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Exhaust gas	Flow rate	Flow rate	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Temperature, Component	Temperature, Component	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
	Hot oil lines	Flow rate, Surface Temperature	Flow rate, Surface Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
Surface Temperature		Surface Temperature	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		

Table 11-10 Detailed Plan and Schedule for Energy of IBF (2/2)

Analyzing and Measuring Item	Personnel Allocation		August							September							Remarks	
	JICA Number	EIE Number	Factory Days							Factory Days								
	1	2	2	5	27	28	29	30	31	1	2	3	4	5	6	7		8
4. Water supply and drainage system	Fresh water to major processes		X	X	X	X	X	X	X									
	Waste water from major processes		X	X	X	X	X	X	X									
5. Electricity system	Receiving transformers	1	2	9	X	X	X	X	X	X	X	X	X	X	X	X	X	X
	Main users of electricity				X	X	X	X	X	X	X	X	X	X	X	X	X	X
6. Open Width Bleaching Range (Babcock 1974)	Machine Body	1	2	5	X	X	X	X	X									
	Cloth				X	X	X	X	X									
	Steam				X	X	X	X	X									
	Steam condensate				X	X	X	X	X									
	Fresh Wwater				X	X	X	X	X									
	Warm water				X	X	X	X	X									
	Electricity				X	X	X	X	X									
7. Washing Range (Max Goller 1995)	Machine Body	1	2	5						X	X	X	X	X	X	X	X	X
	Cloth									X	X	X	X	X	X	X	X	X
	Steam									X	X	X	X	X	X	X	X	X
	Steam condensate									X	X	X	X	X	X	X	X	X
	Washing water									X	X	X	X	X	X	X	X	X
	Waste Water									X	X	X	X	X	X	X	X	X
	Electricity									X	X	X	X	X	X	X	X	X

## 11-9 Results of Measurement and Analysis

### 11-9-1 Open Width Bleaching Range

The open width bleaching range may be divided into two parts as shown in Figure 11-5, namely:

1. Chemical treatment and washing baths and a steamer. The chemical treatment and washing baths are located on the first floor. The steamer is located on the second floor.
2. Heat recovery unit from hot waste water. This is located behind the chemical treatment baths.

The outline of the heat recovery unit is shown in Figure 11-6. Measurements were done on the two parts, and the following results were obtained.

#### (1) Fresh Water and Fabric Speed

The open width bleaching range has nine baths, or sections to be exact, which contain cold, warm and hot water. Each fabric has a code number that determines the processes to be applied: bleaching, mercerization, washing, printing, drying, for example.

Each bleaching bath has two water inlets, cold and warm, to the water basin, one water inlet (mainly cold) for spraying onto squeezing cylinders, and one steam inlet to warm water. Bleaching machine operators manually open or close the water and steam valves to attain the required temperature of the contents of the baths by watching the temperature indicator on each bath. When the operation stops for a moment the water and steam valves are left open, while when the operation stops for a long time the valves are closed. This causes unnecessary heat consumption.

Water consumption was measured from the 3rd to 5th of September by reading the water meter. The measurement results are shown in Table 11-11.






Figure 11-5 Schematic Flow Diagram of the Open Width Bleaching Range




Figure 11-6 Heat Recovery System from Waste Water of the Open Width Bleaching Range & Measuring Points

**Table 11-11 Water Consumption and Fabric Speed of Open Width Bleaching Range**

	Sept. 3. 1996	Sept. 4. 1996	Sept. 5. 1996
Water Meter Reading, m <sup>3</sup>	399,119	399,825	400,704
Water Consumption, m <sup>3</sup> /day	--	706	879
Bleached Fabric, m/day	--	57,000	50,514
Machine Operating Time, hour and min.	--	20 h 45 min	21 h
Average Fabric Speed, m/min	--	45.8	40
Average Water Consumption, m <sup>3</sup> /h	--	34	41.2

The average total water consumption rate of the range was 38 m<sup>3</sup>/h and the inlet temperature was 27.5°C (Refer to Tables 11-11 and 11-12). The fresh water flow is separated into two flows; one goes directly to the baths, the other to the heat recovery unit. The average fabric speed was 43 m/min.

**(2) Waste Water**

This range has a heat recovery unit that recovers heat from hot water discharges from Baths 1, 2, 3 and 5. The recovered heat is used for preheating water. The temperature and flow rates of waste water are shown in Table 11-12. The measured points are shown by numbers in Figure 11-6 and Table 11-12. The waste water in excess of the heat exchanger capacity overflows directly to the canal. Hot water temperatures of overflows were measured as 99.6°C and water temperature from the machine may be considered the same. Because the system is closed, other water temperatures were not measured. Instead, pipe surface temperatures were measured. The overflows, at points [4] and [7], were measured. The measured values were: overflow 1 liter/second at point [4] and also overflow 1 liter/second at point [7], a total of 2 liters/second. The total overflow is: 2 liters/second = 7.2 m<sup>3</sup>/hour. With zero degrees Centigrade being the base temperature of enthalpy, the following mass and heat flows are obtained.

Total overflow before the heat exchanger unit: 7.2 m<sup>3</sup>/h (average)

Total heat loss as overflow:  $7.2 \times 1,000 \times 99.6 = 717 \times 10^3 \text{ kcal/h}$

The amount of waste water which exchanged heat was estimated by the design value of fresh water flow rate at 25 m<sup>3</sup>/h and the measured temperatures of the fresh and waste water at the inlet and outlet of the heat exchanger. The estimated amount was about 5.2 m<sup>3</sup>/h.

Waste water that exchanged heat: 5.2 m<sup>3</sup>/h

Heat loss with the waste water that exchanged heat:  $5.2 \times 1,000 \times 40$

$$= 208 \times 10^3 \text{ kcal/h}$$

Another portion of water is considered to be dumped directly from the machines as waste water without heat exchange or being evaporated to the atmosphere. From the measured values of the inside temperatures of Baths Nos. 4 and 6 to 9, an average temperature of 50°C is assumed.

Other wasted water:  $38 - 7.2 - 5.2 = 25.6 \text{ m}^3/\text{h}$

Heat loss with waste water directly from the machine:

$$25.6 \times 1,000 \times 50 = 1,280 \times 10^3 \text{ kcal/h}$$

**Table 11-12 Measurement Results on Heat Recovery System from Waste Water at the Open Width Bleaching Range**

No. on Figure 11-6	Subject	Temperature (°C)	Flow Rate (m <sup>3</sup> /hour)
[1]	Fresh Water	27.5	38
[2]	Fresh Water (after Heat Exchanger)	40	
[3]	Fresh Water, Hot (after Steam Heater)	90	
[4]	Waste Water (Over flow before Filtering Vessel)	99.6	3.6
[5]	Waste Water (Inside Vessel, before Rotary Filter)	99.6	
[6]	Waste Water (Inside Vessel, after Rotary Filter)	98.5	
[7]	Waste Water (Over flow after Filtering Vessel)	99.6	3.6
[8]	Waste Water (after Filtering Vessel)	92	
[9]	Waste Water (after Heat Exchanger)	40	
(1)	Fresh Water Inlet Pipe to Heat Exchanger	28 (Surface)	
(2)	Fresh Water Inlet Pipe to Steam Heater	34 (Surface)	
(3)	Fresh Water Outlet Pipe from Steam Heater	79 (Surface)	
(4)	Waste Water Inlet Pipe to Filtering Vessel	83 (Surface)	
(5)	Filtering Vessel	83 (Surface)	
(6)	Waste Water Outlet Pipe from Filtering Vessel	89 (Surface)	
(7)	Waste Water Pipe to Heat Exchanger	90 (Surface)	
(8)	Waste Water Pipe from Heat Exchanger	34 (Surface)	

### (3) Steam

The total steam flow rate to the range is 2,200 kg/h. Steam is supplied directly to the baths, the steamer, and the steam heater after the heat recovery unit.

#### (4) Steam Condensate

Steam condensate is not recovered.

#### (5) Cloth (in and out)

The cloth flow rate is calculated by the following equation, and moisture content and temperature were measured.

$$\text{Cloth flow rate} = \text{Fabric Speed} \times \text{Fabric Width} \times \text{Fabric Weight}$$

In the case of the present range the fabric width, fabric weight, moisture content (dry base) and temperature are as follows.

The fabric width was 100 to 220 cm (average 160 cm)

The fabric weight was calculated by measurement by a balance and area measurement, g/m<sup>2</sup>:

Sample 1	120
Sample 2	160
Average	140.

The moisture of the fabric obtained by weighing the dry and wet samples, in percentage, was:

Inlet: 79 to 80

Outlet: 80 to 81.

The temperature of the fabric in degree Centigrade was:

Inlet: 31

Outlet: 31.

#### (6) Temperature of Machine Surface and Heat Loss

The average measured surface temperatures and sizes of the baths and steamer are shown in Table 11-13. The heat loss from the machine surfaces was calculated by the following equations and the results are also shown in Table 11-13.

$$\text{Radiation heat loss} = 0.86 \times (5.67 \times 10^{-8}) \times (\text{Emissivity}) \times (T_o^4 - T_a^4)$$

$$\text{Convection heat loss} = (\text{Heat transfer coefficient}) \times (T_o - T_a)$$

where

Conversion factor, Watts to kcal/h	0.860
Stefan-Boltzmann constant, Watts/m <sup>2</sup> K <sup>4</sup>	5.67 x 10 <sup>-8</sup>
Surface temperature, degree Kelvin	T <sub>o</sub>
Ambient temperature, degree Kelvin	T <sub>a</sub>

Table 11-13 Open Width Bleaching Range Size, Surface Temperature and Heat Loss from the Surface (1/4)

Ambient Temperature ( °C) 31.0  
 Emissivity (-) 0.8  
 Heat Trans. Coefficient (k (kcal/m<sup>2</sup>/h°C) 10

Unit No.	Unit Name	Dimension	Length (m)	Volume (m <sup>3</sup> )	Surface Area (m <sup>2</sup> )	Surface Temp. (°C)	Unit Heat Loss (kcal/m <sup>2</sup> /h)		Total Heat Loss (kcal/h)	
							Radiation	Convection Rad.+ Conv.		
1	1F No.1 Bath	Length	0.90							
		Width	3.00							
		Height	1.80							
		Volume		4.86						
		Fiber Inlet Side			5.40	81.0	279	500	779	4209
		Top Cover			2.70	80.0	273	490	763	2059
		Bottom Plate			2.70	85.0	293	520	813	2196
		Operation Side			1.62	82.0	286	510	796	1290
		Driving Side			1.62	83.0	293	520	813	1318
							Sub Total	11073		
2	1F No.2 Bath	Length	1.70							
		Width	3.00							
		Height	1.60							
		Volume		8.16						
		Top Cover			5.10	95.0	382	640	1022	5214
		Bottom Plate			5.10	97.0	398	660	1058	5396
		Operation Side			2.72	97.0	398	660	1058	2878
		Driving Side			2.72	96.0	390	650	1040	2829
									Sub Total	16317
3	1F No.3 Bath	Length	1.70							
		Width	3.00							
		Height	1.60							
		Volume		8.16						
		Top Cover			5.10	36.0	22	50	72	370
		Bottom Plate			5.10	33.0	9	20	29	147
		Operation Side			2.72	34.0	13	30	43	118
		Driving Side			2.72	33.0	9	20	29	78
									Sub Total	715

Table 11-13 Open Width Bleaching Range Size, Surface Temperature and Heat Loss from the Surface (2/4)

Unit No.	Unit Name	Dimension	Length (m.)	Volume (m <sup>3</sup> )	Surface Area (m <sup>2</sup> )	Surface Temp. (°C.)	Radiation	Convection	Unit Heat Loss (kcal/m <sup>2</sup> /h)	Total Heat Loss (kcal/h)
4	1F No.4 Bath	Length	1.70							
		Width	3.00							
		Height	1.60							
		Volume		8.16						
		Top Cover			5.10	34.0	13	30	43	221
		Bottom Plate			5.10	32.0	4	10	14	73
		Operation Side			2.72	32.0	4	10	14	39
Driving Side			2.72	32.0	4	10	14	39		
									Sub Total	373
5	1F No.5 Bath (Forward)	Length	1.00							
		Width	3.00							
		Height	1.60							
		Volume		4.80						
		Top Cover			3.00	92.0	359	610	969	2908
		Bottom Plate			3.00	97.0	398	660	1058	3174
		Operation Side			1.60	97.0	398	660	1058	1693
Driving Side			1.60	97.0	398	660	1058	1693		
									Sub Total	9467
	1F No.5 Bath (Tail)	Length	1.70							
		Width	3.00							
		Height	1.60							
		Volume		8.16						
		Top Cover			5.10	93.0	367	620	987	5033
		Bottom Plate			5.10	95.0	382	640	1022	5214
		Operation Side			2.72	96.0	390	650	1040	2829
Driving Side			2.72	95.0	382	640	1022	2781		
									Sub Total	15857

Table 11-13 Open Width Bleaching Range Size, Surface Temperature and Heat Loss from the Surface (3/4)

Unit No.	Unit Name	Dimension	Length (m)	Volume (m <sup>3</sup> )	Surface Area (m <sup>2</sup> )	Surface Temp. (C)	Radiation	Convection	Unit Heat Loss (kcal/m <sup>2</sup> /h)	Total Heat Loss (kcal/h)
6	1F No.6 Bath	Length	1.70							
		Width	3.00							
		Height	1.60							
		Volume		8.16						
		Top Cover			5.10	95.0	382	640	1022	5214
		Bottom Plate			5.10	94.0	375	650	1005	5123
		Operation Side			2.72	96.0	390	650	1040	2829
Driving Side			2.72	96.0	390	650	1040	2829		
								Sub Total	15996	
7	1F No.7 Bath	Length	1.70							
		Width	3.00							
		Height	1.60							
		Volume		8.16						
		Top Cover			5.10	63.0	164	320	484	2469
		Bottom Plate			5.10	65.0	176	340	516	2632
		Operation Side			2.72	65.0	176	340	516	1404
Driving Side			2.72	65.0	176	340	516	1404		
								Sub Total	7907	
8	1F No.8 Bath	Length	1.70							
		Width	3.00							
		Height	1.60							
		Volume		8.16						
		Top Cover			5.10	42.0	51	110	161	821
		Bottom Plate			5.10	43.0	56	120	176	897
		Operation Side			2.72	42.0	51	110	161	438
Driving Side			2.72	42.0	51	110	161	438		
								Sub Total	2593	



Table 11-13 Open Width Bleaching Range Size, Surface Temperature and Heat Loss from the Surface (4/4)

Unit No.	Unit Name	Dimension	Length (m.)	Volume (m3)	Surface Area (m2)	Surface Temp. (C)	Radiation	Convection	Rad.+ Conv.	Unit Heat Loss (kcal/m2/h)	Total Heat Loss (kcal/h)
9	1F No.9 Bath	Length	1.70								
		Width	3.00								
		Height	1.60								
		Volume		8.16							
		Top Cover			5.10	35.0	18	40	58	295	
		Bottom Plate			5.10	31.0	0	0	0	0	
		Operation Side			2.72	33.0	9	20	29	78	
Driving Side			2.72	32.0	4	10	14	39			
		Sub Total								413	
10	2F Steamer	Length	7.60								
		Width	3.00								
		Height	2.90								
		Volume		66.12							
		Top Cover			22.80	50.0	91	190	281	6417	
		Bottom Plate			22.80	45.0	66	140	206	4691	
		Front Side			8.70	44.0	61	130	191	1660	
		Back Side			8.70	50.0	91	190	281	2449	
		GlassWindow			3.82	93.0	367	620	987	3768	
		Wall			18.22	49.0	86	180	266	4851	
		GlassWindow			3.82	97.0	398	660	1058	4039	
		Wall			18.22	47.0	76	160	236	4298	
				Sub Total							
		Total								112881	

Radiation Heat Loss =  $0.86 \times 0.0000000567 \times (\text{Emissivity}) \times (T_o^4 - T_a^4)$

Convection Heat Loss =  $(\text{Heat Trans Coefficient}) \times (t_o - t_a)$

Wh/kcal: 0.86

Stefan Boltzmann factor: 0.0000000567

### (7) Temperature of Machine Inside

The average measured inside temperature of the baths and steamer is shown in Table 11-14.

**Table 11-14 Inside Temperature in Baths and Steamer**

(Unit: °C)									
No. of Bath	1	2	3	4	5	6	7	8	9
Temperature	95	100	35	33	98	98	67	43	35
<hr/>									
<b>Steamer</b>									
Temperature	100								

### (8) Analysis

Using the results of measurement and calculation described above, the heat balance (0°C basis) of the open width bleaching range was determined as follows. An energy flowcharts developed based on the heat balance are shown in Figure 11-17 in Section 11-10.

#### 1) Heat Input

Item	Value	Unit
(1) Steam		
Flow rate	2,200	kg/h
Enthalpy	660	kcal/kg
Heat input	1,452	10 <sup>3</sup> kcal/h
(2) Water		
Flow rate	38,000	kg/h
Temperature	27.5	°C
Heat input	1,045	10 <sup>3</sup> kcal/h
(3) Cloth		
Cloth speed	43	m/min
Fabric width (average)	1.6	m
Fabric weight (average)	140	g/m <sup>2</sup>
Moisture (dry base)	80	%
Temperature	31	°C
Specific heat (cotton)	0.319	cal/g°C
Specific heat (moisture)	1	cal/g°C
Heat input	20	10 <sup>3</sup> kcal/h

(4) Electricity		
Consumption rate (measured)	68	10 <sup>3</sup> kcal/h
(5) Total heat input	2,585	10 <sup>3</sup> kcal/h

## 2) Heat Output

Item	Value	Unit
(1) Steam condensate		
Flow rate	2,200	kg/h
Temperature	100	°C
Heat output	220	10 <sup>3</sup> kcal/h
(2) Waste water		
1) Over flow before the heat exchanger		
Flow rate	7,200	kg/h
Temperature	99.6	°C
Heat output	717	10 <sup>3</sup> kcal/h
2) Waste water after the heat recovery unit		
Flow rate	5,200	kg/h
Temperature	40	°C
Heat output	208	10 <sup>3</sup> kcal/h
3) Waste water directly from the machine		
Flow rate	25,600	kg/h
Temperature	50	°C
Heat output	1,280	10 <sup>3</sup> kcal/h
Heat output (sub-total of waste water)	2,205	10 <sup>3</sup> kcal/h
(3) Cloth		
Cloth speed	43	m/min
Fabric width (average)	1.6	m
Fabric weight (average)	140	g/m <sup>2</sup>
Moisture (dry base)	80	%
Temperature	31	°C
Specific heat (cotton)	0.319	cal/g°C
Specific heat (moisture)	1	cal/g°C
Heat input	20	10 <sup>3</sup> kcal/h
(4) Heat loss from surface of machine body		
Heat outlet (as of Table 11-13)	113	10 <sup>3</sup> kcal/h

	including Baths Nos. 1, 2, 5 & 6 (higher than 80°C)	69	
	Windows of steamer	8	
(5)	Others (unknown)	27	10 <sup>3</sup> kcal/h
(6)	Total heat output	2,585	10 <sup>3</sup> kcal/h

### 3) Heat Recycle

Item	Value	Unit
(1) Waste water		
Flow rate	5,200	kg/h
Temperature before heat exchanger unit	99.6	°C
Temperature after heat exchanger unit	40	°C
Heat recovered	313	10 <sup>3</sup> kcal/h

#### 11-9-2 Max Goller Washing Range

The Max Goller washing range was quite recently acquired by IBI, and operation started in December 1995. A schematic flow diagram is shown in Figure 11-7 with utility connections. The range comprises a foulard (padding)/flash ager and nine washing baths. All temperatures, water and steam flows are controlled by a computerized control system. Cold water enters the range and heated by steam to warm water. All parameters such as water temperatures of each unit, chemicals, amounts of steam and water are shown on the display control system. The results of the measurements are as follows.

##### (1) Steam

Steam flow rate to the flash ager was 370 kg/h, and that to the washing part was 1,580 kg/h on an average. The steam consumption of the range was measured by the total flow rate to the factory, while all other machines were stopped intentionally for this measurement. This is done because direct measurement of the steam flow to the Max Goller washing range requires modification of the facilities and this was found impossible. The measured results are probably larger than the actual consumption, because some leakage to other facilities through apparently closed valves might be included.




Figure 11-7 Schematic Flow Diagram of Mac Goller Washing Range

**(2) Fresh Water and Fabric Speed**

Water consumption is calculated by the water meter readings. The results are shown in Table 11-15.

**Table 11-15 Water Consumption and Fabric Speed of Max Goller Washing Range**

	Sept. 3, 1996	Sept. 4, 1996	Sept. 5, 1996
Water Meter Reading, m <sup>3</sup>	19,086.2	19,479.8	19,674.0
Water Consumption, m <sup>3</sup> /day	--	393.6	194.2
Washed Fabric, m/day	--	27,837	9,130
Machine Operating Hour, hour and min.	--	19 h 40 min	9 h 35 min
Average Fabric Speed, m/min	--	23.5	16.0
Average Water Consumption, m <sup>3</sup> /h	--	20.0	20.3

The washing range is provided with automatic shutoff devices, which close the feed lines of water, chemicals and steam when the machine stops. Because of the devices, water consumption rates measured were almost the same for these three days. The average fresh water consumption was 20.2 m<sup>3</sup>/h, and the average fabric speed was 19.8 m/min.

**(3) Cloth Flow Rate and Moisture Content (in and out)**

The fabric speed is shown in Table 11-15, and the fabric width and fabric weight are the same as for the open width bleaching range. The temperature and moisture content of the cloth were measured to be 31°C and 80 percent at the inlet and outlet of the range.

**(4) Electricity**

The flash ager has an electric superheater of steam to raise the inside temperature to 130°C. This is controlled automatically. The design capacity is:

9 kW x 4

6 kW x 4

Total 60 kW

**(5) Steam Condensate**

All steam condensate is recovered.

#### **(6) Waste Water**

This Max Goller washing range has no heat recovery system from the waste water. Only the first bath, No. 0 Bath, has a water cleaning and reusing system. Water coming from the first bath is cleaned in this system by a rotary disc filter and is sent back to the first bath and reused as prewashing water to be sprayed through nozzles on the fabric. Two types of washing are done in this machine, cold washing and hot washing. The temperature of the discharge water from the cold washing is about 30°C and that from the hot washing is about 70°C. All discharges are sent directly to the canal, because no heat recovery system is provided.

#### **(7) Temperature of Machine Surface and Heat Loss**

The surface temperatures and dimensions measured of each unit of the range are shown in Table 11-16. The heat losses from the machine surfaces are calculated by the method applied to the open width bleaching range. The calculated surface heat losses are also shown in Table 11-16.

Table 11-16 Max Goller Washing Range Size, Surface Temperature and Heat Loss from the Surface (1/4)

Ambient Temperature (C °C) 31.0  
 Emissivity (-) 0.8  
 Heat Trans. Coefficient (k kcal/m<sup>2</sup>h°C) 10

Unit No.	Unit Name	Dimension	Length (m)	Volume (m <sup>3</sup> )	Surface Area (m <sup>2</sup> )	Surface Temp. (C)	Unit Heat Loss (kcal/m <sup>2</sup> h.)		Total Heat Loss (kcal/h)	
							Radiation	Convection Rad.+ Conv.		
1	Flash Ager	Length	0.60							
		Width	2.70							
		Height	6.35-6.7							
		Volume		10.57						
		Top Cover			0.42	80.0	273	490	763	318
		Bottom Plate			1.62	50.0	91	190	281	456
		Front Side			18.09	50.0	91	190	281	5091
		Back Side			17.15	50.0	91	190	281	4825
		Right Side			3.92	50.0	91	190	281	1102
		Left Side			3.92	50.0	91	190	281	1102
		Frames arr. Lids			1.00	95.0	382	640	1022	1022
		Fan Body			0.50	92.0	359	610	969	485
		Inlet Pipe of Fan			1.00	95.0	382	640	1022	1022
Outlet Pipe of Fan			2.00	51.0	97	200	297	593		
						Sub Total		16017		
2	No.0 Washing Bath	Length	0.50							
		Width	3.15							
		Height	1.50							
		Volume		2.36						
		Top Cover			1.58	31.0	0	0	0	0
		Bottom Plate			1.58	29.0	-9	-20	-29	-45
		Operation Side			0.75	31.0	0	0	0	0
Driving Side			0.75	32.0	4	10	14	11		
						Sub Total		-34		



Table 11-16 Max Collet Washing Range Size, Surface Temperature and Heat Loss from the Surface (2/4)

Unit No.	Unit Name	Dimension	Length (m)	Volume (m <sup>3</sup> )	Surface Area (m <sup>2</sup> )	Surface Temp. (°C)	Radiation	Convection	Rad.+ Conv. (kcal/h)	Unit Heat Loss (kcal/m <sup>2</sup> /h)	Total Heat Loss (kcal/h)
3	No.1 Washing Bath	Length	2.15								
		Width	3.15								
		Height	1.50								
		Volume		10.16							
		Top Cover			6.77	31.0	0	0	0	0	0
		Bottom Plate			6.77	28.0	-13	-30	-43	-291	
		Operation Side			3.23	31.0	0	0	0	0	
Driving Side			3.23	32.0	4	10	14	46			
									Sub Total	-244	
4	No.2 Washing Bath	Length	2.15								
		Width	3.15								
		Height	1.50								
		Volume		10.16							
		Top Cover			6.77	32.0	4	10	14	98	
		Bottom Plate			6.77	29.0	-9	-20	-29	-194	
		Operation Side			3.23	32.0	4	10	14	46	
Driving Side			3.23	32.0	4	10	14	46			
									Sub Total	-4	
5	No.3 Washing Bath	Length	2.15								
		Width	3.15								
		Height	1.50								
		Volume		10.16							
		Top Cover			6.77	40.0	41	90	131	889	
		Bottom Plate			6.77	40.0	41	90	131	889	
		Operation Side			3.23	39.0	36	80	116	376	
Driving Side			3.23	39.0	36	80	116	376			
									Sub Total	2529	

Table 11-16 Max Goller Washing Range Size, Surface Temperature and Heat Loss from the Surface (3/4)

Unit No.	Unit Name	Dimension	Length (m)	Volume (m <sup>3</sup> )	Surface Area (m <sup>2</sup> )	Surface Temp. (°C)	Radiation	Convection	Rad.+ Conv. (kcal/h)	Unit Heat Loss (kcal/m <sup>2</sup> /h)	Total Heat Loss (kcal/h)	
6	No.4 Washing Bath	Length	2.15									
		Width	3.15									
		Height	1.50									
		Volume		10.16								
		Top Cover			6.77	73.0	226	420	646	4375		
		Bottom Plate			6.77	78.0	259	470	729	4937		
		Operation Side			3.23	73.0	226	420	646	2083		
		Driving Side			3.23	73.0	226	420	646	2083		
											Sub Total	13478
7	No.5 Washing Bath	Length	2.15									
		Width	3.15									
		Height	1.50									
		Volume		10.16								
		Top Cover			6.77	81.0	279	500	779	5279		
		Bottom Plate			6.77	82.0	286	510	796	5394		
		Operation Side			3.23	78.0	259	470	729	2351		
		Driving Side			3.23	77.0	252	460	712	2297		
										Sub Total	15321	
8	No.6 Washing Bath	Length	2.15									
		Width	3.15									
		Height	1.50									
		Volume		10.16								
		Top Cover			6.77	55.0	118	240	358	2427		
		Bottom Plate			6.77	60.0	147	290	437	2956		
		Operation Side			3.23	55.0	118	240	358	1156		
		Driving Side			3.23	54.0	113	230	343	1106		
										Sub Total	7645	

Table 11-16 Max Goller Washing Range Size, Surface Temperature and Heat Loss from the Surface (4/4)

Unit No.	Unit Name	Dimension	Length (m)	Volume (m <sup>3</sup> )	Surface Area (m <sup>2</sup> )	Surface Temp. (°C)	Radiation	Convection	Rad.+ Conv.	Unit Heat Loss (kcal/m <sup>2</sup> /h)	Total Heat Loss (kcal/h)
9	No.7 Washing Bath	Length	2.15								
		Width	3.15								
		Height	1.50								
		Volume		10.16							
		Top Cover			6.77	36.0	22	50	72	72	491
		Bottom Plate			6.77	31.0	0	0	0	0	0
		Operation Side			3.23	35.0	18	40	58	58	187
Driving Side			3.23	36.0	22	50	72	72	234		
		Sub Total									911
10	No.8 Washing Bath	Length	2.15								
		Width	3.15								
		Height	1.50								
		Volume		10.16							
		Top Cover			6.77	36.0	22	50	72	72	491
		Bottom Plate			6.77	30.0	-4	-10	-14	-14	-97
		Operation Side			3.23	35.0	18	40	58	58	187
Driving Side			3.23	35.0	18	40	58	58	187		
		Sub Total									767
		Total									56386

Radiation Heat Loss =  $0.86 \times 0.0000000567 \times (\text{Emissivity}) \times (T_o^4 - T_a^4)$

Convection Heat Loss =  $(\text{Heat Trans Coefficient}) \times (t_o - t_a)$

Wh/kcal: 0.86

Stefan Boltzmann factor: 0.0000000567

### (8) Temperature of Machine Inside

The temperatures of water in the baths were also measured and are shown in Table 11-17.

Table 11-17 Temperature of Water in Each Washing Bath

No. of Bath	0	1	2	3	4	5	6	7	8
Temperature	28	28	28	42	82	87	62	31	30

(Unit: °C)

### (9) Analysis

A heat balance of the Max Goller washing range including the flash ager was calculated as shown below by the same method used for the open width bleaching range. The energy flow chart is shown in Figure 11-18 in Section 11-10.

#### 1) Heat Input

Item	Value	Unit
(1) Steam		
Flow rate	1,950	kg/h
Flash ager	370	
Washing range	1,580	
Enthalpy	660	kcal/kg
Heat input	1,287	10 <sup>3</sup> kcal/h
(2) Water		
Flow rate	20,200	kg/h
Temperature	27.5	°C
Heat input	556	10 <sup>3</sup> kcal/h
(3) Cloth		
Cloth speed	19.8	m/min
Fabric width (average)	1.6	m
Fabric weight (average)	140	g/m <sup>2</sup>
Moisture (dry base)	80	%
Temperature	31	°C
Specific heat (cotton)	0.319	cal/g°C
Specific heat (moisture)	1	cal/g°C
Heat input	9	10 <sup>3</sup> kcal/h
(4) Electricity		

Consumption rate (measured)	35	10 <sup>3</sup> kcal/h
(5) Total heat input	1,887	10 <sup>3</sup> kcal/h


## 2) Heat Output

Item	Value	Unit
(1) Steam for aging		
Flow rate      Flash ager (assumed)	270	kg/h
Enthalpy	660	kcal/kg
Heat output	178	10 <sup>3</sup> kcal/h
(2) Steam condensate		
Flow rate	1,680	kg/h
Flash ager (assumed)	100	
Washing range	1,580	
Temperature	100	°C
Heat output	168	10 <sup>3</sup> kcal/h
(3) Waste water		
Flow rate	20,200	kg/h
Temperature	70	°C
Heat output	1,414	10 <sup>3</sup> kcal/h
(4) Cloth		
Cloth speed	19.8	m/min
Fabric width (average)	1.6	m
Fabric weight (average)	140	g/m <sup>2</sup>
Moisture (dry base)	80	%
Temperature	31	°C
Specific heat (cotton)	0.319	cal/g°C
Specific heat (moisture)	1	cal/g°C
Heat output	9	10 <sup>3</sup> kcal/h
(5) Heat loss from surface of machine body		
Heat outlet (as of Table 11-16)	56	10 <sup>3</sup> kcal/h
including Flash ager	16	
Baths Nos. 5 & 6	28	
(6) Others (unknown)	62	10 <sup>3</sup> kcal/h
(7) Total heat output	1,887	10 <sup>3</sup> kcal/h

### 11-9-3 Energy Supply Side

The results of the measurements are as follows:

1. Hot oil heater flue gas measurement is shown in Figure 11-8 and Table 11-18.
2. Steam boiler flue gas measurement is shown in Figure 11-8 and Table 11-19.
3. Analysis of coal, ash, No. 6 fuel oil, DGO, special fuel oil and the hot oil is shown in Figure 11-9 and Table 11-20.
4. Flow rate of water from the well is shown in Table 11-21.
5. Flow rates of boiler feed water and coal consumption in boilers are shown in Table 11-21 and Figure 11-10.
6. Properties of boiler feed water and blowing drain are shown in Table 11-22.
7. Flow rates of water to each machine are shown in Figure 11-11.
8. Operating temperature of the hot oil heater is shown in Figure 11-12, and detail of the new hot oil heater system is shown in Figure 11-13.
9. Steam flow rates of each machine are shown in Table 11-23.
10. Surface temperatures of the steam line, hot oil line, boiler and hot oil heater are shown in Table 11-24.
11. Temperature and humidity in the factory are shown in Table 11-25.



Sample	Sample	Sample	Sample
1 No.1 Steam Boiler	5 No.4 Hot Oil Heater		
2 No.2 Steam Boiler	6 No.5 Hot Oil Heater		
3 No.3 Steam Boiler	7 No.6 Hot Oil Heater		
4 HO Heater for Calender Machine	8 the Newest Hot Oil Heater		




Figure 11-8 Sampling Points of Flue Gas

Table 11-18 Hot Oil Heater Flue Gas Measuring


Items	Hc	H3	H4	H5	H6	H <sub>New</sub>
Gas Chromato.						(7/9)
O <sub>2</sub> %				20.12	5.44	12.15
N <sub>2</sub> %				81.20	82.55	80.96
CH <sub>4</sub> %				--	--	--
CO %				--	--	0.06
CO <sub>2</sub> %				0.87	12.19	6.83
O <sub>2</sub> Analyzer				11.6	1.3	10.5
YOKOGAWA				260	241	(5/9)
Temp °C			(29/8) =>	328	301	270
Hodaka	(29/8)			(29/8)	(29/8)	(5/9)
Temp °C	148		257	339	319	279
O <sub>2</sub> %	11.4		5.7	6.6	3.8	11.6
CO ppm	16		25	40	34	179
CO <sub>2</sub> %	6.8		11.3	10.6	12.8	7.0
Eff. Gross	85.0		82.9	75 - 78	81.4	76.5
Eff. Net	90.0		88.0	80 - 81.2	86.4	80.9
λ %	122.3		37.5	46.2 - 50.4	21.5	124.7
Draft mbar	0.22		0.55	0.06 - 0.12	0.80	0.07 - 0.10
Remarks	On-Off Operation	Not Measured		Hodaka, Light Oil 30.1°C AT		Hodaka Heavy Oil

Hc --- Hot Oil Heater For 5 Cylinder Calendering Machine  
 On Time 1'18" - 1'25", Off Time 22" - 37"  
 H3 --- Hot Oil Heater For #3 Finishing Machine  
 H4 --- Hot Oil Heater For #4 Finishing Machine  
 H5 --- Hot Oil Heater For #4 Finishing Machine  
 H6 --- Hot Oil Heater For #5 Finishing Machine  
 H<sub>New</sub> --- The Newest Hot Oil Heater For Printing and Fixation Machines

Table 11-19 Steam Boiler Flue Gas Measuring

Items	B1	B2	B3	B4	B1
Gas Chromato.					
O <sub>2</sub> %	18.44	15.54	15.03		
N <sub>2</sub> %	82.46	82.40	80.96		
CH <sub>4</sub> %	0.006	--	--		
CO %	0.03	0.67	--		
CO <sub>2</sub> %	2.96	5.68	5.82		
O <sub>2</sub> Analyzer					
O <sub>2</sub> %	17.6 - 18.1	13.1 - 14.8	12.6 - 14.1		
YOKOGAWA	189	221	236		(3/9)
Temp °C	173	229	230	<=(29/8)	171
Hodaka	(29/8)	(29/8)	(29/8)		(3/9)
Temp °C	183	221	245		186
O <sub>2</sub> %	17.6	11.1	8.6		17.5
CO ppm	682	90	83		357
CO <sub>2</sub> %	2.4	7.0	8.7		3.1
Eff. Gross	61.6	80.9	81.7		63.7
Eff. Net	65.4	86.0	86.4		67.2
λ %	514.7	113 - 122	83.3		450
Draft mbar	9.5	9.4	8.2		9.4
Remarks				Not Operate	





Sample	Date	Sample Name
1	21/8	Coal for Boiler
2	21/8	Coal of Stock yard for Checking storage method
3	22/8	Ash of Steam Boiler, Details are shown below
4	21/8	No.6 Fuel Oil for the Newest Hot Oil Heater
5	21/8	Diesel Gas Oil for Inside Hot Oil Heater
6	21/8	Special Fuel Oil for Outside Hot Oil Heater 4 Unit
7	21/8	Hot Oil in Operation System ( BP Type : Transain )




Figure 11-9 Sampling Points of Coal, Ash and Oil

Table 11-20 Analysis Details (1/2)

	MRI	BATI	TPR	JICA-EIE LAB	CHUGAI	NOC
Coal for Steam Boiler	Elementary Industrial	Industrial	--	H.V., Moist.	CHN	CRN
Ash 1 (from Stoker)	CR.HV	CR.HV	--	H.V.	CHN	CHN
Ash 2 (from Intermid. Drum)	"	--	--	H.V.	--	--
Ash 3 (from Hot Drum Out.)	"	--	--	H.V.	--	--
Hot Oil	--	--	Sp.Gr.	--	--	Sp.Gr.
			Distillation			Distillation
			Viscosity			Viscosity
			Flash Point			Flash Point
No.6 Fuel Oil for H0 Heater	--	--	Spec	H.V.	--	Spec
Sp.Fuel Oil for H0 Heater	--	--	Data	H.V.	--	Data
Diesel Gas Oil for H0 Heater	--	--	--	H.V.	--	--

### Analysis Result of Solid Fuel

BATI Labo.

Sample	Moisture (%)	Volatile Mat. (%-dry base)	Fixed Carbon (%-dry base)	Ash (%-dry base)	HHV (kcal/kg)
Coal for Steam Boiler	16.58	39.49	47.80	12.71	6.179
Ash 1 (from Stoker)	--	--	3.39	--	--

JICA - EIE Labo.

Sample	HHV (kcal/kg)	LHV (kcal/kg)	Moisture (%)
Coal for Steam Boiler	5,780	5,400	0.187
Ash 1 (from Stoker)	145	--	--
Ash 2 (from Intermid. Drum)	2,238	--	--
Ash 3 (from Hot Drum Out.)	1,410	--	--

CHUGAI

Sample	Moisture (%)	Carbon (%-dry base)	Hydrogen (%-dry base)	Nitrogen (%-dry base)	Specific Heat @ 80 C	Specific Heat @ 130 C
Coal for Steam Boiler	18.2	59.9	4.6	1.33	--	--
Ash 1 (from Stoker)	33.7	4.6	0.4	0.09	--	--
Ash from Another Factory	--	--	--	--	0.22	0.23

Table 11-20 Analysis Details (2/2)

Analysis Result of Liquid Fuel

Sample	JICA - E/E Labo.							NOC									
	HHV (kcal/kg)	LHV (kcal/kg)	Density 15 C (g/cm <sup>3</sup> )	Flash Point (PM, C)	Vis @ 40 C (mm <sup>2</sup> /s)	HHV (kcal/kg)	Carbon (%)	Hydrogen (%)	Nitrogen (%)	Sulfur (%)	Density 15 C (g/cm <sup>3</sup> )	Flash Point (PM, C)	Vis @ 40 C (mm <sup>2</sup> /s)	HHV (kcal/kg)	Carbon (%)	Hydrogen (%)	Nitrogen (%)
No.6 Fuel Oil	10,110	9,500	0.9983	176	1,276	10,000	84.7	11.0	0.5	0.9983	176	1,276	10,000	84.7	11.0	0.5	3.44
So.Fuel Oil	10,800		0.9489	84	219.4	10,460	85.4	11.7	0.5	0.9489	84	219.4	10,460	85.4	11.7	0.5	2.26
DGO	11,080	10,300	0.8332	62	2.871	10,950	---	---	---	0.8332	62	2.871	10,950	---	---	---	0.62

Analysis Result of Hot Oil

Sample	TPR Labo.							NOC									
	HHV (kcal/kg)	LHV (kcal/kg)	Density 15 C (g/cm <sup>3</sup> )	Flash Point (PM, C)	Vis @ 40 C (mm <sup>2</sup> /s)	HHV (kcal/kg)	Carbon (%)	Hydrogen (%)	Nitrogen (%)	Sulfur (%)	Density 15 C (g/cm <sup>3</sup> )	Flash Point (PM, C)	Vis @ 40 C (mm <sup>2</sup> /s)	HHV (kcal/kg)	Carbon (%)	Hydrogen (%)	Nitrogen (%)
No.6 Fuel Oil	10,110	9,500	0.9983	176	1,276	10,000	84.7	11.0	0.5	0.9983	176	1,276	10,000	84.7	11.0	0.5	3.44
So.Fuel Oil	10,800		0.9489	84	219.4	10,460	85.4	11.7	0.5	0.9489	84	219.4	10,460	85.4	11.7	0.5	2.26
DGO	11,080	10,300	0.8332	62	2.871	10,950	---	---	---	0.8332	62	2.871	10,950	---	---	---	0.62

Sample	TPR Labo.							NOC																					
	Sp.Gr.	Flash Point, C	Vis @ 100C, cSt	Vis @ 40C, cSt	Distillation, C	IBP	HHV	Density 15 C	Flash Point (PM)	Vis @ 100C	Vis @ 40C	Distillation (Gaschromato.) (C)	IBP	HHV	Specific Heat @ 160 C	Specific Heat @ 170 C	Specific Heat @ 180 C	Specific Heat @ 190 C	Specific Heat @ 200 C	Specific Heat @ 210 C	Specific Heat @ 220 C	Specific Heat @ 230 C	Specific Heat @ 240 C	Specific Heat @ 250 C	Specific Heat @ 260 C	Specific Heat @ 270 C	Specific Heat @ 280 C	Specific Heat @ 290 C	Specific Heat @ 300 C
No.6 Fuel Oil	0.8783	202	5.79	35.91	315	315	0.8783	0.8777	200	5.739	35.34	327	327	0.586	0.595	0.604	0.613	0.622	0.630	0.638	0.646	0.654	0.662	0.670	0.677	0.685	0.692	0.699	
So.Fuel Oil	202	5.79	35.91	408	408	408	202	200	5.739	35.34	327	327	0.586	0.595	0.604	0.613	0.622	0.630	0.638	0.646	0.654	0.662	0.670	0.677	0.685	0.692	0.699		
DGO	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

These Values are estimated by process simulation PRO11, based on density and distillation data by NOC.

Table 11-21 Utility Water and Evaporated Steam Flow Rate


Date	Pump Up Water					Utility Water		Boiler Data		
	#1 Well ( m3 )	#2 Well ( m3 )	#4 Well ( m3 )	#7 Well ( m3 )	Total ( m3 )	Hard ( m3 )	Soft ( m3 )	Steam ( ton )	Coal ( kg )	Coal/Steam ( kg/ton )
26/8/96	138	407	1,814	2,751	5,110	340	3,000	234	32,760	140.0
27/8/96	134	43	1,678	2,652	4,507	900	3,130	230	32,760	142.4
28/8/96	137	1,295	1,200	1,209	3,841	530	1,990	180	22,680	126.0
29/8/96	130	67	1,734	2,891	4,822	600	3,030	244	32,340	132.5
30/8/96	131	345	1,980	2,523	4,979	1,110	3,060	243	31,920	131.4
31/8/96	131	394	1,828	2,615	4,968	1,270	2,800	270	32,760	121.3
1/9/96						800	1,890			

Steam flow contains  
recovered condensate.

#1 Well Depth : 53 m , Pump Elevation : 30 m  
 #2 Well Depth : 144 m , Pump Elevation : 35 m  
 #4 Well Depth : 199 m , Pump Elevation : 55 m  
 #7 Well Depth : 199 m , Pump Elevation : 55 m

Utility Water Flow Counter Reading Value

Date	Pump Up Water				
	#1 Well ( m3 )	#2 Well ( m3 )	#4 Well ( m3 )	#7 Well ( m3 )	Total ( m3 )
26/8/96	40,200	389,463	761,750	408,797	
27/8/96	40,338	389,870	763,564	411,548	
28/8/96	40,472	389,913	765,242	414,200	
29/8/96	40,609	391,208	766,442	415,409	
30/8/96	40,739	391,275	768,176	418,300	
31/8/96	40,870	391,620	770,156	420,823	
1/9/96	41,001	392,014	771,984	423,438	



Always 2 Drums are used.  
Another 2 are stand-by Drums.

Figure 11-10 Detail of Boiler Feed Water and Utility System

Table 11-22 Properties of Feed Water, Blowing Drain

Date: Sep.10/1996

Boiler Water Analysis

	Raw Water	Soft Water	Make-up Water	Condens. Drum	Feed Water	Boiler				Hot Wat. Boiler	Condens. Recovery	Recommended Limit	
						No.	No.1	No.2	No.3			BFW	Blowing Drain
Total Hardness ppm CaCO		1.8			1.7		7.8	2.5	3.0			max. 2.0	--
Phenol Alkaline ppm CaCO		0			0		578	680	1,240			--	--
Total Alkaline ppm CaCO		306			290		940	1,100	1,673			--	max. 1,500
Hydroxide Alkaline ppm CaCO		0			0		216	260	807			--	--
Chloride ppm Cl		45.5			47.3		121	173	196			--	max. 1,000
Phosphate ppm PO <sub>4</sub> <sup>3-</sup>		/			0.89		8.10	11.95	12.0			--	5 - 10
DEHA ppm		/			0.39		0.165	0.135	0.08			--	0.2 - 0.4
Phosphonate ppm PO <sub>4</sub> <sup>3-</sup>		/			0.30		3.20	4.75	4.80			--	3 - 5
Total Iron ppm Fe		/			0.10		3.80	2.35	1.00			max. 0.1	max. 10.0
Sulphate ppm SO <sub>4</sub> <sup>2-</sup>		/			/		/	/	/			--	--
Silicate ppm SiO <sub>2</sub>		/			/		/	/	/			--	--
Conductivity micro-S/cm		631			596		2,380	3,930	6,580			--	max. 7,000
PH		7.4			8.0		11.5	11.8	12.0			--	10.5 - 12

Boiler Operation Information

Feed Water Temperature	95 - 105 C
Condensate Recovery Rate, %	Maximum 10 %
Blowdown	According to Conductivity




Figure 11-11 Water and Steam System

[ ] Hot Oil Heat Using Machine  
 [ ] Temperature, C  
 [ ] Pressure, bar  
 [ ] Flow Rate, kg/hr




Figure 11-12 Operation Temperature of Hot Oil Heater






Figure 11-13 Detail of the New Hot Oil Heater System

Table 11-23 Steam Flow Rate

	Estimate	Design	Meas. 1	Meas. 2	Meas. 3	Meas. 4
Supply	(9,680)					
No.1, 2, 3 Boiler						
Main Line	(8,780)		3,400	3,800	2,210	
Open Width Bleaching	1,750		2,200	Op.	Op.(Ex.-Stop)	Stop
Rope Bleaching	1,250		Stop	Stop	Stop	Stop
Drying	900		Stop	Stop	Stop	Stop
Mercerization	600		Stop	Op.	Op.	Stop
Max Goller (New Washing)	1,500	1,500	Stop	Op.	Stop	1,440 -- 1,710
Old Washing	1,600		Stop	Stop	Stop	Stop
Fixation Steamer			Stop	Stop	Stop	Stop
Mini Flash Ager			Stop	Stop	Stop	Stop
Flash Ager	300		Stop	Stop	Stop	370 (272)
No.1 Dyeing Foulard	150		Stop	Op.	Op.	Stop
No.2 Dyeing Foulard			Stop	Op.	Op.	Stop
No.3, 4, 5, 6 Fixation			Stop	Stop	Stop	Stop
Jigger	600		2/5 Op.	Stop	Stop	Stop
Raising	130		Stop	Stop	Stop	Stop
Boiler	900		Op.	Op.	Op.	Op.

(Unit: kg/hr)

Table 11-24 Surface Temperature of Steam, Condensate and Hot Oil System

No.	Measuring Position		Temperature (°C)	Remarks
	Facility	Location		
1	#1 Steam Boiler	Drum ( 2nd Floor )	50 - 65	Insulated
		Manhole ( 2F )	71	Brick part
		Door of Looking Window (2F)	148	Bare
		Steam Outlet Header ( Top )	152	Bare
		Ash ( 1st Floor, Ground )	35	Ash Holder from Stoker
2	Steam Line	Main Header in Boiler Room ( 2nd Floor )	146 - 160	Bare, Mainly Valve
		Outlet to Factory ( 1F )	41	Insulated (Glasswool 80mm)
		Inlet from Boiler	39	Insulated
		Main Line, By-pass Point	39	Insulated
			155	Bare
6	Condensate	Condensate Receiver	52	Insulated (Glasswool 110mm)
		Condensate Pump	42	Insulated
		Condensate Line	90	Bare
8			87	Bare
			44 - 50	Insulated (Glasswool 40mm)
9	#5, #6 HO Heater	Burner Side	160 - 190	Bare
		Back Side	150 - 180	Bare
		Cylinder Body	50 - 60	Insulated
10	New HO Heater	Burner Side	150 - 180	Bare
		Back Side	160 - 190	Bare
		Cylinder Body	50 - 60	Insulated
11	Hot Oil Line	Inlet to #5 Finish.Machine	46 - 48	Insulated (Glasswool 60mm)
		Outlet from #5 Finish Line	40	Insulated (Glasswool 60mm)
12		Inlet to #5 Finish.Machine	114	Bare
			47	Insulated
13		Inlet to #5 Finish.Machine	167	Bare
			53	Insulated
14		Outlet from #5 Finish Line	132	Bare
			46	Insulated





Table 11-25 Temperature and Humidity in the Factory

30. Aug 09:15

Fine Weather

No.	Measuring Position	Temperature °C	Humidity %
1	Outside of Factory	27.5	51.5
2	NIPCO Calendering machine	29.3	46.3
3	Between #5 & #6 Finishing Machines	37.3	36
4	Foulard	33.4	44.5
5	Between New & Old Washing Machines	32.5	44
6	Between #3 & #4 Finishing Machines	33.6	34
7	Between New & Old Fixation Machines	33.8	38.3
8	Carsat Calendering Machine	32.4	37.6
9	5 Cylinder Calendering Machine	32.4	40
10	Jigger Machines	32.1	41
11	Between #3 & Zimmer Printing Machines	33.7	45
12	Between #2 & #4 Printing Machines	32.3	47
13	Between #1 & #2 Printing Machines	32	38
14	Between Mercerise & Open Width Bleaching Mach.	30	52
15	Singeing Machine	28	52
16	Products Inspection Room	28.3	48
17	#1 Steam Boiler ( 2F )	32	40
18	#3, #4 Hot Oil Heater House	33.4	40
19	#5, #6 Hot Oil Heater House	31	42



#### 11-9-4 Steam Boiler

##### (1) Measurement of Operating Condition

1. Flue gas temperature, °C: between 173 and 245, a large fluctuation
2. O<sub>2</sub> in flue gas, percent: 8.6 to 18.1, a large fluctuation

The content of O<sub>2</sub> in the flue gas is very high. This means that the amount of air supply is too much and air may leak into the boiler combustion chambers.

3. Low heating value of coal and ash, kcal/kg:

Coal	4,385
Ash	488

These values were obtained from the equations and the analytical values shown below.

4. Draft at IDF inlet, mbar: 9.5

Remark: Low heating value estimation of coal and ash

(1)	Coal				
1.	JICA-EIE Laboratory's analysis data				
	High heating value, kcal/kg-dry base		5,780		
	Moisture, weight fraction		0.187		
2.	Chugai Laboratory's element analysis (left side)				
	Moisture, wt %	18.2	Left side data	Moisture, wt %	18.2
	Carbon, wt %-dry base	59.9	give	Carbon, wt %	49.0
	Hydrogen, wt %-dry base	4.6	break down	Hydrogen, wt %	3.8
	Nitrogen, wt %-dry base	1.33	(right side)	Nitrogen, wt %	1.1
	Others, wt %-dry base	(34.17)		Others, wt %	27.9
3.	$\begin{aligned} \text{LHV} &= \text{HHV} - 600 \times (9 \times h + W) \\ &= 5780 \times (1 - 0.187) - 600 \times (9 \times 0.038 + 0.182) \\ &= 4699 - 314 \\ &= 4385 \end{aligned}$ <p style="margin-left: 100px;">                     LHV: Low heating value, kcal/kg-wet base                      HHV: High heating value, kcal/kg-wet base                      h : Hydrogen weight fraction in coal                      W : Moisture weight fraction in coal                 </p>				
(2)	Ash from stoker				
1.	Chugai Laboratory's element analysis				

	Moisture, wt %	33.7
	Carbon, wt %-dry base	4.6
	Hydrogen, wt %-dry base	0.4
	Nitrogen, wt %-dry base	0.09
2.	$\begin{aligned} \text{LHV} &= 8,100 \times C + 29,000 \times h \\ &= 8,100 \times 0.046 + 29,000 \times 0.004 \\ &= 488 \end{aligned}$	
	LHV and h are same as above and C is carbon fraction in ash.	

## (2) Approximate Heat Balance

### 1) Heat Input

	Item	Value	Unit
(1)	Coal		
	Amount of combustion	1,200	kg/h
	Heating value	4,385	kcal/kg
	Heat of combustion	5.26	$10^6$ kcal/h
(2)	Water		
	Flow rate	8.38	tons/h
	(Condensate return: assumed to be zero)		
	Temperature	103	$^{\circ}\text{C}$
	Heat input	0.86	$10^6$ kcal/h
(3)	Air		
	Theoretical air rate <sup>*1</sup>	5.37	$\text{m}^3/\text{kg}$
	Air ratio ( $\text{O}_2\%$ in flue gas 11.1% taken)	2.12	
	Amount of air	13,660	$\text{m}^3/\text{h}$
	Inlet temperature of air	30	$^{\circ}\text{C}$
	Specific heat of air	0.32	$\text{kcal}/\text{m}^3 \text{ } ^{\circ}\text{C}$
	Heat input	0.13	$10^6$ kcal/h
(4)	Soot blow steam		
	Flow rate	0.075	tons/h
	Heat input	0.05	$10^6$ kcal/h
(5)	Total input heat	6.30	$10^6$ kcal/h

## 2) Heat Output

Item	Value	Unit
(1) Steam		
Flow rate	6.80	tons/h
Pressure	7	Kg/cm <sup>2</sup>
Enthalpy	660	kcal/kg
Heat output	4.49	10 <sup>6</sup> kcal/h
(2) Flue gas		
Theoretical flue gas rate <sup>2</sup>	5.82	m <sup>3</sup> /kg
Amount of flue gas <sup>3</sup>	14,200	m <sup>3</sup> /h
Temperature, (taken)	221	°C
Specific heat of flue gas, (assumed)	0.33	kcal/m <sup>3</sup> °C
Heat output	1.04	10 <sup>6</sup> kcal/h
(3) Ash		
Disposal rate <sup>4</sup>	134	kg/h
Temperature, (taken)	60	°C
Specific heat, (assumed)	0.2	kcal/kg °C
Low heating value	488	kcal/kg
Heat output	0.07	10 <sup>6</sup> kcal/h
(4) Blow down water		
Flow rate	1.58	tons/h
Temperature	169	°C
Heat output	0.27	10 <sup>6</sup> kcal/h
(5) Heat loss from wall and others		
Assumed	0.43	10 <sup>6</sup> kcal/h
(6) Total heat output	6.30	10 <sup>6</sup> kcal/h

## 3) Boiler Efficiency

As a result, the boiler efficiency is calculated as shown below.

Steam output heat/total input heat	71.3	percent
------------------------------------	------	---------

Note\*1 Theoretical air rate

$$\begin{aligned}
 A_0 &= 100/21 \times (c/12 \times 22.4 + h/2 \times 11.2 - o/32 \times 22.4 + s/32 \times 22.4) \\
 &= 100/21 \times (0.49/12 \times 22.4 + 0.038/2 \times 11.2 + 0 + 0) \\
 &= 100/21 \times (0.915 + 0.213)
 \end{aligned}$$

$$= 5.37$$

values of c, h, n and w are from Chugai analysis data

Note\*2 Theoretical flue gas rate

$$\begin{aligned} G_0 &= A_0 + h/2 \times 11.2 + w/18 \times 22.4 + o/32 \times 22.4 + n/28 \times 22.4 \\ &= 5.37 + 0.038/2 \times 11.2 + 0.182/18 \times 22.4 + 0 + 0.011/28 \times 22.4 \\ &= 5.82 \end{aligned}$$

Note\*3 Amount of flue gas

$$\begin{aligned} G &= G_0 + (m - 1) \times A_0 \\ &= 5.82 + (2.12 - 1) \times 5.37 \\ &= 11.83 \end{aligned}$$

$$11.83 \text{ (Nm}^3\text{/kg-coal)} \times 1,200 \text{ (kg-coal/h)} = 14,200$$

Note\*4 Disposal rate

$$\begin{aligned} \text{Ash} &= 1,200 \times (100 - 16.58)/100 \times 12.71/100 \times 100/(100 - 4.6 - 0.4 - 0.09) \\ &= 134 \end{aligned}$$

16.58 is moisture wt % and 12.71 is ash wt % (dry base), together from Bati Cement Laboratory data



## 11-9-5 Steam Balance

### (1) Outline

There is no steam flow meter on the supplier side (boiler outlet) and user side (each machine inlet) except for the flash ager in the factory. For this audit, two pieces of steam flow measuring equipment were installed, one on the main steam line and the other at the inlet to the open width bleaching machine, the largest steam consumer of the factory. Steam flows were measured for groups of subject machines as shown in Table 11-23.

### (2) Steam Balance, tons/hour

The steam balance of boilers was calculated as below.

1. Generation, tons/hour	
Boiler feed water	8.38
Blowdown	1.58
Steam evaporated	6.80
2. Consumption, tons/hour	
Degasifier	1.70
Soot blower	0.08
Fuel oil heater	0.40
Open width bleaching machine	2.20
Flash ager	0.37
Max Goller washing machine	1.58
Other machines	0
(Valves were closed at branch line from main line.)	
Others (end users, heat losses, unaccounted-for losses)	0.47
Total	6.80

## 11-9-6 Hot Oil Heater

### (1) Main Operation Condition of the New Hot Oil Heater

The main operation condition of the new hot oil heater is given below.

Item	Value	Unit
(1) Flow rate of hot oil	300	kl/h
(2) Temperature of hot oil		
Inlet	240	°C
Outlet	250	°C
Temperature difference	10	°C
(3) Properties of hot oil heater		
Specific gravity	0.8783	
Specific heat	0.45	kcal/kg °C
(4) No. 6 fuel oil combustion rate	4	tons/d
(5) Properties of No. 6 fuel oil		
Low heating value	9,600	kcal/kg
Specific heat	0.48	kcal/kg °C
(6) Inlet temperature of No. 6 fuel oil at the burner	100	°C
(7) Flue gas temperature		
Outlet of combustion chamber	300	°C
Outlet of flue gas-air exchanger	--	
(8) Flue gas specific heat	0.34	kcal/Nm <sup>3</sup> °C
(9) O <sub>2</sub> % in flue gas	11	%
(10) Temperature of air		
Inlet of flue gas-air exchanger	35	°C
Inlet of combustion chamber	90	°C
(11) Specific heat of air	0.32	kcal/Nm <sup>3</sup> °C

### (2) Approximate Heat Balance Calculation of the New Hot Oil Heater

#### 1) Heat Input

Item	Value	Unit
(1) Heat of combustion of No. 6 fuel oil	1.608	10 <sup>6</sup> kcal/h
(2) Input heat of No. 6 fuel oil	0.008	10 <sup>6</sup> kcal/h

(3) Input heat of Air		
Air ratio	2.1	
Theoretical air rate, Assumed	10.58	Nm <sup>3</sup> /kg
Amount of air	3,700	Nm <sup>3</sup> /h
Input heat	0.106	10 <sup>6</sup> kcal/h
(4) Input heat of hot oil	28.457	10 <sup>6</sup> kcal/h
(5) Total input heat	30.233	10 <sup>6</sup> kcal/h

## 2) Heat Output

	Item	Value	Unit
(1)	Output heat of hot oil	29.643	10 <sup>6</sup> kcal/h
(2)	Output heat of flue gas		
	Theoretical flue gas rate, Assumed	11.29	Nm <sup>3</sup> /kg
	Amount of flue gas	3,821	Nm <sup>3</sup> /h
	Output heat	0.390	10 <sup>6</sup> kcal/h
(3)	Wall loss and others	0.146	10 <sup>6</sup> kcal/h
(4)	Total output heat	30.233	10 <sup>6</sup> kcal/h

## 3) Recovery Heat by the Flue Gas-Air Exchanger

Recovery heat by air side	0.065	10 <sup>6</sup> kcal/h
---------------------------	-------	------------------------

## 4) Efficiency of the Hot Oil Heater

Item	10 <sup>6</sup> kcal/h	Item	10 <sup>6</sup> kcal/h	Percent
Input side		Output side		
Combustion heat	1.608	Net received heat of hot oil	1.186	68.9
Fuel oil input heat	0.008	Flue gas output	0.390	22.6
Air input heat	0.106	Net release heat	0.325	18.8
Fresh air input heat	0.041	Recovery heat	0.065	3.8
Recovery heat	0.065	Heat release from wall	0.146	8.5
Total input heat	1.722	Total output heat	1.722	100

The calculated efficiency is 68.9 percent.

### 11-9-7 Audit of Steam Line, Hot Oil Line and Condensate Recovery Line

The result of the audit on the above subjects may be summarized as follows:

1. The main lines of steam, hot oil and condensate are insulated. These are designed and fabricated adequately, and maintained in good conditions.
2. Small steam pipe lines to the end steam users are sporadically not insulated.
3. The insulation is of either glass wool or rock wool, from 50 to 90 millimeters thick covered by thin steel plate.
4. Measured surface temperatures of the steam lines, hot oil lines and condensate lines at typical points are as follows. (Unit: °C)

Steam line:	Uninsulated pipe	155
	Insulated pipe	52
Hot oil line:	Uninsulated pipe	167
	Insulated pipe	53
Condensate line:	Uninsulated pipe	91
	Insulated pipe	50

5. Measures to prevent heat losses from lines are to determine the effect of insulation on the valves and flanges in the main steam lines and hot oil lines, to watch and prevent leaks of hot oil and steam using an appropriate device, and to conduct good maintenance and adequate repairing of the insulation on the small-sized steam lines, lines supplying steam for room heating, for example.

### 11-9-8 Steam Trap

#### (1) Drain Pit

Steam traps are immersed in hot water in pits. The pits should not hold hot water. Devices to remove hot water are needed. Such devices are preferably equipped with automatic on-off switches, effective in keeping the water levels low. The condensed water recovery line in this section is not insulated.

#### (2) Drying

The steam line in the drying machine leaks at flanges and bonnets. These leaks should be stopped.

### **(3) Rope Bleaching**

#### **1) Steam Trap System**

Steam traps are needed at several points: points on the steam main line from where the line goes up, drain lines before temperature control valve passing through the wall to the sewer in the road, drain line before temperature control valve at the inlet of each machine and at the end of the steam main line.

#### **2) Block Valve**

Block valves are normally needed upstream of steam traps in the main steam line for maintenance of the steam traps. This practice may not be needed for this section, because the machine operates intermittently according to the operation plan. There is ample opportunity for maintenance. This is true with other machines in the factory.

#### **(4) Mercerizing**

It is needed to install a steam trap upstream of the depressurizing control valve.

#### **(5) Check Valves before Rising Lines**

It is necessary to install a check valve downstream of the steam trap in the case where the condensate recovery line goes to a higher position.

#### **(6) Jigger**

It is needed to install a steam trap at the end of the steam main line.

#### **(7) Flash Ager and Max Goller Washing**

There is some steam leakage from the flange of the piping at upper section of the Flash Ager. It is necessary to install a check valve downstream of the steam trap in the condensate recovery line.

#### **(8) Outline of the Steam Trap Audit**

Only a small number of steam traps operated under the design conditions when the measurement was done. Most steam traps operated under conditions which were deviated from the designs, notably to lower temperatures, because machines operated according to the production plan not to the design, many of them at lower temperatures attained by throttling the steam valves. The equipment for diagnosis of steam traps the study team brought along showed:

1. A few steam traps: Good operation
2. One steam trap: Blowing

- 3. Many steam traps: Low temperature
- 4. Many steam traps: Blocked out

The results of the steam trap audit are shown in Table 11-26, an output report of the equipment for diagnosis, and Table 11-27, the code list for the abbreviations used in Table 11-26. Figure 11-14 indicates locations of steam traps and their area numbers.

Table 11-26 Result of the Steam Trap Audit (1/2)

STEAM TRAP MANAGEMENT LOG DETAILS

By Area Trap Number

FILE : IBF

AREA NO.	TRAP NO.	APPL. I/O	MODEL	PRESS (kg)	TEST RSLT	SURF TEMP	STEAM LOSS	INSTAL DATE	OP. HOURS	RCMD MODEL
		PRTY COND RCRY	SIZE	SAT. TEMP	LEAK LEV	SET TEMP	kg/hr \$/year	INSPEC DATE	OP. DAYS	@STEAM \$/ton
		EQUIPMENT	CONN	BACK (kg)	PREV. RSLT	INSP LOSS	COND. RATE	NEXT		REMARKS
002	00010		S-THERMO 0	3.8 150	BLK 0	31 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
002	00020		THERMO 0	3.8 150	I/C 0	53 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
002	00030		THERMO 0	3.8 150	I/C 0	67 0	>0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
002	00040		THERMO 0	3.8 150	I/C 0	78 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
002	00050		THERMO 0	3.8 150	BLK 0	36 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
002	00060		THERMO 0	3.8 150	BLK 0	39 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
002	00070		THERMO 0	3.8 150	I/S 5	103 0	3.9 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
002	00080		THERMO 0	2.5 139	BLK 0	32 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
002	00090		THERMO 0	0.0 0	NCH 0	0 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
005	00010		THERMO 0	2.3 137	I/C 0	65 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
006	00010		THERMO 0	2.3 137	GOOD 0	90 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
006	00020		THERMO 0	2.3 137	I/C 0	51 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
008	00010		THERMO 0	3.5 117	I/C 0	10 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			
008	00020		THERMO 0	3.5 117	BLK 0	39 0	0.0 0	090696 0999	0 0	0.00
			PT	0.0	NCH	0	0.0			

<CONTINUE>

Table 11-26 Result of the Steam Trap Audit (2/2)

STEAM TRAP MANAGEMENT LOG DETAILS

By Area Trap Number

FILE : IBF


AREA NO.	TRAP NO.	APPL	I-O	MODEL	PRESS (kg)	TEST RSLT	SURF TEMP	STEAM LOSS	INSTAL DATE	OP. HOURS	RCMD MODEL
		PRTY	COND RCRY	SIZE	SAT. TEMP	LEAK LCV	SET TEMP	kg/hr \$/year	INSPEC DATE	OP. DAYS	@STEAM \$/ton
		EQUIPMENT		CONN	BACK (kg)	PREV. RSLT	INSP. LOSS	COND. RATE	NEXT	REMARKS	
008	00030			THERMO 0	3.5 147	L/C 0	53 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00040			THERMO 0	3.5 147	L/C 0	65 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00050			THERMO 0	3.5 147	L/C 0	56 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00060			THERMO 0	3.5 147	L/C 0	59 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00070			THERMO 0	3.5 147	L/C 0	61 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00080			THERMO 0	3.5 147	L/C 0	45 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00090			THERMO 0	2.5 139	L/C 0	17 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00100			THERMO 0	3.5 147	L/C 0	13 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00110			THERMO 0	3.5 147	BLW 15	98 0	11.1 0		0 0	0.00
				PT	0.0	NCH	0	0.0	0999		
008	00120			THERMO 0	63.5 273	L/C 0	123 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
008	00130			THERMO 0	3.5 147	L/C 0	61 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			
100	00010			THERMO 0	2.5 139	GOOD 0	81 0	0.0 0	090696 0999	0 0	0.00
				PT	0.0	NCH	0	0.0			

Remark Reference the Code List



Table 11-27 Code List of Steam Trap Audit

Item	Code	Abbreviation used	Meaning
Application	0	DRIP	Drip
	1	PROC	Process
	2	TRCR	Tracer
	3	HEAT	Heating
	4	C-DRYER	Cylinder Dryer
Priority	1	MOST	Most Important
	2	IMP	Important
	3	GENR	General
	4	AUX	Auxiliary
Location/ Elevation	0	O-LW	Outdoor Low
	1	I-LW	Indoor Low
	2	O-HG	Outdoor High
	3	I-HG	Indoor High
Condensate Recovered	0	NO	No (To drain)
	1	YES	Yes (Returned)
Mode of Operation	0	CONTINUOUS	Continuous
	1	BATCH	Batch
	2	PROC.C.	Proportional Control
Connection	00	PT	08 40kRF 16 63kRF 24 125lbRF
	01	SW	09 5kRF 17 125lbFF 25 150lbRF
	02	Other	10 10kRF 18 150lbFF 26 250lbRF
	03	5kFF	11 16kRF 19 250lbFF 27 300lbRF
	04	10kFF	12 20kRF 20 300lbFF 28 400lbRF
	05	16kFF	13 30kRF 21 400lbFF 29 600lbRF
	06	20kFF	14 40kRF 22 600lbFF 30 900lbRF
	07	30kFF	15 60kRF 23 900lbFF 31 1500lbRF
Test Result	01	BLW	Blowing
	02	L/L	Leak / Large
	03	L/M	Leak / Medium
	04	BLK	Blocked
	05	NSV	Not in Service
	06	L/C	Low Temp
	07	L/S	Leak / Small
	08	GOOD	Good
	09	ADJ	Adjustment Failed
	10	L/G	Leak / Gasket
	11	L/B	Leak / Body
	12	NCH	Not checked
	13		Not installed



Area Number	Area
011	Rope Bleaching Range
001	Drying Machine
002	Open Width Bleaching Range
003	Mercerization
004	Raizing Machines
005	Jiggers
006	Mini Flash Ager
007	Fixation
008	Max Coller Washing, Flash Ager
009	Old Washing Range
100	New Hot Oil Heater

Trap Number




Figure 11-14 IBF Steam Trap Location Diagram

### 11-9-9 Electricity

Electricity measurements were done at each transformer and the points shown in Table 11-28. The power meter was read continuously at the factory entrance. Figure 11-15 gives the measured total electric load of the factory. During the last several years, distribution of electrical loads was changed and some saving of energy and money was realized. Peak power load was reduced. Consequently, the demand agreement with the City Electric Company was reduced from 2,500 kW to 2,100 kW. Figure 11-15 shows that the peak demand is below 1,900 kW.

The saving cost of electricity was as shown below.

Year	1991	1992	1993	1994	1995
Million TL/year	60	266	440	907	1,000

Table 11-29 shows the meter readings on each transformer read every morning during the audit period. Data on electricity of the main facilities such as open width bleaching, Max Goller washing range, hot oil heaters, and steam boilers, were measured by the energy analyzer connected to the line at the transformer or the local panel. In the case of steam boilers, the energy analyzer was connected after the connecting point of Nos. 2 and No. 3 transformers. Figure 11-16 shows the variation of electric load of the machines with time. Table 11-30 summarizes the results of measurements. Table 11-30 also shows estimated operating rates of the facilities.

**Table 11-30 Electricity Consumption on Main Facilities**

Facility	Current A	Power Factor	Power kW	Operating Rate, %
Open Width Bleaching	15 - 119	0.52 - 0.54	9 - 44	about 70
Rope Bleaching	4 - 61	0.29 - 0.83	1 - 37	about 50
Max Goller Washing	5 - 85	0.56 - 1.00	2 - 34	less than 30
ATLAS Compressor	56 - 135	0.54 - 0.89	22 - 77	about 50
#4 Finishing Machine	16 - 281	0.41 - 0.75	5 - 130	more than 80
#6 Finishing Machine	21 - 148	0.42 - 0.81	8 - 65	about 70
#3 Printing Machine (Stork 3)	6 - 244	0.61 - 0.95	4 - 127	-
#4 Printing Machine (Stork 4)	2 - 239	0.46 - 0.83	1 - 132	-

#5 Printing Machine (Zimmer)	9 - 278	0.45 - 1.00	6 - 125	-
New Hot Oil Heater	119 - 168	0.80 - 0.88	71 - 98	about 60
#1, #2, #3 Steam Boilers	82 - 159	0.62 - 0.76	38 - 67	almost Full


---

Table 11-28 IBF Electric Measuring

	Machine	Schematic Position	Measuring Location	Measuring Time	
				Period	Interval
1	Receiving Electricity	Up of Trans	Receiving Meter Room	2/Sep.10:15 - 4/Sep. 14:15	1 hr
2	Open Width Bleaching	GT 3-3/A	Out of #4 Transformer	29/Aug.9:54 - 29/Aug.15:39	5 min
3	Rope Bleaching	GT 1-5/4	Local Panel	3/Sep. 9:53 - 4/Sep. 12:15	5 min
4	Max Goller Washing	GT 2-3/5	Local Panel	2/Sep.10:43 - 3/Sep. 14:37	5 min
5	ATLAS Compressor	GT 3-6/3	Local Panel	4/Sep.13:56 - 4/Sep. 17:06	1 min
6	#4 Finishing Machine	GT 1-2/2	Local Panel	4/Sep.16:35 - 5/Sep. 16:29	5 min
7	#6 Finishing Machine	GT 3-5	Out of #4 Transformer	3/Sep.14:53 - 4/Sep. 16:13	5 min
8	#3 Printing Machine (Stork3)	GT 3-7/1	Out of #4 Transformer	27/Aug.9:19 - 27/Aug.15:19	1 hr
9	#4 Printing Machine (Stork4)	GT 3-6/1	Out of #4 Transformer	4/Sep.11:23 - 4/Sep. 17:53	30 min
10	#5 Printing Machine (Zimmer)	GT 1-6	Local Panel	2/Sep.16:29 - 3/Sep. 2:28	30 min
11	New Hot Oil Heater	GT 3-8/1	Out of #4 Transformer	5/Sep.13:51 - 6/Sep.15:10	5 min
12	#1, #2, #3 Steam Boilers	GT 2-1	Out of #2 & #3 Transformer	5/Sep.17:05 - 6/Sep.16:35	5 min

Measuring Instrument

- 1 : Power Meter
- 2, 3, 4, 5, 6, 7, 12 : VIP MK3 ENERGY ANALYZER, Made by ELCONTROL in Italy (EIE's Analyzer)
- 8, 9, 10, 11 : MICROVIP 3 3-Phase energy analyzer, Made in Italy by ELCONTROL (IBF's Analyzer)






Figure 11-15. Total Electric Load of the Factory  
(from 2nd to 4th of September)

Table 11-29 Efficiency of Receiving Transformer

Measured at 9:00 every day

Day	A11			A12			A13			Total Power (kW)				
	#1 Transformer Voltage (V)	#1 Transformer Current (A)	#1 Transformer P. Factor (-)	#2 Transformer Voltage (V)	#2 Transformer Current (A)	#2 Transformer P. Factor (-)	#3 Transformer Voltage (V)	#3 Transformer Current (A)	#3 Transformer P. Factor (-)		#4 Transformer Voltage (V)	#4 Transformer Current (A)	#4 Transformer P. Factor (-)	
28 Aug.	385	200	0.91	385	300	0.98	385	300	0.97	385	1250	0.93	775	1287
29 Aug.	Transformer Breakdown													
30 Aug.	385	550	0.90	385	280	0.93	385	280	0.98	385	1300	0.91	779	1465
31 Aug.	400	400	0.93	400	180	0.92	400	180	0.55	380	1200	0.92	727	1168
1 Sep.	380	150	0.95	380	300	0.96	380	240	0.97	380	1000	0.99	652	1088
2 Sep.	375	400	0.94	375	280	0.95	375	240	0.98	375	925	0.99	595	1165
3 Sep.	380	550	0.91	380	270	0.98	380	260	0.98	400	1200	0.99	823	1494
4 Sep.	390	110	0.93	385	270	0.95	390	260	0.98	370	1100	0.95	670	1082
5 Sep.	380	550	0.91	385	270	0.93	385	280	0.98	370	1400	0.95	852	1532
6 Sep.	390	110	0.93	385	300	0.93	385	300	0.98	385	1400	0.99	924	1375
7 Sep.	400	100	0.91	400	200	0.93	400	200	0.99	400	1200	0.95	790	1119
8 Sep.	395	325	0.92	390	240	0.93	397	250	0.98	340	1050	0.95	587	1111

Power = Sqrt(3) x Voltage x Current x (Power Factor) / 1000





Figure 11-16 Electric Load of Main Facilities (1/3)







Figure 11-16 Electric Load of Main Facilities (2/3)





Figure 11-16 Electric Load of Main Facilities (3/3)

## 11-10 Energy Flowchart for Factory and Major Energy Consuming and Supply Facilities

### 11-10-1 Energy Flowchart for Factory

Total energy consisting of fuel, such as coal, No. 6 fuel oil, special fuel oil, diesel gas oil and LPG, and electricity was used in all facilities in the factory from January to August 1996 as shown in Table 11-31. Their percentages show the features of energy flow in the factory.

The heat consumption by IBF may be compared with that of a certain Japanese factory as follows. Keeping in mind the notes described in Section 11-14-4, the study team made a table of comparison, Table 11-32, using the available data of unit heat consumption of the Japanese factory (Refer to Tables 11-44, 11-45 and 11-47).

The results show that IBF's unit heat consumption is better than the similar Japanese factory in the two processes.

1. Total value of the scouring, bleaching, mercerization and drying processes

The main reason would be that presently IBF is doing the so-called "wet on wet system," doing without unnecessary drying processes. If IBF emphasized heat recovery, the values of EN in Table 11-32 would show that there is an ample room to reduce heat consumption.

2. Printing and fixing process

The data available in Japan are those for flat screen printing; IBF is operating rotary screen printers. This partly explains the difference.

Granting that the IBF and the Japanese factory would be different, the IBF's present unit heat consumption is fairly good, as shown in Table 11-32. Nevertheless, as shown by the results of the present energy audit and the values of EN in Table 11-32, IBF leaves ample room for reducing energy consumption.

Table 11-31 Energy Flowsheet of the Factory

Input	Fuel						Sub Total	Electricity	Energy Total	
	Coal	No.6 Fuel Oil	Special Fuel Oil	Diesel Gas Oil	LPG					
ton or 10 <sup>3</sup> kWh	8,063	586	2,021	77	70	---	7,533			
10 <sup>6</sup> kcal	35,350	5,630	19,400	750	770	---	6,480			
Energy Conversion Efficiency (%)	4.49/5.26	1186/1608	73.8	(73.8)	100					
Energy Consuming Facility	Steam		Hot Oil		LPG					
	kg/h		10 <sup>6</sup> kcal		10 <sup>6</sup> kcal		10 <sup>6</sup> kcal	10 <sup>6</sup> kcal		
	(%)		(%)		(%)		(%)	(%)		
Singeing	---	---	---	---	770	---	40	810		
					(1.5)		(0.6)	(1.4)		
Open Width Bleaching	4,200	---	---	---	---	---	370	13,500		
Rope Bleaching	(43.5)						(5.7)	(23.9)		
Jigger, Mercerization										
Drying	900	---	---	---	---	---	30	2,840		
	(9.3)						(0.5)	(5.0)		
Printing	450	4,150	---	---	---	---	1,830	7,370		
Fixation	(4.6)	(21.8)					(28.2)	(13.1)		
Max Goller Aging	3,100	---	---	---	---	---	190	9,850		
Washing	(32.0)						(2.9)	(17.5)		
Finishing	---	---	14,320	---	---	---	1,250	15,570		
			(75.3)				(19.3)	(27.6)		
Calendering	130	---	---	550	---	---	320	1,260		
Raising	(1.3)			(1.5)			(5.0)	(2.2)		
Utilities Facilities	900	---	---	---	---	---	2,450	5,260		
Others	(9.3)						(37.8)	(9.3)		
Total	30,190	---	19,020	---	770	---	6,480	56,460		
	(60.4)		(38.1)		(1.5)					
Energy Consumption Rate	10 <sup>6</sup> kcal/ton-product	16,885 x 10 <sup>3</sup> m, 1.6 m-width, 140 g/m <sup>2</sup>							1.90	16.6

**Table 11-32 Comparison of Unit Heat Consumption in IBF and a Japanese Printing Factory**

Unit: 10<sup>6</sup> kcal/ton-product

Process	IBF	Japanese Factory	
		EP	EN
Singeing	0.23	0.26	0.26
Scouring	3.86	6.75	2.82
Bleaching			
Mercerization			
Drying	0.83		
Printing	1.63	7.36	7.42
Fixing			
Washing	2.84	2.98	0.92
Finishing	4.21	2.20	0.54
Sub-Total	13.60	19.55	11.96
Others	1.11	--	--
Total	14.70	--	--

Note: EP: Unit heat consumption estimated in 1983

EN: Unit heat consumption after possible heat recovery is performed

The value of EN of printing is calculated by assuming a smaller lot than that in 1983.

### 11-10-2 Energy Flow Chart of Major Energy Consumption and Supply Facilities

The energy flowcharts of the open width bleaching range, Max Goller washing range, steam boiler and hot oil heater are shown in Figures 11-17, 11-18, 11-19 and 11-20 respectively.




Figure 11-17 Energy Flowchart of the Open Width Bleaching Range

Unit:  $10^3$  kcal/h




Figure 11-18 Energy Flowchart of Max Goller Washing Range




Figure 11-19 Energy Flowchart of Steam Boiler






Figure 11-20 Energy Flowchart of Hot Oil Heater