

JAPAN INTERNATIONAL COOPERATION AGENCY

REPUBLIC OF TURKEY
MINISTRY OF ENERGY AND NATURAL RESOURCES
GENERAL DIRECTORATE OF ELECTRICAL SURVEY
AND DEVELOPMENT ADMINISTRATION

**FEASIBILITY STUDY
ON
ÇORUH-BERTA HYDROELECTRIC
POWER DEVELOPMENT PROJECT**

FINAL REPORT

JICA LIBRARY



J1140594 [1]

DECEMBER 1997

ELECTRIC POWER DEVELOPMENT CO., LTD.
PACIFIC CONSULTANTS INTERNATIONAL

| |
|----------|
| M P N |
| J R |
| 97 - 184 |

JAPAN INTERNATIONAL COOPERATION AGENCY


**REPUBLIC OF TURKEY
MINISTRY OF ENERGY AND NATURAL RESOURCES
GENERAL DIRECTORATE OF ELECTRICAL SURVEY
AND DEVELOPMENT ADMINISTRATION**

**FEASIBILITY STUDY
ON
ÇORUH-BERTA HYDROELECTRIC
POWER DEVELOPMENT PROJECT**

FINAL REPORT

DECEMBER 1997

**ELECTRIC POWER DEVELOPMENT CO., LTD.
PACIFIC CONSULTANTS INTERNATIONAL**



1140594 [1]

PREFACE

In response to a request from the Government of Republic of Turkey, the Government of Japan decided to conduct the Technical Cooperation for Feasibility Study on Çoruh-Berta Hydroelectric Power Development Project of Republic of Turkey and entrusted the study to Japan International Cooperation Agency (JICA).


JICA sent a study team led by Mr. Taisuke HASEGAWA of Electric Power Development Co., Ltd. to Republic of Turkey six times from November 1995 to October 1997.

The team held discussions with the officials concerned of the Government of Republic of Turkey, and conducted related field surveys. After returning to Japan, the team conducted further studies and compiled the final results in this report.

I hope this report will contribute to the promotion of the plan and to enhancement of friendly relations between our two countries.

I wish to express my sincere appreciation to the officials concerned of Republic of Turkey for their close cooperation throughout the study.

December 1997



Kimio FUJITA
President
Japan International Cooperation Agency

December 1997

Mr. Kimio Fujita
President
Japan International Cooperation Agency
Tokyo, Japan

Dear Mr. Fujita

Letter of Transmittal


We are pleased to submit to you the feasibility report on the Çoruh-Berta Hydroelectric Power Development Project of the Republic of Turkey. The report contains the advice and suggestions of authorities concerned of the Government of Japan and your Agency as well as the formulation of the above mentioned project. Also included are comments made by the Electrical Survey and Development Administration of the Republic of Turkey during technical discussions on the draft report which were held in ANKARA of the Republic of Turkey.

This report presents a scheme of development for Hydraulic Power Project in accordance with the demand forecast up to 2010. Upon completion of each stage of the Project, the shortage of power will be eliminated, thus greatly contributing to the improvement in stability of electric power net works in northeastern part of Turkey.


In view of the urgency of power development in the Republic of Turkey and of the need for socio-economic development of the Republic of Turkey as a whole, we recommend that the Government of Turkey implement this Project as a top priority.

We wish to take this opportunity to express our sincere gratitude to your Agency, the Ministry of Foreign Affairs, and the Ministry of Energy and Natural Resources. We also wish to express our deep gratitude to the Electrical Survey and Development Administration (EIE) and other authorities' concerned of the Government of the Republic of Turkey for the close cooperation and assistance extended to us during our investigations and study.


Very truly yours,






Taisuke Hasegawa
Team Leader
Çoruh-Berta Hydroelectric
Power Development Project



Composite Photograph of Bayram Dam, Spillway and Power Structure
View from downstream right bank




Composite Photograph of Baglik Dam and Power Structure
View from downstream right bank






ÇORUH-BERTA RIVER HYDROELECTRIC POWER DEVELOPMENT PROJECT

LOCATION MAP

Figure 1







| | |
|--|--|
| ÇORUH-BERTA RIVER HYDROELECTRIC POWER DEVELOPMENT PROJECT | |
| GENERAL PLAN | |
| Figure 3 | |

CONTENTS

| | Page |
|---|------|
| Summary | |
| Conclusion and Recommendation | |
| CHAPTER 1 INTRODUCTION | |
| 1.1 Background of the Project..... | 1-1 |
| 1.2 Objective of Study..... | 1-2 |
| 1.3 Field Investigation during the Study..... | 1-3 |
| 1.4 The record of Dispatched Team and List of Engineers..... | 1-3 |
| CHAPTER 2 GENERAL SITUATION IN THE REPUBLIC OF TURKEY | |
| 2.1 Geography..... | 2-1 |
| 2.2 Climate | 2-2 |
| 2.2.1 Air Temperature..... | 2-3 |
| 2.2.2 Precipitation..... | 2-3 |
| 2.3 Population..... | 2-4 |
| 2.4 Economy..... | 2-5 |
| 2.5 Energy Resources | 2-12 |
| 2.6 Transportation and Telecommunication..... | 2-16 |
| CHAPTER 3 GENERAL DESCRIPTION OF PROJECT AREA AND SURROUNDINGS | |
| 3.1 General Description of Project Area and Surroundings..... | 3-1 |
| 3.1.1 General Description..... | 3-1 |
| 3.1.2 Water Resources Development Plan and its Present Status | 3-3 |
| 3.2 General Description of Project Area..... | 3-5 |
| 3.2.1 Landform and National Environment..... | 3-5 |
| 3.2.2 Natural and Social Environment..... | 3-7 |

CHAPTER 4 PRESENT SITUATION OF ELECTRICITY

| | | |
|-----|--|-----|
| 4.1 | Present Situation of Electricity | 4-1 |
| 4.2 | Electric Power Utilities..... | 4-2 |
| 4.3 | Electric Power Facilities | 4-4 |
| 4.4 | Electric Power Supply and Demand | 4-4 |

CHAPTER 5 LOAD FORECAST AND POWER DEVELOPMENT PROGRAM

| | | |
|-----|--|-----|
| 5.1 | Load Forecast and Power Development Program..... | 5-1 |
| | 5.1.1 Trend in Economic Growth..... | 5-1 |
| | 5.1.2 Power Demand Forecast in Turkey..... | 5-1 |
| | 5.1.3 Power Demand Forecast | 5-1 |
| 5.2 | Power Development Plan | 5-4 |
| 5.3 | Timing of Commissioning of Berta Project..... | 5-5 |

CHAPTER 6 METEOROLOGY AND HYDROLOGY

| | | |
|-----|--|------|
| 6.1 | Outline of Meteorology and Hydrology in the Project Area | 6-1 |
| | 6.1.1 Hydrology..... | 6-1 |
| | 6.1.2 Meteorology | 6-1 |
| 6.2 | Runoff Study | 6-4 |
| | 6.2.1 Available Runoff Data | 6-4 |
| | 6.2.2 Monthly Inflows at Dam Sites | 6-4 |
| 6.3 | Evaporation Study..... | 6-17 |
| | 6.3.1 Available Evaporation Data..... | 6-17 |
| | 6.3.2 Reservoir Evaporation | 6-18 |
| 6.4 | Sedimentation Study..... | 6-24 |
| | 6.4.1 Available Sedimentation Data..... | 6-24 |
| | 6.4.2 Suspended Load..... | 6-24 |
| | 6.4.3 Bed Load | 6-28 |
| | 6.4.4 Density of Sediment Accumulation | 6-28 |
| 6.5 | Study of Probable Flood | 6-30 |
| | 6.5.1 Observed Annual Peak Discharge..... | 6-30 |
| | 6.5.2 Frequency Analysis on the Annual Peak Discharge..... | 6-30 |

| | | |
|-------|---|------|
| 6.6 | Study of the Probable Maximum Flood (PMF)..... | 6-31 |
| 6.6.1 | Flood Discharge from the Probable Maximum Precipitation (PMP).... | 6-31 |
| 6.6.2 | Snowmelt Runoff | 6-46 |
| 6.6.3 | Maximum Base Flow | 6-46 |
| 6.6.4 | Estimates of PMF | 6-46 |

7. GEOLOGY AND MATERIAL

| | | |
|-------|---|------|
| 7.1 | Regional Geology | 7-1 |
| 7.1.1 | Topography..... | 7-1 |
| 7.1.2 | Geology | 7-2 |
| 7.2 | Outline of Investigation | 7-9 |
| 7.2.1 | Existing Data..... | 7-9 |
| 7.2.2 | Geological Investigation Works..... | 7-9 |
| 7.2.3 | Seismic Prospecting..... | 7-14 |
| 7.3 | Site Geology | 7-15 |
| 7.3.1 | Bayram Project | 7-15 |
| 7.3.2 | Bağlık Project..... | 7-37 |
| 7.4 | Savail Slope..... | 7-61 |
| 7.4.1 | General..... | 7-61 |
| 7.4.2 | Geology around Savail Slope..... | 7-62 |
| 7.4.3 | Geology of Savail Slope..... | 7-62 |
| 7.5 | Materials..... | 7-79 |
| 7.5.1 | Soil Material | 7-83 |
| 7.5.2 | Rock Material..... | 7-93 |
| 7.5.3 | Filter Material and Concrete Aggregate..... | 7-94 |

Chapter 8 SEISMIC ANALYSIS

| | | |
|-------|---|-----|
| 8.1 | Structural Geology of Turkey | 8-1 |
| 8.1.1 | Geological Outline..... | 8-1 |
| 8.1.2 | Neotectonics of Turkey..... | 8-2 |
| 8.1.3 | North Anatolian Fault and East Anatolian Fault..... | 8-3 |

| | | |
|-------|---|------|
| 8.2 | General Seismicity of Turkey | 8-4 |
| 8.2.1 | Seismological Outline | 8-4 |
| 8.2.2 | Seismic Activities | 8-5 |
| 8.3 | Design Seismic Coefficient | 8-9 |
| 8.3.1 | Design Seismic Coefficient for Existing Dams | 8-9 |
| 8.3.2 | Estimation of Maximum Acceleration at the Sites | 8-11 |
| 8.3.3 | Design Horizontal Seismic Coefficient Used in Aseismic Design | 8-38 |

CHAPTER 9 DEVELOPMENT PLAN

| | | |
|-------|--|------|
| 9.1 | Review of Existing Development Plan | 9-1 |
| 9.1.1 | Outline of Berta River Development Plan | 9-1 |
| 9.1.2 | Reexamination of Existing Development Plans | 9-6 |
| 9.2 | Comparison Study of Alternative Development Plan | 9-21 |
| 9.2.1 | Method of Comparison Study | 9-21 |
| 9.2.2 | Alternative Plan | 9-25 |
| 9.2.3 | Comparison Study on Alternation Development Plan | 9-39 |

Chapter 10 TRANSMISSION LINE AND POWER SYSTEM ANALYSIS

| | | |
|------|--|------|
| 10.1 | Summary of Power System | 10-1 |
| 10.2 | Route Survey of Transmission Line | 10-2 |
| 10.3 | Survey of Switchyard | 10-3 |
| 10.4 | Transmission Line Plan for Berta Project | 10-3 |
| 10.5 | Power System Analysis | 10-4 |

CHAPTER 11 FEASIBILITY DESIGN

| | | |
|--------|--------------------------------------|------|
| | Outline | 11-1 |
| 11.1 | Bayram Project | 11-1 |
| 11.1.1 | Dam and Appurtenant Structures | 11-1 |
| 11.1.2 | Waterway and Powerhouse | 11-5 |
| 11.1.3 | Electro-mechanical Equipment | 11-9 |

| | | |
|--------|--------------------------------------|-------|
| 11.2 | Bağlık Project..... | 11-11 |
| 11.2.1 | Dam and Appurtenant Structures | 11-11 |
| 11.2.2 | Waterway and Powerhouse..... | 11-15 |
| 11.2.3 | Electro-mechanical Equipment..... | 11-18 |
| 11.3 | Transmission Line..... | 11-19 |
| 11.3.1 | Transmission Line Route..... | 11-19 |
| 11.3.2 | Conductor Size and Tower..... | 11-19 |

CHAPTER 12 CONSTRUCTION PROGRAM AND CONSTRUCTION COST

| | | |
|--------|---|-------|
| 12.1 | Construction Program and Construction Schedule..... | 12-1 |
| 12.1.1 | Basic Conditions..... | 12-1 |
| 12.1.2 | Construction Program and Construction Schedule..... | 12-4 |
| 12.2 | Construction Cost..... | 12-20 |
| 12.2.1 | Fundamental Items..... | 12-20 |

CHAPTER 13 ENVIRONMENT IMPACT AND COMPENSATION

| | | |
|--------|--|-------|
| 13.1 | Purpose of the Project..... | 13-1 |
| 13.2 | Location of the Project Site..... | 13-1 |
| 13.3 | Economic and Social Dimensions of the Project..... | 13-1 |
| 13.3.1 | Investment Program and Financial Resources..... | 13-1 |
| 13.3.2 | Work Schedule..... | 13-1 |
| 13.3.3 | Economic Analysis..... | 13-2 |
| 13.3.4 | Economical Social and Infrastructure Activities..... | 13-2 |
| 13.3.5 | Other Required Activities..... | 13-2 |
| 13.3.6 | Land Acquisition and Resettlement..... | 13-3 |
| 13.4 | Environmental Characteristics of the Project Site..... | 13-3 |
| 13.4.1 | Physical and Biological Environments and Utilization of Natural Resources..... | 13-3 |
| 13.4.2 | Characteristics of Socio-Economic Environment..... | 13-17 |
| 13.5 | Impacts of the Project on Environment and Counter Measure..... | 13-23 |
| 13.5.1 | Activities during Land Preparation, Construction and Installation Stages, Impacts on Physical and Biological Environment and Countermeasure..... | 13-23 |

| | | |
|--------|---|-------|
| 13.5.2 | Activities in the Operation Phase, Impacts on the Physical and Biological Environment and Countermeasure..... | 13-28 |
| 13.5.3 | Effects of the Projection the Socio-Economic Environment..... | 13-37 |
| 13.6 | Effects which may Occur or Continue after the Enterprise | 13-42 |
| 13.7 | Alternative of the Project..... | 13-42 |
| 13-8 | Conclusions | 13-44 |

CHAPTER 14 ECONOMIC AND FINANCIAL FRAMEWORKS

| | | |
|---------|--|-------|
| 14.1 | Proposition..... | 14-1 |
| 14.1.1 | Growth and Macro Management of Economy..... | 14-1 |
| 14.1.2 | The Power Subsector, Policy and Issues..... | 14-3 |
| 14.1.3 | Least Cost Analysis..... | 14-5 |
| 14.2 | Analytical Frameworks for Economic and Financial Analyses..... | 14-6 |
| 14.2.1 | General Remarks..... | 14-6 |
| 14.2.2 | Benefits and Costs..... | 14-7 |
| 14.2.3 | Measurement of Benefits..... | 14-8 |
| 14.3 | Analytical Methodology..... | 14-10 |
| 14.4 | Indices for Project Evaluation..... | 14-10 |
| 14.4.1 | Economic Internal Rate of Return (EIRR)..... | 14-10 |
| 14.4.2 | Benefit-Cost Ratio (B-C ratio)..... | 14-11 |
| 14.4.3 | Financial Rate of Return (FIRR)..... | 14-12 |
| 14.5 | Model Configuration and Parameters..... | 14-12 |
| 14.5.1 | Project Life..... | 14-12 |
| 14.5.2 | Tariff (Revenue)..... | 14-12 |
| 14.5.3 | Sales Volume..... | 14-13 |
| 14.5.4 | Foreign Exchange Quotation..... | 14-14 |
| 14.5.5 | Financial Cost Estimation..... | 14-14 |
| 14.5.6 | Physical Contingencies..... | 14-15 |
| 14.5.7 | Price Contingencies..... | 14-15 |
| 14.5.8 | Recurrent (O/M) Costs..... | 14-16 |
| 14.5.9 | Financial Terms..... | 14-16 |
| 14.5.10 | Interest During Construction (IDC)..... | 14-16 |
| 14.5.11 | Discount Rate..... | 14-17 |
| 14.5.12 | Sensitivity Analysis..... | 14-17 |

| | | |
|--------|---|-------|
| 14.6 | Financial and Economic Evaluation | 14-17 |
| 14.6.1 | General | 14-17 |
| 14.6.2 | Ending Remarks-Evaluation Results | 14-18 |

CHAPTER 15 FINANCING PLAN

| | | |
|------|----------------------|------|
| 15.1 | Financing Plan | 15-1 |
| 15.2 | Repayment Plan | 15-2 |

Chapter 16 FUTHER INVESTIGATION

| | | |
|------|---|------|
| 16.1 | Geological Investigation for Bayram Project | 16-1 |
| 16.2 | Geological Investigation for Bağlık Project | 16-1 |

SUMMARY

SUMMARY

This report concerns the feasibility study of the Çoruh-Berta Hydroelectric Power Development Project of the Republic of Turkey. The feasibility study has been conducted from 1995 to 1997 by the Japan International Cooperation Agency (JICA) under a technical cooperation program of the Government of Japan.

This report is submitted by JICA, through the Ministry of Foreign Affairs of the Japanese Government, to the General Directorate of Electric Survey and Development Administration (EIE) of the Government of Turkey.

A brief summary of the results of the feasibility study is presented in the following part of this section.

(1) Character of the Project

The river basin of Çoruh is divided into two parts, that is, Black sea climate with heavy rain in downstream area and Eastern climate as continental climate in upstream area.

Berta river area is located at the middle of Çoruh river in North East belonging to East climate area, but have an strong effect of Black sea climate and 624 mm yearly rainfall.

By above heavy rainfall, yearly discharge amount is $1.65 \text{ m}^3/\text{s}/100 \text{ km}^2$ at Bağlık damsite, which is equivalent to 1.5 times of whole average discharge of Çoruh river.

The river inclination of Berta river between Bayram dam and the tailrace outlet of Bağlık power station is more than $1/70$, which is fairly steep.

The undeveloped hydropower resources in Çoruh river is equivalent to 10% of undeveloped hydropower resources in Turkey.

EIE has studied M/P of Çoruh river hydropower development scheme in 1982, and proposed total 29 schemes with 10 schemes in main river, 19 schemes in tributary including 2 schemes in Berta river.

Above schemes, 5 schemes of detailed design in main river, total installed capacity 1,957 MW have already been finished.

Additionally 5 schemes in main river and 5 schemes in tributary, total installed capacity 883 MW, those F/S have been finished.

Further more the Deriner scheme of 670 MW capacity located at the downstream of Bağlık scheme is going to start the construction by getting foreign loan as all preparatory works have been finished.

The hydraulic power schemes in Berta river have 42% of power plant factor thanks to abundant natural conditions than that of average 37% of whole Çoruh river's 29 schemes.

The total capacity in Berta river is 127 MW which is middle scale in Çoruh river schemes.

Additionally those schemes have the same economic characteristics with construction cost 250×10^6 US\$ as large scale schemes in Çoruh main river.

And there is no serious problem for transportation because the national motor ways pass through the scheme area.

As for electric transmission line, only 37 km new line would be enough to the Deriner point.

As for submerged compensation, 65 houses in Bayram reservoir and 59 houses in Bayram dam borrow area, although there are relocation of road and electric distribution net work.

Most of those submerged houses are the temporary used one which are used during winter season without farm works.

There is no industry except farm and forestry in those schemes area. So, it would be very difficult to find new industry at present.

But those scheme will employ thousands of men in the area and need a lot of construction materials. Additionally after completion of the schemes, sightseeing and leisure industry would be expected to promote the area economic activities.

(2) Demand Forecast and Power Development Plan

(a) Power Demand Forecast

As a result of comparing the estimate according to the regression formula and the forecast by TEAŞ, proximate values were obtained and the demand forecast of TEAŞ was adopted.

Parenthetically, according to the power demand forecast (as of 1994), the maximum power demand in 2010 will be 43,590 MW and the energy production 271,450 GWh, and an annual growth rate of 8.0% and annual load factor of 70% are forecast.

(b) Power Development Plan

According to the TEAŞ's power development plan

The total installed capacity in 2010 will be as much as 60,056 MW, of which the thermal and nuclear powr amounts to 36,970 MW (62%) in combination while the hydroelectric power to 23,086 MW (38%).

(3) Power System Analysis

An analysis was carried out assuming the power system around the year 2010, the year of commissioning of Bayram and Bağlık Power Stations, in order to check the characteristics of power systems in the vicinity of the power stations.

There will not be any problem with system stability and short-circuiting capacity in relation to the existing system accompanying commissioning of Berta project.

(4) Meteorology and Hydrology

(a) Dam Site Catchment Area and Runoff

| | Bayram | Bağlık |
|--|--------|--------|
| Catchment area (Km ²) | 1,159 | 1,509 |
| Annual inflow (10 ⁶ m ³) | 606 | 786 |
| (m ³ /s) | 19.2 | 24.9 |
| Specific runoff m ³ /s/100km ² | 1.65 | 1.65 |
| Design flood m ³ /s | 1,660 | 1,830 |

(b) Sedimentation

The annual suspended sediment volume at the projected dam site was determined to be as follows:

| | |
|------------|---------------------------------------|
| Bayram dam | $Q_{SMD} = 253,821 \text{ tonf/year}$ |
| Bağlık dam | $Q_{SMD} = 76,650 \text{ tonf/year}$ |

Based on the above, the sedimentation 50 years later is estimated as follows:

| | |
|------------|--|
| Bayram dam | $S_{WU} = 11.76 \times 10^6 \text{ m}^3$ |
| Bağlık dam | $S_{WU} = 3.55 \times 10^6 \text{ m}^3$ |

(5) Topography, Geology, Materials, and Earthquakes

(a) Bayram Project

1) Topography

The Berta river on which the Bayram project is located is a tributary of the Çoruh river which flow into the Black Sea, and one of rivers in the Karçal and Yalnızçam mountain ranges. The mountain ranges on both sides of the Berta river have peaks from 1,000 to 3,000 m in elevation, and extend in belts from north-east to south-west. Unstable topographic features

such as large-scale landslides and collapses have not been found in the results of investigations which have been carried out so far in the project area.

2) Geology

All major civil structures in the Bayram project are to be constructed in the distribution of volcanic rocks which belong to the Berta Formation of Cretaceous age in the Mesozoic. The bedrock at the dam site is composed of the Berta Formation. At the dam site alluvial deposit which consists of sand and gravel is approximately 33 m in thickness. The underground powerhouse site is emplaced in basalt of the Berta Formation. At the powerhouse site the RQD values of drilled cores are from 80% to 100% and the basalt is good condition for excavation. The tailrace tunnel route is in volcanic rocks of the Berta Formation and large faults on the route have not been found. Watertightness of the reservoir is amply assured.

3) Material

i) Core Material

Of the candidate borrow areas for soil material, C site was concluded to be suitable from the view of transportation distance, quality and volume.

The results of laboratory tests were as follows.

- * Specific gravity is 2.68 ~ 2.75 and no problem.
- * Maximum dry density is 1.70 ~ 1.92 t/m³ at optimum water content and no problem.
- * In general, there is little scatter in gradation and is in the range of soil material.

ii) Filter Material

For the filter material, the alluvial deposits on the present river bed in Bayram reservoir were concluded to be suitable from the view of transportation distance, quality and volume.

(iii) Rock Material

For the rock material, the basalt and volcanic breccia at Kirmızııkaya quarry were concluded to be suitable from the view of transportation distance, quality and volume.

(iv) Concrete Aggregate

For the concrete aggregate, the alluvial deposits on the present river bed in Bayram reservoir were concluded to be suitable as the first candidate site from the view of transportation distance, quality and volume, and the basalt and volcanic breccia at Kirmızııkaya quarry as second candidate site.

The results of laboratory tests for the material at first candidate site were as follows.

Sand

- * Specific gravity 2.63 ~ 2.64
- * Water absorption 2.5 ~ 2.7%
- * Other test results will give no problem fundamentally.

Gravel

- * Specific gravity 2.50 ~ 2.61
- * Water absorption 2.4 ~ 2.8%
- * Other test results will give no problem fundamentally.

4) Earthquake

The project area belongs to the seismic active zone by the North Anatolian Fault. (III Seismic Risk Zone).

Maximum acceleration at the project site ground surface was estimated as 150 Gal by the results of seismic risk analysis for the earthquake data in Turkey (1880 ~ 1997).

Design horizontal seismic coefficient for Bayram dam (rockfill dam) adopted $k = 0.15$ as the safety side value.

(b) Bađlık Project

1) Topography

The Berta river on which the Bađlık project is located is a tributary of the oruh river which flow into the Black Sea, and one of rivers in the Karal and Yalnızam mountain ranges. The mountain ranges on both sides of the Berta river have peaks from 1,000 to 3,000 m in elevation, and extend in belts from north-east to south-west. Unstable topographic features such as large-scale landslides and collapses have not been found in the results of investigations which have been carried out so far in the project area.

2) Geology

All major civil structures in the Bađlık project are to be constructed in the distribution of the Yusufeli Formation of Jurassic age, the Berta Formation of Cretaceous age, and the İlzidere granitic rocks which intrude into the Yusufeli Formation and the Berta Formation. The bedrock at the dam site is composed of hard hornfels of the Yusufeli Formation. Alluvial deposit at the dam site which consists of sand and gravel is approximately 6m in thickness. The underground powerhouse site is emplaced in hornfels of the Yusufeli Formation. At the powerhouse site the RQD values of drilled cores are from 60% to 80% and the Yusufeli Formation is good condition for excavation. The tailrace tunnel route is mainly in the İlzidere granitic rocks and large faults on the route have not been found. Watertightness of the reservoir is amply assured.

3) Material

i) Concrete Aggregate

For the concrete aggregate, the alluvial deposits on the present river bed in Bayram reservoir were concluded to be suitable as the first candidate site from the view of transportation distance, quality and volume, and the basalt and volcanic breccia at Kirmızııkaya quarry as second candidate site.

The results of laboratory tests for the material at first candidate site were as follows.

- (i) Sand
 - * Specific gravity 2.63 ~ 2.64
 - * Water absorption 2.5 ~ 2.7%
 - * Other test results will give no problem fundamentally.

- (ii) Gravel
 - * Specific gravity 2.50 ~ 2.61
 - * Water absorption 2.4 ~ 2.8%
 - * Other test results will give no problem fundamentally.

4) Earthquake

The project area belongs to the seismic active zone by the North Anatolian Fault. (III Seismic Risk zone)

Maximum acceleration at the project site ground surface was estimated as 190 Gal by the results of seismic risk analysis for the earthquake data in Turkey (1880 - 1997).

Design horizontal seismic coefficient for Bađlık dam (concrete gravity dam) adopted $k = 0.15$ as the safety side value.

(6) Investigations for Environmental Aspects

- (a) Both project sites lie in the barren area and low population density which has a trend on decreasing. Population to be affected by the dam-reservoirs planned is approximately 380 persons and 124 private houses.

- (b) Land to be inundated is 3.38 km^2 for the Bayram project and 0.37 km^2 for the Bađlık project. There is no agriculture and dwelling area in Bađlık project site, although Bayram project site involves 243.9 da of local agriculture area on domestic consumption. In addition to the land to be inundated, 105.25 da of agricultural and dwelling area at Savail village is utilized for borrow area. These area produce no special products. Economical activity of both sites are not high by low population density and industrial activity.

- (c) No forest exists in the both sites and no protected flora and animals especially found exist in the project sites. No special fish is living in the Berta River.
- (d) Water reduction sections, approximately 8 km for the Bayram project and 4.5 km for the Bağlık project will be formed by the implementation of both projects. 0.3 ~ 0.7 m³/sec of artificial discharge from both dams is planned for 3 months of dry season considering of natural inflow volume for 2 sections in order to maintain a natural river water stream, although precious organisms can not be found in these sections. Appropriate amount of water on discharge to water reduction sections is to be decided by the detailed design study.
- (e) Serious water pollution and eutrophication phenomena are not predicted, since nutrition level of Berta River is low and by rapid exchange of reservoir water.
- (f) Serious losses of sediment matters to be carried to the Çoruh river mouth and expansion of saltification at river mouth region are not expected.
- (g) On the construction works, pollution prevention measures will be introduced in accordance with the related Turkish regulation. Land slope protection measures will be adapted for disposal and borrow area.
Locations of treatment facilities on waste water to be originated from workers and concrete preparation work are to be decided by the detailed design study.
- (h) Serious issues on environmental side is not found. Relocation of private and public properties will be planned. Total cost on land acquisition and relocation of properties is accounted as 21.3×10^6 US\$.

(7) Optimum Development Plan

Based on results of studies of development plans made up to this point, the Çoruh-Berta Hydroelectric Development Project is to be 2-step development scheme consisting of the Bayram project and the Bağlık project.

The Bayram project would consist of constructing dam 145 m in height on the Berta river at the Bayram village site approximately 2.5 km downstream from the confluence of the Meydancık river and the Şavaşat river to provide reservoir of high water level at EL. 740 m, effective storage capacity $113 \times 10^6 \text{ m}^3$, drawing water of maximum $43 \text{ m}^3/\text{s}$ from an intake at the right bank of the dam, generating power of maximum output of 68 MW and with effective head of 182.9 m at underground powerhouse immediately downstream of the intake, and the water after power generation would be discharged into the Berta river at the Köprübaşı village 2 km upstream from the confluence with the Karçal river by tailrace tunnel of length of approximately 8 km, this development plan being the optimum development plan.

For the Bağlık project, the optimum development plan would consist of constructing dam 74 m in height on the Berta river at the Arktaş village site approximately 250 m downstream of the confluence with the Sungu river to provide reservoir of high water level EL. 530 m, effective storage capacity $1 \times 10^6 \text{ m}^3$, drawing water of maximum $52 \text{ m}^3/\text{s}$ from intake that is attached to the dam, generating power of maximum output of 59 MW with effective head of 130.9 m at underground powerhouse immediately downstream of the intake, and the water after power generation would be discharged into the Berta river at the Arktaş village site by tailrace tunnel of length of approximately 4.5 km.

(8) Construction Program and the Cost

(a) Construction Program

The main structures in the Bayram project area are rockfill dam of height 145 m, intake, penstock, underground powerhouse, and tailrace tunnel of approximately 8 km.

The main structures in the Bağlık project area are concrete gravity dam of height 74 m, intake, penstock, underground powerhouse, and a tailrace tunnel of approximately 4.5 km.

With start of operation of Bayram project and Bağlık project in 2007, it will be necessary for preparations for start of construction to be made according to the schedule below.

| | |
|-----------------------|---|
| Nov. 1995 - Dec. 1997 | Feasibility Study |
| Jan. 1998 - Jun. 1998 | Provision and Award of Final Design (6 months) |
| Jul. 1998 - Dec. 1999 | Final Design (1.5 years) |
| Jan. 2000 - Dec. 2000 | Financial Formulation (1 year) |
| Jan. 2001 - Dec. 2001 | Bidding and Award of Contract for Construction (1 year) |
| Jan. 2002 - Dec. 2006 | Construction (5 years) |

The critical path of the Bayram project is dam construction, and it is necessary for a proper schedule to be set up centered on this construction.

The critical path of the Bağlık project is powerhouse construction, and it is necessary for a proper schedule to be set up centered on this construction.

(b) Construction Cost

The time of estimation is to be the initial part of Jan. 1996 with 1US\$ at TL61,000.

The total construction cost of Bayram project is to be TL10,495,634 million (US\$172,060 thousand, L.C=TL6,681,044 million, F.C=TL3,814,590 million).

The total construction cost of Bağlık project is to be TL4,847,268 million (US\$79,463 thousand, L.C=TL3,319,751 million, F.C=TL1,527,517 million).

(9) Economic and Financial Analysis

(a) Economic Internal Rate of Return (EIRR)

With due recognition of the economic viability of the Project to be analyzed from a broader national perspective, the quantitative impact represented by EIRR worked out 15.4%. Given the estimated real weighted average cost of capital for TEAŞ standing at around 10-12%, the EIRRs well outnumber the cut-off rate¹, thereby making it possible to accept that the Project with those sub-projects altogether be substantially feasible. Benefit-Cost ratio also surpassed the crucial cut-off rate of unit 1.0, with the estimated 1.65.

¹ Reference: ADB, *Ibid.*

(b) Financial Internal Rate of Return (FIRR)

The FIRR of the investment plan with the accruable costs (base cost plus physical contingency) and benefits expressed as per 1997 price level, worked out 11.9%. With the current opportunity cost of capital standing at around 9 percent, the FIRRs for the Project, by and large, outnumbers the real cost of capital in view, thereby making it possible to accept the Project as financially viable. Yet, there remains somewhat the vulnerability of the project to real price-hyke. Benefit-Costs ratio is estimated at 1.22, with the implication that the project benefit is higher than the value of investment.

(c) Sensitivity Analysis

The major financial risks associated with power project include lower growth in demand for power and front end implementation delays. Given the strong demand growth experienced in the Project area, the former risk will be considered low. In the meantime, sensitivity analysis is to be carried out for the following three cases to assess the magnitude of the possible risks therein: (i) lower tariff by 10%, (ii) capital cost overrun by 10%, and (iii) one year delay in implementation.

The results of the analysis are summarized as follows.

| | Base Case | Benefits, -10% | Capital C, +10% | Implementation one- year delay |
|-------------|-----------|----------------|-----------------|--------------------------------|
| EIRR | 15.4% | 12.8% | 14.2% | 14.8% |
| E B-C Ratio | 1.65 | 1.38 | 1.41 | 1.50 |
| FIRR | 11.9% | 9.5% | 10.8% | 11.3% |
| F B-C Ratio | 1.22 | 1.20 | 1.11 | 1.18 |

(10) Financing Plan

(a) Financing Plan

Of the total "financial costs" for the project of US\$311.9 million, the initial investment for the foreign and local cost portions, exclusive of replacement cost in the 41-43rd years in the investment outlay worked out respective of US\$95.5 million and US\$150.9 million, thereby leading to US\$246.5 million in aggregate. Replacement cost accrued in the far later years during the project period is being excluded due to very low probability of credit extended by international or bi-lateral financing institutions. With the highly hypothetical assumption that 100 percent of these foreign and local cost (base cost plus physical contingencies) are presumably covered by multi, and bi-lateral aid agencies, notably, the World Bank and the Overseas Economic Cooperation Fund, Japan, differences in financial terms and conditions between the two agencies are reiterated herewith in a bid to articulate the basic assumptions.

| | Foreign Cost Portion | | Local Cost Portion | |
|-----------------------------|----------------------|------------|--------------------|------------|
| | Multi-Lateral | Bi-Lateral | Multi-Lateral | Bi-Lateral |
| Financing Coverage (%) | 100 | 100 | 100 | 100 |
| Loan Period (years) | 20 | 30 | 20 | 30 |
| Grace Period (years) | 5 | 10 | 5 | 10 |
| Loan Repayment Period (yrs) | 15 | 20 | 15 | 20 |
| Interest Rate (%) | 3.5 | 3.5 | 9.5 | 9.5 |

(b) Repayment Plan

In compliance with the hypothetical parameters associated with the two financing sources as above, annuity payments are calculated as follows.

| | Foreign Cost Portion | | Local Cost Portion | |
|---|----------------------|------------|--------------------|------------|
| | Multi-Lateral | Bi-Lateral | Multi-Lateral | Bi-Lateral |
| Disbursement (US\$million) | 95.5 | 95.5 | 150.9 | 150.9 |
| Principal (US\$million) | 101.5 | 95.5 | 184.5 | 150.9 |
| Cumulative Repayment (US\$million) | 132.2 | 157.0 | 353.5 | 445.1 |
| Annual Payment (US\$million) | 8.8 | 6.7 | 23.6 | 17.1 |
| Present value of Repayments (S\$milion) | 85.5 | 85.5 | 117.2 | 116.8 |

In a bid to simplify the model, annuity payments are assumed to be made once a year, at the end of the fourth quarter. Commitment charge of 0.75% which is payable to the agreed amount of loan is not included either in discussion for the same reason. Amortization is on a levelized basis, and interest which is payable all over the project duration will be on the diminishing balance of the outstanding principal, as such interest costs will decrease proportionately as principal is amortized.

(11) Outline of the Project

1) Bayram Project

River

| | |
|----------------|--|
| Name of River | Berta |
| Catchment Area | 1,159 km ² |
| Annual Inflow | 606 x 10 ⁶ m ³ (19.20 m ³ /s) |

Reservoir

| | |
|----------------------------|--|
| High Water Level | 740.00 m |
| Low Water Level | 686.00 m |
| Available Drawdown Depth | 54.00 m |
| Sedimentation Level | 676.00 m |
| Gross Storage Capacity | 133.0 x 10 ⁶ m ³ |
| Effective Storage Capacity | 113.0 x 10 ⁶ m ³ |
| Reservoir Area | 3.38 km ² |

Dam

| | |
|---|--|
| Type | Rockfill Dam with Center Core |
| Elevation of Dam Crest | 745.00 m |
| Thalweg Elevation | 635.00 m |
| Height of Dam (from foundation) | 145.00 m |
| Length of Dam Crest | 415 m |
| Volume of Dam (including coffer dam) | 6,144 x 10 ³ m ³ |

Diversion Tunnel

| | |
|----------------|--|
| Design Flood | 320 m ³ /s |
| Type | Standard Horse Shoe, Pressure, Concrete Lining |
| Number | One |
| Inner Diameter | 5.70 m |
| Length | 795 m |

Outlet Equipment

| | |
|------|---|
| Type | Main valve Jet Flow Gate |
| | Sub valve High Pressure Slide Gate |

Spillway

| | |
|--------------------------|---------------------------------------|
| Design Flood | 1,660 m ³ /s |
| Type | Shute with Gates |
| Overflow Crest Elevation | 727.50 m |
| Width of Overflow Crest | 23.00 m (Including pier width 3.00 m) |
| Energy Dissipator | Hydraulic Jump Basin |
| Type of Gate | Radial |
| Number of Gate | Two |
| Size of Gate | Width 10.00 m x Height 12.50 m |

Intake

| | |
|-----------------|------------|
| Type | Horizontal |
| Number | One |
| Inlet Elevation | 676.00 m |

| | |
|----------------|------------------------------|
| Size | Width 8.00 m x Height 6.00 m |
| Type of Gate | Roller Gate |
| Number of Gate | One |
| Size of Gate | Width 3.30 m x Height 3.30 m |

Intake Tunnel

| | |
|--------------------|-------------------------------------|
| Type | Circular, Pressure, Concrete Lining |
| Number | One |
| Discharge Capacity | 43.00 m ³ /s |
| Inner Diameter | 3.30 m |
| Length | 65.00 m |

Penstock

| | |
|-------------------------|------------------------|
| Type | Steel Embedded |
| Number | One Line |
| Inner Diameter x Length | 3.30~2.50 m x 320.24 m |

Powerhouse

| | |
|------|---|
| Type | Underground, Concrete Lining |
| Size | Width 19.00 m x Height 41.00 m x Length 44.50 m |

Access Tunnel

| | |
|------|---|
| Type | Half Circle Half Rectangular, Concrete Lining |
| Size | Width 5.00 m x Height 5.00 m x Length 901 m |
| | Inclination 1:10.00 |
| | Elevation of Tunnel Exit 635.00 m |

Cable Tunnel

| | |
|------|---|
| Type | Half Circle Half Rectangular, Concrete Lining |
| Size | Width 4.00 m x Height 4.00 m x Length 369 m |
| | Inclination 1:4.02 |
| | Elevation of Tunnel Exit 650.00 m |

Drainage Tunnel

| | |
|------|---|
| Type | Half Circle Half Rectangular, Concrete Lining |
| Size | Width 3.50 m x Height 3.50 m x Length 154 m |
| | Inclination Level |

Tailrace Chamber

| | |
|------|--|
| Type | Chamber, Concrete Lining |
| Size | Width 4.60 m x Height 16.20 m x Length 30.00 m |

Tailrace

| | |
|----------------|--|
| Type | Standard Horse Shoe, Non Pressure, Concrete Lining • Shotcrete |
| Max. Discharge | 43.00 m ³ /s |
| Inner Diameter | 4.60 m |
| Length | 7,930 m |

Development Plan

| | |
|---------------------------|-------------------------|
| Normal Intake Water Level | 722.00 m |
| Normal Tail Water Level | 530.00 m |
| Gross Head | 192.00 m |
| Effective Head | 182.90 m |
| Maximum Discharge | 43.00 m ³ /s |
| Number of Unit | One |
| Installed Capacity | 68 MW |
| Firm Peak Power | 57.6 MW |

Turbine

| | |
|-----------------|---------------------------------|
| Type | Vertical Shaft, Francis Turbine |
| Number | One |
| Max. Discharge | 43.00 m ³ /s |
| Turbine Output | 69,500 kW |
| Revolving Speed | 300 rpm |

Generator

| | |
|-----------------|--|
| Type | Three phases Alternating Current Synchronous |
| Number | One |
| Rated Output | 75,400 kVA |
| Revolving Speed | 300 rpm |
| Frequency | 50 Hz |
| Voltage | 13.2 kV |
| Power Factor | 0.9 lag |

Main Transformer

| | |
|----------|---|
| Type | Outdoor Three phases, Forced-oil-forced-air cooled type |
| Number | One |
| Capacity | 75,400 kVA |
| Voltage | (Primary) 13.2 kV (Secondary) 154 kV |

Switchyard

| | |
|---------------------------|------------------------------|
| Bus System | Single Bus + Transformer Bus |
| Bus | Aluminum Pipe |
| Number of Lines Connected | 1 cct |
| Voltage | 154 kV |
| Conductor Type | ACSR |

Annual Energy Production

| | |
|----------------|-----------|
| Average Energy | 250.4 GWh |
| Firm Energy | 144.9 GWh |

Construction Period

5 years

Project Cost

10,495,634 x 10⁶TL
(172,060 x 10³US\$)

Unit Construction Cost at Sending End

| | |
|---------|---|
| Per kW | 154 x 10 ⁶ TL/kW (2,525 US\$/kW) |
| Per kWh | 4,331 TL/kWh (0.071 US\$/kWh) |

Economic Evaluation (Total value of Bayram project and Bağlık project)

| | |
|--------------------------------|-------|
| EIRR | 15.4% |
| FIRR | 11.9% |
| Benefit-Cost Ratio (Financial) | 1.22 |

2) Bağlık Project

River

| | |
|----------------|--|
| Name of River | Berta |
| Catchment Area | 1,509 km ² |
| Annual Inflow | 786 x 10 ⁶ m ³ (24.90 m ³ /s) |

Reservoir

| | |
|----------------------------|--------------------------------------|
| High Water Level | 530.00 m |
| Low Water Level | 527.00 m |
| Available Drawdown Depth | 3.00 m |
| Sedimentation Level | 517.00 m |
| Gross Storage Capacity | 7.3 x 10 ⁶ m ³ |
| Effective Storage Capacity | 1.0 x 10 ⁶ m ³ |
| Reservoir Area | 0.37 km ² |

Dam

| | |
|------------------------------------|--------------------------------------|
| Type | Concrete Gravity Dam |
| Elevation of Dam Crest | 533.00 m |
| Thalweg Elevation | 465.00 m |
| Height of Dam (from foundation) | 74.00 m |
| Length of Dam Crest | 190 m |
| Volume of Dam | 195 x 10 ³ m ³ |

Outlet Equipment

| | |
|------------|--------------------------|
| Main Valve | Jet Flow Gate |
| Sub Valve | High Pressure Slide Gate |

Spillway

| | |
|--------------------------|---------------------------------------|
| Design Flood | 1,830 m ³ /s |
| Type | Center Overflow with Gates |
| Overflow Crest Elevation | 519.00 m |
| Width of Overflow Crest | 31.00 m (Including pier width 3.00 m) |
| Energy Dissipator | Bucket Basin |
| Type of Gate | Radial |
| Number of Gate | Two |
| Size of Gate | Width 14.00 m x Height 11.00 m |

Intake

| | |
|-----------------|------------------------------|
| Type | Attached to Dam body |
| Number | One |
| Inlet Elevation | 517.00 m |
| Size | Width 3.60 m x Height 3.60 m |
| Type of Gate | Roller Gate |
| Number of Gate | One |
| Size of Gate | Width 3.60 m x Height 3.60 m |

Penstock

| | |
|-------------------------|------------------------|
| Type | Steel Embedded |
| Number | One Line |
| Inner Diameter x Length | 3.60~3.00 m x 212.28 m |

Powerhouse

| | |
|------|---|
| Type | Underground, Concrete Lining |
| Size | Width 21.00 m x Height 41.50 m x Length 50.00 m |

Access Tunnel

Type Half Circle Half Rectangular, Concrete Lining
Size Width 5.00 m x Height 5.00 m x Length 560 m
Inclination 1:10.00
Elevation of Tunnel Exit 462.00 m

Cable Tunnel

Type Half Circle Half Rectangular, Concrete Lining
Size Width 4.00 m x Height 4.00 m x Length 264 m
Inclination 1:5.73
Elevation of Tunnel Exit 465.00 m

Drainage Tunnel

Type Half Circle Half Rectangular, Concrete Lining
Size Width 3.50 m x Height 3.50 m x Length 164 m
Inclination Level

Tailrace Chamber

Type Chamber, Concrete Lining
Size Width 4.60 m x Height 15.10 m x Length 30.00 m

Tailrace

Type Standard Horse Shoe,
Non Pressure, Concrete Lining • Shotcrete
Max. Discharge 52.00 m³/s
Inner Diameter 4.90 m
Length 4,454 m

Development Plan

Normal Intake Water Level 528.50 m
Normal Tail Water Level 392.00 m
Gross Head 136.50 m
Effective Head 130.90 m
Maximum Discharge 52.00 m³/s
Number of Unit One

Installed Capacity 59 MW
Firm Peak Power 56.2 MW

Turbine

Type Vertical Shaft, Francis Turbine
Number One
Max. Discharge 52.00 m³/s
Turbine Output 60,500 kW
Revolving Speed 250 rpm

Generator

Type Three phases
Alternating Current
Synchronous
Number One
Rated Output 65,600 kVA
Revolving Speed 250 rpm
Frequency 50 Hz
Voltage 13.2 kV
Power Factor 0.9 lag

Main Transformer

Type Indoor, Three phases, Forced-oil-forced-air cooled
type
Number One
Capacity 65,600 kVA
Voltage (Primary) 13.2 kV
(Secondary) 154 kV

Switchyard

GIS

Annual Energy Production

| | |
|----------------|-----------|
| Average Energy | 225.8 GWh |
| Firm Energy | 128.4 GWh |

Construction Period

5 years

Project Cost

4,847,268 x 10⁶ TL
(79,463 x 10³ US\$)

Unit Construction Cost at Sending End

| | |
|---------|--|
| Per kW | 82 x 10 ⁶ TL/kW (1,347 US\$/kW) |
| Per kWh | 2,318 TL/kWh (0.038 US\$/kW) |

Economic Evaluation (Total value of Bayram project and Bağlık project)

| | |
|--------------------------------|-------|
| EIRR | 15.4% |
| FIRR | 11.9% |
| Benefit-Cost Ratio (Financial) | 1.22 |

CONCLUSIONS AND RECOMMENDATIONS

Conclusion

- (1) Çoruh-Berta Hydroelectric Power Development Project should be developed as soon as possible because the project is feasible technically, economically and financially. It is possible to commission the project in 2007 when lead time for final design, financial arrangement and construction period are taken into account.
- (2) Optimization study by comparison of various alternatives concerning storage capacity, development layout and etc. was carried out. As a result, it is determined that this project is to be two stage development project by Bayram project and Bağlık project.

Bayram project consists of 145 m high and approximately $6,200 \times 10^3 \text{m}^3$ volume of center core rockfill dam to provide $113 \times 10^6 \text{m}^3$ effective storage capacity of reservoir, approximately 321 m long penstock, underground powerhouse immediate downstream of dam to generate 68 MW of power and 7,930 m of tailrace tunnel.

Bağlık project consists of 74 m high and approximately $195 \times 10^3 \text{m}^3$ volume of concrete gravity dam approximately 213 m long penstock, underground powerhouse immediate downstream of dam to generate 59 MW of power and 4,454 m of tailrace tunnel.

- (3) The electric power generated at Bayram and Bağlık project plant is to be transmitted to Deriner project substation by 37 km of transmission line (Bayram project-Bağlık project 12 km 1 circuit, Bağlık project-Deviner project 25 km 2 circuit).
- (4) The total construction cost of Bayram project is to be TL10,495,634 million (US\$172,060 thousand, L.C=TL6,681,044 million, F.C=TL3,814,590 million).

The total construction cost of Bağlık is to be TL4,847,268 million (US\$79,463 thousand, L.C=TL3,319,751 x million, F.C.=TL1,527,517 million).

EIRR and FIRR for Bayram and Bağlık project is 15.4% and 11.9% respectively.

- (5) The result of environmental impact assessment shows no problem on natural and social environment of the project area.

To keep river environment, continuous water of 0.5 m³/s will be released from Bayram dam and Bađlık dam to downstream.

In order to maintain a natural river water stream 0.3 ~ 0.7 m³/s of artificial discharge from both dams is planned for 3 months of dry season for their each water reduction sections between dam and tailrace outlet.

Recommendation

- (1) Çoruh-Berta hydroelectric power development project is feasible technically, economically and financially. The project is recommended to be put in service in the beginning of 2007.
- (2) Detailed design is needed for the project because this report shows feasibility design.
- (3) The following geological investigations are required for the detailed design.
(Bayram project)
 - Drilling investigation at the dam site
 - Drilling investigation at the underground powerhouse site
 - Drilling investigation at the tailrace tunnel route
(Bağlık project)
 - Drilling investigation at the dam site
 - Exploratory adits at the dam site
 - Drilling investigation at the tailrace tunnel route
- (4) On the detailed design stage, detailed study on discharge to be needed to water reduction sections will be carried out in order to get appropriate amount of discharge considering a natural inflow to these sections.

Location of treatment system of wastewater to be originated from workers and concrete preparation work will be also decided on the detailed design stage.

CHAPTER 1 INTRODUCTION

CONTENTS

| | Page |
|---|-------------|
| Chapter 1 INTRODUCTION | |
| 1.1 Background of the Project..... | 1-1 |
| 1.2 Object of Study..... | 1-2 |
| 1.3 Field Investigation during the Study | 1-3 |
| 1.4 The Record of Dispatched Team and List of Engineers | 1-3 |

List of Tables

Table 1-1 GDP Growth and Energy Generation Growth

Table 1-2 Field Investigation during the Study

CHAPTER 1 INTRODUCTION

The Republic of Turkey was primarily an agricultural country, but emphasis has been placed on industrialization in recent years. It may be considered that economic exchanges with neighboring countries have increased with the collapse of the former Soviet Union, and the rising demand due to this has spurred acceleration of industrialization.

In step with this, securing of electric energy has become of importance, and the Turkish Government, giving priority to development of domestic energy resources, has been endeavoring to develop lignite thermal and hydroelectric power which are domestic resources.

Lignite thermal has met strong opposition because of problems of pollution, and new development has become difficult. Accordingly, the situation in society has become one where installation of pollution prevention facilities cannot be avoided and the increase in construction cost for this has caused priority for development to be lowered, while on the other hand, the superiority of hydroelectric power generation has recently come to be favorably rerecognized.

In general, growth of GDP and growth of electric power become more or less proportionate as industrialization progresses. The growths in GDP and electric power supplied from 1984 to 1994 are shown in Table 1-1.

Table 1-1 GDP Growth and Electric Energy Supply Growth

| | 1984 | 1985 | 1986 | 1987 | 1988 | 1989 | 1990 | 1991 | 1992 | 1993 | 1994 |
|------------------------------|------|------|------|------|------|------|------|------|------|------|------|
| GDP Growth (%) | 6.7 | 4.2 | 7.0 | 7.5 | 2.1 | 0.3 | 9.3 | 0.9 | 6.0 | 7.5 | -5.4 |
| Energy Generating Growth (%) | 12.7 | 13.4 | 17.3 | 11.8 | 8.5 | 10.3 | 11.4 | 4.9 | 10.9 | 9.0 | 7.2 |

Annual Report (from Central Bank)

1.1 Background of the Project

Turkey has 35,241 MW of hydroelectric potential from both economic and technical views point, 9% of which belongs to the Çoruh river.

On the Berta River, which is one of the biggest tributary of the Çoruh river including Oltu, Berta and Barhal rivers, 476 million kWh and 127 MW installed capacity are learned to be developed.

Berta river Hydropower Development Project was started by EIE in 1987 and resulted in master plan report on Çoruh-Berta river basin in 1992.

The Çoruh river is located in the northeast of Turkey and selected as a important river for large scale hydroelectric power development.

The studies have been performing by EIE as a whole.

The Government of Turkey requested the Government of Japan in January 1994 to make a feasibility study concerning the Berta Hydroelectric Power Development Project in Berta river which is one of tributary in Çoruh river.

The Government of Japan in response to this request, commissioned JICA in 1995 to dispatch a preliminary survey team to Turkey for exchange of opinion with the related agencies and to make a general reconnaissance of the project site.

Based on the results of the above, an agreement was reached in August 1995 between EIE and JICA, under the title of Scope of Works for the feasibility study on the Berta Hydroelectric Power Development Project in the Republic of Turkey.

1.2 Objective of Study

Objective of the study is to decide optimum hydroelectric power development project technically, economically and financially, to prepare feasibility study report and to realize technical transfer through study of the project.

1.3 Field Investigation during the Study

Field investigations carried out by EIE during the study are as shown in Table 1-2.

1.4 The Record of Dispatched Team and List of Engineers

In November 1995, JICA began the work based on the before-mentioned "Scope of Works". JICA next dispatched the following survey teams for field investigations concerning the Project.

| | | |
|-----------------------|----------------------|-------------------------------|
| First survey mission | (except Environment) | Nov. 27, 1995 ~ Dec. 13, 1995 |
| First survey mission | (Environment) | Jan. 4, 1996 ~ Jan. 16, 1996 |
| Second survey mission | | Feb. 11, 1996 ~ Feb. 17, 1996 |
| Third survey mission | (Phase 1) | May 22, 1996 ~ Jul. 31, 1996 |
| Third survey mission | (Phase 2) | Sep. 16 1996 ~ Nov. 14, 1996 |
| Fourth survey mission | | Feb. 19, 1997 ~ Mar. 17, 1997 |
| Fifth survey mission | | Oct. 1, 1997 ~ Oct. 15, 1997 |

During this period survey team submitted the following reports to EIE. Engineers participated the Study are as shown in the following list.

| | |
|--------------------|---------------|
| Inception Report | November 1995 |
| Progress Report | March 1996 |
| Interim Report | March 1997 |
| Draft Final Report | October, 1997 |

List of Engagements

EIE

| | |
|-------------------------|---|
| Mr. Tuncay DERMAN | Head of Project Design Department |
| Mr. Şukr  KARABIBER | Chief of Dams and Hydroelectric Power Plants Section |
| Mr. Nejat G RCAN | Design Engineer, Civil, Dams and Hydroelectric Power Plants Section |
| Mrs. Şule AKÇAY | Design Engineer, Civil, Dams and Hydroelectric Power Plants Section |
| Mrs. G lg n G RCAN | Design Engineer, Civil, Dams and Hydroelectric Power Plants Section |
| Mrs.  zlem YILMAZ | Design Engineer, Environmental, Dams and Hydroelectric Power Plants Section |
| Mr. Orhan YAGCI | Chief of Geotechnical Services Section |
| Mr. S kr  BAY | Geological Engineer, Geotechnical Services Section |
| Mr. Mehmet TANRIKULU | Chief of Project Hydrology Section |
| Mrs. Nazlı BAYKARA | Hydrology Engineer, Civil, Project Hydrology Section |
| Mr. Rıdran Seref ENERCU | Laboratory Technician |
| Mr. Mehmet G NG R | Chief of Electrical and Mechanical Division |

JICA Team

| | |
|-----------------------|---------------|
| Mr. Taisuke HASEGAWA | Team Leader |
| Mr. Masayuki SEINO | Planning |
| Mr. Nobuo HASHIMOTO | Design |
| Mr. Mitsuru MIYASHITA | Hydrology |
| Mr. Youzou FUKUTAKE | Geology |
| Mr. Teruyoshi HATANO | Geology |
| Mr. Takaya NOMURA | Electrical |
| Mr. Kiyoshi KIKUCHI | Environmental |
| Mr. Takao OZAKI | Economy |

Table 1-2 Field Investigation during the Study

| Item | Quantity | Remarks |
|------------------------------------|----------------------------------|--|
| Topographical Map (1/1,000) | | |
| Bayram dam | 0.5 km ² | |
| Bayram outlet | 0.1 km ² | |
| Bağlık dam | 0.2 km ² | |
| Bağlık outlet | 0.1 km ² | |
| Geological Investigation | | |
| Drilling Core | | |
| Bayram project | 12 holes 929.65 m | |
| Bağlık project | 5 holes 510 m | |
| Test Pit | | |
| Bayram project | 9 pit 28.35 m | |
| Seismic prospecting | | |
| Bayram project | 6 lines 5,000 m | |
| Hydroelectrical Survey | | |
| Observation of sediment | 3 gaging stations from July 1996 | Must be operated after the Feasibility Study |