

9.2.3 Comparison Study on Alternative Development Plan

(1) Reservoir Operation Study

(a) Bayram Project

The annual average inflow at the Bayram dam site is $19.2 \text{ m}^3/\text{s}$, with the snowmelt period of April to June corresponding to the high water season, 63% of the annual inflow occurring during this period. The inflow during December to February corresponding to the low water season has 9% of the annual inflow, and the seasonal variation range of inflow is not narrow. The minimum value of annual inflow is 49% of the average inflow, and the maximum value 188%. The maximum value of annual inflow is 3.8 times the minimum value.

As described above, inflows at the Bayram project site have fairly large seasonal and annual fluctuations, and a certain degree of reservoir capacity is necessary for effective utilization for power generation.

As reservoir capacity for the Bayram project, it is possible to obtain an effective storage capacity of $113 \times 10^6 \text{ m}^3$ at high water level elevation of EL. 740 m. With regulating capacity of this degree it will not be possible to completely average out inflow, but it will be possible for spillover from the reservoir to be held to a minimum.

The reservoir operation rules of Bayram reservoir have been determined for each study case, based on considerations on the following factors.

- (i) The river water in a wet year is to be stored and released in a dry year, to make the firm discharge as large as possible.
- (ii) During a year, the reservoir is to be operated in such a way that the water in the wet season is to be stored and supplied in the dry season.
- (iii) The reservoir is to be operated so that the spill is as small as possible.
- (iv) The reservoir is to be operated so that a stable supply of power is assured for a long period and at the same time the energy generation is large.

(b) Bağlık Project

The inflow at the Bağlık dam site will be the sum of the inflow at the Bayram dam site regulated outflow from Bayram reservoir including discharged upon power generation, the discharge from the dam spillway and the inflow from the remaining catchment area between Bayram dam and Bağlık dam.

The annual average inflow at the Bağlık dam site is $24.9 \text{ m}^3/\text{s}$. Inflow at the Bağlık dam site, in case of Bayram reservoir capacity of $113 \times 10^6 \text{ m}^3$, with the snowmelt period of April to June 51% of the annual inflow occurring during this period. The inflow during December to February has 15% of the annual inflow, and the seasonal variation range of inflow is not narrow. The minimum value of annual inflow is 56% of the average inflow, and the maximum value 180%. The maximum value of annual inflow is 4.09 times the minimum value.

In this way, the inflow at the Bağlık dam site will have seasonal variations and long-term variations which are both fairly large.

On the other hand, when the high water level at the Bağlık dam site is made 570 m, the dam height would be 114 m and of the same degree as the height of Bayram dam, and effective storage capacity of $30 \times 10^6 \text{ m}^3$ can be secured, which would be a large-scale change in the reservoir water level for only a slight regulating effect, and this will bring about a large variation in power generating head. as a result, the effect of regulating inflow with the reservoir will be offset by the head loss due to variation in reservoir water level, and making the size of Bağlık reservoir large will not lead to increase in power generation with the Bağlık project.

Therefore, it was decided to study a reservoir scale of securing only daily regulating capacity for the Bağlık project in addition to the scheme of a reservoir for seasonal regulation. As for reservoir operation rules, they were set up under the same principles as for Bayram reservoir.

(c) Reservoir Operation Study

The calculations of reservoir operation have been performed by an electronic computer system, and based on the monthly average inflow, for the period of 53 years from October 1942 to September 1995.

The firm discharge is defined as the discharge which can be utilized for power generation at all times during 95% of the 53 year period, and it is obtained by making it the largest with the inflow mass curve considering carry over storage. The inflow mass curve and the effective storage capacity and the firm discharge are shown in Figure 9-9 and 9-10 respectively.

In the calculation, the change of turbine and generator efficiency depending on the change of the reservoir water level has been taken into account. The maximum power discharge is limited by the rated output when the water level is higher than the rated intake water level, and the maximum power discharge is reduced by the reduction of head when the water level is below the rated intake water level.

The rated intake water level was set at an elevation which is below the high water level by 1/3 of the available drawdown.

The procedure of electric energy calculations is shown in Figure 9-11, and the Bayram reservoir operation rules in case of reservoir high water level 740 m, low water level 686 m, tail water level 530 m for the Bayram project are indicated in Figure 9-12. This operation rules curve given in Figure 9-12 was plotted based on the principles of reservoir operation given in the previously-mentioned (I) to (IV), for energy production to be maximum according to the Dynamic Program Method (DP Method) using an electronic computer.

The operation rules curves for overflow from the reservoir to be of the minimum limit prepared by the mass curve conventionally employed in general are shown in Figure 9-13.

the results of energy calculations by these two rules curves are as given below, and there is not much difference between the two. Consequently, it was decided that for the comparison studies of the various alternative plans, the electric energy calculations of the alternative plans would be made with the rules curves prepared by the DP method.

		by DP Method	by Mass Curve
Annual average energy production	(GWh)	247.9	241.2
Annual firm energy production	(GWh)	141.4	141.6
Firm Peak Power	(MW)	58.0	58.4

The rules curve for Bayram reservoir by this DP method, was prepared with Bayram reservoir considered as a reservoir only for power generation in the Bayram project, and the effect on the downstream Bađlık reservoir is not considered, but for the optimum development plan, the study was made for the operation rules curve of Bayram project to be optimum for power generation including the downstream Bađlık reservoir also as described in 9.2.3 (4).






Figure 9-9 Mass Curve of Bayram Reservoir




Figure 9-10 Firm Discharge of Bayram and Bağlık Reservoir





Fig.9-11 Flow Chart of Power and Energy Calculation



Symbols

- V_{n-1} : Storage at the end of previous month
- V_n : Storage at the end of current month
- V_n' : Temporary storage at the end of current month
- V_{max} : Maximum storage (effective storage capacity)
- V_s : Secured storage for firm discharge
- f_n : Spill in current month
- q_n : Inflow in current month
- Q_n : Available discharge for power in current month
- Q_{firm} : Firm discharge for power
- Q_{max} : Maximum discharge for power, variable depending on water level

Operation Rule

$$V_n = V_{n-1} + q_n$$

1. $V_n \geq V_{max}$

(1) $V_n - V_{max} \geq Q_{max} \rightarrow Q_n = Q_{max}$

(2) $Q_{max} > V_n - V_{max} \geq Q_{firm} \rightarrow Q_n = V_n - V_{max}$

(3) $Q_{firm} > V_n - V_{max} \rightarrow Q_n = Q_{firm}$

2. $V_s > V_n$

(1) $V_n \geq Q_{firm} \rightarrow Q_n = Q_{firm}$


(2) $Q_{firm} > V_n \rightarrow Q_n = V_n$

$$V_n - Q_n - V_{max} \geq 0.0 \rightarrow f_n = V_n - V_{max} - Q_n$$

$$V_n - Q_n - V_{max} < 0.0 \rightarrow f_n = 0.0$$

$$V_n = V_n' - Q_n - f_n$$

Figure 9-12 Operation Rule of Reservoir by Dynamic Program Method for Energy Maximum



Symbols

- V_{n-1} : Storage at the end of previous month
- V_n : Storage at the end of current month
- V'_n : Temporary storage at the end of current month
- V_{max} : Maximum storage (effective storage capacity)
- V_s : Secured storage for firm discharge
- f_n : Spill in current month
- q_n : Inflow in current month
- Q_n : Available discharge for power in current month
- Q_{firm} : Firm discharge for power
- Q_{max} : Maximum discharge for power, variable depending on water level

Operation Rule

$$V_n = V_{n-1} + q_n$$

1. $V'_n \geq V_{max}$

(1) $V'_n - V_{max} \geq Q_{max} \rightarrow Q_n = Q_{max}$

(2) $Q_{max} > V'_n - V_{max} \geq Q_{firm} \rightarrow Q_n = V'_n - V_{max}$

(3) $Q_{firm} > V'_n - V_{max} \rightarrow Q_n = Q_{firm}$

2. $V_s > V'_n$

(1) $V'_n \geq Q_{firm} \rightarrow Q_n = Q_{firm}$

(2) $Q_{firm} > V'_n \rightarrow Q_n = V'_n$

$$V_n = V_{max} - Q_n \geq 0.0 \rightarrow f_n = V'_n - V_{max} - Q_n$$

$$V_n = V_{max} - Q_n < 0.0 \rightarrow f_n = 0.0$$

$$V_n = V'_n - Q_n - f_n$$

Figure 9-13(1) Operation Rules of Reservoir by Mass Curve
for Spilled Water Minimum




Figure 9-13(2) Operation Rules of Reservoir by Mass Curve for spilled Water Minimum

(2) Optimum Reservoir Scale

The comparison study results of alternative plans for combinations of reservoir capacities of the Bayram and Bağlık projects are shown in Figure 9-14 and Table 9-9 and 9-10.

The annual surplus benefit of the total of the Bayram and Bağlık projects will be larger the smaller the storage capacity of the Bağlık project. In the relation between the storage capacity of the Bayram project and the total annual surplus benefit, the maximum point will shift depending on the combination with the storage capacity of the Bağlık project, and the combination with the effective storage capacity of the Bağlık project of $1.0 \times 10^6 \text{ m}^3$ (HWL=530 m) is the maximum regardless of the size of the effective storage capacity of Bayram reservoir, while the case of effective storage capacity of Bayram reservoir being $113.0 \times 10^6 \text{ m}^3$ (HWL=740 m) gives the maximum of all combination.

In case of the Bayram project, as mentioned in 9.2.2(3)(b), a comparison study was made whether the optimum storage capacity and the optimum reservoir high water level would shift depending on how reservoir low water level is set up together with Bağlık project, whose effective storage capacity of $1 \times 10^6 \text{ m}^3$ (HWL=530 m) is taken as the optimum storage capacity.

In the Bayram project, the alternative plan for minimum water level of 686 m determined from sedimentation capacity is maximum at all times regardless of the size of effective storage capacity, and the case of high water level of 740 m, effective storage capacity $113.0 \times 10^6 \text{ m}^3$ is the maximum of all cases.

Consequently, this case is taken as the optimum for the Bayram project.

As for Bağlık project, alternative by setting of higher low water level than the minimum low water level of 527 m which determined by sediment volume and combination with Bayram project whose high water level is 740 m and low water level is 686 m. And comparison with the alternative whose high water level is 530 m and low water level is 527 m. As shown in Figure 9-16, Table 9-14 and 9-15, in case of high water level of 530 m and low water level of 527 m is confirmed as the optimum reservoir scale of Bağlık project.

(3) Power Station Scale

Factors determining the installed capacity of a hydroelectric power station are effective head and maximum available discharge as indicated in the equation below, while maximum available discharge is generally determined by firm discharge and equivalent peak duration hours.

$$\text{Installed Capacity (kW)} = 9.8 \times \text{Turbine-Generator Efficiency} \times \text{Effective Head (m)} \times \text{Maximum Discharge (m}^3/\text{s)}$$

$$\text{Maximum Available Discharge} = \text{Firm Discharge (m}^3/\text{s)} \times \frac{24 \text{ hr}}{\text{Equivalent Peak Duration Hours (hr)}}$$

Of the abovementioned factors, effective head and firm discharge are determined by physical conditions such as effective storage capacity and intake and tail water levels, but equivalent peak duration hours are determined by conditions different from the above.

According to the electric power demand and supply plan, prepared by TEAŞ in 1995 the situations of the electric power system in the year 2002 when the construction of Çoruh-Berta project is scheduled to be started, and 2010, the last year of the demand and supply plan, will be as indicated in Table 9-16.

Table 9-16 Demand and Supply Balance

Year			2002	2010	
Demand					
a.	Peak Power	(MW)	24,360	43,590	
b.	Annual Energy	(GWh)	151,720	271,450	
Consumption					
Supply					
c.	Thermal	(MW)	19,090	36,970	
d.	Hydro	(MW)	15,421	23,086	
e.	Total	(MW)	34,511	60,056	
Annual Energy Production					
f.	Thermal	(GWh)	119,838	236,558	
g.	Hydro (Dependable)	(GWh)	38,291	52,219	
Supply Margin (e-a)			(MW)	10,151	16,466
Supply Margin Rate ((e-a)/a)			(%)	42	38
Equivalent Peak Duration Hours for Hydro (g/d)/365)			(Hour)	6.8	6.2

According to the above table, the average equivalent peak duration times of all hydroelectric power generation in 2002 and 2010 will be 6.8 hours and 6.2 hours, but since these have been calculated with daily energy production of the maximum load day as the annual average electric energy, the actual peak duration times are thought to be somewhat longer than these. However, since the trend is for the proportion of hydroelectric power generation in the entire electric power system to decrease year by year, it is thought equivalent peak duration time will also be shortened year by year.

In the Çoruh-Berta project, similarly to most other hydroelectric power generation projects, since storage capacity is large enough that roughly the entire quantity of inflow can be used for power generation, a large increase in electric energy production cannot be expected even when equivalent peak duration time is made shorter and installed capacity larger.

Therefore, for the equivalent peak duration time of the Çoruh-Berta project, it is judged reasonable for about 6 hours, the average for all hydroelectric power generation, to be made the limit.

Examination of the optimum scale of installed capacity for the Çoruh-Berta project was made by comparisons on setting up maximum available discharges for the cases of 8 hours with 6 hours the limit for equivalent peak duration times for dependable discharge of $10.7 \text{ m}^3/\text{s}$.

The result of the comparison studies, as shown in Table 9-17 is that equivalent peak duration time of 6 hours is optimum. Therefore, maximum available discharge of $43 \text{ m}^3/\text{s}$ and installed capacity of 68 MW will be the optimum scale for Bayram project and maximum discharge of $52 \text{ m}^3/\text{s}$ and installed capacity of 59 MW will be the optimum scale for Bağlık project.

(4) Final Reservoir Operation Study

The reservoir operation study for optimization study was prepared with Bayram reservoir considered as a reservoir only for power generation in Bayram project, and effect on the downstream Bağlık project is not considered. On the other hand as final reservoir operation study, optimum reservoir operation rule is established as shown in Figure 17 by the operation study of combined of Bayram and Bağlık project which reservoir operation of Bayram project considers effect on Bağlık project is carried out by utilizing the DP method.

Energy calculation is carried out by this rule curve. In this calculation $0.5 \text{ m}^3/\text{s}$ of constant discharges from Bayram dam and Bağlık dam to their downstream are considered to keep environment of river during the period of August to October.

(5) Optimum Development Plan

Based on results of studies of development plans made up to this point, the Çoruh-Berta Hydroelectric Development Project is to be a 2-step development scheme consisting of the Bayram project and the Bağlık project.

The Bayram project would consist of constructing a dam 145 m in height on the Berta river at the Bayram village site 2.5 km downstream from the confluence of the Meydancık river and the Şavşat river to provide a reservoir of high water level at EL. 740 m, effective storage capacity $113 \times 10^6 \text{ m}^3$, drawing water of a maximum $43 \text{ m}^3/\text{s}$ from an intake at the right bank of the dam, generating power of maximum output of 68 MW with an effective head of 182.9 m at an underground powerhouse immediately downstream of the intake, with the water after power generation discharge into the Berta river at the Köprübaşı village 2 km upstream from the confluence with the Karçal river by a tailrace tunnel of a length of 7.93 km, this development plan being the optimum development plan.

For the Bağlık project, the optimum development plan would consist of constructing a dam 74 m in height on the Berta river at the Arktasi village site 0.1 km downstream of the confluence with the Sungu river to provide a reservoir of high water level EL. 530 m, effective storage capacity $1 \times 10^6 \text{ m}^3$, drawing water of a maximum $52 \text{ m}^3/\text{s}$ from an intake at the left bank of the dam, generating power of a maximum output of 59 MW with an effective head of 130.9 m at an underground powerhouse immediately downstream of the intake, with the water after power generation discharged into the Berta river at the Arktasi village site by a tailrace tunnel of length of 4.45 km.

Table 9-18 and 9-19 show outline and cost estimate of optimum development plant of Çoruh-Berta project.

Table 9-20 and Figure 9-18 show the result of reservoir operation of Bayram project. Table 9-21, 9-22, 9-23, 9-24 and Figure 9-19 show monthly average energy production, monthly firm energy production, monthly peak power, peak power duration and energy generation of Bayram project.

Table 9-25 and Figure 9-20 show the result of reservoir operation study of Bağlık project. Table 9-26, 9-27, 9-28, 9-29 and Figure 9-21 show monthly average energy production, monthly firm energy production, monthly peak power, peak power duration and energy generation of Bağlık project.




Figure 9-14 Comparison Study on Reservoir Capacity




Figure 9-15 Comparison Study on IReservoir Water Level of Bayram Project




Figure 9-16 Comparison Study on Reservoir Water Level of Bağlık Project





Figure 9-17 Final Reservoir Operation Rule

Table 9-10(1-1) Comparison Study on Reservoir Capacity

Bayview Project Tailrace Type Understudy	By Mixed Alternative Thermal Power Plant										
	Bayview 750MW	Baygall 750MW	Baygall 750MW	Baygall 750MW	Baygall 750MW	Baygall 750MW	Baygall 750MW	Baygall 750MW	Baygall 750MW	Baygall 750MW	Total
High Water Level	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
Normal Water Level	555.67	555.67	555.67	555.67	555.67	555.67	555.67	555.67	555.67	555.67	555.67
Low Water Level	527.00	527.00	527.00	527.00	527.00	527.00	527.00	527.00	527.00	527.00	527.00
Available Drawdown	43.00	43.00	43.00	43.00	43.00	43.00	43.00	43.00	43.00	43.00	43.00
Gross Storage Capacity	169.00	36.40	133.00	30.10	133.00	30.10	133.00	30.10	133.00	30.10	169.00
Effective Storage Capacity	149.00	30.10	119.00	30.10	119.00	30.10	119.00	30.10	119.00	30.10	149.00
Dam Type	Con-Gr	Con-Gr	Con-Gr	Con-Gr	Con-Gr	Con-Gr	Con-Gr	Con-Gr	Con-Gr	Con-Gr	Con-Gr
Dam Height	150	114	150	114	150	114	150	114	150	114	150
Dam Volume	6,200	680	6,200	680	6,200	680	6,200	680	6,200	680	6,200
Tailwater Level	570.00	392.00	570.00	392.00	570.00	392.00	570.00	392.00	570.00	392.00	570.00
Effective Head	152.37	181.71	152.37	181.71	152.37	181.71	152.37	181.71	152.37	181.71	152.37
Maximum Discharge	49.00	85.00	49.00	85.00	49.00	85.00	49.00	85.00	49.00	85.00	49.00
Installed Capacity	67.25	72.50	67.25	72.50	67.25	72.50	67.25	72.50	67.25	72.50	67.25
Firm Peak Power	52.40	72.50	52.40	72.50	52.40	72.50	52.40	72.50	52.40	72.50	52.40
Energy Production	215.00	287.00	215.00	287.00	215.00	287.00	215.00	287.00	215.00	287.00	215.00
Average Energy	18.00	178.00	18.00	178.00	18.00	178.00	18.00	178.00	18.00	178.00	18.00
Firm Energy	80.00	109.00	80.00	109.00	80.00	109.00	80.00	109.00	80.00	109.00	80.00
GW	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
US\$MWh	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45
US\$MWh	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270
US\$MWh	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Benefit	9.02	12.46	9.02	12.46	9.02	12.46	9.02	12.46	9.02	12.46	9.02
Firm Peak Power	3.54	4.72	3.54	4.72	3.54	4.72	3.54	4.72	3.54	4.72	3.54
Firm Energy	1.72	2.35	1.72	2.35	1.72	2.35	1.72	2.35	1.72	2.35	1.72
Secondary Energy	14.32	19.06	14.32	19.06	14.32	19.06	14.32	19.06	14.32	19.06	14.32
Investment Cost	174.52	96.24	174.52	96.24	174.52	96.24	174.52	96.24	174.52	96.24	174.52
Coal Facilities	23.61	52.01	23.61	52.01	23.61	52.01	23.61	52.01	23.61	52.01	23.61
Hydro. and Ele-Mech Eq.	190.33	126.22	190.33	126.22	190.33	126.22	190.33	126.22	190.33	126.22	190.33
Total	174.52	96.24	174.52	96.24	174.52	96.24	174.52	96.24	174.52	96.24	174.52
Annual Cost	17.63	9.72	17.63	9.72	17.63	9.72	17.63	9.72	17.63	9.72	17.63
Coal Facilities	2.71	3.65	2.71	3.65	2.71	3.65	2.71	3.65	2.71	3.65	2.71
Hydro. and Ele. Mech Eq.	20.34	13.37	20.34	13.37	20.34	13.37	20.34	13.37	20.34	13.37	20.34
Annual Surplus Benefit(B-C)	-4.02	5.16	-4.02	5.16	-4.02	5.16	-4.02	5.16	-4.02	5.16	-4.02
Benefit Cost Ratio(B/C)	0.70	1.46	0.70	1.46	0.70	1.46	0.70	1.46	0.70	1.46	0.70
Level Annual Cost (Firm)	0.151	0.075	0.151	0.075	0.151	0.075	0.151	0.075	0.151	0.075	0.151
US\$MWh	0.065	0.047	0.065	0.047	0.065	0.047	0.065	0.047	0.065	0.047	0.065
Level Annual Cost (Average)	0.057	0.048	0.057	0.048	0.057	0.048	0.057	0.048	0.057	0.048	0.057
US\$MWh	0.055	0.043	0.055	0.043	0.055	0.043	0.055	0.043	0.055	0.043	0.055

Table 9-10(1-2) Comparison Study on Reservoir Capacity

By Mixed Alternative Thermal Power Plant

Reservoir Dam Site	Layout	720MWP				715MWP				570MWP				705MWP				570MWP			
		Bayern	Back	Total	Bayern	Back	Total	Bayern	Back	Total	Bayern	Back	Total	Bayern	Back	Total	Bayern	Back	Total		
High Water Level		710.00	570.00	710.00	710.00	570.00	710.00	710.00	570.00	710.00	570.00	710.00	705.00	570.00	705.00	700.00	570.00	700.00	570.00		
Normal Water Level		708.67	568.33	708.67	708.67	568.33	708.67	708.67	568.33	708.67	568.33	708.67	705.00	565.67	705.00	695.33	565.67	695.33	565.67		
Low Water Level		696.00	527.00	696.00	696.00	527.00	696.00	696.00	527.00	696.00	527.00	696.00	696.00	527.00	696.00	686.00	527.00	686.00	527.00		
Available Drawdown		34.00	43.00	34.00	34.00	43.00	34.00	34.00	43.00	34.00	43.00	34.00	34.00	43.00	34.00	43.00	34.00	43.00			
Cross Storage Capacity		76.00	36.40	76.00	69.00	36.40	76.00	69.00	36.40	76.00	36.40	76.00	46.00	36.40	76.00	169.00	36.40	76.00			
Effective Storage Capacity		56.00	30.10	56.00	50.00	30.10	56.00	50.00	30.10	56.00	30.10	56.00	26.00	30.10	56.00	146.00	30.10	56.00			
Dam Type		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Dam Height		120	114	120	120	114	120	120	114	120	114	120	114	114	120	105	114	105	114		
Dam Volume		3,500	660	3,500	3,100	660	3,100	3,100	660	3,100	660	3,100	2,700	660	2,700	2,400	660	2,400			
Tailwater Level		570.00	392.00	570.00	570.00	392.00	570.00	570.00	392.00	570.00	392.00	570.00	570.00	392.00	570.00	570.00	392.00	570.00			
Effective Head		132.07	157.97	132.07	128.73	157.97	132.07	128.73	157.97	132.07	157.97	132.07	128.73	157.97	132.07	128.73	157.97	132.07			
Maximum Discharge		33.00	46.00	33.00	31.00	46.00	33.00	31.00	46.00	33.00	46.00	33.00	26.00	46.00	33.00	24.00	46.00	33.00			
Installed Capacity		37.00	63.00	100.00	94.00	63.00	100.00	94.00	63.00	100.00	63.00	94.00	63.00	63.00	94.00	81.00	63.00	94.00			
Firm Peak Power		30.20	50.10	90.30	84.40	50.10	90.30	84.40	50.10	90.30	50.10	84.40	50.10	50.10	84.40	71.70	50.10	84.40			
Energy Production		158.40	293.10	451.50	406.90	293.10	451.50	406.90	293.10	451.50	293.10	406.90	293.10	293.10	406.90	370.70	293.10	406.90			
Firm Energy		78.50	132.70	211.20	196.60	132.70	211.20	196.60	132.70	211.20	132.70	196.60	132.70	132.70	196.60	170.60	132.70	196.60			
Secondary Energy		79.90	160.40	239.30	210.30	160.40	239.30	210.30	160.40	239.30	160.40	210.30	160.40	160.40	210.30	199.90	160.40	210.30			
Unit Benefit Value		180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450			
Firm Peak Power		0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270			
Secondary Energy		0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219			
Firm Peak Power		5.20	10.34	15.54	14.52	10.34	15.54	14.52	10.34	15.54	10.34	14.52	10.34	10.34	14.52	17.34	10.34	14.52			
Firm Energy		2.04	3.52	5.56	5.20	3.52	5.56	5.20	3.52	5.56	3.52	5.20	3.52	3.52	5.20	4.63	3.52	5.20			
Secondary Energy		1.72	2.81	4.53	4.32	2.81	4.53	4.32	2.81	4.53	2.81	4.32	2.81	2.81	4.32	4.30	2.81	4.32			
Total		9.00	15.67	23.67	23.37	15.67	23.67	23.37	15.67	23.67	15.67	23.37	15.67	15.67	23.37	21.18	15.67	23.37			
Investment Cost		101.33	94.43	194.04	190.40	94.43	194.04	190.40	94.43	194.04	94.43	190.40	94.43	94.43	190.40	175.06	94.43	190.40			
Hydro and Ew-Mech Eq		47.26	43.86	15.79	42.18	43.86	15.79	42.18	43.86	15.79	42.18	43.86	14.28	43.86	38.50	33.73	43.86	38.50			
Total		118.63	123.32	241.94	232.58	123.32	241.94	232.58	123.32	241.94	123.32	232.58	118.63	118.63	214.16	188.36	118.63	214.16			
Annual Cost		10.23	9.77	20.01	19.20	9.77	20.01	19.20	9.77	20.01	9.77	19.20	9.77	9.77	19.20	17.74	9.77	19.20			
Hydro and Ew-Mech Eq		1.97	3.03	5.00	4.81	3.03	5.00	4.81	3.03	5.00	3.03	4.81	3.03	3.03	4.81	4.39	3.03	4.81			
Total		12.20	12.80	25.01	24.01	12.80	25.01	24.01	12.80	25.01	12.80	24.01	12.80	12.80	24.01	22.13	12.80	24.01			
Annual Surplus Benefit(B-C)		3.21	3.87	0.67	0.67	3.87	0.67	0.67	3.87	0.67	0.67	0.67	0.67	0.67	0.67	-0.86	0.67	0.67			
Benefit Cost Ratio(B/C)		0.74	1.30	1.00	1.00	1.30	1.00	1.00	1.30	1.00	1.00	1.00	0.99	1.14	0.96	0.71	1.06	0.91			
Unit Annual Cost (Firm)		0.153	0.096	0.116	0.122	0.096	0.116	0.122	0.096	0.116	0.096	0.122	0.125	0.174	0.130	0.176	0.114	0.134			
Unit Annual Cost (Average)		0.077	0.049	0.076	0.059	0.049	0.076	0.059	0.049	0.076	0.049	0.059	0.077	0.051	0.090	0.075	0.053	0.061			

Table 9-10(2-1) Comparison Study on Reservoir Capacity

by Mixed Alternative Thermal Power Plant

Reservoir Item	750m		765m		780m		795m		810m		825m		840m		855m		Total
	Bayan	750m	Bayan	765m	Bayan	780m	Bayan	795m	Bayan	810m	Bayan	825m	Bayan	840m	Bayan	855m	
High Water Level	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00	750.00
Normal Water Level	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00	680.00
Low Water Level	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00	620.00
Available Drawdown	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00	130.00
Crevasse Storage Capacity	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00	180.00
Effective Storage Capacity	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00
Item Type	Reservoir	Con-Gr.	Reservoir	Con-Gr.	Reservoir	Con-Gr.	Reservoir	Con-Gr.	Reservoir	Con-Gr.	Reservoir	Con-Gr.	Reservoir	Con-Gr.	Reservoir	Con-Gr.	
Item Volume	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
Item Volume	470	470	470	470	470	470	470	470	470	470	470	470	470	470	470	470	470
Item Volume	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00	392.00
Item Volume	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87	170.87
Item Volume	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00
Item Volume	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00	72.00
Item Volume	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40	60.40
Energy Production	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69	228.69
Average Energy	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17	143.17
Firm Energy	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52	63.52
Secondary Energy	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Unit Benefit Value	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45
Firm Peak Power	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270
Firm Energy	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Secondary Energy	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39	10.39
Firm Peak Power	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80	3.80
Firm Energy	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80
Secondary Energy	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99	15.99
Total	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69	181.69
Investment Cost	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52	25.52
Civil Facilities	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21	207.21
Hydral. and Ele. Equip. Eq.	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35
Total	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06	231.06
Annual Cost	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35	18.35
Civil Facilities	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35
Hydral. and Ele. Equip. Eq.	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26	21.26
Total	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50	6.50
Annual Surplus Benefit (B-C)	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75
Benefit Cost Ratio (B/C)	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148	0.148
Unit Annual Cost (Firm)	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094	0.094
Unit Annual Cost (Average)	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043	0.043

Table 9-10(2-2) Comparison Study on Reservoir Capacity

Description	Bayern		FMS		Layoff		H.W.L. = 750m		H.W.L. = 700m		H.W.L. = 550.00m		by Mixed Alternative		Thermal Power Plant		Total
	750m	700m	750m	700m	750m	700m	750m	700m	750m	700m	750m	700m	750m	700m	750m	700m	
High Water Level	720.00	536.00	717.00	536.00	717.00	536.00	717.00	536.00	717.00	536.00	717.00	536.00	717.00	536.00	717.00	536.00	0.00
Normal Water Level	708.67	527.00	705.00	527.00	705.00	527.00	705.00	527.00	705.00	527.00	705.00	527.00	705.00	527.00	705.00	527.00	1,250.00
Low Water Level	684.00	510.00	680.00	510.00	680.00	510.00	680.00	510.00	680.00	510.00	680.00	510.00	680.00	510.00	680.00	510.00	
Available Drawdown	34.00	17.00	32.00	17.00	32.00	17.00	32.00	17.00	32.00	17.00	32.00	17.00	32.00	17.00	32.00	17.00	
On-site Storage Capacity	76.00	17.70	75.00	17.70	75.00	17.70	75.00	17.70	75.00	17.70	75.00	17.70	75.00	17.70	75.00	17.70	
Electric Storage Capacity	54.00	11.40	53.00	11.40	53.00	11.40	53.00	11.40	53.00	11.40	53.00	11.40	53.00	11.40	53.00	11.40	
Dam Type	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Dam Height	125	84	125	84	125	84	125	84	125	84	125	84	125	84	125	84	
Dam Volume	3,900	420	3,900	420	3,900	420	3,900	420	3,900	420	3,900	420	3,900	420	3,900	420	
Tailwater Level	560.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	
Electric Load	150.27	140.80	148.93	140.70	148.93	140.70	148.93	140.70	148.93	140.70	148.93	140.70	148.93	140.70	148.93	140.70	
Installed Capacity	33.00	42.00	31.00	40.00	31.00	40.00	31.00	40.00	31.00	40.00	31.00	40.00	31.00	40.00	31.00	40.00	
Firm Capacity	42.00	51.00	39.00	46.00	39.00	46.00	39.00	46.00	39.00	46.00	39.00	46.00	39.00	46.00	39.00	46.00	
Firm Peak Power	33.80	50.00	33.80	47.00	33.80	47.00	33.80	47.00	33.80	47.00	33.80	47.00	33.80	47.00	33.80	47.00	
Energy Production	182.70	227.50	171.40	221.00	171.40	221.00	171.40	221.00	171.40	221.00	171.40	221.00	171.40	221.00	171.40	221.00	
Average Energy	89.10	107.00	81.20	102.60	81.20	102.60	81.20	102.60	81.20	102.60	81.20	102.60	81.20	102.60	81.20	102.60	
Firm Energy	50.80	120.50	214.10	90.20	116.40	208.60	96.00	115.90	201.90	96.00	115.90	201.90	96.00	115.90	201.90	96.00	
Unit Benefit Value	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	180,450	
Firm Energy	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	
Secondary Energy	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	
Benefit	6.00	14.44	5.54	8.09	5.27	7.69	13.63	5.27	7.69	13.63	5.27	7.69	13.63	5.27	7.69	13.63	
Firm Peak Power	2.38	5.20	2.16	2.72	4.88	1.99	2.60	4.99	1.72	2.38	4.10	1.56	2.26	3.81	4.07	3.81	
Firm Energy	2.02	2.59	1.94	2.55	4.49	1.85	2.50	4.35	1.75	2.45	4.21	1.85	2.41	4.05	4.21	4.05	
Secondary Energy	10.21	14.04	24.25	9.64	13.36	23.00	9.11	12.79	21.90	8.26	11.89	20.15	7.85	11.27	18.92	18.92	
Investment Cost	108.02	72.02	180.05	101.01	71.24	172.25	84.28	70.64	164.93	87.48	69.98	157.45	82.08	69.38	151.47	151.47	
Civil Facilities	16.41	23.40	41.31	17.54	22.65	40.19	16.35	21.16	36.51	15.35	21.70	36.54	14.86	20.84	35.70	35.70	
Hydro. and Elec. Mech. Eq.	126.43	86.43	221.86	118.56	93.86	212.43	115.64	92.90	203.44	102.82	91.17	194.00	94.94	90.22	187.16	187.16	
Annual Cost	10.91	7.27	18.18	10.20	7.20	17.40	9.52	7.14	16.66	8.84	7.07	15.90	8.29	7.01	15.30	15.30	
Civil Facilities	2.10	2.87	4.77	2.00	2.98	4.58	1.95	2.83	4.39	1.75	2.42	4.17	1.89	2.36	4.07	4.07	
Hydro. and Elec. Mech. Eq.	13.01	9.94	22.95	12.20	9.78	21.98	11.39	9.68	21.05	10.58	9.46	20.07	9.38	9.38	19.31	19.31	
Total	2.80	4.10	1.30	-2.56	3.56	1.02	-2.28	3.13	0.85	2.32	2.40	0.08	-2.34	1.89	0.44	0.44	
Annual Surplus Benefit(B+C)	0.79	1.41	1.06	0.79	1.05	0.80	1.32	1.04	0.78	1.25	1.00	0.77	1.20	0.88	0.88	0.88	
Benefit Cost Ratio(B/C)	0.093	0.117	0.150	0.096	0.120	0.152	0.098	0.122	0.163	0.139	0.110	0.139	0.170	0.110	0.110	0.110	
Unit Annual Cost (Firm)	0.071	0.044	0.056	0.071	0.044	0.056	0.071	0.044	0.056	0.071	0.044	0.056	0.071	0.044	0.056	0.056	
Unit Annual Cost (Average)	0.071	0.044	0.056	0.071	0.044	0.056	0.071	0.044	0.056	0.071	0.044	0.056	0.071	0.044	0.056	0.056	

Table 9-10(3-1) Comparison Study on Reservoir Capacity

Reservoir Chain Site	Bayern Project Tailrace Type Underpro. Pns Layout H.W.L. 750m 700m 750m 530.00m				by Missed Alternative Thermal Power Plant				Total	Bayern 75°C	Total	Bayern 75°C	Total	Bayern 75°C	Total
	Layout 75°C	Bayern 75°C	Bayern 70°C	Bayern 70°C	Total	Bayern 75°C	Bayern 70°C	Total							
High Water Level	750.00	530.00	745.00	530.00	740.00	530.00	735.00	530.00	730.00	735.00	530.00	730.00	735.00	530.00	730.00
Normal Water Level	725.50	528.50	725.50	528.50	725.50	528.50	718.87	528.50	718.33	528.50	528.50	712	528.50	528.50	712
Low Water Level	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685	527.00	685.00	527.00	685
Available Drawdown	64.00	3.00	64.00	3.00	64.00	3.00	64.00	3.00	64.00	3.00	39	3.00	64.00	3.00	39
Gross Storage Capacity	169.00	7.30	169.00	7.30	169.00	7.30	116.00	7.30	116.00	7.30	102	7.30	116.00	7.30	102
Effective Storage Capacity	142.00	1.00	142.00	1.00	142.00	1.00	96.00	1.00	96.00	1.00	82	1.00	96.00	1.00	82
Chain Type	Roadfill	Con-Gr.	Roadfill	Con-Gr.	Roadfill	Con-Gr.	Roadfill	Con-Gr.	Roadfill	Con-Gr.	Roadfill	Con-Gr.	Roadfill	Con-Gr.	Roadfill
Dam Height	155	74	145	74	145	74	140	74	140	74	136	74	140	74	136
Dam Volume	8,500	196	7,200	196	6,144	196	5,400	195	4,800	195	4,300	195	3,900	195	3,500
Tailwater Level	500.00	392.00	500.00	392.00	500.00	392.00	500.00	392.00	500.00	392.00	500.00	392.00	500.00	392.00	500.00
Effective Head	189.87	131.00	189.87	131.00	189.87	131.00	179.47	130.90	178.70	130.80	177.90	130.80	177.20	130.80	176.50
Maximum Discharge	48.00	58.00	48.00	58.00	48.00	58.00	48.00	58.00	48.00	58.00	38.00	58.00	48.00	58.00	38.00
Installed Capacity	80.00	65.00	80.00	65.00	80.00	65.00	80.00	65.00	80.00	65.00	57.00	65.00	80.00	65.00	57.00
Firm Peak Power	67.40	62.90	67.40	62.90	67.40	62.90	67.40	62.90	67.40	62.90	48.50	62.90	67.40	62.90	48.50
Energy Production	786.80	227.00	489.90	257.70	489.90	257.70	469.30	237.00	462.70	227.00	227.00	462.70	227.00	462.70	227.00
Average Energy	168.50	139.20	168.50	139.20	168.50	139.20	168.50	139.20	168.50	139.20	139.20	168.50	168.50	139.20	139.20
Firm Energy	88.30	87.80	88.30	87.80	88.30	87.80	88.30	87.80	88.30	87.80	87.80	88.30	88.30	87.80	87.80
Secondary Energy	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Unit Benefit Value	100.45	160.45	100.45	160.45	100.45	160.45	100.45	160.45	100.45	160.45	160.45	100.45	160.45	100.45	160.45
Firm Peak Power	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270
Firm Energy	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Secondary Energy	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019	0.0019
Benefit	11.60	10.82	22.42	10.84	22.42	10.84	19.69	9.92	17.97	8.35	8.35	17.97	9.92	8.35	8.35
Firm Peak Power	3.66	4.10	3.66	4.10	3.66	4.10	3.66	4.10	3.66	4.10	3.66	3.66	3.66	4.10	3.66
Firm Energy	2.12	1.89	4.01	2.22	4.01	2.22	2.09	2.34	4.34	2.31	2.31	4.34	2.09	2.31	2.31
Secondary Energy	16.19	16.41	16.19	16.41	16.19	16.41	16.19	16.41	16.19	16.41	16.19	16.19	16.19	16.41	16.19
Total	186.07	185.22	371.29	185.22	371.29	185.22	371.29	185.22	371.29	185.22	185.22	371.29	185.22	185.22	185.22
Cost Facilities	27.05	27.13	54.18	27.13	54.18	27.13	54.18	27.13	54.18	27.13	27.13	54.18	27.13	27.13	27.13
Material and Est-Mech Eq	213.16	62.43	275.59	62.43	275.59	62.43	275.59	62.43	275.59	62.43	62.43	275.59	62.43	62.43	62.43
Annual Cost	16.79	5.59	22.38	16.89	22.38	16.89	22.38	16.89	22.38	16.89	16.89	22.38	16.89	16.89	16.89
Cost Facilities	3.06	3.06	6.12	3.06	6.12	3.06	6.12	3.06	6.12	3.06	3.06	6.12	3.06	3.06	3.06
Hydro. and Est.-Mech Eq	21.66	6.66	28.32	6.66	28.32	6.66	28.32	6.66	28.32	6.66	6.66	28.32	6.66	6.66	6.66
Total	-3.69	7.73	4.04	-2.41	4.04	-2.41	4.04	-2.41	4.04	-2.41	-2.41	4.04	-2.41	-2.41	-2.41
Annual Surplus Benefit(B-C)	0.83	1.89	1.13	0.86	1.13	0.86	1.13	0.86	1.13	0.86	0.86	1.13	0.86	0.86	0.86
Benefit Cost Ratio(B/C)	0.130	0.082	0.099	0.127	0.085	0.099	0.127	0.085	0.099	0.127	0.101	0.127	0.085	0.101	0.101
Unit Annual Cost (Firm)	0.092	0.039	0.052	0.075	0.038	0.052	0.075	0.038	0.052	0.075	0.052	0.075	0.038	0.052	0.052
Unit Annual Cost (Average)	0.092	0.039	0.052	0.075	0.038	0.052	0.075	0.038	0.052	0.075	0.052	0.075	0.038	0.052	0.052

Table 9-10(3-2) Comparison Study on Reservoir Capacity

Description	Bayram Project Tailrace Type Underspill				FWS Layoff at N.W. 5750' x 700m with Bayram N.W.L. = 530.00m				By Mixed Alternative Thermal Reservoir				Total	
	Bayram 720C	Bayram 710C	Bayram 700C	Bayram 700C	Bayram 720C	Bayram 710C	Bayram 700C	Bayram 700C	Bayram 720C	Bayram 710C	Bayram 700C	Bayram 700C		Bayram 700C
Normal Water Level	720.00	715.00	710.00	710.00	720.00	715.00	710.00	710.00	720.00	715.00	710.00	710.00	710.00	710.00
High Water Level	708.67	708.33	708.00	708.00	708.67	708.33	708.00	708.00	708.67	708.33	708.00	708.00	708.00	708.00
Low Water Level	686.00	686.00	686.00	686.00	686.00	686.00	686.00	686.00	686.00	686.00	686.00	686.00	686.00	686.00
Available Drawdown	34.00	34.00	34.00	34.00	34.00	34.00	34.00	34.00	34.00	34.00	34.00	34.00	34.00	34.00
Gross Storage Capacity	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00
Effective Storage Capacity	36.00	36.00	36.00	36.00	36.00	36.00	36.00	36.00	36.00	36.00	36.00	36.00	36.00	36.00
Dam Type	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem	0 Problem
Dam Height	3.26	3.26	3.26	3.26	3.26	3.26	3.26	3.26	3.26	3.26	3.26	3.26	3.26	3.26
Dam Volume	3,900	3,900	3,900	3,900	3,900	3,900	3,900	3,900	3,900	3,900	3,900	3,900	3,900	3,900
Spillway Level	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00
Spillway Capacity	169.27	169.27	169.27	169.27	169.27	169.27	169.27	169.27	169.27	169.27	169.27	169.27	169.27	169.27
Reservoir Discharge	33.00	33.00	33.00	33.00	33.00	33.00	33.00	33.00	33.00	33.00	33.00	33.00	33.00	33.00
Reservoir Capacity	44.00	44.00	44.00	44.00	44.00	44.00	44.00	44.00	44.00	44.00	44.00	44.00	44.00	44.00
Firm Peak Power	39.00	39.00	39.00	39.00	39.00	39.00	39.00	39.00	39.00	39.00	39.00	39.00	39.00	39.00
Energy Production	204.90	204.90	204.90	204.90	204.90	204.90	204.90	204.90	204.90	204.90	204.90	204.90	204.90	204.90
Average Energy	100.10	100.10	100.10	100.10	100.10	100.10	100.10	100.10	100.10	100.10	100.10	100.10	100.10	100.10
Firm Energy	104.90	104.90	104.90	104.90	104.90	104.90	104.90	104.90	104.90	104.90	104.90	104.90	104.90	104.90
Secondary Energy	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450
Unit Benefit Value	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027
Firm Peak Power	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022
Firm Energy	6.71	6.71	6.71	6.71	6.71	6.71	6.71	6.71	6.71	6.71	6.71	6.71	6.71	6.71
Secondary Energy	2.66	2.66	2.66	2.66	2.66	2.66	2.66	2.66	2.66	2.66	2.66	2.66	2.66	2.66
Total	11.62	11.62	11.62	11.62	11.62	11.62	11.62	11.62	11.62	11.62	11.62	11.62	11.62	11.62
Investment Cost	19.71	19.71	19.71	19.71	19.71	19.71	19.71	19.71	19.71	19.71	19.71	19.71	19.71	19.71
Civil Facilities	19.51	19.51	19.51	19.51	19.51	19.51	19.51	19.51	19.51	19.51	19.51	19.51	19.51	19.51
Hydro. and Ele.-Mech.Eq	129.22	129.22	129.22	129.22	129.22	129.22	129.22	129.22	129.22	129.22	129.22	129.22	129.22	129.22
Total	158.73	158.73	158.73	158.73	158.73	158.73	158.73	158.73	158.73	158.73	158.73	158.73	158.73	158.73
Annual Cost	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08
Civil Facilities	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22
Hydro. and Ele.-Mech.Eq	13.30	13.30	13.30	13.30	13.30	13.30	13.30	13.30	13.30	13.30	13.30	13.30	13.30	13.30
Total	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08
Annual Surplus Benefit(B/C)	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87
Benefit Cost Ratio(B/C)	0.132	0.132	0.132	0.132	0.132	0.132	0.132	0.132	0.132	0.132	0.132	0.132	0.132	0.132
Unit Annual Cost (Firm)	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065
Unit Annual Cost (Average)	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065	0.065

Table 9-11(5) Cost Estimate of Alternative Plan for Bayram Reservoir Water Level

Unit: 10³ US\$

Bayram Project Tailrace Undergr. P/S Layout H.W.L. = 730m L.W.L. = 688m-725m With Baglik H.W.L. = 530.00m

Description	Dam Site Layout Type	Bayram						
		730-688	730-700	730-705	730-710	730-715	730-720	730-725
High Water Level (m)		730	730	730	730	730	730	730
Reservoir Area (km²)		2.83	2.83	2.83	2.83	2.83	2.83	2.83
Dam Volume (10⁶m³)		4,800	4,800	4,800	4,800	4,800	4,800	4,800
Dam Height (m)		135	135	135	135	135	135	135
Maximum Head (m)		200	200	200	200	200	200	200
Maximum Discharge (m³/s)		38	35	33	31	28	26	23
Relocation Road		9,758	9,758	9,758	9,758	9,758	9,758	9,758
Camp Facilities		800	800	800	800	800	800	800
Land Acquisition		1,878	1,878	1,878	1,878	1,878	1,878	1,878
Civil Work		70,643	69,835	69,228	68,438	67,686	67,014	66,327
Diversion		2,421	2,421	2,421	2,421	2,421	2,421	2,421
Care of River		1,082	1,082	1,082	1,082	1,082	1,082	1,082
Dam		36,938	36,938	36,938	36,938	36,938	36,938	36,938
Spillway		7,346	7,346	7,346	7,346	7,346	7,346	7,346
Outlet Works		1,018	1,018	1,018	1,018	1,018	1,018	1,018
Intake		912	754	649	579	473	403	263
Headrace Tunnel		0	0	0	0	0	0	0
Surge Tank		0	0	0	0	0	0	0
Penstock		465	431	407	383	348	324	288
Access Tunnels		3,880	3,880	3,880	3,990	3,880	3,880	3,880
Power House		2,664	2,600	2,471	2,375	2,215	2,086	1,926
Tailrace Tunnel		13,655	13,205	12,755	12,154	11,704	11,254	10,504
Switchyard		161	161	161	161	151	161	161
Pre-Subtotal		83,079	82,371	81,664	80,874	80,122	79,450	78,363
Contingency (15%)		12,160	12,074	11,968	11,849	11,737	11,636	11,473
Eng. and Adm. (10%)		9,338	9,257	9,175	9,085	8,998	8,921	8,796
Sub Total		104,597	103,702	102,807	101,808	100,857	100,006	98,632
I.D.C. (9.5%/Year)		20,897	20,718	20,540	20,340	20,150	19,980	19,705
Total		125,494	124,421	123,347	122,147	121,007	119,987	118,337
Hydraulic Equipment		4,652	4,351	4,146	3,968	3,701	3,522	3,227
Spillway		856	856	856	856	856	856	856
Outlet Works		528	528	528	528	528	528	528
Intake Gate		640	529	456	406	332	283	185
Penstock		2,049	1,893	1,789	1,685	1,529	1,424	1,267
Draft Gate		108	99	94	86	78	74	65
Tailrace Gate		54	50	47	44	40	37	33
Pre-Subtotal		4,234	3,965	3,769	3,607	3,364	3,202	2,934
Contingency (10%)		423	396	377	361	336	320	293
Electro-Mechanical Equipment		14,290	13,759	13,294	12,596	11,933	11,426	10,612
Equipment		13,572	13,104	12,661	11,996	11,041	10,632	10,106
Contingency (5%)		679	655	633	600	552	544	505
Eng. and Adm. (10%)		1,831	1,811	1,744	1,656	1,529	1,495	1,384
Sub Total		20,799	19,921	19,184	18,220	16,823	16,443	15,223
I.D.C. (9.5%/Year)		1,118	1,071	1,031	980	904	884	818
Total		21,917	20,992	20,215	19,200	17,727	17,327	16,041
Grand Total		147,411	145,413	143,562	141,348	138,735	137,313	134,378

Unit: 10³ US\$

Tailrace Type Underground Powerhouse Layout Bayram H.W.L. = 735m L.W.L. = 688-730m and Baglik H.W.L. = 530m

Description	Dam Site Layout Type	Bayram						
		530 730-688	530 730-700	530 730-705	530 730-710	530 730-715	530 730-720	530 730-725
High Water Level (m)		530	530	530	530	530	530	530
Reservoir Area (km²)		0.37	0.37	0.37	0.37	0.37	0.37	0.37
Dam Volume (10⁶m³)		195	195	195	195	195	195	195
Dam Height (m)		74	74	74	74	74	74	74
Maximum Head (m)		138	138	138	138	138	138	138
Maximum Discharge (m³/s)		45	41	40	38	35	32	29
Relocation Road		6,759	6,759	6,759	6,759	6,759	6,759	6,759
Camp Facilities		800	800	800	800	800	800	800
Land Acquisition		598	598	598	598	598	598	598
Civil Work		24,887	24,080	24,034	23,662	23,244	22,826	22,084
Diversion		0	0	0	0	0	0	0
Care of River		0	0	0	0	0	0	0
Dam		9,983	9,583	9,583	9,583	9,583	9,583	9,583
Spillway		780	780	780	780	780	780	780
Outlet Works		0	0	0	0	0	0	0
Intake		36	33	32	31	30	27	26
Headrace Tunnel		0	0	0	0	0	0	0
Surge Tank		0	0	0	0	0	0	0
Penstock		335	306	299	285	264	242	221
Access Tunnels		2,478	2,478	2,478	2,478	2,478	2,478	2,478
Power House		3,110	2,882	2,844	2,730	2,579	2,427	2,275
Tailrace Tunnel		8,266	7,617	7,617	7,374	7,131	6,888	6,321
Switchyard		0	0	0	0	0	0	0
Pre-Subtotal		33,144	32,237	32,191	31,819	31,401	30,983	30,240
Contingency (15%)		4,882	4,746	4,739	4,683	4,621	4,558	4,445
Eng. and Adm. (10%)		3,743	3,638	3,633	3,590	3,542	3,494	3,409
Sub Total		41,769	40,621	40,563	40,093	39,564	39,035	38,096
I.D.C. (9.5%/Year)		10,433	10,145	10,132	10,014	9,882	9,750	9,516
Total		52,201	50,766	50,695	50,107	49,447	48,785	47,611
Hydraulic Equipment		2,668	2,525	2,488	2,418	2,311	2,200	2,093
Spillway		870	870	870	870	870	870	870
Outlet Works		0	0	0	0	0	0	0
Intake Gate		152	141	137	134	127	116	109
Penstock		1,248	1,141	1,114	1,062	982	903	823
Draft Gate		105	95	93	88	81	74	67
Tailrace Gate		53	48	47	45	41	38	34
Pre-Subtotal		2,425	2,265	2,262	2,198	2,101	2,000	1,903
Contingency (10%)		243	230	226	220	210	200	190
Electro-Mechanical Equipment		17,814	16,504	16,418	16,055	15,281	14,590	13,589
Equipment		16,775	15,718	15,636	15,290	14,553	13,895	12,942
Contingency (5%)		839	786	782	765	728	695	647
Eng. and Adm. (10%)		2,028	1,903	1,891	1,847	1,759	1,679	1,568
Sub Total		22,310	20,932	20,797	20,320	19,352	18,439	17,251
I.D.C. (9.5%/Year)		1,264	1,186	1,178	1,151	1,096	1,046	977
Total		23,573	22,117	21,975	21,471	20,448	19,515	18,228
Grand Total		75,774	72,885	72,670	71,578	69,895	68,300	65,839

Table 9-12(1) Comparison Study on Bayram Reservoir Water Level

Description Dam Site	Bayram Project Tailrace Undergr. P.S. Layout H.W.L.=750m L.W.L.=686-745m With Baglik H.W.L.=550.00m			By Mixed Alternative Thermal Power Plant		
	Bayram 750-686	Baglik 530C	Total	Bayram 750-705	Baglik 530C	Total
High Water Level	750.00	530.00		750.00	530.00	
Normal Water Level	728.67	528.50		728.67	528.50	
Low Water Level	688.00	527.00		705.00	527.00	
Available Drawdown	64.00	3.00		45.00	3.00	
Gross Storage Capacity	169.00	7.30		169.00	7.30	
Effective Storage Capacity	149.00	1.00		123.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	155	74		155	74	
Dam Volume	8,500	195		8,500	195	
Tailwater Level	530.00	392.00		530.00	392.00	
Effective Head	189.67	131.00		195.90	130.90	
Maximum Discharge	49.00	58.00		45.00	54.00	
Installed Capacity	80.00	65.00	145.00	76.00	61.00	137.00
Firm Peak Power	67.40	62.90	130.30	66.40	58.00	124.40
Energy Production						
Average Energy	266.80	227.00	493.80	266.00	223.00	489.00
Firm Energy	168.50	139.20	307.70	166.61	127.02	293.63
Secondary Energy	98.30	87.80	186.10	99.39	95.98	195.37
Unit Benefit Value	0.00	0.00		0.00	0.00	
Firm Peak Power	180.45	180.45		180.45	180.45	
Firm Energy	0.0270	0.0270		0.0270	0.0270	
Secondary Energy	0.0219	0.0219		0.0219	0.0219	
Benefit						
Firm Peak Power	11.60	10.82	22.42	11.43	9.98	21.41
Firm Energy	4.47	3.69	8.17	4.42	3.37	7.79
Secondary Energy	2.12	1.89	4.01	2.14	2.07	4.21
Total	18.19	16.41	34.60	17.99	15.42	33.41
Investment Cost						
Civil Facilities	195.64	55.30	240.94	182.39	54.32	236.71
Hydrau and Ele. Mech Eq	27.09	27.13	54.22	25.95	26.11	52.06
Total	212.73	82.43	295.16	208.34	80.43	288.77
Annual Cost						
Civil Facilities	18.75	5.59	24.34	18.42	5.49	23.91
Hydrau and Ele. Mech Eq	3.09	3.09	6.18	2.96	2.98	5.93
Total	21.84	8.68	30.52	21.38	8.46	29.84
Annual Surplus Benefit(B-C)	-3.65	7.73	4.08	-3.99	6.96	3.57
Benefit Cost Ratio(B/C)	0.83	1.89	1.13	0.84	1.82	1.12
Unit Annual Cost (Firm)	0.130	0.082	0.099	0.128	0.087	0.102
Unit Annual Cost (Average)	0.062	0.038	0.062	0.062	0.038	0.061

Description Dam Site	Bayram Project Tailrace Undergr. P.S. Layout H.W.L.=750m L.W.L.=686-745m With Baglik H.W.L.=530.00m			By Mixed Alternative Thermal Power Plant		
	Bayram 750-725	Baglik 530C	Total	Bayram 750-730	Baglik 530C	Total
High Water Level	750.00	530.00		750.00	530.00	
Normal Water Level	728.67	528.50		748.33	528.50	
Low Water Level	725.00	527.00		735.00	527.00	
Available Drawdown	25.00	3.00		15.00	3.00	
Gross Storage Capacity	169.00	7.30		169.00	7.30	
Effective Storage Capacity	81.00	1.00		67.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	155	74		155	74	
Dam Volume	8,500	195		8,500	195	
Tailwater Level	530.00	392.00		530.00	392.00	
Effective Head	202.47	130.80		205.60	130.70	
Maximum Discharge	38.00	44.00		35.00	42.00	
Installed Capacity	68.00	49.00	115.00	61.00	47.00	108.00
Firm Peak Power	58.61	48.00	106.61	54.70	46.00	100.70
Energy Production						
Average Energy	259.50	212.00	471.50	253.90	208.40	462.30
Firm Energy	141.79	126.12	267.91	128.90	109.70	238.60
Secondary Energy	117.71	106.88	224.59	125.00	108.70	233.70
Unit Benefit Value						
Firm Peak Power	180.450	180.450		180.450	180.450	
Firm Energy	0.0270	0.0270		0.0270	0.0270	
Secondary Energy	0.0219	0.0219		0.0219	0.0219	
Benefit						
Firm Peak Power	10.09	8.26	18.35	9.41	7.92	17.33
Firm Energy	3.76	2.79	6.55	3.42	2.67	6.09
Secondary Energy	2.53	2.30	4.84	2.69	2.28	4.97
Total	16.38	13.35	29.73	15.53	12.86	28.39
Investment Cost						
Civil Facilities	178.72	52.07	230.79	177.56	51.35	228.91
Hydrau and Ele. Mech Eq	23.56	22.93	46.49	22.22	21.46	43.68
Total	202.28	75.00	277.28	199.78	72.81	272.59
Annual Cost						
Civil Facilities	18.05	5.26	23.31	17.93	5.19	23.12
Hydrau and Ele. Mech Eq	2.69	2.61	5.30	2.53	2.56	5.09
Total	20.74	7.87	28.61	20.47	7.75	28.21
Annual Surplus Benefit(B-C)	-4.35	5.46	1.13	-4.94	5.12	0.18
Benefit Cost Ratio(B/C)	0.79	1.70	1.04	0.76	1.66	1.01
Unit Annual Cost (Firm)	0.145	0.075	0.115	0.159	0.077	0.123
Unit Annual Cost (Average)	0.063	0.037	0.061	0.058	0.036	0.061

Table 9-13 Outline of Alternative Plan for Bağlık Reservoir Water Level

Bayram Project Tailrace Type Undergr. P/S Layout H.W.L.=740m L.W.L.=686m With Bağlık L.W.L.=527-569m

Reservoir	Dam Site Layout	Bayram	Bayram	Bayram	Bayram	Bayram
		740M/P	740M/P	740M/P	740A	740A
Catchment Area	KM ²	1,159	1,159	1,159	1,159	1,159
Annual Inflow	M ³ /S	19.20	19.20	19.20	19.20	19.20
High Water Level	M	740.00	740.00	740.00	740.00	740.00
Normal Water Level	M	722.00	722.00	722.00	722.00	722.00
Low Water Level	M	686.00	686.00	686.00	686.00	686.00
Available Drawdown	M	54.00	54.00	54.00	54.00	54.00
Gross Capacity	10 ⁶ M ³	133.00	133.00	133.00	133.00	133.00
Effective Capacity	10 ⁶ M ³	113.00	113.00	113.00	113.00	113.00
Dam						
Type		Rockfill	Rockfill	Rockfill	Rockfill	Rockfill
Height from Found.	M	145	145	145	145	145
Crest Length	M	415	415	415	415	415
Volume	10 ³ M ³	6,144	6,144	6,144	6,144	6,144
Headrace Tunnel						
Type						
Diameters	M					
Length	M					
Penstock						
Type		Tunnel	Tunnel	Tunnel	Tunnel	Tunnel
Diameters	M	3.3	3.3	3.3	3.3	3.3
Length	M	268	268	268	294	294
Powerhouse						
Type		Undergr.	Undergr.	Undergr.	Undergr.	Undergr.
Tailrace Tunnel						
Type		Non-Pre.	Non-Pre.	Non-Pre.	Non-Pre.	Non-Pre.
Diameters	M	4.6	4.6	4.6	4.6	4.6
Length (Tunnel)	M	4,550	4,550	4,550	6,700	6,700
(Channel)	M					
Firm Discharge	M ³ /S	10.70	10.70	10.70	10.70	10.70
Maximum Discharge	M ³ /S	43.00	43.00	43.00	43.00	43.00
Fall Water Level	M	570.00	570.00	570.00	550.00	550.00
Gross Head						
Maximum Head	M	170.00	170.00	170.00	190.00	190.00
Normal Head	M	152.00	152.00	152.00	172.00	172.00
Minimum Head	M	118.00	115.00	118.00	138.00	138.00
Loss of Head	M	6.40	6.40	6.40	8.10	8.10
Effective Head						
Maximum	M	163.60	163.60	163.60	181.90	181.90
Normal	M	145.60	145.60	145.60	163.90	163.90
Minimum	M	109.60	109.60	109.60	127.90	127.90
Installed Capacity	MW	54	54	54	60	60
Firm Peak Power	MW	44.8	44.8	44.8	51.4	51.4
Annual Energy						
Average	GVh	198.5	198.5	198.5	223.3	223.3
Firm	GVh	113.2	113.2	113.2	126.4	126.4
Secondary	GVh	85.3	85.3	85.3	57.7	57.7

Baglık Project Tailrace Type Underground Powerhouse Layout

Reservoir	Dam Site Layout	Baglık	Baglık	Baglık	Baglık	Baglık
		740M/P	740M/P	740M/P	740A	740A
Catchment Area	KM ²	1,509	1,509	1,509	1,509	1,509
Annual Inflow	M ³ /S	24.90	24.90	24.90	24.90	24.90
High Water Level	M	570.00	570.00	570.00	550.00	550.00
Normal Water Level	M	555.67	563.33	569.50	538.50	548.00
Low Water Level	M	527.00	550.00	569.00	527.00	548.00
Available Drawdown	M	43.00	20.00	1.00	23.00	2.00
Gross Capacity	10 ⁶ M ³	36.40	36.40	36.40	17.70	17.70
Effective Capacity	10 ⁶ M ³	30.10	18.70	1.00	11.40	1.00
Dam						
Type		Con-gra.	Con-gra.	Con-gra.	Con-gra.	Con-gra.
Height from Found.	M	114	114	114	94	94
Crest Length	M	284	284	284	240	240
Volume	10 ³ M ³	680	680	680	420	420
Headrace Tunnel						
Type						
Diameters	M					
Length	M					
Penstock						
Type		Tunnel	Tunnel	Tunnel	Tunnel	Tunnel
Diameters	M	3.8	3.7	3.8	3.7	3.6
Length	M	213	213	213	213	213
Powerhouse						
Type		Undergr.	Undergr.	Undergr.	Undergr.	Undergr.
Tailrace Tunnel						
Type		Hosesho.	Hosesho.	Hosesho.	Hosesho.	Hosesho.
Diameters	M	5.1	5.0	4.9	5.0	4.9
Length (Tunnel)	M	4,454	4,454	4,454	4,454	4,454
(Channel)	M					
Firm Discharge	M ³ /S	14.30	13.80	13.00	13.50	13.00
Maximum Discharge	M ³ /S	57.00	55.00	52.00	54.00	52.00
Fall Water Level	M	392.00	392.00	392.00	392.00	392.00
Gross Head						
Maximum Head	M	178.00	178.00	178.00	158.00	158.00
Normal Head	M	163.67	171.33	177.50	146.50	157.00
Minimum Head	M	135.00	158.00	177.00	135.00	158.00
Loss of Head	M	5.50	5.60	5.60	5.60	5.60
Effective Head						
Maximum	M	172.50	172.40	172.40	152.40	152.40
Normal	M	158.17	165.73	171.90	143.90	151.40
Minimum	M	129.50	152.40	171.40	129.40	150.40
Installed Capacity	MW	78	79	77	66	63
Firm Peak Power	MW	67.6	75.5	75.0	59.8	67.6
Annual Energy						
Average	GVh	282.1	290.4	288.6	250.5	252.1
Firm	GVh	163.7	163.7	164.3	139.0	147.9
Secondary	GVh	118.4	126.7	124.4	111.5	104.2

Table 9-14 Cost Estimate of Alternative Plan for Bağlık Reservoir Water Level

Bayram Project Tailrace Type Undergro. P/S Layout H.W.L.=740m L.W.L=688m With Bağlık L.W.L=527-559m Unit:10*3US\$

Description	Dam Site Layout Type	Bayram 740M/P	Bayram 740M/P	Bayram 740M/P	Bayram 740A	Bayram 740A
High Water Level (m)		740	740	740	740	740
Reservoir Area (km ²)		3.38	3.38	3.38	3.38	3.38
Dam Volume (10 ⁶ m ³)		6,144	6,144	6,144	6,144	6,144
Dam Height (m)		145	145	145	145	145
Maximum Head (m)		170	170	170	190	190
Maximum Discharge (m ³ /s)		43	43	43	43	43
Relocation Road		11,655	11,655	11,655	11,655	11,655
Camp Facilities		800	800	800	800	800
Land Acquisition		2,242	2,242	2,242	2,242	2,242
Civil Work		76,180	76,180	76,180	80,512	80,512
Diversion		2,421	2,421	2,421	2,421	2,421
Care of River		1,082	1,082	1,082	1,082	1,082
Dam		47,281	47,281	47,281	47,281	47,281
Spillway		7,523	7,523	7,523	7,523	7,523
Outlet Works		1,018	1,018	1,018	1,018	1,018
Intake		1,087	1,087	1,087	1,087	1,087
Headrace Tunnel		0	0	0	0	0
Surge Tank		0	0	0	0	0
Penstock		377	377	377	456	456
Access Tunnels		3,990	3,990	3,990	3,990	3,990
Power House		2,664	2,664	2,664	2,856	2,856
Tailrace Tunnel		8,586	8,586	8,586	12,644	12,644
Switchyard		181	181	181	181	181
Pre-Subtotal		90,878	90,878	90,878	95,209	95,209
Contingency (15%)		13,295	13,295	13,295	13,945	13,945
Eng. and Adm. (10%)		10,193	10,193	10,193	10,691	10,691
Sub Total		114,366	114,366	114,366	119,845	119,845
I.D.C. (9.5%/Year)		22,849	22,849	22,849	23,944	23,944
Total		137,215	137,215	137,215	143,789	143,789
Hydraulic Equipment		4,385	4,385	4,385	4,779	4,779
Spillway		856	856	856	856	856
Outlet Works		528	528	528	528	528
Intake Gate		763	763	763	763	763
Penstock		1,656	1,656	1,656	2,015	2,015
Draft Gate		122	122	122	122	122
Tailrace Gate		61	61	61	61	61
Pre-Subtotal		3,838	3,838	3,838	4,345	4,345
Contingency (10%)		399	399	399	434	434
Electro-Mechanical Equipment		13,956	13,956	13,956	14,501	14,501
Equipment		13,291	13,291	13,291	13,816	13,816
Contingency (5%)		665	665	665	685	691
Eng. and Adm. (10%)		1,834	1,834	1,834	1,928	1,928
Sub Total		20,175	20,175	20,175	21,208	21,208
I.D.C. (9.5%/Year)		1,085	1,085	1,085	1,140	1,140
Total		21,259	21,259	21,259	22,348	22,348
Grand Total		158,474	158,474	158,474	166,137	166,137

Baglık Project Tailrace Type Underground Powerhouse Layout Unit:10*3US\$

Description	Dam Site Layout Type	Baglık 740M/P	Baglık 740M/P	Baglık 740M/P	Baglık 740A	Baglık 740A
High Water Level (m)		570	570	570	550	550
Reservoir Area (km ²)		1.23	1.23	1.23	0.69	0.69
Dam Volume (10 ⁶ m ³)		680	680	680	420	420
Dam Height (m)		114	114	114	94	94
Maximum Head (m)		178	178	178	158	158
Maximum Discharge (m ³ /s)		57	55	52	54	52
Relocation Road		9,603	9,603	9,603	8,043	8,043
Camp Facilities		800	800	800	800	800
Land Acquisition		598	598	598	598	598
Civil Work		52,165	51,810	51,402	38,058	37,783
Diversion		0	0	0	0	0
Care of River		0	0	0	0	0
Dam		34,813	34,813	34,813	21,502	21,502
Spillway		780	780	780	780	780
Outlet Works		0	0	0	0	0
Intake		121	89	26	90	34
Headrace Tunnel		0	0	0	0	0
Surge Tank		0	0	0	0	0
Penstock		530	512	485	451	435
Access Tunnels		2,478	2,478	2,478	2,478	2,478
Power House		3,982	3,982	3,906	3,641	3,641
Tailrace Tunnel		9,481	9,157	8,914	9,157	8,914
Switchyard		0	0	0	0	0
Pre-Subtotal		63,166	62,811	62,403	47,539	47,224
Contingency (15%)		9,358	9,332	9,271	7,041	6,994
Eng. and Adm. (10%)		7,158	7,155	7,108	5,368	5,362
Sub Total		79,771	79,298	78,781	59,979	59,580
I.D.C. (9.5%/Year)		19,925	19,807	19,878	14,582	14,882
Total		99,697	99,105	98,660	74,561	74,462
Hydraulic Equipment		3,913	3,641	3,269	3,432	3,097
Spillway		870	870	870	870	870
Outlet Works		0	0	0	0	0
Intake Gate		514	378	112	383	145
Penstock		1,974	1,908	1,807	1,678	1,618
Draft Gate		133	128	121	126	121
Tailrace Gate		87	65	61	63	61
Pre-Subtotal		3,558	3,345	2,971	3,120	2,815
Contingency (10%)		356	335	297	312	282
Electro-Mechanical Equipment		21,528	21,747	22,513	20,450	20,669
Equipment		20,503	20,712	21,441	19,476	19,685
Contingency (5%)		1,025	1,036	1,072	974	984
Eng. and Adm. (10%)		2,544	2,543	2,578	2,388	2,377
Sub Total		27,966	27,971	28,360	26,271	26,142
I.D.C. (9.5%/Year)		1,585	1,584	1,606	1,488	1,481
Total		29,571	29,555	29,966	27,759	27,623
Grand Total		129,268	128,660	128,626	102,719	102,085

Table 9-15 Comparison Study on alternative Plan for Bağlık Reservoir Water Level

Description	Dem Size	Bayram Project Tailrace Type Undergr. P.I.S. Level H.W.L = 740m L.W.L = 688m With Baylik L.W.L = 627-628m						by Mixed Alternative Thermal Power Plant								
		Bayram TACM/P	Baylik TACM/P	Total	Bayram TACM/P	Baylik TACM/P	Total	Bayram TACM/P	Baylik TACA	Total	Bayram TACA	Baylik TACA	Total			
High Water Level	m	740.00	670.00		740.00	670.00		740.00	670.00		740	670.00		740	670.00	
Normal Water Level	m	722.00	655.87		722.00	653.33		722.00	649.50		722	649.00		722	649.00	
Low Water Level	m	686.00	627.00		686.00	620.00		686.00	619.00		686	618.00		686	618.00	
Available Drawdown	m	54.00	43.00		54.00	20.00		54.00	1.00		54	23.00		54	2.00	
Gross Storage Capacity	m ³ 10 ⁶	133.00	36.40		133.00	36.40		133.00	36.40		133	17.70		133	17.70	
Effective Storage Capacity	m ³ 10 ⁶	113.00	30.10		113.00	18.70		113.00	1.00		113	11.40		113	1.00	
Dam Type		Rockfill	Concrete		Rockfill	Concrete		Rockfill	Concrete		Rockfill	Concrete		Rockfill	Concrete	
Dam Height	m	145	114		145	114		145	114		145	94		145	94	
Dam Volume	m ³	8,144	680		8,144	680		8,144	680		8,144	420		8,144	420	
Tail Water Level	m	570.00	392.00		570.00	392.00		570.00	392.00		550.00	392.00		550.00	392.00	
Effective Head	m	145.60	158.17		145.60	165.73		145.60	171.90		183.86	140.90		183.90	151.40	
Maximum Discharge	m ³ /s	43.00	57.00		43.00	55.00		43.00	57.00		43.00	54.00		43.00	52.00	
Installed Capacity	MW	54.00	78.00	132.00	54.00	79.00	133.00	54.00	77.00	131.00	60.00	86.00	126.00	60.00	86.00	126.00
Firm Peak Power	MW	44.80	87.60	112.40	44.80	75.16	120.26	44.80	75.00	119.90	51.40	59.80	111.20	51.40	67.50	118.90
Energy Production	GWh	153.50	282.13	480.63	153.50	290.40	458.90	153.50	288.62	487.12	223.30	250.50	473.90	223.30	252.15	475.45
Firm Energy	GWh	113.20	183.70	276.90	113.20	163.70	278.90	113.20	164.25	277.45	126.40	129.00	265.40	126.40	147.94	274.34
Secondary Energy	GWh	85.30	118.43	203.73	85.30	126.70	212.00	85.30	124.37	209.67	96.90	121.50	208.40	96.90	104.21	201.11
Unit Benefit Value	US\$/kWh	0.00	0.00		0.00	0.00		0.00	0.00		0.00	0.00		0.00	0.00	
Firm Peak Power	US\$/kW	180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45	
Firm Energy	US\$/MWh	0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270	
Secondary Energy	US\$/kWh	0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219	
Benefit																
Firm Peak Power	US\$/10 ⁶	7.71	11.83	19.54	7.71	12.99	20.70	7.71	12.91	20.62	8.85	10.25	18.14	8.85	11.82	20.47
Firm Energy	US\$/10 ⁶	3.00	4.34	7.35	3.00	4.34	7.35	3.00	4.36	7.36	3.35	4.69	7.04	3.35	4.69	7.28
Secondary Energy	US\$/10 ⁶	1.84	2.56	4.39	1.84	2.73	4.56	1.84	2.68	4.51	2.05	2.40	4.49	2.05	2.74	4.33
Total	US\$/10 ⁶	12.55	18.53	31.08	12.55	20.06	32.61	12.55	19.94	32.48	14.26	16.34	30.67	14.26	17.79	32.08
Investment Cost																
Civil Facilities	US\$/10 ⁶	137.21	99.70	236.91	137.21	99.40	236.62	137.21	98.48	235.69	143.79	74.96	218.75	143.79	74.48	218.27
Hydro and Ele. Mech. Eq.	US\$/10 ⁶	21.26	26.81	48.07	21.26	29.56	50.81	21.26	29.97	51.23	22.35	27.74	50.11	22.35	27.62	49.97
Total	US\$/10 ⁶	158.47	126.51	284.98	158.47	129.06	287.43	158.47	128.45	286.92	166.14	102.72	268.86	166.14	102.10	268.24
Annual Cost																
Civil Facilities	US\$/10 ⁶	13.86	10.07	23.93	13.86	10.01	23.87	13.86	9.94	23.80	14.52	7.67	22.09	14.52	7.52	22.04
Hydro and Ele. Mech. Eq.	US\$/10 ⁶	2.42	3.37	5.79	2.42	3.37	5.79	2.42	3.42	5.84	2.55	3.16	5.71	2.55	3.15	5.70
Total	US\$/10 ⁶	16.28	13.44	29.72	16.28	13.38	29.66	16.28	13.36	29.64	17.07	10.74	27.81	17.07	10.67	27.74
Annual Surplus Benefit (B-C)	US\$/10 ⁶	-3.73	5.09	1.36	-3.73	6.56	2.95	-3.73	6.58	2.85	-2.79	5.65	2.66	-2.78	7.13	4.34
Benefit Cost Ratio (B/C)		0.77	1.38	1.08	0.77	1.50	1.10	0.77	1.49	1.10	0.84	1.53	1.10	0.84	1.67	1.18
Unit Annual Cost (Firm)	US\$/kWh	0.144	0.062	0.107	0.144	0.082	0.107	0.144	0.081	0.107	0.135	0.077	0.105	0.135	0.072	0.101
Unit Annual Cost (Total)	US\$/kWh	0.082	0.045	0.062	0.082	0.045	0.061	0.082	0.061	0.076	0.043	0.059	0.076	0.043	0.056	0.056

Table 9-17 Comparison Study on Optimum Installed Capacity

Tailrace Type Underground Powerhouse Layout Bayram H.W.L.=735m L.W.L.=686m-730m and Baglik H.W.L.=530m

Description Dam Site	Layout	Bayram 6h Peak	Baglik 6h Peak	Total 6h Peak	Bayram 6h Peak	Baglik 6h Peak	Total 6h Peak
High Water Level	m	740.00	530.00		740.00	530.00	
Normal Water Level	m	722.00	528.50		722.00	528.50	
Low Water Level	m	686.00	527.00		686.00	527.00	
Available Drawdown	m	54.00	3.00		54.00	3.00	
Gross Storage Capacity	m ³ *10 ⁶	150.00	7.30		133.00	7.30	
Effective Storage Capacity	m ³ *10 ⁶	130.00	1.00		113.00	1.00	
Dam Type		0 Rockfill	Con-Gra.		Rockfill	Con-Gra.	
Dam Height	m	145	74		145	74	
Dam Volume	m ³	6,144	195		6,144	195	
Tailwater Level	m	530.00	392.00		530.00	392.00	
Effective Head	m	182.90	130.90		182.60	130.70	
Maximum Discharge	m ³ /s	43.00	52.00		32.00	39.00	
Installed Capacity	MW	68.00	59.00	127.00	50.00	44.00	94.00
Firm Peak Power	MW	58.00	56.40	114.40	43.10	41.60	84.70
Energy Production							
Average Energy	GWh	247.90	221.40	469.30	225.59	201.47	427.06
Firm Energy	GWh	141.40	124.20	265.60	141.40	124.20	265.60
Secondary Energy	GWh	106.50	97.20	203.70	84.19	77.27	161.46
Unit Benefit Value		0.00	0.00		0.00	0.00	
Firm Peak Power	US\$/kW	180.45	180.45		180.45	180.45	
Firm Energy	US\$/kWh	0.027	0.027		0.027	0.027	
Secondary Energy	US\$/kWh	0.022	0.022		0.022	0.022	
Benefit							
Firm Peak Power	US\$*10 ⁶	9.98	9.71	19.69	7.42	7.18	14.58
Firm Energy	US\$*10 ⁶	3.75	3.30	7.05	3.75	3.30	7.05
Secondary Energy	US\$*10 ⁶	2.29	2.09	4.39	1.81	1.68	3.48
Total	US\$*10 ⁶	16.03	15.09	31.12	12.98	12.12	25.10
Investment Cost							
Civil Facilities	US\$*10 ⁶	147.74	53.78	201.51	148.60	49.07	195.67
Hydrau. and Ele.-Mech.Eq.	US\$*10 ⁶	24.32	25.69	50.01	20.06	22.21	42.27
Total	US\$*10 ⁶	172.06	79.46	251.52	168.66	71.28	237.93
Annual Cost							
Civil Facilities	US\$*10 ⁶	14.92	5.43	20.35	14.81	4.96	19.76
Hydrau. and Ele.-Mech.Eq.	US\$*10 ⁶	2.77	2.93	5.70	2.29	2.53	4.82
Total	US\$*10 ⁶	17.69	8.36	26.05	17.09	7.49	24.58
Annual Surplus Benefit(B-C)	US\$*10 ⁶	-1.67	6.74	5.07	-4.11	4.63	0.52
Benefit Cost Ratio(B/C)		0.91	1.81	1.19	0.76	1.62	1.02
Unit Annual Cost (Firm)	US\$/kWh	0.125	0.067	0.098	0.121	0.060	0.093
Unit Annual Cost (Average)	US\$/kWh	0.071	0.038	0.058	0.076	0.037	0.058

Table 9-18 Outline of Optimum Development Plan of Çoruh-Berta Project

	Unit	Bayram Project	Bağlık Project	Total
Reservoir				
Catchment Area	km ²	1,159	1,509	
Annual Inflow	m ³ /s	19.20	24.90	
High Water Level	m	740.00	530.00	
Normal Water Level	m	722.00	528.50	
Low Water Level	m	686.00	527.00	
Available Drawdown	m	54.00	3.00	
Gross Capacity	10 ⁶ m ³	133.00	7.30	
Effective Capacity	10 ⁶ m ³	113.00	1.00	
Surface Area	10 ⁶ m ²	3.38	0.37	
Dam				
Type		Rockfill	Con-Gra	
Height from Foundation	m	145	74	
Crest Length	m	415	190	
Volume	10 ³ m ³	6,147	195	
Penstock				
Type		Tunnel	Tunnel	
Diameters	m	3.3	3.6	
Length	m	321	213	
Powerhouse				
Type		Underground	Underground	
Tailrace Tunnel				
Type		Horseshoe	Horseshoe	
Diameters	m	4.6	4.9	
Length (Tunnel)	m	7,930	4,454	
Tail Water Level	m	530.00	392.00	
Gross Head				
Maximum Head	m	210.00	138.00	
Normal Head	m	192.00	136.50	
Minimum Head	m	156.00	135.00	
Loss of Head	m	9.10	5.60	
Effective Head				
Maximum	m	200.90	132.40	
Normal	m	182.90	130.90	
Minimum	m	146.90	129.40	
Firm Discharge	m ³ /s	10.70	13.00	
Maximum Discharge	m ³ /s	43.00	52.00	
Installed Capacity	MW	68	59	127
Number of Unit		1	1	
Firm Peak Power	MW	57.60	56.2	113.8
Annual Energy				
Average	GWh	250.4	225.8	476.2
Firm	GWh	144.9	128.4	273.3
Secondary	GWh	105.5	97.5	203.0
Investment Cost	(10 ⁶ US\$)	172.1	79.5	251.5
Annual Surplus Benefit	(10 ⁶ US\$)	-1.66	6.82	5.15
Benefit - Cost Ratio		0.91	1.82	1.20
Unit Energy Cost	(US\$/kWh)	0.071	0.037	0.055

Table 9-19 Cost Estimate of Optimum Development Plan of Çoruh-Berta Project

Unit: 10³US\$

Description	Bayram Project	Bağlık Project	Total
Relocation Road	11,655	6,759	
Camp Facilities	800	800	
Land Acquisition	2,242	598	
Civil Work	83,113	25,984	
Diversion	2,421	0	
Care of River	1,082	0	
Dam	47,281	9,983	
Spillway	7,523	780	
Outlet Works	1,018	0	
Intake ^{*-1}	1,087	40	
Headrace Tunnel	0	0	
Surge Tank	0	0	
Penstock ^{*-2}	546	376	
Access Tunnels ^{*-3}	3,980	2,478	
Power House ^{*-4}	3,049	3,413	
Tailrace	14,965	8,914	
Switchyard	161	0	
Pre-Subtotal	97,810	34,141	
Contingency (15%)	14,335	5,031	
Eng. and Admi. (10%)	10,990	3,857	
Sub Total	123,136	43,030	
I.D.C. (9.5%/year)	24,601	10,748	
Total	147,737	58,778	206,515
Hydraulic Equip.	5,203	2,884	
Spillway	856	870	
Outlet Works	528	0	
Intake Gate	763	170	
Penstock	2,400	1,400	
Draft Gate	122	121	
Tailrace Gate	61	61	
Pre-Subtotal	4,730	2,622	
Contingency (10%)	473	262	
Electro-Mechanical Equip. ^{*-5}	15,780	19,216	
Equipment	15,027	18,301	
Contingency (5%)	751	915	
Eng. And Admi. (10%)	2,098	2,210	
Sub Total	23,082	24,310	
I.D.C. (9.5%/year)	1,241	1,377	
Total	24,323	25,867	50,190
Grand Total	172,060	79,464	251,524

*-1: including Intake Adit

*-2: including Penstock Adit

*-3: including Cable Tunnel and Tailrace Adit

*-4: including Drainage Tunnel, Surge Chamber and Surge Chamber Access Tunnel

*-5: including Transmission Line

Table 9-20 Reservoir Operation of Bayram Project

Unit 10⁶m³

Year	Inflow	Evaporation	Power Discharge	Environment Discharge	Spill	Total Outflow
1 1942	998.64	2.82	719.10	3.97	243.33	969.22
2 1943	549.41	2.73	551.56	3.97	0.00	558.27
3 1944	803.53	2.70	636.47	3.97	154.57	797.71
4 1945	457.91	2.65	468.71	3.97	0.00	475.32
5 1946	525.01	2.58	502.90	3.97	0.00	509.46
6 1947	406.79	2.57	430.93	3.97	0.00	437.47
7 1948	512.54	2.51	486.49	3.97	0.00	492.98
8 1949	389.08	2.49	397.35	3.97	0.00	403.82
9 1950	464.57	2.46	450.70	3.97	0.00	457.13
10 1951	458.18	2.57	442.51	3.97	0.00	449.05
11 1952	557.13	2.68	552.22	3.97	0.00	558.87
12 1953	463.30	2.54	450.80	3.97	0.00	457.31
13 1954	628.09	2.66	598.47	3.97	19.74	624.83
14 1955	296.56	2.39	338.58	3.97	0.00	344.94
15 1956	421.05	2.35	382.20	3.97	0.00	388.52
16 1957	478.52	2.49	470.73	3.97	0.00	477.19
17 1958	471.40	2.52	464.70	3.97	0.00	471.18
18 1959	552.19	2.56	534.24	3.97	0.00	540.77
19 1960	895.78	2.83	712.87	3.97	173.19	892.86
20 1961	369.76	2.48	404.57	3.97	0.00	411.02
21 1962	551.52	2.42	518.96	3.97	0.00	525.36
22 1963	914.65	2.65	666.12	3.97	223.16	895.90
23 1964	617.20	2.67	599.86	3.97	24.67	631.17
24 1965	643.13	2.64	651.25	3.97	1.82	659.68
25 1966	614.92	2.61	595.66	3.97	7.20	609.44
26 1967	571.85	2.51	523.54	3.97	14.44	544.46
27 1968	1,139.87	2.85	740.53	3.97	389.40	1,136.75
28 1969	571.95	2.65	578.12	3.97	24.88	609.62
29 1970	476.69	2.55	461.20	3.97	0.00	467.72
30 1971	600.41	2.66	583.48	3.97	0.00	590.11
31 1972	642.03	2.67	614.86	3.97	12.66	634.16
32 1973	567.68	2.63	573.73	3.97	3.29	583.62
33 1974	472.67	2.50	465.15	3.97	0.00	471.63
34 1975	519.29	2.50	517.89	3.97	0.00	524.36
35 1976	690.13	2.56	597.28	3.97	72.54	676.35
36 1977	535.96	2.64	532.77	3.97	0.00	539.38
37 1978	683.62	2.64	618.08	3.97	54.10	678.78
38 1979	618.21	2.63	603.55	3.97	14.11	624.26
39 1980	635.32	2.69	592.24	3.97	39.33	638.23
40 1981	579.29	2.60	524.79	3.97	38.54	569.90
41 1982	455.55	2.63	454.67	3.97	0.00	461.27
42 1983	583.47	2.57	595.99	3.97	0.00	602.53
43 1984	552.32	2.56	530.36	3.97	0.00	536.90
44 1985	577.63	2.55	523.51	3.97	54.25	584.28
45 1986	677.79	2.64	646.56	3.97	26.28	679.45
46 1987	720.80	2.60	570.16	3.97	131.83	708.55
47 1988	975.42	2.77	700.15	3.97	245.93	952.83
48 1989	992.47	2.87	698.96	3.97	320.75	1,026.55
49 1990	593.79	2.51	560.00	3.97	24.35	590.83
50 1991	524.41	2.56	519.39	3.97	0.00	525.92
51 1992	643.85	2.48	560.75	3.97	61.61	628.80
52 1993	861.65	2.82	685.73	3.97	172.86	865.37
53 1994	601.54	2.70	605.54	3.97	1.95	614.15
Total	32,106.39	138.15	29,206.82	210.64	2,550.77	32,106.37
Ave.	605.78	2.61	551.07	3.97	48.13	605.78
Max.	1,139.87	2.87	740.53	3.97	389.40	1,136.75
Min.	296.56	2.35	338.58	3.97	0.00	344.94

Table 9-21 Total Energy Production of Bayram Project

Unit: GWh

NO. YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1 1942	13.12	16.85	16.39	14.46	27.76	46.05	48.96	50.59	48.96	27.83	14.00	13.34	338.31
2 1943	13.72	13.31	15.18	13.79	19.37	33.09	31.46	36.09	32.06	20.46	13.79	13.21	255.53
3 1944	13.46	12.88	13.19	13.02	11.60	33.18	30.58	50.59	48.96	38.55	13.82	13.30	293.14
4 1945	13.58	12.98	13.22	12.91	11.32	12.30	22.02	32.56	38.01	19.55	13.73	13.03	215.19
5 1946	13.13	12.40	12.43	12.04	10.50	11.28	19.93	37.06	44.95	25.24	14.77	13.29	227.04
6 1947	13.64	13.16	13.42	13.18	12.12	35.94	27.95	12.86	15.08	13.69	13.49	12.71	195.23
7 1948	12.78	12.16	12.39	12.01	10.48	11.16	19.67	36.45	46.94	16.97	13.73	13.08	217.81
8 1949	13.26	12.56	12.63	12.12	10.43	11.10	11.13	28.08	25.74	13.77	13.57	12.81	177.19
9 1950	12.87	12.03	11.89	11.22	9.40	10.03	20.88	36.45	26.73	18.00	13.72	12.99	196.19
10 1951	13.15	12.55	12.71	12.32	11.09	11.51	23.16	24.27	34.41	17.23	13.73	13.10	199.23
11 1952	13.51	13.15	13.50	13.30	11.85	28.32	40.79	32.92	35.03	23.95	13.76	13.11	253.19
12 1953	13.22	12.45	12.43	11.85	10.14	10.57	11.28	34.87	37.39	20.72	13.76	13.18	201.87
13 1954	13.40	12.72	12.85	12.44	10.87	12.77	40.24	50.59	48.96	31.32	13.81	13.25	273.21
14 1955	13.47	12.78	12.80	12.48	11.18	11.52	11.33	12.80	13.09	13.55	13.18	12.27	150.54
15 1956	12.01	10.87	9.99	3.78	5.37	7.45	10.89	23.29	36.03	19.30	13.71	12.99	165.49
16 1957	13.05	12.21	12.03	11.28	9.41	10.38	17.68	33.53	41.73	19.94	13.72	13.01	207.97
17 1958	13.10	12.33	12.33	11.78	10.09	10.87	19.90	36.87	37.39	17.49	13.70	13.00	206.84
18 1959	13.12	12.37	12.40	11.94	10.66	11.16	24.02	45.95	47.93	23.69	13.79	13.20	240.23
19 1960	13.50	12.99	13.27	13.22	23.85	50.59	48.96	50.59	48.96	32.09	14.00	13.28	335.32
20 1961	13.44	12.75	12.84	12.34	10.57	11.22	20.37	22.57	24.74	13.72	13.39	12.47	180.45
21 1962	12.27	11.22	11.06	10.43	6.80	10.85	38.07	42.78	37.02	18.39	13.70	12.98	225.58
22 1963	13.10	12.38	12.44	12.07	10.97	11.57	47.62	50.59	48.96	50.59	21.36	13.31	304.68
23 1964	13.58	12.95	13.14	12.86	11.34	20.88	43.98	50.59	48.96	18.91	13.73	13.07	273.99
24 1965	13.37	12.85	13.19	13.06	11.57	38.03	47.40	50.59	48.96	21.75	13.64	12.81	297.24
25 1966	13.00	12.67	13.09	12.95	11.65	29.32	40.68	50.59	43.65	17.36	13.67	12.88	271.32
26 1967	12.88	11.89	11.54	10.63	4.98	9.06	12.48	50.59	44.58	34.87	15.16	13.33	234.02
27 1968	13.63	13.08	18.84	16.01	25.36	49.14	48.96	50.59	48.96	34.80	16.08	13.36	348.79
28 1969	13.75	13.22	13.58	13.34	11.76	30.36	45.40	50.59	31.95	13.76	13.51	12.71	243.90
29 1970	13.02	12.60	12.62	12.55	11.13	21.67	42.35	24.15	15.32	13.77	13.57	12.86	205.81
30 1971	13.26	12.90	13.24	13.04	12.03	34.43	28.17	50.59	45.23	16.84	13.80	13.16	244.49
31 1972	13.29	12.66	12.94	12.75	11.25	18.89	48.69	50.59	48.96	25.24	13.75	13.18	282.20
32 1973	13.48	12.90	13.13	12.83	11.40	21.00	29.26	48.39	48.96	24.47	13.71	12.97	262.50
33 1974	13.05	12.38	12.53	12.11	10.44	11.50	17.78	49.60	28.84	13.78	13.51	12.85	208.35
34 1975	13.05	12.26	12.20	11.64	10.31	10.88	43.87	36.45	36.40	14.00	13.64	12.87	227.59
35 1976	13.00	12.31	12.28	11.75	10.14	11.15	61.14	50.59	48.96	29.76	13.75	13.12	267.96
36 1977	13.43	12.92	13.15	12.86	11.30	17.39	29.15	46.44	40.12	19.68	13.73	13.06	243.24
37 1978	13.26	12.64	12.79	12.38	10.90	19.34	44.74	50.59	48.96	28.21	13.79	13.17	280.79
38 1979	13.33	12.65	12.84	12.62	11.68	22.35	34.09	50.59	48.96	29.12	13.76	13.08	275.08
39 1980	13.21	12.75	13.24	13.16	11.72	34.07	48.96	50.59	34.20	13.83	13.71	13.00	272.45
40 1981	13.14	12.51	12.71	12.39	10.84	12.08	23.99	38.77	48.96	26.66	13.76	13.14	238.96
41 1982	13.36	12.73	13.01	12.85	11.40	17.08	32.23	31.95	17.68	16.97	13.75	13.08	206.08
42 1983	13.27	12.70	12.85	12.44	11.23	20.78	46.40	50.59	46.53	15.29	13.62	12.72	268.64
43 1984	12.78	12.40	12.85	12.56	11.02	25.18	34.86	38.16	29.33	22.40	13.74	13.03	238.31
44 1985	13.02	12.17	12.67	11.43	9.72	11.02	48.96	50.59	25.82	13.74	13.47	12.77	234.79
45 1986	13.20	12.87	13.24	13.07	11.67	34.16	47.86	50.59	48.96	24.47	13.65	12.84	296.58
46 1987	12.90	12.10	11.96	11.37	10.69	11.83	48.96	50.59	48.96	13.75	13.55	12.96	259.62
47 1988	13.24	12.61	12.80	12.57	11.32	45.67	48.96	50.59	48.96	34.42	17.74	15.32	324.20
48 1989	22.74	19.18	17.29	13.79	21.09	50.59	48.96	50.59	48.96	15.42	13.64	12.83	335.09
49 1990	12.92	12.15	12.08	11.40	9.57	10.82	37.69	50.59	43.45	21.23	13.67	12.90	248.49
50 1991	13.02	12.52	12.88	12.58	11.41	30.86	44.49	22.12	28.09	15.16	13.69	12.90	231.71
51 1992	12.88	11.93	11.71	11.01	8.81	9.99	34.69	45.22	48.96	23.30	13.77	13.15	245.43
52 1993	13.98	24.68	13.78	13.68	16.39	39.99	48.96	50.59	48.96	22.66	13.74	13.08	322.49
53 1994	13.22	12.78	13.33	13.24	11.89	45.12	48.96	50.59	30.57	13.79	13.62	12.86	279.97
TOTAL	711.20	688.07	688.41	654.88	631.84	1167.52	1832.16	2224.02	2093.02	1147.44	742.17	691.99	13222.91
AVE	13.42	12.98	12.99	12.36	11.92	22.03	34.57	41.96	39.49	21.65	14.00	13.06	250.43
MAX	22.74	24.68	18.84	16.01	27.76	50.59	48.96	50.59	48.96	50.59	21.36	15.32	348.79
MIN	12.01	10.87	9.99	3.78	4.98	7.45	10.89	12.80	13.08	13.55	13.18	12.27	150.54

Table 9-22 Firm Energy Production of Bayram Project

Unit: GWh

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1	1942	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
2	1943	12.65	12.24	12.65	12.65	11.83	12.65	11.62	12.65	12.24	12.65	12.65	12.24	148.71
3	1944	12.65	12.24	12.65	12.65	11.42	12.35	11.62	12.65	12.24	12.65	12.65	12.24	148.00
4	1945	12.65	12.24	12.65	12.65	11.32	11.99	11.62	12.65	12.24	12.65	12.65	12.24	147.53
5	1946	12.65	12.24	12.42	11.87	10.18	10.79	11.16	12.65	12.24	12.65	12.65	12.24	143.73
6	1947	12.65	12.24	12.45	12.65	11.83	12.42	11.62	12.65	12.24	12.65	12.65	12.24	143.47
7	1948	12.65	12.16	12.36	11.82	10.15	10.63	11.00	12.65	12.24	12.65	12.65	12.24	143.20
8	1949	12.65	12.24	12.63	11.97	10.09	10.55	10.75	12.65	12.24	12.65	12.65	12.24	143.29
9	1950	12.65	12.00	11.64	10.71	8.68	9.11	10.61	12.65	12.24	12.65	12.65	12.24	137.82
10	1951	12.65	12.24	12.65	12.25	10.85	11.11	11.29	12.65	12.24	12.65	12.65	12.24	145.46
11	1952	12.65	12.24	12.65	12.65	11.42	12.62	11.62	12.65	12.24	12.65	12.65	12.24	148.27
12	1953	12.65	12.24	12.42	11.59	9.69	9.83	10.68	12.65	12.24	12.65	12.65	12.24	141.53
13	1954	12.65	12.24	12.65	12.43	10.70	11.64	11.62	12.65	12.24	12.65	12.65	12.24	146.34
14	1955	12.65	12.24	12.65	12.48	10.98	11.13	11.02	12.65	12.24	12.65	12.65	12.24	145.57
15	1956	11.79	10.37	9.47	3.78	5.37	7.45	10.42	12.65	12.24	12.65	12.65	12.24	121.07
16	1957	12.65	12.21	11.85	10.79	8.70	9.58	10.91	12.65	12.24	12.65	12.65	12.24	139.11
17	1958	12.65	12.24	12.27	11.49	9.62	10.23	10.99	12.65	12.24	12.65	12.65	12.24	141.92
18	1959	12.65	12.24	12.37	11.72	10.25	10.63	11.20	12.65	12.24	12.65	12.65	12.24	143.47
19	1960	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
20	1961	12.65	12.24	12.65	12.29	10.28	10.71	11.08	12.65	12.24	12.65	12.65	12.24	144.31
21	1962	12.16	10.85	10.49	9.64	6.80	10.22	11.46	12.65	12.24	12.65	12.65	12.24	136.64
22	1963	12.65	12.24	12.43	11.90	10.68	11.21	11.91	12.65	12.24	12.65	12.65	12.24	145.45
23	1964	12.65	12.24	12.65	12.65	11.34	12.02	11.62	12.65	12.24	12.65	12.65	12.24	145.57
24	1965	12.65	12.24	12.65	12.65	11.42	12.26	11.86	12.65	12.24	12.65	12.65	12.24	148.15
25	1966	12.65	12.24	12.65	12.65	11.42	12.47	11.62	12.65	12.24	12.65	12.65	12.24	148.11
26	1967	12.65	11.80	11.19	9.92	4.98	9.06	10.49	12.65	12.24	12.65	12.65	12.24	132.50
27	1968	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
28	1969	12.65	12.24	12.65	12.65	11.42	12.44	11.62	12.65	12.24	12.65	12.65	12.24	148.09
29	1970	12.65	12.24	12.65	12.55	11.08	11.94	11.62	12.65	12.24	12.65	12.65	12.24	147.15
30	1971	12.65	12.24	12.65	12.65	11.83	12.38	11.62	12.65	12.24	12.65	12.65	12.24	148.43
31	1972	12.65	12.24	12.65	12.65	11.25	11.97	12.17	12.65	12.24	12.65	12.65	12.24	148.01
32	1973	12.65	12.24	12.65	12.65	11.40	12.18	11.62	12.65	12.24	12.65	12.65	12.24	147.80
33	1974	12.65	12.24	12.53	11.95	10.10	11.10	11.48	12.65	12.24	12.65	12.65	12.24	146.68
34	1975	12.65	12.24	12.09	11.29	9.76	10.25	11.10	12.65	12.24	12.65	12.65	12.24	141.81
35	1976	12.65	12.24	12.20	11.45	9.68	10.63	11.26	12.65	12.24	12.65	12.65	12.24	142.52
36	1977	12.65	12.24	12.65	12.65	11.30	11.99	11.62	12.65	12.24	12.65	12.65	12.24	147.52
37	1978	12.65	12.24	12.65	12.35	10.75	11.75	11.62	12.65	12.24	12.65	12.65	12.24	146.43
38	1979	12.65	12.24	12.65	12.62	11.68	12.09	11.62	12.65	12.24	12.65	12.65	12.24	147.97
39	1980	12.65	12.24	12.65	12.65	11.42	12.46	12.24	12.65	12.24	12.65	12.65	12.24	148.73
40	1981	12.65	12.24	12.65	12.36	10.67	11.61	11.62	12.65	12.24	12.65	12.65	12.24	146.72
41	1982	12.65	12.24	12.65	12.65	11.40	12.09	11.62	12.65	12.24	12.65	12.65	12.24	147.22
42	1983	12.65	12.24	12.65	12.43	11.04	11.57	11.66	12.65	12.24	12.65	12.65	12.24	146.67
43	1984	12.65	12.24	12.65	12.56	10.92	11.78	11.62	12.65	12.24	12.65	12.65	12.24	146.82
44	1985	12.65	12.17	11.90	11.00	9.11	10.45	12.24	12.65	12.24	12.65	12.65	12.24	141.94
45	1986	12.65	12.24	12.65	12.65	11.42	12.44	11.97	12.65	12.24	12.65	12.65	12.24	148.45
46	1987	12.65	12.10	11.75	10.92	10.29	11.57	12.24	12.65	12.24	12.65	12.65	12.24	143.94
47	1988	12.65	12.24	12.65	12.57	11.32	12.20	12.24	12.65	12.24	12.65	12.65	12.24	148.28
48	1989	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
49	1990	12.65	12.15	11.91	10.97	8.92	10.17	11.24	12.65	12.24	12.65	12.65	12.24	140.43
50	1991	12.65	12.24	12.65	12.58	11.30	11.77	11.63	12.65	12.24	12.65	12.65	12.24	147.23
51	1992	12.65	11.86	11.39	10.43	8.43	9.06	10.66	12.65	12.24	12.65	12.65	12.24	136.90
52	1993	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
53	1994	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
TOTAL		668.99	644.00	655.31	632.93	555.06	604.39	611.51	670.34	648.72	670.34	670.34	648.72	7680.62
AVE		12.62	12.15	12.36	11.94	10.47	11.40	11.54	12.65	12.24	12.65	12.65	12.24	144.92
MAX		12.65	12.24	12.65	12.65	11.83	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
MIN		11.79	10.37	9.47	3.78	4.98	7.45	10.42	12.65	12.24	12.65	12.65	12.24	121.07

Table 9-23 Peak Power of Bayram Project

Unit: MW

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< AVE >
1	1942	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00
2	1943	88.00	88.00	88.00	88.00	88.00	88.00	64.54	88.00	88.00	88.00	88.00	88.00	67.72
3	1944	88.00	88.00	88.00	88.00	88.00	66.39	64.54	88.00	88.00	88.00	88.00	88.00	67.58
4	1945	88.00	88.00	88.00	88.00	88.00	67.39	64.41	64.54	88.00	88.00	88.00	88.00	67.36
5	1946	88.00	88.00	66.76	63.79	60.61	58.02	61.98	88.00	88.00	88.00	88.00	88.00	65.63
6	1947	88.00	88.00	88.00	88.00	88.00	66.76	64.54	88.00	88.00	88.00	88.00	88.00	67.61
7	1948	88.00	67.56	66.46	63.56	60.42	57.15	61.12	88.00	88.00	88.00	88.00	88.00	65.39
8	1949	88.00	88.00	67.88	64.36	60.04	56.71	59.73	88.00	88.00	88.00	88.00	88.00	65.43
9	1950	88.00	66.68	62.57	57.58	51.64	48.99	58.92	88.00	88.00	88.00	88.00	88.00	62.93
10	1951	88.00	88.00	88.00	65.88	62.35	59.75	62.70	88.00	88.00	88.00	88.00	88.00	66.24
11	1952	88.00	88.00	88.00	88.00	88.00	67.83	64.54	88.00	88.00	88.00	88.00	88.00	67.70
12	1953	88.00	88.00	66.76	62.34	57.69	52.83	59.35	88.00	88.00	88.00	88.00	88.00	64.62
13	1954	88.00	88.00	88.00	66.81	63.69	62.56	64.54	88.00	88.00	88.00	88.00	88.00	66.82
14	1955	88.00	65.00	68.00	67.11	63.12	59.81	61.22	88.00	88.00	88.00	88.00	88.00	66.29
15	1956	63.37	57.59	50.89	20.31	31.98	40.07	57.90	88.00	88.00	88.00	88.00	88.00	55.28
16	1957	88.00	67.82	63.69	58.02	51.76	51.51	60.61	88.00	88.00	88.00	88.00	88.00	63.52
17	1958	88.00	88.00	65.94	61.78	57.27	55.02	61.08	88.00	88.00	88.00	88.00	88.00	64.80
18	1959	88.00	88.00	66.48	63.00	58.91	57.15	62.21	88.00	88.00	88.00	88.00	88.00	65.33
19	1960	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00
20	1961	88.00	88.00	88.00	66.05	61.17	57.60	61.55	88.00	88.00	88.00	88.00	88.00	65.90
21	1962	65.36	60.29	56.39	51.85	40.49	54.94	63.65	88.00	88.00	88.00	88.00	88.00	61.21
22	1963	88.00	88.00	66.85	63.97	61.40	60.25	66.18	88.00	88.00	88.00	88.00	88.00	66.23
23	1964	88.00	88.00	88.00	88.00	67.48	64.64	64.54	88.00	88.00	88.00	88.00	88.00	67.39
24	1965	88.00	88.00	88.00	88.00	65.89	65.89	65.87	88.00	88.00	88.00	88.00	88.00	67.65
25	1966	88.00	88.00	88.00	88.00	88.00	67.02	64.54	88.00	88.00	88.00	88.00	88.00	67.63
26	1967	88.00	65.57	60.14	53.32	28.61	48.71	58.25	88.00	88.00	88.00	88.00	88.00	60.34
27	1968	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00
28	1969	88.00	88.00	88.00	88.00	88.00	66.88	64.54	88.00	88.00	88.00	88.00	88.00	67.62
29	1970	88.00	88.00	88.00	67.43	65.95	64.19	64.54	88.00	88.00	88.00	88.00	88.00	67.19
30	1971	88.00	88.00	88.00	88.00	88.00	66.54	64.54	88.00	88.00	88.00	88.00	88.00	67.59
31	1972	88.00	88.00	88.00	88.00	66.97	64.38	67.64	88.00	88.00	88.00	88.00	88.00	67.58
32	1973	88.00	88.00	88.00	88.00	67.84	65.46	64.54	88.00	88.00	88.00	88.00	88.00	67.69
33	1974	88.00	88.00	67.39	64.26	60.12	59.68	63.80	88.00	88.00	88.00	88.00	88.00	65.97
34	1975	88.00	88.00	64.99	60.72	56.10	55.09	61.69	88.00	88.00	88.00	88.00	88.00	64.57
35	1976	88.00	88.00	65.60	61.54	57.63	57.12	62.54	88.00	88.00	88.00	88.00	88.00	65.08
36	1977	88.00	88.00	88.00	88.00	67.26	64.43	64.54	88.00	88.00	88.00	88.00	88.00	67.36
37	1978	88.00	88.00	88.00	66.40	64.01	63.16	64.54	88.00	88.00	88.00	88.00	88.00	66.86
38	1979	88.00	88.00	88.00	67.84	67.12	65.02	64.54	88.00	88.00	88.00	88.00	88.00	67.38
39	1980	88.00	88.00	88.00	88.00	88.00	66.98	68.00	88.00	88.00	88.00	88.00	88.00	67.91
40	1981	88.00	88.00	88.00	66.46	63.49	62.44	64.54	88.00	88.00	88.00	88.00	88.00	66.77
41	1982	88.00	88.00	88.00	88.00	67.84	65.01	64.54	88.00	88.00	88.00	88.00	88.00	67.45
42	1983	88.00	88.00	88.00	66.84	63.47	62.20	64.80	88.00	88.00	88.00	88.00	88.00	66.79
43	1984	88.00	88.00	88.00	67.53	64.97	63.24	64.54	88.00	88.00	88.00	88.00	88.00	67.04
44	1985	88.00	67.63	64.00	59.16	54.20	56.16	68.00	88.00	88.00	88.00	88.00	88.00	64.81
45	1986	88.00	88.00	88.00	88.00	88.00	66.91	66.50	88.00	88.00	88.00	88.00	88.00	67.78
46	1987	88.00	67.20	63.15	58.69	59.15	62.23	88.00	88.00	88.00	88.00	88.00	88.00	65.55
47	1988	88.00	88.00	88.00	67.59	67.37	65.57	68.00	88.00	88.00	88.00	88.00	88.00	67.71
48	1989	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00
49	1990	88.00	67.52	64.05	58.96	53.07	54.68	62.43	88.00	88.00	88.00	88.00	88.00	64.12
50	1991	88.00	88.00	88.00	67.61	64.97	63.27	64.59	88.00	88.00	88.00	88.00	88.00	67.05
51	1992	88.00	65.90	61.21	56.07	50.17	48.72	59.21	88.00	88.00	88.00	88.00	88.00	62.51
52	1993	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00
53	1994	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00
AVE		67.84	67.50	66.48	64.21	61.81	61.31	64.10	88.00	88.00	88.00	88.00	88.00	66.13
MAX		88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00	88.00
MIN		63.37	57.59	50.89	20.31	28.61	40.07	57.90	88.00	88.00	88.00	88.00	88.00	55.28

Table 9-24(1) Peak Power Duration of Bayram Project

No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)		
1	68.00	41	68.00	81	68.00	121	68.00	161	68.00	201	68.00	241	68.00	281	68.00	321	68.00	361	68.00	401	68.00
2	68.00	42	68.00	82	68.00	122	68.00	162	68.00	202	68.00	242	68.00	282	68.00	322	68.00	362	68.00	402	68.00
3	68.00	43	68.00	83	68.00	123	68.00	163	68.00	203	68.00	243	68.00	283	68.00	323	68.00	363	68.00	403	68.00
4	68.00	44	68.00	84	68.00	124	68.00	164	68.00	204	68.00	244	68.00	284	68.00	324	68.00	364	68.00	404	68.00
5	68.00	45	68.00	85	68.00	125	68.00	165	68.00	205	68.00	245	68.00	285	68.00	325	68.00	365	68.00	405	68.00
6	68.00	46	68.00	86	68.00	126	68.00	166	68.00	206	68.00	246	68.00	286	68.00	326	68.00	366	68.00	406	68.00
7	68.00	47	68.00	87	68.00	127	68.00	167	68.00	207	68.00	247	68.00	287	68.00	327	68.00	367	68.00	407	68.00
8	68.00	48	68.00	88	68.00	128	68.00	168	68.00	208	68.00	248	68.00	288	68.00	328	68.00	368	68.00	408	68.00
9	68.00	49	68.00	89	68.00	129	68.00	169	68.00	209	68.00	249	68.00	289	68.00	329	68.00	369	68.00	409	68.00
10	68.00	50	68.00	90	68.00	130	68.00	170	68.00	210	68.00	250	68.00	290	68.00	330	68.00	370	68.00	410	68.00
11	68.00	51	68.00	91	68.00	131	68.00	171	68.00	211	68.00	251	68.00	291	68.00	331	68.00	371	68.00	411	68.00
12	68.00	52	68.00	92	68.00	132	68.00	172	68.00	212	68.00	252	68.00	292	68.00	332	68.00	372	68.00	412	68.00
13	68.00	53	68.00	93	68.00	133	68.00	173	68.00	213	68.00	253	68.00	293	68.00	333	68.00	373	68.00	413	68.00
14	68.00	54	68.00	94	68.00	134	68.00	174	68.00	214	68.00	254	68.00	294	68.00	334	68.00	374	68.00	414	68.00
15	68.00	55	68.00	95	68.00	135	68.00	175	68.00	215	68.00	255	68.00	295	68.00	335	68.00	375	68.00	415	68.00
16	68.00	56	68.00	96	68.00	136	68.00	176	68.00	216	68.00	256	68.00	296	68.00	336	68.00	376	68.00	416	68.00
17	68.00	57	68.00	97	68.00	137	68.00	177	68.00	217	68.00	257	68.00	297	68.00	337	68.00	377	68.00	417	68.00
18	68.00	58	68.00	98	68.00	138	68.00	178	68.00	218	68.00	258	68.00	298	68.00	338	68.00	378	68.00	418	68.00
19	68.00	59	68.00	99	68.00	139	68.00	179	68.00	219	68.00	259	68.00	299	68.00	339	68.00	379	68.00	419	68.00
20	68.00	60	68.00	100	68.00	140	68.00	180	68.00	220	68.00	260	68.00	300	68.00	340	68.00	380	68.00	420	68.00
21	68.00	61	68.00	101	68.00	141	68.00	181	68.00	221	68.00	261	68.00	301	68.00	341	68.00	381	68.00	421	68.00
22	68.00	62	68.00	102	68.00	142	68.00	182	68.00	222	68.00	262	68.00	302	68.00	342	68.00	382	68.00	422	68.00
23	68.00	63	68.00	103	68.00	143	68.00	183	68.00	223	68.00	263	68.00	303	68.00	343	68.00	383	68.00	423	68.00
24	68.00	64	68.00	104	68.00	144	68.00	184	68.00	224	68.00	264	68.00	304	68.00	344	68.00	384	68.00	424	68.00
25	68.00	65	68.00	105	68.00	145	68.00	185	68.00	225	68.00	265	68.00	305	68.00	345	68.00	385	68.00	425	68.00
26	68.00	66	68.00	106	68.00	146	68.00	186	68.00	226	68.00	266	68.00	306	68.00	346	68.00	386	68.00	426	68.00
27	68.00	67	68.00	107	68.00	147	68.00	187	68.00	227	68.00	267	68.00	307	68.00	347	68.00	387	68.00	427	68.00
28	68.00	68	68.00	108	68.00	148	68.00	188	68.00	228	68.00	268	68.00	308	68.00	348	68.00	388	68.00	428	68.00
29	68.00	69	68.00	109	68.00	149	68.00	189	68.00	229	68.00	269	68.00	309	68.00	349	68.00	389	68.00	429	68.00
30	68.00	70	68.00	110	68.00	150	68.00	190	68.00	230	68.00	270	68.00	310	68.00	350	68.00	390	68.00	430	68.00
31	68.00	71	68.00	111	68.00	151	68.00	191	68.00	231	68.00	271	68.00	311	68.00	351	68.00	391	68.00	431	68.00
32	68.00	72	68.00	112	68.00	152	68.00	192	68.00	232	68.00	272	68.00	312	68.00	352	68.00	392	68.00	432	68.00
33	68.00	73	68.00	113	68.00	153	68.00	193	68.00	233	68.00	273	68.00	313	68.00	353	68.00	393	68.00	433	68.00
34	68.00	74	68.00	114	68.00	154	68.00	194	68.00	234	68.00	274	68.00	314	68.00	354	68.00	394	68.00	434	68.00
35	68.00	75	68.00	115	68.00	155	68.00	195	68.00	235	68.00	275	68.00	315	68.00	355	68.00	395	68.00	435	68.00
36	68.00	76	68.00	116	68.00	156	68.00	196	68.00	236	68.00	276	68.00	316	68.00	356	68.00	396	68.00	436	68.00
37	68.00	77	68.00	117	68.00	157	68.00	197	68.00	237	68.00	277	68.00	317	68.00	357	68.00	397	68.00	437	68.00
38	68.00	78	68.00	118	68.00	158	68.00	198	68.00	238	68.00	278	68.00	318	68.00	358	68.00	398	68.00	438	68.00
39	68.00	79	68.00	119	68.00	159	68.00	199	68.00	239	68.00	279	68.00	319	68.00	359	68.00	399	68.00	439	68.00
40	68.00	80	68.00	120	68.00	160	68.00	200	68.00	240	68.00	280	68.00	320	68.00	360	68.00	400	68.00	440	68.00

Table 9-24(2) Peak Power Duration of Bayram Project

No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)
321	68.00	361	68.00	401	68.00	441	68.00	481	66.76	521	64.54	561	62.34	601	57.69		
322	68.00	362	68.00	402	68.00	442	68.00	482	66.68	522	64.54	562	62.23	602	57.63		
323	68.00	363	68.00	403	68.00	443	68.00	483	66.54	523	64.54	563	62.21	603	57.60		
324	68.00	364	68.00	404	68.00	444	68.00	484	66.50	524	64.54	564	62.20	604	57.59		
325	68.00	365	68.00	405	68.00	445	68.00	485	66.48	525	64.54	565	61.98	605	57.58		
326	68.00	366	68.00	406	68.00	446	68.00	486	66.46	526	64.54	566	61.78	606	57.57		
327	68.00	367	68.00	407	68.00	447	68.00	487	66.46	527	64.54	567	61.69	607	57.15		
328	68.00	368	68.00	408	68.00	448	68.00	488	66.40	528	64.54	568	61.55	608	57.15		
329	68.00	369	68.00	409	68.00	449	67.88	489	66.39	529	64.48	569	61.54	609	57.12		
330	68.00	370	68.00	410	68.00	450	67.84	490	66.18	530	64.44	570	61.40	610	56.71		
331	68.00	371	68.00	411	68.00	451	67.84	491	66.05	531	64.38	571	61.22	611	56.39		
332	68.00	372	68.00	412	68.00	452	67.84	492	65.96	532	64.36	572	61.21	612	56.16		
333	68.00	373	68.00	413	68.00	453	67.83	493	65.94	533	64.26	573	61.17	613	56.10		
334	68.00	374	68.00	414	68.00	454	67.82	494	65.90	534	64.19	574	61.12	614	56.07		
335	68.00	375	68.00	415	68.00	455	67.64	495	65.89	535	64.05	575	61.08	615	55.09		
336	68.00	376	68.00	416	68.00	456	67.63	496	65.88	536	64.01	576	60.72	616	55.02		
337	68.00	377	68.00	417	68.00	457	67.61	497	65.87	537	64.00	577	60.61	617	54.94		
338	68.00	378	68.00	418	68.00	458	67.59	498	65.60	538	63.97	578	60.61	618	54.68		
339	68.00	379	68.00	419	68.00	459	67.56	499	65.57	539	63.80	579	60.42	619	54.20		
340	68.00	380	68.00	420	68.00	460	67.53	500	65.57	540	63.79	580	60.29	620	53.32		
341	68.00	381	68.00	421	68.00	461	67.52	501	65.46	541	63.69	581	60.25	621	53.07		
342	68.00	382	68.00	422	68.00	462	67.48	502	65.36	542	63.69	582	60.14	622	52.83		
343	68.00	383	68.00	423	68.00	463	67.48	503	65.02	543	63.65	583	60.12	623	51.85		
344	68.00	384	68.00	424	68.00	464	67.39	504	65.01	544	63.56	584	60.04	624	51.76		
345	68.00	385	68.00	425	68.00	465	67.39	505	64.99	545	63.49	585	59.81	625	51.64		
346	68.00	386	68.00	426	68.00	466	67.37	506	64.97	546	63.47	586	59.75	626	51.51		
347	68.00	387	68.00	427	68.00	467	67.26	507	64.97	547	63.37	587	59.73	627	50.89		
348	68.00	388	68.00	428	68.00	468	67.20	508	64.80	548	63.27	588	59.68	628	50.17		
349	68.00	389	68.00	429	68.00	469	67.12	509	64.64	549	63.24	589	59.35	629	48.99		
350	68.00	390	68.00	430	68.00	470	67.11	510	64.59	550	63.16	590	59.21	630	48.72		
351	68.00	391	68.00	431	68.00	471	67.02	511	64.54	551	63.15	591	59.16	631	48.71		
352	68.00	392	68.00	432	68.00	472	66.98	512	64.54	552	63.12	592	59.15	632	40.49		
353	68.00	393	68.00	433	68.00	473	66.97	513	64.54	553	63.00	593	58.96	633	40.07		
354	68.00	394	68.00	434	68.00	474	66.91	514	64.54	554	62.70	594	58.92	634	31.98		
355	68.00	395	68.00	435	68.00	475	66.88	515	64.54	555	62.57	595	58.91	635	28.61		
356	68.00	396	68.00	436	68.00	476	66.85	516	64.54	556	62.56	596	58.69	636	20.31		
357	68.00	397	68.00	437	68.00	477	66.84	517	64.54	557	62.54	597	58.25				
358	68.00	398	68.00	438	68.00	478	66.81	518	64.54	558	62.44	598	58.02				
359	68.00	399	68.00	439	68.00	479	66.76	519	64.54	559	62.43	599	58.02				
360	68.00	400	68.00	440	68.00	480	66.76	520	64.54	560	62.35	600	57.90				

Table 9-25 Reservoir Operation of Bağlık Project

Unit 10⁶m³

Year	Inflow	Evaporation	Power Discharge	Environment Discharge	Spill	Total Outflow
1 1942	1,216.32	0.34	921.08	3.97	289.92	1,215.32
2 1943	717.37	0.35	713.05	3.97	0.00	717.37
3 1944	1,003.39	0.35	811.68	3.97	187.40	1,003.39
4 1945	610.83	0.35	606.53	3.97	0.00	610.85
5 1946	659.85	0.35	655.51	3.97	0.00	659.83
6 1947	563.73	0.35	559.70	3.97	0.00	564.01
7 1948	640.77	0.35	636.17	3.97	0.00	640.48
8 1949	523.52	0.34	519.21	3.97	0.00	523.53
9 1950	592.58	0.34	588.80	3.97	0.00	593.11
10 1951	585.26	0.35	580.41	3.97	0.00	584.73
11 1952	718.18	0.35	713.86	3.97	0.00	718.18
12 1953	593.43	0.34	589.12	3.97	0.00	593.43
13 1954	796.40	0.35	762.55	3.97	29.54	769.40
14 1955	443.75	0.34	440.44	3.97	0.00	444.75
15 1956	514.93	0.34	509.64	3.97	0.00	513.95
16 1957	615.99	0.34	611.68	3.97	0.00	615.99
17 1958	608.88	0.34	604.54	3.97	0.00	608.86
18 1959	696.67	0.35	692.35	3.97	0.00	696.67
19 1960	1,121.07	0.35	913.10	3.97	203.65	1,121.07
20 1961	524.73	0.34	521.42	3.97	0.00	525.73
21 1962	680.86	0.34	675.55	3.97	0.00	679.86
22 1963	1,122.23	0.35	847.99	3.97	269.93	1,122.23
23 1964	799.51	0.35	760.10	3.97	35.10	799.51
24 1965	834.53	0.34	814.16	3.97	17.06	835.53
25 1966	779.58	0.34	755.43	3.97	19.84	779.58
26 1967	701.94	0.34	668.23	3.97	28.41	700.94
27 1968	1,406.78	0.35	941.80	3.97	460.66	1,406.77
28 1969	767.65	0.34	720.05	3.97	44.29	768.65
29 1970	609.22	0.34	603.90	3.97	0.00	608.22
30 1971	758.38	0.34	744.36	3.97	10.70	759.38
31 1972	809.96	0.34	776.41	3.97	28.23	808.96
32 1973	742.95	0.35	732.46	3.97	6.70	743.48
33 1974	610.06	0.34	597.04	3.97	8.17	609.53
34 1975	671.35	0.34	660.99	3.97	6.89	672.18
35 1976	858.65	0.34	761.76	3.97	91.74	857.81
36 1977	692.61	0.35	688.29	3.97	0.00	692.61
37 1978	861.40	0.35	785.73	3.97	71.36	861.40
38 1979	794.73	0.35	766.36	3.97	24.58	795.26
39 1980	811.01	0.35	743.44	3.97	62.73	810.49
40 1981	731.18	0.35	683.37	3.97	43.48	731.16
41 1982	616.21	0.34	612.90	3.97	0.00	617.21
42 1983	801.04	0.34	748.12	3.97	48.61	801.04
43 1984	724.86	0.34	720.55	3.97	0.00	724.86
44 1985	781.64	0.34	653.61	3.97	122.73	780.64
45 1986	911.06	0.34	818.53	3.97	89.22	912.06
46 1987	954.90	0.34	725.47	3.97	224.12	953.90
47 1988	1,288.18	0.35	908.33	3.97	375.54	1,288.18
48 1989	1,367.41	0.34	906.57	3.97	457.53	1,368.41
49 1990	800.34	0.34	732.95	3.97	63.08	800.34
50 1991	699.94	0.34	687.48	3.97	8.15	699.94
51 1992	854.63	0.34	739.07	3.97	110.25	853.63
52 1993	1,170.14	0.35	901.59	3.97	264.23	1,170.14
53 1994	801.02	0.34	755.10	3.97	42.64	802.05
Total	41,563.74	18.19	37,588.42	210.64	3,746.50	41,563.73
Ave.	784.22	0.34	709.22	3.97	70.69	784.22
Max.	1,046.78	0.35	941.98	3.97	460.66	1,406.77
Min.	443.75	0.34	440.44	3.97	0.00	444.75

Table 9-26 Total Energy Production of Bağlık Project

Unit: GWh

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1	1942	12.19	17.27	14.34	12.72	22.24	35.31	42.48	43.90	42.48	23.68	12.49	11.65	293.73
2	1943	12.21	12.32	13.46	11.88	15.56	26.77	30.96	35.22	28.15	17.70	12.03	11.24	227.50
3	1944	11.70	11.49	11.79	11.54	10.65	29.28	30.14	43.90	42.48	32.31	12.29	11.40	258.96
4	1945	11.53	11.49	11.19	11.08	9.97	11.37	22.28	32.23	32.95	17.02	11.52	10.75	193.38
5	1946	11.19	10.83	11.11	11.45	10.03	11.68	22.13	35.99	38.57	21.63	13.17	11.15	209.14
6	1947	12.38	11.41	11.36	11.36	10.87	31.48	27.74	14.78	13.47	11.87	11.11	10.71	178.53
7	1948	11.07	11.91	11.37	11.28	10.27	11.36	22.49	35.48	40.14	14.88	11.52	11.16	202.93
8	1949	11.36	10.92	11.08	10.98	9.74	11.26	13.72	29.37	23.02	11.78	11.19	10.75	165.16
9	1950	11.11	10.72	10.94	10.61	9.73	11.85	25.02	35.48	23.85	15.65	11.35	10.69	187.00
10	1951	11.55	11.16	11.28	11.11	10.47	11.79	24.65	25.23	30.05	15.05	11.52	11.24	185.11
11	1952	12.90	11.90	11.62	11.45	10.65	23.59	39.40	32.57	30.55	20.52	11.69	10.91	227.75
12	1953	11.11	10.72	10.98	10.61	9.73	10.93	15.31	34.20	32.45	17.96	11.78	11.32	187.69
13	1954	11.36	11.08	11.08	11.01	10.11	13.24	38.90	43.90	42.48	26.50	12.20	11.24	243.10
14	1955	11.34	10.91	11.11	11.01	10.16	11.09	13.22	15.63	13.05	11.19	10.88	10.11	139.73
15	1956	10.45	10.11	10.26	4.84	6.63	9.00	15.13	24.57	31.38	16.76	11.35	10.75	161.24
16	1957	11.04	10.46	10.44	10.27	9.81	12.70	20.85	33.09	35.92	17.27	11.44	10.75	194.05
17	1958	11.10	10.83	11.08	10.93	9.81	11.85	22.87	34.20	32.45	15.22	11.27	10.91	192.32
18	1959	11.19	10.83	11.19	11.19	10.34	12.33	25.83	43.43	40.89	20.35	12.03	11.15	220.77
19	1960	12.04	11.57	11.45	12.65	21.35	42.66	42.48	43.90	42.48	27.18	12.49	11.07	291.32
20	1961	11.27	10.83	11.08	10.65	9.58	11.18	22.89	23.86	22.20	11.35	10.71	9.95	165.47
21	1962	10.36	10.35	11.10	11.11	8.50	14.38	37.71	40.78	32.20	15.99	11.27	10.91	214.67
22	1963	11.19	10.92	11.28	11.37	10.95	12.22	42.48	43.90	42.48	43.90	18.55	11.32	270.55
23	1964	11.61	11.08	11.36	11.19	10.19	19.47	42.29	43.90	42.48	16.42	11.52	10.99	242.51
24	1965	12.30	11.24	12.22	11.36	10.26	34.13	42.48	43.90	41.72	18.72	11.04	10.13	259.50
25	1966	12.02	12.40	11.71	11.88	11.19	25.26	39.32	43.90	36.24	15.14	11.04	10.53	240.62
26	1967	10.44	9.95	10.44	10.27	5.96	10.76	16.77	43.90	37.15	31.03	13.43	11.57	211.67
27	1968	11.61	11.66	17.83	14.00	20.23	40.96	42.48	43.90	42.48	29.32	14.19	11.81	300.48
28	1969	12.04	11.57	11.79	11.04	9.94	26.13	42.48	43.90	27.06	11.69	11.01	10.50	229.16
29	1970	12.44	11.33	11.45	11.45	10.80	20.48	40.80	25.14	14.51	11.78	11.27	11.08	192.53
30	1971	13.07	11.68	11.79	11.36	11.19	30.34	27.99	43.90	38.63	14.71	12.12	10.61	237.37
31	1972	11.17	11.16	11.96	11.37	10.34	17.75	42.48	43.90	42.48	21.63	11.69	11.65	247.59
32	1973	11.70	11.41	11.28	11.11	10.88	18.90	28.98	43.90	42.48	20.95	11.35	10.69	235.63
33	1974	11.01	11.21	11.37	11.08	9.95	12.84	18.95	43.90	25.59	11.61	11.07	11.53	190.09
34	1975	11.08	10.69	11.01	10.95	10.17	12.44	42.48	35.48	31.62	12.40	11.04	10.58	209.94
35	1976	11.17	10.83	11.04	10.98	9.94	12.77	41.42	43.90	42.48	25.30	11.69	11.07	242.69
36	1977	12.38	11.33	11.36	11.11	10.26	16.26	28.81	43.85	34.68	17.10	11.52	10.91	219.60
37	1978	11.70	11.16	11.11	11.08	10.89	19.06	42.48	43.90	42.48	24.02	12.03	10.91	250.62
38	1979	11.36	11.16	11.45	11.62	11.43	20.51	33.36	43.90	42.48	24.71	11.78	10.69	244.44
39	1980	11.21	12.48	12.22	11.54	10.50	29.62	42.48	43.90	28.88	12.20	11.35	10.75	237.12
40	1981	11.53	11.25	11.54	11.19	10.27	12.64	24.10	37.45	42.48	22.74	11.69	11.16	218.02
41	1982	11.53	11.16	11.71	11.45	10.03	15.53	34.02	35.48	17.24	15.14	11.52	10.61	195.42
42	1983	11.34	11.25	10.71	10.69	9.84	21.56	42.48	43.90	42.20	13.60	10.28	9.54	237.38
43	1984	11.10	13.15	11.36	11.08	9.97	25.39	36.67	41.38	27.65	19.92	11.44	10.37	229.48
44	1985	10.02	10.27	10.27	10.27	9.66	14.13	42.48	43.90	23.01	11.35	10.79	10.80	206.96
45	1986	13.41	11.82	11.79	11.28	10.73	30.47	42.48	43.90	42.48	21.80	10.82	10.02	260.80
46	1987	10.69	10.11	10.27	10.52	12.81	12.73	42.48	43.90	42.48	11.44	11.27	11.65	230.35
47	1988	11.45	11.00	11.19	11.54	11.58	43.67	42.48	43.90	42.48	30.69	15.99	13.84	289.80
48	1989	20.41	17.08	15.38	11.88	16.94	43.90	42.48	43.90	42.48	13.77	10.53	10.18	288.88
49	1990	10.36	10.19	10.44	9.94	9.43	13.29	41.69	43.90	42.48	19.07	11.07	10.49	232.34
50	1991	10.69	12.28	11.62	10.79	10.19	30.59	42.48	24.82	29.64	14.11	11.01	9.85	218.06
51	1992	9.86	10.43	10.44	9.77	8.32	12.19	42.48	43.90	42.48	22.57	11.10	10.97	234.52
52	1993	19.24	23.01	13.16	11.53	14.44	34.29	42.48	43.90	42.48	20.43	11.78	10.91	287.65
53	1994	10.29	11.13	11.28	11.19	10.03	38.92	42.48	43.90	27.56	12.55	11.11	10.11	240.55
TOTAL		621.93	616.46	613.11	587.64	585.33	1097.48	1775.74	2042.68	1834.29	993.63	623.23	577.62	11969.12
AVE		11.73	11.63	11.57	11.09	11.04	20.71	33.50	38.54	34.61	18.75	11.76	10.90	225.83
MAX		20.41	23.01	17.83	14.00	22.24	43.90	42.48	43.90	42.48	43.90	18.55	13.84	300.48
MIN		9.86	9.95	10.26	4.84	5.96	9.00	13.22	14.78	13.05	11.19	10.28	9.54	139.73

Table 9-27 Firm Energy Production of Bağlık Project

Unit: GWh

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1	1942	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
2	1943	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
3	1944	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
4	1945	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
5	1946	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
6	1947	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
7	1948	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
8	1949	10.97	10.62	10.97	10.97	9.74	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.04
9	1950	10.97	10.62	10.94	10.61	9.73	10.97	10.62	10.97	10.62	10.97	10.97	10.62	128.63
10	1951	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
11	1952	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
12	1953	10.97	10.62	10.97	10.61	9.73	10.90	10.62	10.97	10.62	10.97	10.97	10.62	128.59
13	1954	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
14	1955	10.97	10.62	10.97	10.97	10.13	10.97	10.62	10.97	10.62	10.97	10.88	10.11	128.83
15	1956	10.45	10.11	10.26	4.84	6.63	9.00	10.62	10.97	10.62	10.97	10.97	10.62	116.08
16	1957	10.97	10.44	10.44	10.27	9.75	10.97	10.62	10.97	10.62	10.97	10.97	10.62	127.64
17	1958	10.97	10.62	10.97	10.93	9.75	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.01
18	1959	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
19	1960	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
20	1961	10.97	10.62	10.97	10.68	9.58	10.97	10.62	10.97	10.62	10.97	10.71	9.95	127.64
21	1962	10.36	10.35	10.97	10.97	8.50	10.97	10.62	10.97	10.62	10.97	10.97	10.62	126.92
22	1963	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
23	1964	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
24	1965	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.13	128.72
25	1966	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.53	129.12
26	1967	10.44	9.95	10.44	10.27	5.96	10.76	10.62	10.97	10.62	10.97	10.97	10.62	122.61
27	1968	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
28	1969	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.48	129.07
29	1970	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
30	1971	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.61	129.56
31	1972	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
32	1973	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
33	1974	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
34	1975	10.97	10.62	10.97	10.93	10.14	10.97	10.62	10.97	10.62	10.97	10.97	10.56	129.33
35	1976	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
36	1977	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
37	1978	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
38	1979	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
39	1980	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
40	1981	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
41	1982	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.61	129.20
42	1983	10.97	10.62	10.71	10.69	9.84	10.97	10.62	10.97	10.62	10.97	10.28	9.54	126.82
43	1984	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.37	128.96
44	1985	10.02	10.27	10.27	10.27	9.66	10.97	10.62	10.97	10.62	10.97	10.79	10.62	126.07
45	1986	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.62	10.02	128.25
46	1987	10.69	10.11	10.27	10.52	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	127.62
47	1988	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
48	1989	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.53	10.18	128.33
49	1990	10.36	10.19	10.44	9.64	9.43	10.97	10.62	10.97	10.62	10.97	10.97	10.49	125.98
50	1991	10.69	10.62	10.97	10.79	10.14	10.97	10.62	10.97	10.62	10.97	10.97	9.85	128.21
51	1992	9.86	10.43	10.44	9.77	8.32	10.97	10.62	10.97	10.62	10.97	10.97	10.62	124.58
52	1993	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
53	1994	10.29	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.11	128.02
TOTAL		576.02	559.76	577.07	569.12	516.63	579.36	582.86	581.62	582.84	581.62	579.58	557.09	6803.57
AVE		10.87	10.56	10.89	10.74	9.75	10.93	10.62	10.97	10.62	10.97	10.94	10.51	128.37
MAX		10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
MIN		9.86	9.95	10.26	4.84	5.96	9.00	10.62	10.97	10.62	10.97	10.28	9.54	116.08

Table 9-28 Peak Power of Bağlık Project

Unit: MW

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< AVE >
1	1942	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
2	1943	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
3	1944	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
4	1945	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
5	1946	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
6	1947	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
7	1948	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
8	1949	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
9	1950	59.00	59.00	58.81	57.03	57.93	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.92
10	1951	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.73
11	1952	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
12	1953	59.00	59.00	59.00	57.06	57.93	58.59	59.00	59.00	59.00	59.00	59.00	59.00	58.72
13	1954	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
14	1955	59.00	59.00	59.00	59.00	58.24	59.00	59.00	59.00	59.00	59.00	58.49	56.17	58.66
15	1956	56.19	56.18	55.16	26.02	39.48	48.41	59.00	59.00	59.00	59.00	59.00	59.00	53.01
16	1957	59.00	58.13	56.13	55.24	58.04	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.29
17	1958	59.00	59.00	59.00	58.77	58.04	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.91
18	1959	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
19	1960	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
20	1961	59.00	59.00	59.00	57.40	57.03	59.00	59.00	59.00	59.00	59.00	57.58	55.26	58.28
21	1962	55.72	57.52	59.00	59.00	50.60	59.00	59.00	59.00	59.00	59.00	59.00	59.00	57.66
22	1963	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
23	1964	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
24	1965	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
25	1966	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	56.27	58.78
26	1967	56.14	55.25	56.14	55.24	34.28	57.84	59.00	59.00	59.00	59.00	59.00	58.49	58.96
27	1968	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	55.83
28	1969	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
29	1970	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.22	58.94
30	1971	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
31	1972	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.96	59.00
32	1973	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
33	1974	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
34	1975	59.00	59.00	59.00	58.74	58.25	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.66
35	1976	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.89
36	1977	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
37	1978	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
38	1979	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
39	1980	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
40	1981	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
41	1982	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.97	59.00
42	1983	59.00	59.00	57.58	57.47	56.58	59.00	59.00	59.00	59.00	59.00	55.27	52.99	57.25
43	1984	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	57.41	58.89
44	1985	53.89	57.04	55.23	55.23	57.48	59.00	59.00	59.00	59.00	59.00	58.00	59.00	57.56
45	1986	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	57.08	55.67	58.56
46	1987	57.49	56.14	55.24	56.58	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.11
47	1988	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
48	1989	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.63	56.57	58.60
49	1990	55.69	56.59	56.13	53.44	56.14	59.00	59.00	59.00	59.00	59.00	59.00	58.25	57.52
50	1991	57.48	59.00	59.00	58.03	58.30	59.00	59.00	59.00	59.00	59.00	59.00	54.71	58.38
51	1992	53.00	57.95	56.14	52.54	49.54	59.00	59.00	59.00	59.00	59.00	59.00	59.00	56.89
52	1993	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
53	1994	55.30	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	56.19	58.45
AVE		58.43	58.68	58.54	57.73	57.53	58.77	59.00	59.00	59.00	59.00	58.79	58.40	58.58
MAX		59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
MIN		53.00	55.25	55.16	26.02	34.28	48.41	59.00	59.00	59.00	59.00	55.27	52.99	53.01

Table 9-29(1) Peak Power Duration of Bağlık Project

No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)
1	59.00	41	59.00	81	59.00	121	59.00	161	59.00	201	59.00	241	59.00	281	59.00
2	59.00	42	59.00	82	59.00	122	59.00	162	59.00	202	59.00	242	59.00	282	59.00
3	59.00	43	59.00	83	59.00	123	59.00	163	59.00	203	59.00	243	59.00	283	59.00
4	59.00	44	59.00	84	59.00	124	59.00	164	59.00	204	59.00	244	59.00	284	59.00
5	59.00	45	59.00	85	59.00	125	59.00	165	59.00	205	59.00	245	59.00	285	59.00
6	59.00	46	59.00	86	59.00	126	59.00	166	59.00	206	59.00	246	59.00	286	59.00
7	59.00	47	59.00	87	59.00	127	59.00	167	59.00	207	59.00	247	59.00	287	59.00
8	59.00	48	59.00	88	59.00	128	59.00	168	59.00	208	59.00	248	59.00	288	59.00
9	59.00	49	59.00	89	59.00	129	59.00	169	59.00	209	59.00	249	59.00	289	59.00
10	59.00	50	59.00	90	59.00	130	59.00	170	59.00	210	59.00	250	59.00	290	59.00
11	59.00	51	59.00	91	59.00	131	59.00	171	59.00	211	59.00	251	59.00	291	59.00
12	59.00	52	59.00	92	59.00	132	59.00	172	59.00	212	59.00	252	59.00	292	59.00
13	59.00	53	59.00	93	59.00	133	59.00	173	59.00	213	59.00	253	59.00	293	59.00
14	59.00	54	59.00	94	59.00	134	59.00	174	59.00	214	59.00	254	59.00	294	59.00
15	59.00	55	59.00	95	59.00	135	59.00	175	59.00	215	59.00	255	59.00	295	59.00
16	59.00	56	59.00	96	59.00	136	59.00	176	59.00	216	59.00	256	59.00	296	59.00
17	59.00	57	59.00	97	59.00	137	59.00	177	59.00	217	59.00	257	59.00	297	59.00
18	59.00	58	59.00	98	59.00	138	59.00	178	59.00	218	59.00	258	59.00	298	59.00
19	59.00	59	59.00	99	59.00	139	59.00	179	59.00	219	59.00	259	59.00	299	59.00
20	59.00	60	59.00	100	59.00	140	59.00	180	59.00	220	59.00	260	59.00	300	59.00
21	59.00	61	59.00	101	59.00	141	59.00	181	59.00	221	59.00	261	59.00	301	59.00
22	59.00	62	59.00	102	59.00	142	59.00	182	59.00	222	59.00	262	59.00	302	59.00
23	59.00	63	59.00	103	59.00	143	59.00	183	59.00	223	59.00	263	59.00	303	59.00
24	59.00	64	59.00	104	59.00	144	59.00	184	59.00	224	59.00	264	59.00	304	59.00
25	59.00	65	59.00	105	59.00	145	59.00	185	59.00	225	59.00	265	59.00	305	59.00
26	59.00	66	59.00	106	59.00	146	59.00	186	59.00	226	59.00	266	59.00	306	59.00
27	59.00	67	59.00	107	59.00	147	59.00	187	59.00	227	59.00	267	59.00	307	59.00
28	59.00	68	59.00	108	59.00	148	59.00	188	59.00	228	59.00	268	59.00	308	59.00
29	59.00	69	59.00	109	59.00	149	59.00	189	59.00	229	59.00	269	59.00	309	59.00
30	59.00	70	59.00	110	59.00	150	59.00	190	59.00	230	59.00	270	59.00	310	59.00
31	59.00	71	59.00	111	59.00	151	59.00	191	59.00	231	59.00	271	59.00	311	59.00
32	59.00	72	59.00	112	59.00	152	59.00	192	59.00	232	59.00	272	59.00	312	59.00
33	59.00	73	59.00	113	59.00	153	59.00	193	59.00	233	59.00	273	59.00	313	59.00
34	59.00	74	59.00	114	59.00	154	59.00	194	59.00	234	59.00	274	59.00	314	59.00
35	59.00	75	59.00	115	59.00	155	59.00	195	59.00	235	59.00	275	59.00	315	59.00
36	59.00	76	59.00	116	59.00	156	59.00	196	59.00	236	59.00	276	59.00	316	59.00
37	59.00	77	59.00	117	59.00	157	59.00	197	59.00	237	59.00	277	59.00	317	59.00
38	59.00	78	59.00	118	59.00	158	59.00	198	59.00	238	59.00	278	59.00	318	59.00
39	59.00	79	59.00	119	59.00	159	59.00	199	59.00	239	59.00	279	59.00	319	59.00
40	59.00	80	59.00	120	59.00	160	59.00	200	59.00	240	59.00	280	59.00	320	59.00

Table 9-29(2) Peak Power Duration of Bağlık Project

No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)
321	59.00	361	59.00	401	59.00	441	59.00	481	59.00	521	59.00	561	59.00	601	56.19
322	59.00	362	59.00	402	59.00	442	59.00	482	59.00	522	59.00	562	58.66	602	56.19
323	59.00	363	59.00	403	59.00	443	59.00	483	59.00	523	59.00	563	58.59	603	56.18
324	59.00	364	59.00	404	59.00	444	59.00	484	59.00	524	59.00	564	58.49	604	56.17
325	59.00	365	59.00	405	59.00	445	59.00	485	59.00	525	59.00	565	58.49	605	56.14
326	59.00	366	59.00	406	59.00	446	59.00	486	59.00	526	59.00	566	58.30	606	56.14
327	59.00	367	59.00	407	59.00	447	59.00	487	59.00	527	59.00	567	58.25	607	56.14
328	59.00	368	59.00	408	59.00	448	59.00	488	59.00	528	59.00	568	58.25	608	56.14
329	59.00	369	59.00	409	59.00	449	59.00	489	59.00	529	59.00	569	58.24	609	56.14
330	59.00	370	59.00	410	59.00	450	59.00	490	59.00	530	59.00	570	58.22	610	56.13
331	59.00	371	59.00	411	59.00	451	59.00	491	59.00	531	59.00	571	58.13	611	56.13
332	59.00	372	59.00	412	59.00	452	59.00	492	59.00	532	59.00	572	58.04	612	55.72
333	59.00	373	59.00	413	59.00	453	59.00	493	59.00	533	59.00	573	58.04	613	55.69
334	59.00	374	59.00	414	59.00	454	59.00	494	59.00	534	59.00	574	58.03	614	55.67
335	59.00	375	59.00	415	59.00	455	59.00	495	59.00	535	59.00	575	58.00	615	55.30
336	59.00	376	59.00	416	59.00	456	59.00	496	59.00	536	59.00	576	57.98	616	55.27
337	59.00	377	59.00	417	59.00	457	59.00	497	59.00	537	59.00	577	57.95	617	55.26
338	59.00	378	59.00	418	59.00	458	59.00	498	59.00	538	59.00	578	57.93	618	55.25
339	59.00	379	59.00	419	59.00	459	59.00	499	59.00	539	59.00	579	57.93	619	55.24
340	59.00	380	59.00	420	59.00	460	59.00	500	59.00	540	59.00	580	57.84	620	55.24
341	59.00	381	59.00	421	59.00	461	59.00	501	59.00	541	59.00	581	57.61	621	55.24
342	59.00	382	59.00	422	59.00	462	59.00	502	59.00	542	59.00	582	57.58	622	55.23
343	59.00	383	59.00	423	59.00	463	59.00	503	59.00	543	59.00	583	57.56	623	55.23
344	59.00	384	59.00	424	59.00	464	59.00	504	59.00	544	59.00	584	57.52	624	55.16
345	59.00	385	59.00	425	59.00	465	59.00	505	59.00	545	59.00	585	57.49	625	54.71
346	59.00	386	59.00	426	59.00	466	59.00	506	59.00	546	59.00	586	57.48	626	53.89
347	59.00	387	59.00	427	59.00	467	59.00	507	59.00	547	59.00	587	57.48	627	53.44
348	59.00	388	59.00	428	59.00	468	59.00	508	59.00	548	59.00	588	57.47	628	53.00
349	59.00	389	59.00	429	59.00	469	59.00	509	59.00	549	59.00	589	57.40	629	52.99
350	59.00	390	59.00	430	59.00	470	59.00	510	59.00	550	59.00	590	57.08	630	52.54
351	59.00	391	59.00	431	59.00	471	59.00	511	59.00	551	59.00	591	57.06	631	50.60
352	59.00	392	59.00	432	59.00	472	59.00	512	59.00	552	59.00	592	57.04	632	49.54
353	59.00	393	59.00	433	59.00	473	59.00	513	59.00	553	59.00	593	57.03	633	48.41
354	59.00	394	59.00	434	59.00	474	59.00	514	59.00	554	59.00	594	57.03	634	39.48
355	59.00	395	59.00	435	59.00	475	59.00	515	59.00	555	59.00	595	56.63	635	34.28
356	59.00	396	59.00	436	59.00	476	59.00	516	59.00	556	59.00	596	56.59	636	26.02
357	59.00	397	59.00	437	59.00	477	59.00	517	59.00	557	58.97	597	56.58		
358	59.00	398	59.00	438	59.00	478	59.00	518	59.00	558	58.96	598	56.58		
359	59.00	399	59.00	439	59.00	479	59.00	519	59.00	559	58.81	599	56.57		
360	59.00	400	59.00	440	59.00	480	59.00	520	59.00	560	58.77	600	56.27		





Figure 9-18(1) Reservoir Operation of Bayram Project





Figure 9-18(2) Reservoir Operation of Bayram Project.





Figure 9-18(3) Reservoir Operation of Bayram Project





Figure 9-19(1) Energy Generation of Bayram Project





Figure 9-19(2) Energy Generation of Bayram Project





Figure 9-19(3) Energy Generation of Bayram Project





Figure 9-20(1) Reservoir Operation of Bağlık Project





Figure 9-20(2) Reservoir Operation of Bağlık Project





Figure 9-20(3) Reservoir Operation of Bağlık Project





Figure 9-21(1) Energy Generation of Bağlık Project





Figure 9-21(2) Energy Generation of Bařlık Project





Figure 9-21(3) Energy Generation of Bağlık Project

**CHAPTER 10 TRANSMISSION LINE AND
POWER SYSTEM ANALYSIS**

CONTENTS

	Page
Chapter 10 TRANSMISSION LINE AND POWER SYSTEM ANALYSIS	
10.1	Summary of Power System 10-1
10.2	Route Survey of Transmission Line 10-2
10.3	Survey of Switchyard 10-3
10.4	Transmission Line Plan for Berta Project 10-3
10.5	Power System Analysis 10-4

List of Figures

- Figure 10-1 TEAŞ 380 kV Transmission Line Expansion Plan
- Figure 10-2 EİE Transmission Line Expansion Plan
- Figure 10-3 TEAŞ 154 kV Transmission Line Expansion Plan
- Figure 10-4 Transmission System of Çoruh-Berta River Hydroelectric Power Development Project
- Figure 10-5 Scope of Power System Analysis
- Figure 10-6 Power Flow in 2010
- Figure 10-7 Stability Study



CHAPTER 10 TRANSMISSION LINE AND POWER SYSTEM ANALYSIS

10.1 Summary of Power System

The transmission system in Turkey comprises 380 kV of primary system and 154 kV of secondary system. In addition, 66 kV and 34.5 kV form the lower voltage systems. The total distance of transmission lines at the end of 1994 is 10,717 km for 380 kV and 24,832 km for 154 kV and for below 66 kV 1,190 km.

Power plants newly developed are generally connected to classified systems in response to their plant sizes, that is, large power plants are connected to 380 kV systems, medium and small power plants to 154 kV or 66 kV systems. According to the long term program of TEAŞ, expansion plans of 380 kV transmission lines are formulated taking into account network conditions for 10 years, in a future, and 154 kV lines taking into account these for 5 to 7 years.

TEAŞ has expansion plan of 380 kV power system until 2010 which was prepared in 1994. Figure 10-1 shows expansion plan of eastern power system which will be connected with Berta project:

From this plan, new power plants of eastern power system will be connected with 380 kV power system which will be commissioning in 2005 and this new 380 kV power system will be connected with existing 380 kV power system.

On the other hand, according to the master plan of EİE, transmission lines route of Berta project is indicated as Figure 10-2. This plan is that Bağlık project will be connected with Artvin Substation.

From switchyard plan of Deriner project which is now preparing, Deriner project has two switchyards with 380 kV and 154 kV. 380 kV switchyard will be connected with 380 kV power system which will be commissioning in 2005. Oltu project (including Olur project and Ayvali project) which will be commissioning in 2005 and 2006, branch of existing 154 kV line and Berta project will be connected with 154 kV switchyard of Deriner project. (refer to Figure 10-3)

10.2 Route Survey of Transmission Line

The route survey for the planned transmission line was conducted as to the following two routes.

- (1) Bayram project → Bağılık project
- (2)-(a) Bağılık project → Connection based on EİE master plan (Artvin substation)
- (b) Bağılık project → 154 kV Switchyard of Deriner project

- (1) From Bayram project to Bağılık project

Judging from geographical condition and existing transmission lines, it was found there are no technical restriction which may obstruct construction.

- (2)-(a) From Bağılık project to Artvin substation

In the view of EİE master plan, there are two plans consist of new 154 kV transmission line and using existing 154 kV transmission line (Artvin-Ardahan). As the result of survey, the capacity of existing 154 kV transmission line is only 60 MVA and this means it is impossible to use existing 154 kV transmission line. The measurement for this is replacing the transmission line. And except this replacing work, new transmission line with above 12 km from Bağılık project to existing 154 kV transmission line is necessary.

Furthermore, Artvin substation which will be connected with transmission line from Bağılık project locates narrow mountains district and slope area. So there is no place to install additional equipment.

- (2)-(b) From Bağılık project to 154 kV Switchyard of Deriner project.

There is only new transmission line with 25 km between Bağılık project and 154 kV switchyard of Deriner project.

Because plan (2)-(a) has a lot of restriction and the construction cost estimated more expensive, JICA Study Team recommend plan (2)-(b).

In conclusion, transmission line route is from Bayram project to 154 kV switchyard of Deriner project via Bağlık project.

Figure 10-4 shows outline of transmission system of Berta project.

Before construction, topographical profile of this route should be measured and optimum route should be prepared.

10.3 Survey of Switchyard

JICA Study Team carried out site survey of switchyard for 154 kV transmission line.

In the case of Bayram project, it is confirmed that space for switchyard is ensured at the foot of Dam. Next, in the case of Bağlık project, as a result of site survey, this area is so narrow slope that there is no space to install switchyard. For this situation, power transformer and 154 kV power plant equipment will be installed in powerhouse and outside there will be only outgoing structures.

10.4 Transmission Line Plan for Berta Project

The design condition of transmission line project consists of, to send power demand user economically, to plan based on power system plan of TEAŞ, in accordance with Turkey's standard and to operate safely if accident occurs. Based on these condition, transmission line plan for Berta project is designed as follows.

(1) Transmission Line Voltage

From above mentioned, transmission line for Berta project will be connected with 154 kV switchyard of Deriner project. So transmission line voltage is 154 kV.

(2) Number of Circuits

(a) Bağlık - Bayram : 1 cct

(b) Bağlık - Deriner : 2 cct

(3) Length and Conductor Size

From topographical map, length of transmission line shows as follows.

(a) Bağlık - Bayram : 12 km

(b) Bağlık - Deriner : 25 km

Conductor size is taken for ACSR477MCM (aluminum conductor steel reinforced) out of the standard sizes currently used by TEAŞ.

10.5 Power System Analysis

(1) Purpose of Calculation and Contents

A power system analysis was conducted to verify the characteristics of the power system near the Bayram project and Bağlık project.

The contents of the calculation are as follows:

- Power flow calculation
- Stability calculation
- Short-circuit current calculation

(2) Target Year of Calculation and Range of Simulation

The target year of calculation is presumed to be around 2010 around the operation of the Bayram project and Bağlık project will be commissioned. Since the planned output of the Berta Project is consumed in the nearby 154 kV system, the range of calculation is only limited to the 154 kV system. Figure 10-5 shows scope of calculation. Here Berta project is assumed to be connected with bus of Artvin substation.

(3) Power Flow Calculation

Power flow and voltage calculation was conducted by presuming the operational conditions of the power system as follows:

System voltage being maintained:	95 to 105%
Operating voltage of generator:	100 ±5%
Operation power factor of generator:	Above 0.85
Tap ratio of transformer:	1.00 ±0.10 P.U.

The result is shown as Figure 10-6, and there is no problem.

(4) Stability Calculation

In power system stability study after commissioning the Berta project, a three-phase-ground- fault is applied as the system disturbance on the 154 kV transmission lines and the fault is cleared in 6 cycles (100 ms). The result of simulation study is presented in Figure 10-7. The system is stable from this result.

(5) Short Circuit Capacity Calculation

Study condition is that all generators are connected to the system. Subtransient reactance $X'd$ is used for calculation.

Three-phase short circuit current capacity at bUs of Artvin Substation is 13KA. This shows no problem.




Figure 10-1 TEAS 380 kV Transmission Line Expansion Plan




Figure 10-2 EiE Transmission Line Expansion Plan




Figure 10-3 TEAS 154 kV Transmission Line Expansion Plan

