

### 9.2.3 計画代替案の比較検討

#### (I) 貯水池運用計画

##### (a) Bayram計画

Bayramダム地点の年平均流入量は $19.2\text{ m}^3/\text{s}$ で、4月～6月の融雪期が豊水期にあたりこの時期に年間流入量の63%が流入する。渇水期にあたる12月～2月の流入量は、年間流入量の9%であり、流入量の季節変動幅は小さくない。また年間流入量の最小値は、平均流入量の49%、最大値は平均流入量の188%であり、年間流入量の最大値は最小値の3.8倍である。

この様にBayram計画地点の流入量は、季節変動および経年変動ともかなり大きく、発電への有効利用を図るには、ある程度の貯水池容量が必要である。

Bayram計画の貯水池容量は、満水位標高 740mで有効貯水容量  $113 \times 10^6 \text{ m}^3$ が確保できる。この程度の調整容量では、流入量を完全に平均化する事はできないが、貯水池からの溢水量を最小限に抑える事は可能である。

従って、Bayram貯水池の運用操作ルールは次の諸点を考慮して設定した。

- (a) 豊水年の出水を貯留して渇水年に補給し、保証使用水量を出来るだけ大きくする。
- (b) 一年の内では、豊水期の出水を貯留して渇水期に補給するよう運用する。
- (c) 貯水池の無効溢水を出来るだけ小さくするよう運用する。
- (d) 長期にわたり安定した出力が確保でき、かつ発生電力量が大きくなるよう運用する。

##### (b) Bağlık計画

Bağlıkダム地点の流入量は、Bayramダム地点の流入量をBayram貯水池で調整した後の発電放流量およびダム洪水吐からの放流量と、BayramダムとBağlıkダムの間の残流域からの流入量の合計値となる。

Bayram計画の有効貯水容量が  $113 \times 10^6 \text{ m}^3$ の場合、Bağlıkダム地点では、年間平均流入量は $24.9\text{ m}^3/\text{s}$ である。4月～6月の融雪期が豊水期に年間流入量の51%が流入する。渇水期の12月～2月の流入量は年間流入量の15%である。また年間流入量の最小値は、平均流入量の56%、最大値は平均流入量の180%であり、年間流入量の最大値は最小値の4.09倍である。

この様にBayram貯水池による調整後のBağlıkダム地点の流入量は季節変動および経年変動ともかなり大きい。

一方、Bağlıkダム地点は満水位を標高 570mとした場合、ダム高さは124mと Bayramダムと同程度の規模となるが、有効貯水容量は $30 \times 10^6 \text{ m}^3$ しか確保できない。この場合、わずかな調整効果を出す大幅な貯水池の変動を生じ、このため大幅な発電落差の変動を来す。この結果、貯水池による流入量の調整効果は、貯水池の水位変動による損失落差により相殺されてしまい、Bağlık貯水池の規模を大きくする事がBağlık計画の発電量の増加にはつながらない。

従って、Bağlık計画については季節調整を行う貯水池に加えて、日間調整容量のみ確保する貯水池規模についても検討を行う事とした。また貯水池の運用操作ルールは Bayram貯水池と同様の方針で設定した。

### (c) 貯水池運用計画

貯水池運用の計算は、電子計算機により月平均流量を用いて行い、1942年10月から1995年9月までの53年間を対象とした。保証使用水量は、53年間のうち95%の期間は使用出来る流量と定義し、流入量のマスクープを用いて経年貯留も考慮して保証使用水量が最も大きくなるように決定した。Figure 9-9 にBayram貯水池流入量のマスクープ、Figure 9-10 にBayram貯水池とBağlık貯水池の有効容量と保証使用水量の関係を示す。

発生電力量の計算は、水車、発電機の水位による効率の変化を考慮し、かつ基準取水位より水位の高い時は最大出力に合わせて最大使用水量を絞ることとし、基準取水位より水位の低い時は、落差の低下による最大使用水量の低下を考慮した。なお、基準取水位は満水位より利用水深の1/3だけ低い水位とした。

Figure 9-11 に電力量計算の手順を示し、Figure 9-12 にBayram計画の貯水池満水位 740m、低水位 686m、放水位 530mのケースのBayram貯水池の運用ルールを示す。この Figure 9-12 に示す運用ルールカーブは、前期(a)~(d)に述べた貯水池運用の方針に基づいて、電子計算機によるDynamic Program Method (DP法)にて、発生電力量が最大となるよう作成されたものである。

Figure 9-13 に、同じケースについて、従来一般的に用いられて来たマスクープにより貯水池よりの溢水を最小限となるよう作成されたルールカーブを示す。

この2つのルールカーブによる電力量計算結果は下表に示す通りで、両者に大きな差は無い。このため代替案の比較検討では、各代替案の電力量計算はDP法で作成したルールカーブにより行う事とした。

	DP法	スカ方法
年間発生電力量 (GWh)	247.9	241.2
年間保証電力量 (GWh)	141.4	141.6
保証出力 (MW)	58.0	58.4

またこのDP法によるBayram貯水池のルールカーブは、Bayram貯水池はBayram計画の発電のみの貯水池として作成されており、下流Bağlık貯水池への影響は考慮されていないが最適開発計画に対しては、(4)に述べる様に、Bayram貯水池のルールカーブは、下流Bağlık貯水池も含めた発電に対して最適となるよう検討した。






Figure 9-9 Mass Curve of Bayram Reservoir




Figure 9-10 Firm Discharge of Bayram and Bağlık Reservoir





Fig.9-11 Flow Chart of Power and Energy Calculation



### Symbols

- $V_{n-1}$  : Storage at the end of previous month
- $V_n$  : Storage at the end of current month
- $V_n'$  : Temporary storage at the end of current month
- $V_{max}$  : Maximum storage (effective storage capacity)
- $V_s$  : Secured storage for firm discharge
- $f_n$  : Spill in current month
- $q_n$  : Inflow in current month
- $Q_n$  : Available discharge for power in current month
- $Q_{firm}$  : Firm discharge for power
- $Q_{max}$  : Maximum discharge for power, variable depending on water level

### Operation Rule

$$V_n = V_{n-1} + q_n$$

1.  $V_n \geq V_{max}$

(1)  $V_n - V_{max} \geq Q_{max} \rightarrow Q_n = Q_{max}$

(2)  $Q_{max} > V_n - V_{max} \geq Q_{firm} \rightarrow Q_n = V_n - V_{max}$

(3)  $Q_{firm} > V_n - V_{max} \rightarrow Q_n = Q_{firm}$

2.  $V_s > V_n$

(1)  $V_n \geq Q_{firm} \rightarrow Q_n = Q_{firm}$



(2)  $Q_{firm} > V_n \rightarrow Q_n = V_n$

$$V_n - Q_n - V_{max} \geq 0.0 \rightarrow f_n = V_n - V_{max} - Q_n$$

$$V_n - Q_n - V_{max} < 0.0 \rightarrow f_n = 0.0$$

$$V_n = V_n' - Q_n - f_n$$

Figure 9-12 Operation Rule of Reservoir by Dynamic Program Method for Energy Maximum



Maximum discharge for power

### Symbols

- $V_{n-1}$  : Storage at the end of previous month
- $V_n$  : Storage at the end of current month
- $V_n'$  : Temporary storage at the end of current month
- $V_{max}$  : Maximum storage (effective storage capacity)
- $V_s$  : Secured storage for firm discharge
- $f_n$  : Spill in current month
- $q_n$  : Inflow in current month
- $Q_n$  : Available discharge for power in current month
- $Q_{firm}$  : Firm discharge for power
- $Q_{max}$  : Maximum discharge for power, variable depending on water level

### Operation Rule

$$V_n = V_{n-1} + q_n$$

1.  $V_n \geq V_{max}$

- (1)  $V_n - V_{max} \geq Q_{max} \rightarrow Q_n = Q_{max}$
- (2)  $Q_{max} > V_n - V_{max} \geq Q_{firm} \rightarrow Q_n = V_n - V_{max}$
- (3)  $Q_{firm} > V_n - V_{max} \rightarrow Q_n = Q_{firm}$

2.  $V_s > V_n$

- (1)  $V_n \geq Q_{firm} \rightarrow Q_n = Q_{firm}$
- (2)  $Q_{firm} > V_n \rightarrow Q_n = V_n$

$$V_n = V_{max} - Q_n \geq 0.0 \rightarrow f_n = V_n - V_{max} - Q_n$$

$$V_n = V_{max} - Q_n < 0.0 \rightarrow f_n = 0.0$$

$$V_n = V_n' - Q_n - f_n$$

Figure 9-13(1) Operation Rules of Reservoir by Mass Curve for Spilled Water Minimum






Figure 9-13(2) Operation Rules of Reservoir by Mass Curve for spilled Water Minimum

## (2) 最適貯水池規模

Bayram計画とBağlık計画の貯水容量の組合せの代替案の比較検討結果を Figure 9-14 および Table 9-9, 9-10 に示す。

Bayram計画とBağlık計画の合計の年間超過便益は、Bağlık計画の貯水容量が小さければ小さい程大きくなる。またBayram計画の貯水容量と合計の年間超過便益の関係は、Bağlık計画の貯水容量との組合せによって最大点が移動するが、Bağlık計画の有効貯水容量  $1.0 \times 10^6 \text{ m}^3$  (H. W. L = 530m) との組合せがBayram貯水池の有効貯水容量の大小に関わらず単に最大となり、またBayram貯水池の有効容量が  $113.0 \times 10^6 \text{ m}^3$  (H. W. L = 740m) の場合が全ての組合せの中で最大となる。

更に、Bayram計画の場合、9.2.2(3)(b)に述べた通り、貯水池低水位の設定によって最適貯水容量および最適貯水池満水位が移動しないか比較検討を行った。この場合Bağlık計画は、有効貯水容量  $1.0 \times 10^6 \text{ m}^3$  (H. W. L = 530m) を最適貯水容量とした。

結果は Figure 9-15 および Table 9-11, 9-12 に示通り、Bağlık計画では貯水池低水位を堆砂容量から決まる最低水位である686mとする代替案が有効貯水容量の大小に関わらず常に最大となり、また満水位=740m、有効貯水容量  $113.0 \times 10^6 \text{ m}^3$  のケースが全てのケースの中で最大となる。

従ってBayram計画はこのケースを最適とする。

Bağlık計画については、Table 9-13 に示す様にBayram計画の最適ケースである満水位=740m、低水位=686mのケースとの組合せでBağlık計画の満水位=570mと550mに対して、堆砂容量から決定した低水位=527mより高い水位に低水位を設定したケースによる代替案を策定して満水位=530m (低水位=527m) の代替案との比較検討を行った。

結果は Figure 9-16, Table 9-14, 9-15 に示す通り、最適貯水池規模である満水位=530m、低水位=527mがBağlık計画の最適貯水池規模となった。

## (3) 発電所規模

水力発電所の設備出力の決定要因は、次式に示すとおり有効落差と最大使用水量であり、また最大使用水量は、一般に保証流量と、等価ピーク継続時間により決定される。

$$\text{設備出力 (kW)} = 9.8 \times \text{水車} \cdot \text{発電機効率} \times \text{有効落差 (m)} \times \text{最大使用水量 (m}^3/\text{s)}$$

$$\text{最大使用水量 (m}^3/\text{s)} = \text{保証流量 (m}^3/\text{s)} \times \frac{24 \text{時間}}{\text{等価ピーク継続時間}}$$

上記要因のうち、有効落差と保証流量は、(2)の検討により有効貯水容量および取、放水等物理的条件により決定されるが、等価ピーク継続時間は、上記と違う条件により決定される。

本来、水力発電所の等価ピーク継続時間は、その水力発電所が投入される時点での電力系統からの要求により決定されるべきものである。TEAŞの1995年における電力需給計画によれば、Çoruh・Berta計画の建設開始が予定されている2002年および需給計画最終年である2010における電力系統の状況はTable 9-16に示す通りである。

Table 9-16 Demand and Supply Balance

Year			2002	2010
Demand				
a.	Peak Power	(MW)	24,360	43,590
b.	Annual Energy	(GWh)	151,720	271,450
Consumption				
Supply				
c.	Thermal	(MW)	19,090	36,970
d.	Hydro	(MW)	15,421	23,086
e.	Total	(MW)	34,511	60,056
Annual Energy Production				
f.	Thermal	(GWh)	119,838	236,558
g.	Hydro (Dependable)	(GWh)	38,291	52,219
Supply Margin (e-a)			10,151	16,466
Supply Margin Rate ((e-a)/a)			42	38
Equivalent Peak Duration Hours for Hydro (g/d)/365)			6.8	6.2

上表によれば、2002年および2010年時点の水力発電全体の平均の等価ピーク継続時間は各々6.8時間、6.2時間であるが、これは最大負荷日の日電力量を年間平均電力量として計算したものであるため、実際の等価ピーク継続時間はこれより多少長くなっているものと思われるが、電力系統全体に対する水力発電の占める割合は年々減少の傾向にあるため、等価ピーク継続時間も年々短くなっていくものと思われる。Bayram計画、Bağlık計画

では他の大部分の水力発電計画と同様に、流入量のほぼ全量を発電に使用する事が可能なだけの貯水容量を備えているため、等価ピーク継続時間を短くして設備出力を大きくしても発生電力量の著しい増大は期待できない。

従って、Bayram計画、Bağlık計画の等価ピーク継続時間は、水力発電全体の平均である6時間程度を限度とする事が妥当であると判断される。

Bayram計画、Bağlık計画の設備出力の最適規模の検討は、保証流量に対して、等価ピーク継続時間を6時間と8時間のケースについて最大使用水量を設定して、比較する事により行った。

比較検討の結果は、Table 9-17 に示す通り、等価ピーク時間継続6時間が最適となり、従ってBayram計画では最大使用水量43m<sup>3</sup>/s、設備出力68MWが最適規模となった。また、Bağlık計画では最大使用水量52m<sup>3</sup>/s、設備出力59MWが最適規模となった。

#### (4) 最終貯水池運用計画

計画の最適化のための各代替案の貯水池運用計画は、(1)(c)に述べた様に、上流計画であるBayram貯水池の貯水池運用計画はBayram計画の発電のみを対象にDP法により行い、Bayram貯水池のルールカーブを作成したが、最終貯水池運用計画として下流Bağlık計画の発電も考慮したBayram計画の貯水池運用計画をDP法により行い、Figure 9-17 に示す最適ルールを作成して電力量計算を行った。

この電力量計算では、ダム下流の減水区間の環境保全のため8月～10月の期間中は、BayramダムとBağlıkダムから各々ダム下流に、0.5m<sup>3</sup>/sの放流を行う事とした。

#### (5) 最適開発計画

これまでの開発計画の検討結果により、Berta川水力発電開発計画はBayram計画、Bağlık計画による2段開発計画とする。

Bayram計画はMeydançık川とŞavşat川の合流点下流 2.5kmのBayram部落地点のBerta川に高さ 140mのダムを築造し、満水位標高 740m、有効貯水容量 113×10<sup>6</sup> m<sup>3</sup>の貯水池を設け、ダム右岸の取水口より最大43m<sup>3</sup>/sを取水し、取水口直下流の地下式発電所で、有効落差 182.2mにより最大出力68MWの発電を行い、発電後の水を延長 7.93kmの放水路トンネルによりKarçal川との合流点上流 2 kmのKöprübaşı部落地点のBerta川に放流する開発計画を最適開発計画とする。

Bağlık計画は、Sungu川合流点下流 0.1kmのArklaşı部落地点のBerta川に高さ74mのダムを築造し、満水位標高 530m、有効貯水容量  $1 \times 10^6 \text{ m}^3$ の貯水池を設け、ダム左岸の取水口より最大52m<sup>3</sup>/sを取水し、取水口直下流の地下式発電所で、有効落差 130.9 mにより最大出力59MWの発電を行い、発電後の水を延長、4.45kmの放水路トンネルによりArklaşı部落地点のBerta川に放流する開発計画を最適開発計画とする。

Table 9-18 にBerta川水力発電開発計画の最適開発計画諸元を示し、概算工事費内訳を Table 9-19 に示す。

Table 9-20 および Figure 9-18 に、Bayram計画の貯水池運用結果による流入量、使用水量、溢水量を示す。Table 9-21, 9-22, 9-23, 9-24 および Figure 9-19 同じく各月の発生電力量、保証電力量を、出力および出力デュレーションを示す。

Table 9-25, Figure 9-20 にBağlık計画の貯水池運用結果による貯水池流入量、使用水量、溢水量を示す。Table 9-26, 9-27, 9-28, 9-29 および Figure 9-21 に同じく各月の発生電力量、保証電力量、出力および出力デュレーションを示す。




Figure 9-14 Comparison Study on Reservoir Capacity




Figure 9-15 Comparison Study on Reservoir Water Level of Bayram Project






Figure 9-16 Comparison Study on Reservoir Water Level of Bağlık Project





**Figure 9-17 Final Reservoir Operation Rule**

**Table 9-9(1) Cost Estimate of Alternative Plan for Reservoir Capacity**

Description	Dam Site Layout Type	Unit 10³ US\$										
		Bayram 750M.P.	Bayram 745M.P.	Bayram 740M.P.	Bayram 735M.P.	Bayram 730M.P.	Bayram 725M.P.	Bayram 720M.P.	Bayram 715M.P.	Bayram 710M.P.	Bayram 705M.P.	Bayram 700M.P.
High Water Level (m)		750	745	740	735	730	725	720	715	710	705	700
Reservoir Area (km²)		3.98	3.68	3.38	3.11	2.83	2.58	2.32	2.10	1.88	1.68	1.47
Dam Volume (10⁶m³)		8,500	7,200	6,144	5,400	4,800	4,300	3,900	3,500	3,100	2,700	2,400
Dam Height (m)		155	150	145	140	135	130	125	120	115	110	105
Maximum Head (m)		190	175	170	165	160	155	150	145	140	135	130
Maximum Discharge (m³/s)		49	46	43	40	38	36	33	31	29	26	24
Relocation Road		13,724	12,689	11,655	10,724	9,758	8,896	8,000	7,241	6,483	5,783	5,069
Camp Facilities		800	800	800	800	800	800	800	800	800	800	800
Land Acquisition		2,939	2,616	2,242	2,063	1,878	1,712	1,539	1,393	1,247	1,115	975
Civil Work		96,218	86,162	76,676	70,197	65,019	60,508	56,750	53,076	49,653	45,616	42,781
Division		2,421	2,885	2,885	2,885	2,885	2,885	2,885	2,885	2,885	2,885	2,885
Care of River		1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082
Dam		65,412	55,407	47,281	41,556	36,936	33,091	30,012	26,934	23,856	20,778	18,469
Spillway		8,143	8,143	7,523	7,434	7,346	7,169	7,080	6,992	6,815	6,726	6,603
Outlet Works		1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018
Intake		1,280	1,280	1,087	999	912	842	736	666	596	491	412
Headrace Tunnel		0	0	0	0	0	0	0	0	0	0	0
Surge Tank		0	0	0	0	0	0	0	0	0	0	0
Panstock		450	413	377	342	317	292	261	239	218	190	171
Access Tunnels		3,980	3,580	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980
Power House		2,985	2,856	2,696	2,503	2,407	2,279	2,086	2,022	2,215	1,733	1,605
Tailrace Tunnel		9,287	8,937	8,586	8,236	7,973	7,710	7,447	7,097	6,834	6,571	6,396
Switchyard		161	161	161	161	161	161	161	161	161	161	161
Pre-Subtotal		113,731	102,659	91,374	83,784	77,455	71,917	67,089	62,511	58,189	53,323	49,625
Contingency (15%)		16,611	14,948	13,370	12,258	11,337	10,531	9,833	9,168	8,541	7,831	7,298
Eng. and Adm. (10%)		12,735	11,460	10,250	9,398	8,691	8,074	7,538	7,029	6,548	6,004	5,595
Sub Total		143,078	128,675	114,993	105,440	97,483	90,521	84,460	78,707	73,279	67,159	62,518
I.D.C. (9.5%/Year)		31,447	25,994	22,974	21,068	19,476	18,085	16,874	15,725	14,640	13,417	12,490
Total		174,525	155,670	137,968	126,508	116,959	108,606	101,334	94,432	87,919	80,576	75,008
Hydraulic Equipment		4,917	4,722	4,385	4,135	3,936	3,754	3,569	3,338	3,170	2,943	2,779
Spillway		856	856	856	856	856	856	856	856	856	856	856
Outlet Works		528	528	528	528	528	528	528	528	528	528	528
Intake Gate		858	858	763	701	640	581	517	458	418	345	289
Panstock		1,979	1,815	1,656	1,504	1,392	1,285	1,149	1,051	956	836	751
Draft Gate		139	131	122	113	108	102	94	88	82	74	68
Tailrace Gate		70	65	61	57	54	51	47	44	41	37	34
Pre-Subtotal		4,470	4,293	3,986	3,780	3,578	3,419	3,190	3,034	2,882	2,675	2,528
Contingency (10%)		447	429	399	376	358	341	319	303	288	268	253
Electro-Mechanical Equipment		15,821	14,494	13,759	12,774	12,320	12,036	11,615	10,343	9,761	9,049	8,438
Equipment		14,877	13,804	13,104	12,166	11,733	11,463	10,490	9,850	9,296	8,618	8,036
Contingency (5%)		744	690	655	608	587	573	523	493	465	431	402
Eng. and Adm. (10%)		2,054	1,922	1,814	1,631	1,626	1,579	1,452	1,368	1,293	1,199	1,122
Sub Total		22,592	21,137	19,959	18,601	17,881	17,370	15,977	15,048	14,225	13,191	12,339
I.D.C. (9.5%/Year)		1,215	1,143	1,045	1,533	1,474	1,432	1,317	1,241	1,173	1,087	1,017
Total		23,806	22,880	21,604	20,134	19,355	18,802	17,294	16,289	15,397	14,278	13,356
Grand Total		198,331	178,550	159,572	146,640	136,314	127,407	118,628	110,720	103,316	94,854	85,364

Description	Dam Site Layout Type	Unit 10³ US\$										
		Baglik 750M.P.	Baglik 745M.P.	Baglik 740M.P.	Baglik 735M.P.	Baglik 730M.P.	Baglik 725M.P.	Baglik 720M.P.	Baglik 715M.P.	Baglik 710M.P.	Baglik 705M.P.	Baglik 700M.P.
High Water Level (m)		570	570	570	570	570	570	570	570	570	570	570
Reservoir Area (km²)		0.37	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23
Dam Volume (10⁶m³)		680	680	680	680	680	680	680	680	680	680	680
Dam Height (m)		114	114	114	114	114	114	114	114	114	114	114
Maximum Head (m)		178	178	178	178	178	178	178	178	178	178	178
Maximum Discharge (m³/s)		82	60	57	54	51	49	48	44	42	40	38
Relocation Road		8,759	9,803	9,603	9,603	9,603	9,603	9,603	9,603	9,603	9,603	9,603
Camp Facilities		800	800	800	800	800	800	800	800	800	800	800
Land Acquisition		598	598	598	598	598	598	598	598	598	598	598
Civil Work		52,826	52,730	52,147	51,753	51,250	50,829	50,321	49,823	49,388	48,967	48,926
Division		0	0	0	0	0	0	0	0	0	0	0
Care of River		0	0	0	0	0	0	0	0	0	0	0
Dam		34,813	34,813	34,813	34,813	34,813	34,813	34,813	34,813	34,813	34,813	34,813
Spillway		780	780	780	780	780	780	780	780	780	780	780
Outlet Works		0	0	0	0	0	0	0	0	0	0	0
Intake		128	126	121	116	111	107	102	99	95	92	89
Headrace Tunnel		0	0	0	0	0	0	0	0	0	0	0
Surge Tank		0	0	0	0	0	0	0	0	0	0	0
Panstock		575	557	530	503	478	458	431	413	395	377	359
Access Tunnels		2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478
Power House		4,247	4,171	3,944	3,906	3,678	3,603	3,451	3,299	3,155	3,110	3,034
Tailrace Tunnel		9,805	9,805	9,481	9,157	8,914	8,590	8,266	7,942	7,617	7,374	7,374
Switchyard		0	0	0	0	0	0	0	0	0	0	0
Pre-Subtotal		60,593	63,731	63,145	62,754	62,251	61,829	61,321	60,824	60,389	60,264	59,927
Contingency (15%)		9,058	9,470	9,382	9,323	9,248	9,185	9,109	9,034	8,914	8,950	8,899
Eng. and Adm. (10%)		6,944	7,280	7,193	7,148	7,090	7,042	6,983	6,926	6,810	6,862	6,823
Sub Total		76,595	80,482	79,723	79,225	78,583	78,056	77,413	76,784	76,613	76,080	75,649
I.D.C. (9.5%/Year)		19,229	20,098	19,913	19,789	19,630	19,497	19,336	19,179	19,137	19,003	18,836
Total		95,824	100,580	99,637	99,014	98,213	97,553	96,750	95,963	95,750	95,083	94,485
Hydraulic Equipment		4,148	4,059	3,913	3,766	3,622	3,525	3,379	3,281	3,184	3,088	2,988
Spillway		870	870	870	870	870	870	870	870	870	870	870
Outlet Works		0	0	0	0	0	0	0	0	0	0	0
Intake Gate		543	535	514	492	470	456	434	420	405	391	378
Panstock		2,141	2,075	1,974	1,874	1,774	1,707	1,606	1,539	1,472	1,405	1,337
Draft Gate		144	140	133	126	119	114	107	102	98	93	88
Tailrace Gate		73	70	67	63	60	57	54	52	49	47	45
Pre-Subtotal		3,771	3,690	3,558	3,425	3,293	3,204	3,071	2,983	2,894	2,805	2,717
Contingency (10%)		377	369	356	343	329	320	307	298	289	281	272
Electro-Mechanical Equipment		23,392	22,083	21,528	20,842	20,368	20,169	19,477	18,997	18,493	17,754	17,455
Equipment		22,278	21,032	20,503	19,945	19,358	19,208	18,550	18,092	17,612	16,909	16,633
Contingency (5%)		1,114	1,052	1,025	997	970	960	927	905	881	849	832
Eng. and Adm. (10%)		2,754	2,614	2,544	2,471	2,399	2,369	2,286	2,228	2,158	2,084	2,045
Sub Total		30,294	28,756	27,986	27,181	26,383	26,063	25,141	24,506	23,844	22,924	22,439
I.D.C.												

**Table 9-9(2) Cost Estimate of Alternative Plan for Reservoir Capacity**

Bayram Project Tailrace Type Undergro. P/S Layout H.W.L.=750m-700m With Baglik H.W.L.=550.00m											
Description	Dam Site Layout Type	Unit 10*3US\$									
		Bayram 750A	Bayram 745A	Bayram 740A	Bayram 735A	Bayram 730A	Bayram 725A	Bayram 720A	Bayram 715A	Bayram 710A	Bayram 705A
High Water Level (m)	750	745	740	735	730	725	720	715	710	705	700
Reservoir Area (km <sup>2</sup> )	3,98	3,68	3,38	3,11	2,83	2,58	2,32	2,10	1,88	1,68	1,47
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )	8,500	7,200	6,144	5,400	4,800	4,300	3,900	3,500	3,100	2,700	2,400
Dam Height (m)	155	150	145	140	135	130	125	120	115	110	105
Maximum Head (m)	200	195	190	185	180	175	170	165	160	155	150
Maximum Discharge (m <sup>3</sup> /s)	49	45	43	40	38	36	33	31	29	28	24
Relocation Road	13,724	12,659	11,655	10,724	9,758	8,896	8,000	7,241	6,483	5,793	5,069
Camp Facilities	800	800	800	800	800	800	800	800	800	800	800
Land Acquisition	2,989	2,616	2,242	2,063	1,878	1,712	1,539	1,393	1,247	1,115	975
Civil Work	100,862	89,792	80,880	74,407	69,278	64,884	61,157	57,408	53,853	50,162	47,444
Diversion	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421
Care of River	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082
Dam	65,412	55,407	47,281	41,556	36,938	33,091	30,012	26,934	23,856	20,778	18,469
Spillway	8,143	7,789	7,789	7,789	7,789	7,789	7,789	7,789	7,789	7,789	7,789
Outlet Works	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018
Intake	1,280	1,192	1,192	1,192	1,192	1,192	1,192	1,192	1,192	1,192	1,192
Headrace Tunnel	0	0	0	0	0	0	0	0	0	0	0
Surge Tank	0	0	0	0	0	0	0	0	0	0	0
Penstock	545	501	456	417	387	358	321	295	269	236	212
Access Tunnels	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980
Power House	3,145	3,081	2,856	2,664	2,568	2,439	2,215	2,086	2,022	1,829	1,701
Tailrace Tunnel	13,876	13,160	12,544	12,128	11,741	11,354	10,967	10,451	10,063	9,676	9,418
Switchyard	161	161	161	161	161	161	161	161	161	161	161
Pre-Subtotal	118,375	105,898	95,577	87,994	81,712	76,292	71,496	66,843	62,363	57,870	54,268
Contingency (15%)	17,006	15,492	14,000	12,890	11,975	11,187	10,494	9,817	9,170	8,513	7,997
Eng. and Adm. (10%)	13,269	11,877	10,733	9,882	9,181	8,577	8,045	7,527	7,031	6,527	6,131
Sub Total	148,953	133,267	120,311	110,766	102,869	96,056	90,035	84,187	78,564	72,910	68,416
I.D.C. (9.5%/Year)	32,738	27,968	24,037	22,130	20,552	19,191	17,988	16,819	15,700	14,566	13,669
Total	181,691	161,235	144,347	132,896	123,421	115,247	108,023	101,006	94,264	87,478	82,084
Hydraulic Equipment	5,376	5,061	4,847	4,647	4,493	4,344	4,150	4,012	3,879	3,705	3,583
Spillway	856	856	856	856	856	856	856	856	856	856	856
Outlet Works	528	528	528	528	528	528	528	528	528	528	528
Intake Gate	838	837	837	837	837	837	837	837	837	837	837
Penstock	2,367	2,202	2,003	1,833	1,702	1,575	1,412	1,295	1,182	1,037	934
Draft Gate	139	131	122	113	108	102	94	88	82	74	68
Tailrace Gate	70	65	61	57	54	51	47	44	41	37	34
Pre-Subtotal	4,888	4,619	4,407	4,225	4,065	3,949	3,773	3,647	3,526	3,368	3,257
Contingency (10%)	489	462	441	422	408	396	377	365	353	337	326
Electro-Mechanical Equipment	18,638	15,591	14,501	13,792	13,247	12,643	11,731	11,120	10,230	9,536	9,238
Equipment	15,646	14,849	13,810	13,135	12,616	12,041	11,172	10,591	9,743	9,082	8,798
Contingency (5%)	792	742	691	657	631	602	559	530	487	454	440
Eng. and Adm. (10%)	2,291	2,067	1,935	1,844	1,774	1,699	1,568	1,513	1,411	1,324	1,282
Sub Total	24,216	22,739	21,283	20,283	19,514	18,686	17,470	16,646	15,520	14,564	14,102
I.D.C. (9.5%/Year)	1,302	1,223	1,144	1,091	1,049	1,005	939	895	834	783	758
Total	25,518	23,962	22,427	21,374	20,563	19,691	18,409	17,541	16,354	15,348	14,860
Grand Total	207,209	185,187	166,775	154,269	143,954	134,938	126,432	118,547	110,638	102,824	96,945

Baglik Project Tailrace Type Undergro. P/S Layout H.W.L.=550.00m With Bayram H.W.L.=750m-700m											
Description	Dam Site Layout Type	Unit 10*3US\$									
		Baglik 750A	Baglik 745A	Baglik 740A	Baglik 735A	Baglik 730A	Baglik 725A	Baglik 720A	Baglik 715A	Baglik 710A	Baglik 705A
High Water Level (m)	550	550	550	550	550	550	550	550	550	550	550
Reservoir Area (km <sup>2</sup> )	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )	420	420	420	420	420	420	420	420	420	420	420
Dam Height (m)	94	94	94	94	94	94	94	94	94	94	94
Maximum Head (m)	158	158	158	158	158	158	158	158	158	158	158
Maximum Discharge (m <sup>3</sup> /s)	59	57	54	52	47	45	42	40	38	35	33
Relocation Road	8,043	8,043	8,043	8,043	8,043	8,043	8,043	8,043	8,043	8,043	8,043
Camp Facilities	800	800	800	800	800	800	800	800	800	800	800
Land Acquisition	1,115	598	598	598	598	598	598	598	598	598	598
Civil Work	38,697	38,677	38,097	37,798	37,123	36,706	36,240	35,745	35,169	34,946	34,570
Diversion	0	0	0	0	0	0	0	0	0	0	0
Care of River	0	0	0	0	0	0	0	0	0	0	0
Dam	21,502	21,502	21,502	21,502	21,502	21,502	21,502	21,502	21,502	21,502	21,502
Spillway	780	780	780	780	780	780	780	780	780	780	780
Outlet Works	0	0	0	0	0	0	0	0	0	0	0
Intake	97	94	89	87	80	78	75	71	68	65	61
Headrace Tunnel	0	0	0	0	0	0	0	0	0	0	0
Surge Tank	0	0	0	0	0	0	0	0	0	0	0
Penstock	491	475	451	435	395	378	354	338	322	298	282
Access Tunnels	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478
Power House	3,868	3,868	3,641	3,603	3,299	3,223	3,110	2,958	2,844	2,692	2,579
Tailrace Tunnel	9,481	9,481	9,157	8,914	8,590	8,266	7,942	7,617	7,374	7,131	6,888
Switchyard	0	0	0	0	0	0	0	0	0	0	0
Pre-Subtotal	48,655	48,118	47,537	47,239	46,564	46,147	45,881	45,186	44,809	44,387	44,010
Contingency (15%)	7,131	7,128	7,041	6,996	6,895	6,832	6,782	6,688	6,632	6,568	6,512
Eng. and Adm. (10%)	5,467	5,465	5,358	5,364	5,286	5,238	5,185	5,128	5,084	5,036	4,992
Sub Total	61,253	60,711	59,976	59,599	58,745	58,217	57,628	57,002	56,525	55,991	55,515
I.D.C. (9.5%/Year)	15,300	15,164	14,981	14,887	14,673	14,541	14,394	14,238	14,119	13,985	13,867
Total	76,552	75,875	74,957	74,485	73,419	72,758	72,023	71,239	70,644	69,977	69,381
Hydraulic Equipment	3,647	3,558	3,425	3,343	3,128	3,047	2,920	2,831	2,741	2,614	2,524
Spillway	870	870	870	870	870	870	870	870	870	870	870
Outlet Works	0	0	0	0	0	0	0	0	0	0	0
Intake Gate	412	368	376	369	340	333	318	304	289	275	260
Penstock	1,827	1,767	1,678	1,618	1,469	1,409	1,319	1,259	1,199	1,109	1,049
Draft Gate	137	133	128	121	109	105	98	93	88	81	77
Tailrace Gate	69	67	63	61	55	53	45	47	45	41	39
Pre-Subtotal	3,316	3,235	3,113	3,039	2,844	2,770	2,655	2,573	2,492	2,377	2,295
Contingency (10%)	332	323	311	304	284	277	265	257	249	238	229
Electro-Mechanical Equipment	21,622	20,838	20,192	19,723	18,493	17,965	17,215	16,652	16,324	15,621	15,402
Equipment	20,590	19,855	19,231	18,754	17,612	17,110	16,395	15,860	15,547	14,877	14,669
Contingency (5%)	1,030	983	962	939	881	855	820	793	777	744	733
Eng. and Adm. (10%)	2,527	2,420	2,362	2,307	2,162	2,101	2,014	1,948	1,907	1,824	1,793
Sub Total	27,797	26,616	25,979	25,373	23,783	23,113	22,149	21,431	20,972	20,059	19,719
I.D.C. (9.5%/Year)	1,575	1,508	1,472	1,437	1,347	1,309	1,255	1,214	1,188	1,136	1,117
Total	29,371	28,124	27,451	26,811	25,130	24,422	23,433	22,645	22,150	21,195	20,836
Grand Total	105,924	103,999	102,426	101,296	98,549	97,181	95,426	93,885	92,834	91,172	90,218

**Table 9-9(3) Cost Estimate of Alternative Plan for Reservoir Capacity**

Bayram Project Tailrace Type Undergro. P/S Layout H.W.L. = 750m-700m with Baglik H.W.L. = 530.00m												Unit 10*3US\$		
Description	Dam Site Layout Type	Bayram 750C	Bayram 745C	Bayram 740C	Bayram 735C	Bayram 730C	Bayram 725C	Bayram 720C	Bayram 715C	Bayram 710C	Bayram 705C	Bayram 700C		
High Water Level (m)		750	745	740	735	730	725	720	715	710	705	700		
Reservoir Area (km <sup>2</sup> )		3.98	3.68	3.38	3.11	2.83	2.58	2.32	2.10	1.88	1.68	1.47		
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )		8,500	7,200	6,144	5,400	4,800	4,300	3,900	3,500	3,100	2,700	2,400		
Dam Height (m)		155	150	145	140	135	130	125	120	115	110	105		
Maximum Head (m)		220	215.00	210.00	205.00	200.00	195.00	190.00	185.00	180.00	175.00	170.00		
Maximum Discharge (m <sup>3</sup> /s)		49	46	43	40	38	36	33	31	29	26	24		
Relocation Road		13,724	12,689	11,655	10,724	9,758	8,856	8,000	7,241	6,433	5,733	5,069		
Camp Facilities		800	800	800	800	800	800	800	800	800	800	800		
Land Acquisition		2,985	2,616	2,242	2,063	1,878	1,712	1,539	1,393	1,247	1,115	975		
Civil Work		103,704	92,403	83,113	76,299	70,884	66,201	62,266	58,227	54,253	50,323	47,318		
Diversion		2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421		
Care of River		1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082		
Dam		65,412	55,407	47,281	41,556	36,938	33,091	30,012	26,934	23,856	20,778	18,469		
Spillway		6,143	7,789	7,523	7,434	7,346	7,169	7,080	6,992	6,815	6,726	6,603		
Outlet Works		1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018		
Intake		1,280	1,192	1,087	999	912	842	736	666	596	491	412		
Headrace Tunnel		0	0	0	0	0	0	0	0	0	0	0		
Surge Tank		0	0	0	0	0	0	0	0	0	0	0		
Penstock		651	599	546	501	468	432	388	357	327	287	259		
Access Tunnels		3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980		
Power House		3,370	3,177	3,049	2,792	2,664	2,568	2,407	2,247	2,086	1,926	1,765		
Tailrace Tunnel		18,187	15,576	14,965	14,354	13,896	13,438	12,980	12,369	11,911	11,453	11,147		
Switchyard		161	151	161	161	161	161	161	161	161	161	161		
Pre-Subtotal		121,217	108,508	97,811	89,886	83,320	77,609	72,805	67,661	62,783	58,000	54,182		
Contingency (15%)		17,734	15,854	14,335	13,173	12,216	11,385	10,660	9,940	9,230	8,537	7,978		
Eng. and Adm. (10%)		13,596	12,178	10,990	10,100	9,366	8,728	8,173	7,621	7,077	6,545	6,116		
Sub Total		152,547	136,570	123,136	113,159	104,902	97,722	91,438	85,222	79,090	73,113	68,256		
I.D.C. (9.5%/Year)		33,528	28,631	24,501	22,608	20,958	19,524	18,268	17,026	15,801	14,607	13,637		
Total		186,075	165,201	147,737	135,767	125,860	117,245	109,706	102,249	94,891	87,720	81,893		
Hydraulic Equipment		5,889	5,557	5,203	4,904	4,658	4,430	4,123	3,908	3,694	3,411	3,206		
Spillway		856	856	856	856	856	856	856	856	856	856	856		
Outlet Works		528	528	528	528	528	528	528	528	528	528	528		
Intake Gate		838	837	763	701	640	591	517	458	418	345	289		
Penstock		2,662	2,635	2,400	2,202	2,048	1,900	1,707	1,569	1,436	1,252	1,140		
Draft Gate		139	131	122	113	108	102	94	88	82	74	68		
Tailrace Gate		70	65	61	57	54	51	47	44	41	37	34		
Pre-Subtotal		5,353	5,052	4,730	4,458	4,234	4,028	3,748	3,552	3,362	3,101	2,915		
Contingency (10%)		535	505	473	446	423	403	375	355	336	310	291		
Electro-Mechanical Equipment		17,482	16,260	15,780	14,944	14,250	13,527	12,713	12,073	11,375	10,357	9,605		
Equipment		16,649	15,488	15,029	14,233	13,572	12,863	12,107	11,458	10,833	9,864	9,338		
Contingency (5%)		832	772	751	712	679	644	605	575	542	493	467		
Eng. and Adm. (10%)		2,337	2,182	2,058	1,985	1,891	1,796	1,684	1,598	1,507	1,377	1,301		
Sub Total		25,707	23,999	23,082	21,833	20,799	19,753	18,519	17,578	16,580	15,145	14,312		
I.D.C. (9.5%/Year)		1,382	1,290	1,241	1,174	1,118	1,062	996	945	891	814	769		
Total		27,089	25,289	24,323	23,007	21,917	20,815	19,514	18,523	17,471	15,959	15,082		
Grand Total		213,164	190,509	172,060	158,774	147,777	138,060	129,220	120,772	112,362	103,679	96,974		

Baglik Project Tailrace Type Undergro. P/S Layout H.W.L. = 530.00m with Bayram H.W.L. = 750m-700m													Unit 10*3US\$	
Description	Dam Site Layout Type	Baglik 750C	Baglik 745C	Baglik 740C	Baglik 735C	Baglik 730C	Baglik 725C	Baglik 720C	Baglik 715C	Baglik 710C	Baglik 705C	Baglik 700C		
High Water Level (m)		530	530	530	530	530	530	530	530	530	530	530		
Reservoir Area (km <sup>2</sup> )		0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37		
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )		195	195	195	195	195	195	195	195	195	195	195		
Dam Height (m)		74	74	74	74	74	74	74	74	74	74	74		
Maximum Head (m)		138	138	138	138	138	138	138	138	138	138	138		
Maximum Discharge (m <sup>3</sup> /s)		58	55	52	48	45	43	40	38	36	33	31		
Relocation Road		6,759	6,759	6,759	6,759	6,759	6,759	6,759	6,759	6,759	6,759	6,759		
Camp Facilities		800	800	800	800	800	800	800	800	800	800	800		
Land Acquisition		558	558	558	558	558	558	558	558	558	558	558		
Civil Work		26,948	26,447	25,984	25,410	24,987	24,495	24,034	23,662	23,290	22,834	22,418		
Diversion		0	0	0	0	0	0	0	0	0	0	0		
Care of River		0	0	0	0	0	0	0	0	0	0	0		
Dam		9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983		
Spillway		780	780	780	780	780	780	780	780	780	780	780		
Outlet Works		0	0	0	0	0	0	0	0	0	0	0		
Intake		44	42	40	37	36	34	32	31	30	28	26		
Headrace Tunnel		0	0	0	0	0	0	0	0	0	0	0		
Surge Tank		0	0	0	0	0	0	0	0	0	0	0		
Penstock		426	405	376	356	335	321	299	285	271	250	235		
Access Tunnels		2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478		
Power House		3,754	3,603	3,413	3,185	3,110	2,958	2,844	2,730	2,617	2,427	2,351		
Tailrace Tunnel		9,481	9,157	8,914	8,590	8,266	7,942	7,617	7,374	7,131	6,888	6,654		
Switchyard		0	0	0	0	0	0	0	0	0	0	0		
Pre-Subtotal		35,103	34,604	34,141	33,566	33,144	32,652	32,191	31,819	31,448	30,991	30,575		
Contingency (15%)		5,176	5,101	5,031	4,945	4,882	4,804	4,739	4,683	4,627	4,559	4,497		
Eng. and Adm. (10%)		3,968	3,911	3,857	3,791	3,743	3,686	3,633	3,590	3,548	3,495	3,447		
Sub Total		44,247	43,616	43,030	42,303	41,768	41,146	40,563	40,093	39,621	39,045	38,518		
I.D.C. (9.5%/Year)		11,052	10,894	10,748	10,566	10,433	10,278	10,132	10,014	9,897	9,753	9,621		
Total		55,299	54,510	53,778	52,870	52,201	51,424	50,695	50,107	49,518	48,797	48,140		
Hydraulic Equipment		3,130	3,023	2,884	2,774	2,668	2,594	2,488	2,418	2,344	2,237	2,163		
Spillway		870	870	870	870	870	870	870	870	870	870	870		
Outlet Works		0	0	0	0	0	0	0	0	0	0	0		
Intake Gate		136	177	170	159	152	145	137	134	127	119	112		
Penstock		1,587	1,508	1,400	1,325	1,246	1,193	1,114	1,062	1,009	929	876		
Draft Gate		135	128	121	112	105	100	93	88	84	77	72		
Tailrace Gate		68	55	61	56	53	50	47	45	42	39	36		
Pre-Subtotal		2,816	2,743	2,622</										

Table 9-10(1-1) Comparison Study on Reservoir Capacity

Bayern Project Tailrace Type Undergrd. P/S Level	w/ W.L. = 750m-700m		w/ W.L. = 570m		By Mixed Alternatives Thermal Power Plant	
	Bayern 750MP	Bayern 700MP	Bayern 750MP	Bayern 570MP	Total	Total
High Water Level	50.00	570.00	740.00	570.00	735.00	570.00
Normal Water Level	728.67	555.67	722.00	555.67	718.67	555.67
Low Water Level	666.00	537.00	666.00	537.00	666.00	537.00
Available Drawdown	64.00	43.00	54.00	43.00	49.00	43.00
Gross Storage Capacity	189.00	36.40	150.00	36.40	116.00	36.40
Effective Storage Capacity	149.00	30.10	130.00	30.10	96.00	30.10
Dam Type	0 Rockfill	Con-Cra.	0 Rockfill	Con-Cra.	0 Rockfill	Con-Cra.
Dam Height	135	114	145	114	140	114
Dam Volume	6,500	680	6,144	680	5,400	680
Tower Volume	570.00	392.00	570.00	392.00	570.00	392.00
Effective Head	152.37	158.17	145.70	158.17	142.27	158.07
Maximum Discharge	49.00	82.00	43.00	82.00	40.00	82.00
Installed Capacity	64.00	95.00	54.00	95.00	49.00	95.00
Firm Peak Power	52.40	72.50	48.80	70.80	44.80	67.80
Energy Production	215.00	287.00	207.60	285.60	198.20	279.50
Average Energy	135.00	178.00	133.00	172.20	123.30	168.20
Firm Energy	98.00	129.00	93.70	123.30	85.90	123.30
Secondary Energy	0.00	158.00	113.90	158.90	102.30	145.30
Unit Benefit Value	180.45	180.45	180.45	180.45	180.45	180.45
Firm Peak Value	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270
Firm Energy	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Secondary Energy	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Benefit	9.02	12.48	8.40	12.18	7.71	11.63
Firm Peak Power	3.06	4.72	2.81	4.34	2.62	3.93
Firm Energy	1.72	2.35	1.60	2.44	1.48	2.26
Secondary Energy	14.32	19.53	13.99	19.20	12.55	17.27
Total	174.52	244.73	165.67	233.56	152.76	212.83
Investment Cost	70.81	32.01	65.62	30.35	59.27	28.72
Civil Facilities	108.33	178.22	100.56	173.56	93.49	184.11
Hydro. and Ele-Mech Eq	17.65	9.72	15.72	10.16	14.00	9.61
Other Cost	2.71	3.65	2.61	3.46	2.46	3.37
Civil Facilities	20.34	13.37	18.33	13.62	16.40	13.43
Hydro. and Ele-Mech Eq	-6.02	6.18	-5.58	6.73	-5.09	5.99
Other Cost	0.70	1.46	0.74	1.41	0.77	1.39
Annual Surplus Benefit(B-C)	0.151	0.075	0.148	0.079	0.108	0.147
Benefit Cost Ratio(B/C)	0.095	0.047	0.085	0.048	0.082	0.108
Unit Annual Cost (Firm)	0.095	0.047	0.085	0.048	0.082	0.108
Unit Annual Cost (Average)	0.095	0.047	0.085	0.048	0.082	0.108
Bayern 750MP	750MP	750MP	750MP	750MP	750MP	750MP
Bayern 700MP	700MP	700MP	700MP	700MP	700MP	700MP
Bayern 750MP	750MP	750MP	750MP	750MP	750MP	750MP
Bayern 570MP	570MP	570MP	570MP	570MP	570MP	570MP
Total	Total	Total	Total	Total	Total	Total

Table 9-10(1-2) Comparison Study on Reservoir Capacity

System project Tailrace Type Underpne. P18 Layout H.W.L. 750m-700m. With Reservoir H.W.L. 870m. By Mixed Alternative Thermal Power Plant

	Layout	Reservoir 770Mhp	Reservoir 700Mhp	Reservoir 570Mhp	Total	Reservoir 715Mhp	Reservoir 570Mhp	Total	Reservoir 705Mhp	Reservoir 570Mhp	Total	Reservoir 700Mhp	Reservoir 570Mhp	Total
High Water Level	m	720.00	570.00	570.00		710.00	570.00		705.00	570.00		700.00	570.00	
Normal Water Level	m	708.67	555.67	555.67		702.00	555.67		698.67	555.67		694.33	555.67	
Low Water Level	m	686.00	527.00	527.00		686.00	527.00		686.00	527.00		686.00	527.00	
Available Drawdown	m	34.00	43.00	43.00		24.00	43.00		19.00	43.00		14.00	43.00	
Gross Storage Capacity	m <sup>3</sup> *10 <sup>6</sup>	76.00	36.40	36.40		55.00	36.40		46.00	36.40		169.00	36.40	
Effective Storage Capacity	m <sup>3</sup> *10 <sup>6</sup>	56.00	30.10	30.10		35.00	30.10		26.00	30.10		149.00	30.10	
Dam Type		Roadfill	Roadfill	Roadfill		Roadfill	Roadfill		Roadfill	Roadfill		Roadfill	Roadfill	
Dam Height	m	125	114	114		115	114		110	114		105	114	
Dam Volume	m <sup>3</sup>	3,900	680	680		3,100	680		2,700	680		2,400	680	
Tailrace Level	m	570.00	392.00	392.00		570.00	392.00		570.00	392.00		570.00	392.00	
Effective Head	m	132.67	157.67	157.67		126.73	157.67		121.87	157.67		118.43	157.67	
Maximum Discharge	m <sup>3</sup> /s	33.00	46.00	46.00		29.00	46.00		26.00	46.00		24.00	46.00	
Installed Capacity	MW	37.00	63.00	63.00		31.00	63.00		27.00	63.00		24.00	63.00	
Firm Peak Power	MW	30.20	60.10	60.10		26.20	60.10		23.80	60.10		21.10	60.10	
Energy Production	GWh	159.40	263.10	263.10		139.70	263.10		127.30	263.10		117.30	263.10	
Average Energy	GWh	78.50	132.70	132.70		64.40	132.70		56.20	132.70		51.60	132.70	
Secondary Energy	GWh	79.90	130.40	130.40		75.30	130.40		71.10	130.40		65.50	130.40	
Unit Benefit Value	US\$/MWh	180.450	180.450	180.450		180.450	180.450		180.450	180.450		180.450	180.450	
Firm Energy	US\$/MWh	0.0270	0.027	0.027		0.027	0.027		0.027	0.027		0.027	0.027	
Secondary Energy	US\$/MWh	0.0219	0.022	0.022		0.0219	0.022		0.022	0.022		0.022	0.022	
Benefit														
Firm Peak Power	US\$/10 <sup>6</sup>	3.20	10.34	10.34		4.75	9.77		4.51	9.16		3.63	9.16	
Firm Energy	US\$/10 <sup>6</sup>	2.08	3.52	3.52		1.87	3.22		1.71	3.22		1.37	3.22	
Secondary Energy	US\$/10 <sup>6</sup>	1.72	2.81	2.81		1.74	2.79		1.62	2.79		1.41	2.79	
Total	US\$/10 <sup>6</sup>	9.00	16.67	16.67		8.33	15.94		7.84	15.17		6.42	15.17	
Investment Cost														
US\$/10 <sup>6</sup>		101.33	96.75	96.75		94.43	96.96		87.92	96.96		80.56	96.96	
Self-Reliance	US\$/10 <sup>6</sup>	77.29	26.57	26.57		42.86	26.57		15.40	26.57		13.36	26.57	
Mech. and Ele. Mech. Eq	US\$/10 <sup>6</sup>	116.63	123.32	123.32		110.72	121.86		103.32	123.32		94.85	123.32	
Annual Cost														
US\$/10 <sup>6</sup>		10.73	9.77	9.77		9.54	9.69		8.88	9.69		7.56	9.69	
Mech. and Ele. Mech. Eq	US\$/10 <sup>6</sup>	13.27	3.03	3.03		1.86	2.95		1.76	2.95		1.52	2.95	
Total	US\$/10 <sup>6</sup>	32.74	12.80	12.80		31.39	12.64		29.64	12.64		22.13	12.64	
Annual Surplus Benefit(B/C)	US\$/10 <sup>6</sup>	3.24	3.51	3.51		3.07	3.30		2.90	3.30		2.60	3.30	
Benefit Cost Ratio(B/C)		0.74	0.30	0.30		0.67	0.73		0.74	0.73		0.71	0.73	
Unit Annual Cost (Firm)	US\$/MWh	0.155	0.086	0.086		0.118	0.105		0.122	0.105		0.130	0.105	
Unit Annual Cost (Average)	US\$/MWh	0.077	0.078	0.078		0.078	0.078		0.078	0.078		0.078	0.078	

Table 9-10(2-1) Comparison Study on Reservoir Capacity

by Mixed Alternative Thermal Power Plant

Description	75% A		70% A		75% A		70% A		75% A		70% A		75% A		Total	Bagik 75% A	Bayam 75% A	Total	Bagik 70% A	Bayam 70% A	Total	
	Bayam	75% A	Bayam	70% A	Bayam	75% A	Bayam	70% A	Bayam	75% A	Bayam	70% A	Bayam	75% A								
High Water Level	750.00	550.00	740.00	550.00	735.00	550.00	730.00	550.00	725.00	550.00	720.00	550.00	715.00	550.00	710.00	550.00	705.00	550.00	700.00	550.00	695.00	550.00
Normal Water Level	728.57	538.50	720.00	538.50	716.97	538.50	713.94	538.50	710.91	538.50	707.88	538.50	704.85	538.50	701.82	538.50	698.79	538.50	695.76	538.50	692.73	538.50
Low Water Level	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00	685.00	527.00
Available Drawdown	64.00	23.00	64.00	23.00	64.00	23.00	64.00	23.00	64.00	23.00	64.00	23.00	64.00	23.00	64.00	23.00	64.00	23.00	64.00	23.00	64.00	23.00
Close Storage Capacity	188.00	17.70	188.00	17.70	188.00	17.70	188.00	17.70	188.00	17.70	188.00	17.70	188.00	17.70	188.00	17.70	188.00	17.70	188.00	17.70	188.00	17.70
Effective Storage Capacity	149.00	11.40	149.00	11.40	149.00	11.40	149.00	11.40	149.00	11.40	149.00	11.40	149.00	11.40	149.00	11.40	149.00	11.40	149.00	11.40	149.00	11.40
Dam Type	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Dam Height	155	140	145	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140
Dam Volume	8,500	420	6,144	420	5,400	420	5,000	420	4,600	420	4,200	420	3,800	420	3,400	420	3,000	420	2,600	420	2,200	420
Turbine Level	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00
Effective Head	170.87	141.00	163.33	141.00	163.33	141.00	163.33	141.00	163.33	141.00	163.33	141.00	163.33	141.00	163.33	141.00	163.33	141.00	163.33	141.00	163.33	141.00
Maximum Discharge	48.00	59.00	48.00	59.00	48.00	59.00	48.00	59.00	48.00	59.00	48.00	59.00	48.00	59.00	48.00	59.00	48.00	59.00	48.00	59.00	48.00	59.00
Installed Capacity	72.00	72.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00	144.00
Firm Peak Power	60.40	65.40	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20	126.20
Energy Production	228.88	255.00	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88	481.88
Average Energy	143.17	152.00	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17	295.17
Firm Energy	63.52	103.00	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52	166.52
Secondary Energy	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Unit Demand Value	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45
Firm Peak Power	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270
Firm Energy	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Secondary Energy	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Benefit	10.38	11.32	21.72	21.72	9.62	10.84	20.46	20.46	8.85	10.29	19.14	19.14	17.98	17.98	7.33	9.46	16.83	16.83	6.68	9.12	15.78	15.78
Firm Peak Power	3.80	4.03	7.83	7.83	3.69	3.99	7.56	7.56	3.51	3.81	7.36	7.36	6.57	6.57	2.82	3.19	6.43	6.43	2.65	3.07	5.72	5.72
Firm Energy	1.80	2.22	4.02	4.02	2.02	2.31	4.33	4.33	2.09	2.40	4.49	4.49	4.05	4.05	2.09	2.38	4.57	4.57	2.03	2.57	4.81	4.81
Secondary Energy	15.99	17.56	33.57	33.57	15.30	17.02	32.35	32.35	14.29	16.36	30.67	30.67	29.11	29.11	12.24	15.24	27.48	27.48	11.34	14.76	28.10	28.10
Investment Cost	181.69	76.95	258.24	258.24	161.23	75.88	237.10	237.10	144.30	132.90	277.20	277.20	146.19	146.19	120.42	73.42	219.84	219.84	115.25	72.76	188.01	188.01
Over Facilities	25.32	20.37	54.89	54.89	23.96	28.12	52.09	52.09	21.37	49.88	71.25	71.25	48.81	48.81	20.86	25.11	73.91	73.91	45.69	19.69	65.38	65.38
Total, and Etc.-Mech.Eq.	207.21	105.92	313.13	313.13	185.19	104.00	289.19	289.19	162.77	182.77	348.45	348.45	195.00	195.00	141.28	98.53	293.75	293.75	160.94	92.45	253.32	253.32
Other Cost	16.35	7.73	24.08	24.08	16.26	7.66	23.95	23.95	14.96	7.57	22.53	22.53	14.87	14.87	13.42	7.52	22.39	22.39	11.64	7.35	18.99	18.99
Cost Factors	2.91	3.35	6.26	6.26	2.73	3.21	5.94	5.94	3.13	5.69	11.06	11.06	3.49	3.49	2.34	3.66	5.21	5.21	2.24	2.78	5.03	5.03
Mech. and Etc.-Mech.Eq.	21.36	11.06	32.34	32.34	19.02	10.87	29.89	29.89	17.14	10.70	27.84	27.84	16.36	16.36	14.81	10.26	26.09	26.09	13.86	10.13	24.02	24.02
Total	5.27	6.50	11.73	11.73	5.68	6.15	11.83	11.83	3.23	4.83	10.63	10.63	2.67	2.67	4.58	4.58	2.09	2.09	1.46	1.46	2.09	2.09
Annual Surplus Benefit(B-C)	0.75	1.59	1.04	1.04	0.61	1.57	1.06	1.06	0.83	1.53	1.10	1.10	0.83	0.83	1.10	1.10	0.83	0.83	1.10	1.10	0.83	0.83
Benefit Cost Ratio(B/C)	0.148	0.75	0.110	0.110	0.137	0.075	0.105	0.105	0.136	0.077	0.136	0.136	0.107	0.107	0.139	0.085	0.111	0.111	0.139	0.085	0.112	0.112
Unit Annual Cost (Firm)	0.094	0.043	0.067	0.067	0.092	0.043	0.062	0.062	0.074	0.054	0.074	0.074	0.054	0.054	0.073	0.043	0.052	0.052	0.071	0.043	0.056	0.056
Unit Annual Cost (Average)	0.094	0.043	0.067	0.067	0.092	0.043	0.062	0.062	0.074	0.054	0.074	0.074	0.054	0.054	0.073	0.043	0.052	0.052	0.071	0.043	0.056	0.056

Bayram Project Tailrace Type Undergr. p.13 Layout 14 W. La750m/700m with Dgall. 14 W. L=550.00m. By Mixed Alternative Thermal Power Plant

Description Dam Site	720A		715A		710A		705A		700A		695A		Total
	Bayram	720A	Bayram	715A	Bayram	710A	Bayram	705A	Bayram	700A	Bayram	695A	
High Water Level	720.00	550.00	715.00	550.00	710.00	550.00	705.00	550.00	700.00	550.00	695.00	550.00	0.00
Normal Water Level	708.67	538.50	703.33	538.50	702.00	538.50	698.67	538.50	695.33	538.50	692.00	538.50	1,250.00
Low Water Level	696.00	527.00	696.00	527.00	696.00	527.00	696.00	527.00	696.00	527.00	696.00	527.00	
Available Drawdown	34.00	23.00	29.00	23.00	24.00	23.00	19.00	23.00	14.00	23.00	14.00	23.00	
Gross Storage Capacity	m <sup>3</sup> 10 <sup>6</sup>	79.00	17.70	65.00	17.70	55.00	17.70	46.00	17.70	36.00	17.70	26.00	
Effective Storage Capacity	m <sup>3</sup> 10 <sup>6</sup>	56.00	11.40	45.00	11.40	35.00	11.40	26.00	11.40	18.00	11.40	11.40	
Dam Type	0	Rockfill	0	Rockfill	0	Rockfill	0	Rockfill	0	Rockfill	0	Rockfill	
Dam Height	m	125	94	115	94	115	94	110	94	105	94	94	
Dam Volume	m <sup>3</sup>	3,900	420	3,500	420	3,100	420	2,700	420	2,400	420	420	
Tankwater Level	m	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	550.00	392.00	392.00	
Effective Head	m	150.27	140.80	146.93	140.70	143.50	140.70	140.07	140.00	136.63	140.60	140.60	
Maximum Discharge	m <sup>3</sup> /s	33.00	42.00	31.00	40.00	29.00	36.00	26.00	33.00	24.00	33.00	33.00	
Installed Capacity	MW	42.00	51.00	39.00	48.00	35.00	46.00	33.00	42.00	30.00	40.00	40.00	
Firm Peak Power	MW	33.90	50.00	33.30	47.00	30.60	44.70	27.90	37.80	25.80	36.40	36.40	
Energy Production	GWh	152.70	227.50	110.20	171.40	161.00	214.00	145.40	203.50	135.40	196.90	196.90	
Average Energy	GWh	89.10	107.00	196.10	81.20	75.00	98.10	64.90	89.90	54.40	85.10	143.70	
Secondary Energy	GWh	93.60	120.50	214.10	90.20	66.00	115.90	80.50	114.00	79.90	111.80	188.60	
Unit Benefit Value	US\$/MWh	160.450	160.450	160.450	160.450	160.450	160.450	160.450	160.450	160.450	160.450	160.450	
Firm Energy	US\$/MWh	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	
Secondary Energy	US\$/MWh	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	
Benefit	US\$/MWh	5.53	8.60	14.44	5.54	5.27	7.69	12.96	4.79	6.61	4.44	6.61	
Firm Peak Power	US\$/MWh	2.26	2.84	5.20	2.16	1.99	2.60	4.59	1.72	2.36	1.56	2.26	
Firm Energy	US\$/MWh	2.02	2.36	4.61	0.94	0.84	1.73	2.45	0.71	1.63	0.85	1.63	
Secondary Energy	US\$/MWh	10.21	14.04	24.25	13.36	23.00	9.11	12.79	21.90	7.65	11.27	16.92	
Investment Cost	US\$/MWh	108.00	108.00	108.00	101.01	71.24	172.25	64.26	64.26	64.26	64.26	64.26	
Cost Facilities	US\$/MWh	18.40	23.40	41.61	17.54	16.35	22.16	38.51	15.35	14.86	20.84	35.70	
Hydro and Ele. Mech. Eo	US\$/MWh	136.40	90.40	22.16	93.86	212.40	92.60	203.40	102.82	91.17	134.00	94.22	
Annual Cost	US\$/MWh	10.91	7.97	18.18	10.20	7.20	17.40	16.66	8.94	7.07	15.90	15.30	
Cost Facilities	US\$/MWh	2.10	2.67	4.66	2.16	1.99	2.60	4.29	1.72	1.68	2.36	4.07	
Hydro and Ele. Mech. Eo	US\$/MWh	13.01	9.84	22.86	9.78	21.98	13.36	20.62	4.17	4.17	9.38	19.37	
Total	US\$/MWh	-2.80	4.10	1.30	-2.58	3.58	3.46	2.62	2.07	2.36	1.36	2.41	
Annual Surplus Benefit(B-C)	US\$/MWh	0.79	1.41	1.06	0.79	1.05	1.32	1.64	0.74	1.25	1.00	0.84	
Benefit Ratio(B/C)	US\$/MWh	0.146	0.093	0.117	0.150	0.095	0.120	0.122	0.163	0.108	0.139	0.170	
Unit Annual Cost (Firm)	US\$/MWh	-0.071	0.044	0.026	-0.071	0.044	0.026	0.022	0.072	0.043	0.074	0.093	
Unit Annual Cost (Average)	US\$/MWh	-0.071	0.044	0.026	-0.071	0.044	0.026	0.022	0.072	0.043	0.074	0.093	



Table 9-10(3-1) Comparison Study on Reservoir Capacity

Description/Item Site	By Mixed Alternative Thermal Power Plant									
	740C	750C	760C	770C	780C	790C	800C	810C	820C	830C
High Water Level	740.00	740.00	740.00	740.00	740.00	740.00	740.00	740.00	740.00	740.00
Normal Water Level	738.87	738.87	738.87	738.87	738.87	738.87	738.87	738.87	738.87	738.87
Low Water Level	666.00	666.00	666.00	666.00	666.00	666.00	666.00	666.00	666.00	666.00
Available Drawdown	64.00	64.00	64.00	64.00	64.00	64.00	64.00	64.00	64.00	64.00
Gross Storage Capacity	169.00	169.00	169.00	169.00	169.00	169.00	169.00	169.00	169.00	169.00
Effective Storage Capacity	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00	140.00
Item Type	Reservoir	Reservoir	Reservoir	Reservoir	Reservoir	Reservoir	Reservoir	Reservoir	Reservoir	Reservoir
Item Height	155	155	155	155	155	155	155	155	155	155
Item Volume	8,500	8,500	8,500	8,500	8,500	8,500	8,500	8,500	8,500	8,500
Turbine Level	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00
Effective Head	193.87	193.87	193.87	193.87	193.87	193.87	193.87	193.87	193.87	193.87
Maximum Discharge	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00	49.00
Insulated Capacity	80.00	80.00	80.00	80.00	80.00	80.00	80.00	80.00	80.00	80.00
Firm Peak Power	67.40	67.40	67.40	67.40	67.40	67.40	67.40	67.40	67.40	67.40
Energy Production	265.80	265.80	265.80	265.80	265.80	265.80	265.80	265.80	265.80	265.80
Average Energy	159.70	159.70	159.70	159.70	159.70	159.70	159.70	159.70	159.70	159.70
Firm Energy	98.30	98.30	98.30	98.30	98.30	98.30	98.30	98.30	98.30	98.30
Secondary Energy	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Unit Benefit Value	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45
Firm Peak Power	0.0770	0.0770	0.0770	0.0770	0.0770	0.0770	0.0770	0.0770	0.0770	0.0770
Firm Energy	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270
Secondary Energy	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Benefit	11.60	11.60	11.60	11.60	11.60	11.60	11.60	11.60	11.60	11.60
Firm Peak Power	3.69	3.69	3.69	3.69	3.69	3.69	3.69	3.69	3.69	3.69
Firm Energy	2.12	2.12	2.12	2.12	2.12	2.12	2.12	2.12	2.12	2.12
Secondary Energy	18.19	18.19	18.19	18.19	18.19	18.19	18.19	18.19	18.19	18.19
Total	34.60	34.60	34.60	34.60	34.60	34.60	34.60	34.60	34.60	34.60
Investment Cost	186.07	186.07	186.07	186.07	186.07	186.07	186.07	186.07	186.07	186.07
Cost Facilities	27.09	27.09	27.09	27.09	27.09	27.09	27.09	27.09	27.09	27.09
Hydro and Electric Eq	213.16	213.16	213.16	213.16	213.16	213.16	213.16	213.16	213.16	213.16
Total	55.30	55.30	55.30	55.30	55.30	55.30	55.30	55.30	55.30	55.30
Annual Cost	18.79	18.79	18.79	18.79	18.79	18.79	18.79	18.79	18.79	18.79
Cost Facilities	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09
Hydro and Electric Eq	15.70	15.70	15.70	15.70	15.70	15.70	15.70	15.70	15.70	15.70
Total	21.88	21.88	21.88	21.88	21.88	21.88	21.88	21.88	21.88	21.88
Annual Surplus Benefit(B-C)	3.69	3.69	3.69	3.69	3.69	3.69	3.69	3.69	3.69	3.69
Benefit Cost Ratio(BC)	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63
User Annual Cost (Firm)	0.130	0.130	0.130	0.130	0.130	0.130	0.130	0.130	0.130	0.130
User Annual Cost (Average)	0.085	0.085	0.085	0.085	0.085	0.085	0.085	0.085	0.085	0.085
Total	0.038	0.038	0.038	0.038	0.038	0.038	0.038	0.038	0.038	0.038

Table 9-10(3-2) Comparison Study on Reservoir Capacity

Description/Item Site	By Mixed Alternative Thermal Power Plant									
	Layout	Bayern 700C	Bayern 710C	Bayern 715C	Bayern 710C	Bayern 705C	Bayern 700C	Bayern 705C	Bayern 700C	Total
High Water Level	720.00	715.00	710.00	710.00	710.00	705.00	705.00	700.00	700.00	530.00
Normal Water Level	708.67	705.33	702.00	702.00	702.00	698.67	698.67	695.33	695.33	528.50
Low Water Level	696.00	696.00	696.00	696.00	696.00	696.00	696.00	696.00	696.00	527.00
Available Drawdown	34.00	29.00	3.00	3.00	3.00	24.00	24.00	14.00	14.00	3.00
Gross Storage Capacity	76.00	56.00	7.30	7.30	7.30	46.00	46.00	38.00	38.00	7.30
Effective Storage Capacity	56.00	45.00	1.00	1.00	1.00	26.00	26.00	19.00	19.00	1.00
Item Type	0 Roadfill	Con-Crs	Roadfill	Con-Crs	Roadfill	Con-Crs	Roadfill	Con-Crs	Roadfill	Con-Crs
Item	123	74	115	74	115	74	115	74	115	74
Drain Volume	3,400	3,500	3,100	3,100	3,100	2,700	2,700	2,400	2,400	195
Turbine Level	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	530.00	392.00
Electric Yield	169.27	130.70	162.50	130.70	162.50	159.87	130.60	155.53	130.50	392.00
FW Flow	33.00	31.00	29.00	36.00	29.00	26.00	33.00	24.00	31.00	31.00
Hydro Charge	43.00	44.00	43.00	43.00	43.00	43.00	43.00	43.00	43.00	43.00
FW Peak Power	39.00	36.90	35.00	39.00	35.00	35.00	37.00	32.00	35.00	35.00
Energy Production	204.80	200.60	193.60	193.60	193.60	167.30	176.90	154.40	170.40	324.80
Firm Energy	100.10	96.10	92.00	89.50	83.90	73.30	78.60	67.20	74.20	141.40
GW	104.40	104.50	103.30	103.10	103.40	98.30	96.30	87.20	96.20	183.40
Unit Benefit Value	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450
Firm Peak Power	0.037	0.037	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027
Firm Energy	0.037	0.037	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027
Secondary Energy	0.037	0.037	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027
Benefit	6.71	7.57	14.26	6.35	6.02	6.71	12.73	5.47	6.00	11.67
Firm Peak Power	2.66	2.55	2.44	2.36	2.23	2.00	2.00	1.76	1.97	3.75
Firm Energy	2.36	2.25	2.18	2.12	2.00	1.76	1.76	1.56	1.76	3.60
Secondary Energy	11.62	12.37	24.00	11.65	11.14	11.14	21.48	9.45	10.40	19.85
Total	109.71	50.70	160.40	102.25	50.11	152.36	144.41	87.72	45.80	135.52
Investment Cost	19.51	21.97	41.49	18.52	21.67	40.19	38.26	15.96	20.05	81.88
Civil Facilities	126.22	72.67	201.89	120.77	71.77	192.55	182.68	68.85	172.53	48.14
Hydrow. and Elec. Mech. Eq.	11.08	5.12	16.20	10.33	5.08	15.39	14.59	8.86	4.93	13.79
Annual Cost	2.22	2.51	4.73	2.11	2.47	4.36	4.35	2.29	4.11	4.65
Civil Facilities	13.30	7.63	20.63	12.44	7.53	19.07	18.95	10.65	7.21	17.69
Hydrow. and Elec. Mech. Eq.	-1.65	4.75	3.07	-1.47	4.12	2.65	-1.23	3.16	1.98	1.54
Total	0.87	1.62	1.15	0.88	1.35	0.69	1.13	0.89	1.11	0.87
Annual Surplus Benefit(B-C)	0.133	0.079	0.107	0.084	0.110	0.138	0.112	0.142	0.092	0.121
Benefit Cost Ratio(B/C)	0.095	0.036	0.052	0.064	0.052	0.064	0.052	0.064	0.052	0.064
Unit Annual Cost (Firm)	0.095	0.036	0.052	0.064	0.052	0.064	0.052	0.064	0.052	0.064
Unit Annual Cost (Average)	0.095	0.036	0.052	0.064	0.052	0.064	0.052	0.064	0.052	0.064

**Table 9-11(1) Cost Estimate of Alternative Plan for Bayram Reservoir Water Level**

Bayram Project Tailrace Undergro. P/S Layout H.W.L. = 750m L.W.L. = 688-745m With Baglik H.W.L. = 530.00m											
Description	Dam Site Layout Type	Unit: 10 <sup>3</sup> US\$									
		Bayram 750-688	Bayram 750-705	Bayram 750-710	Bayram 750-715	Bayram 750-720	Bayram 750-725	Bayram 750-730	Bayram 750-735	Bayram 750-740	Bayram 750-745
High Water Level (m)		750	750	750	750	750	750	750	750	750	750
Reservoir Area (km <sup>2</sup> )		3.88	3.68	3.68	3.68	3.68	3.68	3.68	3.68	3.68	3.68
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )		8,500	8,500	8,500	8,500	8,500	8,500	8,500	8,500	8,500	8,500
Dam Height (m)		155	155	155	155	155	155	155	155	155	155
Maximum Head (m)		220	220	220	220	220	220	220	220	220	220
Maximum Discharge (m <sup>3</sup> /s)		49	45	43	42	40	38	35	33	29	24
Relocation Road		13,724	12,689	12,689	12,689	12,689	12,689	12,689	12,689	12,689	12,689
Camp Facilities		800	800	800	800	800	800	800	800	800	800
Land Acquisition		2,989	2,589	2,589	2,989	2,989	2,989	2,989	2,989	2,989	2,989
Civil Work		103,423	102,351	101,541	101,417	100,633	99,973	99,219	98,591	97,109	95,824
Diversion		2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421
Care of River		1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082
Dam		65,412	65,412	65,412	65,412	65,412	65,412	65,412	65,412	65,412	65,412
Spillway		8,143	8,143	8,143	8,143	8,143	8,143	8,143	8,143	8,143	8,143
Outlet Works		1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018
Intake		1,280	1,062	964	865	824	736	631	544	421	272
Headrace Tunnel		0	0	0	0	0	0	0	0	0	0
Surge Tank		0	0	0	0	0	0	0	0	0	0
Penstock		651	600	574	561	535	509	471	445	393	378
Access Tunnels		3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980
Power House		3,370	3,177	3,081	3,049	2,953	2,856	2,695	2,632	2,375	2,054
Tailrace Tunnel		15,906	15,306	14,705	14,705	14,105	13,655	13,205	12,755	11,704	10,954
Switchyard		161	161	161	161	161	161	161	161	161	161
Pre-Subtotal		120,936	118,829	118,019	117,895	117,112	116,452	115,697	115,069	113,587	112,302
Contingency (15%)		17,692	17,376	17,255	17,236	17,118	17,019	16,906	16,812	16,550	16,397
Eng. and Adm. (10%)		13,564	13,322	13,228	13,214	13,124	13,045	12,961	12,889	12,719	12,571
Sub Total		152,192	149,527	148,502	148,345	147,354	146,519	145,565	144,779	142,896	141,270
I.D.C. (9.5%/Year)		33,450	32,864	32,639	32,604	32,387	32,203	31,993	31,819	31,407	31,043
Total		185,641	182,391	181,141	180,950	179,741	178,722	177,558	176,598	174,302	173,313
Hydraulic Equipment		5,889	5,745	5,243	5,115	4,934	4,732	4,449	4,248	3,882	3,429
Spillway		856	856	856	856	856	856	856	856	856	856
Outlet Works		528	528	528	528	528	528	528	528	528	528
Intake Gate		858	738	677	621	578	517	443	382	295	191
Penstock		2,862	2,636	2,523	2,466	2,352	2,239	2,068	1,954	1,728	1,440
Draft Gate		139	128	122	119	113	108	99	94	82	68
Tailrace Gate		70	64	61	60	57	54	50	47	41	34
Pre-Subtotal		5,353	4,950	4,767	4,650	4,485	4,301	4,044	3,860	3,529	3,117
Contingency (10%)		535	495	477	455	449	430	404	386	353	312
Electro-Mechanical Equipment		17,482	16,944	16,587	16,638	16,246	15,581	14,723	14,268	13,681	11,513
Equipment		16,649	16,137	15,798	15,846	15,472	14,849	14,022	13,589	12,065	10,965
Contingency (5%)		832	807	790	792	774	742	701	679	604	548
Eng. and Adm. (10%)		2,337	2,239	2,183	2,175	2,118	2,032	1,917	1,851	1,657	1,494
Sub Total		25,707	24,627	24,014	23,929	23,297	22,355	21,089	20,366	18,230	16,458
I.D.C. (9.5%/Year)		1,582	1,324	1,291	1,287	1,253	1,202	1,134	1,095	980	884
Total		27,090	25,952	25,305	25,215	24,550	23,557	22,222	21,461	19,210	17,319
Grand Total		212,731	208,342	206,446	206,165	204,290	202,280	199,780	198,050	193,512	189,639

Baglik Project Tailrace Undergro. P/S Layout H.W.L. = 530.00m With Bayram H.W.L. = 750m L.W.L. = 688-745m											
Description	Dam Site Layout Type	Unit: 10 <sup>3</sup> US\$									
		Baglik 750-686	Baglik 750-705	Baglik 750-710	Baglik 750-715	Baglik 750-720	Baglik 750-725	Baglik 750-730	Baglik 750-735	Baglik 750-740	Baglik 750-745
High Water Level (m)		530	530	530	530	530	530	530	530	530	530
Reservoir Area (km <sup>2</sup> )		0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )		195	195	195	195	195	195	195	195	195	195
Dam Height (m)		74	74	74	74	74	74	74	74	74	74
Maximum Head (m)		138	138	138	138	138	138	138	138	138	138
Maximum Discharge (m <sup>3</sup> /s)		58	54	52	50	47	44	42	39	36	31
Relocation Road		8,759	8,759	8,759	8,759	8,759	8,759	8,759	8,759	8,759	8,759
Camp Facilities		800	800	800	800	800	800	800	800	800	800
Land Acquisition		558	558	558	558	558	558	558	558	558	558
Civil Work		26,946	26,326	25,892	25,883	25,364	24,903	24,449	23,912	23,571	22,456
Diversion		0	0	0	0	0	0	0	0	0	0
Care of River		0	0	0	0	0	0	0	0	0	0
Dam		9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983
Spillway		780	780	780	780	780	780	780	780	780	780
Outlet Works		0	0	0	0	0	0	0	0	0	0
Intake		44	41	40	39	37	35	33	31	30	28
Headrace Tunnel		0	0	0	0	0	0	0	0	0	0
Surge Tank		0	0	0	0	0	0	0	0	0	0
Penstock		425	398	364	370	349	328	313	292	271	235
Access Tunnels		2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478
Power House		3,754	3,489	3,413	3,299	3,148	3,034	2,920	2,730	2,655	2,389
Tailrace Tunnel		9,481	9,157	8,914	8,914	8,590	8,266	7,942	7,617	7,374	6,564
Switchyard		0	0	0	0	0	0	0	0	0	0
Pre-Subtotal		35,103	34,483	34,148	34,020	33,521	33,060	32,606	32,069	31,727	30,613
Contingency (15%)		5,178	5,083	5,033	5,013	4,938	4,869	4,801	4,721	4,663	4,502
Eng. and Adm. (10%)		3,968	3,897	3,858	3,844	3,786	3,733	3,681	3,619	3,580	3,452
Sub Total		44,247	43,462	43,040	42,877	42,245	41,662	41,088	40,409	39,977	38,566
I.D.C. (9.5%/Year)		11,052	10,856	10,751	10,710	10,552	10,406	10,263	10,093	9,985	9,633
Total		55,299	54,318	53,790	53,587	52,797	52,069	51,351	50,503	49,962	48,200
Hydraulic Equipment		3,130	2,886	2,917	2,848	2,737	2,631	2,558	2,451	2,344	2,163
Spillway		870	870	870	870	870	870	870	870	870	870
Outlet Works		0	0	0	0	0	0	0	0	0	0
Intake Gate		156	174	170	165	156	143	141	134	127	112
Penstock		1,587	1,432	1,430	1,377	1,299	1,220	1,187	1,088	1,009	876
Draft Gate		135	126	121	116	109	102	98	91	84	72
Tailrace Gate		66	63	61	59	55	52	49	46	42	38
Pre-Subtotal		2,845	2,715	2,652	2,569	2,489	2,392	2,325	2,228	2,131	1,967
Contingency (10%)		285	271	265	259	249	239	233	223	213	197
Electro-Mechanical Equipment		20,208	19,477	19,216	18,455	17,922	17,098	16,766	16,152	15,559	14,445
Equipment		19,248	18,550	18,301	17,588	17,069	16,284	15,967	15,383	14,818	13,757
Contingency (5%)		962	927	915	879	853	814	758	769	741	688
Eng. and Adm. (10%)		2,334	2,246	2,213	2,131	2,066	1,973	1,932	1,850	1,790	1,661
Sub Total		25,672	24,710	24,346	23,444	22,726	21,702	21,256	20,464	19,693	18,269
I.D.C. (9.5%/Year)		1,454	1,400	1,379	1,328	1,287	1,229	1,204	1,159	1,115	1,035
Total		27,126	26,109	25,725	24,772	24,013	22,931	22,450	21,623	20,808	19,304
Grand Total		82,425	80,425	79,515	78,359	76,810	75,000	73,811	72,125	70,771	67,504

**Table 9-11(2) Cost Estimate of Alternative Plan for Bayram Reservoir Water Level**

Bayram Project Tailrace Underpro. P/S Layout H.W.L. = 745m L.W.L. = 586-740m With Baglik H.W.L. = 530.00m											
Description	Dam Site Layout Type	Unit: 10³ US\$									
		Bayram 745-686	Bayram 745-700	Bayram 745-705	Bayram 745-710	Bayram 745-715	Bayram 745-720	Bayram 745-725	Bayram 745-730	Bayram 745-735	Bayram 745-740
High Water Level (m)	745	745	745	745	745	745	745	745	745	745	745
Reservoir Area (km²)	3.68	3.68	3.68	3.68	3.68	3.68	3.68	3.68	3.68	3.68	3.68
Dam Volume (10⁶m³)	7,200	7,200	7,200	7,200	7,200	7,200	7,200	7,200	7,200	7,200	7,200
Dam Height (m)	150	150	150	150	150	150	150	150	150	150	150
Maximum Head (m)	215	215	215	215	215	215	215	215	215	215	215
Maximum Discharge (m³/s)	48	43	42	40	38	36	34	32	28	24	24
Relocation Road	12,689	12,689	12,689	12,689	12,689	12,689	12,689	12,689	12,689	12,689	12,689
Camp Facilities	800	800	800	800	800	800	800	800	800	800	800
Land Acquisition	2,616	2,616	2,616	2,616	2,616	2,616	2,616	2,616	2,616	2,616	2,616
Civil Work	92,133	91,205	91,108	90,243	89,593	88,933	88,315	88,065	88,825	88,459	85,459
Diversion	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421
Care of River	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082
Dam	55,407	55,407	55,407	55,407	55,407	55,407	55,407	55,407	55,407	55,407	55,407
Spillway	7,789	7,789	7,789	7,789	7,789	7,789	7,789	7,789	7,789	7,789	7,789
Outlet Works	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018
Inlets	1,192	999	947	868	789	701	622	528	412	272	272
Headrace Tunnel	0	0	0	0	0	0	0	0	0	0	0
Surge Tank	0	0	0	0	0	0	0	0	0	0	0
Penstock	599	562	549	524	499	473	448	429	372	321	321
Access Tunnels	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980
Power House	3,177	3,061	3,049	2,869	2,792	2,696	2,632	2,503	2,279	2,054	2,054
Tailrace Tunnel	15,306	14,705	14,705	14,105	13,655	13,205	12,755	12,755	11,704	10,954	10,954
Switchyard	161	161	161	161	161	161	161	161	161	161	161
Pre-Subtotal	108,236	107,311	107,213	106,348	105,698	105,038	104,420	104,170	102,730	101,564	101,564
Contingency (15%)	15,843	15,704	15,690	15,560	15,462	15,363	15,271	15,233	15,017	14,842	14,842
Eng. and Adm. (10%)	12,147	12,040	12,029	11,929	11,854	11,779	11,707	11,679	11,513	11,379	11,379
Sub Total	136,228	135,055	134,932	133,838	133,015	132,180	131,398	131,061	129,260	127,785	127,785
I.D.C. (9.5%/Year)	28,579	28,333	28,307	28,077	27,905	27,730	27,566	27,499	27,117	26,806	26,806
Total	164,806	163,387	163,239	161,915	160,919	159,910	158,964	158,561	156,377	154,593	154,593
Hydraulic Equipment	5,557	5,211	5,105	4,912	4,720	4,521	4,328	4,121	3,769	3,395	3,395
Spillway	856	856	856	856	856	856	856	856	856	856	856
Outlet Works	528	528	528	528	528	528	528	528	528	528	528
Intake Gate	837	701	665	609	554	492	437	369	289	191	191
Penstock	2,635	2,469	2,413	2,302	2,191	2,080	1,969	1,857	1,634	1,410	1,410
Draft Gate	131	122	119	113	108	102	96	91	79	68	68
Tailrace Gate	65	61	60	57	54	51	48	45	40	34	34
Pre-Subtotal	5,062	4,737	4,641	4,466	4,291	4,110	3,934	3,747	3,426	3,087	3,087
Contingency (10%)	505	474	464	447	429	411	393	375	343	309	309
Electro-Mechanical Equipment	18,260	15,955	15,995	15,566	15,155	14,723	14,057	13,592	12,364	11,378	11,378
Equipment	15,436	15,195	15,233	14,825	14,434	14,022	13,386	12,945	11,775	11,027	11,027
Contingency (5%)	774	760	782	741	722	701	669	647	563	551	551
Eng. and Adm. (10%)	2,102	2,117	2,110	2,048	1,988	1,924	1,839	1,771	1,613	1,497	1,497
Sub Total	23,999	23,283	23,210	22,526	21,863	21,167	20,224	19,485	17,748	16,471	16,471
I.D.C. (9.5%/Year)	1,290	1,252	1,248	1,211	1,175	1,138	1,087	1,048	954	886	886
Total	25,289	24,534	24,457	23,737	23,038	22,306	21,311	20,533	18,700	17,357	17,357
Grand Total	190,095	187,922	187,696	185,652	183,957	182,218	180,275	179,113	175,077	171,949	171,949

Baglik Project Tailrace Underpro. P/S Layout H.W.L. = 530.00m. Bayram H.W.L. = 745m L.W.L. = 586-740m											
Description	Dam Site Layout Type	Unit: 10³ US\$									
		Baglik 745-686	Baglik 745-700	Baglik 745-705	Baglik 745-710	Baglik 745-715	Baglik 745-720	Baglik 745-725	Baglik 745-730	Baglik 745-735	Baglik 745-740
High Water Level (m)	530	530	530	530	530	530	530	530	530	530	530
Reservoir Area (km²)	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37
Dam Volume (10⁶m³)	195	195	195	195	195	195	195	195	195	195	195
Dam Height (m)	74	74	74	74	74	74	74	74	74	74	74
Maximum Head (m)	138	138	138	138	138	138	138	138	138	138	138
Maximum Discharge (m³/s)	55	52	49	46	45	43	41	38	35	30	30
Relocation Road	8,759	8,759	8,759	8,759	8,759	8,759	8,759	8,759	8,759	8,759	8,759
Camp Facilities	800	800	800	800	800	800	800	800	800	800	800
Land Acquisition	599	598	598	598	598	598	598	598	598	598	598
Civil Work	26,447	25,992	25,493	25,410	24,587	24,533	24,042	23,662	23,244	22,373	22,373
Diversion	0	0	0	0	0	0	0	0	0	0	0
Care of River	0	0	0	0	0	0	0	0	0	0	0
Dam	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983
Spillway	780	780	780	780	780	780	780	780	780	780	780
Outlet Works	0	0	0	0	0	0	0	0	0	0	0
Inlets	42	41	38	37	36	34	33	31	29	26	26
Headrace Tunnel	0	0	0	0	0	0	0	0	0	0	0
Surge Tank	0	0	0	0	0	0	0	0	0	0	0
Penstock	405	384	363	356	335	321	306	285	264	228	228
Access Tunnels	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478
Power House	3,603	3,413	3,261	3,185	3,110	2,996	2,844	2,730	2,579	2,313	2,313
Tailrace Tunnel	9,157	8,914	8,590	8,596	8,266	7,842	7,617	7,374	7,131	6,564	6,564
Switchyard	0	0	0	0	0	0	0	0	0	0	0
Pre-Subtotal	34,604	34,149	33,650	33,566	33,144	32,690	32,199	31,819	31,400	30,530	30,530
Contingency (15%)	5,101	5,033	4,958	4,845	4,882	4,814	4,745	4,683	4,620	4,490	4,490
Eng. and Adm. (10%)	3,911	3,858	3,801	3,791	3,743	3,691	3,634	3,590	3,542	3,442	3,442
Sub Total	43,616	43,040	42,409	42,303	41,768	41,194	40,573	40,093	39,563	38,461	38,461
I.D.C. (9.5%/Year)	10,894	10,751	10,593	10,568	10,433	10,290	10,134	10,014	9,882	9,607	9,607
Total	54,510	53,791	53,002	52,870	52,201	51,484	50,708	50,107	49,445	48,068	48,068
Hydraulic Equipment	3,023	2,919	2,811	2,774	2,668	2,584	2,525	2,418	2,307	2,150	2,150
Spillway	870	870	870	870	870	870	870	870	870	870	870
Outlet Works	0	0	0	0	0	0	0	0	0	0	0
Intake Gate	177	172	163	159	152	145	141	134	123	112	112
Penstock	1,508	1,430	1,351	1,325	1,245	1,193	1,141	1,062	982	849	849
Draft Gate	128	121	114	112	105	100	95	88	81	70	70
Tailrace Gate	65	61	57	56	53	50	48	45	41	35	35
Pre-Subtotal	2,748	2,654	2,555	2,522	2,425	2,359	2,295	2,198	2,098	1,937	1,937
Contingency (10%)	275	265	256	252	243	236	230	220	210	194	194
Electro-Mechanical Equipment	19,723	19,216	18,430	18,387	17,813	17,215	16,863	16,223	15,433	14,132	14,132
Equipment	18,784	18,301	17,593	17,512	16,965	16,395	16,060	15,450	14,699	13,459	13,459
Contingency (5%)	939	915	878	876	848	820	803	773	735	673	673
Eng. and Adm. (10%)	2,275	2,213	2,124	2,116	2,048	1,981	1,939	1,864	1,774	1,626	1,626
Sub Total	25,021	24,348	23,565	23,278	22,529	21,790	21,327	20,505	19,515	17,889	17,889
I.D.C. (9.5%/Year)	1,417	1,379	1,323	1,319	1,276	1,234	1,208	1,181	1,105	1,013	1,013
Total	26,438	25,727	24,888	24,596	23,805	23,025	22,535	21,666	20,620	18,902	18,902
Grand Total	80,949	79,519	77,651	77,468	76,006	74,508	73,243	71,774	70,068	66,971	66,971



**Table 9-11(4) Cost Estimate of Alternative Plan for Bayram Reservoir Water Level**

Bayram Project Tailrace Underground Powerhouse Layout H.W.L.=735m L.W.L.=685m-730m With Baglik H.W.L.=630.00m Unit:10^3US\$										
Description	Bayram		Bayram		Bayram		Bayram		Bayram	
	735-666	735-700	735-705	735-710	735-715	735-720	735-725	735-730	735-730	
High Water Level (m)	735	735	735	735	735	735	735	735	735	
Reservoir Area (km <sup>2</sup> )	3.11	3.11	3.11	3.11	3.11	3.11	3.11	3.11	3.11	
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )	5,400	5,400	5,400	5,400	5,400	5,400	5,400	5,400	5,400	
Dam Height (m)	140	140	140	140	140	140	140	140	140	
Maximum Head (m)	205	205	205	205	205	205	205	205	205	
Maximum Discharge (m <sup>3</sup> /s)	40	37	36	34	32	30	27	23	20	
Relocation Road	10,724	10,724	10,724	10,724	10,724	10,724	10,724	10,724	10,724	
Camp Facilities	800	800	800	800	800	800	800	800	800	
Land Acquisition	2,063	2,063	2,063	2,063	2,063	2,063	2,063	2,063	2,063	
Civil Work	28,050	28,050	28,050	28,050	28,050	28,050	28,050	28,050	28,050	
Diversion	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	
Care of River	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	1,082	
Dam	41,556	41,556	41,556	41,556	41,556	41,556	41,556	41,556	41,556	
Spillway	7,434	7,434	7,434	7,434	7,434	7,434	7,434	7,434	7,434	
Outlet Works	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	1,018	
Intake	999	982	947	912	877	842	807	772	737	
Headrace Tunnel	0	0	0	0	0	0	0	0	0	
Surge Tank	0	0	0	0	0	0	0	0	0	
Penstock	501	455	453	429	404	380	344	295	256	
Access Tunnels	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	3,980	
Power House	2,792	2,654	2,600	2,568	2,407	2,311	2,150	1,958	1,744	
Tailrace Tunnel	14,105	13,655	13,205	12,755	12,305	11,855	11,405	10,955	10,505	
Switchyard	161	161	161	161	161	161	161	161	161	
Pre-Subtotal	89,637	88,005	86,443	84,881	83,319	81,757	80,195	78,633	77,071	
Contingency (15%)	13,136	13,041	12,967	12,876	12,843	12,716	12,539	12,190	11,906	
Eng. and Adm. (10%)	10,071	9,959	9,834	9,871	9,846	9,749	9,613	9,346	9,146	
Sub Total	112,844	111,044	111,334	110,849	110,371	109,304	107,805	104,887	102,263	
I.D.C. (9.5%/Year)	27,545	27,385	27,243	27,106	26,961	26,818	26,675	26,532	26,389	
Total	140,389	138,429	138,577	137,955	137,332	136,122	134,380	131,426	128,652	
Hydraulic Equipment	4,904	4,701	4,613	4,457	4,304	4,083	3,825	3,354	2,954	
Spillway	856	856	856	856	856	856	856	856	856	
Outlet Works	528	528	528	528	528	528	528	528	528	
Intake Gate	701	689	665	640	615	529	458	271	211	
Penstock	2,202	2,043	1,990	1,884	1,777	1,671	1,510	1,296	1,111	
Draft Gate	113	105	102	95	91	85	77	65	55	
Tailrace Gate	57	52	51	48	45	43	38	33	28	
Pre-Subtotal	4,458	4,274	4,192	4,052	3,913	3,711	3,477	3,049	2,699	
Contingency (10%)	445	427	419	405	391	371	348	305	269	
Electro-Mechanical Equipment	14,944	14,268	14,043	13,792	13,105	12,596	11,593	11,004	10,450	
Equipment	14,233	13,589	13,374	13,135	12,481	11,996	11,041	10,450	9,900	
Contingency (5%)	712	679	669	657	624	600	552	524	500	
Eng. and Adm. (10%)	1,985	1,897	1,865	1,825	1,741	1,666	1,542	1,436	1,344	
Sub Total	21,833	20,865	20,519	20,075	19,150	18,347	16,959	15,794	14,844	
I.D.C. (9.5%/Year)	1,174	1,122	1,103	1,079	1,030	986	912	849	800	
Total	23,007	21,985	21,622	21,154	20,180	19,333	17,871	16,643	15,644	
Grand Total	158,396	156,417	156,201	155,909	155,601	154,455	152,251	149,529	147,307	

Tailrace Type Underground Powerhouse Layout Bayram H.W.L.=735m L.W.L.=686-730m and Baglik H.W.L.=630m Unit:10^3US\$										
Description	Baglik		Baglik		Baglik		Baglik		Baglik	
	735-666	735-700	735-705	735-710	735-715	735-720	735-725	735-730	735-730	
High Water Level (m)	530	530	530	530	530	530	530	530	530	
Reservoir Area (km <sup>2</sup> )	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )	195	195	195	195	195	195	195	195	195	
Dam Height (m)	74	74	74	74	74	74	74	74	74	
Maximum Head (m)	138	138	138	138	138	138	138	138	138	
Maximum Discharge (m <sup>3</sup> /s)	48	44	42	41	39	36	33	29	26	
Relocation Road	6,759	6,759	6,759	6,759	6,759	6,759	6,759	6,759	6,759	
Camp Facilities	800	800	800	800	800	800	800	800	800	
Land Acquisition	598	598	598	598	598	598	598	598	598	
Civil Work	25,409	24,903	24,450	24,042	23,950	23,494	22,834	22,008	21,182	
Diversion	0	0	0	0	0	0	0	0	0	
Care of River	0	0	0	0	0	0	0	0	0	
Dam	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	9,983	
Spillway	780	780	780	780	780	780	780	780	780	
Outlet Works	0	0	0	0	0	0	0	0	0	
Intake	37	35	34	33	31	29	28	26	24	
Headrace Tunnel	0	0	0	0	0	0	0	0	0	
Surge Tank	0	0	0	0	0	0	0	0	0	
Penstock	356	328	313	306	292	271	250	221	200	
Access Tunnels	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478	
Power House	3,185	3,034	2,920	2,844	2,768	2,579	2,427	2,199	2,000	
Tailrace Tunnel	8,590	8,266	7,942	7,617	7,617	7,374	6,888	6,321	5,780	
Switchyard	0	0	0	0	0	0	0	0	0	
Pre-Subtotal	33,565	33,060	32,607	32,199	32,106	31,651	30,991	30,165	29,340	
Contingency (15%)	4,945	4,859	4,801	4,740	4,726	4,658	4,559	4,435	4,300	
Eng. and Adm. (10%)	3,791	3,733	3,681	3,634	3,623	3,571	3,495	3,400	3,300	
Sub Total	42,303	41,663	41,089	40,573	40,456	39,860	39,045	38,000	37,040	
I.D.C. (9.5%/Year)	10,566	10,407	10,263	10,134	10,105	9,961	9,753	9,492	9,231	
Total	52,869	52,070	51,352	50,707	50,561	49,821	48,798	47,492	46,271	
Hydraulic Equipment	2,773	2,633	2,560	2,524	2,447	2,343	2,237	2,093	1,950	
Spillway	870	870	870	870	870	870	870	870	870	
Outlet Works	0	0	0	0	0	0	0	0	0	
Intake Gate	158	150	143	140	130	125	119	109	100	
Penstock	1,325	1,220	1,167	1,141	1,068	1,009	929	823	744	
Draft Gate	112	102	98	95	91	84	77	67	60	
Tailrace Gate	56	52	49	48	45	42	39	34	31	
Pre-Subtotal	2,521	2,393	2,327	2,295	2,225	2,130	2,034	1,903	1,781	
Contingency (10%)	252	239	233	229	222	213	203	190	178	
Electro-Mechanical Equipment	18,176	18,906	18,582	18,504	18,152	15,402	14,871	13,714	12,814	
Equipment	17,311	16,101	15,793	15,718	15,383	14,669	14,163	13,061	12,161	
Contingency (5%)	866	806	790	786	769	733	708	653	611	
Eng. and Adm. (10%)	2,095	1,954	1,814	1,803	1,860	1,775	1,711	1,581	1,481	
Sub Total	23,044	21,493	21,056	20,931	20,459	19,520	18,819	17,358	16,444	
I.D.C. (9.5%/Year)	1,306	1,217	1,193	1,186	1,159	1,106	1,066	985	926	
Total	24,350	22,710	22,249	22,115	21,618	20,626	19,885	18,343	17,370	
Grand Total	77,218	74,780	73,601	72,824	72,180	70,487	68,682	65,855	63,971	

**Table 9-11(5) Cost Estimate of Alternative Plan for Bayram Reservoir Water Level**

Unit: 10<sup>3</sup>US\$

Bayram Project Tailrace Undergro. P/S Layout H.W.L. = 730m L.W.L. = 586m-725m With Baglik H.W.L. = 530.00m

Description	Dam Site Layout Type	Bayram						
		730-686	730-700	730-705	730-710	730-715	730-720	730-725
High Water Level (m)		730	730	730	730	730	730	730
Reservoir Area (km <sup>2</sup> )		2.83	2.83	2.83	2.83	2.83	2.83	2.83
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )		4,800	4,800	4,800	4,800	4,800	4,800	4,800
Dam Height (m)		135	135	135	135	135	135	135
Maximum Head (m)		200	200	200	200	200	200	200
Maximum Discharge (m <sup>3</sup> /s)		38	35	33	31	28	26	23
Relocation Road		9,758	9,758	9,758	9,758	9,758	9,758	9,758
Camp Facilities		800	800	800	800	800	800	800
Land Acquisition		1,878	1,878	1,878	1,878	1,878	1,878	1,878
Civil Work		70,643	69,935	69,228	68,438	67,686	67,014	65,927
Diversion		2,421	2,421	2,421	2,421	2,421	2,421	2,421
Care of River		1,082	1,082	1,082	1,082	1,082	1,082	1,082
Dam		36,938	36,938	36,938	36,938	36,938	36,938	36,938
Spillway		7,346	7,346	7,346	7,346	7,346	7,346	7,346
Outlet Works		1,018	1,018	1,018	1,018	1,018	1,018	1,018
Intake		912	754	649	579	473	403	263
Headrace Tunnel		0	0	0	0	0	0	0
Surge Tank		0	0	0	0	0	0	0
Penstock		466	431	407	383	348	324	268
Access Tunnels		3,980	3,980	3,980	3,980	3,980	3,980	3,980
Power House		2,664	2,600	2,471	2,375	2,215	2,065	1,928
Tailrace Tunnel		13,655	13,205	12,755	12,154	11,704	11,254	10,504
Switchyard		161	161	161	161	161	161	161
Pre-Subtotal		83,079	82,371	81,664	80,874	80,122	79,450	78,363
Contingency (15%)		12,180	12,074	11,968	11,849	11,737	11,636	11,473
Eng. and Adm. (10%)		9,338	9,257	9,175	9,085	8,998	8,921	8,795
Sub Total		104,597	103,702	102,807	101,808	100,857	100,006	98,632
I.D.C. (9.5%/Year)		20,897	20,718	20,540	20,340	20,150	19,950	19,705
Total		125,494	124,421	123,347	122,147	121,007	119,997	118,337
Hydraulic Equipment		4,658	4,351	4,146	3,968	3,701	3,522	3,227
Spillway		856	856	856	856	856	856	856
Outlet Works		528	528	528	528	528	528	528
Intake Gate		640	529	455	406	332	283	185
Penstock		2,049	1,893	1,789	1,685	1,529	1,424	1,267
Draft Gate		106	89	94	86	79	74	65
Tailrace Gate		54	50	47	44	40	37	33
Pre-Subtotal		4,234	3,955	3,769	3,607	3,364	3,202	2,934
Contingency (10%)		423	396	377	361	336	320	293
Electro-Mechanical Equipment		14,250	13,758	13,294	12,596	11,593	11,426	10,612
Equipment		13,572	13,104	12,661	11,996	11,041	10,882	10,106
Contingency (5%)		679	655	633	600	552	544	505
Eng. and Adm. (10%)		1,831	1,811	1,744	1,656	1,529	1,495	1,384
Sub Total		20,799	19,921	19,184	18,220	16,823	16,443	15,223
I.D.C. (9.5%/Year)		1,118	1,071	1,031	980	904	884	818
Total		21,917	20,992	20,215	19,200	17,727	17,327	16,041
Grand Total		147,411	145,413	143,562	141,348	138,735	137,313	134,378

Unit: 10<sup>3</sup>US\$

Tailrace Type Underground Powerhouse Layout Bayram H.W.L. = 735m L.W.L. = 688-730m and Baglik H.W.L. = 530m

Description	Dam Site Layout Type	530							
		730-686	730-700	730-705	730-710	730-715	730-720	730-725	530
High Water Level (m)		530	530	530	530	530	530	530	530
Reservoir Area (km <sup>2</sup> )		0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )		195	195	195	195	195	195	195	195
Dam Height (m)		74	74	74	74	74	74	74	74
Maximum Head (m)		138	138	138	138	138	138	138	138
Maximum Discharge (m <sup>3</sup> /s)		45	41	40	38	35	32	29	29
Relocation Road		6,759	6,759	6,759	6,759	6,759	6,759	6,759	6,759
Camp Facilities		800	800	800	800	800	800	800	800
Land Acquisition		598	598	598	598	598	598	598	598
Civil Work		24,987	24,060	24,034	23,662	23,244	22,826	22,084	0
Diversion		0	0	0	0	0	0	0	0
Care of River		0	0	0	0	0	0	0	0
Dam		9,583	9,583	9,583	9,583	9,583	9,583	9,583	9,583
Spillway		780	780	780	780	780	780	780	780
Outlet Works		0	0	0	0	0	0	0	0
Intake		36	33	32	31	30	27	26	0
Headrace Tunnel		0	0	0	0	0	0	0	0
Surge Tank		0	0	0	0	0	0	0	0
Penstock		335	306	299	285	264	242	221	0
Access Tunnels		2,478	2,478	2,478	2,478	2,478	2,478	2,478	2,478
Power House		3,110	2,882	2,844	2,730	2,579	2,427	2,275	0
Tailrace Tunnel		8,266	7,617	7,617	7,374	7,131	6,888	6,321	0
Switchyard		0	0	0	0	0	0	0	0
Pre-Subtotal		33,144	32,237	32,191	31,819	31,401	30,983	30,240	0
Contingency (15%)		4,882	4,746	4,739	4,683	4,621	4,558	4,446	0
Eng. and Adm. (10%)		3,743	3,638	3,633	3,590	3,542	3,494	3,409	0
Sub Total		41,769	40,621	40,563	40,093	39,564	39,035	38,096	0
I.D.C. (9.5%/Year)		10,433	10,146	10,132	10,014	9,882	9,750	9,516	0
Total		52,201	50,768	50,695	50,107	49,447	48,785	47,611	0
Hydraulic Equipment		2,668	2,525	2,488	2,418	2,311	2,200	2,093	0
Spillway		870	870	870	870	870	870	870	0
Outlet Works		0	0	0	0	0	0	0	0
Intake Gate		152	141	137	134	127	116	109	0
Penstock		1,246	1,141	1,114	1,062	982	903	823	0
Draft Gate		106	96	93	88	81	74	67	0
Tailrace Gate		53	48	47	45	41	38	34	0
Pre-Subtotal		2,425	2,295	2,262	2,198	2,101	2,000	1,903	0
Contingency (10%)		243	230	226	220	210	200	190	0
Electro-Mechanical Equipment		17,614	16,504	16,418	16,055	15,281	14,590	13,569	0
Equipment		16,775	15,718	15,636	15,290	14,553	13,895	12,942	0
Contingency (5%)		839	786	782	765	728	695	647	0
Eng. and Adm. (10%)		2,028	1,903	1,891	1,847	1,759	1,679	1,568	0
Sub Total		22,310	20,932	20,797	20,320	19,352	18,469	17,251	0
I.D.C. (9.5%/Year)		1,264	1,186	1,178	1,151	1,096	1,045	977	0
Total		23,573	22,117	21,975	21,471	20,448	19,515	18,228	0
Grand Total		75,774	72,885	72,670	71,578	69,895	68,300	65,839	0

**Table 9-12(1) Comparison Study on Bayram Reservoir Water Level**

Bayram Project Tailrace Undergr. P.S. Layout H.W.L. = 750m L.W.L. = 686-745m WITH Baglik H.W.L. = \$30.0m by Mixed Alternative Thermal Power Plant

Description Dam Site	Bayram 750-686			Bayram 750-705			Bayram 750-710			Bayram 750-715			Bayram 750-720		
	Bayram 750-686	Baglik 530C	Total	Bayram 750-705	Baglik 530C	Total	Bayram 750-710	Baglik 530C	Total	Bayram 750-715	Baglik 530C	Total	Bayram 750-720	Baglik 530C	Total
High Water Level	750.00	530.00		750.00	530.00		750.00	530.00		750.00	530.00		750.00	530.00	
Normal Water Level	728.67	528.50		735.00	528.50		736.67	528.50		738.333	528.50		740.00	528.50	
Low Water Level	665.00	527.00		705.00	527.00		710.00	527.00		715.00	527.00		720.00	527.00	
Available Drawdown	64.00	3.00		45.00	3.00		40.00	3.00		35.00	3.00		30.00	3.00	
Gross Storage Capacity	169.00	7.30		169.00	7.30		169.00	7.30		169.00	7.30		169.00	7.30	
Effective Storage Capacity	149.00	1.00		123.00	1.00		114.00	1.00		104.00	1.00		83.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	155	74		155	74		155	74		155	74		155	74	
Dam Volume	8,500	195		8,500	195		8,500	195		8,500	195		8,500	195	
Tailwater Level	530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	189.67	131.00		195.90	130.90		197.57	130.90		199.23	130.90		200.80	130.80	
Maximum Discharge	49.00	58.00		45.00	54.00		43.00	52.00		42.00	50.00		40.00	47.00	
Installed Capacity	80.00	65.00	145.00	76.00	61.00	137.00	73.00	59.00	132.00	72.00	58.00	128.00	69.00	53.00	122.00
Firm Peak Power	67.43	62.90	130.30	66.43	58.00	124.40	64.10	56.40	120.50	62.40	55.00	117.40	60.20	51.00	111.20
Energy Production															
Average Energy	266.80	227.00	493.80	256.00	223.00	479.00	265.20	221.90	487.10	264.50	219.00	483.50	263.50	216.50	480.00
Firm Energy	168.50	139.20	307.70	166.91	127.02	293.93	161.44	124.10	285.54	156.02	120.45	276.47	149.42	111.89	261.31
Secondary Energy	98.30	87.80	186.10	89.09	95.98	195.07	103.76	97.80	201.56	108.48	98.55	207.03	114.08	104.61	218.89
Unit Benefit Value	0.00	0.00		0.00	0.00		0.00	0.00		0.00	0.00		0.00	0.00	
Firm Peak Power	180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45	
Firm Energy	0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270	
Secondary Energy	0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219	
Benefit															
Firm Peak Power	11.60	10.82	22.42	11.43	9.98	21.41	11.03	9.71	20.74	10.74	9.46	20.20	10.36	8.78	19.14
Firm Energy	4.47	3.69	8.17	4.42	3.37	7.79	4.28	3.29	7.58	4.14	3.20	7.34	3.97	2.96	6.93
Secondary Energy	2.12	1.85	4.01	2.14	2.07	4.21	2.23	2.11	4.34	2.34	2.12	4.46	2.46	2.26	4.71
Total	18.19	16.41	34.60	17.99	15.42	33.41	17.55	15.11	32.65	17.21	14.78	32.00	16.78	14.00	30.78
Investment Cost															
Civil Facilities	185.64	56.30	242.94	182.39	54.32	236.71	181.14	53.79	234.93	180.95	53.59	234.54	179.74	52.80	232.54
Hydra and Ele. Mech. Eq.	27.06	27.13	54.22	25.95	26.11	52.06	25.30	25.72	51.03	25.22	24.77	49.99	24.55	24.01	48.56
Total	212.70	82.43	295.15	208.34	80.43	288.77	206.45	79.52	285.96	206.17	78.36	284.52	204.29	76.81	281.10
Annual Cost															
Civil Facilities	18.75	5.59	24.34	18.42	5.49	23.91	18.30	5.43	23.73	18.28	5.41	23.69	18.15	5.33	23.49
Hydra and Ele. Mech. Eq.	3.06	3.06	6.18	2.96	2.98	5.93	2.89	2.93	5.82	2.87	2.82	5.70	2.80	2.74	5.54
Total	21.84	8.66	30.52	21.38	8.48	29.84	21.18	8.37	29.55	21.15	8.24	29.39	20.95	8.07	29.02
Annual Surplus Benefit (B-C)	-3.65	7.73	4.08	-3.39	6.96	3.57	-3.63	6.74	3.11	-3.94	6.56	2.61	-4.17	5.93	1.76
Benefit Cost Ratio (B/C)	0.83	1.89	1.13	0.84	1.82	1.12	0.83	1.81	1.11	0.81	1.79	1.09	0.80	1.73	1.06
Unit Annual Cost (Firm)	0.130	0.062	0.099	0.128	0.067	0.102	0.131	0.067	0.103	0.136	0.068	0.106	0.140	0.072	0.111
Unit Annual Cost (Average)	0.082	0.038	0.062	0.083	0.038	0.061	0.080	0.038	0.061	0.080	0.038	0.061	0.080	0.037	0.060

Bayram Project Tailrace Undergr. P.S. Layout H.W.L. = 750m L.W.L. = 686-745m WITH Baglik H.W.L. = \$30.0m by Mixed Alternative Thermal Power Plant

Description Dam Site	Bayram 750-725			Bayram 750-735			Bayram 750-740			Bayram 750-745		
	Bayram 750-725	Baglik 530C	Total	Bayram 750-735	Baglik 530C	Total	Bayram 750-740	Baglik 530C	Total	Bayram 750-745	Baglik 530C	Total
High Water Level	750.00	530.00		750.00	530.00		750.00	530.00		750.00	530.00	
Normal Water Level	741.67	528.50		743.33	528.50		745.00	528.50		746.67	528.50	
Low Water Level	725.00	527.00		730.00	527.00		735.00	527.00		740.00	527.00	
Available Drawdown	25.00	3.00		20.00	3.00		15.00	3.00		10.00	3.00	
Gross Storage Capacity	169.00	7.30		169.00	7.30		169.00	7.30		169.00	7.30	
Effective Storage Capacity	149.00	1.00		123.00	1.00		104.00	1.00		83.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	155	74		155	74		155	74		155	74	
Dam Volume	8,500	195		8,500	195		8,500	195		8,500	195	
Tailwater Level	530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	202.47	130.90		204.03	130.80		205.66	130.70		207.17	130.70	
Maximum Discharge	38.00	44.00		35.00	42.00		33.00	39.00		29.00	36.00	
Installed Capacity	66.00	43.00	115.30	61.00	47.00	108.00	58.00	44.00	102.00	51.00	40.00	91.00
Firm Peak Power	58.61	48.00	106.61	54.70	45.00	100.70	52.10	43.00	95.10	48.80	39.00	87.80
Energy Production												
Average Energy	259.50	212.00	471.50	253.90	206.40	460.30	245.00	196.00	441.00	232.70	186.10	418.80
Firm Energy	141.79	105.12	246.91	128.90	100.70	229.60	120.21	91.58	211.79	110.20	83.10	193.30
Secondary Energy	117.71	106.88	224.59	125.00	105.70	230.70	124.79	104.42	229.21	122.50	103.00	225.50
Unit Benefit Value												
Firm Peak Power	180.450	180.450		180.450	180.450		180.450	180.450		180.450	180.450	
Firm Energy	0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270	
Secondary Energy	0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219	
Benefit												
Firm Peak Power	10.06	8.26	18.35	9.41	7.92	17.33	8.97	7.23	16.20	8.40	6.74	15.14
Firm Energy	3.76	2.78	6.55	3.42	2.67	6.09	3.19	2.44	5.63	2.92	2.26	5.18
Secondary Energy	2.53	2.33	4.84	2.69	2.28	4.97	2.69	2.28	4.97	2.64	2.13	4.81
Total	16.38	13.35	29.73	15.53	12.86	28.39	14.84	11.95	26.79	13.96	11.14	25.10
Investment Cost												
Civil Facilities	178.72	52.07	230.79	177.56	51.35	228.91	176.59	50.50	227.09	174.30	49.96	224.26
Hydra and Ele. Mech. Eq.	23.58	22.93	46.42	22.22	22.45	44.68	21.46	21.62	43.08	19.21	20.81	40.02
Total	202.28	75.00	277.28	199.78	73.81	273.59	198.05	72.13	270.18	193.51	70.77	264.28
Annual Cost												
Civil Facilities	18.05	5.26	23.31	17.93	5.19	23.12	17.84	5.10	22.94	17.60	5.05	22.65
Hydra and Ele. Mech. Eq.	2.69	2.61	5.30	2.53	2.56	5.06	2.45	2.47	4.91	2.37	2.36	4.73
Total	20.74	7.87	28.61	20.47	7.75	28.22	20.29	7.57	27.85	19.97	7.42	27.38
Annual Surplus Benefit (B-C)	-4.35	5.48	1.13	-4.94	5.12	0.18	-5.44	4.99	-1.05	-5.83	3.73	-2.11
Benefit Cost Ratio (B/C)	0.79	1.70	1.04	0.76	1.68	1.01	0.73	1.58	0.96	0.71	1.50	0.92
Unit Annual Cost (Firm)	0.145	0.075	0.110	0.139	0.077	0.123	0.165	0.082	0.131	0.180	0.087	0.139
Unit Annual Cost (Average)	0.080	0.037	0.061	0.081	0.038	0.061	0.083	0.038	0.063	0.085	0.043	0.065



**Table 9-12(2) Comparison Study on Bayram Reservoir Water Level**

Bayram Project Tailrace Undergr. P/S Layout H.W.L.=745m L.W.L.=666-740m With Baglik H.W.L.=530.00m												by Mixed Alternative Thermal Power Plant			
Description Dam Site	Bayram 745-686	Baglik 530C	Total	Bayram 745-700	Baglik 530C	Total	Bayram 745-705	Baglik 530C	Total	Bayram 745-710	Baglik 530C	Total	Bayram 745-715	Baglik 530C	Total
High Water Level	745.00	530.00		745.00	530.00		745.00	530.00		745.00	530.00		745.00	530.00	
Normal Water Level	725.33	528.50		730.00	528.50		731.67	528.50		733.33	528.50		735.00	528.50	
Low Water Level	688.00	527.00		700.00	527.00		705.00	527.00		710.00	527.00		715.00	527.00	
Available Drawdown	59.00	3.00		45.00	3.00		40.00	3.00		35.00	3.00		30.00	3.00	
Gross Storage Capacity	150.00	7.30		150.00	7.30		150.00	7.30		150.00	7.30		150.00	7.30	
Effective Storage Capacity	130.00	1.00		112.00	1.00		104.00	1.00		95.00	1.00		85.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	150	74		150	74		150	74		150	74		150	74	
Dam Volume	7,200	195		7,200	195		7,200	195		7,200	195		7,200	195	
Tailwater Level	530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	186.33	130.90		190.90	130.90		192.57	130.90		194.13	130.90		195.80	130.90	
Maximum Discharge	45.00	55.00		43.00	52.00		42.00	43.00		40.00	48.00		38.00	45.00	
Installed Capacity	74.00	62.00	136.00	70.00	58.00	128.00	69.00	43.00	112.00	67.00	54.00	121.00	64.00	51.00	115.00
Firm Peak Power	63.00	58.60	121.60	60.90	56.40	117.30	60.12	54.00	114.12	58.29	52.00	110.29	56.20	49.00	105.20
Energy Production															
Average Energy	257.70	224.00	481.70	257.10	220.70	477.80	256.47	218.50	474.97	253.81	215.60	469.41	249.42	212.50	461.92
Firm Energy	154.40	130.70	285.10	148.92	123.52	272.44	151.40	118.26	269.66	149.79	113.88	263.67	139.48	107.31	246.79
Secondary Energy	103.30	93.30	196.60	108.18	97.18	205.36	105.07	100.24	205.31	103.83	101.72	205.55	106.94	105.19	212.13
Unit Benefit Value	0.00	0.00		0.00	0.00		0.00	0.00		0.00	0.00		0.00	0.00	
Firm Peak Power	180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45	
Firm Energy	0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270	
Secondary Energy	0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219	
Benefit															
Firm Peak Power	10.84	10.26	21.10	10.48	9.71	20.19	10.35	9.25	19.60	10.03	8.95	18.98	9.67	8.43	18.10
Firm Energy	4.10	3.47	7.57	3.95	3.26	7.23	4.02	3.14	7.16	3.98	3.02	7.00	3.70	2.85	6.55
Secondary Energy	2.22	2.01	4.23	2.33	2.09	4.42	2.26	2.16	4.42	2.19	2.19	4.33	2.37	2.26	4.63
Total	17.16	15.73	32.90	16.76	15.08	31.84	16.63	14.58	31.22	16.24	14.16	30.40	15.74	13.55	29.29
Investment Cost															
Civil Facilities	164.81	54.51	219.32	163.36	53.79	217.15	163.24	53.00	216.24	161.81	52.87	214.68	160.92	52.20	213.12
Hydra. and Ele.-Mech Eq	25.25	25.44	50.69	24.53	25.73	50.26	24.46	24.69	49.15	23.74	24.60	48.33	23.04	23.81	46.84
Total	190.10	80.95	271.04	187.89	79.52	267.44	187.70	77.69	265.39	185.55	77.47	263.12	183.96	76.01	259.96
Annual Cost															
Civil Facilities	16.65	5.51	22.15	16.55	5.43	21.98	16.49	5.35	21.84	16.35	5.34	21.69	16.25	5.27	21.53
Hydra. and Ele.-Mech Eq	2.88	3.01	5.90	2.80	2.93	5.73	2.79	2.81	5.60	2.71	2.80	5.51	2.63	2.71	5.34
Total	19.53	8.52	28.05	19.35	8.37	27.66	19.28	8.17	27.44	19.06	8.14	27.20	18.88	7.99	26.87
Annual Surplus Benefit(B-C)	-2.36	7.21	4.85	-2.54	8.71	6.17	-2.65	8.42	5.77	-2.82	8.07	5.20	-3.14	5.56	2.42
Benefit Cost Ratio(B/C)	0.88	1.85	1.17	0.87	1.80	1.15	0.86	1.79	1.14	0.85	1.74	1.12	0.83	1.70	1.09
Unit Annual Cost (Firm)	0.126	0.063	0.098	0.130	0.068	0.102	0.127	0.069	0.102	0.127	0.072	0.103	0.135	0.071	0.109
Unit Annual Cost (Average)	0.076	0.038	0.058	0.075	0.038	0.058	0.075	0.037	0.058	0.075	0.038	0.058	0.076	0.038	0.058

Bayram Project Tailrace Undergr. P/S Layout H.W.L.=745m L.W.L.=666-740m With Baglik H.W.L.=530.00m												by Mixed Alternative Thermal Power Plant			
Description Dam Site	Bayram 745-720	Baglik 530C	Total	Bayram 745-725	Baglik 530C	Total	Bayram 745-730	Baglik 530C	Total	Bayram 745-735	Baglik 530C	Total	Bayram 745-740	Baglik 530C	Total
High Water Level	745.00	530.00		745.00	530.00		745.00	530.00		745.00	530.00		745.00	530.00	
Normal Water Level	736.67	528.50		738.33	528.50		740.00	528.50		741.67	528.50		743.33	528.50	
Low Water Level	720.00	527.00		725.00	527.00		730.00	527.00		735.00	527.00		740.00	527.00	
Available Drawdown	25.00	3.00		20.00	3.00		15.00	3.00		10.00	3.00		5.00	3.00	
Gross Storage Capacity	150.00	7.30		150.00	7.30		150.00	7.30		150.00	7.30		150.00	7.30	
Effective Storage Capacity	74.00	1.00		62.00	1.00		43.00	1.00		34.00	1.00		17.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	150	74		150	74		150	74		150	74		150	74	
Dam Volume	7,200	195		7,200	195		7,200	195		7,200	195		7,200	195	
Tailwater Level	530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	197.33	130.80		198.93	130.70		200.60	130.70		202.07	130.60		203.53	130.50	
Maximum Discharge	38.00	43.00		34.00	41.00		32.00	38.00		28.00	35.00		24.00	30.00	
Installed Capacity	61.00	48.00	109.00	58.00	45.00	103.00	55.00	43.00	98.00	49.00	39.00	87.00	42.00	33.00	75.00
Firm Peak Power	54.24	47.00	101.24	52.33	45.00	97.33	50.49	41.00	91.49	45.35	38.00	83.35	40.26	33.00	73.26
Energy Production															
Average Energy	246.48	206.50	452.98	241.24	203.50	444.74	235.23	192.00	427.23	221.13	185.00	406.13	199.83	169.00	368.83
Firm Energy	130.68	102.93	233.59	124.15	98.55	222.70	112.43	89.79	202.22	99.32	83.22	182.54	86.17	72.77	160.44
Secondary Energy	115.82	103.57	219.39	117.09	104.95	222.04	122.81	102.21	225.02	121.81	101.78	223.59	113.63	96.73	208.36
Unit Benefit Value															
Firm Peak Power	190.450	180.450		180.450	180.450		180.450	180.450		180.450	180.450		180.450	180.450	
Firm Energy	0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270	
Secondary Energy	0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219	
Benefit															
Firm Peak Power	9.33	8.05	17.38	9.61	7.74	16.73	8.69	7.06	15.75	7.80	6.54	14.34	6.93	5.68	12.61
Firm Energy	3.47	2.73	6.20	3.30	2.62	5.91	2.98	2.38	5.37	2.64	2.11	4.84	2.34	1.92	4.26
Secondary Energy	2.49	2.27	4.77	2.52	2.26	4.78	2.64	2.20	4.84	2.62	2.19	4.81	2.40	2.06	4.49
Total	15.30	13.09	28.39	14.82	12.62	27.44	14.34	11.64	25.96	13.06	10.94	24.00	11.67	9.58	21.35
Investment Cost															
Civil Facilities	159.91	51.48	211.39	158.96	50.71	209.67	158.56	50.11	208.69	156.38	49.45	205.82	154.59	48.07	202.66
Hydra. and Ele.-Mech Eq	22.31	23.02	45.33	21.31	22.54	43.85	20.53	21.67	42.20	18.70	20.62	39.32	17.36	18.90	36.26
Total	182.22	74.51	256.72	180.27	73.24	253.52	179.11	71.77	250.89	175.08	70.07	245.14	171.95	66.97	238.92
Annual Cost															
Civil Facilities	16.15	5.20	21.35	16.06	5.12	21.18	16.02	5.06	21.08	15.79	4.98	20.79	15.61	4.85	20.47
Hydra. and Ele.-Mech Eq	2.54	2.62	5.17	2.43	2.57	5.00	2.34	2.47	4.81	2.13	2.35	4.48	1.98	2.15	4.13
Total	18.69	7.82	26.52	18.48	7.69	26.18	18.36	7.53	25.89	17.93	7.34	25.27	17.59	7.01	24.60
Annual Surplus Benefit(B-C)	-3.40	5.27	1.87	-3.66											

**Table 9-12(3) Comparison Study on Bayram Reservoir Water Level**

Bayram Project Takease Underpro. P.S Layout H.W.L = 740m L.W.L = 655m-735m With Bagik H.W.L = 530.00m by Mixed Alternative Thermal Power Plant

Description Dam Site	Bayram 740-656			Bayram 740-700			Bayram 740-705			Bayram 740-710			Bayram 740-715		
	Bayram	Bagik	Total	Bayram	Bagik	Total	Bayram	Bagik	Total	Bayram	Bagik	Total	Bayram	Bagik	Total
High Water Level	740.00	530.00		740.00	530.00		740.00	530.00		740.00	530.00		740.00	530.00	
Normal Water Level	722.00	528.50		726.87	528.50		728.33	528.50		730.00	528.50		732.00	528.50	
Low Water Level	696.00	527.00		700.00	527.00		705.00	527.00		710.00	527.00		715.00	527.00	
Available Drawdown	54.00	3.00		40.00	3.00		35.00	3.00		30.00	3.00		25.00	3.00	
Gross Storage Capacity	133.00	7.30		133.00	7.30		133.00	7.30		133.00	7.30		133.00	7.30	
Effective Storage Capacity	113.00	1.00		95.00	1.00		87.00	1.00		78.00	1.00		68.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	145	74		145	74		145	74		145	74		145	74	
Dam Volume	6,144	195		6,144	195		6,144	195		6,144	195		6,144	195	
Talwater Level	530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	182.90	130.80		187.47	130.90		189.13	130.80		190.70	130.80		192.37	130.80	
Maximum Discharge	43.00	52.00		40.00	48.00		39.00	46.00		37.00	44.00		36.00	42.00	
Installed Capacity	68.00	29.00	127.00	64.00	34.00	118.00	63.00	32.00	115.00	61.00	31.00	110.00	59.00	29.00	106.00
Firm Peak Power	58.00	26.40	114.40	55.60	25.50	107.10	54.00	25.00	104.00	52.10	24.00	100.10	51.00	23.00	97.00
Energy Production															
Average Energy	247.90	221.40	469.30	248.50	218.30	466.80	244.89	213.50	458.39	242.80	210.70	453.50	240.00	206.80	446.80
Firm Energy	141.40	124.20	265.60	134.60	113.60	248.20	130.87	109.50	240.37	126.30	104.90	231.20	122.18	100.74	222.92
Secondary Energy	106.50	97.20	203.70	113.90	104.70	218.60	114.00	104.00	218.00	116.50	105.80	222.30	117.82	106.06	223.88
Unit Benefit Value	0.00	0.00		0.00	0.00		0.00	0.00		0.00	0.00		0.00	0.00	
Firm Peak Power	180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45	
Firm Energy	0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270	
Secondary Energy	0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219	
Benefit															
Firm Peak Power	9.56	9.11	19.69	9.57	8.86	18.43	8.29	8.60	17.90	8.97	8.26	17.23	8.78	7.92	16.69
Firm Energy	3.75	3.30	7.05	3.57	3.02	6.59	3.47	2.91	6.38	3.35	2.78	6.14	3.24	2.67	5.92
Secondary Energy	2.29	2.09	4.38	2.41	2.21	4.62	2.46	2.24	4.69	2.51	2.28	4.79	2.54	2.29	4.82
Total	16.03	13.50	31.53	15.55	14.09	29.64	15.22	13.75	28.97	14.83	13.32	28.15	14.56	13.87	27.49
Investment Cost															
Civil Facilities	147.74	53.76	201.51	148.36	52.87	199.23	148.19	52.21	196.40	145.21	51.68	196.89	144.39	51.54	195.93
Hydra and Ele. Mech Eq	24.32	25.89	50.21	23.57	24.35	47.92	23.47	23.82	47.29	22.77	22.94	45.70	22.45	22.45	44.90
Total	172.06	79.65	251.71	169.92	77.22	247.15	168.66	76.13	245.79	167.97	74.62	242.59	166.84	74.01	240.83
Annual Cost															
Civil Facilities	14.92	5.43	20.35	14.78	5.34	20.12	14.76	5.27	20.04	14.67	5.22	19.89	14.58	5.21	19.79
Hydra and Ele. Mech Eq	2.77	2.93	5.70	2.69	2.78	5.46	2.68	2.73	5.40	2.60	2.60	5.21	2.52	2.56	5.08
Total	17.69	8.36	26.05	17.47	8.12	25.58	17.44	8.00	25.44	17.26	7.83	25.10	17.11	7.77	24.87
Annual Surplus Benefit (B/C)	-1.67	6.74	5.07	-1.92	5.97	4.06	-2.22	5.75	3.53	-2.44	5.43	3.05	-2.55	5.11	2.56
Benefit Cost Ratio (B/C)	0.91	1.81	1.19	0.89	1.74	1.16	0.87	1.72	1.14	0.86	1.70	1.12	0.85	1.66	1.10
Unit Annual Cost (Firm)	0.145	0.067	0.056	0.130	0.071	0.103	0.133	0.073	0.106	0.137	0.073	0.109	0.140	0.077	0.112
Unit Annual Cost (Average)	0.071	0.038	0.056	0.071	0.038	0.055	0.071	0.037	0.055	0.071	0.037	0.055	0.071	0.038	0.056

Bayram Project Takease Underpro. P.S Layout H.W.L = 740m L.W.L = 655m-735m With Bagik H.W.L = 530.00m by Mixed Alternative Thermal Power Plant

Description Dam Site	Bayram 740-720			Bayram 740-725			Bayram 740-730			Bayram 740-735		
	Bayram	Bagik	Total	Bayram	Bagik	Total	Bayram	Bagik	Total	Bayram	Bagik	Total
High Water Level	740.00	530.00		740.00	530.00		740.00	530.00		740.00	530.00	
Normal Water Level	733.33	528.50		735.00	528.50		736.67	528.50		738.33	528.50	
Low Water Level	720.00	527.00		725.00	527.00		730.00	527.00		735.00	527.00	
Available Drawdown	20.00	3.00		15.00	3.00		10.00	3.00		5.00	3.00	
Gross Storage Capacity	133.00	7.30		133.00	7.30		133.00	7.30		133.00	7.30	
Effective Storage Capacity	97.00	1.00		45.00	1.00		31.00	1.00		17.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	145	74		145	74		145	74		145	74	
Dam Volume	6,144	195		6,144	195		6,144	195		6,144	195	
Talwater Level	530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	193.93	130.70		195.52	130.70		197.07	130.60		198.53	130.50	
Maximum Discharge	33.00	40.00		31.00	37.00		27.00	34.00		24.00	30.00	
Installed Capacity	55.00	45.00	100.00	52.00	42.00	94.00	46.00	38.00	84.00	41.00	33.00	74.00
Firm Peak Power	49.00	44.00	93.00	46.50	40.00	86.50	42.90	37.00	79.90	39.30	33.00	72.30
Energy Production												
Average Energy	235.20	201.00	436.20	225.82	192.60	418.42	212.80	180.80	393.60	193.83	169.50	363.33
Firm Energy	118.00	56.10	214.10	107.83	87.60	195.43	97.40	80.80	178.20	86.07	72.27	158.34
Secondary Energy	119.20	104.90	224.10	117.99	105.00	222.99	115.20	100.00	215.20	107.77	97.23	205.00
Unit Benefit Value												
Firm Peak Power	180.45	180.45		180.45	180.45		180.45	180.45		180.45	180.45	
Firm Energy	0.0270	0.0270		0.0270	0.0270		0.0270	0.0270		0.0270	0.0270	
Secondary Energy	0.0219	0.0219		0.0219	0.0219		0.0219	0.0219		0.0219	0.0219	
Benefit												
Firm Peak Power	8.43	7.57	16.00	8.00	8.88	14.89	7.36	8.37	13.75	6.76	5.68	12.44
Firm Energy	3.08	2.55	5.63	2.96	2.93	5.19	2.56	2.14	4.73	2.28	1.92	4.20
Secondary Energy	2.57	1.28	4.82	2.54	2.26	4.80	2.48	2.15	4.63	2.32	2.06	4.41
Total	14.08	12.38	26.46	13.43	11.47	24.87	12.45	10.66	23.11	11.37	9.66	21.06
Investment Cost												
Civil Facilities	142.84	50.70	193.54	141.96	49.98	191.94	139.78	49.25	189.03	138.81	47.96	186.78
Hydra and Ele. Mech Eq	20.95	21.98	42.93	20.19	21.32	41.50	18.40	20.26	38.66	17.04	18.75	35.79
Total	163.83	72.68	236.51	162.15	71.30	233.45	158.18	69.51	227.70	155.85	66.70	222.55
Annual Cost												
Civil Facilities	14.43	5.12	19.55	14.34	5.05	19.39	14.12	4.97	19.09	14.02	4.94	18.86
Hydra and Ele. Mech Eq	2.36	2.51	4.90	2.30	2.43	4.73	2.10	2.31	4.41	1.94	2.14	4.08
Total	16.69	7.63	24.45	16.64	7.48	24.12	16.22	7.26	23.50	15.96	6.98	22.94
Annual Surplus Benefit (B/C)	-2.74	4.78	2.01	-3.24	3.95	0.76	-3.77	3.36	-0.39	-4.59	2.71	-1.88
Benefit Cost Ratio (B/C)	0.84	1.62	1.08	0.81	1.53	1.03	0.77	1.46	0.98	0.71	1.39	0.92
Unit Annual Cost (Firm)	0.145	0.079	0.115	0.154	0.085	0.123	0.166	0.090	0.132	0.185	0.097	0.145
Unit Annual Cost (Average)	0.072	0.039	0.066	0.074	0.039	0.058	0.076	0.040	0.060	0.082	0.041	0.063

**Table 9-12(4) Comparison Study on Bayram Reservoir Water Level**

Description Dam Site	Bayram Project Takeover Undergr. P/S Layout H.W.L.=735m L.W.L.=655m-730m With Baglik H.W.L.=530.00m			by Mixed Alternative Thermal Power Plant								
	Bayram 735-656	Baglik 530C	Total	Bayram 735-700	Baglik 530C	Total	Bayram 735-710	Baglik 530C	Total	Bayram 735-715	Baglik 530C	Total
High Water Level	735.00	530.00		735.00	530.00		735.00	530.00		735	530.00	
Normal Water Level	718.67	528.50		723.33	528.50		725.00	528.50		728.3333	528.50	
Low Water Level	686.00	527.00		700.00	527.00		705.00	527.00		710	527.00	
Available Drawdown	49.00	3.00		35.00	3.00		30.00	3.00		25	3.00	
Gross Storage Capacity	116.00	7.30		116.00	7.30		116.00	7.30		116	7.30	
Effective Storage Capacity	96.00	1.00		78.00	1.00		70.00	1.00		61	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	140	74		140	74		140	74		140	74	
Dam Volume	5,400	195		5,400	195		5,400	195		5,400	195	
Tailwater Level	530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	179.47	130.90		184.03	130.80		185.70	130.80		187.27	130.70	
Maximum Discharge	40.00	48.00		37.00	44.00		36.00	42.00		34.00	41.00	
Installed Capacity	62.00	54.00	116.00	58.00	49.00	107.00	57.00	47.00	104.00	55.00	46.00	101.00
Firm Peak Power	52.40	52.00	104.40	50.46	48.00	98.46	49.59	46.00	95.59	49.50	45.00	94.50
Energy Production												
Average Energy	237.00	215.70	452.70	235.06	210.10	445.16	233.13	207.20	440.33	228.93	203.20	432.13
Firm Energy	128.20	113.60	241.80	110.51	105.12	215.63	108.60	100.74	209.34	106.41	98.55	206.96
Secondary Energy	108.80	102.10	210.90	124.55	104.98	229.53	124.53	106.46	231.05	120.53	104.65	225.18
Unit Benefit Value	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Firm Peak Power	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45
Firm Energy	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270
Secondary Energy	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Benefit												
Firm Peak Power	8.02	8.95	17.97	8.58	8.26	16.84	8.53	7.92	16.45	8.52	7.74	16.26
Firm Energy	3.40	3.02	6.42	2.93	2.79	5.72	2.88	2.67	5.56	2.88	2.62	5.49
Secondary Energy	2.34	2.20	4.54	2.68	2.26	4.94	2.68	2.29	4.97	2.59	2.25	4.85
Total	14.76	14.16	28.92	14.30	13.31	27.61	14.10	12.88	26.98	13.99	12.61	26.60
Investment Cost												
Civil Facilities	135.30	52.87	188.26	134.43	52.07	186.50	133.56	51.55	184.93	132.76	50.71	183.46
Hydra. and Ele. Mech. Eq.	23.01	24.35	47.36	21.95	22.71	44.70	21.82	22.25	43.87	21.15	22.12	43.27
Total	158.40	77.22	235.61	156.42	74.78	231.20	155.20	73.60	228.80	153.91	72.82	226.73
Annual Cost												
Civil Facilities	13.67	5.34	19.01	13.58	5.26	18.84	13.49	5.19	18.68	13.41	5.12	18.53
Hydra. and Ele. Mech. Eq.	2.62	2.78	5.40	2.51	2.59	5.10	2.46	2.54	5.00	2.41	2.52	4.93
Total	16.30	8.12	24.41	16.06	7.85	23.93	15.96	7.72	23.58	15.82	7.64	23.46
Annual Surplus Benefit(B-C)	-1.53	8.05	6.51	-1.75	5.46	3.68	-1.86	5.16	3.30	-1.83	4.97	3.14
Benefit Cost Ratio(B/C)	0.91	1.75	1.18	0.89	1.70	1.15	0.88	1.67	1.14	0.88	1.65	1.13
Unit Annual Cost (Firm)	0.127	0.071	0.101	0.148	0.075	0.111	0.147	0.077	0.113	0.146	0.078	0.113
Unit Annual Cost (Average)	0.069	0.036	0.054	0.068	0.037	0.054	0.068	0.037	0.054	0.069	0.038	0.054

Description Dam Site	Bayram Project Takeover Undergr. P/S Layout H.W.L.=735m L.W.L.=655m-730m With Baglik H.W.L.=530.00m			by Mixed Alternative Thermal Power Plant					
	Bayram 735-725	Baglik 530C	Total	Bayram 735-725	Baglik 530C	Total	Bayram 735-730	Baglik 530C	Total
High Water Level	735.00	530.00		735.00	530.00		735.00	530.00	
Normal Water Level	730.00	528.50		731.67	528.50		733.33	528.50	
Low Water Level	720.00	527.00		725.00	527.00		730.00	527.00	
Available Drawdown	15.00	3.00		10.00	3.00		5.00	3.00	
Gross Storage Capacity	116.00	7.30		116.00	7.30		116.00	7.30	
Effective Storage Capacity	40.00	1.00		28.00	1.00		14.00	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	140	74		140	74		140	74	
Dam Volume	5,400	195		5,400	195		5,400	195	
Tailwater Level	530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	190.50	130.70		192.07	130.60		193.43	130.50	
Maximum Discharge	30.00	36.00		27.00	33.00		23.00	29.00	
Installed Capacity	48.00	40.00	88.00	44.00	37.00	81.00	38.00	32.00	70.00
Firm Peak Power	48.00	39.00	85.00	43.12	36.00	79.12	37.62	31.00	68.62
Energy Production									
Average Energy	215.76	189.50	405.26	204.78	180.00	384.78	184.73	166.00	350.73
Firm Energy	100.87	85.41	186.28	84.43	78.84	173.27	82.59	87.89	150.28
Secondary Energy	114.88	104.09	218.97	110.35	101.16	211.51	102.54	98.11	200.45
Unit Benefit Value									
Firm Peak Power	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450	180.450
Firm Energy	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027	0.027
Secondary Energy	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022
Benefit									
Firm Peak Power	7.93	8.71	14.64	7.43	6.20	13.62	6.47	5.33	11.81
Firm Energy	2.68	2.27	4.94	2.51	2.05	4.60	2.19	1.80	3.99
Secondary Energy	2.47	2.24	4.71	2.38	2.18	4.55	2.20	2.11	4.32
Total	13.08	11.22	24.30	12.30	10.47	22.77	10.86	9.25	20.11
Investment Cost									
Civil Facilities	131.14	49.84	180.98	129.34	48.90	178.14	125.82	47.49	173.31
Hydra. and Ele. Mech. Eq.	19.33	20.63	39.96	17.87	19.82	37.76	16.64	18.37	35.02
Total	150.47	70.47	220.94	147.21	68.68	215.90	142.46	65.86	208.33
Annual Cost									
Civil Facilities	13.25	5.03	18.28	13.06	4.93	17.99	12.71	4.80	17.50
Hydra. and Ele. Mech. Eq.	2.20	2.35	4.56	2.04	2.27	4.30	1.90	2.06	3.99
Total	15.45	7.39	22.83	15.10	7.20	22.30	14.60	6.85	21.50
Annual Surplus Benefit(B-C)	-2.37	3.83	1.46	-2.80	3.27	0.47	-3.74	2.36	-1.38
Benefit Cost Ratio(B/C)	0.85	1.52	1.06	0.81	1.45	1.02	0.74	1.34	0.94
Unit Annual Cost (Firm)	0.153	0.086	0.123	0.150	0.091	0.129	0.177	0.102	0.143
Unit Annual Cost (Average)	0.072	0.036	0.054	0.074	0.042	0.058	0.079	0.042	0.061

**Table 9-12(5) Comparison Study on Bayram Reservoir Water Level**

Bayram Project Takease Undergr. P.S Layout H.W.L.=730m L.W.L.=635m-725m With Bagik H.W.L.= 530.00m						by Mixed Alternative Thermal Power Plant									
Description Dam Site	Bayram 730-686	Bagik 530C	Total	Bayram 730-700	Bagik 530C	Total	Bayram 730-705	Bagik 530C	Total	Bayram 730-710	Bagik 530C	Total	Bayram 730-715	Bagik 530C	Total
High Water Level	730.00	530.00		730.00	530.00		730.00	530.00		730	530.00		730	530.00	
Normal Water Level	715.33	528.50		720.00	528.50		721.67	528.50		723.3333	528.50		725	528.50	
Low Water Level	686.00	527.00		700.00	527.00		705.00	527.00		710	527.00		715	527.00	
Available Drawdown	44.00	3.00		30.00	3.00		25.00	3.00		20	3.00		15	3.00	
Gross Storage Capacity	102.00	7.30		102.00	7.30		102.00	7.30		102	7.30		102	7.30	
Effective Storage Capacity	82.00	1.00		84.00	1.00		86.00	1.00		87	1.00		89	1.00	
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra		Rockfill	Con-Gra	
Dam Height	135	74		135	74		135	74		135	74		135	74	
Dam Volume	4,800	195		4,800	195		4,800	195		4,800	195		4,800	195	
Tailwater Level	530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00		530.00	392.00	
Effective Head	176.23	130.80		180.80	130.70		182.37	130.70		183.93	130.70		185.50	130.80	
Maximum Discharge	38.00	45.00		35.00	41.00		33.00	40.00		31.00	38.00		28.00	35.00	
Installed Capacity	57.00	51.00	108.00	54.00	48.00	102.00	52.00	45.00	97.00	49.00	43.00	92.00	44.00	39.00	83.00
Firm Peak Power	45.50	43.00	87.50	46.30	45.00	91.30	45.00	44.00	89.00	43.60	41.00	84.60	42.40	38.00	80.40
Energy Production															
Average Energy	227.00	210.60	437.60	223.90	204.00	427.90	221.00	200.00	421.00	215.40	193.30	408.70	206.50	183.00	389.50
Firm Energy	119.50	107.10	226.60	110.80	98.30	209.10	107.10	96.36	203.46	103.70	89.50	193.20	97.06	82.72	180.28
Secondary Energy	107.50	103.50	211.00	113.10	105.70	218.80	113.90	103.64	217.54	112.20	103.80	216.00	109.44	99.78	209.22
Unit Benefit Value	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Firm Peak Power	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45
Firm Energy	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270
Secondary Energy	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219
Benefit															
Firm Peak Power	8.35	8.43	16.78	7.97	7.74	15.71	7.74	7.57	15.32	7.50	7.06	14.56	7.30	6.54	13.84
Firm Energy	3.17	2.84	6.01	2.94	2.61	5.55	2.84	2.56	5.40	2.74	2.38	5.11	2.58	2.21	4.78
Secondary Energy	2.31	2.23	4.54	2.43	2.28	4.71	2.45	2.23	4.68	2.42	2.23	4.65	2.36	2.15	4.50
Total	13.83	13.50	27.34	13.34	12.63	25.97	13.04	12.36	25.40	12.66	11.67	24.32	12.23	10.90	23.13
Investment Cost															
Civil Facilities	125.49	52.20	177.70	124.42	50.77	175.19	123.35	50.70	174.04	122.15	50.11	172.25	121.01	49.45	170.45
Hydra. and Ele. Mech Eq	21.92	23.51	45.43	20.96	22.12	43.11	20.72	21.97	42.19	19.20	21.47	40.67	17.73	20.45	38.18
Total	147.41	75.71	223.13	145.38	72.88	218.30	143.94	72.67	216.23	141.35	71.58	212.93	138.73	69.89	208.63
Annual Cost															
Civil Facilities	12.67	5.27	17.95	12.57	5.13	17.89	12.48	5.12	17.58	12.34	5.08	17.40	12.27	4.99	17.22
Hydra. and Ele. Mech Eq	2.50	2.62	5.19	2.38	2.52	4.91	2.30	2.51	4.81	2.19	2.45	4.64	2.02	2.33	4.35
Total	15.17	7.96	23.13	14.96	7.65	22.61	14.78	7.63	22.39	14.53	7.51	22.03	14.29	7.33	21.57
Annual Surplus Benefit(B-C)	-1.34	5.54	4.20	-1.62	4.56	3.36	-1.72	4.74	3.01	-1.87	4.16	2.29	-2.01	3.57	1.56
Benefit Cost Ratio(B/C)	0.91	1.70	1.18	0.88	1.65	1.15	0.88	1.62	1.13	0.87	1.55	1.10	0.86	1.49	1.07
Unit Annual Cost (Firm)	0.127	0.074	0.102	0.126	0.078	0.108	0.128	0.079	0.110	0.141	0.064	0.114	0.147	0.068	0.120
Unit Annual Cost (Average)	0.067	0.038	0.053	0.067	0.037	0.053	0.067	0.038	0.053	0.067	0.038	0.054	0.069	0.040	0.055

Bayram Project Takease Undergr. P.S Layout H.W.L.=730m L.W.L.=686m-725m With Bagik H.W.L.= 530.00m						by Mixed Alternative Thermal Power Plant					
Description Dam Site	Bayram 730-720	Bagik 530C	Total	Bayram 730-725	Bagik 530C	Total					
High Water Level	730.00	530.00		730.00	530.00						
Normal Water Level	726.67	528.50		729.33	528.50						
Low Water Level	720.00	527.00		725.00	527.00						
Available Drawdown	10.00	3.00		5.00	3.00						
Gross Storage Capacity	102.00	7.30		102.00	7.30						
Effective Storage Capacity	28.00	1.00		14.00	1.00						
Dam Type	Rockfill	Con-Gra		Rockfill	Con-Gra						
Dam Height	135	74		135	74						
Dam Volume	4,800	195		4,800	195						
Tailwater Level	530.00	392.00		530.00	392.00						
Effective Head	187.07	130.80		186.53	130.50						
Maximum Discharge	26.00	32.00		23.00	29.00						
Installed Capacity	36.00	36.00	72.00	37.00	32.00	69.00					
Firm Peak Power	36.48	35.00	71.48	36.26	31.00	67.26					
Energy Production											
Average Energy	187.80	171.70	359.50	150.00	152.00	312.00					
Firm Energy	87.30	76.42	163.70	79.41	67.89	147.30					
Secondary Energy	100.50	95.30	195.80	80.59	84.11	164.70					
Unit Benefit Value											
Firm Peak Power	180.450	180.450	180.450	180.450	180.450	180.450					
Firm Energy	0.027	0.027	0.027	0.027	0.027	0.027					
Secondary Energy	0.022	0.022	0.022	0.022	0.022	0.022					
Benefit											
Firm Peak Power	6.19	6.02	12.22	6.24	5.33	11.57					
Firm Energy	2.32	2.03	4.34	2.11	1.80	3.61					
Secondary Energy	2.16	2.05	4.22	1.74	1.61	3.55					
Total	11.27	10.10	21.38	10.08	8.95	19.03					
Investment Cost											
Civil Facilities	119.96	48.78	168.77	118.34	47.61	165.95					
Hydra. and Ele. Mech Eq	17.33	19.52	36.84	16.04	18.23	34.27					
Total	137.31	68.30	205.61	134.38	65.84	200.22					
Annual Cost											
Civil Facilities	12.12	4.93	17.05	11.95	4.81	16.76					
Hydra. and Ele. Mech Eq	1.96	2.22	4.20	1.85	2.08	3.91					
Total	14.08	7.15	21.25	13.78	6.85	20.67					
Annual Surplus Benefit(B-C)	-2.82	2.95	0.13	-3.70	2.06	-1.64					
Benefit Cost Ratio(B/C)	0.90	1.41	1.01	0.73	1.30	0.92					
Unit Annual Cost (Firm)	0.161	0.054	0.130	0.174	0.101	0.140					
Unit Annual Cost (Average)	0.075	0.042	0.059	0.086	0.045	0.066					

**Table 9-13 Outline of Alternative Plan for Bağlık Reservoir Water Level**

Bayram Project Tailrace Type Underpro. P/S Layout H W L = 740m L W L = 686m With Bağlık L W L = 527-569m

Reservoir	Dam Site Layout	Bayram 740A.P	Bayram 740A.P	Bayram 740A.P	Bayram 740A	Bayram 740A
Catchment Area	KM <sup>2</sup>	1,159	1,159	1,159	1,159	1,159
Annual Inflow	M <sup>3</sup> /S	19 20	19 20	19 20	19 20	19 20
High Water Level	M	740 00	740 00	740 00	740 00	740 00
Normal Water Level	M	722 00	722 00	722 00	722 00	722 00
Low Water Level	M	686 00	686 00	686 00	686 00	686 00
Available Drawdown	M	54 00	54 00	54 00	54 00	54 00
Gross Capacity	10 <sup>6</sup> M <sup>3</sup>	133 00	133 00	133 00	133 00	133 00
Effective Capacity	10 <sup>6</sup> M <sup>3</sup>	113 00	113 00	113 00	113 00	113 00
Dam						
Type		Rockfill	Rockfill	Rockfill	Rockfill	Rockfill
Height from Found.	M	145	145	145	145	145
Crest Length	M	415	415	415	415	415
Volume	10 <sup>3</sup> M <sup>3</sup>	6,144	6,144	6,144	6,144	6,144
Headrace Tunnel						
Type						
Diameters	M					
Length	M					
Penstock						
Type		Tunnel	Tunnel	Tunnel	Tunnel	Tunnel
Diameters	M	3 3	3 3	3 3	3 3	3 3
Length	M	268	268	268	294	294
Powerhouse						
Type		Undergr.	Undergr.	Undergr.	Undergr.	Undergr.
Tailrace Tunnel						
Type		Non-Pre.	Non-Pre.	Non-Pre.	Non-Pre.	Non-Pre.
Diameters	M	4 6	4 6	4 6	4 6	4 6
Length (Tunnel)	M	4,550	4,550	4,550	6,700	6,700
(Channel)	M					
Firm Discharge	M <sup>3</sup> /S	10 70	10 70	10 70	10 70	10 70
Maximum Discharge	M <sup>3</sup> /S	43 00	43 00	43 00	43 00	43 00
Tail Water Level	M	570 00	570 00	570 00	550 00	550 00
Gross Head						
Maximum Head	M	170 00	170 00	170 00	190 00	190 00
Normal Head	M	152 00	152 00	152 00	172 00	172 00
Minimum Head	M	116 00	116 00	116 00	136 00	136 00
Loss of Head	M	6 40	6 40	6 40	8 10	8 10
Effective Head						
Maximum	M	163 60	163 60	163 60	181 90	181 90
Normal	M	145 60	145 60	145 60	163 90	163 90
Minimum	M	109 60	109 60	109 60	127 90	127 90
Installed Capacity	MW	54	54	54	60	60
Firm Peak Power	MW	44 8	44 8	44 8	51 4	51 4
Annual Energy						
Average	GWh	198 5	198 5	198 5	223 3	223 3
Firm	GWh	113 2	113 2	113 2	126 4	126 4
Secondary	GWh	85 3	85 3	85 3	57 7	57 7

Baglık Project Tailrace Type Underground Powerhouse Layout

Reservoir	Dam Site Layout	Baglık 740A.P	Baglık 740A.P	Baglık 740A.P	Baglık 740A	Baglık 740A
Catchment Area	KM <sup>2</sup>	1,509	1,509	1,509	1,509	1,509
Annual Inflow	M <sup>3</sup> /S	24 90	24 90	24 90	24 90	24 90
High Water Level	M	570 00	570 00	570 00	550 00	550 00
Normal Water Level	M	555 67	563 33	569 50	538 50	549 00
Low Water Level	M	527 00	550 00	563 00	527 00	548 00
Available Drawdown	M	43 00	20 00	1 00	23 00	2 00
Gross Capacity	10 <sup>6</sup> M <sup>3</sup>	36 40	36 40	36 40	17 70	17 70
Effective Capacity	10 <sup>6</sup> M <sup>3</sup>	30 10	18 70	1 00	14 40	1 00
Dam						
Type		Con-gra.	Con-gra.	Con-gra.	Con-gra.	Con-gra.
Height from Found.	M	114	114	114	94	94
Crest Length	M	284	284	284	240	240
Volume	10 <sup>3</sup> M <sup>3</sup>	680	630	660	420	420
Headrace Tunnel						
Type						
Diameters	M					
Length	M					
Penstock						
Type		Tunnel	Tunnel	Tunnel	Tunnel	Tunnel
Diameters	M	3 8	3 7	3 6	3 7	3 6
Length	M	213	213	213	213	213
Powerhouse						
Type		Undergr.	Undergr.	Undergr.	Undergr.	Undergr.
Tailrace Tunnel						
Type		Hosesho.	Hosesho.	Hosesho.	Hosesho.	Hosesho.
Diameters	M	5 1	5 0	4 9	5 0	4 9
Length (Tunnel)	M	4,454	4,454	4,454	4,454	4,454
(Channel)	M					
Firm Discharge	M <sup>3</sup> /S	14 30	13 80	13 00	13 50	13 00
Maximum Discharge	M <sup>3</sup> /S	57 00	55 00	52 00	54 00	52 00
Tail Water Level	M	392 00	392 00	392 00	392 00	392 00
Gross Head						
Maximum Head	M	178 00	178 00	178 00	158 00	158 00
Normal Head	M	163 67	171 33	177 50	148 50	157 00
Minimum Head	M	135 00	158 00	177 00	135 00	158 00
Loss of Head	M	5 50	5 60	5 60	5 60	5 60
Effective Head						
Maximum	M	172 50	172 40	172 40	152 40	152 40
Normal	M	158 17	165 73	171 90	140 90	151 40
Minimum	M	129 50	152 40	171 40	129 40	150 40
Installed Capacity	MW	78	79	77	66	65
Firm Peak Power	MW	67 6	75 5	75 0	59 8	67 6
Annual Energy						
Average	GWh	282 1	290 4	288 6	250 5	252 1
Firm	GWh	163 7	163 7	164 3	139 0	147 9
Secondary	GWh	118 4	126 7	124 4	111 5	104 2

**Table 9-14 Cost Estimate of Alternative Plan for Bağlık Reservoir Water Level**

Bayram Project Tailrace Type Underpro. P/S Layout H.W.L.=740m L.W.L.=586m With Bağlık L.W.L.=527-550m Unit:10<sup>3</sup>US\$

Description	Dam Site Layout Type	Bayram				
		740M.P	740M.P	740M.P	740A	740A
High Water Level (m)		740	740	740	740	740
Reservoir Area (km <sup>2</sup> )		3.38	3.38	3.38	3.38	3.38
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )		6.144	6.144	6.144	6.144	6.144
Dam Height (m)		145	145	145	145	145
Maximum Head (m)		170	170	170	190	190
Maximum Discharge (m <sup>3</sup> /s)		43	43	43	43	43
Relocation Road		11,655	11,655	11,655	11,655	11,655
Camp Facilities		800	800	800	800	800
Land Acquisition		2,242	2,242	2,242	2,242	2,242
Civil Work		78,180	78,180	78,180	80,512	80,512
Diversion		2,421	2,421	2,421	2,421	2,421
Care of River		1,082	1,082	1,082	1,082	1,082
Dam		47,281	47,281	47,281	47,281	47,281
Spillway		7,523	7,523	7,523	7,523	7,523
Outlet Works		1,018	1,018	1,018	1,018	1,018
Intake		1,087	1,087	1,087	1,087	1,087
Headrace Tunnel		0	0	0	0	0
Surge Tank		0	0	0	0	0
Penstock		377	377	377	458	458
Access Tunnels		3,980	3,980	3,980	3,980	3,980
Power House		2,664	2,664	2,664	2,856	2,856
Tailrace Tunnel		8,588	8,588	8,588	12,644	12,644
Switchyard		161	161	161	161	161
Pre-Subtotal		90,878	90,878	90,878	95,209	95,209
Contingency (15%)		13,295	13,295	13,295	13,945	13,945
Eng. and Adm. (10%)		10,193	10,193	10,193	10,691	10,691
Sub Total		114,366	114,366	114,366	119,845	119,845
I.D.C. (9.5%/Year)		22,849	22,849	22,849	23,944	23,944
Total		137,215	137,215	137,215	143,789	143,789
Hydraulic Equipment		4,385	4,385	4,385	4,779	4,779
Spillway		856	856	856	856	856
Outlet Works		528	528	528	528	528
Intake Gate		763	763	763	763	763
Penstock		1,656	1,656	1,656	2,015	2,015
Draft Gate		122	122	122	122	122
Tailrace Gate		61	61	61	61	61
Pre-Subtotal		3,936	3,936	3,936	4,345	4,345
Contingency (10%)		399	399	399	434	434
Electro-Mechanical Equipment		13,956	13,956	13,956	14,501	14,501
Equipment		13,291	13,291	13,291	13,810	13,810
Contingency (5%)		665	665	665	691	691
Eng. and Adm. (10%)		1,834	1,834	1,834	1,928	1,928
Sub Total		20,175	20,175	20,175	21,236	21,236
I.D.C. (9.5%/Year)		1,085	1,085	1,085	1,140	1,140
Total		21,259	21,259	21,259	22,348	22,348
Grand Total		158,474	158,474	158,474	166,137	166,137

Baglık Project Tailrace Type Underground Powerhouse Layout

Unit:10<sup>3</sup>US\$

Description	Dam Site Layout Type	Baglık				
		740M.P	740M.P	740M.P	740A	740A
High Water Level (m)		570	570	570	550	550
Reservoir Area (km <sup>2</sup> )		1.23	1.23	1.23	0.69	0.69
Dam Volume (10 <sup>6</sup> m <sup>3</sup> )		680	680	680	420	420
Dam Height (m)		114	114	114	94	94
Maximum Head (m)		178	178	178	158	158
Maximum Discharge (m <sup>3</sup> /s)		57	55	52	54	52
Relocation Road		9,603	9,603	9,603	8,043	8,043
Camp Facilities		800	800	800	800	800
Land Acquisition		598	598	598	598	598
Civil Work		52,185	51,810	51,402	38,098	37,783
Diversion		0	0	0	0	0
Care of River		0	0	0	0	0
Dam		34,813	34,813	34,813	21,502	21,502
Spillway		780	780	780	780	780
Outlet Works		0	0	0	0	0
Intake		121	89	25	90	34
Headrace Tunnel		0	0	0	0	0
Surge Tank		0	0	0	0	0
Penstock		530	512	485	451	435
Access Tunnels		2,478	2,478	2,478	2,478	2,478
Power House		3,582	3,582	3,906	3,641	3,641
Tailrace Tunnel		9,431	9,157	8,914	9,157	8,914
Switchyard		0	0	0	0	0
Pre-Subtotal		63,186	62,811	62,403	47,539	47,224
Contingency (15%)		9,388	9,332	9,271	7,041	6,994
Eng. and Adm. (10%)		7,198	7,155	7,108	5,396	5,362
Sub Total		79,771	79,298	78,781	59,979	59,580
I.D.C. (9.5%/Year)		19,925	19,807	19,678	14,982	14,882
Total		99,697	99,105	98,459	74,960	74,462
Hydraulic Equipment		3,913	3,681	3,269	3,432	3,097
Spillway		870	870	870	870	870
Outlet Works		0	0	0	0	0
Intake Gate		514	376	112	383	145
Penstock		1,974	1,908	1,507	1,878	1,618
Draft Gate		133	128	129	126	121
Tailrace Gate		67	65	61	63	61
Pre-Subtotal		3,558	3,346	2,971	3,120	2,815
Contingency (10%)		356	335	297	312	282
Electro-Mechanical Equipment		21,528	21,747	22,513	20,450	20,669
Equipment		20,503	20,712	21,441	19,476	19,685
Contingency (5%)		1,025	1,036	1,072	974	984
Eng. and Adm. (10%)		2,544	2,543	2,578	2,368	2,377
Sub Total		27,986	27,971	28,360	26,271	26,142
I.D.C. (9.5%/Year)		1,585	1,584	1,606	1,488	1,481
Total		29,571	29,555	29,966	27,759	27,623
Grand Total		129,268	128,660	128,426	102,719	102,085

**Table 9-15 Comparison Study on alternative Plan for Bağlık Reservoir Water Level**

Description Dam Site	Layout	By Bayram Project Tailrace Type Understudy (P.8 Level) L.W.L. T40m L.W.L. T45m L.W.L. T50m With Bağlık L.W.L. T52.50m						By Mixed Alternative Thermal Power Plant					
		Bayrak T40m/LP	Bayrak T45m/LP	Total	Bayrak T40m/LP	Bayrak T45m/LP	Total	Bayrak T40m/LP	Total	Bayrak T45m/LP	Total	Bayrak T40m/LP	Total
High Water Level	m	740.00	570.00		740.00	570.00		740.00	570.00		740.00	570.00	
Normal Water Level	m	722.00	558.87		722.00	543.33		722.00	569.50		722.00	549.00	
Low Water Level	m	698.00	527.00		698.00	550.00		698.00	589.00		698.00	548.00	
Available Drawdown	m	54.00	43.00		54.00	20.00		54.00	1.00		54.00	2.00	
Gross Storage Capacity	m <sup>3</sup> 10 <sup>6</sup>	133.00	36.40		133.00	36.40		133.00	36.40		133.00	17.70	
Effective Storage Capacity	m <sup>3</sup> 10 <sup>6</sup>	113.00	30.10		113.00	18.70		113.00	1.00		113.00	1.00	
Dam Type		Rockfill	Con-gra		Rockfill	Con-gra		Rockfill	Con-gra		Rockfill	Con-gra	
Dam Height	m	145	114		145	114		145	114		145	94	
Dam Volume	m <sup>3</sup>	8,144	640		8,144	640		8,144	640		8,144	420	
Tail Water Level	m	570.00	392.00		570.00	392.00		570.00	392.00		570.00	392.00	
Effective Head	m	145.80	158.17		145.80	183.73		145.80	171.80		145.80	143.80	
Maximum Discharge	m <sup>3</sup> /s	43.00	57.00		43.00	30.00		43.00	52.00		43.00	52.00	
Installed Capacity	MW	54.80	78.00	132.00	54.80	78.00	132.00	54.80	77.00	131.00	54.80	68.00	
Firm Peak Power	MW	64.80	67.60	112.40	64.80	75.46	120.26	64.80	75.00	110.80	64.80	67.55	
Energy Production	GWh	198.50	262.13	480.83	198.50	290.40	458.90	198.50	268.82	487.12	198.50	252.15	
Average Energy	GWh	113.20	163.70	278.90	113.20	163.70	278.90	113.20	164.25	277.45	113.20	163.40	
Firm Energy	GWh	85.30	118.43	203.73	85.30	126.70	212.00	85.30	124.57	206.87	85.30	118.40	
Secondary Energy	GWh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Unit Benefit Value	US\$/kWh	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	180.45	
Firm Peak Power	US\$/kW	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	0.0270	
Firm Energy	US\$/kWh	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	0.0219	
Secondary Energy	US\$/kWh	7.71	11.63	19.34	7.71	12.99	20.70	7.71	12.91	20.82	7.71	11.62	
Firm Peak Power	US\$/kW	3.90	4.34	7.35	3.90	4.34	7.35	3.90	4.36	7.36	3.90	4.35	
Firm Energy	US\$/kWh	1.84	2.35	4.36	1.84	2.73	4.56	1.84	2.68	4.51	1.84	2.70	
Secondary Energy	US\$/kWh	12.55	18.53	31.08	12.55	20.26	32.61	12.55	19.94	32.49	12.55	18.53	
Total	US\$/kWh	137.21	99.70	236.81	137.21	96.10	236.32	137.21	96.48	235.87	137.21	94.96	
Investment Cost	US\$/kWh	24.26	28.57	50.83	24.26	29.56	50.81	24.26	29.97	51.23	24.26	27.78	
Civil Facilities	US\$/kWh	158.47	128.21	287.74	158.47	128.66	287.13	158.47	126.43	284.90	158.47	127.62	
Hydro and Ele. Mech. Eq.	US\$/kWh	13.86	10.01	23.83	13.86	10.01	23.87	13.86	9.94	23.80	13.86	9.57	
Annual Cost	US\$/kWh	2.42	3.37	5.79	2.42	3.37	5.79	2.42	3.42	5.84	2.42	3.56	
Civil Facilities	US\$/kWh	18.28	13.44	29.72	18.28	13.38	29.88	18.28	13.36	29.84	18.28	13.07	
Hydro and Ele. Mech. Eq.	US\$/kWh	-3.73	5.06	1.96	-3.73	6.68	1.96	-3.73	6.58	1.96	-3.73	5.55	
Total	US\$/kWh	0.77	1.58	4.08	0.77	1.56	4.10	0.77	1.48	4.04	0.77	1.40	
Annual Surplus Benefit (B-C)	US\$/kWh	0.144	0.062	0.107	0.144	0.062	0.107	0.144	0.061	0.107	0.144	0.061	
Benefit Cost Ratio (B/C)	US\$/kWh	0.144	0.062	0.107	0.144	0.062	0.107	0.144	0.061	0.107	0.144	0.061	
Unit Annual Cost (Firm)	US\$/kWh	0.087	0.044	0.062	0.087	0.044	0.062	0.087	0.044	0.062	0.087	0.044	
Unit Annual Cost (Average)	US\$/kWh	0.087	0.044	0.062	0.087	0.044	0.062	0.087	0.044	0.062	0.087	0.044	

**Table 9-17 Comparison Study on Optimum Installed Capacity**

**Tailrace Type Underground Powerhouse Layout Bayram H.W.L.=735m L.W.L.=686m-730m and Baglik H.W.L.=530m**

Description Dam Site	Layout	Bayram 6h Peak	Baglik 6h Peak	Total 6h Peak	Bayram 8h Peak	Baglik 8h Peak	Total 8h Peak
High Water Level	m	740.00	530.00		740.00	530.00	
Normal Water Level	m	722.00	528.50		722.00	528.50	
Low Water Level	m	686.00	527.00		686.00	527.00	
Available Drawdown	m	54.00	3.00		54.00	3.00	
Gross Storage Capacity	m <sup>3</sup> *10 <sup>6</sup>	150.00	7.30		133.00	7.30	
Effective Storage Capacity	m <sup>3</sup> *10 <sup>6</sup>	130.00	1.00		113.00	1.00	
Dam Type		0 Rockfill	Con-Gra.		Rockfill	Con-Gra.	
Dam Hight	m	145	74		145	74	
Dam Volume	m <sup>3</sup>	6,144	195		6,144	195	
Tailwater Level	m	530.00	392.00		530.00	392.00	
Effective Head	m	182.90	130.90		182.60	130.70	
Maximum Discharge	m <sup>3</sup> /s	43.00	52.00		32.00	39.00	
Installed Capacity	MW	68.00	59.00	127.00	50.00	44.00	94.00
Firm Peak Power	MW	58.00	56.40	114.40	43.10	41.60	84.70
Energy Production							
Average Energy	GWh	247.90	221.40	469.30	225.59	201.47	427.06
Firm Energy	GWh	141.40	124.20	265.60	141.40	124.20	265.60
Secondary Energy	GWh	106.50	97.20	203.70	84.19	77.27	161.46
Unit Benefit Value		0.00	0.00		0.00	0.00	
Firm Peak Power	US\$/kW	180.45	180.45		180.45	180.45	
Firm Energy	US\$/kWh	0.027	0.027		0.027	0.027	
Secondary Energy	US\$/kWh	0.022	0.022		0.022	0.022	
Benefit							
Firm Peak Power	US\$*10 <sup>6</sup>	9.98	9.71	19.69	7.42	7.16	14.58
Firm Energy	US\$*10 <sup>6</sup>	3.75	3.30	7.05	3.75	3.30	7.05
Secondary Energy	US\$*10 <sup>6</sup>	2.29	2.09	4.39	1.81	1.66	3.48
Total	US\$*10 <sup>6</sup>	16.03	15.09	31.12	12.98	12.12	25.10
Investment Cost							
Civil Facilities	US\$*10 <sup>6</sup>	147.74	53.78	201.51	146.60	49.07	195.67
Hydrau. and Ele.-Mech Eq.	US\$*10 <sup>6</sup>	24.32	25.69	50.01	20.06	22.21	42.27
Total	US\$*10 <sup>6</sup>	172.06	79.46	251.52	166.66	71.28	237.93
Annual Cost							
Civil Facilities	US\$*10 <sup>6</sup>	14.92	5.43	20.35	14.81	4.96	19.76
Hydrau. and Ele.-Mech Eq.	US\$*10 <sup>6</sup>	2.77	2.93	5.70	2.29	2.53	4.82
Total	US\$*10 <sup>6</sup>	17.69	8.36	26.05	17.09	7.49	24.58
Annual Surplus Benefit(B-C)	US\$*10 <sup>6</sup>	-1.67	6.74	5.07	-4.11	4.63	0.52
Benefit Cost Ratio(B/C)		0.91	1.81	1.19	0.76	1.62	1.02
Unit Annual Cost (Firm)	US\$/kWh	0.125	0.067	0.098	0.121	0.060	0.093
Unit Annual Cost (Average)	US\$/kWh	0.071	0.038	0.058	0.076	0.037	0.058



Table 9-18 Outline of Optimum Development Plan of Çoruh-Berta Project

	Unit	Bayram Project	Bağlık Project	Total
<b>Reservoir</b>				
Catchment Area	km <sup>2</sup>	1,159	1,509	
Annual Inflow	m <sup>3</sup> /s	19.20	24.90	
High Water Level	m	740.00	530.00	
Normal Water Level	m	722.00	528.50	
Low Water Level	m	686.00	527.00	
Available Drawdown	m	54.00	3.00	
Gross Capacity	10 <sup>6</sup> m <sup>3</sup>	133.00	7.30	
Effective Capacity	10 <sup>6</sup> m <sup>3</sup>	113.00	1.00	
Surface Area	10 <sup>6</sup> m <sup>2</sup>	3.38	0.37	
<b>Dam</b>				
Type		Rockfill	Con-Gra	
Height from Foundation	m	145	74	
Crest Length	m	415	190	
Volume	10 <sup>3</sup> m <sup>3</sup>	6,147	195	
<b>Penstock</b>				
Type		Tunnel	Tunnel	
Diameters	m	3.3	3.6	
Length	m	321	213	
<b>Powerhouse</b>				
Type		Underground	Underground	
<b>Tailrace Tunnel</b>				
Type		Horseshoe	Horseshoe	
Diameters	m	4.6	4.9	
Length (Tunnel)	m	7,930	4,454	
Tail Water Level	m	530.00	392.00	
<b>Gross Head</b>				
Maximum Head	m	210.00	138.00	
Normal Head	m	192.00	136.50	
Minimum Head	m	156.00	135.00	
Loss of Head	m	9.10	5.60	
<b>Effective Head</b>				
Maximum	m	200.90	132.40	
Normal	m	182.90	130.90	
Minimum	m	146.90	129.40	
Firm Discharge	m <sup>3</sup> /s	10.70	13.00	
Maximum Discharge	m <sup>3</sup> /s	43.00	52.00	
Installed Capacity	MW	68	59	127
Number of Unit		1	1	
Firm Peak Power	MW	57.60	56.2	113.8
<b>Annual Energy</b>				
Average	GWh	250.4	225.8	476.2
Firm	GWh	144.9	128.4	273.3
Secondary	GWh	105.5	97.5	203.0
Investment Cost	(10 <sup>6</sup> US\$)	172.1	79.5	251.5
Annual Surplus Benefit	(10 <sup>6</sup> US\$)	-1.66	6.82	5.15
Benefit - Cost Ratio		0.91	1.82	1.20
Unit Energy Cost	(US\$/kWh)	0.071	0.037	0.055

**Table 9-19 Cost Estimate of Optimum Development Plan of Çoruh-Berta Project**

Unit: 10<sup>3</sup>US\$

Description	Bayram Project	Bağlık Project	Total
Relocation Road	11,655	6,759	
Camp Facilities	800	800	
Land Acquisition	2,242	598	
Civil Work	83,113	25,984	
Diversion	2,421	0	
Care of River	1,082	0	
Dam	47,281	9,983	
Spillway	7,523	780	
Outlet Works	1,018	0	
Intake <sup>*-1</sup>	1,087	40	
Headrace Tunnel	0	0	
Surge Tank	0	0	
Penstock <sup>*-2</sup>	546	376	
Access Tunnels <sup>*-3</sup>	3,980	2,478	
Power House <sup>*-4</sup>	3,049	3,413	
Tailrace	14,965	8,914	
Switchyard	161	0	
Pre-Subtotal	97,810	34,141	
Contingency (15%)	14,335	5,031	
Eng. and Admi. (10%)	10,990	3,857	
Sub Total	123,136	43,030	
I.D.C. (9.5%/year)	24,601	10,748	
Total	147,737	58,778	206,515
Hydraulic Equip.	5,203	2,884	
Spillway	856	870	
Outlet Works	528	0	
Intake Gate	763	170	
Penstock	2,400	1,400	
Draft Gate	122	121	
Tailrace Gate	61	61	
Pre-Subtotal	4,730	2,622	
Contingency (10%)	473	262	
Electro-Mechanical Equip. <sup>*-5</sup>	15,780	19,216	
Equipment	15,027	18,301	
Contingency (5%)	751	915	
Eng. And Admi. (10%)	2,098	2,210	
Sub Total	23,082	24,310	
I.D.C. (9.5%/year)	1,241	1,377	
Total	24,323	25,867	50,190
Grand Total	172,060	79,464	251,524

\*-1: including Intake Adit

\*-2: including Penstock Adit

\*-3: including Cable Tunnel and Tailrace Adit

\*-4: including Drainage Tunnel, Surge Chamber and Surge Chamber Access Tunnel

\*-5: including Transmission Line

**Table 9-20 Reservoir Operation of Bayram Project**

Unit 10<sup>6</sup>m<sup>3</sup>

	Year	Inflow	Evaporation	Power Discharge	Environment Discharge	Spill	Total Outflow
1	1942	998.64	2.82	719.10	3.97	243.33	969.22
2	1943	549.41	2.73	551.56	3.97	0.00	558.27
3	1944	803.53	2.70	636.47	3.97	154.57	797.71
4	1945	457.91	2.65	468.71	3.97	0.00	475.32
5	1946	525.01	2.58	502.90	3.97	0.00	509.46
6	1947	406.79	2.57	430.93	3.97	0.00	437.47
7	1948	512.54	2.51	486.49	3.97	0.00	492.98
8	1949	389.08	2.49	397.35	3.97	0.00	403.82
9	1950	464.57	2.46	450.70	3.97	0.00	457.13
10	1951	458.18	2.57	442.51	3.97	0.00	449.05
11	1952	557.13	2.68	552.22	3.97	0.00	558.87
12	1953	463.30	2.54	450.80	3.97	0.00	457.31
13	1954	628.09	2.66	598.47	3.97	19.74	624.83
14	1955	296.56	2.39	338.58	3.97	0.00	344.94
15	1956	421.05	2.35	382.20	3.97	0.00	388.52
16	1957	478.52	2.49	470.73	3.97	0.00	477.19
17	1958	471.40	2.52	464.70	3.97	0.00	471.18
18	1959	552.19	2.56	534.24	3.97	0.00	540.77
19	1960	895.78	2.83	712.87	3.97	173.19	892.86
20	1961	369.76	2.48	404.57	3.97	0.00	411.02
21	1962	551.52	2.42	518.96	3.97	0.00	525.36
22	1963	914.65	2.65	666.12	3.97	223.16	895.90
23	1964	617.20	2.67	599.86	3.97	24.67	631.17
24	1965	643.13	2.64	651.25	3.97	1.82	659.68
25	1966	614.92	2.61	595.66	3.97	7.20	609.44
26	1967	571.85	2.51	523.54	3.97	14.44	544.46
27	1968	1,139.87	2.85	740.53	3.97	389.40	1,136.75
28	1969	571.95	2.65	578.12	3.97	24.88	609.62
29	1970	476.69	2.55	461.20	3.97	0.00	467.72
30	1971	600.41	2.66	583.48	3.97	0.00	590.11
31	1972	642.03	2.67	614.86	3.97	12.66	634.16
32	1973	567.68	2.63	573.73	3.97	3.29	583.62
33	1974	472.67	2.50	465.15	3.97	0.00	471.63
34	1975	519.29	2.50	517.89	3.97	0.00	524.36
35	1976	690.13	2.56	597.28	3.97	72.54	676.35
36	1977	535.96	2.64	532.77	3.97	0.00	539.38
37	1978	683.62	2.64	618.08	3.97	54.10	678.78
38	1979	618.21	2.63	603.55	3.97	14.11	624.26
39	1980	635.32	2.69	592.24	3.97	39.33	638.23
40	1981	579.29	2.60	524.79	3.97	38.54	569.90
41	1982	455.55	2.63	454.67	3.97	0.00	461.27
42	1983	583.47	2.57	595.99	3.97	0.00	602.53
43	1984	552.32	2.56	530.36	3.97	0.00	536.90
44	1985	577.63	2.55	523.51	3.97	54.25	584.28
45	1986	677.79	2.64	646.56	3.97	26.28	679.45
46	1987	720.80	2.60	570.16	3.97	131.83	708.55
47	1988	975.42	2.77	700.15	3.97	245.93	952.83
48	1989	992.47	2.87	698.96	3.97	320.75	1,026.55
49	1990	593.79	2.51	560.00	3.97	24.35	590.83
50	1991	524.41	2.56	519.39	3.97	0.00	525.92
51	1992	643.85	2.48	560.75	3.97	61.61	628.80
52	1993	861.65	2.82	685.73	3.97	172.86	865.37
53	1994	601.54	2.70	605.54	3.97	1.95	614.15
	Total	32,106.39	138.15	29,206.82	210.64	2,550.77	32,106.37
	Ave.	605.78	2.61	551.07	3.97	48.13	605.78
	Max.	1,139.87	2.87	740.53	3.97	389.40	1,136.75
	Min.	296.56	2.35	338.58	3.97	0.00	344.94

Table 9-21 Total Energy Production of Bayram Project

Unit: GWh

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1	1942	13.12	16.85	16.39	14.46	27.76	46.05	48.96	50.59	48.96	27.83	14.00	13.34	338.31
2	1943	13.72	13.31	15.18	13.79	19.37	33.09	31.46	38.09	32.04	20.46	13.79	13.21	255.53
3	1944	13.46	12.88	13.19	13.02	11.60	33.18	30.58	50.59	48.96	38.55	13.82	13.30	293.14
4	1945	13.58	12.98	13.22	12.91	11.32	12.30	22.02	32.56	38.01	19.55	13.73	13.03	215.19
5	1946	13.13	12.40	12.43	12.04	10.50	11.28	19.93	37.06	44.95	25.24	14.77	13.29	227.04
6	1947	13.64	13.16	13.42	13.18	12.12	35.94	27.95	12.86	13.08	13.69	13.49	12.71	195.23
7	1948	12.76	12.16	12.39	12.01	10.48	11.16	19.67	36.45	46.94	16.97	13.75	13.05	217.81
8	1949	13.26	12.56	12.63	12.12	10.43	11.10	11.13	28.08	25.74	13.77	13.57	12.81	177.19
9	1950	12.87	12.03	11.89	11.22	9.40	10.03	20.88	36.45	26.73	18.00	13.72	12.99	196.19
10	1951	13.15	12.55	12.71	12.32	11.09	11.51	23.18	24.27	34.41	17.23	13.73	13.10	199.23
11	1952	13.51	13.15	13.50	13.30	11.85	28.32	40.79	32.92	35.03	23.95	13.76	13.11	253.19
12	1953	13.22	12.45	12.43	11.85	10.14	10.57	11.28	34.87	37.39	20.72	13.76	13.18	201.87
13	1954	13.40	12.72	12.85	12.44	10.87	12.77	40.24	50.59	48.96	31.32	13.81	13.25	273.21
14	1955	13.47	12.78	12.90	12.48	11.18	11.52	11.33	12.80	13.09	13.55	13.18	12.27	150.54
15	1956	12.01	10.87	9.99	3.78	5.37	7.45	10.89	23.29	36.03	19.30	13.71	12.99	165.69
16	1957	13.05	12.21	12.03	11.28	9.41	10.38	17.68	33.53	41.73	19.94	13.72	13.01	207.97
17	1958	13.10	12.33	12.33	11.78	10.09	10.87	19.90	34.87	37.39	17.49	13.70	13.00	206.84
18	1959	13.12	12.37	12.40	11.94	10.66	11.16	24.02	45.95	67.93	23.69	13.79	13.20	240.23
19	1960	13.50	12.99	13.27	13.22	23.86	50.59	68.94	50.59	48.96	32.09	14.00	13.28	335.32
20	1961	13.46	12.75	12.84	12.34	10.57	11.22	20.37	22.57	24.74	13.72	13.39	12.47	180.45
21	1962	12.27	11.22	11.06	10.43	6.80	10.85	38.07	42.78	37.02	18.39	13.70	12.98	225.58
22	1963	13.10	12.38	12.44	12.07	10.97	11.57	47.62	50.59	48.96	50.59	21.36	13.31	304.98
23	1964	13.58	12.95	13.14	12.85	11.34	20.89	43.98	50.59	48.96	18.91	13.73	13.07	273.99
24	1965	13.37	12.85	13.19	13.06	11.57	38.03	47.40	50.59	48.96	21.75	13.66	12.81	297.24
25	1966	13.00	12.67	13.09	12.95	11.65	29.32	40.68	50.59	43.45	17.36	13.67	12.88	271.32
26	1967	12.88	11.89	11.56	10.63	4.98	9.06	12.48	50.59	44.58	36.87	15.14	13.33	234.02
27	1968	13.63	13.06	18.84	16.01	25.36	49.14	48.96	50.59	48.96	34.80	16.06	13.36	348.79
28	1969	13.75	13.22	13.56	13.34	11.76	30.36	45.40	50.59	31.95	13.76	13.51	12.71	263.90
29	1970	13.02	12.80	12.82	12.55	11.13	21.67	42.33	24.15	15.32	13.77	13.57	12.86	205.81
30	1971	13.26	12.90	13.24	13.04	12.03	36.43	28.17	50.59	45.23	16.84	13.80	13.16	266.69
31	1972	13.29	12.66	12.94	12.75	11.25	18.89	48.69	50.59	48.96	25.24	13.75	13.18	282.20
32	1973	13.48	12.90	13.13	12.83	11.40	21.00	29.26	48.39	48.96	24.47	13.71	12.97	262.50
33	1974	13.05	12.38	12.53	12.11	10.44	11.50	17.78	49.60	28.84	13.76	13.51	12.85	208.35
34	1975	13.05	12.26	12.20	11.64	10.31	10.88	43.87	36.45	36.40	14.00	13.66	12.87	227.59
35	1976	13.00	12.31	12.28	11.75	10.14	11.15	41.14	50.59	48.96	29.76	13.75	13.12	267.96
36	1977	13.43	12.92	13.15	12.86	11.30	17.39	29.15	46.44	40.12	19.88	13.73	13.08	243.24
37	1978	13.26	12.64	12.79	12.38	10.90	19.34	44.74	50.59	48.96	26.21	13.79	13.17	280.79
38	1979	13.35	12.65	12.84	12.62	11.68	22.35	34.09	50.59	48.96	29.12	13.76	13.08	275.08
39	1980	13.21	12.75	13.26	13.16	11.72	34.07	48.96	50.59	34.20	13.83	13.71	13.00	272.45
40	1981	13.14	12.51	12.71	12.39	10.84	12.08	23.99	38.77	48.96	26.66	13.78	13.14	238.96
41	1982	13.36	12.73	13.01	12.85	11.40	17.08	32.23	31.95	17.68	16.97	13.75	13.08	206.08
42	1983	13.27	12.70	12.85	12.44	11.23	20.78	46.60	50.59	46.53	15.29	13.62	12.72	268.64
43	1984	12.78	12.40	12.85	12.56	11.02	25.18	34.86	38.16	29.33	22.40	13.74	13.03	238.31
44	1985	13.02	12.17	12.07	11.43	9.72	11.02	48.96	50.59	25.82	13.74	13.47	12.77	234.79
45	1986	13.20	12.87	13.24	13.07	11.67	34.16	47.86	50.59	48.96	24.47	13.65	12.84	298.58
46	1987	12.90	12.10	11.96	11.37	10.69	11.83	48.96	50.59	48.96	13.75	13.55	12.96	259.62
47	1988	13.24	12.61	12.80	12.57	11.32	45.67	48.96	50.59	48.96	34.42	17.74	15.32	324.20
48	1989	22.74	19.18	17.29	13.79	21.09	50.59	48.96	50.59	48.96	15.42	13.64	12.83	335.09
49	1990	12.92	12.15	12.08	11.40	9.57	10.82	37.69	50.59	43.45	21.23	13.67	12.90	248.49
50	1991	13.02	12.52	12.88	12.58	11.41	30.86	46.49	22.12	28.09	15.16	13.69	12.90	231.71
51	1992	12.88	11.93	11.71	11.01	8.81	9.99	34.69	45.22	48.96	23.30	13.77	13.15	245.43
52	1993	15.98	24.68	13.78	13.68	16.39	39.99	48.96	50.59	48.96	22.66	13.74	13.08	322.49
53	1994	13.22	12.78	13.33	13.24	11.89	45.12	48.96	50.59	30.57	13.79	13.62	12.86	279.97
TOTAL		711.20	688.07	688.61	654.88	631.84	1167.52	1832.16	2224.02	2093.02	1147.44	742.17	691.99	13272.91
AVE		13.42	12.98	12.99	12.36	11.92	22.03	34.57	41.96	39.49	21.65	14.00	13.06	250.43
MAX		22.74	24.68	18.84	16.01	27.76	50.59	48.96	50.59	48.96	50.59	21.36	15.32	348.79
MIN		12.01	10.87	9.99	3.78	4.98	7.45	10.89	12.80	13.08	13.55	13.18	12.27	150.54

Table 9-22 Firm Energy Production of Bayram Project

Unit: GWh

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1	1942	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
2	1943	12.65	12.24	12.65	12.65	11.83	12.65	11.62	12.65	12.24	12.65	12.65	12.24	148.71
3	1944	12.65	12.24	12.65	12.65	11.42	12.35	11.62	12.65	12.24	12.65	12.65	12.24	148.00
4	1945	12.65	12.24	12.65	12.65	11.32	11.98	11.62	12.65	12.24	12.65	12.65	12.24	147.53
5	1946	12.65	12.24	12.42	11.87	10.18	10.79	11.16	12.65	12.24	12.65	12.65	12.24	143.73
6	1947	12.65	12.24	12.65	12.65	11.83	12.42	11.62	12.65	12.24	12.65	12.65	12.24	148.47
7	1948	12.65	12.16	12.36	11.82	10.15	10.63	11.00	12.65	12.24	12.65	12.65	12.24	143.20
8	1949	12.65	12.24	12.63	11.97	10.09	10.55	10.75	12.65	12.24	12.65	12.65	12.24	143.29
9	1950	12.65	12.00	11.84	10.71	8.68	9.11	10.61	12.65	12.24	12.65	12.65	12.24	137.82
10	1951	12.65	12.24	12.65	12.25	10.85	11.11	11.29	12.65	12.24	12.65	12.65	12.24	145.46
11	1952	12.65	12.24	12.65	12.65	11.42	12.62	11.62	12.65	12.24	12.65	12.65	12.24	148.27
12	1953	12.65	12.24	12.42	11.59	9.69	9.83	10.68	12.65	12.24	12.65	12.65	12.24	141.53
13	1954	12.65	12.24	12.65	12.43	10.70	11.64	11.62	12.65	12.24	12.65	12.65	12.24	146.34
14	1955	12.65	12.24	12.65	12.48	10.98	11.13	11.02	12.65	12.24	12.65	12.65	12.24	146.34
15	1956	11.79	10.37	9.47	3.78	5.37	7.45	10.42	12.65	12.24	12.65	12.65	12.24	121.07
16	1957	12.65	12.21	11.85	10.79	8.70	9.58	10.91	12.65	12.24	12.65	12.65	12.24	139.11
17	1958	12.65	12.24	12.27	11.49	9.62	10.23	10.99	12.65	12.24	12.65	12.65	12.24	141.92
18	1959	12.65	12.24	12.37	11.72	10.25	10.83	11.20	12.65	12.24	12.65	12.65	12.24	143.47
19	1960	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
20	1961	12.65	12.24	12.65	12.29	10.28	10.71	11.08	12.65	12.24	12.65	12.65	12.24	144.31
21	1962	12.16	10.85	10.49	9.64	6.80	10.22	11.46	12.65	12.24	12.65	12.65	12.24	136.04
22	1963	12.65	12.24	12.43	11.90	10.68	11.21	11.91	12.65	12.24	12.65	12.65	12.24	145.45
23	1964	12.65	12.24	12.65	12.65	11.34	12.02	11.62	12.65	12.24	12.65	12.65	12.24	147.59
24	1965	12.65	12.24	12.65	12.65	11.42	12.26	11.66	12.65	12.24	12.65	12.65	12.24	148.15
25	1966	12.65	12.24	12.65	12.65	11.42	12.47	11.62	12.65	12.24	12.65	12.65	12.24	148.11
26	1967	12.65	11.80	11.19	9.92	4.98	9.06	10.49	12.65	12.24	12.65	12.65	12.24	132.50
27	1968	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
28	1969	12.65	12.24	12.65	12.65	11.42	12.44	11.62	12.65	12.24	12.65	12.65	12.24	148.09
29	1970	12.65	12.24	12.65	12.55	11.08	11.94	11.62	12.65	12.24	12.65	12.65	12.24	147.15
30	1971	12.65	12.24	12.65	12.65	11.83	12.38	11.62	12.65	12.24	12.65	12.65	12.24	148.43
31	1972	12.65	12.24	12.65	12.65	11.25	11.97	12.17	12.65	12.24	12.65	12.65	12.24	148.01
32	1973	12.65	12.24	12.65	12.65	11.40	12.18	11.62	12.65	12.24	12.65	12.65	12.24	147.80
33	1974	12.65	12.24	12.53	11.95	10.10	11.10	11.48	12.65	12.24	12.65	12.65	12.24	144.48
34	1975	12.65	12.24	12.09	11.29	9.76	10.25	11.10	12.65	12.24	12.65	12.65	12.24	141.81
35	1976	12.65	12.24	12.20	11.45	9.68	10.63	11.26	12.65	12.24	12.65	12.65	12.24	142.52
36	1977	12.65	12.24	12.65	12.65	11.30	11.99	11.62	12.65	12.24	12.65	12.65	12.24	147.52
37	1978	12.65	12.24	12.65	12.35	10.75	11.75	11.62	12.65	12.24	12.65	12.65	12.24	146.43
38	1979	12.65	12.24	12.65	12.62	11.68	12.09	11.62	12.65	12.24	12.65	12.65	12.24	147.97
39	1980	12.65	12.24	12.65	12.65	11.42	12.46	12.24	12.65	12.24	12.65	12.65	12.24	148.73
40	1981	12.65	12.24	12.65	12.38	10.67	11.61	11.62	12.65	12.24	12.65	12.65	12.24	146.22
41	1982	12.65	12.24	12.65	12.65	11.40	12.09	11.62	12.65	12.24	12.65	12.65	12.24	147.72
42	1983	12.65	12.24	12.65	12.43	11.04	11.57	11.66	12.65	12.24	12.65	12.65	12.24	146.67
43	1984	12.65	12.24	12.65	12.56	10.92	11.76	11.62	12.65	12.24	12.65	12.65	12.24	146.82
44	1985	12.65	12.17	11.90	11.00	9.11	10.45	12.24	12.65	12.24	12.65	12.65	12.24	141.94
45	1986	12.65	12.24	12.65	12.65	11.42	12.44	11.97	12.65	12.24	12.65	12.65	12.24	148.45
46	1987	12.65	12.10	11.75	10.92	10.29	11.57	12.24	12.65	12.24	12.65	12.65	12.24	143.94
47	1988	12.65	12.24	12.65	12.57	11.32	12.20	12.24	12.65	12.24	12.65	12.65	12.24	148.28
48	1989	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
49	1990	12.65	12.15	11.91	10.97	8.92	10.17	11.24	12.65	12.24	12.65	12.65	12.24	140.43
50	1991	12.65	12.24	12.65	12.58	11.30	11.77	11.63	12.65	12.24	12.65	12.65	12.24	147.23
51	1992	12.65	11.86	11.39	10.43	8.43	9.06	10.66	12.65	12.24	12.65	12.65	12.24	136.90
52	1993	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
53	1994	12.65	12.24	12.65	12.65	11.42	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
TOTAL		668.99	644.00	655.31	632.93	555.06	604.39	611.51	670.34	648.72	670.34	670.34	648.72	7680.62
AVE		12.62	12.15	12.38	11.94	10.47	11.40	11.54	12.65	12.24	12.65	12.65	12.24	144.92
MAX		12.65	12.24	12.65	12.65	11.83	12.65	12.24	12.65	12.24	12.65	12.65	12.24	148.92
MIN		11.79	10.37	9.47	3.78	4.98	7.45	10.42	12.65	12.24	12.65	12.65	12.24	121.07

Table 9-23 Peak Power of Bayram Project

Unit: MW

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< AVE >
1	1942	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00
2	1943	68.00	68.00	68.00	68.00	68.00	68.00	64.54	68.00	68.00	68.00	68.00	68.00	67.72
3	1944	68.00	68.00	68.00	68.00	68.00	66.39	64.54	68.00	68.00	68.00	68.00	68.00	67.58
4	1945	68.00	68.00	68.00	68.00	67.39	64.41	64.54	68.00	68.00	68.00	68.00	68.00	67.36
5	1946	68.00	68.00	68.76	63.79	60.61	58.02	61.98	68.00	68.00	68.00	68.00	68.00	66.83
6	1947	68.00	68.00	68.00	68.00	68.00	66.76	64.54	68.00	68.00	68.00	68.00	68.00	67.61
7	1948	68.00	67.56	66.46	63.56	60.42	57.15	61.12	68.00	68.00	68.00	68.00	68.00	65.39
8	1949	68.00	68.00	67.88	64.36	60.04	56.71	59.73	68.00	68.00	68.00	68.00	68.00	65.43
9	1950	68.00	66.68	62.57	57.58	51.44	48.99	58.92	68.00	68.00	68.00	68.00	68.00	62.93
10	1951	68.00	68.00	68.00	65.88	62.35	59.75	62.70	68.00	68.00	68.00	68.00	68.00	66.24
11	1952	68.00	68.00	68.00	68.00	68.00	67.83	64.54	68.00	68.00	68.00	68.00	68.00	67.70
12	1953	68.00	68.00	68.00	66.76	62.34	57.69	59.35	68.00	68.00	68.00	68.00	68.00	64.62
13	1954	68.00	68.00	68.00	66.81	63.69	62.56	64.54	68.00	68.00	68.00	68.00	68.00	66.82
14	1955	68.00	68.00	68.00	67.11	63.12	59.81	61.22	68.00	68.00	68.00	68.00	68.00	66.29
15	1956	63.37	57.59	50.89	20.31	31.98	40.07	57.90	68.00	68.00	68.00	68.00	68.00	55.28
16	1957	68.00	67.82	63.69	58.02	51.76	51.51	60.61	68.00	68.00	68.00	68.00	68.00	63.52
17	1958	68.00	68.00	66.94	61.78	57.27	55.02	61.08	68.00	68.00	68.00	68.00	68.00	64.80
18	1959	68.00	68.00	66.48	63.00	58.91	57.15	62.21	68.00	68.00	68.00	68.00	68.00	65.33
19	1960	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00
20	1961	68.00	68.00	68.00	66.05	61.17	57.60	61.55	68.00	68.00	68.00	68.00	68.00	65.90
21	1962	65.36	60.29	56.39	51.85	40.49	54.94	63.65	68.00	68.00	68.00	68.00	68.00	41.21
22	1963	68.00	68.00	66.85	63.97	61.40	60.25	66.10	68.00	68.00	68.00	68.00	68.00	66.23
23	1964	68.00	68.00	68.00	68.00	67.48	64.64	64.54	68.00	68.00	68.00	68.00	68.00	67.39
24	1965	68.00	68.00	68.00	68.00	68.00	65.89	65.87	68.00	68.00	68.00	68.00	68.00	67.65
25	1966	68.00	68.00	68.00	68.00	68.00	67.02	64.54	68.00	68.00	68.00	68.00	68.00	67.63
26	1967	68.00	65.57	60.14	53.32	28.61	48.71	58.25	68.00	68.00	68.00	68.00	68.00	40.36
27	1968	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00
28	1969	68.00	68.00	68.00	68.00	68.00	66.88	64.54	68.00	68.00	68.00	68.00	68.00	67.62
29	1970	68.00	68.00	68.00	67.48	65.96	64.19	64.54	68.00	68.00	68.00	68.00	68.00	67.19
30	1971	68.00	68.00	68.00	68.00	68.00	68.00	66.54	68.00	68.00	68.00	68.00	68.00	67.59
31	1972	68.00	68.00	68.00	68.00	66.97	64.38	67.66	68.00	68.00	68.00	68.00	68.00	67.58
32	1973	68.00	68.00	68.00	68.00	67.84	65.46	64.54	68.00	68.00	68.00	68.00	68.00	67.49
33	1974	68.00	68.00	67.39	64.26	60.12	59.68	63.80	68.00	68.00	68.00	68.00	68.00	65.97
34	1975	68.00	68.00	64.99	60.72	56.10	55.09	61.69	68.00	68.00	68.00	68.00	68.00	66.57
35	1976	68.00	68.00	65.60	61.54	57.63	57.12	62.54	68.00	68.00	68.00	68.00	68.00	65.08
36	1977	68.00	68.00	68.00	68.00	67.26	64.48	64.54	68.00	68.00	68.00	68.00	68.00	67.36
37	1978	68.00	68.00	68.00	68.40	64.01	63.16	64.54	68.00	68.00	68.00	68.00	68.00	66.86
38	1979	68.00	68.00	68.00	67.24	67.12	65.02	64.54	68.00	68.00	68.00	68.00	68.00	67.38
39	1980	68.00	68.00	68.00	68.00	68.00	66.98	68.00	68.00	68.00	68.00	68.00	68.00	67.91
40	1981	68.00	68.00	68.00	66.46	63.49	62.44	64.54	68.00	68.00	68.00	68.00	68.00	66.77
41	1982	68.00	68.00	68.00	68.00	67.84	65.01	64.54	68.00	68.00	68.00	68.00	68.00	67.45
42	1983	68.00	68.00	68.00	68.84	63.47	62.20	64.80	68.00	68.00	68.00	68.00	68.00	66.79
43	1984	68.00	68.00	68.00	67.53	64.97	63.24	64.54	68.00	68.00	68.00	68.00	68.00	67.04
44	1985	68.00	67.63	64.00	59.16	54.20	56.16	68.00	68.00	68.00	68.00	68.00	68.00	66.81
45	1986	68.00	68.00	68.00	68.00	68.00	66.91	66.50	68.00	68.00	68.00	68.00	68.00	67.78
46	1987	68.00	67.20	63.15	58.69	59.15	62.23	68.00	68.00	68.00	68.00	68.00	68.00	65.55
47	1988	68.00	68.00	68.00	67.59	67.37	65.57	68.00	68.00	68.00	68.00	68.00	68.00	67.71
48	1989	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00
49	1990	68.00	67.52	64.05	58.96	53.07	54.68	62.43	68.00	68.00	68.00	68.00	68.00	64.12
50	1991	68.00	68.00	68.00	67.61	64.97	63.27	64.59	68.00	68.00	68.00	68.00	68.00	67.05
51	1992	68.00	65.90	61.21	56.07	50.17	48.72	59.21	68.00	68.00	68.00	68.00	68.00	62.51
52	1993	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00
53	1994	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00
	AVE	67.86	67.50	66.48	64.21	61.81	61.31	64.10	68.00	68.00	68.00	68.00	68.00	66.13
	MAX	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00	68.00
	MIN	63.37	57.59	50.89	20.31	28.61	40.07	57.90	68.00	68.00	68.00	68.00	68.00	55.28

Table 9-24(1) Peak Power Duration of Bayram Project

No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)		
1	68.00	41	68.00	81	68.00	121	68.00	161	68.00	201	68.00	241	68.00	281	68.00	321	68.00	361	68.00	401	68.00
2	68.00	42	68.00	82	68.00	122	68.00	162	68.00	202	68.00	242	68.00	282	68.00	322	68.00	362	68.00	402	68.00
3	68.00	43	68.00	83	68.00	123	68.00	163	68.00	203	68.00	243	68.00	283	68.00	323	68.00	363	68.00	403	68.00
4	68.00	44	68.00	84	68.00	124	68.00	164	68.00	204	68.00	244	68.00	284	68.00	324	68.00	364	68.00	404	68.00
5	68.00	45	68.00	85	68.00	125	68.00	165	68.00	205	68.00	245	68.00	285	68.00	325	68.00	365	68.00	405	68.00
6	68.00	46	68.00	86	68.00	126	68.00	166	68.00	206	68.00	246	68.00	286	68.00	326	68.00	366	68.00	406	68.00
7	68.00	47	68.00	87	68.00	127	68.00	167	68.00	207	68.00	247	68.00	287	68.00	327	68.00	367	68.00	407	68.00
8	68.00	48	68.00	88	68.00	128	68.00	168	68.00	208	68.00	248	68.00	288	68.00	328	68.00	368	68.00	408	68.00
9	68.00	49	68.00	89	68.00	129	68.00	169	68.00	209	68.00	249	68.00	289	68.00	329	68.00	369	68.00	409	68.00
10	68.00	50	68.00	90	68.00	130	68.00	170	68.00	210	68.00	250	68.00	290	68.00	330	68.00	370	68.00	410	68.00
11	68.00	51	68.00	91	68.00	131	68.00	171	68.00	211	68.00	251	68.00	291	68.00	331	68.00	371	68.00	411	68.00
12	68.00	52	68.00	92	68.00	132	68.00	172	68.00	212	68.00	252	68.00	292	68.00	332	68.00	372	68.00	412	68.00
13	68.00	53	68.00	93	68.00	133	68.00	173	68.00	213	68.00	253	68.00	293	68.00	333	68.00	373	68.00	413	68.00
14	68.00	54	68.00	94	68.00	134	68.00	174	68.00	214	68.00	254	68.00	294	68.00	334	68.00	374	68.00	414	68.00
15	68.00	55	68.00	95	68.00	135	68.00	175	68.00	215	68.00	255	68.00	295	68.00	335	68.00	375	68.00	415	68.00
16	68.00	56	68.00	96	68.00	136	68.00	176	68.00	216	68.00	256	68.00	296	68.00	336	68.00	376	68.00	416	68.00
17	68.00	57	68.00	97	68.00	137	68.00	177	68.00	217	68.00	257	68.00	297	68.00	337	68.00	377	68.00	417	68.00
18	68.00	58	68.00	98	68.00	138	68.00	178	68.00	218	68.00	258	68.00	298	68.00	338	68.00	378	68.00	418	68.00
19	68.00	59	68.00	99	68.00	139	68.00	179	68.00	219	68.00	259	68.00	299	68.00	339	68.00	379	68.00	419	68.00
20	68.00	60	68.00	100	68.00	140	68.00	180	68.00	220	68.00	260	68.00	300	68.00	340	68.00	380	68.00	420	68.00
21	68.00	61	68.00	101	68.00	141	68.00	181	68.00	221	68.00	261	68.00	301	68.00	341	68.00	381	68.00	421	68.00
22	68.00	62	68.00	102	68.00	142	68.00	182	68.00	222	68.00	262	68.00	302	68.00	342	68.00	382	68.00	422	68.00
23	68.00	63	68.00	103	68.00	143	68.00	183	68.00	223	68.00	263	68.00	303	68.00	343	68.00	383	68.00	423	68.00
24	68.00	64	68.00	104	68.00	144	68.00	184	68.00	224	68.00	264	68.00	304	68.00	344	68.00	384	68.00	424	68.00
25	68.00	65	68.00	105	68.00	145	68.00	185	68.00	225	68.00	265	68.00	305	68.00	345	68.00	385	68.00	425	68.00
26	68.00	66	68.00	106	68.00	146	68.00	186	68.00	226	68.00	266	68.00	306	68.00	346	68.00	386	68.00	426	68.00
27	68.00	67	68.00	107	68.00	147	68.00	187	68.00	227	68.00	267	68.00	307	68.00	347	68.00	387	68.00	427	68.00
28	68.00	68	68.00	108	68.00	148	68.00	188	68.00	228	68.00	268	68.00	308	68.00	348	68.00	388	68.00	428	68.00
29	68.00	69	68.00	109	68.00	149	68.00	189	68.00	229	68.00	269	68.00	309	68.00	349	68.00	389	68.00	429	68.00
30	68.00	70	68.00	110	68.00	150	68.00	190	68.00	230	68.00	270	68.00	310	68.00	350	68.00	390	68.00	430	68.00
31	68.00	71	68.00	111	68.00	151	68.00	191	68.00	231	68.00	271	68.00	311	68.00	351	68.00	391	68.00	431	68.00
32	68.00	72	68.00	112	68.00	152	68.00	192	68.00	232	68.00	272	68.00	312	68.00	352	68.00	392	68.00	432	68.00
33	68.00	73	68.00	113	68.00	153	68.00	193	68.00	233	68.00	273	68.00	313	68.00	353	68.00	393	68.00	433	68.00
34	68.00	74	68.00	114	68.00	154	68.00	194	68.00	234	68.00	274	68.00	314	68.00	354	68.00	394	68.00	434	68.00
35	68.00	75	68.00	115	68.00	155	68.00	195	68.00	235	68.00	275	68.00	315	68.00	355	68.00	395	68.00	435	68.00
36	68.00	76	68.00	116	68.00	156	68.00	196	68.00	236	68.00	276	68.00	316	68.00	356	68.00	396	68.00	436	68.00
37	68.00	77	68.00	117	68.00	157	68.00	197	68.00	237	68.00	277	68.00	317	68.00	357	68.00	397	68.00	437	68.00
38	68.00	78	68.00	118	68.00	158	68.00	198	68.00	238	68.00	278	68.00	318	68.00	358	68.00	398	68.00	438	68.00
39	68.00	79	68.00	119	68.00	159	68.00	199	68.00	239	68.00	279	68.00	319	68.00	359	68.00	399	68.00	439	68.00
40	68.00	80	68.00	120	68.00	160	68.00	200	68.00	240	68.00	280	68.00	320	68.00	360	68.00	400	68.00	440	68.00

Table 9-24(2) Peak Power Duration of Bayram Project

No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)
321	68.00	361	68.00	401	68.00	441	68.00	481	66.76	521	64.54	561	62.34	601	57.69
322	68.00	362	68.00	402	68.00	442	68.00	482	66.68	522	64.54	562	62.23	602	57.63
323	68.00	363	68.00	403	68.00	443	68.00	483	66.54	523	64.54	563	62.21	603	57.60
324	68.00	364	68.00	404	68.00	444	68.00	484	66.50	524	64.54	564	62.20	604	57.59
325	68.00	365	68.00	405	68.00	445	68.00	485	66.48	525	64.54	565	61.98	605	57.58
326	68.00	366	68.00	406	68.00	446	68.00	486	66.46	526	64.54	566	61.78	606	57.27
327	68.00	367	68.00	407	68.00	447	68.00	487	66.46	527	64.54	567	61.69	607	57.15
328	68.00	368	68.00	408	68.00	448	68.00	488	66.40	528	64.54	568	61.55	608	57.15
329	68.00	369	68.00	409	68.00	449	67.88	489	66.39	529	64.48	569	61.54	609	57.12
330	68.00	370	68.00	410	68.00	450	67.84	490	66.18	530	64.41	570	61.40	610	56.71
331	68.00	371	68.00	411	68.00	451	67.84	491	66.05	531	64.38	571	61.22	611	56.39
332	68.00	372	68.00	412	68.00	452	67.84	492	65.96	532	64.36	572	61.21	612	56.16
333	68.00	373	68.00	413	68.00	453	67.83	493	65.94	533	64.26	573	61.17	613	56.10
334	68.00	374	68.00	414	68.00	454	67.82	494	65.90	534	64.19	574	61.12	614	56.07
335	68.00	375	68.00	415	68.00	455	67.64	495	65.89	535	64.05	575	61.08	615	55.09
336	68.00	376	68.00	416	68.00	456	67.63	496	65.88	536	64.01	576	60.72	616	55.02
337	68.00	377	68.00	417	68.00	457	67.61	497	65.87	537	64.00	577	60.61	617	54.94
338	68.00	378	68.00	418	68.00	458	67.59	498	65.80	538	63.97	578	60.61	618	54.68
339	68.00	379	68.00	419	68.00	459	67.56	499	65.57	539	63.80	579	60.42	619	54.20
340	68.00	380	68.00	420	68.00	460	67.53	500	65.57	540	63.79	580	60.29	620	53.32
341	68.00	381	68.00	421	68.00	461	67.52	501	65.46	541	63.69	581	60.25	621	53.07
342	68.00	382	68.00	422	68.00	462	67.48	502	65.36	542	63.69	582	60.14	622	52.83
343	68.00	383	68.00	423	68.00	463	67.48	503	65.02	543	63.65	583	60.12	623	51.85
344	68.00	384	68.00	424	68.00	464	67.39	504	65.01	544	63.56	584	60.04	624	51.76
345	68.00	385	68.00	425	68.00	465	67.39	505	64.99	545	63.49	585	59.81	625	51.64
346	68.00	386	68.00	426	68.00	466	67.37	506	64.97	546	63.47	586	59.75	626	51.51
347	68.00	387	68.00	427	68.00	467	67.26	507	64.97	547	63.37	587	59.73	627	50.89
348	68.00	388	68.00	428	68.00	468	67.20	508	64.80	548	63.27	588	59.68	628	50.17
349	68.00	389	68.00	429	68.00	469	67.12	509	64.64	549	63.24	589	59.35	629	48.99
350	68.00	390	68.00	430	68.00	470	67.11	510	64.59	550	63.16	590	59.21	630	48.72
351	68.00	391	68.00	431	68.00	471	67.02	511	64.54	551	63.15	591	59.16	631	48.71
352	68.00	392	68.00	432	68.00	472	66.98	512	64.54	552	63.12	592	59.15	632	40.49
353	68.00	393	68.00	433	68.00	473	66.97	513	64.54	553	63.00	593	58.96	633	40.07
354	68.00	394	68.00	434	68.00	474	66.91	514	64.54	554	62.70	594	58.92	634	31.98
355	68.00	395	68.00	435	68.00	475	66.88	515	64.54	555	62.57	595	58.91	635	28.61
356	68.00	396	68.00	436	68.00	476	66.85	516	64.54	556	62.56	596	58.69	636	20.31
357	68.00	397	68.00	437	68.00	477	66.84	517	64.54	557	62.54	597	58.25		
358	68.00	398	68.00	438	68.00	478	66.81	518	64.54	558	62.44	598	58.02		
359	68.00	399	68.00	439	68.00	479	66.76	519	64.54	559	62.43	599	58.02		
360	68.00	400	68.00	440	68.00	480	66.76	520	64.54	560	62.35	600	57.90		



Table 9-25 Reservoir Operation of Bağlık Project

Unit 10<sup>6</sup>m<sup>3</sup>

	Year	Inflow	Evaporation	Power Discharge	Environment Discharge	Spill	Total Outflow
1	1942	1,216.32	0.34	921.08	3.97	289.92	1,215.32
2	1943	717.37	0.35	713.05	3.97	0.00	717.37
3	1944	1,003.39	0.35	811.68	3.97	187.40	1,003.39
4	1945	610.83	0.35	606.53	3.97	0.00	610.85
5	1946	659.85	0.35	655.51	3.97	0.00	659.83
6	1947	563.73	0.35	559.70	3.97	0.00	564.01
7	1948	640.77	0.35	636.17	3.97	0.00	640.48
8	1949	523.52	0.34	519.21	3.97	0.00	523.53
9	1950	592.58	0.34	588.80	3.97	0.00	593.11
10	1951	585.26	0.35	580.41	3.97	0.00	584.73
11	1952	718.18	0.35	713.86	3.97	0.00	718.18
12	1953	593.43	0.34	589.12	3.97	0.00	593.43
13	1954	796.40	0.35	762.55	3.97	29.54	769.40
14	1955	443.75	0.34	440.44	3.97	0.00	444.75
15	1956	514.93	0.34	509.64	3.97	0.00	513.95
16	1957	615.99	0.34	611.68	3.97	0.00	615.99
17	1958	608.88	0.34	604.54	3.97	0.00	608.86
18	1959	696.67	0.35	692.35	3.97	0.00	696.67
19	1960	1,121.07	0.35	913.10	3.97	203.65	1,121.07
20	1961	524.73	0.34	521.42	3.97	0.00	525.73
21	1962	680.86	0.34	675.55	3.97	0.00	679.86
22	1963	1,122.23	0.35	847.99	3.97	269.93	1,122.23
23	1964	799.51	0.35	760.10	3.97	35.10	799.51
24	1965	834.53	0.34	814.16	3.97	17.06	835.53
25	1966	779.58	0.34	755.43	3.97	19.84	779.58
26	1967	701.94	0.34	668.23	3.97	28.41	700.94
27	1968	1,406.78	0.35	941.80	3.97	460.66	1,406.77
28	1969	767.65	0.34	720.05	3.97	44.29	768.65
29	1970	609.22	0.34	603.90	3.97	0.00	608.22
30	1971	758.38	0.34	744.36	3.97	10.70	759.38
31	1972	809.96	0.34	776.41	3.97	28.23	808.96
32	1973	742.95	0.35	732.46	3.97	6.70	743.48
33	1974	610.06	0.34	597.04	3.97	8.17	609.53
34	1975	671.35	0.34	660.99	3.97	6.89	672.18
35	1976	858.65	0.34	761.76	3.97	91.74	857.81
36	1977	692.61	0.35	688.29	3.97	0.00	692.61
37	1978	861.40	0.35	785.73	3.97	71.36	861.40
38	1979	794.73	0.35	766.36	3.97	24.58	795.26
39	1980	811.01	0.35	743.44	3.97	62.73	810.49
40	1981	731.18	0.35	683.37	3.97	43.48	731.16
41	1982	616.21	0.34	612.90	3.97	0.00	617.21
42	1983	801.04	0.34	748.12	3.97	48.61	801.04
43	1984	724.86	0.34	720.55	3.97	0.00	724.86
44	1985	781.64	0.34	653.61	3.97	122.73	780.64
45	1986	911.06	0.34	818.53	3.97	89.22	912.06
46	1987	954.90	0.34	725.47	3.97	224.12	953.90
47	1988	1,288.18	0.35	908.33	3.97	375.54	1,288.18
48	1989	1,367.41	0.34	906.57	3.97	457.53	1,368.41
49	1990	800.34	0.34	732.95	3.97	63.08	800.34
50	1991	699.94	0.34	687.48	3.97	8.15	699.94
51	1992	854.63	0.34	739.07	3.97	110.25	853.63
52	1993	1,170.14	0.35	901.59	3.97	264.23	1,170.14
53	1994	801.02	0.34	755.10	3.97	42.64	802.05
	Total	41,563.74	18.19	37,588.42	210.64	3,746.50	41,563.73
	Ave.	784.22	0.34	709.22	3.97	70.69	784.22
	Max.	1,046.78	0.35	941.98	3.97	460.66	1,406.77
	Min.	443.75	0.34	440.44	3.97	0.00	444.75

Table 9-26 Total Energy Production of Bağlık Project

Unit: GWh

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1	1942	12.19	17.27	14.34	12.72	22.24	38.31	42.48	43.90	42.48	23.68	12.49	11.65	293.73
2	1943	12.21	12.32	13.46	11.88	15.56	26.77	30.96	35.22	28.15	17.70	12.03	11.24	227.50
3	1944	11.70	11.49	11.79	11.54	10.65	29.28	30.14	43.90	42.48	32.31	12.29	11.40	256.96
4	1945	11.53	11.49	11.19	11.08	9.97	11.37	22.28	32.23	32.95	17.02	11.52	10.75	193.38
5	1946	11.19	10.83	11.11	11.45	10.03	11.88	22.13	35.99	38.57	21.63	13.17	11.15	209.14
6	1947	12.38	11.41	11.36	11.36	10.87	31.48	27.74	14.78	13.47	11.87	11.11	10.71	178.53
7	1948	11.07	11.91	11.37	11.28	10.27	11.36	22.49	35.48	40.14	14.88	11.52	11.16	202.93
8	1949	11.36	10.92	11.08	10.98	9.74	11.26	13.72	29.37	23.02	11.78	11.19	10.75	165.16
9	1950	11.11	10.72	10.94	10.61	9.73	11.85	25.02	35.48	23.85	15.65	11.35	10.69	187.00
10	1951	11.55	11.16	11.28	11.11	10.47	11.79	24.65	25.23	30.05	15.05	11.52	11.24	185.11
11	1952	12.90	11.90	11.62	11.45	10.65	23.59	39.40	32.57	30.55	20.52	11.69	10.91	227.75
12	1953	11.11	10.72	10.98	10.61	9.73	10.93	15.31	34.20	32.45	17.96	11.78	11.32	187.09
13	1954	11.36	11.08	11.08	11.01	10.11	13.24	38.90	43.90	42.48	26.50	12.20	11.24	243.10
14	1955	11.36	10.91	11.11	11.01	10.16	11.09	13.22	15.63	13.05	11.19	10.88	10.11	139.73
15	1956	10.45	10.11	10.26	4.84	6.63	9.00	15.13	24.57	31.38	16.76	11.35	10.75	161.24
16	1957	11.04	10.46	10.44	10.27	9.81	12.70	20.85	33.09	35.92	17.27	11.44	10.75	194.05
17	1958	11.10	10.83	11.08	10.93	9.81	11.85	22.67	34.20	32.45	15.22	11.27	10.91	192.32
18	1959	11.19	10.83	11.19	11.19	10.34	12.33	25.83	43.43	40.89	20.35	12.03	11.15	220.77
19	1960	12.04	11.57	11.45	12.65	21.35	42.66	42.48	43.90	42.48	27.18	12.49	11.07	291.32
20	1961	11.27	10.83	11.08	10.68	9.58	11.18	22.80	23.86	22.20	11.35	10.71	9.95	165.47
21	1962	10.36	10.35	11.10	11.11	8.50	14.38	37.71	40.78	32.20	15.99	11.27	10.91	214.67
22	1963	11.19	10.92	11.28	11.37	10.95	12.22	42.48	43.90	42.48	43.90	18.55	11.32	270.55
23	1964	11.61	11.08	11.36	11.19	10.19	19.47	42.29	43.90	42.48	16.42	11.52	10.99	242.51
24	1965	12.30	11.24	12.22	11.36	10.26	34.13	42.48	43.90	41.72	18.72	11.04	10.13	259.50
25	1966	12.02	12.40	11.71	11.88	11.19	25.26	39.32	43.90	38.24	15.14	11.04	10.53	240.62
26	1967	10.44	9.95	10.44	10.27	5.96	10.76	16.77	43.90	37.15	31.03	13.43	11.57	211.67
27	1968	11.61	11.66	17.83	14.00	20.23	40.96	42.48	43.90	42.48	29.32	14.19	11.61	300.48
28	1969	12.04	11.57	11.79	11.04	9.94	26.13	42.48	43.90	27.06	11.69	11.01	10.50	229.16
29	1970	12.44	11.33	11.45	11.45	10.80	20.48	40.80	25.14	14.51	11.78	11.27	11.08	192.53
30	1971	13.07	11.66	11.79	11.36	11.19	30.34	27.99	43.90	38.63	14.71	12.12	10.61	237.37
31	1972	11.17	11.16	11.96	11.37	10.34	17.75	42.48	43.90	42.48	21.63	11.69	11.65	247.59
32	1973	11.70	11.41	11.28	11.11	10.88	18.90	28.98	43.90	42.48	20.95	11.35	10.69	233.63
33	1974	11.01	11.21	11.37	11.08	9.95	12.84	18.95	43.90	25.59	11.61	11.07	11.53	190.09
34	1975	11.08	10.69	11.01	10.95	10.17	12.44	42.48	35.48	31.62	12.40	11.04	10.58	209.94
35	1976	11.17	10.83	11.04	10.98	9.94	12.77	41.42	43.90	42.48	25.30	11.69	11.07	242.60
36	1977	12.38	11.33	11.36	13.11	10.26	16.26	28.81	43.85	34.68	17.10	11.52	10.91	219.60
37	1978	11.70	11.16	11.11	11.08	10.69	19.06	42.48	43.90	42.48	24.02	12.03	10.91	250.62
38	1979	11.36	11.16	11.45	11.62	11.43	20.51	35.36	43.90	42.48	24.71	11.78	10.69	244.44
39	1980	11.21	12.48	12.22	11.54	10.50	29.62	42.48	43.90	28.88	12.20	11.35	10.75	237.12
40	1981	11.53	11.25	11.54	11.19	10.27	32.64	24.10	37.45	42.48	22.74	11.69	11.16	218.02
41	1982	11.53	11.16	11.71	11.45	10.03	15.53	34.02	35.48	17.24	15.14	11.52	10.61	195.42
42	1983	11.34	11.25	10.71	10.69	9.84	21.56	42.48	43.90	42.20	13.60	10.28	9.54	237.38
43	1984	11.10	13.15	11.36	11.08	9.97	25.39	36.67	41.38	27.65	19.92	11.44	10.37	229.48
44	1985	10.02	10.27	10.27	10.27	9.66	14.13	42.48	43.90	23.01	11.35	10.79	10.80	206.96
45	1986	13.41	11.82	11.79	11.28	10.73	30.47	42.48	43.90	42.48	21.60	10.62	10.02	260.80
46	1987	10.69	10.11	10.27	10.52	12.81	12.73	42.48	43.90	42.48	11.44	11.27	11.65	230.35
47	1988	11.45	11.00	11.19	11.54	11.58	43.67	42.48	43.90	42.48	30.69	15.99	13.84	289.60
48	1989	20.41	17.06	15.36	11.88	16.94	43.90	42.48	43.90	42.48	13.77	10.53	10.18	288.88
49	1990	10.36	10.19	10.44	9.94	9.43	13.29	41.69	43.90	42.48	19.07	11.07	10.49	232.34
50	1991	10.69	12.28	11.62	10.79	10.19	30.59	42.48	42.48	24.82	14.11	11.01	9.65	218.06
51	1992	9.86	10.43	10.44	9.77	8.32	12.19	42.48	43.90	42.48	22.57	11.10	10.97	234.52
52	1993	19.24	23.01	13.16	11.53	14.44	34.29	42.48	43.90	42.48	20.43	11.78	10.91	267.65
53	1994	10.29	11.13	11.28	11.19	10.03	38.92	42.48	43.90	27.56	12.55	11.11	10.11	240.55
TOTAL		621.93	616.46	613.11	587.64	585.33	1097.48	1775.74	2042.68	1834.29	993.63	623.23	577.62	11969.12
AVE		11.73	11.63	11.57	11.09	11.04	20.71	33.50	38.54	34.61	18.75	11.76	10.90	225.83
MAX		20.41	23.01	17.83	14.00	22.24	43.90	42.48	43.90	42.48	43.90	18.55	13.84	300.48
MIN		9.86	9.95	10.26	4.84	5.96	9.00	13.22	14.78	13.05	11.19	10.28	9.54	139.73

Table 9-27 Firm Energy Production of Bağlık Project

Unit: GWh

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< TOTAL >
1	1942	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
2	1943	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
3	1944	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
4	1945	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
5	1946	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
6	1947	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
7	1948	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
8	1949	10.97	10.62	10.97	10.97	9.74	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.04
9	1950	10.97	10.62	10.94	10.61	9.73	10.97	10.62	10.97	10.62	10.97	10.97	10.62	128.63
10	1951	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
11	1952	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
12	1953	10.97	10.62	10.97	10.61	9.73	10.90	10.62	10.97	10.62	10.97	10.97	10.62	128.59
13	1954	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
14	1955	10.97	10.62	10.97	10.97	10.13	10.97	10.62	10.97	10.62	10.97	10.88	10.11	128.83
15	1956	10.45	10.11	10.26	4.84	6.63	9.00	10.62	10.97	10.62	10.97	10.97	10.62	116.08
16	1957	10.97	10.44	10.44	10.27	9.75	10.97	10.62	10.97	10.62	10.97	10.97	10.62	127.66
17	1958	10.97	10.62	10.97	10.93	9.75	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.01
18	1959	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
19	1960	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
20	1961	10.97	10.62	10.97	10.68	9.58	10.97	10.62	10.97	10.62	10.97	10.71	9.95	127.44
21	1962	10.36	10.35	10.97	10.97	8.50	10.97	10.62	10.97	10.62	10.97	10.97	10.62	126.92
22	1963	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
23	1964	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
24	1965	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.13	128.72
25	1966	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.53	129.12
26	1967	10.44	9.95	10.44	10.27	5.96	10.76	10.62	10.97	10.62	10.97	10.97	10.62	122.61
27	1968	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
28	1969	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.48	129.07
29	1970	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
30	1971	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.61	129.56
31	1972	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
32	1973	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
33	1974	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
34	1975	10.97	10.62	10.97	10.93	10.14	10.97	10.62	10.97	10.62	10.97	10.97	10.56	129.33
35	1976	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
36	1977	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
37	1978	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
38	1979	10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
39	1980	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
40	1981	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
41	1982	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.61	129.20
42	1983	10.97	10.62	10.71	10.69	9.84	10.97	10.62	10.97	10.62	10.97	10.28	9.54	126.82
43	1984	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.37	128.96
44	1985	10.02	10.27	10.27	10.27	9.66	10.97	10.62	10.97	10.62	10.97	10.79	10.62	126.07
45	1986	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.62	10.02	128.25
46	1987	10.69	10.11	10.27	10.52	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	127.62
47	1988	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
48	1989	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.53	10.18	128.33
49	1990	10.36	10.19	10.44	9.74	9.43	10.97	10.62	10.97	10.62	10.97	10.97	10.49	125.98
50	1991	10.69	10.62	10.97	10.79	10.14	10.97	10.62	10.97	10.62	10.97	10.97	9.85	128.21
51	1992	9.86	10.43	10.44	9.77	8.32	10.97	10.62	10.97	10.62	10.97	10.97	10.62	124.58
52	1993	10.97	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.21
53	1994	10.29	10.62	10.97	10.97	9.91	10.97	10.62	10.97	10.62	10.97	10.97	10.11	128.02
TOTAL		576.02	559.76	577.07	569.12	516.63	579.36	562.86	581.62	562.86	581.62	579.58	557.09	6803.57
AVE		10.87	10.56	10.89	10.74	9.75	10.93	10.62	10.97	10.62	10.97	10.94	10.51	128.37
MAX		10.97	10.62	10.97	10.97	10.27	10.97	10.62	10.97	10.62	10.97	10.97	10.62	129.56
MIN		9.86	9.95	10.26	4.84	5.96	9.00	10.62	10.97	10.62	10.97	10.28	9.54	116.08

Table 9-28 Peak Power of Bağlık Project

Unit: MW

NO.	YEAR	< OCT >	< NOV >	< DEC >	< JAN >	< FEB >	< MAR >	< APR >	< MAY >	< JUN >	< JUL >	< AUG >	< SEP >	< AVE >
1	1942	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
2	1943	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
3	1944	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
4	1945	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
5	1946	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
6	1947	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
7	1948	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
8	1949	59.00	59.00	59.00	59.00	57.98	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
9	1950	59.00	59.00	58.81	57.03	57.93	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.92
10	1951	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.73
11	1952	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
12	1953	59.00	59.00	59.00	59.00	57.06	57.93	58.59	59.00	59.00	59.00	59.00	59.00	59.00
13	1954	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.72
14	1955	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
15	1956	56.19	56.18	55.16	26.02	39.48	48.41	59.00	59.00	59.00	59.00	58.49	56.17	58.66
16	1957	59.00	58.13	56.13	55.24	58.04	59.00	59.00	59.00	59.00	59.00	59.00	59.00	53.01
17	1958	59.00	59.00	59.00	59.00	58.77	58.04	59.00	59.00	59.00	59.00	59.00	59.00	58.29
18	1959	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.91
19	1960	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
20	1961	59.00	59.00	59.00	59.00	57.40	57.03	59.00	59.00	59.00	59.00	59.00	59.00	59.00
21	1962	55.72	57.52	59.00	59.00	50.60	59.00	59.00	59.00	59.00	59.00	57.56	55.26	58.28
22	1963	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
23	1964	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
24	1965	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
25	1966	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	56.27	58.78
26	1967	56.14	55.25	56.14	55.24	34.28	57.64	59.00	59.00	59.00	59.00	59.00	58.49	58.96
27	1968	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	55.83
28	1969	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
29	1970	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.22
30	1971	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
31	1972	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.96
32	1973	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
33	1974	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
34	1975	59.00	59.00	59.00	58.74	58.25	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
35	1976	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.66
36	1977	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.89
37	1978	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
38	1979	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
39	1980	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
40	1981	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
41	1982	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
42	1983	59.00	59.00	57.58	57.47	56.58	59.00	59.00	59.00	59.00	59.00	59.00	58.97	59.00
43	1984	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	55.27	57.75
44	1985	53.89	57.04	55.23	55.23	57.48	59.00	59.00	59.00	59.00	59.00	59.00	57.61	58.89
45	1986	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.00	59.00	57.56
46	1987	57.49	56.14	55.24	56.58	59.00	59.00	59.00	59.00	59.00	59.00	57.08	55.67	58.56
47	1988	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	58.11
48	1989	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
49	1990	55.69	58.59	56.13	53.44	56.14	59.00	59.00	59.00	59.00	59.00	56.63	56.57	58.60
50	1991	57.48	59.00	59.00	58.03	58.30	59.00	59.00	59.00	59.00	59.00	59.00	58.25	57.52
51	1992	53.00	57.95	56.14	52.54	49.54	59.00	59.00	59.00	59.00	59.00	59.00	56.71	58.35
52	1993	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	56.69
53	1994	55.30	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
	AVE	58.43	58.68	58.54	57.73	57.53	58.77	59.00	59.00	59.00	59.00	58.79	58.40	58.58
	MAX	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00	59.00
	MIN	53.00	55.25	55.16	26.02	34.28	48.41	59.00	59.00	59.00	59.00	55.27	52.99	53.01

Table 9-29(1) Peak Power Duration of Bağlık Project

No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)
1	59.00	41	59.00	81	59.00	121	59.00	161	59.00	201	59.00	241	59.00	281	59.00	321	59.00
2	59.00	42	59.00	82	59.00	122	59.00	162	59.00	202	59.00	242	59.00	282	59.00	322	59.00
3	59.00	43	59.00	83	59.00	123	59.00	163	59.00	203	59.00	243	59.00	283	59.00	323	59.00
4	59.00	44	59.00	84	59.00	124	59.00	164	59.00	204	59.00	244	59.00	284	59.00	324	59.00
5	59.00	45	59.00	85	59.00	125	59.00	165	59.00	205	59.00	245	59.00	285	59.00	325	59.00
6	59.00	46	59.00	86	59.00	126	59.00	166	59.00	206	59.00	246	59.00	286	59.00	326	59.00
7	59.00	47	59.00	87	59.00	127	59.00	167	59.00	207	59.00	247	59.00	287	59.00	327	59.00
8	59.00	48	59.00	88	59.00	128	59.00	168	59.00	208	59.00	248	59.00	288	59.00	328	59.00
9	59.00	49	59.00	89	59.00	129	59.00	169	59.00	209	59.00	249	59.00	289	59.00	329	59.00
10	59.00	50	59.00	90	59.00	130	59.00	170	59.00	210	59.00	250	59.00	290	59.00	330	59.00
11	59.00	51	59.00	91	59.00	131	59.00	171	59.00	211	59.00	251	59.00	291	59.00	331	59.00
12	59.00	52	59.00	92	59.00	132	59.00	172	59.00	212	59.00	252	59.00	292	59.00	332	59.00
13	59.00	53	59.00	93	59.00	133	59.00	173	59.00	213	59.00	253	59.00	293	59.00	333	59.00
14	59.00	54	59.00	94	59.00	134	59.00	174	59.00	214	59.00	254	59.00	294	59.00	334	59.00
15	59.00	55	59.00	95	59.00	135	59.00	175	59.00	215	59.00	255	59.00	295	59.00	335	59.00
16	59.00	56	59.00	96	59.00	136	59.00	176	59.00	216	59.00	256	59.00	296	59.00	336	59.00
17	59.00	57	59.00	97	59.00	137	59.00	177	59.00	217	59.00	257	59.00	297	59.00	337	59.00
18	59.00	58	59.00	98	59.00	138	59.00	178	59.00	218	59.00	258	59.00	298	59.00	338	59.00
19	59.00	59	59.00	99	59.00	139	59.00	179	59.00	219	59.00	259	59.00	299	59.00	339	59.00
20	59.00	60	59.00	100	59.00	140	59.00	180	59.00	220	59.00	260	59.00	300	59.00	340	59.00
21	59.00	61	59.00	101	59.00	141	59.00	181	59.00	221	59.00	261	59.00	301	59.00	341	59.00
22	59.00	62	59.00	102	59.00	142	59.00	182	59.00	222	59.00	262	59.00	302	59.00	342	59.00
23	59.00	63	59.00	103	59.00	143	59.00	183	59.00	223	59.00	263	59.00	303	59.00	343	59.00
24	59.00	64	59.00	104	59.00	144	59.00	184	59.00	224	59.00	264	59.00	304	59.00	344	59.00
25	59.00	65	59.00	105	59.00	145	59.00	185	59.00	225	59.00	265	59.00	305	59.00	345	59.00
26	59.00	66	59.00	106	59.00	146	59.00	186	59.00	226	59.00	266	59.00	306	59.00	346	59.00
27	59.00	67	59.00	107	59.00	147	59.00	187	59.00	227	59.00	267	59.00	307	59.00	347	59.00
28	59.00	68	59.00	108	59.00	148	59.00	188	59.00	228	59.00	268	59.00	308	59.00	348	59.00
29	59.00	69	59.00	109	59.00	149	59.00	189	59.00	229	59.00	269	59.00	309	59.00	349	59.00
30	59.00	70	59.00	110	59.00	150	59.00	190	59.00	230	59.00	270	59.00	310	59.00	350	59.00
31	59.00	71	59.00	111	59.00	151	59.00	191	59.00	231	59.00	271	59.00	311	59.00	351	59.00
32	59.00	72	59.00	112	59.00	152	59.00	192	59.00	232	59.00	272	59.00	312	59.00	352	59.00
33	59.00	73	59.00	113	59.00	153	59.00	193	59.00	233	59.00	273	59.00	313	59.00	353	59.00
34	59.00	74	59.00	114	59.00	154	59.00	194	59.00	234	59.00	274	59.00	314	59.00	354	59.00
35	59.00	75	59.00	115	59.00	155	59.00	195	59.00	235	59.00	275	59.00	315	59.00	355	59.00
36	59.00	76	59.00	116	59.00	156	59.00	196	59.00	236	59.00	276	59.00	316	59.00	356	59.00
37	59.00	77	59.00	117	59.00	157	59.00	197	59.00	237	59.00	277	59.00	317	59.00	357	59.00
38	59.00	78	59.00	118	59.00	158	59.00	198	59.00	238	59.00	278	59.00	318	59.00	358	59.00
39	59.00	79	59.00	119	59.00	159	59.00	199	59.00	239	59.00	279	59.00	319	59.00	359	59.00
40	59.00	80	59.00	120	59.00	160	59.00	200	59.00	240	59.00	280	59.00	320	59.00	360	59.00

Table 9-29(2) Peak Power Duration of Bağlık Project

No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	No.	Peak Power (MW)	
321	59.00	361	59.00	401	59.00	441	59.00	481	59.00	521	59.00	561	59.00	601	56.19					
322	59.00	362	59.00	402	59.00	442	59.00	482	59.00	522	59.00	562	58.66	602	56.19					
323	59.00	363	59.00	403	59.00	443	59.00	483	59.00	523	59.00	563	58.59	603	56.18					
324	59.00	364	59.00	404	59.00	444	59.00	484	59.00	524	59.00	564	58.49	604	56.17					
325	59.00	365	59.00	405	59.00	445	59.00	485	59.00	525	59.00	565	58.49	605	56.14					
326	59.00	366	59.00	406	59.00	446	59.00	486	59.00	526	59.00	566	58.30	606	56.14					
327	59.00	367	59.00	407	59.00	447	59.00	487	59.00	527	59.00	567	58.25	607	56.14					
328	59.00	368	59.00	408	59.00	448	59.00	488	59.00	528	59.00	568	58.25	608	56.14					
329	59.00	369	59.00	409	59.00	449	59.00	489	59.00	529	59.00	569	58.24	609	56.14					
330	59.00	370	59.00	410	59.00	450	59.00	490	59.00	530	59.00	570	58.22	610	56.13					
331	59.00	371	59.00	411	59.00	451	59.00	491	59.00	531	59.00	571	58.13	611	56.13					
332	59.00	372	59.00	412	59.00	452	59.00	492	59.00	532	59.00	572	58.04	612	55.72					
333	59.00	373	59.00	413	59.00	453	59.00	493	59.00	533	59.00	573	58.04	613	55.69					
334	59.00	374	59.00	414	59.00	454	59.00	494	59.00	534	59.00	574	58.03	614	55.67					
335	59.00	375	59.00	415	59.00	455	59.00	495	59.00	535	59.00	575	58.00	615	55.30					
336	59.00	376	59.00	416	59.00	456	59.00	496	59.00	536	59.00	576	57.98	616	55.27					
337	59.00	377	59.00	417	59.00	457	59.00	497	59.00	537	59.00	577	57.95	617	55.26					
338	59.00	378	59.00	418	59.00	458	59.00	498	59.00	538	59.00	578	57.93	618	55.25					
339	59.00	379	59.00	419	59.00	459	59.00	499	59.00	539	59.00	579	57.93	619	55.24					
340	59.00	380	59.00	420	59.00	460	59.00	500	59.00	540	59.00	580	57.84	620	55.24					
341	59.00	381	59.00	421	59.00	461	59.00	501	59.00	541	59.00	581	57.61	621	55.24					
342	59.00	382	59.00	422	59.00	462	59.00	502	59.00	542	59.00	582	57.56	622	55.23					
343	59.00	383	59.00	423	59.00	463	59.00	503	59.00	543	59.00	583	57.56	623	55.23					
344	59.00	384	59.00	424	59.00	464	59.00	504	59.00	544	59.00	584	57.52	624	55.16					
345	59.00	385	59.00	425	59.00	465	59.00	505	59.00	545	59.00	585	57.49	625	54.71					
346	59.00	386	59.00	426	59.00	466	59.00	506	59.00	546	59.00	586	57.48	626	53.89					
347	59.00	387	59.00	427	59.00	467	59.00	507	59.00	547	59.00	587	57.46	627	53.44					
348	59.00	388	59.00	428	59.00	468	59.00	508	59.00	548	59.00	588	57.47	628	53.00					
349	59.00	389	59.00	429	59.00	469	59.00	509	59.00	549	59.00	589	57.40	629	52.99					
350	59.00	390	59.00	430	59.00	470	59.00	510	59.00	550	59.00	590	57.06	630	52.54					
351	59.00	391	59.00	431	59.00	471	59.00	511	59.00	551	59.00	591	57.06	631	50.60					
352	59.00	392	59.00	432	59.00	472	59.00	512	59.00	552	59.00	592	57.04	632	49.54					
353	59.00	393	59.00	433	59.00	473	59.00	513	59.00	553	59.00	593	57.03	633	48.41					
354	59.00	394	59.00	434	59.00	474	59.00	514	59.00	554	59.00	594	57.03	634	39.48					
355	59.00	395	59.00	435	59.00	475	59.00	515	59.00	555	59.00	595	56.63	635	34.28					
356	59.00	396	59.00	436	59.00	476	59.00	516	59.00	556	59.00	596	56.59	636	26.02					
357	59.00	397	59.00	437	59.00	477	59.00	517	59.00	557	56.97	597	56.58							
358	59.00	398	59.00	438	59.00	478	59.00	518	59.00	558	58.96	598	56.58							
359	59.00	399	59.00	439	59.00	479	59.00	519	59.00	559	58.81	599	56.57							
360	59.00	400	59.00	440	59.00	480	59.00	520	59.00	560	56.77	600	56.27							





Figure 9-18(1) Reservoir Operation of Bayram Project

\*\*\* BAYRAM 740-685 QMAX=43.PMAX=68 \*\*\*

-- WATER LEVEL --





Figure 9-18(2) Reservoir Operation of Bayram Project







Figure 9-18(3) Reservoir Operation of Bayram Project





Figure 9-19(1) Energy Generation of Bayram Project





Figure 9-19(2) Energy Generation of Bayram Project





Figure 9-19(3) Energy Generation of Bayram Project





Figure 9-20(1) Reservoir Operation of Bağlık Project





Figure 9-20(2) Reservoir Operation of Bağlık Project





Figure 9-20(3) Reservoir Operation of Bağlık Project





Figure 9-21(1) Energy Generation of Bağlık Project







Figure 9-21(2) Energy Generation of Bağlık Project





Figure 9-21(3) Energy Generation of Bağlık Project