

## 4. Stationary sources data

**[Data Sheet] Analyzed data sheet for first field survey [Table 3.4.2-10(2)]**

1. Room heater (Gas oil)
2. Room heater (Kerosene)
3. Fire place (Natural gas)
4. Heater (Natural gas)
5. Cooking burner (Natural gas)
6. Cooking burner (LPG)
7. Water boiler (Natural gas)
8. Tehran cement No.4
9. Tehran cement No.6
10. Tehran cement No.7
11. Tehran refinery 2H-101
12. Tehran refinery boiler

Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T. Nambu (JICA)

F. Goodarz (AQCC)

Facility Name : Room heater (Gas oil)

Measuring Date : 18, Feb, 1997

Item	Measuring Result	
CO <sub>2</sub> Concentration	4.4	%
O <sub>2</sub> Concentration	14.2	%
CO Concentration	105	ppm
NO <sub>x</sub> Concentration	14.6	ppm
SO <sub>x</sub> Concentration	137	ppm
Emission factor CO		g/Gj
Emission factor NO <sub>x</sub>		g/Gj
Emission factor Sox		g/Gj

Measurement of component in flue gas

Measuring time	14:30	15:53
CO <sub>2</sub> concentration (%)	4.4	4.4
O <sub>2</sub> concentration (%)	15.4	15.5
CO concentration (ppm)	110	100

Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
14:50	17.0	145	10.0
15:00	15.0	148	13.8
15:10	14.0	139	14.4
15:20	14.6	140	13.9
15:30	15.0	133	14.4
15:40	14.5	130	14.8
15:50	12.0	125	15.0
Mean	14.6	137	14.2

Fuel Combustion Analysis Work Sheet

	Item	Remark
1	Type	Room heater
2	Fuel type	Gas oil
3	Flow rate	0.353 Kg/h
4	Others	

Calculation of Emission factor

$$EF = C \text{ (ppm)} \times \frac{CO_2 th}{CO_2} \times G_o \times \frac{A}{22.4} \times 10^{-3} \times \frac{1}{Hh} \text{ (g/Gj)}$$

$$CO_2 th \text{ (%) } = 12.23 \text{ (NG) , } 15.11 \text{ (Kerosene)}$$


$$G_o = 8.74 \text{ (NG) , } 10.51 \text{ (Kerosene)}$$

$$A = 46 \text{ (Nox) , } 64 \text{ (Sox) , } 28 \text{ (CO)}$$

$$Hh = 0.0472 \text{ (NG} \cdot \text{Gj/m}^3\text{)}$$

$$0.0429 \text{ (Kerosene} \cdot \text{Gj/L)}$$

$$EF = \text{Emission factor}$$



# Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T.Nambu (JICA)  
F. Goodarz (AQCC)

Facility Name : Room heater (Kerosene)

Measuring Date : 18, Feb, 1997

Item	Measuring Result	
CO <sub>2</sub> Concentration	2.8	%
O <sub>2</sub> Concentration	15.8	%
CO Concentration	360	ppm
NOx Concentration	6.5	ppm
SOx Concentration	27.3	ppm
Emission factor CO	595	g/Gj
Emission factor NOx	17.6	g/Gj
Emission factor Sox	103	g/Gj

Measurement of component in flue gas

Measuring time	11:30	12:50
CO <sub>2</sub> concentration (%)	2.8	2.8
O <sub>2</sub> concentration (%)	16.8	16.8
CO concentration (ppm)	350	370

Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
11:49	8.0	27.0	14.3
11:59	6.6	30.0	15.3
12:09	6.0	29.2	15.5
12:19	6.4	28.4	16.1
12:29	5.0	27.0	16.4
12:39	6.8	28.0	16.4
12:49	7.0	21.8	17.1
Mean	6.5	27.3	15.8



Fuel Combustion Analysis Work Sheet

	Item	Remark
1	Type	Room heater
2	Fuel type	Kerosen
3	Flow rate	0.229 Kg/h
4	Others	

Calculation of Emission factor

$$EF = C \text{ (ppm)} \times \frac{CO_{2th}}{CO_2} \times G_o \times \frac{A}{22.4} \times 10^{-3} \times \frac{1}{Hh} \text{ (g/Gj)}$$


$$CO_{2th} \text{ (%) } = 15.11 \text{ (Kerosene)}$$

$$G_o = 10.51 \text{ (Kerosene)}$$

$$A = 46 \text{ (NO}_x\text{)}, 64 \text{ (SO}_x\text{)}, 28 \text{ (CO)}$$

$$Hh = 0.0429 \text{ (Kerosene} \cdot \text{Gj/L)}$$

$$EF = \text{Emission factor}$$



## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T.Nambu (JICA)  
F. Goodarz (AQCC)

Facility Name : Fire place

Measuring Date : 19, Feb, 1997

Item	Measuring Result	
CO <sub>2</sub> Concentration	0.64	%
O <sub>2</sub> Concentration	19.6	%
CO Concentration	53	ppm
NO <sub>x</sub> Concentration	6.4	ppm
SO <sub>x</sub> Concentration	1.3	ppm
Emission factor CO	234	g/Gj
Emission factor NO <sub>x</sub>	46.5	g/Gj
Emission factor Sox	13.1	g/Gj

Measurement of component in flue gas

Measuring time	10:00	11:08
CO <sub>2</sub> concentration (%)	0.63	0.65
O <sub>2</sub> concentration (%)	19.8	19.9
CO concentration (ppm)	55	50

Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
10:05	6.0	1.6	19.6
10:15	6.0	1.6	19.6
10:25	6.4	1.6	19.6
10:35	6.2	1.0	19.6
10:45	6.4	1.0	19.6
10:55	7.0	1.0	19.6
11:05	7.0	1.0	19.6
Mean	6.4	1.3	19.6

Fuel Combustion Analysis Work Sheet

	Item	Remark
1	Type	Fire place
2	Fuel type	NG
3	Flow rate	1.27 m <sup>3</sup> /h
4	Others	


Calculation of Emission factor

$$EF = C \text{ (ppm)} \times \frac{CO_2 th}{CO_2} \times G_o \times \frac{A}{22.4} \times 10^{-3} \times \frac{1}{Hh} \quad (\text{g/Gj})$$

$CO_2 th \text{ (\%)} = 12.23 \text{ (NG)}$   
 $G_o = 8.74 \text{ (NG)}$   
 $A = 46 \text{ (Nox)}, 64 \text{ (Sox)}, 28 \text{ (CO)}$   
 $Hh = 0.0472 \text{ (NG} \cdot \text{Gj/m}^3\text{)}$   
 $EF = \text{Emission factor}$

1CH 0.0000  
 2CH 0.7870  
 3CH 0.0457  
 1CH 0.0340  
 300.00H

V  
1.0000



50	80	SO <sub>x</sub> (ppm)	120	160	200
50	80	NO <sub>x</sub> (ppm)	140	180	220
50	80	O <sub>2</sub> (%)	18.0	20.0	22.0

## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T. Nambu (JICA)  
F. Goodarz (AQCC)

Facility Name : Room heater (NG)

Measuring Date : 19, Feb, 1997

Item	Measuring Result	
CO <sub>2</sub> Concentration	2.2	%
O <sub>2</sub> Concentration	16.7	%
CO Concentration	25	ppm
NO <sub>x</sub> Concentration	21.3	ppm
SO <sub>x</sub> Concentration	0	ppm
Emission factor CO	32.2	g/Gj
Emission factor NO <sub>x</sub>	45.0	g/Gj
Emission factor Sox	0	g/Gj

Measurement of component in flue gas

Measuring time	14:15	15:23
CO <sub>2</sub> concentration (%)	2.2	2.2
O <sub>2</sub> concentration (%)	16.2	16.4
CO concentration (ppm)	25	25

Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
14:20	19.0	0	17.0
14:30	19.0	0	17.0
14:40	22.6	0	16.4
14:50	21.6	0	16.8
15:00	22.4	0	16.7
15:10	22.0	0	16.7
15:20	22.6	0	16.6
Mean	21.3	0	16.7




Fuel Combustion Analysis Work Sheet

	Item	Remark
1	Type	ZARIEF Room heater Type1000A
2	Fuel type	NG
3	Flow rate	0.60 m <sup>3</sup> /h
4	Others	Heating Value Minimum 1500 Kcal/h Maximum 8500 Kcal/h

Calculation of Emission factor

$$EF = C \text{ (ppm)} \times \frac{CO_{2th}}{CO_2} \times G_o \times \frac{A}{22.4} \times 10^{-3} \times \frac{1}{Hh} \quad (\text{g/Gj})$$

$CO_{2th} \text{ (%) = 12.23 (NG)}$   
 $G_o = 8.74 \text{ (NG)}$   
 $A = 46 \text{ (NO}_x\text{)}, 64 \text{ (SO}_x\text{)}, 28 \text{ (CO)}$   
 $Hh = 0.0472 \text{ (NG} \cdot \text{Gj/m}^3\text{)}$   
 $EF = \text{Emission factor}$



## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T.Nambu (JICA)  
F. Goodarz (AQCC)

Facility Name : Stove (NG) \_\_\_\_\_

Measuring Date : 22, Feb, 1997 \_\_\_\_\_

Item	Measuring Result	
CO <sub>2</sub> Concentration	0.64	%
O <sub>2</sub> Concentration	20.5	%
CO Concentration	N D	ppm
NO <sub>x</sub> Concentration	3.2	ppm
SO <sub>x</sub> Concentration	2.1	ppm
Emission factor CO	0	g/GJ
Emission factor NO <sub>x</sub>	23.3	g/GJ
Emission factor Sox	21.2	g/GJ

Measurement of component in flue gas

Measuring time	11:36	12:50
CO <sub>2</sub> concentration (%)	0.64	0.64
O <sub>2</sub> concentration (%)	20.5	20.5
CO concentration (ppm)	N D	N D

Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
11:43	3.8	2.0	20.5
11:53	3.0	1.0	20.5
12:03	4.0	2.1	20.5
12:13	3.0	2.0	20.5
12:23	3.0	2.1	20.5
12:33	3.0	2.1	20.5
12:43	2.8	2.1	20.5
Mean	3.2	2.1	20.5


Fuel Combustion Analysis Work Sheet

	Item	Remark
1	Type	MANDANA Stove
2	Fuel type	NG
3	Flow rate	0.25 m <sup>3</sup> /h
4	Others	Heating Value Bigger    2500 BIG       2200 Medium   1400

Calculation of Emission factor

$$EF = C \text{ (ppm)} \times \frac{CO_{2th}}{CO_2} \times G_o \times \frac{A}{22.4} \times 10^{-3} \times \frac{1}{Hh} \quad (\text{g/Gj})$$

CO<sub>2th</sub> (%) = 12.23 (NG)  
 G<sub>o</sub> = 8.74 (NG)  
 A = 46 (Nox), 64 (Sox), 28 (CO)  
 Hh = 0.0472 (NG · Gj/m<sup>3</sup>)  
 EF = Emission factor



ICH  
 0.0060  
 SCH 0.01500  
 SCH 0.01500  
 SCH 0.00900  
 300mm-H

Feb. 22 12:00.

NO<sub>2</sub> (PPM)  
 SO<sub>2</sub> (PPM)

0	Sp	Sp	SO <sub>2</sub> (PPM)	110	110	240
0	Sp	PP	NO <sub>2</sub> (PPM)	110	160	120
0	Sp	20.0	O <sub>2</sub> (%)	110	240	250

## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T. Nambu (JICA)  
F. Goodarz (AQCC)

Facility Name : Stove (LPG)

Measuring Date : 22, Feb, 1997

Item	Measuring Result	
CO <sub>2</sub> Concentration	0.22	%
O <sub>2</sub> Concentration	20.6	%
CO Concentration	N D	ppm
NO <sub>x</sub> Concentration	2.0	ppm
SO <sub>x</sub> Concentration	0.1	ppm
Emission factor CO		g/Gj
Emission factor NO <sub>x</sub>		g/Gj
Emission factor Sox		g/Gj

Measurement of component in flue gas

Measuring time	13:50	15:00
CO <sub>2</sub> concentration (%)	0.22	0.22
O <sub>2</sub> concentration (%)	20.6	20.6
CO concentration (ppm)	N D	N D

Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
13:57	2.0	0.0	20.6
14:07	2.0	0.1	20.6
14:17	2.0	0.1	20.6
14:27	2.0	0.2	20.6
14:37	2.0	0.2	20.6
14:47	2.0	0.1	20.6
14:57	2.1	0.2	20.6
Mean	2.0	0.1	20.6



Fuel Combustion Analysis Work Sheet


	Item	Remark
1	Type	
2	Fuel type	LPG
3	Flow rate	0.18 Kg/h
4	Others	

Calculation of Emission factor

$$EF = C \text{ (ppm)} \times \frac{CO_2 th}{CO_2} \times G_o \times \frac{A}{22.4} \times 10^{-3} \times \frac{1}{Hh} \quad (\text{g/Gj})$$

$CO_2 th \text{ (\%)} =$  (LPG)  
 $G_o =$  (LPG)  
 $A =$  46 (Nox) , 64 (Sox) , 28 (CO)  
 $Hh =$  (LPG · Gj/Kg)  
 $EF =$  Emission factor

Feb. 22 15100.



# Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T. Nambu (JICA)  
F. Goodarz (AQCC)

Facility Name : Boiler house

Measuring Date : 20, Feb, 1997

Item	Measuring Result	
CO <sub>2</sub> Concentration	2.1	%
O <sub>2</sub> Concentration	15.8	%
CO Concentration	7750	ppm
NO <sub>x</sub> Concentration	5.9	ppm
SO <sub>x</sub> Concentration	-	ppm
Emission factor CO	10200	g/Gj
Emission factor NO <sub>x</sub>	12.5	g/Gj
Emission factor Sox	-	g/Gj

Measurement of component in flue gas

Measuring time	10:00	11:20
CO <sub>2</sub> concentration (%)	2.2	2.0
O <sub>2</sub> concentration (%)	15.8	15.8
CO concentration (ppm)	7300	7800

Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
10:12	5.6	-	15.8
10:18	6.0	-	15.8
10:24	6.0	-	15.8
10:30	6.0	-	15.8
10:36	6.0	-	15.8
Mean	21.3	0	16.7


Fuel Combustion Analysis Work Sheet

	Item	Remark
1	Type	AZARPAD Boiler
2	Fuel type	NG
3	Flow rate	6.30 m <sup>3</sup> /h
4	Others	Concentration of Sox was not available because of high content of CO and CH <sub>4</sub> etc. in the flue gas.

Calculation of Emission factor

$$EF = C \text{ (ppm)} \times \frac{CO_{2th}}{CO_2} \times G_o \times \frac{A}{22.4} \times 10^{-3} \times \frac{1}{Hh} \quad (\text{g/Gj})$$

$CO_{2th} \text{ (%) = 12.23 (NG)}$   
 $G_o = 8.74 \text{ (NG)}$   
 $A = 46 \text{ (Nox)}, 64 \text{ (Sox)}, 28 \text{ (CO)}$   
 $Hh = 0.0472 \text{ (NG} \cdot \text{Gj/m}^3\text{)}$   
 $EF = \text{Emission factor}$



## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T.Nambu (JICA)

F. Goodarz (AQCC)

S. Hossini (AQCC)

Factory / Facility Name: Cement factory No. 4

Address / Location : Khavaran road-Tehran Cement factory  
district 15

Measuring Date : 25 . Feb . 1997

Item	Measuring Result	
Flow rate of wet flue gas	241000	m <sup>3</sup> <sub>N</sub> /h
Flow rate of dry flue gas	210000	m <sup>3</sup> <sub>N</sub> /h
Temperature of flue gas	145	°C
CO <sub>2</sub> Concentration	16.0	%
O <sub>2</sub> Concentration	10.6	%
CO Concentration	0.22	%
Dust Concentration	0.32	g/m <sup>3</sup> <sub>N</sub>
NO <sub>x</sub> Concentration	307	ppm
SO <sub>x</sub> Concentration	4	ppm

Measurement of water content in flue gas

Measuring time		10:26 ~ 10:31		10:33 ~ 10:38	
Gas volume	(V <sub>m</sub> , L)	10.0		10.0	
Gas meter temp.	(θ <sub>m</sub> , °C)	20.5		20.5	
Moisture absorption tube	m <sub>1</sub>	107.110	104.912	110.152	118.121
	m <sub>2</sub>	106.130	104.912	109.220	118.121
	m <sub>1</sub> -m <sub>2</sub>	0.980		0.952	
Moisture content	(X <sub>w</sub> , %)	12.9		12.6	
Mean	(X <sub>w</sub> , %)	12.8			

Measurement of component in flue gas

Measuring time	10:45
CO <sub>2</sub> concentration (%)	16.0
O <sub>2</sub> concentration (%)	10.6
CO concentration (%)	0.22
r <sub>o</sub> (kgf/m <sup>3</sup> )	1.32
Air ratio	2.17

Pa= 673 mmHg





Measurement of dust concentration

Measuring time		11:55 ~ 12:04	12:08 ~ 12:15
Gas meter temp. (°C)		22.9	22.0
Gas volume (V <sub>m</sub> , L)		111.6	74.7
Gas volume (V <sub>m</sub> ', L <sub>N</sub> )		91.0	61.1
Filter weight	Sampled (md2, g)	0.1217	0.1119
	Unsampled (md1, g)	0.0932	0.0924
Collected dust (md, g)		0.0285	0.0195
Dust concentration (g/m <sup>3</sup> <sub>N</sub> )		0.31	0.32
Mean (C <sub>N</sub> , g/m <sup>3</sup> <sub>N</sub> )		0.32	

Flow rate of equal velocity aspiration


Inner diameter of suction nozzle (d, mm) = 6					
No	Point	Flow rate (L/min)	No	Point	Flow rate (L/min)
1	1	17.1	7		
2	2	15.5	8		
3	3	14.5	9		
4			10		
5			11		
6			12		

Measurement of NOx, SOx and O<sub>2</sub>


Sampling Time	NOx (ppm)	SOx (ppm)	O <sub>2</sub> (%)
13:40	280	4	10.9
13:50	291	4	10.7
14:00	284	3	10.7
14:10	302	3	10.6
14:20	331	4	10.6
14:30	330	4	10.4
14:40	330	4	10.6
Mean	307	4	10.6

Measuring point

Comment



$A = 7.069 \text{ m}^2$



## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T.Nambu (JICA)

F.Goodarz (AQCC)

S.Hossini (AQCC)

Factory / Facility Name: Cement factory No.6

Address / Location : Khavaran road-Tehran Cement factory  
district 15

Measuring Date : 26 . Feb . 1997

Item	Measuring Result	
Flow rate of wet flue gas	569000	m <sup>3</sup> <sub>N</sub> /h
Flow rate of dry flue gas	506000	m <sup>3</sup> <sub>N</sub> /h
Temperature of flue gas	158	°C
CO <sub>2</sub> Concentration	11.4	%
O <sub>2</sub> Concentration	11.6	%
CO Concentration	N.D	ppm
Dust Concentration	0.37	g/m <sup>3</sup> <sub>N</sub>
NO <sub>x</sub> Concentration	258	ppm
SO <sub>x</sub> Concentration	1 >	ppm

Measurement of water content in flue gas

Measuring time		9:50 ~ 9:53		9:55 ~ 10:00	
Gas volume	(V <sub>m</sub> , L)	10.0		10.0	
Gas meter temp.	(θ <sub>m</sub> , °C)	18.8		18.8	
Moisture absorption tube	m,1	106.930	104.850	108.890	106.570
	m,2	106.256	104.824	108.152	106.362
	m,1-m,2	0.700		0.946	
Moisture content	(X <sub>w</sub> , %)	9.5		12.4	
Mean	(X <sub>w</sub> , %)	11.0			

Measurement of component in flue gas

Measuring time	10:02
CO <sub>2</sub> concentration (%)	11.4
O <sub>2</sub> concentration (%)	14.8
CO concentration (ppm)	N. D
ρ <sub>o</sub> (kgf/m <sup>3</sup> )	1.29
Air ratio	2.31

Pa= 672 mmHg

Measurement of velocity

Measuring time 10:11 ~ 10:18		Pitot tube coefficient = 0.850			
Point	h (mmAq)	Ps (mmAq)	r (kgf/m <sup>3</sup> )	Dt (°C)	V (m/s)
1	8.5	-22	0.726	158	12.9
2	12.0	-22	0.726	158	15.4
3	15.0	-22	0.726	158	17.2
4	12.0	-22	0.726	158	15.4
5	9.5	-22	0.726	158	13.7
6	9.0	-22	0.726	158	13.3
7	5.5	-22	0.726	158	10.4
8	8.0	-22	0.726	158	12.5
9	10.0	-22	0.726	158	14.0
10	13.0	-22	0.726	158	16.0
11	13.0	-22	0.726	158	16.0
12	12.0	-22	0.726	158	15.4
	Mean	-22	0.726	158	14.3

Measurement of dust concentration

Measuring time		11:08 ~ 11:12	11:15 ~ 11:20
Gas meter temp. (°C)		20.1	20.5
Gas volume (V <sub>G</sub> , L)		37.9	56.1
Gas volume (V <sub>m</sub> <sup>'</sup> , L <sub>N</sub> )		31.1	46.0
Filter	Sampled (m <sub>d2</sub> , g)	0.1050	0.1106
weight	Unsampled (m <sub>d1</sub> , g)	0.0928	0.0950
Collected dust (m <sub>d</sub> , g)		0.0122	0.0156
Dust concentration (g/m <sup>3</sup> <sub>N</sub> )		0.39	0.34
Mean (C <sub>N</sub> , g/m <sup>3</sup> <sub>N</sub> )		0.37	

Flow rate of equal velocity aspiration

Inner diameter of suction nozzle (d, mm) = 6					
No	Point	Flow rate (L/min)	No	Point	Flow rate (L/min)
1	1	13.8	7		
2	2	11.4	8		
3	3	11.8	9		
4			10		
5			11		
6			12		




Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>


Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
11:33	190	0	14.9
11:43	290	0	14.1
11:53	238	0	14.3
12:03	275	0	14.8
12:13	268	0	15.3
12:23	282	0	15.0
12:33	265	0	15.0
Mean	258	0	14.8

Measuring point

Comment



$A = 19.635 \text{ m}^2$



## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T.Nambu (JICA)

F. Goodarz (AQCC)

S. Hossini (AQCC)

Factory / Facility Name: Cement factory No. 7

Address / Location : Moshirieh-Cement Co-District15

Measuring Date : 6 . Mar . 1997

Item	Measuring Result	
Flow rate of wet flue gas	283000	m <sup>3</sup> <sub>N</sub> /h
Flow rate of dry flue gas	241000	m <sup>3</sup> <sub>N</sub> /h
Temperature of flue gas	126	°C
CO <sub>2</sub> Concentration	14.5	%
O <sub>2</sub> Concentration	10.8	%
CO Concentration	38	ppm
Dust Concentration	0.14	g/m <sup>3</sup> <sub>N</sub>
NO <sub>x</sub> Concentration	252	ppm
SO <sub>x</sub> Concentration	1 >	ppm

Measurement of water content in flue gas

Measuring time		10:00 ~ 10:14		10:14 ~ 10:19	
Gas volume (V <sub>m</sub> , L)		10.0		10.0	
Gas meter temp. (θ <sub>m</sub> , °C)		21.6		21.6	
Moisture absorption tube	m,1	105.815	107.090	108.212	108.537
	m,2	104.715	107.090	106.950	108.535
	m,1-m,2	1.100		1.264	
Moisture content (X <sub>w</sub> , %)		14.0		15.8	
Mean (X <sub>w</sub> , %)		14.9			


Measurement of component in flue gas

Measuring time	10:22
CO <sub>2</sub> concentration (%)	14.5
O <sub>2</sub> concentration (%)	10.8
CO concentration (ppm)	38
ρ <sub>o</sub> (kgf/m <sup>3</sup> )	1.29
Air ratio	2.19

Pa= 663 mmHg

Measurement of velocity

Measuring time 10:40 ~ 10:50			Pitot tube coefficient = 0.850		
Point	h (mmAq)	Ps (mmAq)	r (kgf/m <sup>3</sup> )	Dt (°C)	V (m/s)
1	12.0	-20	0.768	126	14.9
2	12.0	-20	0.768	126	14.9
3	10.5	-20	0.768	126	13.9
4	7.5	-20	0.768	126	11.8
5	9.5	-20	0.768	126	13.2
	Mean	-20	0.768	126	13.7



## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T.Nambu (JICA)

F. Goodarz (AQCC)

S. Hossini (AQCC)

Factory / Facility Name: Tehran refinery 2H-101

Address / Location : Qom road-Tehran refinery

District Boundary No20

Measuring Date : 1 . Mar . 1997

Item	Measuring Result	
Flow rate of wet flue gas	976000	m <sup>3</sup> <sub>N</sub> /h
Flow rate of dry flue gas	880000	m <sup>3</sup> <sub>N</sub> /h
Temperature of flue gas	429	°C
CO <sub>2</sub> Concentration	6.8	%
O <sub>2</sub> Concentration	9.4	%
CO Concentration	N. D	ppm
Dust Concentration	0.028	g/m <sup>3</sup> <sub>N</sub>
NO <sub>x</sub> Concentration	111	ppm
SO <sub>x</sub> Concentration	521	ppm

Measurement of water content in flue gas

Measuring time		11:47 ~ 11:51		11:55 ~ 12:00	
Gas volume	(V <sub>m</sub> , L)	10.0		10.0	
Gas meter temp.	(θ <sub>m</sub> , °C)	13.2		13.2	
Moisture absorption tube	m,1	108.795	106.995	107.865	108.108
	m,2	108.126	106.908	107.120	108.082
	m,1-m,2	0.716		0.771	
Moisture content	(X <sub>w</sub> , %)	9.5		10.1	
Mean	(X <sub>w</sub> , %)	9.8			

Measurement of component in flue gas

Measuring time	11:45
CO <sub>2</sub> concentration (%)	6.8
O <sub>2</sub> concentration (%)	9.4
CO concentration (ppm)	N. D.
ρ <sub>o</sub> (kgf/m <sup>3</sup> )	1.27
Air ratio	1.73

Pa= 678 mmHg





Measurement of dust concentration

Measuring time		12:44 ~ 13:00	13:06 ~ 13:22
Gas meter temp. (°C)		16.5	15.9
Gas volume (V <sub>m</sub> , L)		185.3	164.8
Gas volume (V <sub>m'</sub> , L <sub>N</sub> )		155.8	138.8
Filter weight	Sampled (md <sub>2</sub> , g)	0.0976	0.0989
	Unsampled (md <sub>1</sub> , g)	0.0939	0.0945
Collected dust (md, g)		0.0037	0.0044
Dust concentration (g/m <sup>3</sup> <sub>N</sub> )		0.024	0.032
Mean (C <sub>N</sub> , g/m <sup>3</sup> <sub>N</sub> )		0.028	

Flow rate of equal velocity aspiration


Inner diameter of suction nozzle (d, mm) = 10					
No	Point	Flow rate (L/min)	No	Point	Flow rate (L/min)
1	1	10.4	7		
2	2	13.1	8		
3	3	13.1	9		
4			10		
5			11		
6			12		

Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
13:32	115	455	9.3
13:42	113	523	9.3
13:52	108	497	9.8
14:02	110	535	9.3
14:12	111	547	9.1
14:22	111	543	9.3
14:32	111	545	9.3
Mean	111	521	9.3

Measuring point


Comment



$A = 10.179 \text{ m}^2$

1CH 0.0000  
 3CH 0.3737V  
 2CH 0.5353V  
 1CH 0.2197V  
 300mm/H

Mar. 01 14:00



## Analyzed Data Sheet for Stationary Emission Sources

Analyzer : Messrs T.Nambu (JICA)

F. Goodarz (AQCC)

S. Hossini (AQCC)

Factory / Facility Name: Tehran refinery Steam boiler

Address / Location : Qom road-Tehran refinery

District Boundary No20

Measuring Date : 2 . Mar . 1997

Item	Measuring Result	
Flow rate of wet flue gas	127000	m <sup>3</sup> /h
Flow rate of dry flue gas	112000	m <sup>3</sup> /h
Temperature of flue gas	460	°C
CO <sub>2</sub> Concentration	12.4	%
O <sub>2</sub> Concentration	2.8	%
CO Concentration	750	ppm
Dust Concentration	-	g/m <sup>3</sup>
NO <sub>x</sub> Concentration	186	ppm
SO <sub>x</sub> Concentration	778	ppm

Measurement of water content in flue gas

Measuring time		9:28 ~ 9:32		9:33 ~ 9:38	
Gas volume (V <sub>m</sub> , L)		10.0		10.0	
Gas meter temp. (θ <sub>m</sub> , °C)		23.0		23.0	
Moisture absorption tube	m.1	107.870	108.780	108.960	107.780
	m.2	106.905	108.776	108.090	107.780
	m.1-m.2	0.969		0.870	
Moisture content (X <sub>w</sub> , %)		12.7		11.7	
Mean (X <sub>w</sub> , %)		12.2			

Measurement of component in flue gas

Measuring time	9:43
CO <sub>2</sub> concentration (%)	12.4
O <sub>2</sub> concentration (%)	2.8
CO concentration (ppm)	750
r <sub>o</sub> (kgf/m <sup>3</sup> )	1.28
Air ratio	1.14

Pa= 677 mmHg

Measurement of velocity

Measuring time 10:22 ~ 10:30		Pitot tube coefficient = 0.850			
Point	h (mmAq)	Ps (mmAq)	r (kgf/m <sup>3</sup> )	Dt (°C)	V (m/s)
1	0.9	-32	0.377	460	5.8
2	4.8	-32	0.377	460	13.4
3	3.2	-32	0.377	460	11.0
4	7.0	-32	0.377	460	16.2
5	0.2	-32	0.377	460	2.7
6	7.0	-32	0.377	460	16.2
7	7.6	-32	0.377	460	16.9
8	12.6	-32	0.377	460	21.8
	Mean	-32	0.377	460	13.0

Measurement of dust concentration

Measuring time		10:42 ~ 10:52	10:54 ~ 11:04
Gas meter temp. (°C)		27.0	25.3
Gas volume (V <sub>m</sub> , L)		64.1	79.6
Gas volume (V <sub>m'</sub> , L <sub>N</sub> )		51.9	64.8
Filter weight	Sampled (md2, g)	-	-
	Unsampled (md1, g)	-	-
Collected dust (md, g)		-	-
Dust concentration (g/m <sup>3</sup> <sub>N</sub> )		-	-
Mean (C <sub>N</sub> , g/m <sup>3</sup> <sub>N</sub> )		-	-

Flow rate of equal velocity aspiration

Inner diameter of suction nozzle (d, mm) = 6					
No	Point	Flow rate (L/min)	No	Point	Flow rate (L/min)
1	5	2.0	7		
2	6	9.6	8		
3			9		
4			10		
5			11		
6			12		




Measurement of NO<sub>x</sub>, SO<sub>x</sub> and O<sub>2</sub>

Sampling Time	NO <sub>x</sub> (ppm)	SO <sub>x</sub> (ppm)	O <sub>2</sub> (%)
11:32	185	700	2.0
11:42	188	780	2.0
11:52	185	790	1.9
12:02	185	793	2.0
12:12	186	795	2.0
12:22	185	807	1.9
12:32	185	780	2.0
Mean	186	778	2.0

Measuring point

Comment



Dust concentration was not available because the teflon packing of the instrument was melted due to the high temperature of flue gas, ca. 450°C.

$$A = 8.217 \text{ m}^2$$

