

**APPENDIX 2**

**TO SUPPORTING REPORT E**

**COMPARISON OF**

**ALTERNATIVE WATER**

**SUPPLY SCHEMES**

# **COMPARISON OF ALTERNATIVE WATER SUPPLY SCHEMES**

## **TABLE OF CONTENTS**

<b>KLIPVOOR EAST AND MORETELE NORTH SUPPLY BLOCKS</b>	<b>A-1</b>
<b>ALTERNATIVE 1 :</b>	
COST SUMMARY .....	A-4
SCHEMATICS.....	A-6
<b>ALTERNATIVE 2 :</b>	
COST SUMMARY.....	A-9
SCHEMATICS.....	A-11
<b>ALTERNATIVE 3 :</b>	
COST SUMMARY.....	A-14
SCHEMATICS.....	A-16
<b>MORETELE 2.....</b>	<b>A-20</b>
<b>ALTERNATIVE 1 :</b>	
COST SUMMARY.....	A-23
SCHEMATICS (EXISTING).....	A-25
SCHEMATICS (PROPOSED).....	A-31
<b>ALTERNATIVE 2 :</b>	
COST SUMMARY.....	A-37
SCHEMATICS (EXISTING).....	A-39
SCHEMATICS (PROPOSED).....	A-46
<b>ALTERNATIVE 3 :</b>	
COST SUMMARY.....	A-53
SCHEMATICS (EXISTING).....	A-55
SCHEMATICS (PROPOSED).....	A-62

**NOTE : THERE ARE CURRENTLY NO SURFACE WATER INFRASTRUCTURE  
IN KLIPVOOR EAST AND MORETELE NORTH SUPPLY BLOCKS.**

**COMPARISON OF ALTERNATIVE SUPPLY  
SCHEMES TO KLIPVOOR EAST AND  
MORETELE NORTH SUPPLY BLOCKS**

**(KLIPVOOR SUPPLY AREA)**

## **KLIPVOOR SUPPLY AREA - TECHNICAL ALTERNATIVES**

### **1 Technical Alternatives**

With regard to the supply to Klipvoor East and Moretele North Supply Blocks in Klipvoor Supply Area, three technical alternatives were investigated as follows:

Alternative 1: Both Supply Blocks are supplied from a proposed new water treatment works at Klipvoor Dam.

Alternative 2: Both Supply Blocks are supplied from Temba WTW via a new pipeline laid parallel to the existing MW's Temba - Warmbaths/Nylstroom pipeline.

Alternative 3: This alternative is a combination of the above two alternatives in that the supply to the two Blocks is split between a new water treatment at Klipvoor Dam supplying the Klipvoor East Supply Block while the Moretele North Supply Block is supplied via a new pipeline branching off the existing MW's Temba - Warmbaths/Nylstroom pipeline.

Alternative 1 comprises a water treatment plant below Klipvoor Dam from which water is pumped in an easterly direction to Lebotlwane, Mokobjane, Tlhloewe and Bollantlokwe. At Bollantlokwe the pipeline splits with water being pumped through one branch to Slagboom, Transactie/Ngobi, Swartboom, Mogholwanong and Makekeng. The other branch runs southwards under gravity to Sutelong from where it is pumped southwards to Rantebeng and Makgabetslwane. At Makgabetslwane, the pipeline again splits with a pumpline continuing in a south-westerly direction to Shakung, Bufflesdoorn, Moletswane and Dipompong; and a gravity line continuing in a south-easterly direction to Rabosula, Ga-Moti, Garantlapane and Botshabelo.

Alternative 2 has the same links as Alternative 1. The source however is Temba WTW and a new Temba - Makakeng pipeline which is connected to the Makakeng - Slagboom branch will supply water in the opposite direction up to a new regional reservoir at Bollantlokwe which then feeds the rest of the network.

### **2 Planning Schematics**

For each of the above three alternatives, planning schematics were prepared on spreadsheets; a hydraulic analysis based on the projected 2015 primary demand was carried out; and the required capital works and their costs were estimated. The schematics are compiled for each alternative and included in this appendix. Details of the required works and costs are provided on a Cost Summary Sheet for each alternative.

### **3 Conclusions**

A comparative summary of the capital expenditure and operation costs required for each alternative scheme is shown in the table below.

<b>Capital/Operation Cost</b>	<b>Alternative 1</b>	<b>Alternative 2</b>	<b>Alternative 3</b>
Bulk Infrastructure Cost	R37.744 million	R62.599 million	R40.272 million
Third Tier Infrastructure Cost	R27.501 million	R27.121 million	R27.686 million
Total Capital Cost	R65.245 million	R89.720 million	R67.958 million
Annual Pumping Cost	R0.120 million	R0.170 million	R0.119 million

It can be seen from the table that Alternative 1 and Alternative 3 are very close to each other. Alternative 3 however depends on the Magalies Water's existing Temba - Warmbaths/Nylstroom pipeline, and its implementation is likely to result in this pipeline reaching its full capacity and requiring augmentation earlier than planned.

Klipvoor West Supply Block is located west of Klipvoor Dam and it is proposed that it be supplied entirely from the new water treatment works at the Dam. This also gives an advantage to Alternative 1 in terms of operation and maintenance of the proposed new water works.


From the above considerations, Alternative 1 has been selected as the preferred alternative among the three.

## COST SUMMARY FOR INFRASTRUCTURE

NAME OF SUPPLY AREA :	KLIPVOOR ALT 1 SUPPLIED FROM KLIPVOOR	
INCLUDING SUPPLY BLOCKS :	Moretele North Klipvoor East	
POPULATION SERVED (2015) :	43,717	
AADD in mcm/a (2015) :	0.75	
BULK COST :	QUANTITY	COST (R million)
Water Purification Works	Kl/d (SDD)	
Klipvoor	3128	R5.938
Pump Stations	Kl/d (SDD)	
A : Capital Cost		
Klipvoor	3,127	R0.376
Slagboom	1,171	R0.186
Sutelong	0.889	R0.143
Sub-total	4,299	R0.705
B : Annual Energy Cost (Not Incl'd with Total)		
Klipvoor		R0.076
Slagboom		R0.028
Sutelong		R0.016
Sub-total		R0.120
Reservoirs (Regional)	Ml	
Sutelong	1	R0.518
Bollantlokwé	0.841	R0.453
Sub-total	1.841	R0.971
Pipelines (Bulk)	km	
110 dia	79.9	R7.108
125 dia	13.5	R1.728
140 dia	7.3	R1.000
160 dia	31	R6.032
200 dia	1.6	R0.510
Total		R16.378
Sub Total Construction Cost		R23.992
Engineering Fees (15 %)		R3.599
VAT (14 %)		R3.863
Project Contingency (20%)		R6.291
<b>TOTAL : Bulk Cost</b>		<b>R37.744</b>
<b>Bulk Cost per Capita (Rands)</b>		<b>R863.376</b>

<b>KLIPVOOR</b>		
<b>SECONDARY COST :</b>	<b>QUANTITY</b>	<b>COST (R million)</b>
Reservoirs (Service)	Ml	
Klipvoor North and Moretele bloc	3.74	R2,723
Water Towers	Ml	
	NIL	NIL
Pump Stations (Secondary)	Kl/d	
A : Capital Cost	NIL	NIL
B : Annual Energy Cost (Not Incl'd with Total)	NIL	NIL
Pipelines (Secondary)	km	
Reticulation	km	
Moretele		R4.379
Klipvoor North		R10.379
Sub-total		R14.758
<b>Sub Total Construction Cost</b>		<b>R17.481</b>
<b>Engineering Fees (15 %)</b>		<b>R2.622</b>
<b>VAT (14 %)</b>		<b>R2.814</b>
<b>Project Contingency (20%)</b>		<b>R4.584</b>
<b>TOTAL : Secondary Cost</b>		<b>R27.501</b>
<b>Secondary Cost per Capita (Rands)</b>		<b>R629.071</b>
<b>GRAND TOTAL COST</b>		<b>R65.245</b>
<b>Grand Total Cost per Capita (R)</b>		<b>R1,492.447</b>

Kieweenaw supplying Marquette North and Keweenaw East (proposed planning to meet 2015 demand)  
 Alternative 1  
 107  
 14-Oct-96



卷之三

۱۷۲

Project Name	Project ID	Project Status	Project Manager	Project Description
Project A	PJ-A-001	In Progress	John Doe	Software Development
Project B	PJ-B-002	Completed	Jane Smith	System Upgrade
Project C	PJ-C-003	On Hold	Mike Johnson	Infrastructure
Project D	PJ-D-004	Planned	Sarah Lee	Market Research

Parameter	Value	Description
Number of workers	100	Number of workers in the company
Hours worked	100 hours	Number of hours worked per week
Wage rate	\$1000/mo	Wage rate per hour
Number of managers	20	Number of managers in the company
Number of executives	5	Number of executives in the company
Number of shareholders	10	Number of shareholders in the company
Number of customers	100	Number of customers per month
Revenue per customer	\$100	Average revenue per customer
Cost per customer	\$50	Average cost per customer
Profit per customer	\$50	Average profit per customer

National Data  
Year


Geometric time	Geometric range
Carrie	110 nm
Emmett	110 nm
Lamont	110 nm
Levi	110 nm

۷۰

00	00000000000000000000000000000000	00000000000000000000000000000000	00000000000000000000000000000000
00	00000000000000000000000000000000	00000000000000000000000000000000	00000000000000000000000000000000

2004

Rs.600



COST SUMMARY FOR INFRASTRUCTURE		
NAME OF SUPPLY AREA :	KLIPVOOR ALT 2 SUPPLIED FROM TEMBA	
INCLUDING SUPPLY BLOCKS :	Moretele North Klipvoor East	
POPULATION SERVED (2015) :	43,717	
AADD in mcm/a (2015) :	0.75	
BULK COST :	QUANTITY	COST (R million)
Water Purification Works	Kl/d (SDD)	
Temba	3128	R1.032
Pump Stations	Kl/d (SDD)	
<b>A : Capital Cost</b>		
Temba	3,127	R0.317
Makakeng	2,875	R0.439
Sutelong	0.889	R0.143
Sub-total	6,003	R0.899
<b>B : Annual Energy Cost (Not Incl'd with Total)</b>		
Temba		R0.060
Makakeng		R0.094
Sutelong		R0.016
Sub-total		<b>R0.170</b>
Reservoirs (Regional)	Ml	
Makakeng	4.17	R1.551
Slagboom	1.336	R0.646
Sutelong	1.001	R0.518
Sub-total	6.507	R2.715
Pipelines (Bulk)	km	
110 dia	68.2	R6.069
125 dia	17.5	R2.176
160 dia	15	R3.250
200 dia	35.1	R23.650
Total		<b>R35.145</b>
<b>Sub Total Construction Cost</b>		<b>R39.791</b>
<b>Engineering Fees (15 %)</b>		<b>R5.969</b>
<b>VAT (14 %)</b>		<b>R6.406</b>
<b>Project Contingency (20%)</b>		<b>R10.433</b>
<b>TOTAL : Bulk Cost</b>		<b>R62.599</b>

<b>Bulk Cost per Capita (Rands)</b>		<b>R1,431.919</b>
<b>KLIPVOOR ALT 2</b>		
<b>SUPPLIED FROM TEMBA</b>		
<b>SECONDARY COST :</b>	<b>QUANTITY</b>	<b>COST (R million)</b>
Reservoirs (Service)	Ml	
Klipvoor North and Moretele blocks	2.3899	<b>R2.481</b>
Water Towers	Ml	
	NIL	<b>NIL</b>
Pump Stations (Secondary)	Kl/d	
A : Capital Cost	NIL	<b>NIL</b>
<b>B : Annual Energy Cost (Not Incl'd with Total)</b>	<b>NIL</b>	<b>NIL</b>
Pipelines (Secondary)	km	
Reticulation	km	
Moretele		<b>R4.379</b>
Klipvoor North		<b>R10.380</b>
Sub-total		<b>R14.759</b>
<b>Sub Total Construction Cost</b>		<b>R17.240</b>
<b>Engineering Fees (15 %)</b>		<b>R2.586</b>
<b>VAT (14 %)</b>		<b>R2.776</b>
<b>Project Contingency (20%)</b>		<b>R4.520</b>
<b>TOTAL : Secondary Cost</b>		<b>R27.121</b>
<b>Secondary Cost per Capita (Rands)</b>		<b>R620.381</b>
<b>GRAND TOTAL COST</b>		<b>R89.720</b>
<b>Grand Total Cost per Capita (R)</b>		<b>R2,052.300</b>







## COST SUMMARY FOR INFRASTRUCTURE


NAME OF SUPPLY AREA :	KLIPVOOR ALT 3	
	SPLIT SUPPLY BETWEEN KLIPVOOR AND TEMBA	
INCLUDING SUPPLY BLOCK	Moretele North	
	Klipvoor East	
POPULATION SERVED (2015)	43,717	
AADD in mcm/a (2015) :	0.75	
 <b>BULK COST :</b>	 <b>QUANTITY</b>	 <b>COST (R million)</b>
Water Purification Works	Kl/d (SDD)	
Temba (existing)	1090	R0.360
Klipvoor (new)	1989	R5.656
		R6.016
Pump Stations	Kl/d (SDD)	
 <b>A : Capital Cost</b>		
Moretele N	1.11	R0.588
Klipvoor	1.99	R0.217
Sutelong	0.86	R0.143
Slagboom	0.06	R0.007
Sub-total	4.02	R0.955
 <b>B : Annual Energy Cost (Not Incl'd with Total)</b>		
Moretele N		R0.068
Klipvoor		R0.035
Sutelong		R0.016
Slagboom		R0.000
Sub-total		R0.119
 <b>Reservoirs (Regional)</b>	 MI	
Moretele N	0.739	R0.410
Sutelong	0.981	R0.510
Sub-total	1.72	R0.920
 <b>Pipelines (Bulk)</b>	 km	
110 dia	82.5	R7.343
125 dia	20.7	R2.634
140 dia	5.6	R0.820
160 dia	15	R3.250
200 dia	13.2	R3.762
Total		R17.708
 <b>Sub Total Construction Cost</b>		R25.599
 <b>Engineering Fees (15 %)</b>		R3.840
 <b>VAT (14 %)</b>		R4.121
 <b>Project Contingency (20%)</b>		R6.712


<b>TOTAL : Bulk Cost</b>		R40.272
<b>Bulk Cost per Capita (Rands)</b>		R921.195
<b>KLIPVOOR ALT 3</b>		
<b>SPLIT SUPPLY FROM KLIPVOOR AND TEMBA</b>		
<b>SECONDARY COST :</b>	<b>QUANTITY</b>	<b>COST (R million)</b>
<b>Reservoirs (Service)</b>	MI	
Klipvoor North and Moretele blocks	3.842	R2.840
<b>Water Towers</b>	MI	
	NIL	NIL
<b>Pump Stations (Secondary)</b>	Kl/d	
<b>A : Capital Cost</b>	NIL	NIL
<b>B : Annual Energy Cost (Not Incl'd with Total)</b>	NIL	NIL
<b>Pipelines (Secondary)</b>	km	
<b>Reticulation</b>	km	
Moretele		R4.379
Klipvoor North		R10.380
<b>Sub-total</b>		R14.759
<b>Sub Total Construction Cost</b>		R17.599
<b>Engineering Fees (15 %)</b>		R2.640
<b>VAT (14 %)</b>		R2.833
<b>Project Contingency (20%)</b>		R4.614
<b>TOTAL : Secondary Cost</b>		R27.686
<b>Secondary Cost per Capita (Rands)</b>		R633.300
<b>GRAND TOTAL COST</b>		R67.958
<b>Grand Total Cost per Capita (R)</b>		R1,554.494

Kilpoor East supply area - Alt 3 (proposed planning to meet 2015 demand)

Notes:

14-Other





## Moretele North supply area supplied out of spare capacity from Temba-Warmbaths existing pipeline (proposed planning to meet 2015 demand)

## Part of Klipvoor Alternative 3

27-Dec-96

Date:

Cost Summary

		Total demand on source
	Year	MWh
BULK,	2015	0.736
Water Treatment		
Pump stations		R1.560 Million
Reservoirs		R0.410 Million
Pipelines		R0.636 Million
SECONDARY		
Reservoirs		R1.047 Million
Water towers		R0.000 Million
Redundancy		R0.370 Million
Pipelines		R0.000 Million
Total 1996 cost		R13.652 Million
Pumping costs		R0.094 Million

		Total demand on source
	Year	MWh
Excludes Nyando/Nyandam Block of		18.095
2015		
BULK,		
Water Treatment		R0.369 Million (addition to 1996)
Pump stations		R0.560 Million
Reservoirs		R0.410 Million
Pipelines		R0.636 Million
SECONDARY		
Reservoirs		R1.047 Million
Water towers		R0.000 Million
Redundancy		R0.370 Million
Pipelines		R0.000 Million
Total 1996 cost		R13.652 Million
Pumping costs		R0.094 Million

<b>Nyando/Tremba Reservoir</b>	<b>Pumping Swartboom</b>	<b>Mogothwaneong Reservoir</b>
Cap = 0.682 Ml	Cap = N/A	Cap = 0.166 Ml
TWL = m ASL	Chain = 125 mm	Dam = m ASL
BWL = 1080 m ASL	Length = 7200 m	BWL = 1060 m ASL
Required as per day	Required capacity	Required capacity
512	Balance	Balance
Estimated cost	R689.700	R130.231
Transvaal/Ngqura Demand	Swartboom Demand	Mogothwaneong Demand
Year MWh 2015 322	Year MWh 2015 81	Year MWh 2015 45
<b>Nyando/Tremba Reservoir</b>	<b>Pumping Matjiesphe</b>	<b>Pumping Matjiesphe</b>
Cap = 0.682 Ml	Cap = N/A	Cap = N/A
TWL = m ASL	Chain = 125 mm	Chain = 110 mm
BWL = 1080 m ASL	Length = 5000 m	Length = 5000 m
Required as per day	Required capacity	Required capacity
512	Balance	Balance
Estimated cost	R130.220	R44.000
Transvaal/Ngqura Demand	Swartboom Demand	Matjiesphe Demand
Year MWh 2015 322	Year MWh 2015 81	Year MWh 2015 20
<b>Gravity line Sedgepe</b>	<b>Pumping Dipseltonna</b>	<b>Pumping Dipseltonna</b>
Cap = N/A	Cap = 200	Cap = 200
Dam = 110 mm	Chain = 110 mm	Chain = 110 mm
Length = 5700 m	Length = 5000 m	Length = 5000 m
Required Capacity	Required capacity	Required capacity
26.5	Balance	Balance
Estimated cost	R507.300	R462.900
Sedgepe Reservoir	Dipseltonna Reservoir	Makgathopheng Reservoir
Cap = 0.030 Ml	Cap = 0.04 Ml	Cap = 0.04 Ml
TWL = m ASL	TWL = m ASL	TWL = m ASL
BWL = 1065 m ASL	BWL = 1100 m ASL	BWL = 1060 m ASL
Required Capacity	Required capacity	Required capacity
30	Balance	Balance
Estimated cost	R43.820	R200.100
Sedgepe Demand	Dipseltonna Demand	Makgathopheng Demand
Year MWh 2015 39	Year MWh 2015 20	Year MWh 2015 19
<b>Sedgepe Reservoir</b>	<b>Pumping Kromme River</b>	<b>Pumping Kromme River</b>
Cap = N/A	Cap = N/A	Cap = N/A
Dam = 110 mm	Chain = 110 mm	Chain = 110 mm
Length = 2300 m	Length = 2300 m	Length = 2300 m
Required Capacity	Required capacity	Required capacity
26.5	Balance	Balance
Estimated cost	R41.934	R41.934

Pump line Wambartha block total Year: 2015 Hdg: 14085	Pump line from Temba block Cap: 15238 m³/d Qdm: 450 mm Length: 33000 m Required capacity: 54913 20251 Estimated cost: R410,374	Tembabuluwa CW Pumping Station Cap: 1105 m³/d GL: 1105 m ASL Required capacity: 37964 20251 Estimated cost: R410,374
Pump line Mwakateng Cap: 1400 Diam: 210 mm Length: 5100 m Required capacity: Balance 1105 Estimated cost: R2,479,500 Annual cost: R64,740	Mwakateng Reservoir Cap: 0.338 Ml TWL: 1080 m ASL EWL: 1080 m ASL Required capacity: Balance 330 Estimated cost: R223,976	Tembabuluwa Regional Reservoir Cap: 1105 m³/d TWL: 1105 m ASL EWL: 1105 m ASL Required capacity: Balance 37964 Estimated cost: R223,976
Mwakateng Demand Year: 2015 Hdg: 1000		Tembabuluwa Cap: 1105 m³/d GL: 1105 m ASL Required Capacity: Balance 20251 Estimated cost:

**COMPARISON OF ALTERNATIVE SUPPLY  
SCHEMES TO MORETELE 2**

**(WELTEVREDEN SUPPLY AREA)**

## **WELTEVREDEN SUPPLY AREA - TECHNICAL ALTERNATIVES**

### **1 Description of Alternatives**

With regard to the supply to Weltevreden Supply Area, three technical alternatives were investigated which relate to Bloedfontein Supply Block as follows:

**Alternative 1:** Expand Weltevreden WTW and supply the entire Bloedfontein Supply Block from that works.

**Alternative 2:** Provide a pipeline from Temba WTW to supply the western end of Bloedfontein Supply Block while demands in the eastern part are met from Weltevreden as for Alternative 1.

**Alternative 3:** Construct a small new water treatment works at Rust de Winter Dam to supply the western end of Bloedfontein Supply Block while demands in the eastern part are met from Weltevreden as for Alternative 1.

The three other Supply Blocks in the Weltevreden Supply Area are unchanged under the three alternatives and so their schematics are not included here (see the Weltevreden Supply Area in Appendix 1). The alternatives address the Moretele 2 District which is currently unserved by a surface water system so most facilities proposed are new although the extent of the necessary strengthening of existing infrastructure will vary under the alternatives.

Under Alternative 1 it will be necessary to expand Weltevreden WTW to meet the demand in the target year, unless a significant change is made to the current demarcation between Weltevreden WTW and Bronkhorstspruit WTW. As described in Chapter 5, treated water from Weltevreden is pumped to Bloedfontein Regional Reservoir (16 Ml). This supplies Spitspunt Regional Reservoir (2.7 Ml) via a booster pumping station which in turn supplies the surrounding villages in western Moutse 1 by gravity. The proposed new scheme comprises strengthening the pipework and pumps supplying Bloedfontein and Spitspunt reservoirs and providing 4.7 Ml of additional capacity at Spitspunt. A new 450 mm diameter gravity pipeline is proposed running in a south-westerly direction as far as Ga-Ramantshane but booster pumps will be required subsequently at Ga-Ramantshane, Nokaneng, Bamokgoko and Phake B. The new system will extend as far as Pankop at the west end of Moretele 2 and service reservoirs will be provided as required to serve the communities en route. New service reservoirs are required in the parts of Moutse 1 to be supplied from the Spitspunt system.

In the case of Alternative 2, a new pipeline would be required from Temba WTW to be laid parallel with the existing main to Wambaths. It would branch off to supply the western end of Moretele 2 and discharge into a 5.8 Ml regional reservoir at Phake B. This would then supply the west end of Moretele 2 as far eastwards as Ga-Ramantshane. The infrastructure in the eastern part of Moretele 2 would be similar to Alternative 1 however the trunk mains and regional reservoirs would not be as large.

For Alternative 3, a new water treatment works would be constructed using water from Rust de Winter Dam. Previously the total yield from the dam has been allocated to Gauteng Province. Presently no water is being abstracted from the dam as all of the farms in the irrigation area have been bought out by the Government. The Gauteng Provincial Government is in the planning process for reestablishing farmers in the irrigation area. In order to utilise the water for primary

water supply, the water rights would have to be negotiated and the current planning would probably be affected.

## 2 Planning Schematics

For each of the above three alternatives, schematics were prepared on spreadsheets to analyse the capacity of the existing facilities and to show the new infrastructure required to meet the 2015 primary water demand. This analysis was carried out, and the required capital works were sized and the associated cost was estimated. The schematics for each alternative are compiled and included in this appendix although, as stated above, the alternatives only affect Bloedfontein Supply Block therefore schematics for the three other Blocks in the Supply Area are not included here (although the costs are included in the Cost Summary Sheets). Details of the required work and the associated costs are summarised on a Cost Summary Sheet for each alternative.

## 3 Conclusions

A comparison of the capital expenditure required for each of the alternatives is summarised in the following table.

Capital/Operation Cost	Alternative 1	Alternative 2	Alternative 3
Bulk Infrastructure Cost	R117.447 million	R141.261 million	R97.199 million
Third Tier Infrastructure Cost	R359.953 million	R359.127 million	R359.111 million
Total Capital Cost	R477.400 million	R500.388 million	R456.310 million
Annual Pumping Cost	R0.556 million	R0.276 million	R0.247 million

Although superficially Alternative 3 (utilising Rust de Winter Dam) appears to be the most favourable option, the operation and maintenance costs associated with constructing a new, small treatment works and the lack of existing water rights mitigate against this option. Also for the purpose of this simple comparison, the provision of treatment capacity was calculated using the same unit rate for both Weltevreden WTW and the possible Rust de Winter. In reality, the unit cost of constructing a new facility is likely to exceed that of extending an existing one where some existing parts may be utilised. For these reasons, Alternative 1 (supply the entire Block from Weltevreden WTW) is proposed.


### COST SUMMARY FOR INFRASTRUCTURE

NAME OF SUPPLY AREA :	WELTEVREDEN ALTERNATIVE 1	
INCLUDING SUPPLY BLOCKS :	1. Waalkraal Supply Block 2. Kameelrivier Supply Block	
POPULATION SERVED (2015) :	631,276	
AADD in mcm/a (2015) :	19.01	
BULK COST :	QUANTITY	COST (R million)
Water Purification Works	Kl/d (SDD)	
1. Weltevreden WTW	9,000	2.984
Pump Stations	Kl/d (SDD)	
A : Capital Cost		
1. Weltevreden (Bloodfontein) CWPS	9,345	1.007
2. Leuwfontein PS	675	0.053
3. Matsippe A	362	0.059
4. Spitspunt BPS	8,848	0.382
5. Tshikanossi BPS	284	0.007
6. Mmakola BPS	323	0.020
7. Radjoko BPS	270	0.007
8. Bamokgoko PS	1,616	0.206
9. Phake B	1,277	0.148
10. Ga Ramanishane (Kalkfontein)	908	0.094
11. Ramanisho	33	0.006
12. Lefifi	2,523	0.183
13. Ga Ramanishane (Lefifi)	4,221	0.412
	Sub-Total	2.584
B : Annual Energy Cost (Not incl'd with Total)		
1. Weltevreden (Bloodfontein) CWPS	-	0.255
2. Leuwfontein PS	-	0.059
3. Matsippe A	-	0.006
4. Spitspunt BPS	-	0.070
5. Tshikanossi BPS	-	0.002
6. Mmakola BPS	-	0.003
7. Radjoko BPS	-	0.002
8. Bamokgoko PS	-	0.029
9. Phake B	-	0.019
10. Ga Ramanishane	-	0.011
11. Ramanisho	-	0.002
12. Lefifi	-	0.025
13. Ga Ramanishane (Lefifi)	-	0.074
	Sub-Total	0.556
Reservoirs (Regional)	Ml	
1. Spitspunt Reservoir	4.7 Ml	1.605
2. Ga-Ramanishane	4.5 Ml	1.653
Pipelines (Bulk)	km	
1. 110 PVC	70.3	6.649
2. 125 PVC	10.2	1.336
3. 140 PVC	10.8	1.764
4. 150 PVC	0	0.000
5. 160 PVC	26.3	6.259
6. 200 PVC	40.1	11.087
7. 250 PVC	11.3	4.710
8. 300 PVC	3.6	2.009
9. 400 ST	31.7	30.418
10. 450 ST	2.8	2.797
	Sub-Total	65.929

<b>Sub Total Construction Cost</b>		<b>74.655</b>
Engineering Fees (15 %)		11.198
VAT (14 %)		12.019
Project Contingency (20%)		19.575
<b>TOTAL : Bulk Cost</b>		<b>117.447</b>
Bulk Cost per Capita (Rands)		186
<b>SECONDARY COST :</b>	<b>QUANTITY</b>	<b>COST (R million)</b>
Reservoirs (Service)	ML	
1. Bloedfontein Supply Block	14.63 (34 No)	8.368
2. Waalkraal Supply Block	10.17 (25 No)	5.812
3. Kameelrivier Supply Block	0.92 (2 No)	0.523
4. Mapoch Supply Block	0	0.000
	<b>Sub-Total</b>	<b>14.703</b>
Water Towers	ML	
N/A	NIL	NIL
Pump Stations (Secondary)	Kl/d	
A : Capital Cost	NIL	NIL
B : Annual Energy Cost (Not Incl'd with Total)	NIL	NIL
Pipelines (Secondary)	km	
Reticulation	km	
1. Bloedfontein Supply Block	NIL	99.837
2. Waalkraal Supply Block		95.056
3. Kameelrivier Supply Block		12.356
4. Mapoch Supply Block		6.651
	<b>Sub-Total</b>	<b>214.100</b>
<b>Sub Total Construction Cost</b>		<b>228.803</b>
Engineering Fees (15 %)		34.320
VAT (14 %)		36.837
Project Contingency (20%)		59.992
<b>TOTAL : Secondary Cost</b>		<b>359.933</b>
Secondary Cost per Capita (Rands)		570
<b>GRAND TOTAL COST</b>		<b>477.400</b>
Grand Total Cost per Capita (R)		756

## EASTERN ZONE : WELTEVREDEN SUPPLY AREA : EXISTING INFRASTRUCTURE (E/W/1E)

ALTERNATIVE 1 (Moretele 2 supplied from Weltevreden Purification Works only)



# EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/WB/1E)


## BLOEDFONTEIN TO SPITSPTUIN : ALTERNATIVE 1 (Moretele 2 supplied from Weltevreden Purification Works only)

Form Sheet No. E/WB/1E

2015 REGION TOTAL PFAWU	Year	MWh
	1995	1,362
	1996	1,362
	1997	2,348
	2002	2,348
	2015	2,794

REGIONAL RESERVOIR	TOTAL OF DEMAND	
	MWh	
	1995	7,438
	1996	10,411
	1997	10,411
	2002	13,027
	2015	13,027

COST SUMMARY (Rands)	
Regional Reservoir	0
Channel Rehabilitation	0
Pump Station	0
Upgrades	0
OTAL	0
Energy Costs (Rands)	14.0



Note : Pumping energy costs for main pump stations assume 1/2 load due to Pioneer (PWA) and 1/2 due to Energy (KWH).  
To that actual cost is 1/4 of that calculated for continuous pumping for a Peak Factor = 1 (ie. 1800 per day).

## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/WB/2E)

BLOEDFONTEIN TO UITVLUGT, RATHOKE AND MATTALA : ALTERNATIVES 1,2 or 3 (Modetole 2 supplied from Weltevreden Purification Works and/or Temba Purification Works or Rust De Winter Dam)


From Sheet 1m, EMBASE

SUB-MEASURE		
TOTAL OF MEASURE		
Year	1995	2002
Value	114	212
2005	333	667
2015	1999	

From Sheet 1m, EMBASE

SUB-MEASURE		
TOTAL OF MEASURE		
Year	1995	2002
Value	114	212
2005	333	667
2015	1999	

COST SUMMARY (Year 2005 \$)		
Regional Resources	0	
Service Reserves	0	
Pump Stations	0	
Reserves	0	
TOTAL	0	
Estimated Cost (Rands/Year)	0	



Note : Pumping energy costs for main pump stations assume 1/2 load due to Power (kVA) and 1/2 due to Energy (kWh), so that actual cost is 2/3 of that estimated for continuous pumping for a Peak Factor = 1.5 (ie 1600 per day).



# EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/WB/4E)

SPITSPOINT TO KWAMATABANE AND GARAHANTSHANE : ALTERNATIVE 1 (Moretele 2 supplied from Weltevreden Purification Works only)

Sheet No. E/WB/4E

REGIONAL RESERVOIR	
TOTAL DEMAND	
Yr 1995	MG 4158
1996	4158
2002	4507
2015	7079

SPUR PIPE TO GARAHANTSHANE	
GRAVITY PIPELINE (1 km)	
Cap = 100 mm	No. Poles = 10
Dist = 1 km	Length = 1 km
Required Capacity (M3/d) = 0	Year 2015 = 270
Estimated Cost (R/M3/d) = 0	Estimated Cost (R/M3/d) = 0


Kwamatabane	
SILKUNI HILL STATION	
Cap = 100 mm	No. Poles = 10
Dist = 1027 m	Length = 1027 m
Required Capacity (M3/d) = 0	Year 2015 = 270
Estimated Cost (R/M3/d) = 0	Estimated Cost (R/M3/d) = 0

Kwamatabane	
HARSHI	
Cap = 100 mm	No. Poles = 10
Dist = 15 m	Length = 15 m
Required Capacity (M3/d) = 0	Year 2015 = 270
Estimated Cost (R/M3/d) = 0	Estimated Cost (R/M3/d) = 0

Kwamatabane	
SERVICE RESERVOIR	
Cap = 100 mm	No. Poles = 10
Dist = 103 m	Length = 103 m
Required Capacity (M3/d) = 0	Year 2015 = 0
Estimated Cost (R/M3/d) = 0	Estimated Cost (R/M3/d) = 0

Kwamatabane	
SERVICE RESERVOIR	
Cap = 100 mm	No. Poles = 10
Dist = 103 m	Length = 103 m
Required Capacity (M3/d) = 0	Year 2015 = 0
Estimated Cost (R/M3/d) = 0	Estimated Cost (R/M3/d) = 0


Kwamatabane	
SERVICE RESERVOIR	
Cap = 100 mm	No. Poles = 10
Dist = 103 m	Length = 103 m
Required Capacity (M3/d) = 0	Year 2015 = 0
Estimated Cost (R/M3/d) = 0	Estimated Cost (R/M3/d) = 0



Note : Pumping energy costs for main pump stations assume 1/2 cost due to Power (kW/h) and 1/2 due to Energy (kWh).  
so that actual cost is 5/6 of that calculated for continuous pumping (or a Peak Factor = 1.5 (ie. 160% per day).

## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. EW/B/5E)


GA-RAMANTSHANE TO MASOBE : ALTERNATIVE 1 (Moretele 2 supplied from Weltevreden Purification Works only)



Note : Pumping energy costs for main boreholes assume 1/2 cost due to Power (kVA) and 1/2 due to Energy (kW),  
so the actual cost is 5/8 of that calculated for continuous pumping for a Peak Factor 1.5 (ie. 16hrs per day).

# EASTERN ZONE : WELTEVREDEN SUPPLY AREA : PROPOSED INFRASTRUCTURE (E/W/1P)

ALTERNATIVE 1 (Moretele 2 supplied from Weltevreden Purification Works only)




## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/1P)

BLOEDFONTEIN TO SPITSPOUNT : ALTERNATIVE 1 (Moretele 2 supplied from Weltevreden Purification Works only)

From Sheet No. E/WB/P

SUB-SECTION		TOTAL DEMAND		
Year	Wd	Wd	Wd	Wd
1995	1.452			
2000	2.348			
2015	2.764			


PROPOSED DOMEIN		TOTAL DEMAND		
Year	Wd	Wd	Wd	Wd
1995	0.00			
2000	104.6 mm			
2015	103.6 mm			



# EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/MB/2P)

BLOEDFONTEIN TO UTVLUGT, RATHOKE AND MATHALA : ALTERNATIVES 1,2 or 3 (Morotolo 2 supplied from Weltevreden Purification Works and/or Ternba Purification Works or Rust De Winter Dam)

From Sheet No. E/MB/1



Note : Pumping energy costs for main pump stations assume 1/2 cost due to Power (kVA) and 1/2 due to Energy (kWh).  
to set actual 2015 \$ of that calculated for construction (allowing for a Peak Factor of 1.5 (ie. 15hrs per day))

# EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/3P)

## FROM BLOEDFONTEIN/SPITSPOUNT PIPELINE TO SEMOHLASE : ALTERNATIVES 1, 2 or 3 (Moretele 2 supplied from Weltevreden Purification Works or Rust De Winter Dam)

From Sheet No. E/WB/P

Proposed Treatment Unit Capacity (M3/Hr)

De Beers to De Beers Gravity Pipe Line	250 due to De Beers
Cap =	172 M3
Qa =	200 m3
Length =	5.7 km
Required Capacity (M3/Hr)	870
Year 2015	443
Estimated Cost (Rands)	1,472

COST SUMMARY (Rands)	
Regional Services	0
Source Reserves	1,043
Pump Stations	6
Total	4,761
Estimated Cost (Rands)	5,912

Or Stroom	Gravity Pipe Line
Cap =	0 M3
Qa =	150 m3
Length =	2.1 km
Required Capacity (M3/Hr)	60 (400)
Year 2015	310
Estimated Cost (Rands)	0

Or Stroom	Gravity Pipe Line
Cap =	0 M3
Qa =	150 m3
Length =	3.5 km
Required Capacity (M3/Hr)	60 (400)
Year 2015	370
Estimated Cost (Rands)	0

Or Stroom	Gravity Pipe Line
Cap =	0 M3
Qa =	150 m3
Length =	3.5 km
Required Capacity (M3/Hr)	60 (400)
Year 2015	370
Estimated Cost (Rands)	0

Or Stroom	Gravity Pipe Line
Cap =	0 M3
Qa =	150 m3
Length =	3.5 km
Required Capacity (M3/Hr)	60 (400)
Year 2015	370
Estimated Cost (Rands)	0

Or Stroom	Gravity Pipe Line
Cap =	0 M3
Qa =	150 m3
Length =	3.5 km
Required Capacity (M3/Hr)	60 (400)
Year 2015	370
Estimated Cost (Rands)	0

Or Stroom	Gravity Pipe Line
Cap =	0 M3
Qa =	150 m3
Length =	3.5 km
Required Capacity (M3/Hr)	60 (400)
Year 2015	370
Estimated Cost (Rands)	0

Note : Pumping energy costs for main pump stations assume 1/2 cost due to Power (MWh) and 1/2 due to Energy (MWh),  
so that actual costs is 50% of that calculated for continuous pumping for a Peak Factor = 1.5 (ie. 10hrs per day).

# EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/4P)

SPITSPUTT TO KWAMATABANE AND GA-RAMANTSHANE : ALTERNATIVE 1 (Moretele 2 supplied from Weltevreden Purification Works only)

From Sheet No. E/WB/1

REGIONAL RESERVOIR		SUB-REGION	
YEAR	NAME	YEAR	NAME
1995	N/A	1995	N/A
2002	1152	2002	1527
2007	1557	2007	1079
2015	1554	2015	1076


REGIONAL RESERVOIR		SUB-REGION	
YEAR	NAME	YEAR	NAME
1995	1152	1995	1527
2002	1557	2002	1782
2015	1554	2015	1076

COST SUMMARY (Rands)	
Regional Reserves	1,605
Service Reserves	1,411
Pump Stations	777
Storage	75,489
TOTAL	78,569
(Country Costs) (Rands)	20

REGIONAL RESERVOIR		SUB-REGION	
YEAR	NAME	YEAR	NAME
1995	1152	1995	1527
2002	1557	2002	1782
2015	1554	2015	1076

REGIONAL RESERVOIR		SUB-REGION	
YEAR	NAME	YEAR	NAME
1995	1152	1995	1527
2002	1557	2002	1782
2015	1554	2015	1076


COST SUMMARY (Rands)	
Regional Reserves	1,605
Service Reserves	1,411
Pump Stations	777
Storage	75,489
TOTAL	78,569
(Country Costs) (Rands)	20



Note : Pending energy costs for main pump stations assume 1/2 rate due to Power (kVA) and 1/2 due to Energy (kWh).  
so that actual cost is 50% of that calculated for continuous pumping for a Peak Factor = 1.5 (or 10% per day).

**EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/SP)**

GA-RAMANTSHANE TO MASOBE : ALTERNATIVE 1 (Morotele 2 supplied from Weltevreden Purification Works only)




### COST SUMMARY FOR INFRASTRUCTURE

<b>WELTEVREDEN ALTERNATIVE 2</b>		
SPLIT BETWEEN WELTEVREDEN AND TEMBA		
<b>INCLUDING SUPPLY BLOCKS :</b>	1. Waatkraal Supply Block 2. Kameelrivier Supply Block	3. Mapoch Supply Block 4. Bloedfontein Supply Block
<b>POPULATION SERVED (2015) :</b>	631,276	
<b>AADD in mom/a (2015) :</b>	(19.01)	
<b>BULK COST :</b>	<b>QUANTITY</b>	<b>COST (R million)</b>
Water Purification Works	Kl/d (SDD)	
1. Weltevreden WTW	320	0.107
2. Temba WTW	8,631	2.877
Pump Stations	Kld (SDD)	
<b>A : Capital Cost</b>		
1. Weltevreden (Bloedfontein) CWPS	714	0.124
2. Leuwfontein PS	575	0.053
3. Matsiphe A	362	0.059
4. Spitspunt BPS	217	0.023
5. Tshikanossi BPS	284	0.007
6. Mmakola BPS	323	0.020
7. Radjoko BPS	270	0.007
8. Ramantsho	33	0.006
9. Temba CWPS	8,631	0.722
10. Phake B	1,277	0.148
11. Ga Ramantshane	908	0.094
	<b>Sub-Total</b>	<b>1.263</b>
<b>B : Annual Energy Cost (Not Incl'd with Total)</b>		
1. Weltevreden (Bloedfontein) CWPS	-	0.015
2. Leuwfontein PS	-	0.058
3. Matsiphe A	-	0.006
4. Spitspunt BPS	-	0.003
5. Tshikanossi BPS	-	0.002
6. Mmakola BPS	-	0.003
7. Radjoko BPS	-	0.002
8. Ramantsho	-	0.002
9. Temba CWPS	-	0.155
10. Phake B	-	0.019
11. Ga Ramantshane	-	0.011
	<b>Sub-Total</b>	<b>0.276</b>
<b>Reservoirs (Regional)</b>	<b>Ml</b>	
1. Phake B	5.8	1.883
2. Letfin	4.1	1.447
<b>Pipelines (Bulk)</b>	<b>km</b>	
1. 110 PVC	76.7	7.120
2. 125 PVC	10.2	1.336
3. 140 PVC	10.8	1.764
4. 160 PVC	28.4	5.831
5. 200 PVC	13.1	3.383
6. 250 PVC	0	0.000
7. 300 PVC	19.3	11.176
8. 315 PVC	0	0.000
9. 350 ST	41.4	27.053
10. 400 ST	13.5	11.062
11. 450 ST	13.5	13.490
	<b>Sub-Total</b>	<b>82.215</b>

<b>Sub Total Construction Cost</b>		<b>89.792</b>
<b>Engineering Fees (15 %)</b>		<b>13.469</b>
<b>VAT (14 %)</b>		<b>14.457</b>
<b>Project Contingency (20%)</b>		<b>23.543</b>
<b>TOTAL : Bulk Cost</b>		<b>141.261</b>
<b>Bulk Cost per Capita (Rands)</b>		<b>224</b>
<b>SECONDARY COST :</b>		
	<b>QUANTITY</b>	<b>COST (R million)</b>
Reservoirs (Service)	Ml	
1. Bloedfontein Supply Block	6.71 (23 No)	4.354
	6.55 (19 No)	3.489
2. Waalkraal Supply Block	10.17 (25 No)	5.812
3. Kameeldrivier Supply Block	0.92 (2 No)	0.523
4. Mapoch Supply Block	0	0.000
	<b>Sub-Total</b>	<b>14.178</b>
Water Towers	Ml	
N/A	NIL	NIL
Pump Stations (Secondary)	Ki/d	
A : Capital Cost	NIL	NIL
N/A	NIL	NIL
B : Annual Energy Cost. (Not Inc'd with Total)	NIL	NIL
N/A	NIL	NIL
Pipelines (Secondary)	km	
	NIL	NIL
Recirculation	km	
1. Bloedfontein Supply Block		99.837
2. Waalkraal Supply Block		95.056
3. Kameeldrivier Supply Block		12.356
4. Mapoch Supply Block		6.851
	<b>Sub-Total</b>	<b>214.100</b>
<b>Sub Total Construction Cost</b>		<b>228.278</b>
<b>Engineering Fees (15 %)</b>		<b>34.242</b>
<b>VAT (14 %)</b>		<b>36.753</b>
<b>Project Contingency (20%)</b>		<b>59.854</b>
<b>TOTAL : Secondary Cost</b>		<b>359.127</b>
<b>Secondary Cost per Capita (Rands)</b>		<b>569</b>
<b>GRAND TOTAL COST</b>		<b>500.388</b>
<b>Grand Total Cost per Capita (R)</b>		<b>793</b>

## EASTERN ZONE : WELTEVREDEN SUPPLY AREA : EXISTING INFRASTRUCTURE (E/W/1E/2&3)

### ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden and Temba Purification Works)




**EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/WB/1E/2&3)**  
**BLOEDFONTEIN TO SPITSPOINT : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden and Temba Purification Works)**

From Sheet No. E/WB/1E

SUB-REGION TOTAL DEMAND	
Year	MM
1995	1,342
1996	1,043.6
2002	2,244
2015	2,726

Bloedfontein Demand	
REGIONAL RESERVOIR	
Cap.	16.0 Ml
TWL	1,043.6 (ml)
EWL	1,031 (ml)
Required Capacity (Ml)	8.6 (ml)
Year 2015	7.3
Estimated Cost (R1000/ML)	8.7


COST SUMMARY (R1000's)	
Regional Reservoir	0
Service Reservoir	0
Purification	0
<b>TOTAL</b>	<b>0</b>
Estimated Cost (R1000/ML)	14.0



## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/WB/2E)

BLOEDFONTEIN TO UTVLUGT, RATHOEK AND MATTALA : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden Purification Works and Temba Purification Works)

From Sheet No. E/WB/E



## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. EWB/3E)

FROM BLOEDFONTEIN/SPITSPIJT PIPLINE TO SEMOHLESE : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden Purification Works)

From Sheet No. EWB/E

SUB-REGION TOTAL DEMAND			
Year	NoV	2002	2015
1995	1272	1175	1119
2002	1270	1175	1119
2015	1143	0	0

COST SUMMARY (R000's)			
Regional Reservoirs	0	0	0
Service Reservoirs	0	0	0
Pump Stations	0	0	0
Pipelines	0	0	0
TOTAL	0	0	0
(Excl.) Cost (R000's)	0	0	0

SUB-REGION TOTAL DEMAND			
Year	NoV	2002	2015
1995	105	105	105
2002	103	103	103
2015	170	0	0

SUB-REGION TOTAL DEMAND			
Year	NoV	2002	2015
1995	105	105	105
2002	103	103	103
2015	170	0	0


COST SUMMARY (R000's)			
Regional Reservoirs	0	0	0
Service Reservoirs	0	0	0
Pump Stations	0	0	0
Pipelines	0	0	0
TOTAL	0	0	0
(Excl.) Cost (R000's)	0	0	0

De Beaufort to Grootfontein GRAVITY PIPELINE	On Demand	GRAVITY PIPELINE	On Demand
Cap = 2034 NoV	Cap = 144 NoV	Cap = 0 NoV	Cap = 144 NoV
Dia = 150 mm	Dia = 150 mm	Dia = 150 mm	Dia = 150 mm
Length = 7.4 km	Length = 7.4 km	Length = 7.4 km	Length = 7.4 km
Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)
Year 2015 423	Year 2015 423	Year 2015 423	Year 2015 423
Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0
On Demand	On Demand	On Demand	On Demand
SERVICE RESERVOIR	SERVICE RESERVOIR	SERVICE RESERVOIR	SERVICE RESERVOIR
Cap = 0 NoV	Cap = 0 NoV	Cap = 0 NoV	Cap = 0 NoV
GL = 900 m3	GL = 900 m3	GL = 900 m3	GL = 900 m3
Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)
Year 2015 0.75	Year 2015 0.75	Year 2015 0.75	Year 2015 0.75
Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0
On Demand	On Demand	On Demand	On Demand
LOADING	LOADING	LOADING	LOADING
GRAVITY PIPELINE	GRAVITY PIPELINE	GRAVITY PIPELINE	GRAVITY PIPELINE
Cap = 0 NoV	Cap = 0 NoV	Cap = 0 NoV	Cap = 0 NoV
Dia = 150 mm	Dia = 150 mm	Dia = 150 mm	Dia = 150 mm
Length = 5.5 km	Length = 5.5 km	Length = 5.5 km	Length = 5.5 km
Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)
Year 2015 0.56	Year 2015 0.56	Year 2015 0.56	Year 2015 0.56
Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0
On Demand	On Demand	On Demand	On Demand
LOADING	LOADING	LOADING	LOADING
GRAVITY PIPELINE	GRAVITY PIPELINE	GRAVITY PIPELINE	GRAVITY PIPELINE
Cap = 0 NoV	Cap = 0 NoV	Cap = 0 NoV	Cap = 0 NoV
Dia = 150 mm	Dia = 150 mm	Dia = 150 mm	Dia = 150 mm
Length = 1.0 km	Length = 1.0 km	Length = 1.0 km	Length = 1.0 km
Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)
Year 2015 0.56	Year 2015 0.56	Year 2015 0.56	Year 2015 0.56
Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0
On Demand	On Demand	On Demand	On Demand
SEWAGE	SEWAGE	SEWAGE	SEWAGE
SERVICE RESERVOIR	SERVICE RESERVOIR	SERVICE RESERVOIR	SERVICE RESERVOIR
Cap = 0 NoV	Cap = 0 NoV	Cap = 0 NoV	Cap = 0 NoV
GL = 900 m3	GL = 900 m3	GL = 900 m3	GL = 900 m3
Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)	Required Capacity (NoV) Bas (NoV)
Year 2015 0.15	Year 2015 0.15	Year 2015 0.15	Year 2015 0.15
Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0	Estimated Cost (R000's) 0

Note: Planning energy costs for main pump stations assume 1/2 cost due to Power (kVA) and 1/2 due to Energy (kWh), so that actual cost is 25% of that calculated for continuous pumping for a Peak Factor = 1.5 (ie. 10hrs per day).


## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE. (Sheet No. E/WB/4E/2&3)

From Sheet No. E/WB/EZ



# EASTERN ZONE : BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/TM/1E)


TEMBA TO LEIFI : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden and Temba Purification Works)



## EASTERN ZONE : BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/TM/2E)


LEIFI TO MARAPYANE : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden and Temba Water Purification Works)

From Sheet No. E/TM/1E



# EASTERN ZONE : PROPOSED INFRASTRUCTURE (EW/1P/2&3)


## ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden and Temba Purification Works)



# EASTERN ZONE : WELTEVREDDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/1P/2&3)

## BLOEDFONTEIN TO SPITSPOUNT : ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden and Rust De Winter Dam)


From Sheet No. E/WB/1P



## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/2P)

BLOEDFONTEIN TO UITVLUGT, RATHOKE AND MATTALA : ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden Purification Works and Rust De Winter Dam)


From Sheet No. E/WB/1P



## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/3P)

FROM BLOEDFONTEIN SUPPLY PIPELINE TO SEMOHLASE : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden Purification Works)

From Sheet No. E/WB/2P




Note : Pumping energy costs for main pump stations assumed 12 cost due to Power (MM) and 172 due to Energy (MM).

10 of the total costs is 1/5 of the calculated for continuous pumping for a Peak Factor = 1.5 (ie. 10% per day).

## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/4P/2&3)


SPITSPUNT TO KWAMATABANE AND RADJKOKO : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden and Temba Purification Works)

From Sheet No. E/WB/1E2



# EASTERN ZONE : BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/TM/1P)


## TEMBA TO LEPIFI : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden and Temba Purification Works)



## EASTERN ZONE : BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/TM/2P)

### LEFIKI TO MARAPYANE : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden and Temba Purification Works)

From Sheet No. E/TM/1P



COST SUMMARY FOR INFRASTRUCTURE		
NAME OF SUPPLY AREA:	WELTEVREDEN ALTERNATIVE 3 SPLIT BETWEEN WELTEVREOEN AND RUST DE WINTER (New treatment works)	
INCLUDING SUPPLY BLOCKS:	1. Waalkraal Supply Block	3. Mapoch Supply Block
	2. Kameelrivier Supply Block	4. Bloedfontein Supply Block
POPULATION SERVED (2015):	631,276	
AADD in mom/a (2015):	19.01	
BULK COST:	QUANTITY	COST (R million)
Water Purification Works	Kl/d (SDD)	
1. Weltevreden WTW	320	0.107
2. Rust de Winter WTW	8,631	2.877
Pump Stations	Kl/d (SDD)	
<b>A : Capital Cost</b>		
1. Weltevreden (Bloedfontein) CWPS	714	0.124
2. Leuwfontein PS	575	0.053
3. Matsipha A	362	0.059
4. Spitspunt BPS	217	0.023
5. Tshikanossi BPS	284	0.007
6. Mmakola BPS	323	0.020
7. Radjoko BPS	270	0.007
8. Ramantsho	33	0.006
9. Rust de Winter CWPS	8,631	0.621
10. Phake B	1,277	0.148
11. Ga Ramatshane	908	0.094
	Sub-Total	1.162
<b>B : Annual Energy Cost (Not incl'd with Total)</b>		
1. Weltevreden (Bloedfontein) CWPS	-	0.015
2. Leuwfontein PS	-	0.058
3. Matsipha A	-	0.006
4. Spitspunt BPS	-	0.003
5. Tshikanossi BPS	-	0.002
6. Mmakola BPS	-	0.003
7. Radjoko BPS	-	0.002
8. Ramantsho	-	0.002
9. Rust de Winter CWPS	-	0.126
10. Phake B	-	0.019
11. Ga Ramatshane	-	0.011
	Sub-Total	0.247
Reservoirs (Regional)	Ml	
N/A	NIL	NIL
Pipelines (Bulk)	km	
1. 110 PVC	76.7	7.120
2. 125 PVC	10.2	1.336
3. 140 PVC	10.8	1.764
4. 160 PVC	28.4	5.831
5. 200 PVC	13.1	3.383
6. 250 PVC	0	0.000
7. 300 PVC	28.9	16.529
8. 315 PVC	0	0.000
9. 350 ST	0	0.000
10. 400 ST	13.5	11.062
11. 450 ST	13.5	13.490
	Sub-Total	60.515

<b>Sub Total Construction Cost</b>		<b>61.784</b>
Engineering Fees (15 %)		<b>9.269</b>
VAT (14 %)		<b>9.947</b>
Project Contingency (20%)		<b>16.200</b>
<b>TOTAL : Bulk Cost</b>		<b>97.199</b>
Bulk Cost per Capita (Rands)		<b>154</b>
<b>SECONDARY COST :</b>	<b>QUANTITY</b>	<b>COST (R million)</b>
Reservoirs (Service)	ML	
1. Bloedfontein Supply Block	6.71 (23 No)	4.354
	6.55 (10 No)	3.479
2. Waalkraal Supply Block	10.17 (25 No)	5.812
3. Kameelfvlei Supply Block	0.92 (2 No)	0.523
4. Mapoch Supply Block	0	0.000
	<b>Sub-Total</b>	<b>14.168</b>
Water Towers	ML	
N/A	NIL	NIL
Pump Stations (Secondary)	Ki/d	
A : Capital Cost	N/A	NIL
B : Annual Energy Cost (Not Inc'd with Total)	N/A	NIL
Pipelines (Secondary)	km	
	NIL	NIL
Reticulation	km	
1. Bloedfontein Supply Block		99.837
2. Waalkraal Supply Block		95.056
3. Kameelfvlei Supply Block		12.356
4. Mapoch Supply Block		6.851
	<b>Sub-Total</b>	<b>214.100</b>
<b>Sub Total Construction Cost</b>		<b>228.268</b>
Engineering Fees (15 %)		<b>34.240</b>
VAT (14 %)		<b>36.751</b>
Project Contingency (20%)		<b>59.852</b>
<b>TOTAL : Secondary Cost</b>		<b>359.111</b>
Secondary Cost per Capita (Rands)		<b>569</b>
<b>GRAND TOTAL COST</b>		<b>456.310</b>
<b>Grand Total Cost per Capita (R)</b>		<b>723</b>


## EASTERN ZONE : WELTEVREDEN SUPPLY AREA : EXISTING INFRASTRUCTURE (E/W/1E/2&3)

### ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden and Rust De Winter Dam)

SUPPLY AREA TOTAL DEMAND	
Year	kWd
1995	22,109
2002	35,662
2015	40,213
Required Capacity (kWd)	Bal (kWd)
Year 2015	10,910
Estimated Cost (R000's)	7214
Energy Costs (R000's/kw)	0
Estimated Cost (R000's)	208
Energy Costs (R000's/kw)	0


WELTEVREDEN PUMP STATION	
Cap =	10,106 kWd
GL =	919 masi
Pump head =	172 m
Required Capacity (kWd)	Bal (kWd)
Year 2015	10,910
Estimated Cost (R000's)	0
Energy Costs (R000's/kw)	0

WELTEVREDEN TO MAPOCH PUMP PIPELINE	
Cap =	10,106 kWd
GL =	919 masi
Pump head =	172 m
Required Capacity (kWd)	Bal (kWd)
Year 2015	10,910
Estimated Cost (R000's)	0
Energy Costs (R000's/kw)	0




WELTEVREDEN PURIFICATION WORKS	
Cap =	60,000 kWd
GL =	919 masi
Pump head =	70 m
Required Capacity (kWd)	Bal (kWd)
Year 2015	60,320
Estimated Cost (R000's)	320
Energy Costs (R000's/kw)	0


WELTEVREDEN PUMP STATION	
Cap =	53,306 kWd
GL =	919 masi
Pump head =	134 m
Required Capacity (kWd)	Bal (kWd)
Year 2015	40,577
Estimated Cost (R000's)	12,616
Energy Costs (R000's/kw)	7470



WELTEVREDEN TO WALKRAAL PUMP PIPELINE	
Cap =	53,306 kWd
GL =	919 masi
Pump head =	134 m
Required Capacity (kWd)	Bal (kWd)
Year 2015	40,577
Estimated Cost (R000's)	12,616
Energy Costs (R000's/kw)	7470




WELTEVREDEN TO KAMEELRIVIER B PUMP STATION	
Cap =	6,381 kWd
GL =	919 masi
Pump head =	68 m
Required Capacity (kWd)	Bal (kWd)
Year 2015	5,946
Estimated Cost (R000's)	2,432
Energy Costs (R000's/kw)	66.0



## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/WB/1E/2&3)

### BLOEDFONTEIN TO SPITSPUNT : ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden and Rust De Winter Dam)


Elev Sheet No. EW/E



# EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/WB/2E)


BLOEDFONTEIN TO UITVLUGT, RATHOKE AND MATLALA : ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden Purification Works and Rust De Winter Dam)

From Sheet No. E/WB/1E



## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/WB/3E)

FROM BLOEDFONTEIN/SPITSPOUNT PIPELINE TO SEMOHASE 3 (Moretele 2 supplied from Weltevreden Purification Works and Rust De Winter Dam)




Note : Pumping overhead costs for main pump stations assume 1/2 cost due to Power (MM) and 1/2 due to Energy (MM), so that actual cost is 3/4 of true calculated for continuous pumping at a Peak Factor = 1.5 (ie. 1 day per day).



## EASTERN ZONE : BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/RM/1E)


RUST DE WINTER TO LEFFI : ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden Purification Works and Rust De Winter Dam)



## EASTERN ZONE: BLOEDFONTEIN SUPPLY BLOCK : EXISTING INFRASTRUCTURE (Sheet No. E/TM/2E)


### LEFI TO MARAPYANE : ALTERNATIVE 3 (Moretele 2 supplied from Weltevrede and Rust De Winter Dam)

From Sheet No. E/TM/1E



# EASTERN ZONE : WELTEVREDEN SUPPLY AREA : PROPOSED INFRASTRUCTURE (E/W/1P/2&3)


## ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden and Rust De Winter Dam)



## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WS/1P/2&3)

### BLOEDFONTEIN TO SPITSPUNT : ALTERNATIVE 2 supplied from Weltevreden and Temba Purification Works


From Sheet No. E/WMP



# EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/2P)

BLOEDFONTEIN TO UITVLUGT, RATHOKE AND MATLALA : ALTERNATIVE 2 (Moretele 2 supplied from Weltevreden Purification Works)


From Sheet No. E/WB/P



## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/3P)

FROM BLOEDFONTEIN/SPITSPOUNT PIPELINE TO SEMOHLESE : ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden Purification Works and Rust De Winter Dam)


From Sheet No. E/WB/1P



Note : Plumbing energy costs for main pump stations assume 1/2 cost due to Power (kVA) and 1/2 due to Energy (kWh).  
so that actual cost is 50% of that calculated for continuous pumping for a Peak Factor = 1.5 (ie. 15% per day).


## EASTERN ZONE : WELTEVREDEN - BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/WB/4P/2&3)

From Sheet No. E/WB/4P/2



## EASTERN ZONE : BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/RM/1P)

RUST DE WINTER TO LEFIIFI : ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden Purification Works and Rust De Winter Dam)



## EASTERN ZONE : BLOEDFONTEIN SUPPLY BLOCK : PROPOSED INFRASTRUCTURE (Sheet No. E/TM2P)

LEFI TO MARAPYANE : ALTERNATIVE 3 (Moretele 2 supplied from Weltevreden and Rust De Winter Dam)

From Sheet No. E/TM1P

LEFI		REGIONAL RESERVOIR		REGIONAL RESERVOIR		REGIONAL RESERVOIR		REGIONAL RESERVOIR		REGIONAL RESERVOIR		REGIONAL RESERVOIR	
Leifi Demand	kL/d	Cap = 4.1 Ml	GL = 1032 msl	Year 1995	1974	Year 2002	2002	Year 2009	2015	Year 2015	2015	Year 2022	2015
		Required Capacity (Ml)	Bal (Ml)		0		623		407.2		614		106.1
		Estimated Cost (R000's)	1,447										
Lefi to Ga-Ramantshane		PUMP PIPELINE		Ga-Ramantshane to Marapayne		Opperend GRAVITY PIPELINE		Opperend SERVICE RESERVOIR		Opperend SERVICE RESERVOIR		Marapayne SERVICE RESERVOIR	
		Cap = 5789 kL/d	GL = 450 mm PVC/9		Cap = 2500 kL/d	GL = 300 mm PVC/9		Cap = 0.12 Ml	GL = 1011 msl		Cap = 0.12 Ml	GL = 1005 msl	
		Length = 13.5 km			Length = 10.6 km			Required Capacity (kL/d)	Bal (kL/d)		Required Capacity (Ml)	Bal (Ml)	
		Required Capacity (kL/d)	Bal (kL/d)	Year 2015	4470	Year 2015	1.1	Year 2015	1,911	Year 2015	0.15	Year 2015	0
		Estimated Cost (R000's)	13,90					Estimated Cost (R000's)	532		Estimated Cost (R000's)	5,134	
Lefi to Rapoorware		GRAVITY PIPELINE		Ga-Ramantshane to Kaldonien		Marapayne		Marapayne		Kaldonien		Kaldonien	
		Cap = 1270 kL/d	GL = 150 mm PVC/9		Cap = 908 kL/d	GL = 1022 msl		Cap = 1.2 Ml	GL = 1011 msl		Cap = 1.2 Ml	GL = 1005 msl	
		Length = 6.9 km			Pump head = 84 m			Required Capacity (Ml)	Bal (Ml)		Required Capacity (Ml)	Bal (Ml)	
		Required Capacity (kL/d)	Bal (kL/d)	Year 2015	908	Year 2015	1	Year 2015	1.2	Year 2015	0.15	Year 2015	0
		Estimated Cost (R000's)	1,197					Estimated Cost (R000's)	562		Estimated Cost (R000's)	117	
Rapoorware		SERVICE RESERVOIR		Rapoorware DEMAND		Marapayne DEMAND		Rapoorware DEMAND		Marapayne DEMAND		Kaldonien DEMAND	
		Cap = 0.33 Ml	GL = 995 msl		Year 1995	190	Year 2002	2002	Year 2009	2015	Year 2015	2015	
		Required Capacity (Ml)	Bal (Ml)	Year 2015	0.33	Year 2015	0	Required Capacity (kL/d)	Bal (kL/d)	Year 2015	1	Required Capacity (Ml)	Bal (Ml)
		Estimated Cost (R000's)	213					Estimated Cost (R000's)	1,012			Estimated Cost (R000's)	572
Rapoorware Demand		Year		Year		Year		Year		Year		Year	







