

REFERENCES

REFERENCES

- 01 to 10: Attached with May/10/1995 Letter of Mr. Diniz de Figueiredo to Miss. Ago
11 to 16: Attached with March/7/1995 Letter of Mr. Ladniuk to Mr. Inoue
17 to 40: Received during the First Field Work
41 to : Received & collected during the Second Field Work and following period

01

Title: (Ambient Air Quality for TSP, Smoke, Inhalable Particle, SO₂, CO, O₃, NO₂)

Source Resolucao/CONAMA/No.003 de 28 de junho de 1990

02

Title: (Stationary Source Emission for TSP, Smoke, SO₂, and Fuel Oil Consumption at each Designated Area)

Source Resolucao/CONAMA/No.008 de 06 de dezembro de 1990

03

Title: (Designation of Area I, II, and III for Air Pollution Control)

Source Resolucao/CONAMA/No. 005 de 15 de junho de 1989

04

Title: Jorge Lacerda Wind Rose (Nov/86 - Out/87) and Porto Alegre Wind Rose (1981 - 1985)

Source ELETROSUL

05

Title: Map - Monitoramento Ambiental na Regiao do Baxio Jacui

Source ELETROSUL

06

Title: Map - Monitoramento Ambiental na Regiao de Tubarao Area de Influencia do Complexo Term. Jorge Lacerda

Source ELETROSUL

07

Title: Tables - Resultados das Medias Mensais, Anuais e Maximos de 24h para SO₂ & PM - 87 a 94 da Regiao de Baxio Jacui e de Tubarao/Capivari de Baxio

Source ELETROSUL

08

Title: Maintenance & Calibration Method of Hi-Vol. Sampler

Source Environmental Science and Engineering, Inc.

09

Title: Maintenance & Calibration Method of SO₂ Bubbler

Source ELETROSUL

10

Title: Map - Coal Deposit around Jorge Lacerda

Source ELETROSUL

11

Author: Sergio T. Ladniuk

Title: Letter to Mr. Inoue dated March/7/1995

Source CEEE

- 12
Title: Map - Massas de Ar
Source: CEEE
- 13
Title: Estacao Meteorologica de Candiota & Bage
Source: CEEE
- 14
Title: Map - Monitoramento Ambiental Localizacao, Candiota
Source: CEEE
- 15
Title: Tablea III - Presidente Medici; Emissioes Aereas
Source: CEEE
- 16
Title: 24 Tables - Meio Ambiente de Presidente Medici (Hi-vol & Tri-gas) (1 - 12/1994)
Source: CEEE
- 17
Author: Carlos Gothe
Title: Brazilian Environmental Policy and Air Pollution Control Legislation
Source: ELETROSUL DET/DIPT, pp2
- 18
Author: Edited by Noguchi
Title: Coal & Stack Gas Properties at Jorge Lacerda
Source: Data from Mr. Pasquottoin of Jorge Lacerda Plant
- 19
Author: RSC- Regional de Santa Catarina; Complexo Jorge Lacerda
Title: Carvao Consumido (Coal & Ash analyses)
Source: Jorge Lacerda
- 20
Title: Analises Mensais do Carvao (in 1993 & 1994 at Candiota)
Source: Candiota
- 21
Author: Naiare Dal Molin
Title: Candiota - Origem e Historia
Source: TCHE 10/1994
- 22
Title: Map - Tubarao
Source: Ministerio da Economia, Fazenda e Planejamento
- 23
Title: Map - Laguna
Source: Ministerio da Economia, Fazenda e Planejamento
- 24
Title: Map - Lagoa de Garopaba do Sul
Source: Ministerio da Economia, Fazenda e Planejamento

- 25
 Title: Map - Jaguaruna
 Source: Minsterio da Economia, Fazenda e Planejamento
- 26
 Title: Map - Taquari
 Source: Minsterio do Exercicio, Diretoria de Servico Geografico
- 27
 Title: Map - Sao Jeronimo
 Source: Minsterio do Exercicio, Diretoria de Servico Geografico
- 28
 Title: Map - Morrêtes
 Source: Minsterio do Exercicio, Diretoria de Servico Geografico
- 29
 Title: Map - Guaiba
 Source: Minsterio do Exercicio, Diretoria de Servico Geografico
- 30
 Title: Map - Arroio dos Ratos
 Source: Minsterio do Exercicio, Diretoria de Servico Geografico
- 31
 Title: Map - Butia
 Source: Minsterio do Exercicio, Diretoria de Servico Geografico
- 32
 Title: Map - Hulha Negra
 Source: Minsterio do Exercicio, Departamento de Engenharia e Comunicacoes
- 33
 Title: Map - Seival
 Source: Minsterio do Exercicio, Departamento de Engenharia e Comunicacoes
- 34
 Title: Map - Pedras Altas
 Source: Minsterio do Exercicio, Departamento de Engenharia e Comunicacoes
- 35
 Title: Map - Tupi Sileira
 Source: Minsterio do Exercicio, Departamento de Engenharia e Comunicacoes
- 36
 Author: CEEE, Cordenadoria Central de Planejamento
 Title: CEEE em Numeros
 Source: CEEE, End of 1993
- 41
 Title: Legislacao Ambiental Basica do Estado de Santa Catarina
 Source: FATMA, 5/1995
- 42
 Author: Governo do Estado de Sao Paulo, Secretaria do Meio Ambiente
 Title: Legislacao Federal Controle da Poluicao Ambiental
 Source: Companhia de Tecnologia de Saneamento Ambiental, as of 1989

- 43
 Title: **Qualidade do Ar na Regiao Metropolitana do Rio de Janeiro - 1984/1987**
 Source: **FEEMA, 6/1989**
- 44
 Author: **Karen Walker**
 Title: **Select a Continuous Emissions Monitoring System**
 Source: **Chemical Engineering Progress, p 28, Vol. 92, No. 2, 1996**
- 45
 Author: **Aaron M. Cheng, et. al.**
 Title: **An Accurate Predictive Emissions Monitoring System for an Ethylene Furnace**
 Source: **Environmental Progress, p 19, Vol. 15, No. 1, 1996**
- 46
 Author: **World Resources Institute, UNEP, UNDP**
 Title: **World Resources 1994-1995: a Guide to the Global Environment**
 Source: **World Resources Institute**
- 47
 Author: **SC-Secretaria de Desenvolvimento Urbano e do Meio Ambiente, and FATMA**
 Title: **Legislacao Ambiental Basica do SC; Lei 5793 (10/80) & Decreto 14250(6/81)**
 Source: **FATMA, 5/1995**
- 48
 Title: **Boletim Trimestral - Electric Power Summary Statistics for Brazil 1992**
 Source: **SIESE, 1992**
- 49
 Title: **Outlook of Overseas Electric Utilities - 1993 (J)**
 Source: **Japan Electric Power Information Center, Inc.**
- 50
 Title: **National Energy Balance, 1995**
 Source: **Ministry of Mines and Energy**
- 51
 Title: **Annual Administrative Report, 1995**
 Source: **ELETROSUL**
- 52
 Author: **Program or concessions and partnerships of the government of Rio Grande do Sul**
 Title: **Partnerships for the future**
 Source: **Government of Rio Grande do Sul, 1995**
- 53
 Author: **O. A. Cavalcante, et. al.**
 Title: **Informativo Anual da Industria Carbonifera, 1994**
 Source: **Ministerio de Minas e Energia, 7/1994**
- 54
 Title: **The Challenge of Sustainable Development - The Brazilian Report for the United Nations Conference on Environment and Development**
 Source: **Governo do Brasil, 1992**

- 55
 Author: UNDP, UNEP, World Bank, et. al.
 Title: World Resources 1996-97: Guide to the Global Environment
 Source: World Resources Institute
- 56
 Author: The World Bank
 Title: World Development Report, 1992
 Source: Oxford University Press, Inc.
- 57
 Title: ELETROSUL - Informacoes Basicas
 Source: ELETROSUL CDE, 12/1993
- 58
 Title: Chapter V. De-NOx Facilities (J) - (a part of technical information book)
 Source: Thermal & Nuclear Power Generation Engineering Association (Japan), 6/1991
- 59
 Author: Natural Resources, Environment and Rural Poverty Division, Country Dept. 1
 Title: Brazil - Managing Environmental Pollution in the State of Rio de Janeiro
 Source: World Bank, August, 1996
- 60
 Author: Infrastructure and Urban Development Division, Country Department 1
 Title: Brazil - Natural Gas Pricing and Regulatory Study
 Source: World Bank, October 25, 1996
- 61
 Author: JICA Planning Department
 Title: Kunibetsu Kankyo Joho Seibi Chousa - (Environmental Information in Brazil)
 Source: JICA - Feb./1990
- 62
 Title: World Development Indicators - 1997
 Source: World Bank
- 63
 Title: Arranjo Geral (Candiota General Layout for Unit III with legends)
 Source: CEEE, 06/96
- 64
 Author: Verena Nygaard, Directora-Presidente de FEPAM
 Title: Letter FEPAM/GAB/258-96 addressed to President of CEEE
 Source: fepam, 7/30/1996
- 65
 Title: Emissões de Poluentes Aéreos da Ute Jacuí e Alternativas para Atendimento dos
 Padrões de Emissão da Resolução CONAMA 08/90
 Source: ELETROSUL/DET/DIPT, 09/07/96, calculation based on the Contract 61.501 - Oct/82
- 66
 Author: JICA
 Title: Information on Your New Post Country (Japanese)
 Source: JICA, 1997, J1132779(8)

67

Author: Middle and South America Sect. No.1, J. Ministry of Foreign Affairs, 7/96
Title: General View of Brazil (Japanese)
Source: JICA Library A1130637(0)

68

Title: ARC Report - Trends and Forecast of Economy and Trade in Brazil (Japanese)
Source: World Economic Information Services, 1997

69

Author: Supervised by Air Pollution Sect, Japan Environment Agency
Title: Stationary Source Control Manual at Developing Countries - Power Plants (Japanese)
Source: Global Environment Centre Foundation, 3/97


70

Author: Junpei Andou
Title: Flue Gas Clean-up Technologies in the World (Japanese)
Source: Technical Institute for Coal, 8/1990

71

Title: Analysis and Simulation of SPM Pollution (Japanese)
Source: Japan Environment Agency, 1987

APPENDICES



CONTENTS OF APPENDICES

1- 1	Solicitacao de Cooperacao Technica (Feb./7/94)	A1- 1
1- 2	Scope of Work and Minutes of Meeting for the Study on Evaluation of Environmental Quality in Regions under Influence of Coal Steam Power Plants in the Federative Republic of Brazil (1/25/95)	A1-13
1- 3	List of Existing Equipment available for the JICA Study	A1-25
1- 4	JICA Equipment Specification	A1-26
1- 5	Technology Transfer	A1-42
2- 1	Coal Mines in Brazil: Production and Sulfur Contents	A2- 1
3- 1	Comparison of International Ambient Air Quality Standards	A3- 1
3- 2	Comparison of Emission Standard of Coal Burnt Pollutants	A3- 2
4- 1	Compilation Method of the Monitoring Data	A4- 1
4- 2	Wind Roses by Month	A4- 4
4- 3	Stability Classification	A4- 7
4- 4	Diurnal and Monthly Change of Meteorological Factors	A4- 8
4- 5	Cumulative Distribution	A4-14
4- 6	TSP Concentration by High Volume Sampler	A4-16
4- 7	Monthly Change of SO ₂	A4-19
4- 8	Average Concentration by Wind Directions (SO ₂ & NO _x)	A4-20
4- 9	Air Borne SO ₂ and NO ₂ by Simple Method	A4-22
4- 9B	Regression Equations for Simple Method	A4-31
4-10	Chemical Analysis of Rain and Dry Precipitation	A4-33
4-11A	Each Correlation Graph of Rain and Dry Precipitation Data	A4-44
4-11B	ditto Correlation Tables	A4-62
4-11C	Cation/Anion Ratios of Rain Samples	A4-65
4-11D	pH of Rain in Japan	A4-67
4-12	Elemental Analyses of Particulates	A4-68
5- 1	Stack Gas Sampling Nozzle Locations	A5- 1
5- 2	Results of Stack Gas Measurement	A5- 4
5- 3	Pollutant Flow Rates per MW Plotted on Measured Dates	A5- 8
5- 4	Distribution of Velocity, Temperature, and Dust Loading	A5- 9
5- 5	Various Correlation with Outputs	A5-13
5- 6	Comparison of Calculated and Measured Flow Rates	A5-16

5-7	Heat Loss due to Excess Combustion Air	A5-17
5-8	Ratio of Emissions from Existing Units / National Standard - Pseudo-situation	A5-19
6-1	Emission Parameters under the Current Condition	A6-1
6-2	Hourly Concentration Profile under the Current Condition	A6-4
6-3	Setting of Diffusion Parameter	A6-49
7-1	Emission Parameters under the Future Condition	A7-1
7-2	Gas Volumes and Pollutant Emissions under Maximum Loading in the Future	A7-4
7-3	Hourly Concentration Profile under the Future Condition	A7-5
8-1	Various Air Pollutant Control Measures at Thermal Power Plants	A8-1
8-2	Stack Gas Monitoring Equipment in Brazilian Market	A8-21
8-3	Notes on Management of Ambient Air Monitoring Stations	A8-22
8-4	Maintenance of Continuous Stack Gas Monitoring Analyzers	A8-26
8-5	CMB (Chemical Mass Balance) Method	A8-28
8-6	Specifications of SPM Meter	A8-33

ABC/DAOC-II/26 /ETEC-BRAS-JAPA

O Ministério das Relações Exteriores cumprimenta a Embaixada do Japão e, em aditamento à Nota Verbal ABC/DAOC-II/03, de 06 de janeiro de 1994, tem a honra de encaminhar, em anexo, a seguinte proposta de Estudo para o Desenvolvimento, para a Programação de 1994:

ENERGIA

- Título: Avaliação da Qualidade Ambiental nas Regiões de Influência dos Pólos de Termoeletricidade a Carvão Mineral
Executor: Ministério das Minas e Energia - MME.

2. O Ministério das Relações Exteriores agradecerá à Embaixada do Japão verificar a possibilidade de atender a solicitação em apreço, no âmbito do Acordo Básico de Cooperação Técnica Brasil-Japão.

Brasília, em 07 de fevereiro de 1994

SOLICITAÇÃO DE COOPERAÇÃO TÉCNICA
Fonte Externa: JAPÃO

1 TÍTULO DO PROJETO

Avaliação da Qualidade Ambiental nas Regiões de Influência dos Polos de Termelétricidade a Carvão Mineral.

2. OBJETIVOS DO PROJETO

2.1 Objetivo Superior

Formar recursos humanos e materiais, quanto a qualidade ambiental nas Regiões de influência dos polos de termelétricidade a carvão mineral, necessários à proposição de diretrizes para a implantação das futuras usinas termelétricas a carvão.

2.2 Objetivos Imediatos

- Projetar, implantar e operar redes de monitoramento com a finalidade de avaliar a qualidade ambiental nas áreas de influência dos polos de termelétricidade a carvão nos estados de Santa Catarina e Rio Grande do Sul;

- Treinamento de equipes técnicas para gerenciamento e execução de atividades de monitoramento ambiental e desenvolvimento de modelos de simulação;

- Elaboração de diagnóstico ambiental das regiões com vocação para a termelétricidade a carvão;

- Elaboração de prognósticos ambientais a partir dos planos de expansão da termelétricidade a carvão no sul do Brasil.

A ênfase neste projeto será dada nos aspectos relativos à poluição atmosférica e grau de pH das chuvas, complementarmente deverão ser abordadas, na medida do necessário, as questões relativas à contaminação de águas superficiais e subterrâneas, bem como os aspectos referentes à disposição de resíduos sólidos.

3 RESULTADOS

INDICADORES

PRAZOS

- | | | |
|---|--|----------|
| 1) Duas Equipes treinadas para a concepção, planejamento implantação e operação de projetos de monitoramento da qualidade ambiental. | 1) Existência das equipes treinadas | 12 meses |
| 2) Diagnóstico ambiental das seis regiões influenciadas pelos polos termelétricos, | 2) Realização do diagnóstico | 33 meses |
| 3) Prognósticos ambientais para as regiões influenciadas pelos polos termelétricos. | 3) Realização dos prognósticos | 36 meses |
| 4) Documento de projeto consolidado por relatórios conclusivos e diretrizes ambientais enfocando a expansão da termelétricidade a carvão. | 4) Relatório final do projeto com os resultados das diversas atividades desenvolvidas. | 36 meses |

4. JUSTIFICATIVA

A revisão da Matriz Energética Nacional, elaborada em atendimento ao Decreto Presidencial nº 99.503, de 02.09.90, e aprovada pelo Presidente da República em 19.11.91, define expressiva expansão do consumo de carvão mineral para as próximas décadas.

O principal vetor para este crescimento é o resultado dos estudos de planejamento do setor elétrico que, a partir da constatação do gradativo esgotamento dos potenciais hidráulicos competitivos, indicaram o carvão mineral como a alternativa mais econômica para o atendimento à expansão nas regiões sul/sudeste do País.

Mantidas as expectativas de crescimento da economia, o aumento da participação da termelétrica a carvão na produção de energia elevará o consumo deste mineral de, aproximadamente três milhões de toneladas (1990), para cerca de vinte e cinco milhões de toneladas (2010), decorrente de um aumento na capacidade instalada de 1050 MW para 7150 MW.

Esta significativa elevação da participação do carvão tem sido objeto de preocupação das entidades de proteção e controle ambiental, bem como das comunidades científicas e políticas envolvidas com as questões relativas à compatibilização do desenvolvimento com as necessidades de preservação do ambiente natural.

Este cenário sugere um aprofundamento nos assuntos referentes ao monitoramento ambiental, notadamente quanto à qualidade do ar e das chuvas, a partir de um diagnóstico das regiões com vocação termelétrica e de produção de carvão. Tendo em vista ao estabelecimento dos critérios e tecnologias a serem empregados para permitir o aproveitamento energético do carvão de forma alternativa, mantendo-se a qualidade ambiental em níveis adequados, ou seja, de forma harmônica com os ecossistemas das áreas de influência dos polos termelétricos e compatível com as necessidades das populações habitantes destas áreas.

Considerando que o Japão possui larga experiência no que tange controle e monitoramento ambiental, assim como o fato de usar o carvão mineral, como energético para geração de energia, julgamos ser de vital importância a cooperação tecnológica desse país, para a consecução desse projeto.

5. PRAZO DE EXECUÇÃO

O presente Projeto tem como prazo total uma previsão de 36 meses para sua execução, porém a etapa que aqui propomos refere-se aos primeiros 24 meses.

6. RECURSOS NECESSÁRIOS E CUSTOS ESTIMADOS

6.1 Cooperação Solicitada

a) Consultoria Especializada de Curto Prazo para:

- Conceituação e definição dos limites (escopo) do projeto;
- Treinamento de equipe de coordenação/gerenciamento;
- Planejamento detalhado do projeto.

b) Consultoria Especializada de Longo Prazo para:

- Treinamento de equipes técnicas;
- Execução do projeto;
- Compilação de dados;
- Desenvolvimento de modelos para simulação.

c) Equipamentos Científicos:

- Amostradoras;
- Analisadoras de gases;
- Computadores;
- Cromatógrafo;
- Espectrofotômetro;
- etc..

6.1.1 - PERITOS PARA PRESTAÇÃO DE CONSULTORIA

a) DE LONGO PRAZO:

.Perfil Profissional: Especialização em modelagem de dispersão de poluentes atmosféricos.

.Duração da Missão: 10 meses

.Início Previsto: Dez/94

.Valor: US\$ 100,000

.Perfil Profissional: Projeto de redes de monitoramento da qualidade do ar e das precipitações.

.Duração da Missão: 10 meses

.Início Previsto: Jul/94

.Valor: US\$ 100,000

.Perfil Profissional: Medição e Controle de Emissões Gasosas em Chaminés

.Duração da Missão: 5 meses

.Início Previsto: Jan/95

.Valor: US\$ 50,000

.Perfil Profissional: Monitoramento da qualidade de águas da superfície e subsolo
.Duração da Missão: 5 meses
.Início Previsto: Jan/95
.Valor: US\$ 50,000

.Perfil Profissional: Disposição e/ou aproveitamento de resíduos da combustão
.Duração da Missão: 10 meses
.Início Previsto: Jul/95
.Valor: US\$ 100,000

b) DE CURTO PRAZO (6 MESES)

.Perfil Profissional: Análise Instrumental
.Duração da Missão: 3 meses
.Início Previsto: Jul/94
.Valor: US\$ 30,000

.Perfil Profissional: Planejamento Ambiental
.Duração da Missão: 3 meses
.Início Previsto: Jan/94
.Valor: US\$ 30,000

.Perfil Profissional: Processo de Limpeza de gases de combustão
.Duração da Missão: 2,5 meses
.Início Previsto: Ago/94
.Valor: US\$ 25,000

6.1.2 - TREINAMENTO

a) No Japão

! Clientela: Equipe de Coordenação
Duração: de 15 a 30 dias
Quantidade: 10 homens/mês
Valor: US\$ 30.000,00
Natureza:

- 1) Familiarização com os aspectos de planejamento e gerenciamento de atividades de diagnósticos ambientais;
- 2) Atualização do estado-da-arte das técnicas em monitoramento da qualidade do ar;
- 3) Atualização do estado-da-arte na geração termelétrica a carvão.

b) No Brasil

Clientela: Equipes Técnicas do Projeto (On Job Training);

Técnicos e Cientistas de Outras Entidades:

- Universidades
- Centros de Pesquisas
- Órgãos Oficiais de Controle Ambiental
- Outros Interessados

Duração: Variada em função da natureza (base 40 - 80 horas)

Natureza: Diversa (aproveitamento da presença dos consultores), com assuntos relacionados às especialidades e/ou equipamentos científicos a serem utilizados pelo projeto.

Quantidade: 33 homens/mês

1/3 - nível superior, sendo:

- engenheiros;
- químicos;
- biólogos.

2/3 - Nível médio, sendo:

- técnicos em química;
- técnicos em biologia;
- laboratoristas.

6.1.3 - EQUIPAMENTOS

- a) Analisadores de gases em chaminés e/ou dutos SO_x, NO_x, CO, CO₂, HC's.
- b) Aparelhos de Amostragem/Análise do ar Atmosférico SO_x, NO_x, CO, CO₂, Partículas, etc.
- c) Amostradores de Precipitações Secas e Chuvas
- d) Equipamentos para Análise Instrumental cromatógrafos, espectrofotômetros, etc. (laboratório e campo)
- e) Amostradores e analisadores para águas superficiais, subsolo e pluviais pH, DBO, DQO, Sólidos suspensos, Metais Dissolvidos, etc.

f) Infra-estrutura de apoio em informática

- .computadores
- .impressoras
- ."scanners"
- ."plotters"

6.1.4 Valores Solicitados

Perito: US\$ 485,000.00
Treinamento: US\$ 129,000.00
Equipamentos: US\$ 650,000.00

6.2 - Contrapartida Oferecida

6.2.1 - Pessoal

Todo o efetivo de pessoal necessário à composição das equipes de gerenciamento e execução do projeto.

6.2.2 - Treinamento

Toda a infra-estrutura administrativa de apoio necessário à organização, divulgação, meios didáticos e instalação dos cursos a serem ministrados no Brasil.

6.2.3 - Material Permanente

Mobiliário e facilidades para a instalação das equipes de projeto, equipamentos de transporte terrestre e fluvial equipamentos de laboratório.

6.2.4 - Instalações

Salas de trabalho para consultores estrangeiros e equipes de projeto, bem como laboratórios de análise químicas.

6.2.5 - Diversos

Contratação de transportes especiais, bem como análise químicas e físico-químicas que não possam ser realizadas nos laboratórios das empresas.

6.2.5 - Valores de contrapartida

- Pessoal:	US\$ 569,000.00
- Serviço de Terceiros:	US\$ 50,000.00
- Material de Consumo:	US\$ 41,000.00
- Material Permanente:	US\$ 54,000.00
- Instalação:	US\$ 57,000.00
- Passagens Diárias:	US\$ 238,000.00

7. ENTIDADES PARTICIPANTES:

Ministério de Minas e Energia MME

Centrais Elétricas do Sul do Brasil S/A ELETROSUL

Companhia Estadual de Energia Elétrica CEEE

7.1 Credenciais Técnicas da Instituição Coordenadora e Executora

Coordenação

Ministério de Minas e Energia - MME

Secretaria Executiva

Esplanada dos Ministérios Bloco U - 7º Andar

Brasília DF

Titular: William S. Penido Vale - Secretário Executivo do MME

Ivonice Aires Campos - Coordenadora de Tecnologia e
Meio Ambiente do MME

Telefone com prefixo :55 61 225-4072

218-5708

Fax :55 61 322-3615

Execução

A execução deste projeto está a cargo da ELETROSUL E CEEE

ELETROSUL é uma das quatro empresas regionais da "holding" ELETROBRÁS, voltada principalmente para geração e transmissão de energia elétrica, atuando com termelétricas a carvão mineral e hidrelétricas na região sul do Brasil e no Mato Grosso do Sul, sendo vetor de integração energética dos países do Cone Sul.

CEEE é uma empresa estadual, coligada a ELETROBRÁS, cabendo ao Estado do Rio Grande do Sul a participação majoritária no seu capital social, e está voltada principalmente na geração e distribuição de energia elétrica, atuando também com termelétrica a carvão mineral.

A1. CURRICULUM VITAE

1. Nome
2. Nacionalidade, naturalidade, data de nascimento
3. Graduação
4. Pós graduação
5. Principais trabalhos realizados

JOSÉ CARLOS CARVALHO DA CUNHA - ELETROSUL

Nacionalidade: Brasileira

Naturalidade: São Gabriel/RS

Data de Nascimento: 29.11.49

Engenheiro Químico

Especialização em combustão de carvão e tecnologias limpas para o uso energético do carvão.

Principais Trabalhos Realizados:

- Desenvolvimento de tecnologia de combustão e gaseificação de carvão em reatores de leito fluidizado;
- Professor do Curso de especialização em carvão mineral (MME-CAEEB/PLANFAP);
- Projeto de caldeiras e fornalhas com queima de carvão em leito fluido;
- Estudos de atualização do estado-da-arte da termelétricidade com base na queima de carvão em caldeiras de leito fluidizado;
- Elaboração de projetos ambientais para a recuperação da região carbonífera do sul catarinense - Projeto Provida;
- Estudos preliminares de viabilidade para usina termelétrica baseadas nas chamadas tecnologias limpas para o carvão;

A1. CURRICULUM VITAE

1. Nome 2. Nacionalidade, naturalidade, data de nascimento
3. Graduação 4. Pós graduação 5. Principais trabalhos realizados

SÉRGIO TADEU LADNIUK - CEEE

Nacionalidade: brasileira

Naturalidade: Porto Alegre - RS

Data de Nascimento: 09.04.57

Engenheiro Químico

Especialização em Ecologia Humana e Gerenciamento Ambiental


Principais Trabalhos Realizados:

- Coordenação EIA/RIMA da Usina Termelétrica Candiota III
- Programa de Monitoramento Ambiental de Candiota
- Participação no Projeto de Equipamentos anti-poluente para usinas termelétricas.


SCOPE OF WORK
FOR
THE STUDY
ON
EVALUATION OF ENVIRONMENTAL QUALITY
IN REGIONS UNDER INFLUENCE OF COAL STEAM POWER PLANTS
IN
THE FEDERATIVE REPUBLIC OF BRAZIL

AGREED UPON AMONG
CENTRAIS ELETRICAS DO SUL DO BRASIL S/A,
COMPANHIA ESTADUAL DE ENERGIA ELETRICA
AND
JAPAN INTERNATIONAL COOPERATION AGENCY


BRASILIA, JANUARY 26, 1995




Mr. Claudio Avila da Silva
President
Centrais Elétricas do Sul do
Brasil S/A



Mr. Nobuyuki Yamaura
Leader of Preparatory Study
Team
Japan International
Cooperation Agency



Mr. Telmo Borba Magadan
President
Companhia Estadual de Energia
Elétrica



Mr. Sergio de Souza Fontes Arruda
Director
Agência Brasileira de Cooperação



I. INTRODUCTION

In response to the request of the Government of the Federative Republic of Brazil (hereinafter referred to as "the Government of Brazil"), the Government of Japan decided to conduct the Study on Evaluation of Environmental Quality in Regions under Influence of Coal Steam Power Plants (hereinafter referred to as "the Study ") together with the Government of Brazil, in accordance with the Basic Agreement on Technical Cooperation between the Government of Japan and the Government of Brazil, signed in Brasilia on September 22, 1970 (hereinafter referred to as "the Basic Agreement").

Accordingly, the Japan International Cooperation Agency (hereinafter referred to as "JICA"), the official agency responsible for the implementation of the technical cooperation programs of the Government of Japan, Agência Brasileira de Cooperação (hereinafter referred to as "ABC") as legal intervenient agency on behalf of the Government of Brazil, Centrais Elétricas do Sul do Brasil S/A (hereinafter referred to as "ELETROSUL"), and Companhia Estadual de Energia Elétrica (hereinafter referred to as "CEEE"), the executing agencies responsible for the implementation of the technical cooperation for the Study, will undertake the Study in close cooperation with the other Brazilian authorities concerned.

The present document sets forth the Scope of Work with regard to the Study.

II. OBJECTIVES OF THE STUDY

The Objectives of the Study are to evaluate environmental quality of air in regions under influence of coal steam power plants and to contribute to the planning for development of coal steam power plants.

The study areas are around the following three power plants.

- a) Jorge Lacerda
- b) Charqueadas
- c) Candiota

III. SCOPE OF THE STUDY

In order to achieve the objectives mentioned above, the Study shall cover following items:

ACM



1. Review of existing data and information

- (1) Socio-economic conditions and economic development policy
- (2) National policy and present situation of the electric power sector
- (3) Present situation and future plan of coal steam power plants.
- (4) Laws and regulations for air pollution control
- (5) Specification of objective power plants (facilities, fuel, stack)
- (6) Future plans of air pollution control
- (7) Collection and review of existing data concerning air pollution (ambient air quality and stationary source)

2. Survey of present status of air pollutants

- (1) Measurement of ambient conditions at each coal steam power plant
SO₂, NO_x, TSP, Acid rain, Wind direction and Velocity,
Solar radiation
- (2) Measurement of flue gas of each coal steam power plant
SO_x, NO_x, Dust, Heavy metals, Others (exhaust gas temperature and gas volume)

3. Assessment of environmental impact by pollutants from each coal steam power plant

- (1) Assessment of present environmental impact (hourly average, daily average and annual average)
- (2) Assessment of the future environmental impact after completing the reinforcement plan (hourly average, daily average and annual average)

4. Formulation of appropriate monitoring system for both ambient air quality and emission from each coal steam power plant

- (1) Planning of ambient air monitoring system surrounding of each coal steam power plant

Handwritten signature



Handwritten mark

- (2) Planning of inspecting system for emission of pollutants from each coal steam power plant
- (3) Recommendation of suitable organization and its responsibility

5. Training

In order to transfer technologies to Brazilian counterpart personnel, training on following items shall be held.

- (1) Planning of environmental monitoring and maintenance of the monitoring system
- (2) Measurement of emission gases from sources
- (3) Estimation of the effects of each power plant by numerical simulation model

IV. STUDY SCHEDULE

The Study will be carried out in accordance with the attached tentative work schedule, as shown in Appendix I.

V. REPORT

JICA shall prepare the following report in English, which will be submitted by JICA to the Government of Brazil:

1. Inception Report
Twenty (20) copies at the beginning of the Study in Brazil;
2. Interim Report
Twenty (20) copies within twelve (12) months after commencement of the Study
3. Draft Final Report and its Summary Report
Twenty (20) copies within twenty four (24) months after commencement of the Study
4. Final Report and its Summary Report
Within two (2) months after receiving the written comments on the Draft Final Report from the Government of Brazil. These comments shall be submitted to JICA by the Government of Brazil within four (4) weeks after explanation of the Draft Final Report by the Japanese Study Team.

[Handwritten signature]



[Handwritten mark]

VI. DIVISION OF TECHNICAL UNDERTAKINGS


The division of technical undertaking conducted by ELETROSUL, CEEE and JICA for the Study are shown in Appendix II.

VII. UNDERTAKING OF THE GOVERNMENT OF BRAZIL

1. The Government of Brazil shall accord privileges, immunities and other benefits to the Japanese Study Team in accordance with the Basic Agreement on Technical Cooperation between the Government of Japan and the Government of Brazil, as follows.

- (1) to ensure the safety of the Japanese Study Team;
- (2) to permit the members of the Japanese Study Team to enter, leave and stay in Brazil for the duration of their assignment therein, and exempt them from foreign registration requirements and consular fees;
- (3) to exempt the members of the Japanese Study Team from taxes, duties, and any other charges on equipment, machinery and other materials brought into Brazil and out for the conduct of the Study;
- (4) to exempt the members of the Japanese Study Team from income tax and other charges of any kind imposed on or in connection with any emoluments or allowances paid to the members of the Japanese Study Team for their services in connection with the implementation of the Study;
- (5) to provide necessary facilities to the Japanese Study Team for remittance as well as utilization of the funds introduced into Brazil from Japan in connection with the implementation of the Study;
- (6) to ensure permission for entry into private properties or restricted areas for the implementation of the Study within the laws and regulations in force in the Federative Republic of Brazil;
- (7) to ensure permission for the Japanese Study Team to take necessary data and documents (including maps, photographs) related to the Study out of Brazil to Japan;
- (8) to provide medical services as needed. Its expenses will be chargeable to the members of the Japanese Study Team.

[Handwritten signature]



57

2. The Government of Brazil shall bear claims, if any arises, against the members of the Japanese Study Team resulting from, occurring in the course of, or otherwise connected with, the discharge of their duties in the implementation of the Study, except when such claims arise from gross negligence or willful misconduct on the part of the members of the Japanese Study Team.

3. ELETROSUL and CEEE shall act as counterpart agency to the Japanese Study Team and also as coordinating body in relation with other governmental and non-governmental organizations concerned for the smooth implementation of the Study.

4. ELETROSUL and CEEE shall, at its own expense, provide the Japanese Study Team with the following, in cooperation with other relevant organizations concerned:

- (1) available data and information related to the Study;
- (2) counterpart personnel;
- (3) suitable office space with necessary equipment;
- (4) credentials or identification cards;
- (5) appropriate number of vehicles with drivers.

VIII. UNDERTAKING OF JICA

For the implementation of the Study, JICA shall take the following measures:

- (1) to dispatch, at its own expense, the Japanese Study Teams to Brazil;
- (2) to pursue technology transfer to the Brazilian counterpart personnel in the course of the Study.

IX. OTHERS

JICA, ELETROSUL and CEEE shall consult with each other in respect of any matter that may arise from or in connection with the Study.



57

TENTATIVE TIME SCHEDULE

APPENDIX 1

YEAR	1995							1996							1997												
	Calendar Month	1	2	3	4	5	6	1	2	3	4	5	6	1	2	3	4	5	6	1	2	3	4	5	6	7	8
1. Review of existing data and information																											
2. Survey of present status of air pollutants (1) Measurement of ambient conditions at each coal steam power plant																											
Continuous measurement of SO2 and NO2																											
Simple measurement of SO2 and NO2; TSP and acid rain measurement																											
(2) Measurement of flue gas of each coal steam power plant																											
3. Assessment of environmental impact by pollutants from each coal steam power plant																											
4. Formulation of appropriate monitoring system for both ambient air quality and emission from each coal steam power plant																											
5. Reports																											

▲ Discussion on Report ▲ IC/R : Inception Report ▲ IT/R : Interim Report ▲ DF/R : Draft Final Report
 ▲ Submission of Report

— JICA Work in BRAZIL
 ... JICA Work in JAPAN
 ... Brazilian Side Work



Appendix II DIVISION OF TECHNICAL UNDERTAKINGS

Working Items	Undertaking by JICA	Undertaking by ELETROSUL and CEEE
1. Review of existing data and information	<ul style="list-style-type: none"> - Review and analysis 	<ul style="list-style-type: none"> - Provision of necessary data and information
2. Survey of present status of air pollutants (1) Measurement of ambient conditions at each coal steam power plant	<ul style="list-style-type: none"> - Planning and establishment of air monitoring system - Procurement of equipment - Installation of equipment - Data analysis - Review of results 	<ul style="list-style-type: none"> - Preparation of monitoring place and electricity etc. - Assistance for installation - Measurement by simple method (SO₂, NO₂) - TSP and acid rain sampling - Routine maintenance for automatic analyzers - Chemical analysis - Data reporting
(2) Measurement of flue gas of each coal steam power plant	<ul style="list-style-type: none"> - Planning of flue gas measurement - Procurement of equipment - Execution and direction of flue gas and dust measurement - Review of results 	<ul style="list-style-type: none"> - Installation of sampling hole, working space and electricity - Execution of measurement and assistance - Chemical analysis



22

[Handwritten signature]

Working Items	Undertaking by JICA	Undertaking by ELETROSUL and CEEE
3. Assessment of environmental impact by pollutants from each coal steam power plant	<ul style="list-style-type: none"> - Programming - Estimation and assessment 	<ul style="list-style-type: none"> - Provision of necessary data and information - Confirmation of results
4. Formulation of appropriate monitoring system for both ambient air quality and emission from each coal steam power plant	<ul style="list-style-type: none"> - Formulation of inspection system for emissions - Formulation of monitoring system for ambient air quality - Cost estimation - Scheduling 	<ul style="list-style-type: none"> - Provision of necessary data and information - Confirmation of results



4

MINUTES OF MEETING
FOR
THE STUDY
ON
EVALUATION OF ENVIRONMENTAL QUALITY
IN REGIONS UNDER INFLUENCE OF COAL STEAM POWER PLANTS
IN
THE FEDERATIVE REPUBLIC OF BRAZIL

The Preparatory Study Team (the Team) organized by the Japan International Cooperation Agency (JICA) of the Government of Japan, headed by Mr. Nobuyuki Yamaura, Leader of the Team, visited the Federative Republic of Brazil from January 17 to 27, 1995 for the purpose of discussing on the Scope of Work of the Study on Evaluation of Environmental Quality in Regions under Influence of Coal Steam Power Plants in the Federative Republic of Brazil (the Study).


The Team made a series of discussion with the authorities concerned of Centrais Elétricas do Sul do Brasil S/A (ELETROSUL) and Companhia Estadual de Energia Elétrica (CEEE).

The salient result of the discussions mutually confirmed are as follows:


1. The study area of Charqueadas power plant also covers the area of prospective Jacui power plant.
2. Measurement methods are generally based on the Japanese Industrial Standard (JIS) method.
3. Brazilian side requested to analyze Co, Cr(VI), Pb, As, Be, Ni, F and Cl in suspended particulates and emission dusts.
4. Brazilian side requested to perform chemical analysis of anionic components (SO₄, NO₃, Cl and F) in rain.
5. Brazilian side requested that technical training in Japan shall be provided to counterpart personnel in the implementation of the project. The Team stated to convey the request to JICA head office.

6. Workshop shall be held when Draft Final Report Team comes to Brazil.
7. Brazilian side requested to the Team that the equipment shall be supplied for the implementation of the study, and the Team stated to convey the request to the authorities concerned.
8. Vehicles provided do not serve for commutation of Study Teams.
9. When IC/R Team comes to Brazil, precise discussion shall be held with regard to the schedule of the team in charge of installation and instruction of the measurement equipments.
10. The Participants accorded with the items of the scope of work. ELETROSUL and CEEE will perform the necessary internal procedures and will sign the S/W as soon as possible.


PORTO ALEGRE, JANUARY 25, 1995




 Mr. Duílio Biniz de Figueiredo
 Gerente do Departamento de
 Planejamento da Expansão
 Centrais Elétricas do Sul do
 Brasil S/A



 Mr. Nobuyuki Yamaura
 Leader of Preparatory Study
 Team
 Japan International Cooperation
 Agency



 Mr. Sérgio Tadeu Ladniuk
 Coordenador de Meio Ambiente
 Companhia Estadual de Energia
 Elétrica



 Mr. Oswaldo Baumgarten
 Diretor Adjunto do Departamento
 Nacional de Desenvolvimento
 Energético do
 Ministério de Minas e Energia

Attendants of the Meeting

Nelson de Oliveira

ABC / MRE

Raimundo Alves de Lima Filho

ABC / MRE

Oswaldo Baumgarten

MME

Duilio Diniz de Figueiredo

ELETROSUL

Jose de M. Ramos Filho

ELETROSUL

Edison Pereira de Lima

ELETROSUL

Fernando Yutak Takasugi

ELETROSUL

Jose Lourival Magri

ELETROSUL

Mario Rache Freitas

ELETROSUL

Sergio Ladniuk

CEEE

Luiz Henrique Mengatto

CEEE

Plinio Slomp

CEEE

Antonio Carlos Rossato

CEEE

Nobuyuki YAMAURA

JICA

Tomoyuki OKUMURA

JICA

Tsuyoshi ISHIKAWA

JICA

Mitsuru FUJIMURA

JICA

Haruo ONO

JICA

Jorge NINOMIYA -

Interpreter

2
\$

Appendix 1-3

List of Existing Equipment available for the JICA Study

Jorge Lacerda Power Station

Power Plant's Laboratory	Electric Oven, Desiccator, pH meter, Electro-conductivity meter, and others
Power Plant's Mete. Observatory	Anemoscope (AH120/5: 0 - 540°) Anemometer (AH-110/5: 0 - 30 m/s) Pyranometer (RH-6010: 0 - 1330 W/m) Rain Guage (PH-310P: 0 - 330 mm/h)
Capivari Air Monitoring Station	High Volume Sampler of TSP Low Volume Sampler of SPM 15 μ m Shelter & Accessories for JICA Equip.
Vila Moema Air Monit. Station	High Volume Sampler of TSP Shelter & Accessories for JICA Equip.
Sao Bernardo Air Monit. Station	High Volume Sampling of TSP Shelter & Accessories for JICA Equip.

Charqueadas Power Plant

Power Plant's Laboratory	Room & Furniture for JICA Lab. Electric Oven, Desiccator and others
Jaqui Air Monitoring Station	Anemoscope Anemometer Pyranometer Rain Gauge High Volume Sampler of TSP Shelter & Accessories for JICA Equip.
Arranca Toco Air Monit. Station	High Volume Sampler of TSP Shelter & Accessories for JICA Equip.
DEPRC Air Monitoring Station	Shelter & Accessories for JICA Equip.

Candiota Power Plant

Power Plant's Laboratory	Electric Oven, Desiccator, pH meter Electro-conductivity meter, and others
Airport Air Monitoring Station	Anemoscope Anemometer Pyranometer Rain Guage High Volume Sampler of TSP Shelter & Accessories for JICA Equip.
Candiota III Air Monit. Station	High Volume Sampler of TSP Shelter & Accessories for JICA Equip.
Lago Air Monitoring Station	Shelter & Accessories for JICA Equip.

ITEM	SPECIFICATION	No. of Req'd																																										
Ambient Air Monitoring																																												
1-1-1	<p>Automatic NOx Analyzer · HORIBA Co., APNA-360</p> <p>Method: Chemiluminescence</p> <p>Range: 0 · 0.1/0.2/0.5/1.0ppm (changeable automatically & manually)</p> <p>Detectable Limit: 0.5 ppb</p> <p>Zero Point Adjustment: Automatic</p> <p>Zero Drift: ± 1.0% of full scale/24hrs or ± 2.0% of full scale/week</p> <p>Span Drift: ditto</p> <p>Analogue Output: Selectable 0-1 V(DC), 0-10 V(DC), 4-20 mA(DC)</p> <p>Two Outputs: Current and summation (or average) values</p> <p>Data Storage: 1 hr summation value · 1000 data (equiv. to 1.5 months)</p> <p>Sensitivity: Zero drift free, 0.1 ppm sensitivity, High stability</p> <p>Power: Supply 100 VAC, 60 Hz; Consumption less than 200 VA</p>	3 sets																																										
Consumable and Spare Parts																																												
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 40%; text-align: left;">Name</th> <th style="width: 30%; text-align: left;">Code</th> <th style="width: 30%;"></th> </tr> </thead> <tbody> <tr> <td>1. PPD Capillary</td> <td>U801200600</td> <td>6 sets</td> </tr> <tr> <td>2. Air Filter</td> <td>H443672-02</td> <td>3 sets</td> </tr> <tr> <td>3. DO Unit</td> <td>U801154200</td> <td>3 sets</td> </tr> <tr> <td>4. Filter Element</td> <td>F021434400</td> <td>3 sets</td> </tr> <tr> <td>5. O-Ring</td> <td>F020223700</td> <td>3 sets</td> </tr> <tr> <td>6. F-Packing</td> <td>H457606-02</td> <td>3 sets</td> </tr> <tr> <td>7. UV Lamp Unit</td> <td>U800952700</td> <td>3 sets</td> </tr> <tr> <td>8. UV Liner</td> <td>H533781-01</td> <td>3 sets</td> </tr> <tr> <td>9. CAT Pipe Unit</td> <td>U800694300</td> <td>3 sets</td> </tr> <tr> <td>10. Diaphragm</td> <td>9022002900</td> <td>6 sets</td> </tr> <tr> <td>11. Silica Gel</td> <td>F022298500</td> <td>3 sets</td> </tr> <tr> <td>12. Pump Unit (100V, 60Hz)</td> <td>U801145900</td> <td>3 sets</td> </tr> <tr> <td>13. Solenoid Valve</td> <td>U801163300</td> <td>9 sets</td> </tr> </tbody> </table>			Name	Code		1. PPD Capillary	U801200600	6 sets	2. Air Filter	H443672-02	3 sets	3. DO Unit	U801154200	3 sets	4. Filter Element	F021434400	3 sets	5. O-Ring	F020223700	3 sets	6. F-Packing	H457606-02	3 sets	7. UV Lamp Unit	U800952700	3 sets	8. UV Liner	H533781-01	3 sets	9. CAT Pipe Unit	U800694300	3 sets	10. Diaphragm	9022002900	6 sets	11. Silica Gel	F022298500	3 sets	12. Pump Unit (100V, 60Hz)	U801145900	3 sets	13. Solenoid Valve	U801163300	9 sets
Name	Code																																											
1. PPD Capillary	U801200600	6 sets																																										
2. Air Filter	H443672-02	3 sets																																										
3. DO Unit	U801154200	3 sets																																										
4. Filter Element	F021434400	3 sets																																										
5. O-Ring	F020223700	3 sets																																										
6. F-Packing	H457606-02	3 sets																																										
7. UV Lamp Unit	U800952700	3 sets																																										
8. UV Liner	H533781-01	3 sets																																										
9. CAT Pipe Unit	U800694300	3 sets																																										
10. Diaphragm	9022002900	6 sets																																										
11. Silica Gel	F022298500	3 sets																																										
12. Pump Unit (100V, 60Hz)	U801145900	3 sets																																										
13. Solenoid Valve	U801163300	9 sets																																										

ITEM	SPECIFICATION	No. of Req'd																																								
1-1-2	<p>Automatic SO₂ Analyzer - HORIBA APSA-360</p> <p>Method: Ultraviolet Fluorimeter</p> <p>Range: 0-0.05/0.1/0.2/0.5 ppm (changeable automatically & manually)</p> <p>Detection Limit: 0.5 ppb</p> <p>Zero Drift: ± 1.0 ppb/24hrs or ± 2.0 ppb/week</p> <p>Span drift: ± 1.0% of full scale/24hrs or ± 2.0% of full scale/week</p> <p>Analogue output: Selectable of 0-1 V(DC), 0-10 V(DC), or 4-20 mA(DC)</p> <p>Two Outputs: Current and summation (or average) values</p> <p style="padding-left: 40px;">Connectable to RS-232C (deci-chain)</p> <p>Data Memory: 1000 data of 1 hr value (equiv. to 1.5 months data)</p> <p>Light source: Long life xenon lamp</p> <p>Power: Supply-100 VAC, 60Hz, Consumption-150 VA</p>	9 sets																																								
	<p>Automatic Voltage Regulator (SVC-1030-A)</p> <p>Input : single phase 220 VAC, 48Hz-62Hz</p> <p>Input Variation: ± 15% (187 - 253 V)</p> <p>Output : 100 VAC, Accuracy ±(1.0 - 1.5)%</p> <p>Capacity : 3.0 KVA</p> <p>Response Speed : within 1.0 sec to 10% of abrupt change of input voltage</p>	9 sets																																								
	<p>Lightning Arrester (RP-200, Mfg No. 59920804M)</p> <p>Input : single phase 220 VAC</p> <p>Output : single phase 220 VAC</p> <p>Capacity : 3 KVA</p> <p>Including double coils, case cover and connectors</p>	9 sets																																								
	<p>Earth rod: Length more than 30 cm/set</p>	9 sets																																								
	<p>Earthing Line: total 150 m</p> <p style="padding-left: 40px;">1 V more than 5.5 mm² or better grade than UL-AWG-No. 10</p>	150 m																																								
	<p>File Conversion CPU Soft: total 1 unit/9 sets</p> <p style="padding-left: 40px;">Possible to convert binary file of data floppy to text file</p>	1 set																																								
Consumable and Spare Parts																																										
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Name</th> <th>Code</th> <th>Req'd No./set</th> </tr> </thead> <tbody> <tr> <td>1. Filter Element</td> <td>F021434400</td> <td>4</td> </tr> <tr> <td>2. Diaphragm</td> <td>9022002900</td> <td>1</td> </tr> <tr> <td>3. HC Cutter</td> <td>9022003700</td> <td>1</td> </tr> <tr> <td>4. Xenon Lamp</td> <td>9022003800</td> <td>1</td> </tr> <tr> <td>5. Air Filter</td> <td>H443672-02</td> <td>1</td> </tr> <tr> <td>6. Filter Element</td> <td>F021565700</td> <td>1</td> </tr> <tr> <td>7. CAT Pipe Unit</td> <td>U801145600</td> <td>1</td> </tr> <tr> <td>8. O-ring</td> <td>U801150900</td> <td>1</td> </tr> <tr> <td>9. Pump Unit (110 V, 60 Hz)</td> <td>9022003400</td> <td>1</td> </tr> </tbody> </table>	Name	Code	Req'd No./set	1. Filter Element	F021434400	4	2. Diaphragm	9022002900	1	3. HC Cutter	9022003700	1	4. Xenon Lamp	9022003800	1	5. Air Filter	H443672-02	1	6. Filter Element	F021565700	1	7. CAT Pipe Unit	U801145600	1	8. O-ring	U801150900	1	9. Pump Unit (110 V, 60 Hz)	9022003400	1	<table border="1" style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td>36 sets</td> </tr> <tr> <td>9 sets</td> </tr> <tr> <td>9 sets</td> </tr> <tr> <td>9 sets</td> </tr> <tr> <td>9 sets</td> </tr> <tr> <td>9 sets</td> </tr> <tr> <td>9 sets</td> </tr> <tr> <td>9 sets</td> </tr> <tr> <td>9 sets</td> </tr> <tr> <td>9 sets</td> </tr> </tbody> </table>	36 sets	9 sets	9 sets	9 sets	9 sets	9 sets	9 sets	9 sets	9 sets	9 sets
Name	Code	Req'd No./set																																								
1. Filter Element	F021434400	4																																								
2. Diaphragm	9022002900	1																																								
3. HC Cutter	9022003700	1																																								
4. Xenon Lamp	9022003800	1																																								
5. Air Filter	H443672-02	1																																								
6. Filter Element	F021565700	1																																								
7. CAT Pipe Unit	U801145600	1																																								
8. O-ring	U801150900	1																																								
9. Pump Unit (110 V, 60 Hz)	9022003400	1																																								
36 sets																																										
9 sets																																										
9 sets																																										
9 sets																																										
9 sets																																										
9 sets																																										
9 sets																																										
9 sets																																										
9 sets																																										
9 sets																																										

ITEM	SPECIFICATION	No. of Req'd																		
1-1-3	<p>NO_x Span Gas Generator - HORIBA SGGU-514</p> <p>Blank Gas: Air to be purified in the generator</p> <p>Purity - NO less than 0.001 ppm</p> <p>H₂O saturation at 0°C</p> <p>Stabilized within 5 min</p> <p>NO Gas: Packed in cylinder, 90 ppm in nitrogen gas</p> <p>Span Gas: NO gas dilution with purified air by regulated flow ratio</p> <p>Dilution Ratio Indication: ±5%; Accuracy ±2% of indicated dilution</p> <p>Span Gas Concentration: 0.09 ppm of NO in purified air</p> <p>Span Gas Flow Rate: 2.5 l/min (overflow at 500 ml/min)</p> <p>Span Gas Pressure: 10 mmAq Gauge</p> <p>Span Gas Stabilization: within 10 min</p> <p>Power: AC 100 VAC, 60 Hz, Consumption-100 VA</p> <p>Consumable and Spare Parts</p> <table border="1" data-bbox="292 969 1142 1227"> <thead> <tr> <th>Name</th> <th>Code</th> <th>Require No./set</th> </tr> </thead> <tbody> <tr> <td>1. Silicagel</td> <td>F021100500</td> <td>8</td> </tr> <tr> <td>2. Charcoal</td> <td>F021100600</td> <td>4</td> </tr> <tr> <td>3. Purifier Unit</td> <td>F02191100</td> <td>1</td> </tr> <tr> <td>4. Filter Element</td> <td>H435126-01</td> <td>4</td> </tr> <tr> <td>5. Gas Filter</td> <td>F021100400</td> <td>8</td> </tr> </tbody> </table>	Name	Code	Require No./set	1. Silicagel	F021100500	8	2. Charcoal	F021100600	4	3. Purifier Unit	F02191100	1	4. Filter Element	H435126-01	4	5. Gas Filter	F021100400	8	3 sets
Name	Code	Require No./set																		
1. Silicagel	F021100500	8																		
2. Charcoal	F021100600	4																		
3. Purifier Unit	F02191100	1																		
4. Filter Element	H435126-01	4																		
5. Gas Filter	F021100400	8																		
1-1-4	<p>SO₂ Span Gas Generator - HORIBA SGGU-514</p> <p>Blank Gas: Air to be purified in the generator</p> <p>Purity - SO₂ less than 0.01 ppm</p> <p>H₂O saturation at 0°C</p> <p>Stabilized within 5 min</p> <p>SO₂ Gas: Packed in cylinder, 45 ppm in nitrogen gas</p> <p>Span Gas: SO₂ gas dilution with purified air by regulated flow ratio</p> <p>Dilution Ratio Indication: ±5%; Accuracy ±2% of indicated dilution</p> <p>Span Gas Concentration: 0.045 ppm of SO₂ in purified air</p> <p>Span Gas Flow Rate: 2.5 l/min (overflow at 500 ml/min)</p> <p>Span Gas Pressure: 10 mmAq Gauge</p> <p>Span Gas Stabilization: within 10 min</p> <p>Power: AC 100 VAC, 60 Hz, Consumption-100 VA</p>	3 sets																		

ITEM	SPECIFICATION	No. of Req'd																		
1-1-4 cont'd	<p>Consumable and Spare Parts</p> <table border="1"> <thead> <tr> <th>Name</th> <th>Code</th> <th>Require No./set</th> </tr> </thead> <tbody> <tr> <td>1. Silicagel</td> <td>F021100500</td> <td>8</td> </tr> <tr> <td>2. Charcoal</td> <td>F021100600</td> <td>4</td> </tr> <tr> <td>3. Purifier Unit</td> <td>F02191100</td> <td>1</td> </tr> <tr> <td>4. Filter Element</td> <td>H435126-01</td> <td>4</td> </tr> <tr> <td>5. Gas Filter</td> <td>F021100400</td> <td>8</td> </tr> </tbody> </table>	Name	Code	Require No./set	1. Silicagel	F021100500	8	2. Charcoal	F021100600	4	3. Purifier Unit	F02191100	1	4. Filter Element	H435126-01	4	5. Gas Filter	F021100400	8	<p>24 pc's 12 pc's 3 pc's 12 pc's 24 pc's</p>
Name	Code	Require No./set																		
1. Silicagel	F021100500	8																		
2. Charcoal	F021100600	4																		
3. Purifier Unit	F02191100	1																		
4. Filter Element	H435126-01	4																		
5. Gas Filter	F021100400	8																		
1-1-5	<p>Data Logger - HORIBA DL-360</p> <p>No. of Channel: 8</p> <p>Analogue Input: Selectable of 0-1 V(DC), 0-10 V(DC), 0-16 mV, or 4-20 mA(DC)</p> <p>Resolution: 12 bits</p> <p>Accuracy: $\pm 0.5\%$ or within ± 1 digit, to be isolated</p> <p>Data File: 3.5 inches floppy</p> <p>Recordable - Hourly data for more than 1 month/floppy</p> <p>Record Frequency - every hour on the hour</p> <p>Data: binary</p> <p>Watch: year to second (autocalender) with power failure compensation</p> <p>Memory Back-up: When power failure, set values and data to be backed up with automatic recovery system upon power supply</p> <p>Power Supply: 100 VAC, 50 - 60 Hz</p> <p>Consumable and Spare Parts for 24 months operation</p>	9 sets																		
1-1-6	<p>6 Points Recorder - YOKOGAWA μ R-1800</p> <p>Input Signal: DC 0-100 mV, 0-1 V</p> <p>Recording Paper Speed: 1 - 10 mm/hr (1 mm/hr step)</p> <p>Effective Paper Width: 180 mm</p> <p>Power: 100 VAC, 60 Hz, Consumption 22VA</p> <p>Consumable and Spare Parts</p> <table border="1"> <tbody> <tr> <td>1. Ribbon Cassette</td> <td>3 pc's/set</td> <td>27 pc's</td> </tr> <tr> <td>2. Recording Paper</td> <td>25 volumes/set</td> <td>230 vols</td> </tr> </tbody> </table>	1. Ribbon Cassette	3 pc's/set	27 pc's	2. Recording Paper	25 volumes/set	230 vols	9 sets												
1. Ribbon Cassette	3 pc's/set	27 pc's																		
2. Recording Paper	25 volumes/set	230 vols																		
1-1-7	<p>Cylinder Gases</p> <table border="1"> <tbody> <tr> <td>1. 90 ppm of NO in nitrogen</td> <td>10 liter cylinder</td> <td>1 cylinder/set</td> <td>3 cyldrs</td> </tr> <tr> <td>2. 45 ppm of SO₂ in nitrogen</td> <td>ditto</td> <td>3 cylinders/set</td> <td>9 cyldrs</td> </tr> <tr> <td>3. Two Stage Pressure Controller</td> <td></td> <td>4 pc's /set</td> <td>12 pc's</td> </tr> </tbody> </table> <p>Inlet 250 kg/cm², Secondary Stage 5 kg/cm²</p> <p>Outlet Joint RC 1/4 T joint (for Teflon tube)</p>	1. 90 ppm of NO in nitrogen	10 liter cylinder	1 cylinder/set	3 cyldrs	2. 45 ppm of SO ₂ in nitrogen	ditto	3 cylinders/set	9 cyldrs	3. Two Stage Pressure Controller		4 pc's /set	12 pc's							
1. 90 ppm of NO in nitrogen	10 liter cylinder	1 cylinder/set	3 cyldrs																	
2. 45 ppm of SO ₂ in nitrogen	ditto	3 cylinders/set	9 cyldrs																	
3. Two Stage Pressure Controller		4 pc's /set	12 pc's																	

ITEM	SPECIFICATION	No. of Req'd
1-1-8	Miscellaneous for ITEM 1-1.	
1-1-8-1	Equipment Support Rack	9 sets
	Cylinder Rack for 3 cylinder	3 sets
	for 2 cylinder	6 sets
	Cables and Pippings	9 sets
1-1-8-2	Sampling Fittings for NO _x and SO ₂	
	1. Teflon Tube: 6 x 8 mm	150 m
	2. Polypropylene Funnel	22 pc's
	3. Silicon Tube: 7 x 12 mm	10 m
1-1-8-3	Cable: CVV 5.5 mm ² 100 m/coil	1 coil
1-2-1	Automatic Rain Sampler - OGASAWARA US-410 "SUMPLER"	4 sets
	Rain Fall: Receiver - 200 mm diameter; made with stainless and coated with Teflon	
	Filter - membrane; 0.8 μ m, 47 mm diameter	
	Water Tank - 20 liter polyethylene tank	
	Dry Deposition Collector: Receiver - 200 mm diameter; made with stainless and coated with Teflon	
	Power: 100 VAC, 60 Hz, 125 VA for 3 sets (M. No. 51247 - 9)	
	125 VAC, 60 Hz, 125 VA for 1 set (M. No. 51246)	
	Consumable and Spare Parts	
	1. Deposit gage 1 unit/set	4 units
	2. Water tank 1 unit/set	4 units
	3. Membrane filter 100 sheets/unit	4 units
1-3	Net Pyrradiometer - EIKO MF-11	3 sets
	Principle: Cu-Constantan bi-metal thermocouple	
	Sensitivity: more than 25 mV/KW x m ⁻² , Shunt box sensitivity - 7 mV	
	Wave Range: 0.3 - 30 μ m	
	Power: 100 VAC, 60 Hz	
	Including: Supports, Shunt box(SS-1), 2 boxes of Polyethylene domes, Summater (MP-200) Output= 0-10 mV DC, Cable (50 m) Silicagel (500 g), Scale; each/set	
	Messenger Cable 5 mm diameter 50 m in total/3 sets	50 m
	Wire Clips 30 pc's in total/3 sets	30 pc's

ITEM	SPECIFICATION	No. of Req'd
1-4	Ambient Air Simple Monitor - NIGORIKAWA	
	Shelter: NG-KN-SH	110 pc's
	Sampler Case: NG-KN-S	340 pc's
	Case Stem: PVC 26 mmOD x 20 mmID x 1800 mm(length)	110 pc's
	Support Metal Rod: Length 80 cm, OD 20 mm	110 pc's
	Sampler Transporter: Wooden, containable 20 samplers	6 pc's
	Filter Paper: 26 mm round, cellulose fibers, 100 sheets	24 boxes
	Metal Wire: 1 mm in diameter	200 m
1-5	Tools and Miscellaneous Parts:	
	1. Tool Kit, HOZAN S-45	3 sets
	2. Adjustable Wrench for Gas Cylinder	3 pcs
	3. Wire Binder, 100 mm, 100 pcs / case	3 cases
	4. Wire Binder, 140 mm, ditto	3 cases
	5. Wire Binder, 180 mm, ditto	3 cases
	6. Gum Tape, 50 mm x 25 m	9 pcs
	7. Vinyl Tape, 19 mm x 10 m	30 pcs
	8. Teflon Seal Tape, 0.1 mm x 13 mm x 15 m	15 pcs
	9. Instant Bond, ARON-ALFA, 2 g, 5 tubes / box	3 boxes
	10. Bond, Two Chemicals Type, 30 g	3 sets
	11. Saw	1 pcs
	12. Saw Blade	15 pcs
	13. Portable Electric Drill	3 pcs
	14. Drill Blade, 1,2,3,4,5,6,7,8,9,10 mm diameter	3 sets
	15. Silicon Sealing Compound, White, 330 ml / pcs	6 pcs
	16. Pipe Wrench, 300 mm	3 pcs
	17. Electric Wire Terminal Set, T-10	6 sets
	18. ditto, T-20	6 sets
	19. ditto, T-30	6 sets
	20. Digital Tester	3 pcs
	21. Wire Terminal Crimping Tool with Wire Stripper	3 pcs
	22. Wire Terminal Crimping Tool	3 pcs
	23. Precision Screw Driver set	3 sets

ITEM	SPECIFICATION	No. of Req'd
2-2	<p>Automatic NO_x-O₂ Analyzer - SHIMADZU NOA-7000</p> <p>Principle: For NO_x - atmospheric chemiluminescence O₂ - Zirconia method</p> <p>Range: NO_x 0-25/50/250/500/1000/2500/4000 ppm O₂ 0-5/10/25 vol%</p> <p>Re-producibility: ±0.5% of full scale</p> <p>Zero Drift: ± 1.5% of full scale in ±5°C</p> <p>Span Drift: ditto</p> <p>Linerability: ±2% of full scale</p> <p>Response: NO_x - 20/30/60 sec changeable O₂ - 30/60 sec changeable</p> <p>Sample Gas: Flow rate 2.0 liter/min , Pressure -100 to +100 mmAq G Dust less than 0.1 g/Nm³ Contaminants CO less than 500 ppm SO₂ less than 1000 ppm NO₂ less than 300 ppm NH₃ less than 20 ppm CO₂ less than 30 vol% SO₃ less than 50 ppm H₂O less than 10 wt% CH₄ less than 1000 ppm</p> <p>Display: Liquid crystal (320 x 200 dots), 3 displays simultaneously</p> <p>Output: 0-1 VDC (3 channels)</p> <p>Data: Memory card</p> <p>Operation: within 5-37°C</p> <p>Power: AC 100 V, 60 Hz</p> <p>Carry Case: one/set</p> <p>Cylinder Gas: 250 ppm NO in nitrogen, 0.5% O₂ in nitrogen, 9.0% O₂ in nitrogen, and nitrogen blank gas, each 3.4 liter cylinder</p> <p>Recorder: US-211, 100 mm width</p> <p>Pressure Regulator: TUS-1090</p> <p>Pressure Regulator: TU-1085</p> <p>Cylinder Support: for 4 cylinders</p> <p>Pretreatment Unit - SHIMADZU CFP-301 Cooler Capacity: cool sample down to 1.5 - 3.5°C Sampling Rate: max. 3 liter/min</p>	<p>2 sets</p> <p>2 sets</p> <p>each 3 cylinders</p> <p>2 units</p> <p>2 units</p> <p>4 units</p> <p>3 units</p> <p>2 sets</p>

ITEM	SPECIFICATION	No. of Req'd
2-2	Consumable and Spare Parts	2 sets
cont'd	1. Chart 3AA	2 boxes
	2. Cartridge Ink Pad 2 in one pack	2 packs
	3. Diaphragm for Sample Pump, Air Pump, and Drain Pump	each 2 sets
	4. Converter Reaction Tube with Catalyst	2 sets
	5. NH ₃ Absorbent 6 pc's in one box	4 boxes
	6. SO ₂ Absorbent 186 g packed	4 packs
	7. O-ring 5 pc's in one pack	2 packs
	8. Polypropylene Cotton 100 g	2 packs
	9. Filter Membrane 50 sheets in one pack	2 packs
	10. Ozone Killer Catalyst 300 g in one pack	2 packs
	11. Front Filter 2 sheets in one pack	2 packs
	12. Rear Filter 6 sheets in one pack	2 packs
	13. Silicagel Case	2 cases
2-3	TSP Measurement	
2-3-1	Dynamic Balance Dust Sampler - NIGORIKAWA NG-Z-2N, Sampler Probe - NIGORIKAWA NG-Z-4	2 sets
	Pitot Tube: Type 304 stainless steel, 6 mm in diameter with a cylindrical filter paper holder of 34 mm in diameter, each one piece of 2 and 4 m length/set; in Al cases	
	Accessories	
	1. Gas Pump - NIGORIKAWA NG-17S; Capacity: 100 liter/min, Equipped with mist oil separator, needle valve, and casters; in Al cases	2 sets
	2. Wet Gas Meter - NIGORIKAWA W-NK-2.5A; 5 liter/revolution; in AL case	2 sets
	3. Mist Separator - NIGORIKAWA NG-Z-19; SO ₂ Remover-700 ml bottle; Dryer-500 ml bottle; each one bottle/set	2 sets
	4. Gas Hose - 9 mm ID x 21 mm OD x 30 m Length rubber	2 hoses
	5. Tumble Filter set	
	5-1. Holder - Type G-23; Stainless 304; 25 mm Diameter x 90 mm	10 sets
	5-2. Suction Nozzle - NG-25; Stainless 304; 4,6,8,10 mm Diameter; each 3 pieces/set	2 sets
	5-3. Clamp - NG-28; Stainless 304	12 pieces
	5-4. Case - NG-23B	4 sets

ITEM	SPECIFICATION	No. of Req'd
2-3-1	6. Flange - NG-30; 200 mm diameter x 3 mm Thickness	2 pieces
cont'd	7. Cord Reel - AC100, 15A; 30 m coil	4 coils
	8. Table Tap - 3 outlets	8 pieces
	9. Tool Set	2 sets
	Consumable	
	1. Cylindrical Filter - 25 mm Diameter x 90 mm; 10 pieces/set; Silica	50 sets
	2. Differential Pressure Tube - 4 colors; 6 mm ID x 8 mm OD x 30 m L	2 pieces
	3. Pincette - IPT-05; 120 mm Length	6 pieces
	4. Pincette - IPT-12; 165 mm Length	6 pieces
	5. Glove - NT-100; 350°C heat resistance; 400 mm Length	20 pairs
	6. Teflon Tube - 6 mm ID x 8 mm OD x 30 m Length	4 pieces
	7. Silicon Tube - 6 mm ID x 10 mm OD x 10 m Length	4 pieces
	8. Silica Gel - 18 liter canned	2 cans
	9. Container Case - Type 75H; 656 x 456 x 356 mm; 2/set	
2-3-2	Water Measurement Unit - NIGORIKAWA	2 sets
	1. Suction Tube - NG-11-H with regulator; with Case of Stainless 304	
	2. Flange - Stainless 304; 200 mm Diameter x 3 mm Thickness	
	3. Gas Meter (wet) - W-NK-1A; 1 liter/revolution; in Al case	
	4. Gas Pump - NG-15-N; 15 liter/min; in a case	
	5. SO ₂ Washer - NG-19; Bottle in a case	
	6. Cooling Water Box - NG-15; with a support stand and in a case	
	7. Electronic Balance - PB303; Metler; 310 g; Sensitivity-1 mg; Dish-100mm Diameter	
	8. Dehumidifier - NG-12; Sheffield 10 piece/set in a case	
	Accessory	
	1. Seal for Measurement Hole - SC cloth; 3 mm T x 50 mm x 30 mL	4 roles
	2. Stopwatch - SSj018; with spare battery	4 sets
	3. Gas Hose - 6 mm ID x 15 mm OD x 30 m	2 hoses
	Consumable	
	1. CaCl ₂ - 500 g	20 bottles
	2. Rock Wool - 1 kg	4 packs
	3. Heat Resistance Adhesive Tape - 0.18 mm T x 19 mm W x 10 mL	40 roles
	4. Vinyl Tape - 0.2 mm T x 19 mm W x 10 mL	40 roles
	5. Seal Tape - 0.1 mm T x 13 mm W x 5 mL	40 roles
	6. Silicon Grease - 50 g	20 bottles
	7. Cotton - 10 boxes/case	2 cases

ITEM	SPECIFICATION	No. of Req'd
Chemical Analysis		
3-1	<p>Digital Electric Conductivity Meter - TOA Electronics CM-40V</p> <p>Display - Digital, Fluorescent</p> <p>Indication - Conductivity; 0-199.9 μ S/m, -1.999 mS/m, -19.99 mS/m, -199.9 mS/m, -1.999 S/m, -19.99 S/m, -199.9 S/m</p> <p>Resistivity; 0-1.999 Ω m, -19.99 Ω m, -199.9 Ω m, -1.999k Ω m, -19.99k Ω m, -199.9k Ω m, -1.999M Ω m</p> <p>Concentration; 0-1.999%, -19.99%, -199.9%</p> <p>Temperature; 0-100°C</p> <p>Range Selection - Automatic or Manual</p> <p>Temperature Compensation - 0-100°C</p> <p>Temperature Coefficient - 0-10%/deg C</p> <p>Standard Temperature - 0-100°C variable</p> <p>Measuring Wave Frequency - 80 Hz and 3 KHz</p> <p>Output - 0-1 V full scale</p> <p>Accessory</p> <ol style="list-style-type: none"> 1. Conductivity Cell - CT-54101B; including spares 2. Plastic Beaker - 150 ml 3. Cell Holder - Free arm 4. Earthing wire, Cord, and AC adapter <p>Power Supply - 220V and 60 Hz</p>	<p>1 set</p> <p>3 cells</p> <p>1 pieces</p> <p>1 set</p> <p>1 set</p>
3-2	<p>Digital pH Meter - TOA Electronics HM-40V</p> <p>Indication - Digital; pH, mV, and temperature</p> <p>Temperature Compensation - Automatic 0-100°C</p> <p>Measuring Range - pH 1-14 (0.01pH), 0-\pm1999 mV(1 mV), 0-100°C (0.1°C)</p> <p>Output - pH \pm 700 mV, mV \pm 1 mV, Temp. 0-1 V</p> <p>Calibration - Automatic at pH 1, 4, 7, 9, 12</p> <p>Standard Accessory</p> <ol style="list-style-type: none"> 1. Cell - GST-5421C; including spare 2. Standard Solution - pH=4.01, 6.86, 9.18, and 3.3 mol/liter KCl each 500 ml 3. Plastic Beaker 150 ml 4. Earthing Wire, Cord, AC Adapter 	<p>1 set</p> <p>3 cells</p> <p>each 2 bttls</p> <p>1 set</p> <p>1 set</p>

ITEM	SPECIFICATION	No. of Req'd
3-3	Glass Wares	1 set
	1. Graduated Cylinder, Stand Grade, w/Glass Stopper	100 pcs
	2. Centriguge Tube, round Bottom, w/Stopper	100 pcs
	3. Support Stand for 50 Test Tubes	2 pcs
	4. Pipette, 10 ml	20 pcs
	5. Rubber Bulb for 10 ml Pipette	10 pcs
	6. Macro-pipette Dispenser, 0.2 - 1.0 ml, accuracy $\pm 1\%$	2 pcs
	7. Support Stand for 5 macro-pipettes	1 pcs
	8. 200 Tips for Macro-pipette / box	2 boxes
	9. Micro-syringe, 250 μ litre, Changable Needles	2 pcs
	10. Needles, Type A, 50 mm, 5 pcs / box	2 boxes
	11. Para-film, 4 inches x 125 feet	2 pcs
3-4	Chemicals	
	1. Methan-sulfonic acid - First Grade, 500 g	2 bottles
	2. Sodium carbonate - Extra Grade, 500 g	2 bottles
	3. Sodium bicarbonate - ditto	2 bottles
	4. PTIO - TOKYO KASEI Reagent, 5 g	15 bottles
	5. Acetone - Extra Grade, 500 ml	5 bottles
	6. 30% Hydrogen peroxide - Extra Grade, 500 ml	2 bottles
3-5	Ion Chromatograph; Puchased from ACATEC - Sao Paulo	
1)	43066 - DX-100 Ion Chromatograph - two column set Power Supply: 110 V, 60 Hz	1 set
	(Component Parts of ITEM 3-5 - 1)	
2)	43117 - TS-2 Thermal Stabilizer	1 set
3)	43174 - IONPAC AS4A-SC 4mm Column	1 set
4)	43175 - IONPAC AG4A-SC 4mm Guard Column	2 sets
5)	43189 - ASRS 4mm Anion Self Regenerating Suppressor	1 set
6)	38018 - MMS/SRS External Regen Installation Kit	2 sets
7)	46073 - IONPAC CS-12A 4mm Analytical Column	1 set
8)	46074 - IONPAC CG-12A 4mm Guard Column	2 sets
9)	43190 - CSRS 4mm Cation Self Regenerating Suppressor	1 set
10)	42132 - 4400 Integrator 115/230V 1 Channel with Extended BASIC	1 set
11)	42819 - 4400 Startup Kit (Paper Rack, Paper, Printhead Cartridge)	1 set
12)	46029 - AS40 Automated Sampler with Starter Vial Kit (5ml)	1 set
13)	43051 - DX100 Automation Cable, DX100 to Integrator to ASM	1 set

ITEM	SPECIFICATION	No. of Req'd
14)	43050 - DX100 Spare Parts Kit	1 set
15)	37157 - Combined Five Anion Standard, 100mL	1 set
16)	40187 - Combined Six Cation Standard-I, 50mL	1 set
17)	Nitrogen Cylinders (99.99%) 7 M ³	2 btl's
18)	Pressure Regulator Stainless Steel	1 set
	(Consumable & Spare Parts, and Manuals of ITEM 3-5)	
19)	35686 - Piston Seal	4 sets
20)	38599 - Portface, CHA	16 sets
21)	42368 - Pressure Bolts (10-32 fitting)	4 sets
22)	43275 - Bolt, Double Cone Ferrule Fitting(10-32 thread)	10 sets
23)	37627 - Fitting, 1/8"	5 sets
24)	30538 - Fitting Tee, Air Line	4 sets
25)	30538 - Fitting Tee, Air Line	4 sets
26)	43276 - Ferrule, Double Cone(10-32 thread)	10 sets
27)	39167 - Quick Disconnect for Air Tubing	2 sets
28)	42690 - Tube, PEEK, 100 m	1 set
29)	14157 - Tube, Teflon, Low Pressure, 100 m	1 set
30)	35113 - Gasket, Transducer	2 sets
31)	35777 - O-ring, 0.614 x 0.07	2 sets
32)	35014 - Spring, Piston for DX-100	2 sets
33)	36901 - Back-up Seal	2 sets
34)	42955 - Bed Support	10 sets
35)	43146 - Inline Filter Kit	2 sets
36)	43112 - Inline Filter Refills	2 sets
37)	43945 - Pulse Damper for DX-100	1 set
38)	43174 - IONPAC AS4A-SC 4mm Analytical Column	1 set
39)	43175 - IONPAC AG4A-SC 4mm Guard Column	2 sets
40)	43189 - ASRS 4mm Anion Self Regenerating Suppressor	1 set
41)	46073 - IONPAC CS-12A 4mm Analytical Column	1 set
42)	46074 - IONPAC CG-12A 4mm Guard Column	2 sets
43)	43190 - CSRS 4mm Cation Self Regenerating Suppressor	1 set
44)	42821 - 4400-4460 Printhead (5 packages)	2 boxes
45)	4400 - Paper, 2500 sheets	4 boxes
46)	38141 - Polyvials, c/Cap 5ml Dionex (250 ea per pack)	50 bxes
47)	Thermo-syringe (poly), 2.5 ml, (100 per pack)	5 boxes
48)	Chromato-disk 25A (100 per pack)	5 boxes
49)	Manuals (Operation, Maintenance, etc.)	6 sets

ITEM	SPECIFICATION	No. of Req'd
3-6 1)	WaterPro PS 90005 - Ultra-Pure Water Unit; Purchased from ACATEC Power Supply: 115V, 60Hz Purification System: Activated Carbon + Ionexchange Resin + UF Membrane Filter Flow Rate: 2.0 Liter/Minute (Changeable) Required Quality: More Than 18M Ω · cm Raw Water Inlet Pressure: 0 to 1.0 kg/cm²G Operating Temperature: 10 to 35°C Feature: Automatically maintained water quality Indications: water flow rate, water temperature, and change timing of cartridge and final filter	1 set
	Consumable & Spare Parts of ITEM 3-6	
2)	WaterPro PS 90474-01 & -03 - Purification Cartridges	5 sets
3)	WaterPro PS 90929 - Final Filter	5 sets
4)	WaterPro PS 90764 - Water tank (15 liter) with One-touch Connector	2 units
5)	WaterPro PS 90774 - Support Stand	1 set
6)	Manuals (Operation, Maintenance, etc.)	6 sets

ITEM	SPECIFICATION	No.of Req'd
Computer System		
4-1-1	Computer CPU - COMPAQ DESKPRO 2000M5166/250 Extended Memory - 16MB EDO RAM Extended Hard Disk - 2GB HD External Memory Device - SCSI Controller + PD-CD Drive Power Cord (Cable) Keyboard (with connecting cable to Desktop) Mouse (with connecting cable to Desktop)	1 1 1 1 1 1 1
4-1-2	Monitor - 171FS Color Monitor (Connecting cable to main body) Power cord (Cable) for Monitor	1 1
4-1-3	Printer - Hewlett Packard Laser Jet 5L Power Cord for Printer Printer (Parallel) Cable Toner Cartridge (Spare)	1 1 1 1
4-1-4	Backup Media - PD disk	10
4-1-5	Spare parts for future extension (Drive Bracket, SCSI Cable, Screw, etc.)	1 set
4-1-6	Software - Windows 95 (English version) installed Backup Disks MS FORTRAN Power Station Vz Editor Other Software - FD : Floppy Disk, Diskette (15 FD and 2 CD-ROM)	32 FD 1 set 1 set 1 set
4-1-7	Manuals in English	1 set
Miscellaneous Local Supply		
	Tri-ethanol Amine: 500 cc - courtesy of ELETROSUL & CEEE	
	Cylinder Gas: SO ₂ 2500 ppm in nitrogen - 5 litre cylinder with pressure regulator	2 cylinders

Technology Transfer

(Chapter 7 of Interim Report, June 1996)

7.1 Preface

Scope of Work for the Study has stated as follows for the technology transfer:

In order to transfer technologies to Brazilian counterpart personnel, training on following items shall be held.

- (1) Planning of environmental monitoring and maintenance of the monitoring system,*
- (2) Measurement of emission gases from sources, and*
- (3) Estimation of the effects of each power plant by numerical simulation model*

The Study is scheduled only for a little more than two years and is evaluating only the coal fired boilers. Pollution issues must be dealt with long and wide ranged actions. Air and stack gas qualities have to be monitored continuously in order to meet variations of weather and emission sources. And accordingly, future qualities have to be predicted and countermeasures have to be planned.

The JICA Team planned and carried out classroom lectures and on-the-job training during the Second Field Work to implement the statements of the Scope of Work. Acquired technologies by Brazilian counterparts can be applied not only for regions influenced of coal boilers but any other regions influenced of any air pollution sources.

7.2 Classrooms

CEEE's Training Center hosted three classrooms as follows:

- a) Ambient Air Monitoring on February 8, 1996
- b) Stack Gas Measurement on February 8, 1996
- c) Data Management on March 5, 1996

Altogether 41 Brazilian audiences from FEPAM, two power company headquarters, and three power plants had signed up to the lectures on February 8. Texts had been delivered to the two power companies ten copies each with guaranteed arrival of two

weeks beforehand. The lectures were designed to impress the audiences practical aspects for principles, operation, maintenance, calibration, and trouble findings of the related JICA Equipment. They might have difficulties in digesting the details, because there was no real equipment in hand to see. Besides, there was unavoidable language barriers. However, the JICA Team evaluated the lectures were worth to give the audiences general idea on the equipment and its operation and maintenance. Parts of the lectures important for the field work were repeated in small classrooms at each site with seeing and touching the real equipment and with interpreters gradually accustomed in technical terms with repeated discussion.

The third classroom at the CEEE Training Center was for pollutant diffusion in the air. Around 15 people attended the class. For those who were specialized in air pollution, the lecture may be worthy for reconfirmation of one's knowledge. However, for starters or novices to the air pollution issue, it was the must to realize. It covered factors affecting air diffusion, data analyses, and diffusion simulation in general. The JICA Team will open similar classes with advanced topics.

In Charqueadas, a classroom was held for theoretical and operational training courses about ion-chromatography and pure-water preparation given by a local representative of the equipment supplier. More than ten people from ELETROSUL had attended at the class.

7.3 On-The-Job Training

On-the-job training (OJT) is the most effective method to transfer technologies in shorter period to a small group, because it is carried out person to person directly.

The JICA Team carried out OJT always when any new kind of the JICA Equipment was mobilized to use primarily at the site. An experienced member of the JICA Team showed his technology at first to his counterparts with explanation and subsequently guided the counterparts to follow the explanation repeatedly until the JICA member felt confident his trainees to be able to use by themselves the equipment without giving damages on it.

There is no other method than the OJT to transfer stack gas monitoring technologies. However it is very laborious because of noisy and dusty conditions around boilers. At least two people is needed to carry out the monitoring, one at the sampling nozzle and the other at the analyzer. Both are usually separated apart from each other: on top of

the duct and on the ground. These were true in all three power plants. Especially where there was only one instructor, the technology transfer by OJT was very difficult. The most troublesome part was for monitoring of TSP loading in stack gas. The JICA Team will continue OJT on TSP monitoring at the sites stressing technologies or know how as mentioned in Item 4.2, Chapter 4.

The first OJT for the stack gas monitoring was at the Charqueadas Plant. Because of the first, there were many people circled around the instructor and raised many questions of the same kinds repeatedly. Progress was slow, probably partly because of too many people having wide variety of vocational backgrounds, unbearable site conditions, in-experience of interpreters in technical terms. Both sides were patient enough for the technology to be transferred finally to the satisfaction of the JICA Team. However, the satisfaction is limited just in keeping functions of analyzers without damages. Among the first group, if named only two, Mr. Jose L. Magri and Ms Christine R. Coelho had well acquired the technologies. The JICA Team asked and ELETROSUL kindly agreed to dispatch Mr. Magri to Candiota to assist the JICA Team in transferring his knowledge to people in the Candiota Plant. Ms. Coelho helped also in leading operators for understanding technologies.

OJT was carried out in many events for operation and maintenance instruction of the fixed ambient air monitoring stations and of the chemical laboratory, also. From now on, experiences will help accumulation of know-how in Brazilian Team member on handling of the JICA Equipment.

7.4 JICA Courses

In its various activities, the JICA Headquarters has two training courses for foreigners, namely the project counterpart course and the group course. These courses are under separated account from an ordinary project such as this Study. As the project counterpart in the fiscal year of 1995, Mr. Sergio Ladniuk was invited to Japan in January 1996 to acquire facts on monitoring, control, public relation, and so on of air pollution at a power company, a steel mill, and a typical local municipality of Japan. By his understanding of Japanese conducts on air pollution issue, both Brazilian and Japanese Teams have been able to have common points of view in the Study.

Also, there were several engineers in Brazilian Teams who had visited Japan in the group courses in relation to power plant operation. They were and would be very

helpful for the duration of the Study, and beyond for the future in Brazil.

(p1 - 7 of Interim Report, June 1996)

JICA dispatched an instrument expert, Hisao Sugidomari, for a month and a local ion-chromatography specialist, Eduardo Alberto Giachero, for 5 days, together with the JICA Team under separate contracts. Their contribution to installation, commissioning, and technology transfer for operation, inspection and maintenance of the equipment was very much appreciated by Japanese and Brazilian Teams.

(Addition, August 1997)

JICA Courses

As the project counterpart course trainee in the fiscal year of 1996, Mr. Edison Pereira de Lima was invited to Japan in September-October, 1996. His courses were almost the same as those of Mr. Ladniuk's visit. By his study in Japan, both the Brazilian Teams were in the same understanding of Japanese conducts on air pollution issues.

Mrs. Rita Tissot was invited as the last project counterpart trainee in July - August 1997. Her course was mainly to acquire technologies on heavy metal analyses using the atomic absorption method, and to improve the ion chromatography technology in addition to those acquired during the Study. She brought samples of air borne TSP and stack gas fly ash for her analyses. The results were reported in Appendix 4-12 and cited in Section 4.4.3.

(Addition, June 1997)

Numerical Simulation Model Transfer

During the period of every Field Work, analyses of numerical data and air pollution mechanism had been discussed. Finally, during the Fourth Field Work (March 1997), the dispersion simulation system fabricated by the JICA Team was installed in the computer of the JICA Equipment. Usage of the system, function of each module composing the system, etc. were transferred to both Brazilian Teams in detail.

(Addition June 1997)

Materials Handed-over to Brazilian Side for Technology Transfer

- a. Class Room Text - Volume A: Ambient Air Monitoring, pp 71
- b. Class Room Text - Volume B: Stack Gas Monitoring, pp 63
- c. Venders Instruction Manuals - HORIBA, EKO, OGASAWARA KEIKI, NIGORIKAWA RIKAKOGYO, TOA Electronics, SHIMADZU, Water Pro, and DIONEX-USA
- d. JIS Handbook - Environmental Technology, 1992
- e. Industrial Pollution Control Vol. I, published by Industrial Pollution Control Association (Japan)

Appendix 2-1

Coal Mines in Brazil: Production and Sulfur Contents

Source (#053)

State of Santa Catarina

Mine	ROM in 1993		Recovery tons	Major Products in 1993			
	tons	S %		tons	S%	kcal/kg	Name
Nova Prospera Miner. Mina A - Sangao	804,714	3.19	284,825	266,049	1.6	4,550	CE4500
Carb. Metropolotana Esperanca	1,213,719	4	295,116	242,018	2.22	4,592	CE4500
Fontanella	66,302	4.1					
Carb. Criciuma	671,022	na	301,923	225,785	1.8	4,500	CE4500
Co. Carb. de Urussanga Santana	201,033	4.75	65,436	40,649	2.5	4,550	CE4500
Santa Augusta		3.65	50,413	31,625			CE4500
Sao Geraldo	1,093,827	4.2	289,932	131,578	2.57	4,687	CE4500
C. Treviso-Itanema II	573,900		106,930	87,405	4.5	5,600	CPL
Massa Falida de CBCA Mina 3-Verdin.	584,072	3.1	219,274	102,820	1.9	4,500	CE4500
Sao Simao	88,290	2.8	25,604	99,004	2.0	5,400	CE5400
Sao Pedro	91,762	2.85	26,611	10,000			CE4500
				12,955	(2.0)	5,400	CE5400
				20,042			CE5400
Barro Branco, Mina 3G	336,623	3.21	167,132	151,094	2.75	4,510	CE4500
Ibramil-Plano Legeado	80,858	2.79	26,762	18,025	2.7		CE4500
C. Catarinense - Poco 3	337,786	3.5	170,566	92,993	1.4	5460	CE5400
				28,506			CE5800
				28,580	2.5	4,500	CE4500
Coque Catar. - COCALIT Rio Fiorita - Sideropolis Cativari	87,493 0		35,308	13,138	2.18	4524	CE4500
Rio Deserto	114,837	4.47	na	na	na	na	
C. Belluno, Vila Irapua	22,000	4.3	12,800	12,800	3.5	4500	CE4500
Miner. Perola, S. Pedro	91,762	2.85	26,610	21,858	na	na	CE5400

Refer to attached figures for locations of mines.

State of Rio Grande do Sul

Mine	ROM in 1993		Recovery tons	Major Products in 1993			
	tons	S %		tons	tons	S%	kcal/kg
CRM-Mina Candiota	1,216,171	1.58	1,210,648	na	1.58	2,930	ROM
				2,096	na	na	CE3300
				1,239	0.9	4,605	CE4200
Mina Leao I	153,667	0.9	102,613	53,101	0.7	4,250	CE4200
Taquara	71,833	na	na	48,523	0.65	4,750	CE4700
Copelmi Mineracao							
Recreio	969,655	1.9	849,272	236,902	1.3	3,044	CE3100
Butia-Leste	480,705	2.3		323,640	1.9	3,750	CE3700
				240,135	0.8	4,752	CE4700
Faxinal	28,620	1.6		62,456	1.3	3,044	CE3100
Recreio	87,476			47,950	0.8	4,752	CE4700
Charqueadas	0						
Santa Heloisa	0						
Carbonifera Palermo	253,259	na	111,703	62,908	0.55	4,195	CE4200
				39,067	0.38	4,721	CE4700
Co. Nacional de Miner. Candiota, Mina de Seival	46,701	1.5	46,701	46,701	1.5	3,200	ROM

State of Parana

Mine	ROM in 1993		Recovery tons	Major Products in 1993			
	tons	S %		tons	S%	kcal/kg	Name
Carbonifera do Cambui							
Amando Simoes	194,395	5.5		94,816	3.4	6,050	CPL
Poco 115 ss	66,610	6.5		23,612	3.5	6,000	Fino
Frente 20	7,101	7.5		3,917		4,880	ROM
830 ss	5,205	7.5	Total			4,880	
			150,647				
Klabin do Parana Miner. Mina 2	7,119	13.23	4,505	4,505	9.46	5,855	CE6000

Note:

1) Mine name order:


Company Name - Mine Name - and indented mine names where coals are produced if several kinds of coals are processed at the mine (the name not indented).

2) ROM: Run of Mine, 3) CPL: coal pre-washed


4) Long names are abbreviated and to be referred to the original source.


5) C. or Carb.: Carbonifera, 6) Miner.: Mineracao, 7) Co.: Companhia 8) na: not available

Refer to attached figures for locations of mines.



MINAS E JAZIDAS DO RIO GRANDE DO SUL





Appendix 3-1 : Comparison of Environmental Criteria of Air Quality

Pollutant	Valuation time	Brazil		Japan	World Bank (WB)	World Health Organization (WHO)
		Primary Criteria	Secondary Criteria			
Total suspended particulate ($\mu\text{g}/\text{m}^3$)	Annual mean	80	60	-	-	0.04-0.06 mg/m^3 (40-60)
	24 hours	240	150	-	-	0.15-0.23 mg/m^3 (150-230)
Smoke ($\mu\text{g}/\text{m}^3$)	Annual mean	60	40	-	-	-
	24 hours	150	100	-	-	-
Thoracic particles ($\mu\text{g}/\text{m}^3$)	Annual mean	50	50	-	-	-
	24 hours	150	150	0.1 mg/m^3 (100)	-	0.07 mg/m^3 (70)
	1 hour	-	-	0.2 mg/m^3 (200)	-	-
Sulfur dioxide ($\mu\text{g}/\text{m}^3$)	Annual mean	80	40	-	-	-
	24 hours	365	100	0.04ppm (114)	-	0.15 mg/m^3 (150)
	1 hour	-	-	0.1ppm (285)	-	0.35 mg/m^3 (350)
Carbon monoxide ($\mu\text{g}/\text{m}^3$)	24 hours	-	-	10ppm (12,500)	-	-
	8 hours	10,000	10,000	20ppm (25,000)	-	10 mg/m^3 (10,000)
	1 hour	40,000	40,000	-	-	30 mg/m^3 (30,000)
Ozone ($\mu\text{g}/\text{m}^3$)	8 hours	-	-	Oxidant -	Oxidant -	-
	1 hour	160	160	0.06ppm (128)	160	-
Nitrogen dioxide ($\mu\text{g}/\text{m}^3$)	Annual mean	100	100	-	Nitrogen oxides 100	-
	24 hours	-	-	0.04-0.06 (82 - 123)	-	0.15 mg/m^3 (150)
	1 hour	320	190	-	-	0.4 mg/m^3 (400)

Notes :

- 1) Equivalent values which are converted into the units used in Brazilian criteria, are given in parentheses.
- 2) These concentrations are measured at the condition of 25 °C and 1 atm. for the criteria of Brazil, WB and WHO, and at 15°C and 1 atm. for the Japanese, respectively

Appendix 3-2 Comparison of Emission Standard of Pollutants

Scale of facilities	Emission Standard of Brazil		Emission Standard of Japan		Emission Standard of the Guideline of World Bank(WB)
	70 MW or less	70 MW or more	Class	Class	
Area categories	Class I	Class II, III	Class I	Class II, III	
Pollutants and unit					
Total dust and soot (g/1 million Kcal)	120	350 (petroleum) 1.500 (coal)	Impermissible for new Installation	120 (petroleum) 800 (coal)	Suspended particulate 100mg/m ³ N
Smoke color (%)	20 ⁺	25 ⁺		20 ⁺	
Sulfur dioxide (g/1 million Kcal)	2.000	5.000		2.000	k = 17.5 ⁺ Sulfur oxides 500t/day
Fuel oil consumption limit (t/year)	3.000 ⁺	-		-	3~17.5 : 16 phases
Nitrogen oxides	-	-		-	130ppm (288mg/m ³ N)

Notes :

*1) Except for the case of cleaning and of installation of facilities.

*2) The approval from the State Environmental Organ should be required for the consumption of the amount of fuel oil which exceeds this value.

*3) K-value is determined to calculate the emission standard of sulfur oxides for each area, and classified into 16 phases within the range from 3.0 to 17.5. The calculation method of emission standard for sulfur oxides is as follows.

Calculation method :

$$(1) \text{The emission standard of sulfur oxides is identified as a emission quantity of sulfur oxides which is calculated by the following equation.}$$

$$q = K \times He^2 \times 10^{-3}$$

where:

q : Emission quantity of sulfur oxides (converted into the condition at 0°C and 1 atm. Unit : m³ N/H)

K : The value determined for each area.

He: Height of outlet corrected by the following method, that is determined in the next term. (Unit:m)

(2) The corrected height of outlet is calculated by the equations below.

$$H_c = H_o + 0.65 (H_m + H_e) \quad H_o = 2.01 \times 10^{-3} \cdot Q \cdot (T - 228) \cdot \left(2.30 \log J + \frac{1}{J} - 1 \right)$$

$$H_o = \frac{0.795 \sqrt{Q \cdot V}}{1 + \frac{2.58}{V}} \quad J = \frac{1}{\sqrt{Q \cdot V}} (1460 - 296 \times \frac{V}{T - 228}) + 1$$

where:

H_c : Corrected height of outlet (m)

H_o : Real height of outlet (m)

Q : Emission gas quantity at 15 °C (m³ /s)

V : Velocity of emission gas (m/s)

T : Temperature of emission gas (absolute temperature)

Appendix 4-1 Compilation Method of the Monitoring Data

A4.1.1 Monitoring data measured by JICA equipment

The data copied from the data logger to floppy disks are converted into text data of DOS system with the program 'APCONV.EXE'. However, this program only converts the binary data of the logger to text data, and some more processing is necessary for compilation as hourly data base.

- (1) Abnormal Data Screening
- (2) Unit Conversion

(1) Abnormal Data Screening

Abnormal data should be excluded based on the information like 'Value Code' and 'Device Alarm' of text data (Fig. 1). The value code indicates '0' for no data and '1' for hourly average value. The equipment installed in Brazil usually takes 3600 data for one hour and average them to obtain the hourly average value. At present, the 'Log Alarm' is not used, and alarm information from analyzer and measuring device is stored as the device alarm information. The device alarm area takes 2 bytes (= 16bits) and each bit is defined as Table 1 (Also included in Instruction Manual by HORIBA).

Table 1. Definition of Device Alarm Bits

Bit	Meaning of Alarm
bit00	Analyzer Alarm
bit01	Reserve (Don't Care)
↓	
bit12	
bit13	Calibration Alarm
bit14	Maintenance Alarm
bit15	Power Failure

Only once alarm during one hour results in changing the bit value from 0 to 1. The device alarm bit is converted in hexadecimal expression, and right side is lower bit.

The algorithm to exclude abnormal data was defined as the followings:

Device Alarm=0;	Normal
Device Alarm=1;	
Value Code=0;	Abnormal
Value Code=1;	
1800 <= Valid Data < 5400;	Normal
Valid Data < 1800 or 5400 <= Valid Data;	Abnormal

Essentially, the monitoring staff should check the original data with editor based on the above information to obtain certified values.

(2) Unit Conversion

The 'value' of the text data is shown to the fifth decimal place with the original unit as in Table 2, but the fifth or the fourth decimal is nonsense considering the accuracy of monitoring equipment. Moreover, the usual range of the items are known from the experience. The units of the monitoring items are converted as in Table 2.

Table 2. Unit Conversion

Items	Item Code	Before	After
SO ₂	2	ppm	ppb
NO _x	3	ppm	ppb
NO	4	ppm	ppb
NO ₂	5	ppm	ppb
Net Radiation	135	KJ/m ²	W/ m ²

When NO_x value is not equal to the sum of NO and NO₂ values because of rounding off, NO₂ value is determined by subtracting NO value from NO_x value to keep the equality. This processing is justified from the fact that NO₂ value is also calculated with NO and NO_x in the monitoring equipment.

A4.1.2 Monitoring data measured by Brazilian equipment

Meteorological data except net radiation are measured by Brazilian side, and provided to the JICA study team in floppy disks. The items used in this report are wind speed, wind direction, solar radiation and rainfall amount. Six of 10 minutes average data for wind speed and wind direction are recorded for every one hour, hourly integrated data are recorded for solar radiation and hourly accumulated data (rainfall total for each

hour) are recorded for rainfall amount. Basically, unit conversion is not necessary for solar radiation and rainfall amount, but the solar radiation data during the nighttime are assumed as zero for the convenience of the analysis.

For the data of wind speed and wind direction, the following processing are necessary.

- (1) Averaging from 10 minutes data to hourly data
- (2) Unit conversion of wind direction data

(1) Averaging to Hourly Data

Usually, six of 10 minutes values are averaged to one hourly value for wind speeds and wind directions. There are two options for averaging wind data. One is vector averaging method and another is scalar averaging method. For the purpose of this study, the scalar averaging method should be used because the scalar value of wind speed is the important parameter for dispersion simulation.

Algorithm to calculate the scalar average (AS) of wind direction is as the followings.

$$AS = \frac{\sum_{i=1}^6 D_i(i)}{N}$$

If $i = 1$,

$$D_i(i) = A_i(i)$$

If $i > 1$,

$$DELTA = A_i(i) - D_i(i-1)$$

$$\text{If } DELTA < -180, D_i(i) = D_i(i-1) + DELTA + 360$$

$$\text{If } DELTA < 180, D_i(i) = D_i(i-1) + DELTA$$

$$\text{If } DELTA > 180, D_i(i) = D_i(i-1) + DELTA - 360$$

Here, $A_i(i)$ is each 10 minutes value of wind direction in degrees from 0 to 360.


Reference: On-site Meteorological Program Guidance for Regulatory Modeling Applications, U.S.EPA, 1987

(2) Unit conversion of wind direction

Wind direction data in degrees will be converted into 16 wind direction to be used for the analysis and simulation system of this study. The conversion is conducted as the followings.

$0 \leq D \leq 11.25:N$	$11.25 < D \leq 33.75:NNE$	$33.75 < D \leq 56.25:NE$
$56.25 < D \leq 78.75:ENE$	$78.75 < D \leq 101.25:E$	$101.25 < D \leq 123.75:ESE$
$123.75 < D \leq 146.25:SE$	$146.25 < D \leq 168.75:SSE$	$168.75 < D \leq 191.25:S$
$191.25 < D \leq 213.75:SSW$	$213.75 < D \leq 236.25:SW$	$236.25 < D \leq 258.75:WSW$
$258.75 < D \leq 281.25:W$	$281.25 < D \leq 303.75:WNW$	$303.75 < D \leq 326.25:NW$
$326.25 < D \leq 348.75:NNW$	$348.75 < D \leq 360.0:N$	


Appendix 4-2 Wind Rose by Month



LACERDA

Fig. Wind Rose Diagram
A4.4

Year: 1996 (Mar. to Feb.)



JACUI

— Frequency of Wind Direction
 - - - Average of Wind Speed
 Calm: Less than 0.5 m/sec
 \bar{U} : Ave. of wind speed (m/sec)
 N: Number of sample

Fig. Wind Rose Diagram

Year: 1996 (Mar. to Feb.)




Fig. Wind Rose Diagram

Year: 1996 (Mar. to Feb.)

Appendix 4-3 Stability Classification

Table 1 Pasquill's Stability Classification
(Wind Speed, Solar Radiation, Net Radiation)


Wind Speed (U)m/s	Solar Radiation(T) kW/m ²				Net Radiation(Q) kW/m ²		
	T ≥ 0.60	0.60 > T ≥ 0.30	0.30 > T ≥ 0.15	0.15 > T	Q ≥ -0.020	-0.020 > Q ≥ -0.040	-0.040 > Q
U < 2	A	A-B	B	D	D	G	G
2 ≤ U < 3	A-B	B	C	D	D	E	F
3 ≤ U < 4	B	B-C	C	D	D	D	E
4 ≤ U < 6	C	C-D	D	D	D	D	D
6 ≤ U	C	D	D	D	D	D	D

Table 2 Pasquill's Stability Classification (Senshu, 1977)
(Wind Speed, Net Radiation)


Surface wind Speed (m/sec)	Daytime				Nighttime		
	Net radiation (γ, cal/cm ² /h)						
	γ >=30	30 > γ >=15	15 > γ >=7.5	7.5 > γ >=0	0 > γ >=-1.8	-1.8 > γ >=-3.6	-3.6 > γ
U < 2	A	A-B	B	dD	nD	G	G
2 ≤ U < 3	A-B	B	C	dD	nD	E	F
3 ≤ U < 4	B	B-C	C	dD	nD	nD	E
4 ≤ U < 6	C	C-D	dD	dD	nD	nD	E
6 ≤ U	C	dD	dD	dD	nD	nD	E

Appendix 4-4 Diurnal and Monthly Change of Meteorological Factors

Jorge Lacerda Power Plant



Charqueadas Power Plant



Candiota Power Plant





Fig. Diurnal Change of Wind Speed

Year 1996 Mar to 1997 Feb

Jorge Lacerda Power Plant



Charqueadas Power Plant






Fig. Diurnal Change of Solar Radiation

Year 1996 Mar to 1997 Feb

Jorge Lacerda Power Plant



Charqueadas Power Plant



Candiota Power Plant






Fig. Diurnal Change of Wind Speed Year 1996 Mar to 1997 Feb

Jorge Lacerda Power Plant



Charqueadas Power Plant



Candiota Power Plant






Fig. Diurnal Change of Net Radiation Year 1996 Mar to 1997 Feb

Jorge Lacerda Power Plant



Charqueadas Power Plant



Candiota Power Plant





Fig. Monthly Change of Wind Speed Year 1996 Mar to 1997 Feb

Jorge Lacerda Power Plant



Charqueadas Power Plant







Fig. Monthly Change of Solar Radiation

Year 1996 Mar to 1997 Feb




Appendix 4-5 Cumulative Distribution

— Daily Average
 — Hourly Average




Jorge Lacerda Power Plant



Charqueadas Power Plant






Candiota Power Plant






Cumulative Distribution Year 1996 Mar to 1997 Feb

— Daily Average
 — Hourly Average




Jorge Lacerda Power Plant



Charqueadas Power Plant



Candiota Power Plant



Cumulative Distribution

Year 1996 Mar to 1997 Feb

Appendix 4-6 TSP Concentration by High Volume Sampler ($\mu\text{g}/\text{m}^3$)

Data taken by the Brazilian Team

Jorge Lacerda

Date	Vila Moema	Capivari	Sao Bernardo
07/01/96	56.21	59.78	24.49
07/04/96	67.71	136.40	35.43
07/09/96	54.43	63.10	28.14
07/11/96	82.44	213.26	
07/16/96	119.49	291.20	61.77
07/18/96	199.05	182.90	74.46
07/23/96	43.50	115.42	25.09
07/25/96	66.46	102.50	61.92
07/29/96	123.84	175.98	197.28
07/31/96	107.35	227.33	60.11
08/06/96	119.28	218.53	40.76
08/08/96	89.04	134.85	68.62
08/15/96	80.06	140.28	63.24
08/20/96	167.65	174.60	104.26
08/22/96	126.12	181.78	78.15
08/26/96	19.91	29.88	14.74
08/29/96		123.54	48.29
09/06/96		313.07	94.70
09/12/96		203.73	54.42
09/12/96		186.40	53.50
09/18/96		87.90	33.54
09/24/96		13.39	11.03
09/26/96		18.46	11.56
10/01/96			30.29
10/08/96		46.40	31.29
10/10/96		51.48	
10/15/96			32.62
10/17/96		44.71	32.42
10/22/96	32.83	44.67	26.67
10/24/96	29.83	48.69	30.00
10/29/96		46.67	31.80
10/31/96		46.17	32.21
11/05/96	189.52	232.68	
11/07/96	179.80	152.58	
11/19/96		99.91	75.17
11/27/96		110.46	
12/03/96		133.38	
12/05/96		72.40	
12/10/96		26.00	
12/12/96		94.10	
12/17/96	95.24	110.00	
12/26/96	102.78	109.20	72.84
01/02/97	49.00	46.12	
01/06/97	129.47	144.01	112.42
01/08/97	101.59	147.42	116.92
01/13/97	78.46	102.11	
01/16/97	59.21	78.68	54.43
01/20/97		46.69	68.08
01/22/97		23.92	52.41
01/27/97		39.84	68.30

Date	Vila Moema	Capivari	Sao Bernardo
03/04/96	22.93		18.45
03/11/96	38.32	77.57	
03/20/96	43.22	32.21	
03/27/96	47.08	63.98	
04/03/96	56.27	117.94	
04/10/96	22.12	35.32	23.69
04/18/96	58.63	106.37	47.66
04/23/96	96.91	124.91	97.83
04/25/96	100.59	79.20	44.08
05/02/96		43.19	38.48
05/07/96		121.70	68.03
05/09/96		141.48	59.20
05/22/96		49.43	18.98
05/27/96		46.33	45.93
06/04/96			69.73
06/10/96	92.57		59.96
06/12/96	117.60		77.97
06/17/96	39.65	42.74	47.66
06/26/96	27.14	21.78	11.12
07/02/96	45.76	91.48	54.72

02/03/97		33.62	57.91
02/05/97		113.95	
02/13/97		94.47	
02/18/97		75.26	
02/20/97		211.13	
02/25/97		69.38	
03/06/97	43.83	114.55	38.85
03/11/97	66.15	189.03	78.65
03/18/97	43.31	113.56	46.33
03/20/97	77.52	133.82	75.78
03/24/97	76.31	207.13	47.70
03/26/97	198.71	284.99	88.62

Data Distribution (1/96-3/97)

(No. of Data)

$\mu\text{g}/\text{m}^3$	V.Moema	Capivari	S.Bernado
≤ 149	52	59	60
150 - 239	5	14	1
≥ 240	0	3	0
All	57	76	61

CHARQUEADAS

Date	Arranca Toco	Jacui
01/09/96	75	
01/10/96		60
01/12/96	74	38
01/18/96		12
01/24/96	64	22
02/06/96	47	
02/08/96		33
02/11/96	26	
02/18/96	27	13
02/23/96	87	41
02/29/96	28	
04/05/96	36	19
04/11/96		24
04/17/96	53	47
04/23/96	133	59
05/07/96		54
05/11/96	129	52
05/18/96	109	33
05/23/96		26
05/29/96		37
07/04/96	64	19
07/10/96		11
07/16/96	84	26
07/21/96	79	
07/24/96	121	
07/30/96		32
08/01/96	112	
08/07/96	40	
08/08/96		
08/09/96	50	
08/13/96	126	
08/15/96	55	
08/20/96		
08/23/96	103	
08/27/96	8	
08/29/96	67	
09/03/96	20	
09/05/96	84	
09/10/96	60	
09/12/96	86	
09/17/96	41	
09/19/96	119	
09/24/96	34	
09/25/96		
09/27/96	24	
10/01/96	63	
10/03/96	44	
10/08/96	139	
10/11/96	75	
10/15/96	42	

DEPREC
16
31
79
3
7
25
14
4
27
14

Date	Arranca Toco
10/17/96	81
10/22/96	10
10/24/96	25
10/29/96	61
10/31/96	52
11/05/96	118
11/07/96	67
11/12/96	
11/13/96	69
11/19/96	60
11/21/96	78
11/26/96	86
11/29/96	193
12/03/96	102
12/04/96	
12/06/96	80
12/10/96	139
12/17/96	30
12/19/96	47
12/24/96	
12/27/96	41
12/31/96	60
01/03/97	68
01/07/97	93
01/09/97	35
01/14/97	53
01/16/97	39
01/21/97	52
01/23/97	41
01/28/97	99
02/14/97	67
02/18/97	46
02/20/97	54
02/22/97	44
02/25/97	59
02/27/97	
02/28/97	32
03/04/97	
03/06/97	39
03/07/97	74
03/12/97	60
03/15/97	43
03/18/97	60
03/20/97	58
03/25/97	

DEPREC
4
37
46
31
33
19
63
23
19
15
44
44
32
41
30
10
20
25
45

CHARQUEADAS - continued

Date	Arranca Toco	Jacui
03/02/96		26
03/06/96	40	25
03/12/96	144	54
03/18/96	64	33
03/24/96	84	135
03/30/96	38	
04/29/96	94	28
06/04/96	71	
06/10/96	152	
06/16/96	46	
06/22/96	49	
06/28/96	13	20

Data Distribution
(No. of Data)

μ g/m ³	Arranca Toco	Jacui	DEPREC
	3/96-2/97	1/96-7/96	8/96-3/97
≤149	86	27	29
150 - 239	2	0	0
≥240	0	0	0
All	88	27	29

Data Distribution
(1/96-9/96) & (12/96-2/97)
(No. of Data)

μ g/m ³	Candiota III
≤149	54
150 - 239	0
≥240	0
All	54




CANDIOTA

Date	Candiota III
01/06/96	48.30
01/12/96	16.23
01/18/96	79.11
01/24/96	21.44
01/30/96	20.81
02/05/96	64.30
02/11/96	15.81
02/17/96	39.13
02/23/96	45.51
02/29/96	109.46
03/12/96	42.11
03/18/96	16.26
03/24/96	20.54
03/30/96	11.43
04/11/96	24.79
04/17/96	15.53
04/23/96	17.83
04/29/96	14.04
05/05/96	26.90
05/11/96	28.04
05/17/96	17.20
05/23/96	50.39
05/29/96	21.03
06/04/96	13.88
06/10/96	31.39
06/16/96	10.72
06/22/96	14.05
06/28/96	8.69
07/04/96	42.58
07/10/96	5.12
07/16/96	17.88
07/22/96	16.54
07/28/96	31.71
08/03/96	67.64
08/09/96	11.00
08/15/96	17.60
08/21/96	33.20
08/27/96	25.39
09/02/96	12.60
09/08/96	2.10
09/14/96	16.77
09/20/96	58.27
09/26/96	6.82
12/13/96	34.25
12/19/96	38.40
01/06/97	30.60
01/12/97	27.37
01/18/97	22.02
01/24/97	19.31
01/30/97	21.85




	Candiota III
02/05/97	8.91
02/11/97	54.08
02/17/97	13.02
02/23/97	13.23

Appendix 4-7 Monthly Change of SO₂

Jorge Lacerda Power Plant



Charqueadas Power Plant



Candiota Power Plant







Fig. Monthly Change of Sulfur Dioxide


Year 1996 Mar to 1997 Feb
 1SO₂: 1ppb=2.60 μ/m³ at 25°C

Appendix 4-8 Average Concentration by Wind Directions (SO₂ & NO_x)


Jorge Lacerda Power Plant



Charqueadas Power Plant



Candiota Power Plant




--: Upwind directions of power plants


Fig. Average Concentration by Wind Directions (Sulfur Dioxides)

Jorge Lacerda Power Plant


●—● NO : ppb +--+ NO₂ : ppb —>—> NO_x : ppb



Charqueadas Power Plant



Candiota Power Plant



—: Upwind directions of power plants

Fig. Average Concentration by Wind Directions (Nitrogen Oxides)
A4-21

Year 1996 Mar to 1997 Feb

Appendix 4-9A

Airborne SO₂ and NO₂ by Simple Method

Jorge Lacerda (1)

No.	NAME	29/02/96 to 07/03/96		07/03/96 to 14/03/96		01/04/96 to 02/05/96		02/05/96 to 03/06/96		03/06/96 to 03/07/96	
		SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)
1	Banhado da Estiva	<1.0	<0.8	<1.0	<0.8	<1.0	3.1	<1.0	4.8	<1.0	4.8
2	Igreja de Sao Sebastiao	<1.0	1.1	<1.0	<0.8	<1.0	4.2	<1.0	6.4	<1.0	6.6
3	Campo dos Bandeirantes	<1.0	<0.8	<1.0	<0.8	<1.0	1.4	<1.0	2.2	<1.0	2.3
4	Turist Hotel	<1.0	<0.8	<1.0	<0.8	<1.0	0.9	<1.0	1.7	<1.0	2.2
5	Ribeirao da Pescaria Brava	<1.0	<0.8	<1.0	<0.8	<1.0	1.2	<1.0	2.5	<1.0	3.6
6	Sao Bernardo*	<1.0	<0.8	<1.0	<0.8	<1.0	2.8	<1.0	3.2	<1.0	2.8
7	Domingo Saviatto/Ceramica *	<1.0	<0.8	<1.0	<0.8	<1.0	2.3	<1.0	2.3	<1.0	2.3
8	Pasto do Gado EFFSA *	<1.0	<0.8	<1.0	<0.8	<1.0	3.3	<1.0	4.6	1.2	4.5
9	Vila Moana*	<1.0	<0.8	<1.0	0.8	<1.0	4.1	<1.0	6.2	1.2	5.2
10	Monte Castelo *	<1.0	<0.8	<1.0	<0.8	<1.0	2.8	<1.0	3.0	<1.0	2.8
11	Escola Jose Botega*	<1.0	<0.8	<1.0	<0.8	<1.0	3.4	<1.0	1.8	<1.0	2.6
12	Estrada Geral Treze de Maio	<1.0	<0.8	<1.0	<0.8	1.2	2.4	<1.0	3.1	<1.0	2.0
13	Colegio Gallotti*	<1.0	0.9	<1.0	1.4	1.4	6.0	2.2	1.9	2.2	6.3
14	Capivari*	<1.0	<0.8	<1.0	<0.8	1.4	3.9	<1.0	6.7	<1.0	5.4
15	Oficinas**	<1.0	1.0	<1.0	1.1	----	----	<1.0	5.3	<1.0	6.5
16	Ilhota Grande	<1.0	<0.8	<1.0	<0.8	<1.0	1.1	<1.0	6.3	1.2	1.6
17	Cachoeira Segunda	<1.0	<0.8	<1.0	<0.8	<1.0	1.6	<1.0	2.8	1.1	2.2
18	Escola Cristina Avila Tendhausen	<1.0	<0.8	<1.0	<0.8	<1.0	2.2	<1.0	2.7	1.0	2.6
19	Lacruba	<1.0	<0.8	<1.0	<0.8	<1.0	1.2	<1.0	1.8	<1.0	2.0
20	Cabecudas	<1.0	1.0	<1.0	<0.8	<1.0	4.6	<1.0	7.0	1.6	5.4

** : 29/02/96 to 06/03/96
 ** : 01/03/96 to 08/03/96

06/03/96 to 13/03/96
 08/03/96 to 15/03/96

***: No Data

Jorge Lacerda (2)

No	NAME	03/07/96 to 05/08/96		05/08/96 to 03/09/96		03/09/96 to 02/10/96		02/10/96 to 06/11/96		06/11/96 to 09/12/96	
		SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)
1	Banhado da Estiva	--	--	<1.0	<0.8	--	--	<1.0	3.2	<1.0	2.8
2	Igreja de Sao Sebastiao	<1.0	7.2	<1.0	5.4	<1.0	4.2	<1.0	4.9	<1.0	4.0
3	Campo dos Bandeirantes	<1.0	3.8	<1.0	2.6	<1.0	1.2	<1.0	1.8	<1.0	2.2
4	Turist Hotel	<1.0	3.0	<1.0	1.8	<1.0	1.0	<1.0	1.4	<1.0	1.0
5	Ribeirao da Pescaria Brava	<1.0	2.7	1.2	1.5	<1.0	1.5	1.5	2.5	<1.0	1.4
6	Sao Bernardo	<1.0	5.4	<1.0	4.0	<1.0	3.2	<1.0	3.8	1.1	3.2
7	Domingo Saviatto/Ceramica	<1.0	3.5	<1.0	2.4	<1.0	2.1	1.9	3.8	4.5	3.8
8	Pasto do Gado RFSA	<1.0	6.4	<1.0	4.8	<1.0	3.8	<1.0	<0.8	<1.0	4.4
9	Vila Moema	<1.0	8.0	<1.0	5.6	<1.0	4.4	<1.0	5.5	<1.0	4.1
10	Monte Castelo	<1.0	5.0	<1.0	4.0	<1.0	2.8	<1.0	3.7	<1.0	3.4
11	Escola Jose Botega	1.5	4.6	<1.0	4.9	<1.0	3.2	<1.0	4.0	1.6	4.4
12	Estrada Geral Treze de Maio	<1.0	3.6	<1.0	3.5	<1.0	2.7	1.5	3.2	<1.0	2.8
13	Colegio Gallotti	<1.0	9.4	<1.0	7.5	<1.0	6.6	<1.0	3.8	<1.0	7.0
14	Capivari	<1.0	6.8	<1.0	4.5	<1.0	3.7	<1.0	3.7	<1.0	3.1
15	Oficinas	<1.0	7.8	<1.0	7.3	<1.0	6.9	<1.0	6.7	<1.0	6.6
16	Ibota Grande	<1.0	2.4	<1.0	1.8	<1.0	1.7	<1.0	2.0	<1.0	<0.8
17	Cachoeira Segunda	<1.0	3.4	<1.0	2.1	<1.0	2.2	<1.0	2.6	2.5	2.7
18	Escola Cristina Avila Mendhausen	<1.0	4.1	<1.0	2.4	<1.0	2.1	<1.0	2.3	<1.0	2.0
19	Lactuba	<1.0	2.7	<1.0	2.6	<1.0	1.3	1.7	1.5	<1.0	1.3
20	Cabecudas	<1.0	8.0	<1.0	4.7	<1.0	4.7	<1.0	5.2	<1.0	4.3

* No Data

Jorge Lacerda (3)

No	NAME	09/12/96 to 06/01/97		06/01/97 to 04/02/97		04/02/97 to 06/03/97		06/03/97 to 07/04/97	
		SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)	SO ₂ (μg)	NO ₂ (μg)
1	Banhado da Estiva	<1.0	2.8	<1.0	2.1	--	--	1.7	3.7
2	Igreja de Sao Sebastiao	<1.0	4.8	<1.0	3.8	<1.0	3.1	<1.0	3.8
3	Campo dos Bandeirantes	2.3	2.0	<1.0	1.9	<1.0	2.3	<1.0	1.7
4	Turist Hotel	1.5	2.4	<1.0	1.7	1.1	1.4	<1.0	1.7
5	Ribeirao da Pescaria Brava	<1.0	1.3	1.2	1.6	<1.0	3.3	<1.0	1.4
6	Sao Bernardo	<1.0	3.1	<1.0	3.1	<1.0	3.0	<1.0	3.6
7	Domingo Saviatto/Ceramica	<1.0	3.4	<1.0	2.4	<1.0	2.6	1.9	2.4
8	Pasto do Gado EFPSA	<1.0	3.2	2.0	3.2	<1.0	3.9	1.2	4.1
9	Villa Noema	3.8	4.1	<1.0	3.3	<1.0	3.7	<1.0	4.1
10	Monte Castelo	1.7	3.0	<1.0	2.6	<1.0	3.1	<1.0	2.1
11	Escola Jose Botega	2.0	2.9	<1.0	3.0	<1.0	3.0	<1.0	3.7
12	Estrada Geral Treze de Maio	<1.0	1.9	<1.0	2.3	<1.0	2.4	<1.0	2.5
13	Colegio Gallotti	<1.0	5.1	<1.0	4.8	<1.0	5.7	<1.0	6.0
14	Capivari	<1.0	3.7	<1.0	2.6	1.1	3.2	<1.0	4.3
15	Oficinas	--	--	<1.0	5.3	<1.0	5.2	<1.0	5.4
16	Ilhota Grande	1.5	4.0	<1.0	1.2	<1.0	4.3	<1.0	1.7
17	Cachoeira Segunda	1.1	2.4	<1.0	2.0	<1.0	2.2	<1.0	2.1
18	Escola Cristina Avila Vendhausen	<1.0	1.7	<1.0	2.0	<1.0	2.1	<1.0	1.8
19	Lactuba	<1.0	1.6	<1.0	1.5	<1.0	1.5	1.6	1.4
20	Cabecudas	2.8	4.0	<1.0	3.8	<1.0	3.9	<1.0	5.1

* No Data