


2. Existing Pump Station Check List



**Existing Pump Station Check List**

**Skuodas**

**Pump Station No.1 (Existing Pump Station)**

Item	Contents	Remark
Year constructed	1973	
Type of structure	B. Circular/without housing	
Equipment		
1) Screen Type Bar spacing Quantity	none	
2) Pump Type Capacity Quantity	horizontal shaft, centrifugal pump 80 m <sup>3</sup> /hour x 7.5 kW 1 unit	
3) Others	floor drain pump	
Stand-by Generator	no	
Operation		
Disposal of screenings Method Frequency Amount	none	
Pump Operation Automatic on-off No. of unit operated Flow measurement	automatic by water level in the pump well 1 unit none	
Discharge amount/flow	no record due to lack of flow meter	
Operator	circulating for inspection	
Existing problems	Equipment is old. Leaks in walls at pipe penetration	
Improvement in the Project	This pump station will be abandoned upon completion of a new pump station in the same premise. Structure of the new pump station has been completed. New pump units have been purchased.	

### Existing Pump Station Check List

Skuodas

**Pump Station No.1 (New Pump Station)**

Item	Contents	Remark
Year constructed	To be completed, but not scheduled	
Type of structure	B. Circular/without housing	
Equipment		
1) Screen		
Type	caged screen	
Bar spacing	unknown	
Quantity	1	
2) Pump		
Type	submersible pump	
Capacity	58 m <sup>3</sup> /hour x H15 m x 9 kW	
Quantity	2 units	
3) Others		
Stand-by Generator	no	
Operation		
Disposal of screenings		
Method	not operated yet	
Frequency		
Amount		
Pump Operation		
Automatic on-off	automatic by water level in the pump well	
No. of unit operated	1 unit	
Flow measurement	none	
Discharge amount/flow		
Operator	circulating for inspection	
Existing problems	not applicable	
Improvement in the Project	Pump units have been purchased and should be installed.	

### Existing Pump Station Check List

Skuodas

Pump Station No.2

Item	Contents	Remark
Year constructed	1976	
Type of structure	A. Circular/with upper housing	
Equipment		
1) Screen		
Type	manual bar screen	
Bar spacing	40 – 50 mm	
Quantity	1	
2) Pump		
Type	horizontal shaft, centrifugal pump	
Capacity	60 m <sup>3</sup> /hour x 22 kW	
Quantity	2 units	
3) Others		
	hoist crane floor drain pump ventilation system	
Stand-by Generator	no	
Operation		
Disposal of screenings		
Method	container	
Frequency	every day	
Amount	little	
Pump Operation		
Automatic on-off	automatic by water level in the pump well	
No. of unit operated	1 unit	
Flow measurement	none	
Discharge amount/flow	no record due to lack of flow meter	
Operator	circulating for inspection	
Existing problems	Large amount of rainwater flows in. To prevent inundation, the inlet gate is throttled. Equipment is old. Leaks in walls at pipe penetration	
Improvement in the Project	Prevention of rainwater intrusion must be carried out with proper investigation. For the case of a large pumping amount, by-pass discharge will be installed at the proposed STP after the primary sedimentation tank.  Repair of leaks should be included in the scope of this project.	

### Existing Pump Station Check List

Skuodas

**Pump Station No.3**

Item	Contents	Remark
Year constructed	1976	
Type of structure	A. Circular/with upper housing	
Equipment		
1) Screen		
Type	manual	
Bar spacing	20 mm	
Quantity	1	
2) Pump		
Type	horizontal shaft, centrifugal pump	
Capacity	110 m <sup>3</sup> /hour x 22 kW	
Quantity	2 units	
3) Others		
	hoist crane floor drain pump ventilation system	
Stand-by Generator	no	
Operation		
Disposal of screenings		
Method	by container	
Frequency	every day	
Amount	little	
Pump Operation		
Automatic on-off	automatic by water level in the pump well	
No. of unit operated	2 units (1 unit on at all time)	
Flow measurement	none	
Discharge amount/flow	no record due to lack of flow meter	
Operator	circulating for inspection	
Existing problems		
	Equipment is very old. Leaks in walls at pipe penetration	
Improvement in the Project		
	No need to replace the pump units immediately. Repair of cracks and leaks should be included in the project scope.	

**Existing Pump Station Check List**

Skudodas

Pump Station No.4 (Proposed at the Treatment Plant No.1)

Item	Contents	Remark
Year constructed	To be completed, but not scheduled	
Type of structure	B. Circular/without housing	
Equipment		
1) Screen Type Bar spacing Quantity	caged screen unknown 1	
2) Pump Type Capacity Quantity	submersible pump 140 m <sup>3</sup> /hour x 12 kW 3 units	
3) Others		
Stand-by Generator	no	
Operation		
Disposal of screenings Method Frequency Amount	not operated yet	
Pump Operation Automatic on-off No. of unit operated Flow measurement	automatic by water level in the pump well 2 units (1 unit on at all time) none	
Discharge amount/flow	no record due to lack of flow meter	
Operator	circulating for inspection	
Existing problems	not applicable	
Improvement in the Project	Pump units have been purchased and should be installed under this project. Only two units may be installed because the pump capacity is too big for the planned sewage amount.	

### 3. Comparison of Treatment Plant Alternatives





### Appendix 3 Comparison of Treatment Plant Alternatives (Skuodas)

(1/4)

Item	Case-1 Oxidation Ditch System with P.S.T.	Case-2 Oxidation Ditch System without P.S.T.	Case-3 Sequencing Batch Reactor (SBR) System	Remarks																																																																																																																																																										
1. Design Criteria																																																																																																																																																														
1) Design Flow	Daily average : $Q_1 = 1,270 \text{ m}^3/\text{day}$ Daily maximum : $Q_2 = 1,600 \text{ m}^3/\text{day}$ Hourly maximum : $Q_3 = 3,200 \text{ m}^3/\text{day}$	Daily average : $Q_1 = 1,270 \text{ m}^3/\text{day}$ Daily maximum : $Q_2 = 1,600 \text{ m}^3/\text{day}$ Hourly maximum : $Q_3 = 3,200 \text{ m}^3/\text{day}$	Daily average : $Q_1 = 1,270 \text{ m}^3/\text{day}$ Daily maximum : $Q_2 = 1,600 \text{ m}^3/\text{day}$ Hourly maximum : $Q_3 = 3,200 \text{ m}^3/\text{day}$																																																																																																																																																											
2) Design Water Quality	<table border="1"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">I.Q. (mg/l)</th> <th colspan="2">P.S.T.</th> <th colspan="2">S.T.F.</th> <th colspan="2">D.S.</th> </tr> <tr> <th>R.R. (%)</th> <th>E.Q. (mg/l)</th> <th>R.R. (%)</th> <th>E.Q. (mg/l)</th> <th>Ave. (mg/l)</th> <th>Max. (mg/l)</th> </tr> </thead> <tbody> <tr> <td>BOD<sub>5</sub></td> <td>490</td> <td>30</td> <td>343</td> <td>96.2</td> <td>13</td> <td>13</td> <td>21.7</td> </tr> <tr> <td>BOD<sub>7</sub></td> <td>560</td> <td>30</td> <td>392</td> <td>96.2</td> <td>15</td> <td>15</td> <td>25</td> </tr> <tr> <td>SS</td> <td>500</td> <td>40</td> <td>300</td> <td>90</td> <td>30</td> <td>30</td> <td>45</td> </tr> <tr> <td>COD</td> <td>1,000</td> <td>30</td> <td>700</td> <td>90</td> <td>70</td> <td>75</td> <td>120</td> </tr> <tr> <td>T-N</td> <td>70</td> <td>10</td> <td>63</td> <td>70</td> <td>18.9</td> <td>20</td> <td>35</td> </tr> <tr> <td>T-P</td> <td>12</td> <td>10</td> <td>10.8</td> <td>*86.2</td> <td>*1.5</td> <td>1.5</td> <td>2.5</td> </tr> </tbody> </table> <p>Note) I.Q. : Influent Quality P.S.T. : Primary Sedimentation Tank R.R. : Removal Rate E.Q. : Effluent Quality S.T.F. : Secondary Treatment Facility D.S. : Discharge Standard * : with Coagulant Treatment</p>		I.Q. (mg/l)	P.S.T.		S.T.F.		D.S.		R.R. (%)	E.Q. (mg/l)	R.R. (%)	E.Q. (mg/l)	Ave. (mg/l)	Max. (mg/l)	BOD <sub>5</sub>	490	30	343	96.2	13	13	21.7	BOD <sub>7</sub>	560	30	392	96.2	15	15	25	SS	500	40	300	90	30	30	45	COD	1,000	30	700	90	70	75	120	T-N	70	10	63	70	18.9	20	35	T-P	12	10	10.8	*86.2	*1.5	1.5	2.5	<table border="1"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">I.Q. (mg/l)</th> <th colspan="2">S.T.F.</th> <th colspan="2">D.S.</th> </tr> <tr> <th>R.R. (%)</th> <th>E.Q. (mg/l)</th> <th>Ave. (mg/l)</th> <th>Max. (mg/l)</th> </tr> </thead> <tbody> <tr> <td>BOD<sub>5</sub></td> <td>490</td> <td>97.4</td> <td>13</td> <td>13</td> <td>21.7</td> </tr> <tr> <td>BOD<sub>7</sub></td> <td>560</td> <td>97.4</td> <td>15</td> <td>15</td> <td>25</td> </tr> <tr> <td>SS</td> <td>500</td> <td>95</td> <td>25</td> <td>30</td> <td>45</td> </tr> <tr> <td>COD</td> <td>1,000</td> <td>92.5</td> <td>70</td> <td>75</td> <td>120</td> </tr> <tr> <td>T-N</td> <td>70</td> <td>70</td> <td>21</td> <td>20</td> <td>35</td> </tr> <tr> <td>T-P</td> <td>12</td> <td>*87.5</td> <td>*1.5</td> <td>1.5</td> <td>2.5</td> </tr> </tbody> </table> <p>Note) I.Q. : Influent Quality S.T.F. : Secondary Treatment Facility R.R. : Removal Rate E.Q. : Effluent Quality D.S. : Discharge Standard * : with Coagulant Treatment</p>		I.Q. (mg/l)	S.T.F.		D.S.		R.R. (%)	E.Q. (mg/l)	Ave. (mg/l)	Max. (mg/l)	BOD <sub>5</sub>	490	97.4	13	13	21.7	BOD <sub>7</sub>	560	97.4	15	15	25	SS	500	95	25	30	45	COD	1,000	92.5	70	75	120	T-N	70	70	21	20	35	T-P	12	*87.5	*1.5	1.5	2.5	<table border="1"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">I.Q. (mg/l)</th> <th colspan="2">S.T.F.</th> <th colspan="2">D.S.</th> </tr> <tr> <th>R.R. (%)</th> <th>E.Q. (mg/l)</th> <th>Ave. (mg/l)</th> <th>Max. (mg/l)</th> </tr> </thead> <tbody> <tr> <td>BOD<sub>5</sub></td> <td>490</td> <td>97.4</td> <td>13</td> <td>13</td> <td>21.7</td> </tr> <tr> <td>BOD<sub>7</sub></td> <td>560</td> <td>97.4</td> <td>15</td> <td>15</td> <td>25</td> </tr> <tr> <td>SS</td> <td>500</td> <td>95</td> <td>25</td> <td>30</td> <td>45</td> </tr> <tr> <td>COD</td> <td>1,000</td> <td>92.5</td> <td>70</td> <td>75</td> <td>120</td> </tr> <tr> <td>T-N</td> <td>70</td> <td>70</td> <td>21</td> <td>20</td> <td>35</td> </tr> <tr> <td>T-P</td> <td>12</td> <td>*87.5</td> <td>*1.5</td> <td>1.5</td> <td>2.5</td> </tr> </tbody> </table> <p>Note) I.Q. : Influent Quality S.T.F. : Secondary Treatment Facility R.R. : Removal Rate E.Q. : Effluent Quality D.S. : Discharge Standard * : with Coagulant Treatment</p>		I.Q. (mg/l)	S.T.F.		D.S.		R.R. (%)	E.Q. (mg/l)	Ave. (mg/l)	Max. (mg/l)	BOD <sub>5</sub>	490	97.4	13	13	21.7	BOD <sub>7</sub>	560	97.4	15	15	25	SS	500	95	25	30	45	COD	1,000	92.5	70	75	120	T-N	70	70	21	20	35	T-P	12	*87.5	*1.5	1.5	2.5	
	I.Q. (mg/l)			P.S.T.		S.T.F.		D.S.																																																																																																																																																						
		R.R. (%)	E.Q. (mg/l)	R.R. (%)	E.Q. (mg/l)	Ave. (mg/l)	Max. (mg/l)																																																																																																																																																							
BOD <sub>5</sub>	490	30	343	96.2	13	13	21.7																																																																																																																																																							
BOD <sub>7</sub>	560	30	392	96.2	15	15	25																																																																																																																																																							
SS	500	40	300	90	30	30	45																																																																																																																																																							
COD	1,000	30	700	90	70	75	120																																																																																																																																																							
T-N	70	10	63	70	18.9	20	35																																																																																																																																																							
T-P	12	10	10.8	*86.2	*1.5	1.5	2.5																																																																																																																																																							
	I.Q. (mg/l)	S.T.F.		D.S.																																																																																																																																																										
		R.R. (%)	E.Q. (mg/l)	Ave. (mg/l)	Max. (mg/l)																																																																																																																																																									
BOD <sub>5</sub>	490	97.4	13	13	21.7																																																																																																																																																									
BOD <sub>7</sub>	560	97.4	15	15	25																																																																																																																																																									
SS	500	95	25	30	45																																																																																																																																																									
COD	1,000	92.5	70	75	120																																																																																																																																																									
T-N	70	70	21	20	35																																																																																																																																																									
T-P	12	*87.5	*1.5	1.5	2.5																																																																																																																																																									
	I.Q. (mg/l)	S.T.F.		D.S.																																																																																																																																																										
		R.R. (%)	E.Q. (mg/l)	Ave. (mg/l)	Max. (mg/l)																																																																																																																																																									
BOD <sub>5</sub>	490	97.4	13	13	21.7																																																																																																																																																									
BOD <sub>7</sub>	560	97.4	15	15	25																																																																																																																																																									
SS	500	95	25	30	45																																																																																																																																																									
COD	1,000	92.5	70	75	120																																																																																																																																																									
T-N	70	70	21	20	35																																																																																																																																																									
T-P	12	*87.5	*1.5	1.5	2.5																																																																																																																																																									
3) Design Temperature	7 degree C. at winter	7 degree C. at winter	7 degree C. at winter																																																																																																																																																											
2. Flow Chart																																																																																																																																																														

Item	Case-1 Oxidation Ditch System with P.S.T.	Case-2 Oxidation Ditch System without P.S.T.	Case-3 Sequencing Batch Reactor (SBR) System	Remarks
<b>3. Sludge (<math>Q_{dmax}</math>)</b>  Primary Sludge Excess Sludge Thickened Sludge Dewatered Sludge	399 kgDS/day, 20 m <sup>3</sup> /day, 98.0 %WT 424 kgDS/day, 75 m <sup>3</sup> /day, 99.4 %WT 658 kgDS/day, 26 m <sup>3</sup> /day, 97.5 %WT 625 kgDS/day, 3.9 m <sup>3</sup> /day, 84 %WT	701 kgDS/day, 121 m <sup>3</sup> /day, 99.4 %WT 561 kgDS/day, 37 m <sup>3</sup> /day, 98.5 %WT 533 kgDS/day, 3.6 m <sup>3</sup> /day, 85 %WT	939 kgDS/day, 156 m <sup>3</sup> /day, 99.4 %WT 751 kgDS/day, 50 m <sup>3</sup> /day, 98.5 %WT 713 kgDS/day, 4.8 m <sup>3</sup> /day, 85 %WT	
<b>4. Major Facility</b>	1) Grit Chamber Gravity Type W 0.8 m x L 2.5 m x D 0.3 m x 1 unit Water Surface Load : 1,800 m <sup>3</sup> /m <sup>2</sup> day Average Velocity : 0.15 m/s  2) Flow Measurement Parshall Flume Type W = 0.31 m x 1 unit  3) Primary Sedimentation Tank Rectangular Tank W 5.0 m x L 5.0 m x D 3.5 m x 1 unit Surface Load : 64 m <sup>3</sup> /m <sup>2</sup> day Retention Time : 1.3 hrs  4) Reaction Tank Oxidation Ditch W 4.5 m x L 132.8 m x D 2.5 m x 2 units MLSS : 4,000 mg/l HRT : 43.2 hrs BOD-SS Load : 0.05 kg BOD/kg SS  5) Aeration Equipment Blower : 14.5 m <sup>3</sup> /min x 15 kw x 3 (1) unit Diffuser : Membrane Disc Aerator Submersible Mixer : 2.3 kw x 4 units  6) Final Sedimentation Tank Circular Tank with Center driven Sludge Collector Dia. 14.5 m x D 3.5 m x 2 units Surface Load : 5 m <sup>3</sup> /m <sup>2</sup> day Retention Time : 17.3 hrs	1) Grit Chamber Same as Case-1  2) Flow Measurement Same as Case-1  3) Reaction Tank Oxidation Ditch W 4.5 m x L 192.8 m x D 3.5 m x 2 units MLSS : 4,000 mg/l HRT : 62.4 hrs BOD-SS Load : 0.05 kg BOD/kg SS  4) Aeration Equipment Same as Case-1  5) Final Sedimentation Tank Same as Case-1	1) Grit Chamber Same as Case-1  2) Flow Measurement Same as Case-1  3) Balancing Tank Rectangular Tank W 9.0 m x L 11.0 m x D 4.5 m x 1 unit Retention Time : 6 hrs  4) Reaction Tank Sequencing Batch Reactor W 12.0 m x L 30.0 m x D 5.5 m x 2 units MLSS : 2,000 - 3,000 mg/l BOD-SS Load : 0.13 - 0.2 kg BOD/kg SS Cycle Number : 3 Cycle Retention Time : 59.4 hrs  5) Aeration Equipment Blower : 23 m <sup>3</sup> /min x 45 kw x 2 (1) unit Aerator : 38 kg O <sub>2</sub> /hr x 7.5 kw x 4 units	Note) Considering the case of P.S.T.'s by-pass operation, oxygen requirement of Case-2 is also adopted to Case-1.

Item	Case-1 Oxidation Ditch System with P.S.T.	Case-2 Oxidation Ditch System without P.S.T.	Case-3 Sequencing Batch Reactor (SBR) System	Remarks
	<p>7) Sludge Pumps Return Sludge Pumps : Max. Ratio 200 % 0.6 m<sup>3</sup>/min x 1.5 kw x 4 units Excess Sludge Pumps : 6.5 m<sup>3</sup>/hr x 2.2 kw x 2 units Primary Sludge Pumps : 0.3 m<sup>3</sup>/in x 1.5 kw x 1 unit</p> <p>8) Sludge Thickener Rectangular Tank with Center driven Picket Fence Type Mixer W 5.0 m x L 5.0 m x D 4.0 m x 1 unit Dry Solid Surface Load : 40 kg DS/m<sup>2</sup> day Retention Time : 25 hrs</p> <p>9) Sludge Storage Tank Rectangular Tank W 3.0 m x L 5.0 m x D 4.0 m x 1 unit Retention Time : 2.3 days</p> <p>10) Sludge Dewatering Machine Centrifugal Dewatering Machine 5.0 m<sup>3</sup>/hr x 22.2 kw x 1 unit Polymer : 1.3 % per DS</p> <p>11) Sludge Composting Yard Stockpiling Yard W 9.0 m x L 36.0 m x 2 lines Storage Period : 6 months</p> <p>12) Sludge Lagoon Open Cut W (top) 26 m - (bottom) 20 m x L (top) 26 m - (bottom) 20 m x D 1.5 m x 1 unit Storage Period : 1 month</p> <p>13) Chemical Feeding Facility Alum-oxichloride Tank and Pumps Caustic Soda Tank and Pumps Polymer Tank and Pumps</p> <p>14) Transformer 100 KVA x1 unit</p>	<p>6) Sludge Pumps Return Sludge Pumps : Max. Ratio 200 % 0.6 m<sup>3</sup>/min x 1.5 kw x 4 units Excess Sludge Pumps : 6.5 m<sup>3</sup>/hr x 2.2 kw x 2 units</p> <p>7) Sludge Thickener Rectangular Tank with Center driven Picket Fence Type Mixer W 5.0 m x L 5.0 m x D 4.0 m x 1 unit Dry Solid Surface Load : 30 kg DS/m<sup>2</sup> day Retention Time : 19.8 hrs</p> <p>8) Sludge Storage Tank Rectangular Tank W 4.0 m x L 5.0 m x D 4.0 m x 1 unit Retention Time : 2.2 days</p> <p>9) Sludge Dewatering Machine Centrifugal Dewatering Machine 8.0 m<sup>3</sup>/hr x 27.5 kw x 1 unit Polymer : 1.5 % per DS</p> <p>10) Sludge Composting Yard Stockpiling Yard W 10.0 m x L 30.0 m x 2 lines Storage Period : 6 months</p> <p>11) Sludge Lagoon Open Cut W (top) 26 m - (bottom) 20 m x L (top) 36 m - (bottom) 30 m x D 1.5 m x 1 unit Storage Period : 1 month</p> <p>12) Chemical Feeding Facility Same as Case-1</p> <p>13) Transformer 100 KVA x1 unit</p>	<p>6) Sludge Pumps Excess Sludge Pumps : 0.4 m<sup>3</sup>/min x 2.2 kw x 4 (2) units</p> <p>7) Sludge Thickener Rectangular Tank with Center driven Picket Fence Type Mixer W 6.0 m x L 6.0 m x D 4.0 m x 1 unit Dry Solid Surface Load : 30 kg DS/m<sup>2</sup> day Retention Time : 22 hrs</p> <p>8) Sludge Storage Tank Rectangular Tank W 4.6 m x L 6.0 m x D 4.0 m x 1 unit Retention Time : 2.2 days</p> <p>9) Sludge Dewatering Machine Centrifugal Dewatering Machine 10.0 m<sup>3</sup>/hr x 44.5 kw x 1 unit Polymer : 1.5 % per DS</p> <p>10) Sludge Composting Yard Stockpiling Yard W 11.0 m x L 36.0 m x 2 lines Storage Period : 6 months</p> <p>11) Sludge Lagoon Open Cut W (top) 38 m - (bottom) 32 m x L (top) 32 m - (bottom) 26 m x D 1.5 m x 1 unit Storage Period : 1 month</p> <p>12) Chemical Feeding Facility Same as Case-1</p> <p>13) Transformer 200 KVA x1 unit</p>	

Item	Case-1 Oxidation Ditch System with P.S.T.	Case-2 Oxidation Ditch System without P.S.T.	Case-3 Sequencing Batch Reactor (SBR) System	Remarks
	15) Auxiliary Facilities Administration Building Single Story, W 12.0 m x L 18.0 m x 216 m <sup>2</sup> Sludge Building Single Story, W 9.0 m x L 11.0 m x 99 m <sup>2</sup> Sludge Pump Building Single Story, W 6.0 m x L 12.5 m x 75 m <sup>2</sup>	14) Auxiliary Facilities Same as Case-1	14) Auxiliary Facilities Administration Building Single Story, W 12.0 m x L 18.0 m x 216 m <sup>2</sup> Sludge Building Single Story, W 9.0 m x L 11.0 m x 99 m <sup>2</sup>	
5. Total Motor Power	90 kw	96 kw	166 kw	
6. Construction Cost	Civil/Arch. : 3,737,000 Mech./Elect. : 2,885,000 <hr/> Total : 6,622,000	Civil/Arch. : 4,670,000 Mech./Elect. : 2,690,000 <hr/> Total : 7,360,000	Civil/Arch. : 2,754,000 Mech./Elect. : 3,249,000 <hr/> Total : 6,003,000	
7. O/M Cost				
1) Power Consumption	- Demand 177,000 kWh/year  - Electricity Charge 177,000 x 0.204 = 36,000 Lts/year	- Demand 216,000 kWh/year  - Electricity Charge 216,000 x 0.204 = 44,000 Lts/year	- Demand 255,000 kWh/year  - Electricity Charge 255,000 x 0.204 = 52,000 Lts/year	Unit price 0.204 Lts/kWh (Aug. 1998)
2) Chemical Consumption	- Alum oxichloride : 38,600 kg/year 38,600 x 0.424 = 16,366 Lts/year  Transportation 38.6 x 1/11 = 3.5 ..... 4 times 350 km x 4 x 1.3 = 1,820 Lts/year  - Polymer : 1,340 kg/year 1,340 x 25 = 33,500 Lts/year <hr/> Total 52,000 Lts/year	- Alum oxichloride : 50,800 kg/year 50,800 x 0.424 = 21,539 Lts/year  Transportation 50.8 x 1/11 = 4.6 ..... 5 times 350 km x 5 x 1.3 = 2,275 Lts/year  - Polymer : 1,370 kg/year 1,370 x 25 = 34,250 Lts/year <hr/> Total 58,000 Lts/year	- Alum oxichloride : 18,400 kg/year 18,400 x 0.424 = 7,802 Lts/year  Transportation 18.4 x 1/11 = 1.7 ..... 2 times 350 km x 2 x 1.3 = 910 Lts/year  - Polymer : 1,830 kg/year 1,830 x 25 = 45,750 Lts/year <hr/> Total 55,000 Lts/year	For annual average consumption Alum-oxichloride 0.424 Lts/kg Transportation 11 ton, 1.3 Lts/km (Aug. 1998)  Polymer 25 Lts/kg including transportation (Aug. 1998)
3) Fuel	- 100 Lts/wk x 52 = 5,000 Lts/year	- 100 Lts/wk x 52 = 5,000 Lts/year	- 100 Lts/wk x 52 = 5,000 Lts/year	
4) Consumable Parts and Repairing	2,885,000 x 0.015 = 43,000 Lts/year	2,690,000 x 0.015 = 41,000 Lts/year	3,249,000 x 0.015 = 49,000 Lts/year	1.5 % of M/E construction cost
5) Total	136,000 Lts/year	148,000 Lts/year	161,000 Lts/year	

4. Capacity Calculation for Skuodas Treatment Plant  
(Case 1)

## Appendix 4 Capacity Calculation for Skoudas Sewage Treatment Plant (Case 1)

### Case 1 : Oxidation Ditch System with Primary Sedimentation Tank

#### 1. Design Criteria

##### 1.1 Design Sewage Flow

$$Q_{\text{dave}} = Q_1 = 1,270 \text{ m}^3/\text{day}$$

$$Q_{\text{dmax}} = Q_2 = 1,600 \text{ m}^3/\text{day}$$

$$Q_{\text{hmax}} = Q_3 = 3,200 \text{ m}^3/\text{day}$$

##### 1.2 Design Sewage Quality

Item	Influent Quality (mg/l)	P.S.T.		S.T.F.		Discharge Standard	
		R.R. (%)	E.Q. (mg/l)	R.R. (%)	E.Q. (mg/l)	Average (mg/l)	Maximum (mg/l)
BOD <sub>5</sub>	490	30	343	96.2	13	13	21.7
BOD <sub>7</sub>	560	30	392	96.2	15	15	25
SS	500	40	300	90	30	30	45
COD <sub>C<sub>1</sub></sub>	1,000	30	700	90	70	75	120
T-N	70	10	63	70	18.9	20	35
T-P	12	10	10.8	*86.2	1.5	1.5	2.5

P.S.T. : Primary Sedimentation Tank

R.R. : Removal Rate

E.Q. : Effluent Quality


S.T.F. : Secondary Treatment Facility

\* : with coagulant treatment

##### 1.3 Design Seage Temperature


In winter : 7 degree C.

## 2. Flow Chart





**MASS BALANCE IN OXIDATION DITCH SYSTEM**  
1. Design for Daily Maximum Flow



4. Facility Capacity Calculation  
4.1 Grit Chamber

Item	Sysmbol	Calculation	Remarks
Design flow (Hourly maximum)	$Q_3$	$3,200 \text{ m}^3/\text{day} = 133.3 \text{ m}^3/\text{hr} = 2.22 \text{ m}^3/\text{min} = 0.037 \text{ m}^3/\text{sec}$	
Type		Sand pit type	
Surface load	$S_L$	$1,800 \text{ m}^3/\text{m}^2.\text{day}$	
Required surface area	$A$	$Q_3 \times 1/S_L = 1.78 \text{ m}^2$	
Effective depth	$h$	0.3 m	
Dimensions		$0.8 \text{ m} \times 2.5 \text{ m} \times \text{Effective depth } 0.3 \text{ m} \times 1 \text{ unit}$	
<i>Check</i>			
Surface area	$A$	$0.8 \times 2.5 = 2.0 \text{ m}^2 > 1.78 \text{ m}^2 \dots \text{OK}$	
Average velocity	$V$	$0.037 \times 1/(0.8 \times 0.3) = 0.15 \text{ m/s} < 0.3 \text{ m/s} \dots \text{OK}$	
Retention time	$T$	$0.8 \times 2.5 \times 0.3 \times 1/0.037 = 16 \text{ sec}$	
Grit		(Daily Average) Assuming that sand volume contained in sewage is $0.01 \text{ m}^3$ per $1,000 \text{ m}^3$ of sewage ; $1,270 \text{ m}^3/\text{day} \times 0.01/1,000 = 0.013 \text{ m}^3/\text{day}$	
Screenings		(Daily average) Equivalent to grit	

4.2 Primary Sedimentation Tank

Item	Symbol	Calculation	Remarks
Design flow (Daily maximum)	$Q_2$	$1,600 \text{ m}^3/\text{day} = 66.7 \text{ m}^3/\text{hr} = 1.1 \text{ m}^3/\text{min}$	
Type		Radial Flow Rectangular Sedimentation Tank	
Surface load	$S_1$	$70 \text{ m}^3/\text{m}^2 \cdot \text{day}$	
Required surface area	$A_1$	$Q_2 \times 1/S_1 = 22.9 \text{ m}^2$	
Effective depth	$H$	3.5 m	
Overflow load		$250 \text{ m}^3/\text{m} \cdot \text{day}$	
Required weir length	$l_1$	$1,600 \times 1/250 = 6.4 \text{ m}$	
Dimensions		W 5.0 m x L 5.0 m x 3.5 mH x 1 unit	
(Surface area)	$A_2$	$5.0 \times 5.0 = 25.0 \text{ m}^2$	
(Capacity)	$V_2$	$25 \times 3.5 = 87.5 \text{ m}^3$	
(Weir length)	$l_2$	$5.0 \times 4 = 20.0 \text{ m}$	
<b>Check</b>			
Surface load		$1,600 \times 1/25 = 64 \text{ m}^3/\text{m}^2 \cdot \text{day} < 70 \dots \text{OK}$	
Retention time	$T_2$	$87.5 \times 1/1,600 \times 24 = 1.3 \text{ hrs}$	
Overflow load		$1,600 \times 1/20 = 80 \text{ m}^3/\text{m} \cdot \text{day} < 250 \dots \text{OK}$	

4.3 Oxidation Ditch  
4.3.1 Oxidation Ditch

Item	Symbol	Calculation	Remarks
Design flow (Daily max.)	$Q_2$	1,600 m <sup>3</sup> /day	
Type		Circulation Flow Channel Type	
Design sewage quality	$S_C$	BOD <sub>5</sub> : 343 mg/l	
	$S_{SS}$	SS : 392 mg/l	
	$S_N$	T-N : 63 mg/l	
MLSS	$C_A$	4,000 mg/l	
BOD-SS load	$B_s$	0.05 kg BOD/kg SS	
Return sludge density	$C_r$	6,000 mg/l	
Hydraulic retention time (HRT)	HRT	1.8 day = 43.2 hrs	
Required capacity	$V$	$V = HRT \times Q_2 = 2,880 \text{ m}^3$	
Dimension			
Channel width	$B$	4.5 m	
Length	$L$	132.8 m	
Effective depth	$H$	2.5 m	
No. of channel	$N$	2 units	
Effective capacity	$V_2$	3.0 % of capacity loss bt hunch shall be considered $V_2 = B \times L \times H \times N \times 0.97 = 2,898 \text{ m}^3$	
<i>Check</i>			
Aeration time	$T_1$	$V_2 \times 24 / Q_2 = 43.5 \text{ hrs}$	

Examination on Retention Time of Oxidation Ditch

Retention time will be calculated by the following three alternatives and largest value will be adopted.

A : Calculation by BOD-SS loading

B : Calculation by Required nitrification/denitrification zone capacity

C : Calculation by Required SRT

Inflow sewage flow per channel =  $Q_2 = 800 \text{ m}^3/\text{day}$

	A. BOD-SS loading	B. Nitrification/denitrification zone		C. Required SRT
		Summer	Winter	
O.D. capacity (m <sup>3</sup> )	1,372	694	1,324	1,305
Retention time (day)	1.72	0.87	1.66	1.63

Thus, Hydraulic Retention Time (HRT) of Oxidation Ditch will be 1.8 days.

A. Calculation by BOD-SS load

$$V = (Q_2 \times \text{BOD}_{in} \times 10^{-3}) / (\text{BOD-SS load} \times \text{MLSS} \times 10^{-3})$$

BOD-SS load : 0.05 kg BOD/kg SS day

MLSS : 4,000 mg/l

B. Calculation by required nitrification/denitrification zone capacity, when sewage temperature is 18 degree C. in summer and 7 degree C. in winter.

Nitrification ratio : 90 % in summer, 70 % in winter

Denitrification ratio : 80 % in summer, 80 % in winter

Nitrification velocity :  $K_N = 0.159 \exp(0.0908T)$  (g-N/g MLSS day)

Denitrification velocity :  $K_{DN} = 0.324 \exp(0.0634T)$  (g-N/g MLSS day)

C. Calculation by required SRT

$$\text{Required SRT} = 20.65 \exp(-0.0639T) = 13.2 \text{ days}$$

T : Sewage temperature in winter (7 degree C.)

Required Oxidation Ditch volume was calculated based on above SRT.

## 4.3.2 Coagulation Facility

Item	Symbol	Calculation	Remarks
Dosing amount			
Design flow	Q	$Q_1 = 1,270 \text{ m}^3/\text{day}, Q_2 = 1,600 \text{ m}^3/\text{day}$	
Inflow T-P	$C_{TP-in}$	10.8 mg/l	
Inflow ST-P	$C_{SIP-in}$	8.6 mg/l	
Coagulant		Alum-Oxichloride ( $\text{Al}_2\text{O}_3$ content : 10 %)	
Dosing concentration	$C_{AL}$	$C_{SIP-in}/P \times m \times AL$ = 7.4 mg/l	
Atomic value of Phosphorous	P	31	
Dosing mole ratio	m	1.0	
Atomic value of Aluminium	AL	27	
Dosing amount (Max)	$R_{AL}$	$C_{AL} \times (O \times 3 + AL \times 2)/(AL \times 2 \times C_{ALL} \times 10^{-2}) \times Q \times 10^{-3}$	
Atomic value of Oxygen	O	16	
$\text{Al}_2\text{O}_3$ content	$C_{ALL}$	10%	
At Daily Maximum	$R_{AL}$	= 224 kg/day	
At Daily Average	$R_{AL}$	= 178 kg/day	
Anticipated consumption		Assuming that annual average inlet T-P is 10 mg/l. Posphorous removal at secondary treatment facility (30 %) shall also be considered.	
Target T-P	$C_{TP-in}$	$10 \times (1 - 0.1) \times (1 - 0.3) = 6.3 \text{ mg/l}$	
Target ST-P	$C_{SIP-in}$	5.0 mg/l	
Dosing concentration	$C_{AL}$	4.4 mg/l	
Dosing amount (Daily average)	$R_{AL}$	105.6 kg/day = 38,544 kg/year	

## 4.3.3 Aeration Equipment

Item	Symbol	Calculation	Remarks
Design sewage flow (Daily maximum)	$Q_2$	1,600 m <sup>3</sup> /day	
Type		Submersible Propeller Mixer and Diffuser Type	
Oxygen Supply	SOR	Oxygen supply is supposed to be 2.1 kg O <sub>2</sub> /kg BOD per unit inflow BOD. Further, aeration equipment shall be able to supply the required oxygen even in case of P.S.T.'s by-pass operation.  = 1,600 m <sup>3</sup> /day x 490 mg/l x 10 <sup>-3</sup> x 2.1 = 1,646 kg O <sub>2</sub> /day	
Air supply	Qa	= SOR/(E x h x 10 <sup>-3</sup> x 24)  E : Oxygen dissolution efficiency (18 g O <sub>2</sub> /m <sup>3</sup> air.water depth) h : Diffuser depth = 2.2 m  = 1,646/(18 x 2.2 x 10 <sup>-3</sup> x 24) = 1,732 m <sup>3</sup> /hr = 28.9 m <sup>3</sup> /min	
Aeration blower			
Type		Roots Blower	
Specification		Dia. 150 mm x 14.5 m <sup>3</sup> /min x 3,200 mmAq x 15 kw	
Quantity		3 sets ( 1 set as stand-by)	
Diffuser			
Type		Membrane Disk Acrator	
Unit air flow		7 m <sup>3</sup> /hr. 1 set	
Quantity		32 units/set x 4 sets/channel x 2 channel = 256 units	
Submersible mixer			
Type		Submersible Propeller Mixer	
Power requirement	Lp	N x V x 10 <sup>-3</sup> = 2.9 kw/channel	

Item	Symbol	Calculation	Remarks
Unit power requirement	N	2.0 w/m <sup>3</sup>	
Ditch volume	V	2,898 m <sup>3</sup> /channel x 1/2 channel = 1,449 m <sup>3</sup> /channel	
Specification and quantity		Dia. 1.6 m x 2.3 kw x 2 sets/channel x 2 channel	



## 4.4 Final Sedimentation Tank

Item	Symbol	Calculation	Remarks
Design flow (Daily maximum)	$Q_2$	$1,600 \text{ m}^3/\text{day} = 66.7 \text{ m}^3/\text{hr} = 1.1 \text{ m}^3/\text{min}$	
Type		Radial Flow Circular Sedimentation Tank with Center driven Sludge Collector	
Surface load	$S_1$	$5 \text{ m}^3/\text{m}^2 \cdot \text{day}$	
Required surface area	$A_1$	$Q_2 \times 1/S_1 = 320 \text{ m}^2$	
Effective depth	$H$	3.5 m	
Overflow load	$O_L$	Less than $25 \text{ m}^3/\text{m} \cdot \text{day}$	
Weir length	$l_1$	$Q_2/O_L = 64 \text{ m}$	
Dimensions		Dia. 14.5 m x 3.5 mH x 2 units	
(Surface area)	$A_2$	$\pi/4 \times 14.5^2 = 165 \text{ m}^2$	
(Capacity)	$V_2$	$165 \times 3.5 = 577.5 \text{ m}^3$	
(Weir length)	$l_2$	$\pi \times (14.5 - 1.0) = 42.4 \text{ m}$	
<b>Check</b>			
Surface load	$A$	$1,600 \times 1/(165 \times 2) = 4.8 \text{ m}^3/\text{m}^2 \cdot \text{day} < 5.0 \dots \text{OK}$	
Retention time	$T_2$	$577.5 \times 2 \times 1/66.7 = 17.3 \text{ hrs}$	
Overflow load		$1,600 \times 1/(42.4 \times 2) = 18.9 \text{ m}^3/\text{m}^2 \cdot \text{day} < 25 \dots \text{OK}$	
<b>Examination on Surface load</b>			
Initial sedimentation velocity	$v_0$	$4.9 \times 10^6 \times T^{0.95} \times X_A^{-1.35} \times [\text{SVI}]^{-0.77}$ $= 9.0 \text{ m/hr}$	
Sewage temperature	$T$	7 degree C.	
MLSS	$X_A$	4,000 mg/l	
SVI		150	

SC-1

Item	Symbol	Calculation	Remarks
Surface load	S	$v_0/R = 4.5 \dots 5.0 \text{ m}^3/\text{m}^2 \text{ day}$	
Fluctuation ratio	R	2	

## 4.5 Sludge Thickener

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	$q_2$	P.S.T. sludge : 20 m <sup>3</sup> /day, 399 kg/day Excess sludge : 75 m <sup>3</sup> /day, 424 kg/day Total 95 m <sup>3</sup> /day, 823 kg/day	
Type		Radial Flow Rectangular Sedimentation Tank with Picket Fence Mixer	
Solid load		40 kg DS/m <sup>2</sup> .day	
Required surface area		$823 \times 1/40 = 20.6 \text{ m}^2$	
Effective depth		4.0 m	
Dimensions		W 5.0 m x L 5.0 m x 4.0 mH x 1 unit	
(Surface area)	$A_2$	$5.0 \times 5.0 = 25.0 \text{ m}^2$	
(Capacity)	$V_2$	$25 \times 4.0 = 100 \text{ m}^3$	
<i>Check</i>			
Solid load		$823 \times 1/25 = 33 \text{ kg DS/m}^2 \cdot \text{day}$	
Thickening time	T	$100 \times 1/95 \times 24 = 25 \text{ hrs}$	

4.6 Sludge Storage Tank

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	$Q_2$	Gravity thickened sludge : 26 m <sup>3</sup> /day, 658 kg DS/day	
Type		Rectangular Tank	
Storage days	$T_1$	More than 2 day's sludge volume	
Storage capacity	$V_1$	26 x 2 = 52 m <sup>3</sup>	
Dimensions		3.0 m x 5.0m x 4.0 mH (effective depth)	
(Effective capacity)	$V_2$	3.0 x 5.0 x 4.0 = 60 m <sup>3</sup>	
<i>Check</i>			
Storage days	$T_2$	60 x 1/26 = 2.3 days	

## 4.7 Sludge Dewater

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	$Q_2$	Gravity thickened sludge : 26 m <sup>3</sup> /day, 658 kg DS/day (Mixed sludge)	
Type		Centrifugal Dewater Machine	
Operation time		6 days in week, 6 hrs/day	
Capacity requirement		26 m <sup>3</sup> /day x 7/6 x 1/6 = 5.0 m <sup>3</sup> /hr	
Specifications		5.0 m <sup>3</sup> /hr x 18.5 kw/7.5 kw x 1 unit	
Polymer dosing ratio		Less than 1.3 % per DS	
Polymer consumption (Daily average)		Assuming that annual average inlet SS is 350 mg/l and average dosing ratio is 1.0 % ;  $658 \times 350/500 \times 1,270/1,600 \times 1.0 \times 10^{-2}$ $= 3.66 \text{ kg/day} = 1,336 \text{ kg/year}$	

## 4.8 Composting Yard

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily average)	$q_1$	Target dewatered sludge volume is based on daily average sewage flow.	
Dewatered cake			
Solid weight	$D_1$	$625 \text{ kg DS/day} \times 0.8 = 500 \text{ kg DS/day}$	
Water content	$w_1$	84 % (water content of dewatered cake : 97.5 %)	
Cake weight	$V_1$	$500 \times 100 / (100 - 84) \times 10^{-3} = 3.1 \text{ wt/day}$	
Bulk density	$C_1$	$1.0 \text{ t/m}^3$	
Apparent volume	$V_1'$	$3.1 \text{ wt /day} \times 1/1.0 = 3.1 \text{ m}^3/\text{day}$	
Organic content		80%	
Organic digestion ratio		60%	
Digested organic		$500 \times 0.8 \times 0.6 = 240 \text{ kg DS/day}$	
Compost products			
Solid weight	$D_2$	$500 - 240 = 260 \text{ kg/day} = 0.26 \text{ t/day}$	
Water content	$w_2$	35%	
Product weight	$V_2$	$0.26 \times 100 / (100 - 35) = 0.4 \text{ wt/day}$	
Bulk density	$C_2$	$0.4 \text{ wt/m}^3$	
Apparent volume	$V_2'$	$0.4 \times 1/0.4 = 1.0 \text{ m}^3/\text{day}$	
Composting yard			
Storage days	T	180 days	
Deposit height	h	0.6 m	
Required area	A	$(3.1 + 1.0) \times 1/2 \times 180 \times 1/0.6 = \text{more than } 615 \text{ m}^2$	
Dimensions (Area)		$9.0 \text{ m} \times 36.0 \text{ mL} \times 2 \text{ lines}$ $9.0 \times 36.0 \times 2 = 648 \text{ m}^2$	

## 4.9 Sludge Lagoon

Item	Symbol	Calculation	Remarks
Design sewage flow (Thickened sludge)	Qd.ave	$26 \times 1,270 / 1,600 = 20.6 \text{ m}^3/\text{day}$	
Retention time	T	30 days	
Required volume	V	$20.6 \times 30 = 618 \text{ m}^3$	
Depth	D	1.5 m	
Surface area	A	$618 \times 1 / 1.5 = 412 \text{ m}^2$	
Dimension		W 20 m x 20 m L x 1.5 mH	

4.10 Transformer Capacity

Item	Symbol	Calculation	Remarks
Transformer capacity	TC	$EC \times (B \times A) / (E \times PF)$ $= 84.3 \text{ KVA} \dots 100 \text{ KVA}$	
Electrical capacity	EC	90.2 kw	
Demand factor	B	0.65	
Allowance	A	1.1	
General Efficiency	E	0.85	
General power factor	PF	0.9	



## 5. Mechanical Equipment List

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-1	Mechanical Screen	Mechanical Bar Screen 800 W x 1,000 H Bar spacing : 5 mm	0.4	1	For main channel with screening cage
M-2	Bypass Screen	Bar Screen 800 W x 600 H Bar spacing : 20 mm	-	1	For bypass channel
M-3	Sand Pump	Submersible Sand Pump Dia. 80 mm x 0.3 m <sup>3</sup> /min x 10 mH	3.7	1	
M-4	Raw Sludge Pump	Nonclog Centrifugal Sludge Pump Dia. 80 mm x 0.3 m <sup>3</sup> /min x 5 mH	1.5	1	
M-5	Submersible Mixer	Submersible Propeller Mixer Dia. 1.6 m x two blades Lifter Type	2.3	4	
M-6	Diffuser	Membrane Rubber Diffuser 7 m <sup>3</sup> air/hr set 32 sets/1 unit x 8 units	-	256	Oxygen supply efficiency 18 g O <sub>2</sub> /m <sup>3</sup> -air-m water depth
M-7	Aeration Blower	Roots Blower Dia. 150 mm x 14.5 m <sup>3</sup> /min x 3,200 mmAq	15	2 + 1	Inverter control
M-8	Coagulant Tank	FRP Cylindrical Tank 5.0 m <sup>3</sup> with Mixer	0.1	1	
M-9	Coagulant Feed Pump	Diaphragm Pump 0.1 l/min x 20 m	0.2	2	Manual control
M-10	Caustic Soda Tank	FRP Cylindrical Tank 4.0 m <sup>3</sup> with Mixer	0.1	1	
M-11	Caustic Soda Feed Pump	Diaphragm Pump 0.1 l/min. x 20 m	0.2	2	Manual control

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-12	Bypass Gate	Rising Spindle Type Gate Dia. 400 mm	-	1	
M-13	Final Sedimentation Tank Sludge Collector	Center Drive Clarifier Dia. 14.5 m x 3.5 mH with Picket Fence	0.75	2	
M-14	Return Sludge Pump	Nonlog Centrifugal with Screw Type Sludge Pump Dia. 80mm x 0.6 m <sup>3</sup> /min x 5 m	1.5	4	Hydrostal Type
M-15	Excess Sludge Pump	Progressive Cavity Pump Dia. 80mm x 6.5 m <sup>3</sup> /hr x 10 m	2.2	2	
M-16	Plant Water Pump	Submersible Pump Dia. 65mm x 0.2 m <sup>3</sup> /min x 30 m	2.2	1	
M-17	Sludge Thickening Mixer	Center Drive Picket Fence Type Mixer Dia. 1,500 mm	0.2	1	
M-18	Thickened Sludge Pump	Progressive Cavity Pump Dia. 80 mm x 7.5 m <sup>3</sup> /hr x 20 m	2.2	1 + 1	
M-19	Sludge Storage Tank Mixing Blower	Roots Blower Dia. 50 mm x 0.2 m <sup>3</sup> /min x 4,000 mm Aq	0.75	1	
M-20	Sludge Feed Pump	Progressive Cavity Pump Dia. 80 mm x 7.5 m <sup>3</sup> /hr x 20 m	2.2	1	
M-21	Sludge Dewatering Unit	Centrifugal Type Dewaterer 5.0 m <sup>3</sup> /hr	18.5 + 3.7	1	
M-22	Sludge Cake Conveyor	Screw Conveyor 1.0 m <sup>3</sup> /hr	0.75	1	
M-23	Polymer Tank	FRP Cylindrical Tank 5.0 m <sup>3</sup> with Mixer	0.1	1	

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-24	Polymer Feed Pump	Progressive Cavity Pump Dia. 25 mm x 0.9 m <sup>3</sup> /hr x 20 mH	0.4	1	
M-25	Drain Pump	Submersible Non-clog Pump Dia. 80 mm x 0.3 m <sup>3</sup> /min x 10 mH	1.5	1	
M-26	Flow Measurement Equipment	Parshall Flume Type W = 0.31 m	-	1	
M-27	Septage Transfer Pump	Submersible Non-clog Pump Dia. 80 mm x 0.3 m <sup>3</sup> /min x 10 mH	1.5	1	

5. Capacity Calculation for Skuodas Treatment Plant  
(Case 2)

**Appendix 5 Capacity Calculation for Skoudas Sewage Treatment Plant (Case 2)**  
**Case 2 : Oxidation Ditch System without Primary Sedimentation Tank**

**1. Design Criteria**

**1.1 Design Sewage Flow**

$$Q_{dave} = Q_1 = 1,270 \text{ m}^3/\text{day}$$

$$Q_{dmax} = Q_2 = 1,600 \text{ m}^3/\text{day}$$

$$Q_{hmax} = Q_3 = 3,200 \text{ m}^3/\text{day}$$

**1.2 Design Sewage Quality**


Item	Influent Quality (mg/l)	Secondary Treatment Facility		Discharge Standard		Remarks
		Removable Rates (%)	Effluent Quality (mg/l)	Average (mg/l)	Maximum (mg/l)	
BOD <sub>5</sub>	490	97.4	13	13	21.7	
BOD <sub>7</sub>	560	97.4	15	15	25	
SS	500	95	25	30	45	
COD <sub>Cr</sub>	1,000	92.5	75	75	120	
T-N	70	70	21	20	35	
T-P	12	*87.5	1.5	1.5	2.5	

\* : with coagulant treatment

**1.3 Design Seage Temperature**

In winter : 7 degree C.

2. Flow Chart



Mass Balance

Skudgas OD mass balance.cdr

OD Qdm (2)

MASS BALANCE IN OXIDATION DITCH SYSTEM

1. Design for Daily Maximum Flow (without Primary Sedimentation Tank)

Inflow  
 Qdm 1,600 m<sup>3</sup>/day  
 BOD<sub>5</sub> 784 kg/day  
 SS 800 kg/day  
 COD 1,600 kg/day  
 Total-N 112 kg/day  
 Total-P 19 kg/day

Design Flow	Qdm	m <sup>3</sup> /hour	m <sup>3</sup> /min	m <sup>3</sup> /sec
Daily Average	1,270	52.8	0.88	0.015
Daily Maximum	1,600	66.7	1.11	0.019
Hourly Peak	3,200	133.3	2.22	0.037

Influent Quality	Effluent Quality
BOD <sub>5</sub> 960 mg/l	15 mg/l
BOD <sub>5</sub> 490 mg/l	13 mg/l
SS 500 mg/l	30 mg/l
COD 1,000 mg/l	75 mg/l
Total-N 70 mg/l	20 mg/l
Total-P 12 mg/l	1.5 mg/l

OD Design Criteria for Daily Maximum Flow  
 Design MLSS 4,000 mg/l  
 Design BOD/SS Ratio 0.05 kg-BOD/kg-SS  
 Minimum HRT 2.0 days for Nitrification/Denitrification

Oxidation Ditch Influent  
 Q 1,718 m<sup>3</sup>/day  
 BOD<sub>5</sub> 784 kg/day  
 SS 988 kg/day

Oxidation Ditch  
 $V = \frac{Q \cdot (C_0 - C)}{C} = \frac{1,718 \cdot (960 - 15)}{15} = 10,446 \text{ m}^3$   
 HRT = 2.0 days  
 MLSS = 15,901 kg  
 BOD/SS Ratio = 0.049

Return Sludge  
 Return Ratio 200 % of Inflow  
 Or 3,200 m<sup>3</sup>/day  
 Water Contents 99.4 %  
 SS 6,000 mg/l  
 = 19,200 kg/day

Final Sedimentation Tank  
 Q 4,918 m<sup>3</sup>/day  
 BOD<sub>5</sub> 13 mg/l  
 SS 64 kg/day  
 COD 4,058 mg/l  
 Total-N 19,949 kg/day  
 Total-P (see SS Balance below)

Excess Sludge  
 Qe 121 m<sup>3</sup>/day  
 SS Water C. 99.4 %  
 SS 6,000 mg/l  
 = 701 kg/day

Sludge Thickener  
 SS Yield 80 %  
 Water Cont. 98.5 %  
 SS 561 kg/day  
 Qe 37 m<sup>3</sup>/day

Sludge Dewatering  
 SS Yield 95 %  
 Water Cont. 85 %  
 SS 533 kg/day  
 Sludge Volume 3.6 m<sup>3</sup>/day (wet base)  
 Qa

Oxidation Ditch Dimension  
 volume 3,920 m<sup>3</sup>  
 no. 2 units  
 unit vol. 1,960 m<sup>3</sup>/unit  
 depth 5.0 m  
 surface area 392 m<sup>2</sup>/unit  
 width 5.0 m  
 length 78 m/unit

SS Balance in Oxidation Ditch	kg/day
Influent SS	988
Effluent SS	48
SS removed	920
Net reduction by endogenous decay	75 (including convert from BOD removed)
SS increase after decay	690
SS increase by coagulant dosage	59
SS in the Return Sludge	19,200
Total SS	19,949

Liquid Returned to Grit Chamber  
 Or 34 m<sup>3</sup>/day  
 SS 28 kg/day  
 = 829 mg/l

Liquid Returned to Grit Chamber  
 Or 84 m<sup>3</sup>/day  
 SS 140 kg/day  
 = 1,670 mg/l

← coagulant dosage rate  
 7.4 mg/l  
 SS production factor  
 5.0 kg-SS/kg-coagulant

## 4. Facility Capacity Calculation

## 4.1 Grit Chamber

Item	Symbol	Calculation	Remarks
Design flow (Hourly maximum)	$Q_3$	$3,200 \text{ m}^3/\text{day} = 133.3 \text{ m}^3/\text{hr} = 2.22 \text{ m}^3/\text{min} = 0.037 \text{ m}^3/\text{sec}$	
Type		Sand pit type	
Surface load	$S_L$	$1,800 \text{ m}^3/\text{m}^2 \cdot \text{day}$	
Required surface area	A	$Q_3 \times 1/S_L = 1.78 \text{ m}^2$	
Effective depth	h	0.3 m	
Dimensions		$0.8 \text{ m} \times 2.5 \text{ m} \times \text{Effective depth } 0.3 \text{ m} \times 1 \text{ unit}$	
<i>Check</i>			
Surface area	A	$0.8 \times 2.5 = 2.0 \text{ m}^2 > 1.78 \text{ m}^2 \dots \text{OK}$	
Average velocity	V	$0.037 \times 1/(0.8 \times 0.3) = 0.15 \text{ m/s} < 0.3 \text{ m/s} \dots \text{OK}$	
Retention time	T	$0.8 \times 2.5 \times 0.3 \times 1/0.037 = 16 \text{ sec}$	
Grit		(Daily Average) Assuming that sand volume contained in sewage is $0.01 \text{ m}^3$ per $1,000 \text{ m}^3$ of sewage ; $1,270 \text{ m}^3/\text{day} \times 0.01/1,000 = 0.013 \text{ m}^3/\text{day}$	
Screenings		(Daily average) Equivalent to grit	



4.2 Oxidation Ditch  
4.2.1 Oxidation Ditch

Item	Symbol	Calculation	Remarks
Design flow (Daily max.)	$Q_2$	1,600 m <sup>3</sup> /day	
Type		Circulation Flow Channel Type	
Design sewage quality	$S_C$	BOD <sub>5</sub> : 490 mg/l	
	$S_{SS}$	SS : 500 mg/l	
	$S_N$	T-N : 70 mg/l	
MLSS	$C_A$	4,000 mg/l	
BOD-SS load	$B_S$	0.05 kg BOD/kg SS	
Return sludge density	$C_r$	6,000 mg/l	
Hydraulic retention time (HRT)	HRT	2.6 day = 62.4 hrs	
Required capacity	$V$	$V = HRT \times Q_2 = 4,160 \text{ m}^3$	
Dimension			
Channel width	$B$	4.5 m	
Length	$L$	192.8 m	
Effective depth	$H$	2.5 m	
No. of channel	$N$	2 units	
Effective capacity	$V_2$	3.0 % of capacity loss bt hunch shall be considered $V_2 = B \times L \times H \times N \times 0.97 = 4,208 \text{ m}^3$	
<i>Check</i>			
Aeration time	$T_1$	$V_2 \times 24/Q_2 = 63.1 \text{ hrs}$	

Examination on Retention Time of Oxidation Ditch

Retention time will be calculated by the following three alternatives and largest value will be adopted.

A : Calculation by BOD-SS loading

B : Calculation by Required nitrification/denitrification zone capacity

C : Calculation by Required SRT

Inflow sewage flow per channel =  $Q_2 = 800 \text{ m}^3/\text{day}$

	A. BOD-SS loading	B. Nitrification/denitrification zone		C. Required SRT
		Summer	Winter	
O.D. capacity ( $\text{m}^3$ )	1,960	694	1,324	2,063
Retention time (day)	2.45	0.87	1.66	2.58

Thus, Hydraulic Retention Time (HRT) of Oxidation Ditch will be 2.6 days.

A. Calculation by BOD-SS load

$$V = (Q_2 \times \text{BOD}_{\text{in}} \times 10^{-3}) / (\text{BOD-SS load} \times \text{MLSS} \times 10^{-3})$$

BOD-SS load : 0.05 kg BOD/kg SS day

MLSS : 4,000 mg/l

B. Calculation by required nitrification/denitrification zone capacity,  
when sewage temperature is 18 degree C. in summer and 7 degree C. in winter.

Nitrification ratio : 90 % in summer, 70 % in winter

Denitrification ratio : 80 % in summer, 80 % in winter

Nitrification velocity :  $K_N = 0.159 \exp (0.0908T)$  (g-N/g MLSS day)

Denitrification velocity :  $K_{DN} = 0.324 \exp (0.0634T)$  (g-N/g MLSS day)

C. Calculation by required SRT

$$\text{Required SRT} = 20.65 \exp (-0.0639T) = 13.2 \text{ days}$$

T : Sewage temperature in winter (7 degree C.)

Required Oxidation Ditch volume was calculated based on above SRT.

4.2.2 Coagulation Facility

Item	Symbol	Calculation	Remarks
<b>Dosing amount</b>			
Design flow	Q	$Q_1 = 1,270 \text{ m}^3/\text{day}, Q_2 = 1,600 \text{ m}^3/\text{day}$	
Inflow T-P	$C_{TP-in}$	12.0 mg/l	
Inflow ST-P	$C_{STP-in}$	9.6 mg/l	
Coagulant		Alum-Oxichloride ( $Al_2O_3$ content : 10 %)	
<b>Dosing concentration</b>			
	$C_{AL}$	$C_{STP-in}/P \times m \times AL$ = 8.4 mg/l	
Atomic value of Phosphorous	P	31	
Dosing mole ratio	m	1.0	
Atomic value of Aluminium	AL	27	
<b>Dosing amount (Max)</b>			
	$R_{AL}$	$C_{AL} \times (O \times 3 + AL \times 2) / (AL \times 2 \times C_{ALL} \times 10^{-2}) \times Q \times 10^{-3}$	
Atomic value of Oxygen	O	16	
$Al_2O_3$ content	$C_{ALL}$	10%	
At Daily Maximum	$R_{AL}$	= 254 kg/day	
At Daily Average	$R_{AL}$	= 202 kg/day	
<b>Anticipated consumption</b>			
		Assuming that annual average inlet T-P is 10 mg/l. Posphorous removal at secondary treatment facility (30 %) shall also be considered.	
Target T-P	$C_{TP-in}$	$12 \times (1 - 0.3) = 8.4 \text{ mg/l}$	
Target ST-P	$C_{STP-in}$	6.7 mg/l	
Dosing concentration	$C_{AL}$	5.8 mg/l	
Dosing amount (Daily average)	$R_{AL}$	139.2 kg/day = 50,808 kg/year	

## 4.2.3 Aeration Equipment

Item	Sysmbol	Calculation	Remarks
Design sewage flow (Daily maximum)	$Q_2$	1,600 m <sup>3</sup> /day	
Type		Submersible Propeller Mixer and Diffuser Type	
Oxygen Supply	SOR	Oxygen supply is supposed to be 2.1 kg O <sub>2</sub> /kg BOD per unit inflow BOD. Further, aeration equipment shall be able to supply the required oxygen even in case of P.S.T.'s by-pass operation.  = 1,600 m <sup>3</sup> /day x 490 mg/l x 10 <sup>-3</sup> x 2.1 = 1,646 kg O <sub>2</sub> /day	
Air supply	Qa	= SOR/(E x h x 10 <sup>-3</sup> x 24)  E : Oxygen dissolution efficicney (18 g O <sub>2</sub> /m <sup>3</sup> air.water depth) h : Deffuser depth = 2.2 m  = 1,646/(18 x 2.2 x 10 <sup>-3</sup> x 24) = 1,732 m <sup>3</sup> /hr = 28.9 m <sup>3</sup> /min	
Aeration blower			
Type		Roots Blower	
Specification		Dia. 150 mm x 14.5 m <sup>3</sup> /min x 3,200 mmAq x 15 kw	
Quantity		3 sets ( 1 set as stand-by)	
Diffuser			
Type		Membrane Disk Acrator	
Unit air flow		7 m <sup>3</sup> /hr. 1 set	
Quantity		32 units/set x 4 sets/channel x 2 channel = 256 units	
Submersible mixer			
Type		Submersible Propeller Mixer	
Power requirement	Lp	N x V x 10 <sup>-3</sup> = 4.2 kw/channel	

Item	Symbol	Calculation	Remarks
Unit power requirement	N	2.0 w/m <sup>3</sup>	
Ditch volume	V	4,208 m <sup>3</sup> /channel x 1/2 channel = 2,104 m <sup>3</sup> /channel	
Specification and quantity		Dia. 1.6 m x 2.3 kw x 2 sets/channel x 2 channel	

## 4.3 Final Sedimentation Tank

Item	Symbol	Calculation	Remarks
Design flow (Daily maximum)	$Q_2$	$1,600 \text{ m}^3/\text{day} = 66.7 \text{ m}^3/\text{hr} = 1.1 \text{ m}^3/\text{min}$	
Type		Radial Flow Circular Sedimentation Tank with Center driven Sludge Collector	
Surface load	$S_1$	$5 \text{ m}^3/\text{m}^2 \cdot \text{day}$	
Required surface area	$A_1$	$Q_2 \times 1/S_1 = 320 \text{ m}^2$	
Effective depth	H	3.5 m	
Overflow load	$O_1$	Less than $25 \text{ m}^3/\text{m} \cdot \text{day}$	
Weir length	$l_1$	$Q_2/O_1 = 64 \text{ m}$	
Dimensions		Dia. 14.5 m x 3.5 mH x 2 units	
(Surface area)	$A_2$	$\pi/4 \times 14.5^2 = 165 \text{ m}^2$	
(Capacity)	$V_2$	$165 \times 3.5 = 577.5 \text{ m}^3$	
(Weir length)	$l_2$	$\pi \times (14.5 - 1.0) = 42.4 \text{ m}$	
<b>Check</b>			
Surface load	A	$1,600 \times 1/(165 \times 2) = 4.8 \text{ m}^3/\text{m}^2 \cdot \text{day} < 5.0 \dots \text{OK}$	
Retention time	$T_2$	$577.5 \times 2 \times 1/66.7 = 17.3 \text{ hrs}$	
Overflow load		$1,600 \times 1/(42.4 \times 2) = 18.9 \text{ m}^3/\text{m}^2 \cdot \text{day} < 25 \dots \text{OK}$	
<b>Examination on Surface load</b>			
Initial sedimentation velocity	$v_0$	$4.9 \times 10^6 \times T^{0.95} \times X_A^{-1.35} \times [\text{SVI}]^{-0.77}$ $= 9.0 \text{ m/hr}$	
Sewage temperature	T	7 degree C.	
SVI		150	
Surface load	S	$v_0/R = 4.5 \dots 5.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$	
Fluctuation ratio	R	2	

## 4.4 Sludge Thickener

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	$Q_2$	Excess sludge : 121 m <sup>3</sup> /day, 701 kg/day	
Type		Radial Flow Rectangular Sedimentation Tank with Picket Fence Mixer	
Solid load		30 kg DS/m <sup>2</sup> .day	
Required surface area		$701 \times 1/40 = 23.4 \text{ m}^2$	
Effective depth		4.0 m	
Dimensions		W 5.0 m x L 5.0 m x 4.0 mH x 1 unit	
(Surface area)	$A_2$	$5.0 \times 5.0 = 25.0 \text{ m}^2$	
(Capacity)	$V_2$	$25 \times 4.0 = 100 \text{ m}^3$	
<b>Check</b>			
Solid load		$701 \times 1/25 = 28 \text{ kg DS/m}^2 \cdot \text{day}$	
Thickening time	T	$100 \times 1/121 \times 24 = 19.8 \text{ hrs}$	

4.5 Sludge Storage Tank

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	$q_2$	Gravity thickened sludge : $37 \text{ m}^3/\text{day}$ , $561 \text{ kg DS}/\text{day}$	
Type		Rectangular Tank	
Storage days	$T_1$	More than 2 day's sludge volume	
Storage capacity	$V_1$	$37 \times 2 = 74 \text{ m}^3$	
Dimensions		$4.0 \text{ m} \times 5.0 \text{ m} \times 4.0 \text{ mH}$ (effective depth)	
(Effective capacity)	$V_2$	$4.0 \times 5.0 \times 4.0 = 80 \text{ m}^3$	
<b>Check</b>			
Storage days	$T_2$	$80 \times 1/37 = 2.2 \text{ days}$	



4.6 Sludge Dewater

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	Q <sub>2</sub>	Gravity thickened sludge : 37 m <sup>3</sup> /day, 561 kg DS/day (Excess sludge only)	
Type		Centrifugal Dewater Machine	
Operation time		6 days in week, 6 hrs/day	
Capacity requirement		37 m <sup>3</sup> /day x 7/6 x 1/6 = 7.2 m <sup>3</sup> /hr	
Specifications		8.0 m <sup>3</sup> /hr x 22 kw/5.5 kw x 1 unit	
Polymer dosing ratio		Less than 1.5 % per DS	
Polymer consumption (Daily average)		Assuming that annual average inlet SS is 350 mg/l and average dosing ratio is 1.2 % ;  561 x 350/500 x 1,270/1,600 x 1.2 x 10 <sup>-2</sup> = 3.74 kg/day = 1,365 kg/year	

## 4.7 Composting Yard

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily average)	$q_1$	Target dewatered sludge volume is based on daily average sewage flow.	
Dewatered cake			
Solid weight	$D_1$	$533 \text{ kg DS/day} \times 0.8 = 426 \text{ kg DS/day}$	
Water content	$w_1$	85 % (water content of dewatered cake : 98.5 %)	
Cake weight	$V_1$	$426 \times 100 / (100 - 85) \times 10^{-3} = 2.8 \text{ wt/day}$	
Bulk density	$C_1$	$1.0 \text{ t/m}^3$	
Apparent volume	$V_1'$	$2.8 \text{ wt/day} \times 1/1.0 = 2.8 \text{ m}^3/\text{day}$	
Organic content		70%	
Organic digestion ratio		60%	
Digested organic		$426 \times 0.7 \times 0.6 = 179 \text{ kg DS/day}$	
Compost products			
Solid weight	$D_2$	$426 - 179 = 247 \text{ kg/day} = 0.25 \text{ t/day}$	
Water content	$w_2$	35%	
Product weight	$V_2$	$0.25 \times 100 / (100 - 35) = 0.38 \text{ wt/day}$	
Bulk density	$C_2$	$0.4 \text{ wt/m}^3$	
Apparent volume	$V_2'$	$0.38 \times 1/0.4 = 0.95 \text{ m}^3/\text{day}$	
Composting Yard			
Storage days	T	180 days	
Deposit height	h	0.6 m	
Required area	A	$(2.8 + 0.95) \times 1/2 \times 180 \times 1/0.6 = \text{more than } 563 \text{ m}^2$	
Dimensions		10.0 m x 30.0 mL x 2 lines	
(Area)		$10.0 \times 30.0 \times 2 = 600 \text{ m}^2$	

## 4.8 Sludge Lagoon

Item	Sysmbol	Calculation	Remarks
Design sewage flow (Thickened sludge)	Qd.ave	$37 \times 1,270/1,600 = 29.4 \text{ m}^3/\text{day}$	
Retention time	T	30 days	
Required volume	V	$29.4 \times 30 = 882 \text{ m}^3$	
Depth	D	1.5 m	
Surface area	A	$882 \times 1/1.5 = 588 \text{ m}^2$	
Dimension		W 20 m x 30 mL x 1.5 mH	

4.9 Transformer Capacity

Item	Symbol	Calculation	Remarks
Transformer capacity	TC	$EC \times (B \times A) / (E \times PF)$ $= 89.3 \text{ KVA} \dots 100 \text{ KVA}$	
Electrical capacity	EC	95.5 kw	
Demand factor	B	0.65	
Allowance	A	1.1	
General Efficiency	E	0.85	
General power factor	PF	0.9	

## 5. Mechanical Equipment List

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-1	Mechanical Screen	Mechanical Bar Screen 800 W x 1,000 H Bar spacing : 5 mm	0.4	1	For main channel with screening cage
M-2	Bypass Screen	Bar Screen 800 W x 600 H Bar spacing : 20 mm	-	1	For bypass channel
M-3	Sand Pump	Submersible Sand Pump Dia. 80 mm x 0.3 m <sup>3</sup> /min x 10 mH	3.7	1	
M-4	Submersible Mixer	Submersible Propeller Mixer Dia. 1.6 m x two blades Lifter Type	2.3	4	
M-5	Diffuser	Membrane Rubber Diffuser 7 m <sup>3</sup> air/hr set 32 sets/1 unit x 8 units	-	256	Oxygen supply efficiency 18 g O <sub>2</sub> /m <sup>3</sup> -air-m water depth
M-6	Aeration Blower	Roots Blower Dia. 150 mm x 14.5 m <sup>3</sup> /min x 3,200 mmAq	15	2 + 1	Inverter control
M-7	Coagulant Tank	FRP Cylindrical Tank 5.0 m <sup>3</sup> with Mixer	0.1	1	
M-8	Coagulant Feed Pump	Diaphragm Pump 0.1 l/min x 20 m	0.2	2	Manual control
M-9	Caustic Soda Tank	FRP Cylindrical Tank 4.0 m <sup>3</sup> with Mixer	0.1	1	
M-10	Caustic Soda Feed Pump	Diaphragm Pump 0.1 l/min. x 20 m	0.2	2	Manual control
M-11	Bypass Gate	Rising Spindle Type Gate Dia. 400 mm	-	1	

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-12	Final Sedimentation Tank Sludge Collector	Center Drive Clarifier Dia. 14.5 m x 3.5 mH with Picket Fence	0.75	2	
M-13	Return Sludge Pump	Nonlog Centrifugal with Screw Type Sludge Pump Dia. 80mm x 0.6 m <sup>3</sup> /min x 5 m	1.5	4	Hydrostal Type
M-14	Excess Sludge Pump	Progressive Cavity Pump Dia. 80mm x 6.5 m <sup>3</sup> /hr x 10 m	2.2	2	
M-15	Plant Water Pump	Submersible Pump Dia. 65mm x 0.2 m <sup>3</sup> /min x 30 m	2.2	1	
M-16	Sludge Thickening Mixer	Center Drive Picket Fence Type Mixer Dia. 1,500 mm	0.2	1	
M-17	Thickened Sludge Pump	Progressive Cavity Pump Dia. 80 mm x 7.5 m <sup>3</sup> /hr x 20 m	2.2	1 + 1	
M-18	Sludge Storage Tank Mixing Blower	Roots Blower Dia. 50 mm x 0.2 m <sup>3</sup> /min x 4,000 mm Aq	0.75	1	
M-19	Sludge Feed Pump	Progressive Cavity Pump Dia. 100 mm x 12 m <sup>3</sup> /hr x 20 m	3.7	1	
M-20	Sludge Dewatering Unit	Centrifugal Type Dewater 8.0 m <sup>3</sup> /hr	22 + 5.5	1	
M-21	Sludge Cake Conveyor	Screw Conveyor 1.0 m <sup>3</sup> /hr	0.75	1	
M-22	Polymer Tank	FRP Cylindrical Tank 5.0 m <sup>3</sup> with Mixer	0.1	1	
M-23	Polymer Feed Pump	Progressive Cavity Pump Dia. 25 mm x 1.3 m <sup>3</sup> /hr x 20 mH	0.4	1	

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-24	Drain Pump	Nonclog Submersible Pump Dia. 80 mm x 0.3 m <sup>3</sup> /min x 10 mH	1.5	1	
M-25	Flow Measurement Equipment	Parshall Flume Type W = 0.31 m	-	1	

6. Capacity Calculation for Skuodas Treatment Plant  
(Case 3)



## Appendix 6 Capacity Calculation for Skondas Sewage Treatment Plant (Case 3)

### Case 3 : Sequencing Batch Reactor System

#### 1. Design Criteria

##### 1.1 Design Sewage Flow

$$Q_{\text{dave}} = Q_1 = 1,270 \text{ m}^3/\text{day}$$

$$Q_{\text{dmax}} = Q_2 = 1,600 \text{ m}^3/\text{day}$$

$$Q_{\text{hmax}} = Q_3 = 3,200 \text{ m}^3/\text{day}$$

##### 1.2 Design Sewage Quality


Item	Influent Quality (mg/l)	Secondary Treatment Facility		Discharge Standard		Remarks
		Removable Rates (%)	Effluent Quality (mg/l)	Average (mg/l)	Maximum (mg/l)	
BOD <sub>5</sub>	490	97.4	13	13	21.7	
BOD <sub>7</sub>	560	97.4	15	15	25	
SS	500	95	25	30	45	
COD <sub>Cr</sub>	1,000	92.5	75	75	120	
T-N	70	70	21	20	35	
T-P	12	*87.5	1.5	1.5	2.5	

\* : with coagulant treatment

##### 1.3 Design Seage Temperature

In winter : 7 degree C.

2. Flow Chart



Mass Balance

MASS BALANCE IN SBR SYSTEM  
1. Design for Daily Maximum Flow

Inflow

Qdm	1,600 m <sup>3</sup> /day
BOD5	784 kg/day
SS	800 kg/day
COD	1,600 kg/day
Total-N	112 kg/day
Total-P	19 kg/day

Design Flow	m <sup>3</sup> /day	m <sup>3</sup> /hour	m <sup>3</sup> /min	m <sup>3</sup> /sec
Daily Average	1,270	52.9	0.88	0.015
Daily Maximum	1,600	66.7	1.11	0.019
Hourly Peak	3,200	133.3	2.22	0.037

	Influent Quality	Affluent Quality
BOD7	950 mg/l	15 mg/l
BOD5	490 mg/l	13 mg/l
SS	500 mg/l	30 mg/l
COD	1,000 mg/l	75 mg/l
Total-N	70 mg/l	20 mg/l
Total-P	12 mg/l	1.5 mg/l

SBR Design Criteria for Daily Maximum Flow  
 Design MLSS 2,000 mg/l  
 Design BOD/SS Ratio 0.2 Kg-BOD/kg-SS  
 Minimum HRT 2.0 days for Nitrification/Denitrification  
 Oxidation Ditch

V = 4,000 m<sup>3</sup>  
 HRT = 2.50 day  
 MLSS = 2,000 mg/l  
 BOD/SS Ratio 0.20

SBR Influent Q

BOD5 1,752 m<sup>3</sup>/day  
 SS 784 kg/day  
 1,029 kg/day

Grit Chamber

Inflow

Chemical Coagulant  
 7.4 mg/l for influent Q  
 11.8 kg/day

Effluent

Q 1,596 m<sup>3</sup>/day  
 BOD5 13 mg/l  
 = 21 kg/day  
 SS 30 mg/l  
 = 48 kg/day

Excess Sludge  
 Qe 156 m<sup>3</sup>/day  
 Ca 99.4 %  
 SS Water C. 6,000 mg/l  
 = 939 kg/day  
 (see SS Balance below)

Liquid Returned to Grit Chamber  
 Qr 106 m<sup>3</sup>/day  
 Or 188 kg/day  
 SS = 1,765 mg/l

Liquid Returned to Grit Chamber  
 Qr 45 m<sup>3</sup>/day  
 Or 38 kg/day  
 SS = 829 mg/l

SS Balance	
Influent SS	1,025 kg/day
Affluent SS	48 kg/day
SS removed	977 kg/day
Net reduction by endogenous decay	90 % (including convert from BOD removed)
SS increase after decay	879 kg/day
SS increase by coagulant dosage	59 kg/day
Total SS	939 kg/day

← coagulant dosage rate  
 7.4 mg/l  
 SS production factor  
 5.0 kg-SS/kg-coagulant

Sludge Thickener

80 %  
 98.5 % water  
 751 kg/day  
 SS  
 50 m<sup>3</sup>/day

Sludge Dewatering

95 %  
 85 % water  
 713 kg/day  
 SS

Sludge Volume  
 Qs 4.8 m<sup>3</sup>/day (wet base)

4. Facility Capacity Calculation

4.1 Grit Chamber

Item	Symbol	Calculation	Remarks
Design flow (Hourly maximum)	$Q_3$	$3,200 \text{ m}^3/\text{day} = 133.3 \text{ m}^3/\text{hr} = 2.22 \text{ m}^3/\text{min} = 0.037 \text{ m}^3/\text{sec}$	
Type		Sand pit type	
Surface load	$S_i$	$1,800 \text{ m}^3/\text{m}^2 \cdot \text{day}$	
Required surface area	A	$Q_3 \times 1/S_i = 1.78 \text{ m}^2$	
Effective depth	h	0.3 m	
Dimensions		$0.8 \text{ m} \times 2.5 \text{ m} \times \text{Effective depth } 0.3 \text{ m} \times 1 \text{ unit}$	
<b>Check</b>			
Surface area	A	$0.8 \times 2.5 = 2.0 \text{ m}^2 > 1.78 \text{ m}^2 \dots \text{OK}$	
Average velocity	V	$0.037 \times 1/(0.8 \times 0.3) = 0.15 \text{ m/s} < 0.3 \text{ m/s} \dots \text{OK}$	
Retention time	T	$0.8 \times 2.5 \times 0.3 \times 1/0.037 = 16 \text{ sec}$	
Grit		(Daily Average) Assuming that sand volume contained in sewage is $0.01 \text{ m}^3$ per $1,000 \text{ m}^3$ of sewage ; $1,270 \text{ m}^3/\text{day} \times 0.01/1,000 = 0.013 \text{ m}^3/\text{day}$	
Screenings		(Daily average) Equivalent to grit	

4.2 Balancing Tank

Item	Symbol	Calculation	Remarks
Design flow (Daily maximum)	$Q_2$	1,600 m <sup>3</sup> /day	
Type		Rectangular Tank	
Retention time	T	6 hrs	
Required capacity	V	$Q_2 \times T \times 1/24 = 400 \text{ m}^3$	
Dimensions (Capacity)	V'	9.0 m x 11.0 m x 4.5 mH (effective depth) $9.0 \times 11.0 \times 4.5H = 446 \text{ m}^3$	



## 4.3.2 Coagulation Facility

Item	Symbol	Calculation	Remarks
<b>Dosing amount</b>			
Design flow	Q	$Q_1 = 1,270 \text{ m}^3/\text{day}, Q_2 = 1,600 \text{ m}^3/\text{day}$	
Inflow T-P	$C_{\text{TP-in}}$	12.0 mg/l	
Inflow ST-P	$C_{\text{STP-in}}$	9.6 mg/l	
Coagulant		Alum-Oxichloride ( $\text{Al}_2\text{O}_3$ content : 10 %)	
<b>Dosing concentration</b>			
	$C_{\text{AL}}$	$C_{\text{STP-in}}/P \times m \times \text{AL}$ = 8.4 mg/l	
Atomic value of Phosphorous	P	31	
Dosing mole ratio	m	1.0	
Atomic value of Aluminium	AL	27	
<b>Dosing amount (Max)</b>			
	$R_{\text{AL}}$	$C_{\text{AL}} \times (\text{O} \times 3 + \text{AL} \times 2) / (\text{AL} \times 2 \times C_{\text{AII}} \times 10^{-3}) \times Q \times 10^{-3}$	
Atomic value of Oxygen	O	16	
$\text{Al}_2\text{O}_3$ content	$C_{\text{AII}}$	10%	
At Daily Maximum	$R_{\text{AL}}$	= 254 kg/day	
At Daily Average	$R_{\text{AL}}$	= 202 kg/day	
<b>Anticipated consumption</b>			
		Assuming that annual average inlet T-P is 10 mg/l. Posphorous removal at secondary treatment facility (70 %) shall also be considered.	
Target T-P	$C_{\text{TP-in}}$	$10 \times (1 - 0.7) = 3.0 \text{ mg/l}$	
Target ST-P	$C_{\text{STP-in}}$	2.4 mg/l	
<b>Dosing concentration</b>			
	$C_{\text{AL}}$	2.1 mg/l	
Dosing amount (Daily average)	$R_{\text{AL}}$	50.4 kg/day = 18,396 kg/year	

4.3.3 Aeration Equipment

Item	Sysmbol	Calculation	Remarks
Type		Submersible Mechanical Aerator	
Oxygen Supply	SOR	$Q \times (S_{in} - S_{out}) \times 10^{-3} \times A$ = 1,596 kg O <sub>2</sub> /day = 66.5 kg O <sub>2</sub> /hr	
Sewage inflow	Q	= Q <sub>2</sub> = 1,600 m <sup>3</sup> /day	
Inflow BOD	S <sub>in</sub>	490 mg/l	
Effluent BOD	S <sub>out</sub>	15 mg/l	
Required oxygen per unit BOD removal	A	2.1 kg O <sub>2</sub> /kg BOD	
Air supply	Qa	= $SOR / (G_s \times 10^{-2} \times E \times O_w) \times (273 + T) / 273 \times 1/60 \times A$ = 22.1 m <sup>3</sup> /min	
Oxygen transfer efficiency against clear water	G <sub>s</sub>	20 % (Submergible Mechanical Aerator)	
Air density	E	1.2923 kg air/N m <sup>3</sup>	
Air temperature	T	15 degree C.	
Surplus ratio	A	1.15	
Aeration blower			
Type		Roots Blower	
Specification		Dia. 200 mm x 23 m <sup>3</sup> /min x 6,000 mmAq x 55 kw	
Quantity		2 sets ( 1 set as stand-by)	
Aeration equipment			
Type		Submersible Type Mochanical Aerator	
Specification		38 kg O <sub>2</sub> /hr x 11 kw x 4 sets	



4.4 Sludge Thickener

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	$Q_2$	Excess sludge : 156 m <sup>3</sup> /day, 939 kg/day	
Type		Radial Flow Rectangular Sedimentation Tank with Picket Fence Mixer	
Solid load		30 kg DS/m <sup>2</sup> .day	
Required surface area		$939 \times 1/30 = 31.3 \text{ m}^2$	
Effective depth		4.0 m	
Dimensions		W 6.0 m x L 6.0 m x 4.0 mH x 1 unit	
(Surface area)	$A_2$	$6.0 \times 6.0 = 36.0 \text{ m}^2$	
(Capacity)	$V_2$	$36 \times 4.0 = 144 \text{ m}^3$	
<i>Check</i>			
Solid load		$939 \times 1/36 = 26.1 \text{ kg DS/m}^2 \cdot \text{day}$	
Thickening time	T	$144 \times 1/156 \times 24 = 22 \text{ hrs}$	

4.5 Sludge Storage Tank

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	$q_2$	Gravity thickened sludge : $50 \text{ m}^3/\text{day}$ , $751 \text{ kg DS/day}$	
Type		Rectangular Tank	
Storage days	$T_1$	More than 2 day's sludge volume	
Storage capacity	$V_1$	$50 \times 2 = 100 \text{ m}^3$	
Dimensions		$5.0 \text{ m} \times 5.5 \text{ m} \times 4.0 \text{ mH}$ (effective depth)	
(Effective capacity)	$V_2$	$5.0 \times 5.5 \times 4.0 = 110 \text{ m}^3$	
<i>Check</i>			
Storage days	$T_2$	$110 \times 1/50 = 2.2 \text{ days}$	

## 4.6 Sludge Dewater

Item	Symbol	Calculation	Remarks
Design sludge volume (Daily maximum)	$q_2$	Gravity thickened sludge : 50 m <sup>3</sup> /day, 751 kg DS/day (Excess sludge only)	
Type		Centrifugal Dewater Machine	
Operation time		6 days in week, 6 hrs/day	
Capacity requirement		50 m <sup>3</sup> /day x 7/6 x 1/6 = 9.7 m <sup>3</sup> /hr	
Specifications		10 m <sup>3</sup> /hr x 1 unit	
Polymer dosing ratio		Less than 1.5 % per DS	
Polymer consumption (Daily average)		Assuming that annual average inlet SS is 350 mg/l and average dosing ratio is 1.2 % ;  751 x 350/500 x 1,270/1,600 x 1.2 x 10 <sup>-2</sup> = 5.01 kg/day = 1,829 kg/year	

## 4.7 Composting Yard

Item	Sysnbol	Calculation	Remarks
Design sludge volume (Daily average)	$q_1$	Target dewatered sludge volume is based on daily average sewage flow.	
Dewatered cake			
Solid weight	$D_1$	$713 \text{ kg DS/day} \times 0.8 = 570 \text{ kg DS/day}$	
Water content	$wt_1$	85%	
Cake weight	$V_1$	$570 \times 100 / (100 - 85) \times 10^{-3} = 3.8 \text{ wt/day}$	
Bulk density	$C_1$	$1.0 \text{ t/m}^3$	
Apparent volume	$V_1'$	$3.8 \text{ wt /day} \times 1/1.0 = 3.8 \text{ m}^3/\text{day}$	
Organic content		80%	
Organic digestion ratio		60%	
Digested organic		$570 \times 0.8 \times 0.6 = 274 \text{ kg DS/day}$	
Compost products			
Solid weight	$D_2$	$570 - 274 = 296 \text{ kg/day} = 0.29 \text{ t/day}$	
Water content	$wt_2$	35%	
Product weight	$V_2$	$0.29 \times 100 / (100 - 35) = 0.44 \text{ wt/day}$	
Bulk density	$C_2$	$0.4 \text{ wt/m}^3$	
Apparent volume	$V_2'$	$0.44 \times 1/0.4 = 1.1 \text{ m}^3/\text{day}$	
Composting yard			
Storage days	T	180 days	
Deposit height	h	0.6 m	
Required area	A	$(3.8 + 1.1) \times 1/2 \times 180 \times 1/0.6 = \text{more than } 735 \text{ m}^2$	
Dimensions (Area)		$11.0 \text{ m} \times 36.0 \text{ mL} \times 2 \text{ lines}$ $11.0 \times 36.0 \times 2 = 792 \text{ m}^2$	

4.8 Sludge Lagoon

Item	Symbol	Calculation	Remarks
Design sewage flow (Thickened sludge)	Qd.ave	$50 \times 1,270 / 1,600 = 39.7 \text{ m}^3/\text{day}$	
Retention time	T	30 days	
Required volume	V	$39.7 \times 30 = 1,191 \text{ m}^3$	
Depth	D	1.5 m	
Surface area	A	$1,191 \times 1 / 1.5 = 794 \text{ m}^2$	
Dimension		W 26 m x 32 mL x 1.5 mH	

## 4.9 Transformer Capacity

Item	Symbol	Calculation	Remarks
Transformer capacity	TC	$EC \times (B \times A) / (E \times PF)$ = 155 KVA ... 200 KVA	
Electrical capacity	EC	166.25 kw	
Demand factor	B	0.65	
Allowance	A	1.1	
General Efficiency	E	0.85	
General power factor	PF	0.9	

## 5. Mechanical Equipment List

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-1	Mechanical Screen	Mechanical Bar Screen 800 W x 1,000 H Bar spacing : 5 mm	0.4	1	For main channel with screening cage
M-2	Bypass Screen	Bar Screen 800 W x 600 H Bar spacing : 20 mm	-	1	For bypass channel
M-3	Sand Pump	Submersible Sand Pump Dia. 80 mm x 0.3 m <sup>3</sup> /min x 10 mH	3.7	1	
M-4	Mixing Pump	Submersible Pup with Ejector Dia. 80 mm	5.5	2	
M-5	Lift Pump	Submersible Non-clog Pump Dia. 100 mm x 1.33 m <sup>3</sup> /min x 10 m	5.5	1 + 1	
M-6	Aerator	Submersible Mechanical Aerator Lifter Type, 38 kg O <sub>2</sub> /hr	7.5	4	
M-7	Aeration Blower	Roots Blower Dia. 200 mm x 23 m <sup>3</sup> /min x 6,000 mmAq	45	1 + 1	Inverter control
M-8	Outlet Equipment	Float-arm Type 4.0 mL	0.75	2	
M-9	Coagulant Tank	FRP Cylindrical Tank 5.0 m <sup>3</sup> with Mixer	0.1	1	
M-10	Coagulant Feed Pump	Diaphragm Pump 0.1 l/min x 20 m	0.2	2	Manual control
M-11	Caustic Soda Tank	FRP Cylindrical Tank 4.0 m <sup>3</sup> with Mixer	0.1	1	
M-12	Caustic Soda Feed Pump	Diaphragm Pump 0.1 l/min. x 20 m	0.2	2	Manual control

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-13	Scum Removal Equipment	Trough Skimer FRP, 150W x 7,000L	0.2	2	
M-14	Motor Valve	Motorized Butterfly Valve Dia. 200 mm	0.1	4	
M-15	Excess Sludge Pump	Submersible Non-clog Pump Dia. 80mm x 0.4 m <sup>3</sup> /min x 10 m	2.2	4	
M-16	Plant Water Pump	Submersible Pump Dia. 65mm x 0.2 m <sup>3</sup> /min x 30 m	2.2	1	
M-17	Sludge Thickening Mixer	Center Drive Picket Fence Type Mixer Dia. 1,500 mm	0.2	1	
M-18	Thickened Sludge Pump	Progressive Cavity Pump Dia. 80 mm x 7.5 m <sup>3</sup> /hr x 20 m	2.2	1 + 1	
M-19	Sludge Storage Tank Mixing Blower	Roots Blower Dia. 50 mm x 0.2 m <sup>3</sup> /min x 4,000 mm Aq	0.75	1	
M-20	Sludge Feed Pump	Progressive Cavity Pump Dia. 125 mm x 15 m <sup>3</sup> /hr x 20 m	5.5	1	
M-21	Sludge Dewatering Unit	Centrifugal Type Dewater 10 m <sup>3</sup> /hr	37 + 7.5	1	
M-22	Sludge Cake Conveyor	Screw Conveyor 1.0 m <sup>2</sup> /hr	0.75	1	
M-23	Polymer Tank	FRP Cylindrical Tank 8.0 m <sup>3</sup> with Mixer	0.2	1	
M-24	Polymer Feed Pump	Progressive Cavity Pump Dia. 32 mm x 1.8 m <sup>3</sup> /hr x 20 mH	0.75	1	
M-25	Drain Pump	Submersible Non-clog Pump Dia. 80 mm x 0.3 m <sup>3</sup> /min x 10 mH	1.5	1	




SC-3

No.	Equipment Name	Specification	Motor Output (kw)	Quantity	Remarks
M-26	Flow Measurement Equipment	Parshall Flume Type W = 0.31 m	-	1	

7. Topographic Survey Map






Study on the Sewerage System Improvement of  
Birzai and Skuodas Town in the Republic of Lithuania

Figure ST 1-1  
Skuodas Sewage Treatment Plant  
Topographic Map

## 8. Soil Investigation Result





Study on the Sewerage System Improvement of  
 Birzai and Skuodas Town in the Republic of Lithuania  
 Figure SG 1-1  
 Skuodas Sewage Treatment Plant  
 Soil Investigation Location Map

No.	Description of soil	Symbol	Unit Volume Weight (kg/cm <sup>3</sup> )	Adhesion (kPa)	Friction Angle (degree)	Def. Modulus (MPa)	Strength (kPa)	Soil Clasific. Number
1	Poured soil		1760	-	-	-	80	10b
2	Plastic sandy soil		2.050	15	26	10	180	10a
3	Fine sand, loose		1620	-	29	5	100	10a
4	Fine sand, medium density		1660	2	32	24	300 (200)	10a
5	Loamy soil, solidly plastic		2.010	28	22	22	250	10b
6	Gravel		1900	1	40	40	500	10d
7	Clay, solidly plastic		1920	43	16	13	250	10v
8	Moraine loamy soil		2.240	39	24	23	300	10ž
9	Moraine loamy soil, solidly plastic		2.260	47	26	40	300	10ž
10	Moraine sandy soil, solid		2.250	21	30	45	300	10ž

Study on the Sewerage System Improvement of Birzai and Skuodas Town in the Republic of Lithuania


Table SG 2-1

Skuodas Sewage Treatment Plant  
Geological Symbols and  
Characteristic of Soils




-

17.0  
16.0  
15.0  
14.0  
13.0  
12.0  
11.0  
10.0  
9.0  
8.0



Boring No.	GR.1	GR.2
Ground Level	16.61	16.03
Section Length (m)	61.50	

| - |



Scale V : 1/100  
H : 1/200



Study on the Sewerage System Improvement of  
Birzoi and Skuodas Town in the Republic of Lithuania  
Figure SG 2-1  
Skuodas Sewage Treatment Plant  
Geological Section (I-I)  
8-3

GR2

16.03


61.50

IV - IV



Boring No.	GR 7	GR 8
Ground Level	16.24	16.32
Section Length (m)	63.00	

IV - IV





Scale V : 1/100  
H : 1/200

Study on the Sewerage System Improvement of  
Biržai and Skuodas Town in the Republic of Lithuania  
Figure SG 2-2  
Skuodas Sewage Treatment Plant  
Geological Section (IV-IV)  
8-4


63.00

V - V



Boring No.	GR.7	GR.5
Ground Level	16.24	16.39
Section Length (m)	41.00	36.00

V - V





GR 5	GR 3	GR 1
16.39	16.75	16.61
36.00	32.50	

Scale V : 1/100  
H : 1/200


Study on the Sewerage System Improvement of  
Birzoi and Skuodas Town in the Republic of Lithuania  
Figure SG 2-3  
Skuodas Sewage Treatment Plant  
Geological Section (V-V)  
8-5

VI - VI



Boring No.	GR.8	GR.6
Ground Level	16.32	16.25
Section Length (m)	43.00	34.00

VI - VI



Scale V : 1/100  
H : 1/200

GR.6

GR.4

GR.2

16.25

16.20

16.03


34.00

33.00

Study on the Sewerage System Improvement of  
Birzai and Skuodas Town in the Republic of Lithuania  
Figure SG 2-4  
Skuodas Sewerage Treatment Plant  
Geological Section (VI-VI)  
8-6



XIII - XIII




Boring No.	GR.24	GR.21	GR.17
Ground Level	16.73	16.54	16.20
Section Length (m)	35.50	22.00	



XV - XV


17.0  
16.0  
15.0  
14.0  
13.0  
12.0  
11.0  
10.0  
9.0  
8.0  
7.0  
6.0  
5.0  
4.0



Boring No.	GR.26	GR.23	GR.19
Ground Level	16.70	16.65	16.79
Section Length (m)	34.00		21.50

Study on the  
Birzai and Sku  
Figure SG 2  
Skuo  
Geolo

XV - XV



Scale V : 1/100  
H : 1/200

GR.26

GR.23

GR.19

16.70

16.65

16.79

34.00

21.50



Study on the Sewerage System Improvement of  
Birzai and Skuodas Town in the Republic of Lithuania

Figure SG 2-6

Skuodas Sewage Treatment Plant  
Geological Section (XV-XV)


8-8

XVI - XVI



Boring No.	GR.16	GR.17	GR.18
Ground Level	16.20	16.20	16.20
Section Length (m)	14.50	26.50	29.00



XVI - XVI



Scale V : 1/100  
H : 1/200


Study on the Sewerage System Improvement of  
Birzai and Skuodas Town in the Republic of Lithuania  
Figure SG 2-7  
Skuodas Sewage Treatment Plant  
Geological Section (XVI-XVI)  
8-9

14.50	26.50	29.00
16.20	16.20	16.45
GR.17	GR.18	GR.19



Boring No.	GR.20	GR.21	GR.22
Ground Level	16.32	16.54	16.50
Section Length (m)	15.00	26.00	29.00

XVII - XVII



GR 22

GR 23

GR 27

GR 30

16.50

16.65

16.27

16.25

26.00


29.00

20.50

15.50

21.00





GR.27

GR.30

GR.31

GR.32

Scale V : 1/100  
H : 1/200

Study on the Sewerage System Improvement of  
Biržai and Skuodas Town in the Republic of Lithuania  
Figure SG 2-8  
Skuodas Sewerage Treatment Plant  
Geological Section (XVI-XVII)  
8-10

16.27

16.25

16.23

16.23

20.50


15.50

21.00

12.00


XIX - XIX

17.0  
16.0  
15.0  
14.0  
13.0  
12.0  
11.0  
10.0  
9.0  
8.0  
7.0  
6.0  
5.0  
4.0



Boring No.	GR.24	GR.25
Ground Level	16.73	16.83
Section Length (m)	35.00	28.50

XIX - XIX



GR 25

GR 26

Scale V : 1/100  
H : 1/200

35.00

28.50

16.83

16.70

Study on the Sewerage System Improvement of  
Birzai and Skuodas Town in the Republic of Lithuania

Figure SG 2-9

Skuodas Sewage Treatment Plant  
Geological Section (XIX-XIX)

8-11