

**BASIC DESIGN STUDY REPORT  
ON  
THE PROJECT FOR THE EXPANSION  
OF  
TRANSMISSION AND DISTRIBUTION GRID  
FOR  
THE DISTRICTS COMMEWIJNE AND SARAMACCA  
IN  
THE REPUBLIC OF SURINAME**

**NOVEMBER, 1999**

JICA LIBRARY



J 1153781 181

**JAPAN INTERNATIONAL COOPERATION AGENCY  
YACHIYO ENGINEERING CO., LTD.**

|        |
|--------|
| GRO    |
| CR (1) |
| 99-151 |

NOVEMBER 1999

10  
44  
R0  
RARY







**BASIC DESIGN STUDY REPORT  
ON  
THE PROJECT FOR THE EXPANSION  
OF  
TRANSMISSION AND DISTRIBUTION GRID  
FOR  
THE DISTRICTS COMMEWIJNE AND SARAMACCA  
IN  
THE REPUBLIC OF SURINAME**

**NOVEMBER, 1999**

**JAPAN INTERNATIONAL COOPERATION AGENCY  
YACHIYO ENGINEERING CO., LTD.**



1153781 (8)

## PREFACE

In response to a request from the Government of the Republic of Suriname, the Government of Japan decided to conduct a basic design study on the Project for the Expansion of Transmission and Distribution Grid for the Districts Commewijne and Saramacca in the Republic of Suriname and entrusted the study to the Japan International Cooperation Agency (JICA).

JICA sent to Suriname a study team from April 25 to June 6, 1999.

The team held discussions with the officials concerned of the Government of Suriname, and conducted a field study at the study area. After the team returned to Japan, further studies were made. Then, a mission was sent to Suriname in order to discuss a draft basic design, and as this result, the present report was finalized.

I hope that this report will contribute to the promotion of the project and to the enhancement of friendly relations between our two countries.

I wish to express my sincere appreciation to the officials concerned of the Government of the Republic of Suriname for their close cooperation extended to the teams.

November, 1999

A handwritten signature in black ink, appearing to read 'Kimio Fujita', with a stylized, flowing script.

Kimio Fujita

President

Japan International Cooperation Agency





## LETTER OF TRANSMITTAL


November, 1999

We are pleased to submit to you the basic design study report on the Project for the Expansion of Transmission and Distribution Grid for the Districts Commewijne and Saramacca in the Republic of Suriname.


This study was conducted by Yachiyo Engineering Co., Ltd., under a contract to JICA, during the period from March 29, 1999 to November 9, 1999. In conducting the study, we have examined the feasibility and rationale of the project with due consideration to the present situation of Suriname and formulated the most appropriate basic design for the project under Japan's grant aid scheme.

Finally, we hope that this report will contribute to further promotion of the project.


Very truly yours,



Mitsuhsa Nishikawa  
Project Manager,  
Basic design study team on the Project for  
the Expansion of Transmission and Distribution Grid for  
the Districts Commewijne and Saramacca  
Yachiyo Engineering Co., Ltd.



Map of Suriname



Map of Suriname





Map of Project Site

## **ABBREVIATIONS**

|                  |   |
|------------------|---|
| <b>CBB</b>       | <b>Centraal Bureau voor Burgerzaken (Central Bureau for Statistics)</b>             |
| <b>EBS</b>       | <b>N.V. Energie Bedrijven Suriname</b>  |
| <b>EC</b>        | <b>European Commission</b>  |
| <b>E/N</b>       | <b>Exchange of Notes</b>  |
| <b>GDP</b>       | <b>Gross Domestic Product</b>   |
| <b>IEC</b>       | <b>International Electrotechnical Commission</b>                                    |
| <b>JEAC</b>      | <b>Japan Electric Association Code</b>  |
| <b>JEC</b>       | <b>Japanese Electrotechnical Committee</b>  |
| <b>JEM</b>       | <b>Standards of Japan Electrical Manufacturers' Association</b>                     |
| <b>JICA</b>      | <b>Japan International Cooperation Agency</b>                                       |
| <b>JIS</b>       | <b>Japanese Industrial Standards</b>  |
| <b>IPP</b>       | <b>Independent Power Producer</b>   |
| <b>O &amp; M</b> | <b>Operation and Maintenance</b>  |
| <b>OJT</b>       | <b>On-the-Job Training</b>  |
| <b>OLTC</b>      | <b>On-Load Tap Changer</b>  |
| <b>SCADA</b>     | <b>Supervisory Control and Data Acquisition</b>                                     |
| <b>Sf</b>        | <b>Suriname Guilder (official rate: 1 US\$ = 790 Sf as of the end of May, 1999)</b> |

# CONTENTS

PREFACE

LETTER OF TRANSMITTAL

LOCATION MAP

ABBREVIATIONS

CHAPTER 1 BACKGROUND OF THE PROJECT.....1

CHAPTER 2 CONTENTS OF THE PROJECT .....5

2.1 Objective of the Project.....5

2.2 Basic Concept of the Project.....5

2.3 Basic Design.....7

2.3.1 Design Concept.....7

2.3.2 Basic Design.....10

CHAPTER 3 IMPLEMENTATION PLAN.....91

3.1 Implementation Plan .....91

3.1.1 Implementation Concept .....91

3.1.2 Implementation Conditions.....92

3.1.3 Scope of Work.....93

3.1.4 Work Supervision by the Consultant.....97

3.1.5 Equipment and Materials Procurement Plan.....101

3.1.6 Implementation Schedule .....103

3.1.7 Obligations of Recipient Country.....103

3.2 Operation and Maintenance Plan.....105

CHAPTER 4 PROJECT EVALUATION AND RECOMMENDATIONS.....111

4.1 Project Effects .....111

4.2 Recommendations.....114

## APPENDICES

1. Member List of the Survey Team
2. Survey Schedule
3. List of Party Concerned in the Recipient Country
4. Minutes of Discussions
5. Cost Estimation Borne by the Recipient Country
6. Boring Data

## **LIST OF FIGURES AND TABLES**

### **Chapter 2**

|              |   |
|--------------|---|
| Table 2-3-1  | Peak Demand of EPAR System and GDP  |
| Table 2-3-2  | Present Load in Project Area (1999)   |
| Table 2-3-3  | Load List of Waiting Consumers in Commewijne District   |
| Table 2-3-4  | Load List of Waiting Consumers in Saramacca District  |
| Table 2-3-5  | Power Demand Forecast for Project Area  |
| Table 2-3-6  | Required Number of Pole-Mounted Transformers for Civil Use in Commewijne District                       |
| Table 2-3-7  | Required Number of Pole-Mounted Transformers for Civil Use in Saramacca District                        |
| Table 2-3-8  | Outline of Basic Plan   |
| Table 2-3-9  | Details of La Paix Substation Construction Plan   |
| Table 2-3-10 | Details of Sidodadiweg Substation Construction Plan   |
| Table 2-3-11 | Details of Existing Substation B Expansion Plan   |
| Table 2-3-12 | Details of Existing Substation D Expansion Plan   |
| Table 2-3-13 | Procurement Quantity of Conductors for Overhead Transmission and Distribution Lines and Grounding Wires |
| Table 2-3-14 | Procurement Quantity of Pole-Mounted Transformers   |
| Table 2-3-15 | Procurement Quantity of Open Fuse Cutout  |
| Table 2-3-16 | Procurement Quantity of Insulators  |
| Table 2-3-17 | Quantity of Electric Poles  |
| Table 2-3-18 | Purpose of Use and Procurement Quantity by Pole Type  |
| Table 2-3-19 | Procurement Quantity of Underwater Cable  |
| Table 2-3-20 | Equipment and Materials for Underwater Cable Installation Work (Japanese Portion)                       |
| Table 2-3-21 | Equipment and Materials for Underwater Cable Installation Work (Suriname Side)                          |
| Table 2-3-22 | Procurement Quantity of Cable for Saramacca Bridge Section  |
| Table 2-3-23 | Procurement Quantity of Cable for Substation Connection   |

### **Chapter 3**

|             |   |
|-------------|---|
| Fig. 3-1-1  | Project Implementation System   |
| Fig. 3-1-2  | Project Implementation Schedule   |
| Fig. 3-2-1  | Basic Concept of Substation, Transmission and Distribution Equipment Maintenance                        |
| Table 3-1-1 | Division of Work Between Japanese and Suriname Sides  |
| Table 3-1-2 | Engineers Dispatched by the Equipment Supplier  |
| Table 3-2-1 | Regular Inspection Items for Standard Substation, Transmission and Distribution Equipment and Materials |
| Table 3-2-2 | Spare Parts and Maintenance Tools to be Procured Under the Project Spare Parts for Substation           |



## **CHAPTER 1**

### **BACKGROUND OF THE PROJECT**



## **CHAPTER 1**

### **BACKGROUND OF THE PROJECT**

The Republic of Suriname (hereinafter referred to as Suriname) was governed by the Netherlands until its independence in 1975. Even today, the Netherlands is still Suriname's largest donor and maintains a close relationship with the country. The main industry of Suriname is the production and export of bauxite. Although the export of such natural resources as wood and oil is hoped for in addition to bauxite, the social instability since independence and the sluggish prices of these export products have prevented the development of export industries. Suriname has a population of approximately 434,000 (1997 statistics), most of which live on the fertile plains in the north. Some 228,000 people, more than half of the total population, live in the capital, Paramaribo (1997 statistics). While there is still continuous migration to the capital region, the slow progress of social infrastructure development due to the budgetary shortage of the competent authorities has prevented improvement of the local standard of living and industrial development.

Northern parts of both Commewijne District and Saramacca District which comprise the Project Area are adjacent to the capital region and are expected to see industrial development as well as to absorb the increasing population in the capital region. Accordingly, the Government of Suriname believes that improvement of the social infrastructure in these districts is essential.

The electricity sector in Suriname is run by the N.V. Energie Bedrijven Suriname (EBS). While the EBS supplies electricity to residential areas in the capital region as well as to local areas, there is no national transmission grid. Although the diesel power stations owned by the EBS supply electricity to Paramaribo and the surrounding area, the electricity demand is mainly met by means of the purchase of electricity from the hydropower and thermal power stations owned by a private mining company (SURALCO). Sufficient electricity is supplied to Paramaribo and the surrounding area by these power sources via the local transmission and distribution grid. In contrast, most of the northern parts of the Commewijne and Saramacca Districts are not connected to the power grid serving Paramaribo. Meanwhile, the stability of the electricity supply and equipment capacity are inadequate in most parts of the northern Commewijne and Saramacca Districts and some areas do not even have electricity supply.

Against this background, the Government of Suriname formulated the National Multi-Annual Development Programme (1994 - 1999) for the Commewijne and Saramacca Districts to improve the standard of living by means of improving the social infrastructure, including the electricity supply and road networks. In the electricity sector, there is a transmission and

distribution grid expansion project to connect these two districts to the power grid around Paramaribo with a view to providing these districts with a stable supply of electricity and this project commands high implementation priority. Nevertheless, there is no realistic prospect of project implementation because of the government's budgetary shortage, resulting in a request to the Government of Japan for the implementation of the project for the Expansion of Transmission and Distribution Grid for the Districts Commewijne and Sarawacca (hereinafter referred to as the Project) with Japan's grant aid.

**[Contents of the Request]**

**(1) Construction of Substations**

**1) Construction of New La Paix Substation in Commewijne District**

One main transformer (10 MVA; 33/12.6 kV); three 33 kV switchgear panels; seven 12.6 kV switchgear panels; one set of remote control and protection panels; one DC supply system; all necessary civil and building work

**2) Construction of New Sidodadiweg Substation in Saramacca District**

One main transformer (10 MVA; 33/12.6 kV); three 33 kV switchgear panels; seven 12.6 kV switchgear panels; one set of remote control and protection panels; one DC supply system; all necessary civil and building work

**3) Expansion of Existing Substation B**

One 33 kV switchgear panel; one remote control and protection panel; others

**4) Expansion of Existing Substation D**

One 33 kV switchgear panel; one remote control and protection panel; others

**5) Spare Parts and Operation and Maintenance Manuals**

Spare parts (for one year); operation and maintenance manuals; set of tools

**(2) Procurement of Equipment and Materials for Construction of Transmission and Distribution Lines**

**1) Equipment and Materials for 33 kV Transmission Line in Commewijne District**

- (a) Underground cables and accessories from the existing Substation B to the riverside of Suriname River Bridge (approximately 1.6 km)**

- (b) Cables and accessories to cross Suriname River Bridge (approximately 1.7 km)
  - (c) Materials (Conductors, grounding wires, insulators, steel arms, steel poles, etc., excluding wooden poles) for new 33 kV overhead transmission line (approximately 16.5 km) from Meerzorg, the crossing point of Suriname River, to the La Paix Substation to be newly constructed under the Project
- 2) Equipment and Materials for 12.6 kV Distribution Line in Commewijne District
- (a) Materials (Conductors, grounding wires, insulators, steel arms and pole-mounted transformers, etc., excluding wooden poles) for new 12.6 kV distribution line (approximately 13 km)
  - (b) Underwater cables and accessories to cross Commewijne River (approximately 1.5 km)
- 3) Equipment and Materials for 33 kV Transmission Line in Saramacca District
- (a) Materials (Conductors, grounding wires, insulators, steel arms, steel poles, etc., excluding wooden poles) for new 33 kV overhead transmission line from the connection point of the existing 33 kV transmission line (Garnizoenspad) to the new Sidodadiweg Substation (approximately 23 km)
  - (b) 33 kV underground cables and accessories for the Saramacca Bridge section (approximately 0.8 km)
- 4) Materials for 12.6 kV Distribution Line in Saramacca District
- (a) Materials (cables, grounding cables, insulators, steel arms, pole-mounted transformers, etc., excluding wooden poles) for new 12.6 kV distribution line (approximately 42 km)
  - (b) 12.6 kV underground cables and accessories for the Saramacca Bridge section (approximately 0.8 km x two lines)
- 5) Installation and Operation and Maintenance Manuals
- Set of installation and operation and maintenance manuals for 1) through 4) above.

In the original request, the use of underwater cable was planned to cross Suriname River, running from existing Substation A located at the Paramaribo Power Station to Meerzorg Town on the opposite bank. At the time of explanation of the draft Basic Design Report to the Surinamese side, however, it was confirmed that Suriname Bridge under construction is likely to be completed by May, 2000. Consequently, it was decided to use the said bridge as the cabling route in view of the improved safety of the transmission line construction work and ease of future maintenance work. Following this change of the cabling route, it was also decided to change the substation for the installation of a 33 kV switchgear panel from the originally requested Substation A of the Paramaribo Power Station to Substation B.

In regard to the extension of the 33 kV transmission line to the Saramacca District, the original request listed existing Substation E for the installation of a 33 kV switchgear feeder panel. However, such installation would require major remodelling of the said substation, necessitating large funding. Moreover, it was found possible to use one of the two transmission lines connecting existing Substation D to Substation E. In view of this prospect, the installation site of the new 33 kV switchgear feeder panel to be procured under the Project was changed to existing Substation D located in the western part of Paramaribo.

In the case of the procurement of pole-mounted transformers for distribution grid, the Suriname side requested the inclusion of such transformers to serve consumers waiting to be connected to the existing distribution grid. While the procurement of pole-mounted transformers for areas with many waiting consumers and of high priority is included in the Project, the procurement of such transformers for other areas to be connected to the existing distribution grid is excluded from the Project and is left to the self-reliant efforts of the Surinamese side.

Overhead grounding wires for the 33 kV transmission line in Saramacca District which were requested by the Surinamese side during the field survey are included in the scope of procurement under the Project in view of their necessity to protect the new substation.

## **CHAPTER 2**

### **CONTENTS OF THE PROJECT**





## **CHAPTER 2**

### **CONTENTS OF THE PROJECT**

#### **2.1 Objective of the Project**

No medium-term or long-term economic development plan was formulated for a long time in Suriname following its independence in 1975. Twenty years after independence, the Multi-Annual Development Programme was formulated for the first time with its main emphasis on the improvement of social infrastructure together with the promotion of agriculture and fisheries. Under this Programme, Commewijne District and Saramacca District (comprising the Project Area) lying to the east and west of Paramaribo respectively are expected to benefit from increasing decentralisation, industrial development and the improvement of basic infrastructure following the population increase in the expanding capital region.

The Project is considered to be part of the social infrastructure improvement which is essential to achieve an improved standard of living, stable operation of social and public facilities and industrial development to promote "the development of agriculture and fisheries and the improvement of social infrastructure" as a major policy of the Multi-Annual Development Programme. The objective of the Project is the construction of 33 kV transmission and 12.6 kV distribution grids capable of meeting the power demand upto the year 2006 in order to establish a consistent transmission and distribution grid through the connection of the new grids to the existing 12.6 kV distribution grid to create an efficient power supply system in unelectrified areas and electrified areas where the power supply is unstable despite their proximity to the capital region.

#### **2.2 Basic Concept of the Project**

Suriname has a population of approximately 434,000 (1997 statistics), most of which live on the fertile plains in the north. Some 228,000 people, more than half of the total population, live in the capital, Paramaribo (1997 statistics). While there is still continuous migration to the capital region, the slow progress of social infrastructure development due to the budgetary shortage of the competent authorities has prevented improvement of the local standard of living and industrial development.

The electricity sector in Suriname is run by the EBS. While the EBS supplies electricity to residential areas in the capital region as well as local areas, there is no national transmission grid. The electricity demand in Paramaribo and the surrounding area is met by a diesel power station (rated output: approximately 60 MW) operated by the EBS and purchased electricity

from the hydropower and thermal power stations owned by a private mining company (SURALCO).

The transmission and distribution grid in Paramaribo is uniformly managed by the EBS but the extension of the main 33 kV transmission line to the ever expanding distribution area has made slow progress. As a result, power supply to meet the demand in the suburban areas located in Saramacca and Commewijne Districts uses the 12.6 kV distribution lines crossing either Saramacca River or Suriname River. Power supply to the other 10 scattered user areas is independently conducted by small diesel power generating units.

The consumer areas around Paramaribo, including the northern parts of Saramacca and Commewijne Districts, suffer from a large voltage drop because of the distribution distance involved. In addition, the power supply is unstable and uneconomical because of the distribution capacity shortage. Moreover, some areas are not even electrified. Under these circumstances, the EBS hopes to establish an efficient as well as stable power supply system by means of the new construction of 33 kV transmission lines and substations in these areas to create a consistent grid through their connection to the existing 12.6 kV distribution grid.

Although the Government of Suriname and the EBS have been constructing the transmission and distribution grid with their own funding, the scale of the work has so far been small. The transmission and distribution grid extension project for Saramacca and Commewijne Districts for which a request has currently been made to the Government of Japan was, in fact, previously requested to the EC in 1996. As the EC adopted a policy of loan extension for the project, both sides failed to agree on the loan conditions, resulting in cancellation of the project. The Government of Suriname then reviewed and revised the project as "the Project for Expansion of Transmission and Distribution Grid for the District of Saramacca" with a view to obtaining grant aid and made a request for assistance to the Government of Japan.

The basic concept of the Project is, therefore, expansion of the transmission and distribution grid serving Paramaribo and the surrounding area (EPAR system) to the northern parts of Saramacca and Commewijne Districts to create a sufficient power supply capacity which will constitute important social infrastructure in areas of an expected continuous population increase and industrial development due to expansion of the capital region. To be more precise, substations and the 33 kV transmission grid will be newly constructed together with the procurement of equipment and materials to expand and reinforce the existing 12.6 kV distribution grid for the purposes of improving the local standard of living and ensuring stable socioeconomic activities.

## **2.3 Basic Design**

### **2.3.1 Design Concept**

#### **(1) Natural Conditions**

##### **1) Temperature**

The temperature in the Project Area is constantly high throughout the year, ranging from approximately 22°C (mean annual minimum temperature) to 34°C (mean annual maximum temperature). As the planned substations will be equipped with outdoor use metal-enclosed type switchgear panels, their structure should be carefully designed, including the installation of a ventilation system, so that a temperature increase inside the switchgear due to the high ambient temperature and direct sunlight does not disrupt the operation and maintenance of the equipment because of an increase of the temperature inside the switchgear panels beyond the temperature range for normal operation.

##### **2) Relative Humidity and Rainfall**

The relative humidity is 60 - 90% throughout the year, causing discomfort, particularly during the rainy season. The installation of a space heater will be considered for closed substation and transmission/distribution equipment to prevent condensation due to temperature fluctuations. Rainwater drainage facilities, etc. will be constructed on the substation premises to prevent standing rainwater from disrupting the operation and maintenance of the substation equipment.

#### **(2) Social Conditions**

While a certain level of convenience is expected in Paramaribo, the capital of Suriname, there is a large gap between the capital and local areas in terms of the living infrastructure, highlighted by the low level of infrastructure development in terms of not only the power supply but also the water supply and telecommunications networks in local areas, including the Project Area. Local areas also lack adequate medical facilities, posing an inconvenience for long stays by foreigners. It will, therefore, be necessary for the planning of the substation construction project to incorporate the introduction of many temporary facilities.

#### **(3) Local Construction Industry**

There has been no large-scale construction work in Paramaribo, reflecting Suriname's sluggish economic situation. Even though there are several general construction companies

in the capital region, these are of a relatively small size with some 200 employees, including around 10 engineers.

The number of construction works is even smaller in the Project Area and infrastructure development has been long delayed. Consequently, no local construction company exists, making reliance on a construction company in Paramaribo necessary. Accordingly, it will be necessary for the implementation plan to take the transportation method of the construction equipment and materials from the capital and the introduction of the necessary facilities for the site offices into careful consideration.

Equipment installation work at substations has so far been directly conducted by the EBS in many cases. As a result, there is no private company with the high technical capability and specialist expertise required for the installation, test operation and adjustment of substation equipment. The dispatch of Japanese engineers is, therefore, desirable to supervise the substation equipment installation work under the Project.

#### (4) Use of Local Construction Companies and Materials

##### 1) Use of Local Construction Companies

As described earlier, there are several general construction companies in Paramaribo. As the local procurement of transport vehicles and construction equipment as well as the recruitment of local workers are relatively easy, the subcontracting of the foundation work, exterior work and building work of the control house, etc. to local companies is possible.

Meanwhile, the use of local companies for the installation of substation equipment will be difficult because of their lack of experience of this type of work which requires a high level of technical ability and specialist expertise. Consequently, apart from the recruitment of local works and the procurement of transport vehicles, etc. in Suriname, the dispatch of Japanese engineers will be required together with the possible dispatch of equipment testing and adjustment staff to ensure both schedule and quality control.

##### 2) Use of Locally Available Materials

The project implementation plan should consider the use of locally available materials as much as possible.

**(5) Maintenance Capability of Project Implementation Agency**

The EBS has been directly engaged in the operation and maintenance of the transmission and distribution grid, including 33 kV transmission lines, in the capital region. It also conducts the appropriate operation and maintenance of substations similar to those planned under the Project and these substations are operating in good condition.

Judging from the current maintenance conditions of the existing facilities, EBS operators are believed to have good expertise in regard to the maintenance of common substation as well as transmission/distribution equipment. However, it may be the case that their knowledge of the latest equipment to be installed under the Project is inadequate. Therefore, Japanese engineers will provide OJT (on the job training) on the operation and maintenance of the new substation equipment during the construction/installation period in view of the effective and efficient operation of the new equipment.

As it is possible that the EBS does not fully possess the latest operation and maintenance skills for the installation equipment of the 12.6 kV underwater cable, OJT on the relevant equipment will be provided by engineers of the Japanese cable manufacturer.

**(6) Scope and Grade of Facilities, Equipment and Materials**

The scope for the procurement and installation of the equipment and materials under the Project and their technical grades and level are determined based on the following principles, taking the conditions described in (1) - (5) above into consideration.

**1) Scope of Facilities, Equipment and Materials**

The minimum configuration of the facilities and their specifications should be selected in view of the construction of new substations and 33 kV transmission grid and the procurement of substation and transmission equipment and materials to expand and reinforce the existing 12.6 kV distribution grid with a view to improving the local standard of living, making social welfare facilities active and ensuring stable socioeconomic activities by means of creating an adequate power supply capacity as an important component of the social infrastructure in the northern parts of the Commewijne and Saramacca Districts, where continuous population increase and industrial development are expected to take place due to the expansion of the capital region, by the target year of 2006.

## 2) Grade

Special consideration must be given to the grades of the substation and transmission/distribution equipment to be procured under the Project so that the technical requirements do not exceed the technical capability of the EBS which will be responsible for the operation and maintenance of such equipment after the completion of the Project. The transmission and distribution equipment and materials should be selected to suit the level of installation skill of the EBS as the EBS will be responsible for their installation.

### 2.3.2 Basic Design

#### (1) Preconditions

##### 1) Power Demand Forecast for the Project Area

##### (a) Increasing Trend of Peak Demand in Capital Region (EPAR System)

The EBS, the project implementation agency on the Suriname side, has recorded the peak demand of the EPAR system since 1966. Table 2-3-1 shows the peak demand of the EPAR system for the past 12 years and the trend of the GDP for the same period.

Table 2-3-1 Peak Demand of EPAR System and GDP

|  | 1987 | 1988 | 1989  | 1990  | 1991  | 1992  | 1993  | 1994  | 1995  | 1996  | 1997  | 1998 |
|--|------|------|-------|-------|-------|-------|-------|-------|-------|-------|-------|------|
| Peak Demand of EPAR System (MW)  | 53.3 | 53.8 | 55.1  | 58.5  | 60.3  | 64.2  | 62.1  | 58.9  | 62.1  | 67.9  | 72.6  | 80.7 |
| GDP (excl. Gov. Adm. & Defense) [constant prices (million \$) in 1998] | 891  | 984  | 1,036 | 1,024 | 1,063 | 1,081 | 1,065 | 1,094 | 1,081 | 1,225 | 1,285 | NA   |

Note: Average Annual Increase Ratio

① Peak demand: 1.038 (from 1987 to 1998)

② GDP: 1.039 (from 1987 to 1997)

Source: EBS and CBB

As the above table shows, the average increase rate of the peak demand for the EPAR system for the 12 year period from 1987 to 1998 was 1.038 (approximately 1.04) which was almost identical to the GDP growth ratio of 1.039 (approximately 1.04) from 1987 to 1997.

In general, the annual increase rate of the power demand is in proportion to the GDP growth rate, supporting the trend in Suriname. Accordingly, the annual increase rate used for the power demand forecast for the Project is set at 4%.

(b) Present Load in Project Area

Although the EBS does not possess clear records of the historical changes of the peak demand in the Project Area, it does have records of the peak load of each feeder at substations involved in the Project and operation records of the peak demand by independent power stations. Using these records, the estimated present load in the Project Area is shown in Table 2-3-2.

Table 2-3-2 Present Load in Project Area (1999)

| District   | Substation/Power Station           | Load (kW) | Load (kVA) |
|------------|------------------------------------|-----------|------------|
| Commewijne | Substation A (feeder for Meerzorg) | 2,700.0   | 2,749.6    |
|            | Canawapibo Power Station           | 154.0     | 192.5      |
|            | Alliance Power Station             | 205.0     | 256.3      |
|            | Total                              | 3,059.0   | 3,198.3    |
| Saramacca  | Substation E (feeder for Uitkijk)  | 1,186.6   | 1,396.0    |
|            | Lareco Power Station               | 114.0     | 142.5      |
|            | Total                              | 1,300.6   | 1,538.5    |

Notes: 1. The data on kW and kVA for Substation A and Substation E is based on the operation records of the EBS.

2. The data on power stations is based on operation records (kW) for 1998 and kVA is calculated on the basis of pf = 0.8 (estimate).

Source: EBS

(c) Estimated Load for Waiting Consumers in Project Area

The EBS still has consumers awaiting connection with the EPAR system in the Project Area despite their expressed wish for connection and has estimated the load required to meet this demand. Failure to serve these consumers so far can be attributed to the following.

- The distribution line capacity is too small.
- The distance to reach these consumers is prohibitively long vis-a-vis the construction of a new distribution line.
- Distribution transformers cannot be installed because of the financial situation.

Table 2-3-3 and Table 2-3-4 show the waiting consumer list for the Commewijne District and Saramacca District respectively as of 1997. These tables also show the estimated load demands for 1998 and 1999, calculated on the basis of the annual demand increase rate of 4% as described in (a) above. The figures include the load for new consumers to be served by the newly extended 12.6 kV distribution line under the Project although their areas are currently unelectrified.

The estimated load demand of waiting consumers in the Commewijne District in 1999 is approximately 2,830 kVA (1,920 kVA for consumers awaiting connection with existing distribution lines and 910 kVA awaiting connection with new distribution lines) while the corresponding load in the Saramacca District is approximately 3,780 kVA (1,360 kVA for consumers awaiting connecting with existing distribution lines and 2,420 kVA awaiting connection with new distribution lines).

Table 2-3-3 Load List of Waiting Consumers in Commewijne District

(Unit: kVA)

| Lines                  | Area No.          | Area                         | 1997    | 1998    | 1999    |
|------------------------|-------------------|------------------------------|---------|---------|---------|
|                        |                   | Annual Increase Rate         | -       | 1.04    | 1.04    |
| Existing Lines         | 1                 | Tamanredjo-Welbedacht        | 554.0   | 576.2   | 599.2   |
|                        | 2                 | Oost-West Verbinng           | 30.0    | 31.2    | 32.4    |
|                        | 3                 | Meerzorg                     | 25.0    | 26.0    | 27.0    |
|                        | 4                 | Tamanredjo                   | 25.0    | 26.0    | 27.0    |
|                        | 5                 | Pandit Titakdariweg          | 25.4    | 26.4    | 27.5    |
|                        | 6                 | Marienburgoroj               | 6.0     | 6.2     | 6.5     |
|                        | 7                 | Alkmar                       | 5.0     | 5.2     | 5.4     |
|                        | 8                 | New Amsterdam-Zoelen         | 24.0    | 25.0    | 26.0    |
|                        | 9                 | Comm. Thurkoweg (Commercial) | 830.0   | 863.2   | 897.7   |
|                        | 10                | Canawapibo                   | 246.0   | 255.8   | 266.1   |
| Total (Existing Lines) |                   |                              | 1,770.4 | 1,841.3 | 1,914.9 |
| New Lines              | 11                | Tamanredjo-Meerzorg          | 843.1   | 876.8   | 911.9   |
|                        | Total (New Lines) |                              | 843.1   | 876.8   | 911.9   |
| Grand Total            |                   |                              | 2,613.5 | 2,718.0 | 2,826.8 |

Note: Calculated using EBS data for 1997.



Table 2-3-4 Load List of Waiting Consumers in Saramacca District

(Unit: kVA)

| Lines                  | Area No. | Area                        | 1997    | 1998    | 1999    |
|------------------------|----------|-----------------------------|---------|---------|---------|
|                        |          | Annual Increase Rate        | -       | 1.04    | 1.04    |
| Existing Lines         | 1        | Catharine Area (Commercial) | 415.0   | 431.6   | 448.9   |
|                        | 2        | La Proveyance (Commercial)  | 149.0   | 155.0   | 161.2   |
|                        | 3        | Josi Area (Commercial)      | 55.0    | 57.2    | 59.5    |
|                        | 4        | Tambaredjo (Commercial)     | 332.0   | 345.3   | 359.1   |
|                        | 5        | Dam Malang                  | 1.0     | 1.0     | 1.0     |
|                        | 6        | Vankweg                     | 31.0    | 32.2    | 33.5    |
|                        | 7        | Saramaccaweg                | 29.0    | 30.2    | 31.4    |
|                        | 8        | Groningen                   | 55.0    | 57.2    | 59.5    |
|                        | 9        | Kochweg                     | 25.0    | 26.0    | 27.0    |
|                        | 10       | Kampong Baroe               | 29.0    | 30.2    | 31.4    |
|                        | 11       | Saramacca 3 Sprong          | 137.3   | 142.8   | 148.5   |
| Total (Existing Lines) |          |                             | 1,258.3 | 1,308.6 | 1,361.0 |
| New Lines              | 12       | Santa Maria (Commercial)    | 974.0   | 1,013.0 | 1,053.5 |
|                        | 13       | Paloeleweg                  | 300.0   | 312.0   | 324.5   |
|                        | 14       | Wayamboweg                  | 750.0   | 780.0   | 811.2   |
|                        | 15       | Damboentong                 | 100.0   | 104.0   | 108.2   |
|                        | 16       | Tigerkreek West             | 55.7    | 57.9    | 60.2    |
|                        | 17       | Calcutta                    | 70.3    | 73.1    | 76.0    |
| Total (New Lines)      |          |                             | 2,237.6 | 2,327.1 | 2,420.1 |
| Grand Total            |          |                             | 3,496.0 | 3,635.8 | 3,781.2 |

Note: Calculated using EBS data for 1997.

## (d) Power Demand Forecast for Project Area

Table 2-3-5 shows the power demand forecast results upto the year 2010 based on the annual increase rate of the power demand, the existing peak demand as of 1999 and the demand forecast for waiting consumers, including new consumers, discussed in (a), (b) and (c) respectively.

According to Table 2-3-5, the peak demand in 2006, the target year of the Project, will be approximately 7.9 MVA for the Commewijne District and approximately 7 MVA for the Saramacca District.

Table 2-3-5 Power Demand Forecast for Project Area

(Unit: kVA)

|                       | 1999  | 2000  | 2001  | 2002  | 2003  | 2004  | 2005  | 2006  | 2007  | 2008  | 2009  | 2010  |
|-----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Annual Increase Ratio | -     | 1.04  | 1.04  | 1.04  | 1.04  | 1.04  | 1.04  | 1.04  | 1.04  | 1.04  | 1.04  | 1.04  |
| Commewijne District   |       |       |       |       |       |       |       |       |       |       |       |       |
| Existing Demand       | 3,198 | 3,326 | 3,459 | 3,597 | 3,741 | 3,891 | 4,046 | 4,208 | 4,377 | 4,552 | 4,734 | 4,923 |
| Waiting Consumers     | 2,825 | 2,939 | 3,057 | 3,179 | 3,308 | 3,439 | 3,576 | 3,719 | 3,868 | 4,023 | 4,184 | 4,351 |
| Total Demand          | 6,025 | 6,266 | 6,516 | 6,777 | 7,048 | 7,330 | 7,623 | 7,928 | 8,245 | 8,575 | 8,918 | 9,275 |
| Saramacca District    |       |       |       |       |       |       |       |       |       |       |       |       |
| Existing Demand       | 1,539 | 1,600 | 1,664 | 1,731 | 1,800 | 1,872 | 1,947 | 2,025 | 2,106 | 2,190 | 2,277 | 2,368 |
| Waiting Consumers     | 3,781 | 3,932 | 4,090 | 4,253 | 4,424 | 4,600 | 4,784 | 4,976 | 5,182 | 5,382 | 5,597 | 5,821 |
| Total Demand          | 5,320 | 5,533 | 5,754 | 5,984 | 6,223 | 6,472 | 6,731 | 7,000 | 7,272 | 7,572 | 7,875 | 8,189 |

Note: The target year of the Project is 2006.

## 2) Capacity and Required Number of Pole-Mounted Transformers

It will be necessary to install distribution pole-mounted transformers along the existing distribution lines for waiting consumers and along the new distribution lines to be constructed under the Project Area with a view to stepping down the 12.6 kV main distribution voltage to a lower distribution voltage (220 - 127 V) to serve consumers.

The capacity and number of such pole-mounted transformers to be procured under the Project are basically determined to meet the peak demand in the target year of 2006. However, in view of the requirements of Japan's grant aid scheme, pole-mounted transformers serving commercial and industrial consumers and those serving areas with a small load vis-a-vis consumers awaiting extension of the existing distribution lines are omitted from the scope of the Project as these should be procured by the self-reliant efforts of the Surinamese side.

In regard to the selection of pole-mounted transformers, the three phase four wire system will be employed for the secondary side of the transformer to reduce the voltage drop on the low voltage distribution lines and also to meet a relatively large load.

In regard to the transformer capacity, 50 kVA which is the standard transformer capacity at this time in Suriname will, in principle, be selected while 100 kVA will be selected for areas with a high demand. The required number of transformers is calculated based on the capacity of each distribution line. Table 2-3-6 and Table 2-3-7

show the required number and capacity of pole-mounted transformers for civil use in the Commewijne District and Saramacca District respectively. The pole-mounted transformers to be procured under the Project are those in brackets in these tables, totalling 66 units (50 kVA) and 12 units (100 kVA) (total: 78 units).

Table 2-3-6 Required Number of Pole-Mounted Transformers for Civil Use in Commewijne District

| Lines                  | Area No.          | Area                         | Demand in 2006 (kVA) | Required No. of TRF |         | Remarks          |
|------------------------|-------------------|------------------------------|----------------------|---------------------|---------|------------------|
|                        |                   |                              |                      | 50 kVA              | 100 kVA |                  |
| Existing Lines         | 1                 | Tamanredjo-Welbedacht        | 788.6                | 16 (16)             | 0       | Along trunk road |
|                        | 2                 | Oost-West Verbinng           | 42.7                 | 1                   | 0       |                  |
|                        | 3                 | Meerzorg                     | 35.6                 | 1                   | 0       |                  |
|                        | 4                 | Tamanredjo                   | 35.6                 | 1                   | 0       |                  |
|                        | 5                 | Pandit Tilakdariweg          | 36.2                 | 1                   | 0       |                  |
|                        | 6                 | Marienburgoroj               | 8.5                  | 0                   | 0       | Included in No.5 |
|                        | 7                 | Alkmar                       | 7.1                  | 0                   | 0       | Included in No.5 |
|                        | 8                 | New Amsterdam-Zoelen         | 34.2                 | 1                   | 0       |                  |
|                        | 9                 | Comm. Thurkoweg (Commercial) | 1,181.2              | NA                  | NA      |                  |
|                        | 10                | Canawepibo                   | 350.0                | 7 (7)               | 0       | Along trunk road |
| Total (Existing Lines) |                   |                              | 2,519.8              | 28 (23)             | 0       |                  |
| New Lines              | 11                | Tamanredjo-Meerzorg          | 1,200.0              | 0                   | 12(12)  |                  |
|                        | Total (New Lines) |                              | 1,200.0              | 0                   | 12 (12) |                  |
| Grand Total            |                   |                              | 3,719.8              | 28 (23)             | 12 (12) |                  |

- Notes:
1. The demand in the year 2006 above is calculated in accordance with the waiting consumer list and annual increase ratio (1.04).
  2. NA: transformers for commercial consumers are not considered in the required number of transformers.
  3. Figures in brackets indicate the number of transformers to be procured under the Project.

**Table 2-3-7 Required Number of Pole-Mounted Transformers for Civil Use  
in Saramacca District**

| Lines                  | Area No. | Area                        | Demand in 2006 (kVA) | Required No. of TRF |         | Remarks                |
|------------------------|----------|-----------------------------|----------------------|---------------------|---------|------------------------|
|                        |          |                             |                      | 50 kVA              | 100 kVA |                        |
| Existing Lines         | 1        | Catharine Area (Commercial) | 590.7                | NA                  | NA      | Included in No. 11     |
|                        | 2        | La Proveyance (Commercial)  | 212.1                | NA                  | NA      |                        |
|                        | 3        | Josi Area (Commercial)      | 78.3                 | NA                  | NA      |                        |
|                        | 4        | Tambaredjo (Commercial)     | 472.5                | NA                  | NA      |                        |
|                        | 5        | Dam Malang                  | 1.4                  | 0                   | 0       |                        |
|                        | 6        | Vankweg                     | 44.1                 | 1                   | 0       | District Seat          |
|                        | 7        | Saramaccaweg                | 41.3                 | 1                   | 0       |                        |
|                        | 8        | Groningen                   | 78.3                 | 2 (2)               | 0       |                        |
|                        | 9        | Kochweg                     | 35.6                 | 1                   | 0       |                        |
|                        | 10       | Kampong Baroe               | 41.3                 | 1                   | 0       | Dense residential area |
|                        | 11       | Saramacca 3 Sprong          | 195.5                | 4 (4)               | 0       |                        |
| Total (Existing Lines) |          |                             | 1,791.0              | 10 (16)             | 0       |                        |
| New Lines              | 12       | Sarah Maria (Commercial)    | 1,386.3              | NA                  | NA      |                        |
|                        | 13       | Paloeleweg                  | 427.0                | 9 (9)               | 0       |                        |
|                        | 14       | Wayamboweg                  | 1,050.0              | 21 (21)             | 0       |                        |
|                        | 15       | Damboentong                 | 142.3                | 3 (3)               | 0       |                        |
|                        | 16       | Tigerkreek West             | 79.2                 | 2 (2)               | 0       |                        |
|                        | 17       | Calcutta                    | 100.0                | 2 (2)               | 0       |                        |
| Total (New Lines)      |          |                             | 3,184.8              | 37 (37)             | 0       |                        |
| Grand Total            |          |                             | 4,975.8              | 47 (43)             | 0       |                        |

Note: see Table 2-3-6

## (2) General Plan

Having examined the preconditions described in (1) above, the following conditions are set to determine the scale and specifications of the facilities, equipment and materials for the Project.

### 1) Climatic Conditions

#### (a) Temperature

- Annual mean daily temperature : 26.0°C
- Annual mean monthly minimum temperature : 21.6°C
- Annual mean monthly maximum temperature : 33.7°C

- Extreme minimum temperature : 18.2°C
- Extreme maximum temperature : 36.8°C

(b) Relative Humidity

- Maximum relative humidity : 90.0%

(c) Wind

- Maximum wind velocity (gust) : 28.0 m/sec
- Average wind velocity : 3.0 - 5.0 m/sec
- Hurricanes : none
- Wind direction : dominated by northeasterly trade wind except for July, August and November when a southeasterly wind prevails

(d) Altitude : approx. 5.0 m above sea-level

(e) Wet and Dry Seasons

- Major wet season : May to August
- Major dry season : August to December
- Minor wet season : December to February
- Minor dry season : February to May

(f) Rainfall

- Mean monthly rainfall : 170 - 180 mm
- Monthly rainfall in major wet season : 200 - 300 mm

(g) Earthquakes : no earthquakes are recorded in Suriname

(h) Thunderstorms : 25 times/year on average

2) Soil Survey Findings on Bearing Capacity

A soil survey was conducted by the local soil investigation company at the two planned construction sites for the new substations in May, 1999 and the determined bearing capacity is listed below.

- La Paix Substation Site : 20.0 tons/m<sup>2</sup> (see attached Boring Test Report)
- Sidodadiweg Substation Site : 6.0 ~ 8.0 tons/m<sup>2</sup> (see attached Boring Test Report)

Based on the above findings, the soil investigation company proposed the same type of foundations for both sites as described below.

- Transformer foundations : spread foundations with the foundation bed 1 m below the ground level
- Control room foundations : continuous footings with the foundation bed 1.5 m below the ground level

### 3) Electrical System

- (a) Transmission voltage : 33 kV  
- three phase three wire (rated voltage)
- (b) Distribution voltage : 12.6 kV  
- three phase three wire (rated voltage)  
220 - 127 V  
- three phase four wire
- (c) Frequency : 60 Hz
- (d) Earthing system : 33 kV transmission line  
- effective earthing  
12.6 kV distribution line  
- neutral earthing (direct earth)
- (e) Basic insulation level (BIL) : 33 kV transmission line  
- BIL 170 kV  
12.6 kV distribution line  
- BIL 95 kV
- (f) Line capacity : 33 kV transmission line  
- 10 MVA/line  
12.6 kV distribution line  
- 3 MVA/line

### 4) Use of Existing Facilities

The following existing facilities will be used as part of the Project.

**(a) La Paix Substation Construction Work**

- Transformer foundations
- Control room
- Gate and perimeter fence

**(b) 33 kV Transmission Line Construction Work**

Existing 33 kV transmission line (one of two lines linking existing Substation D with existing Substation E for a distance of some 10.5 km)

**5) Applicable Codes/Standards and Units**

Such international standards as IEC and ISO are referred to for the design of the main functions of the equipment and materials to be procured under the Project. Meanwhile, the following Japanese standards are applied as the manufacturing standards for the equipment and materials. The International System of Units (SI) is used for the units.

- (a) IEC : applied to the main functions of electrical goods in general
- (b) ISO : applied to evaluate the performance of industrial products in general
- (c) JIS : applied to industrial products in general
- (d) JEC : applied to electrical goods in general
- (e) JEM : as above
- (f) JEAC : as above
- (g) JCS : applied to electrical wires and cable
- (h) Technical standards for electrical facilities in Japan :  
applied to electrical work in general
- (i) Other related Japanese and international standards :  
applied to industrial products in general

**(3) Outline of Basic Design**

The outline of the basic design for the Project is shown in Table 2-3-8 based on the basic design concept described in 2.3.1.

Table 2-3-8 Outline of Basic Plan

| Item  | Quantity  |
|---|-----------|
| <b>[Procurement and Installation Plan for Substation Construction Work]</b>   |           |
| 1. New La Paix Substation   |           |
| (1) Main transformer (33/12.6 kV; 10 MVA; with OLTC)  | 1         |
| (2) 33 kV outdoor switchgear panels (including transformer primary panel)   | 3         |
| (3) 12.6 kV outdoor switchgear panels (including transformer secondary panel)   | 7         |
| (4) DC supply system (outdoor cubicle-type)   | 1         |
| (5) SCADA interface cubicle (outdoor-type)  | 1         |
| (6) Indoor remote control and protection panels   | 5         |
| (7) Auxiliary materials for above equipment (cables and conduit pipes, etc.)  | one lot   |
| (8) Outdoor lighting system   | one lot   |
| (9) Necessary civil and building works  | one lot   |
| 2. New Sidodadiweg Substation   |           |
| (1) Main transformer (33/12.6 kV; 10 MVA; with OLTC)  | 1         |
| (2) 33 kV outdoor switchgear panels (including transformer primary panel)   | 3         |
| (3) 12.6 kV outdoor switchgear panels (including transformer secondary panel)   | 7         |
| (4) DC supply system (outdoor cubicle-type)   | 1         |
| (5) SCADA interface cubicle (outdoor-type)  | 1         |
| (6) Indoor remote control and protection panels   | 5         |
| (7) Auxiliary materials for above equipment (cables and conduit pipes, etc.)  | one lot   |
| (8) Outdoor lighting system   | one lot   |
| (9) Necessary civil and building works  | one lot   |
| 3. Existing Substation B (Expansion)  |           |
| (1) 33 kV indoor switchgear panel   | 1         |
| (2) DC supply system  | 1         |
| (3) Indoor remote control and protection panel  | 1         |
| (4) Auxiliary materials for above equipment (cables and conduit pipes, etc.)  | one lot   |
| 4. Existing Substation D (Expansion)  |           |
| (1) 33 kV indoor switchgear panel   | 1         |
| (2) DC supply system  | 1         |
| (3) Indoor remote control and protection panel  | 1         |
| (4) Auxiliary materials for above equipment (cables and conduit pipes, etc.)  | one lot   |
| 5. Spare Parts and Maintenance Tools for above Substations  | one lot   |
| <b>[Procurement Plan for Transmission and Distribution Lines]</b>   |           |
| 1. Materials for 33 kV Transmission Line  |           |
| (1) 33 kV overhead transmission conductors (ACSR)   | 127.0 km  |
| (2) Overhead grounding wires  | 54.5 km   |
| (3) 33 kV lightning arresters (single phase with surge counter)   | 33 pcs    |
| (4) Suspension insulators (common use with 12.6 kV lines)   | 3,123 pcs |
| (5) Pin insulators  | 1,326 pcs |
| (6) Steel poles (15 m)  | 80 sets   |
| (7) Pole fitting materials (for steel and wooden poles)   | one set   |
| (8) Cables for Suriname River Bridge (triplex 95 mm <sup>2</sup> )  | 1,760 m   |
| (9) Cables for Saramacca Bridge section (single core 95 mm <sup>2</sup> tape-armoured)  | 1,080 m   |
| (10) Underground cables (between existing Substation B and Suriname River Bridge; single core 95 mm <sup>2</sup> tape-armoured) | 4,200 m   |
| (11) Substation connection cables (triplex cable 95 mm <sup>2</sup> )   | 210 m     |
| (12) Equipment and materials for installation of above cables   | one lot   |



(cont.)

| Item  | Quantity  |
|---|-----------|
| <b>[Procurement Plan for Transmission and Distribution Lines]</b>                                   |           |
| 2. Materials for 12.6 kV Distribution Line  |           |
| (1) Pole-mounted transformers (50 kVA)  | 66 sets   |
| (2) Pole-mounted transformers (100 kVA)   | 12 sets   |
| (3) 12.6 kV overhead distribution conductors (ACSR)   | 192.8 km  |
| (4) 12.6 kV lightning arresters (single phase)  | 231 pcs   |
| (5) Open fuse cutouts (for distribution pole-mounted transformers)                                  | 165 pcs   |
| (6) Open fuse cutouts (for 12.6 kV distribution line)   | 126 pcs   |
| (7) Pin insulators  | 3,586 pcs |
| (8) Polefitting materials (for wooden poles)  | one lot   |
| (9) Underwater cables (to cross Commewijne River; three core 70 mm <sup>2</sup> )                   | 1,300 m   |
| (10) Underground cables for Saramacca Bridge section (single core 70 mm <sup>2</sup> tape-armoured) | 2,160 m   |
| (11) Substation connection cables (triplex 70 mm <sup>2</sup> )                                     | 390 m     |
| (12) Equipment and materials for installation of above cables including those for underwater cables | one lot   |

#### (4) Substation Construction Plan

The substation construction work to be conducted by the Japanese side under the Project consists of the construction of the new La Paix Substation in the Commewijne District and the new Sidodadiweg Substation in the Saramacca District and the expansion work of the switchgear panels, etc. at existing Substation B and Substation D in Paramaribo. The equipment and materials to be used for the substation construction work will be selected on the basis of the following issues.

##### 1) Basic Issues

In regard to the selection of the equipment and materials required for the construction (expansion) of substations, metal-enclosed switchgear panels will be selected for all four sites in order to shorten the installation period, taking ease of operation, maintenance and equipment safety after the completion of the work into consideration.

##### 2) Capacities of Main Transformers

The capacities of the main transformers to be installed at the La Paix Substation and Sidodadiweg Substation will be based on the rated capacity listed by the IEC standard, taking the estimated peak demand in the target year of 2006 [7,928 kVA for the Commewijne District and 7,000 kVA for the Saramacca District as described in 2.3.2-(1)-1)] and efficient transformer operation (approximately 80% of the rated capacity) into consideration. The planned capacities of the transformers to be installed at these substations are described below.

(a) La Paix Substation

$$\text{Peak demand (7,928 kVA)} \div 0.8 = 9,910 \text{ kVA}$$

Based on the rated capacity listed by the IEC standard, a transformer capacity of 10 MVA which is the nearest capacity above 9,910 kVA on the IEC list is selected.

(b) Sidodadiweg Substation

$$\text{Peak demand (7,000 kVA)} \div 0.8 = 8,750 \text{ kVA}$$

Based on the rated capacity listed by the IEC, a transformer capacity of 10 MVA which is the nearest capacity above 8,750 kVA on the IEC list is selected.

3) Equipment Layout Plan

(a) La Paix Substation

The La Paix Substation will be constructed at Tamanredjo which is the second largest city in the Commewijne District. The EBS secured the substation site some seven years ago and has so far completed not only the site leveling work, gate and boundary fence but has also completed the structure work for the control room building and main transformer. Consequently, the use of the control room building and the existing foundations for main transformer for the Project is planned and the 33 kV outdoor switchgear panels and 12.6 kV outdoor switchgear panels will be installed around the main transformer. The remote control and protection panel will be installed in the control room building (see 2.3.2-(6) - Basic Design Drawing MS-01).

(b) Sidodadiweg Substation

The Sidodadiweg Substation will be located some 39 km west of the centre of Paramaribo, facing the trunk road (East-West Road) linking Suriname with neighbouring Guyana and near the three-way junction leading to Groningen (the District Seat), Coronie and Paramaribo. The diamond-shape site has a size of 40 m x 35 m and was acquired by the EBS in May, 1995 from the Government of Suriname for the Project. Consequently, the site is currently empty land with no existing facilities and it will be necessary for the work to start with site leveling work, including the replacement of soft soil and banking.

As the area along the road is some 40 cm lower than the road surface, making it vulnerable to flooding by rainwater, it is planned to install the substation equipment as far as possible from the road. While the 33 kV outdoor switchgear panels and 12.6 kV outdoor switchgear panels will be placed around the main transformer, the remote control and protection panel will be installed inside the control room building to be constructed under the Project (see 2.3.2-(6) - Basic Design Drawing NS-01).

**(c) Existing Substation B**

Existing Substation B is located at the junction between Martin Luther King Road and Saramacca Canal, some 4 km west of the centre of Paramaribo, and is the central substation of the EPAR system which comprises the transmission and distribution grid in Paramaribo and its surrounding area. One 33 kV switchgear panel to feed power to the La Paix Substation and a related DC supply system as well as a remote control and protection panel will be installed at this substation under the Project. Although the existing building has sufficient space for the DC supply system and the remote control and protection panel, the existing switchgear panel room is too small to accommodate the new switchgear panel, making it necessary for the EBS to expand the switchgear panel room (see 2.3.2-(6) - Basic Design Drawing BS-01).

**(d) Existing Substation D**

Existing Substation D is located some 6 km from the centre of Paramaribo along the East-West Road and is responsible for power distribution to consumers in the northwestern part of Paramaribo as well as for the transmission of 33 kV power to existing Substation E. One 33 kV switchgear panel to feed power to the Sidodadiweg Substation and a related DC supply system as well as a remote control and protection panel will be installed at this substation under the Project. The existing building has sufficient space for the installation of the new 33 kV switchgear panel at the side of the existing panel while the control room has enough space to accommodate both the DC supply system and the remote control and protection panel. However, the dimensions of the door of the switchgear room are too small to bring in the new switchgear panel, making it necessary for the EBS to replace it with a larger door (see 2.3.2-(6) - Basic Design Drawing DS-01).

#### 4) Connection with SCADA System

The EBS plans to connect the existing SCADA system and the new substations to be constructed under the Project for remote control operation from the central control room at the Paramaribo Power Station. The following work will, therefore, be conducted at the new substations to enable the exchange of signals between the SCADA system and the new substations.

##### (a) La Paix Substation and Sidodadiweg Substation

As these substations will be newly constructed, a SCADA interface panel will be installed at the side of the 12.6 kV switchgear panel to allow the exchange of signals required for SCADA operation by the interface panels.

##### (b) Existing Substations B and D

A terminal board will be installed inside the remote control and protection panel to be procured under the Project to allow the exchange of the necessary signals with the existing SCADA interface panel.

#### 5) Construction Plan for Each Substation

The details of the construction plan for each substation to be constructed/expanded under the Project are shown in Tables 2-3-9 through 2-3-12.

- La Paix Substation (New) : Table 2-3-9
- Sidodadiweg Substation (New) : Table 2-3-10
- Existing Substation B (Expansion) : Table 2-3-11
- Existing Substation D (Expansion) : Table 2-3-12

Table 2-3-9 Details of La Paix Substation Construction Plan

| Item/Equipment  | Specifications/Quantity   |
|---|---|
| 1. Construction of Facilities on Premises<br>(1) Building services in control building<br>(2) Outdoor lighting<br>(3) Cable pits and rainwater drainage<br>(4) Foundations for switchgear and others<br>(5) Pit cover for existing transformer foundation | one lot (lighting, power outlets, air-conditioning, plumbing, fire extinguishers, etc.)<br>one lot<br>one lot<br>one lot<br>one lot   |
| 2. Procurement and Installation of Main Transformer<br>(1) Type<br>(2) Rated capacity/voltage<br>(3) Applicable standards<br>(4) Quantity   | Outdoor-type; oil-immersed self-cooling; OLTC<br>10 MVA, 33/12.6 kV, three phase<br>IEC<br>1  |
| 3. Procurement and Installation of 33 kV Switchgear Panel<br>(1) Type<br>(2) Applicable standards<br>(3) Quantity<br><br>(4) Circuit breaker  | Outdoor use metal enclosed-type; air insulation<br>IEC/JIS/JEM<br>33 kV incoming panels: 2<br>33 kV transformer primary panel: 1<br>Vacuum circuit breaker (36 kV, 630 A, 25 kA)  |
| 4. Procurement and Installation of 12.6 kV Switchgear Panel<br>(1) Type<br>(2) Applicable standards<br>(3) Quantity<br><br>(4) Circuit breaker  | Outdoor use metal enclosed-type; air insulation<br>IEC/JIS/JEM<br>12.6 kV switchgear panels: 5<br>12.6 kV transformer secondary panel: 1<br>DC supply system: 1<br>12.6 kV house transformer panel: 1<br>SCADA interface panel: 1<br>Vacuum circuit breaker (15 kV, 630 A, 12.5 kA) |
| 5. Procurement and Installation of Remote Control and Protection Panels<br>(1) Type<br>(2) Applicable standards<br>(3) Quantity   | Indoor use metal enclosed-type; air insulated<br>IEC/JIS/JEM<br>33 kV remote control and protection panels: 2<br>12.6 kV remote control and protection panels: 3  |
| 6. Procurement and Installation of 33 kV Power Cables<br>(1) Type<br><br>(2) Applicable standards<br>(3) Size<br>(4) Quantity<br>(5) Accessories  | 19/33 kV XLPE insulation; PVC sheath; copper conductor cable<br>IEC502<br>CVT 95 mm <sup>2</sup> (three core)<br>20 m<br>One lot of terminal treatment materials, etc.  |
| 7. Procurement and Installation of 12.6 kV Power Cables<br>(1) Type<br><br>(2) Applicable standards<br>(3) Size<br>(4) Quantity<br>(5) Accessories  | 8.7/15 kV XLPE insulation; PVC sheath; copper conductor cable<br>IEC502<br>CV 240 mm <sup>2</sup> (single core)<br>60 m (20 m/phase x three phase)<br>One lot of terminal treatment materials, etc.   |
| 8. Procurement and Installation of Low Voltage Power and Control Cables, etc.<br>(1) Low voltage cables<br><br>(2) Control cables<br><br>(3) Quantity<br>(4) Miscellaneous materials for cabling work   | 600 V XLPE insulation; PVC sheath; copper conductor cable<br>600 V XLPE insulation; PVC sheath; copper cable conductor<br>one lot<br>one lot (including grounding work materials)   |

Table 2-3-10 Details of Sidodadiweg Substation Construction Plan

| Item/Equipment  | Specifications/Quantity   |
|---|---|
| <b>1. Construction of Facilities on Premises</b><br>(1) Construction of control building<br>(2) Building services for control building<br>(3) Outdoor lighting<br>(4) Foundations for transformer, switchgear panels, etc.<br>(5) Cable pits and rainwater drainage | One lot (lighting, power outlets, air-conditioning, plumbing fire extinguishers, etc.)<br>One lot<br>One lot<br>One lot   |
| <b>2. Procurement and Installation of Main Transformer</b><br>(1) Type<br>(2) Rated capacity/voltage<br>(3) Applicable standards<br>(4) Quantity  | Outdoor-type; oil-immersed self-cooling; OLTC<br>10 MVA, 33/12.6 kV, three phase<br>IEC<br>1  |
| <b>3. Procurement and Installation of 33 kV Switchgear Panel</b><br>(1) Type<br>(2) Applicable standards<br>(3) Quantity<br>(4) Circuit breaker   | Outdoor use metal enclosed-type; air insulation<br>IEC/JIS/JEM<br>33 kV incoming panels: 2<br>33 kV transformer primary panel: 1<br>Vacuum circuit breaker (36 kV, 630 A, 25 kA)  |
| <b>4. Procurement and Installation of 12.6 kV Switchgear Panel</b><br>(1) Type<br>(2) Applicable standards<br>(3) Quantity<br>(4) Circuit breaker   | Outdoor use metal enclosed-type; air insulation<br>IEC/JIS/JEM<br>12.6 kV switchgear panels: 5<br>12.6 kV transformer secondary panel: 1<br>DC supply system: 1<br>12.6 kV house transformer panel: 1<br>SCADA interface panel: 1<br>Vacuum circuit breaker (15 kV, 630 A, 12.5 kA) |
| <b>5. Procurement and Installation of Remote Control and Protection Panels</b><br>(1) Type<br>(2) Applicable standards<br>(3) Quantity  | Indoor use metal enclosed-type; air insulated<br>IEC/JIS/JEM<br>33 kV remote control and protection panels: 2<br>12.6 kV remote control and protection panels: 3  |
| <b>6. Procurement and Installation of 33 kV Power Cables</b><br>(1) Type<br>(2) Applicable standards<br>(3) Size<br>(4) Quantity<br>(5) Accessories   | 19/33 kV XLPE insulation; PVC sheath; copper conductor cable<br>IEC502<br>CVT 95 mm <sup>2</sup> (three core)<br>20 m<br>One lot of terminal treatment materials, etc.  |
| <b>7. Procurement and Installation of 12.6 kV Power Cables</b><br>(1) Type<br>(2) Applicable standards<br>(3) Size<br>(4) Quantity<br>(5) Accessories   | 8.7/15 kV XLPE insulation; PVC sheath; copper conductor cable<br>IEC502<br>CV 240 mm <sup>2</sup> (single core)<br>60 m (20 m/phase x three phase)<br>One lot of terminal treatment materials, etc.   |
| <b>8. Procurement and Installation of Low Voltage Power and Control Cables, etc.</b><br>(1) Low voltage cables<br>(2) Control cables<br>(3) Quantity<br>(4) Miscellaneous materials for cabling work  | 600 V XLPE insulation; PVC sheath; copper conductor cable<br>600 V XLPE insulation; PVC sheath; copper cable conductor<br>one lot<br>one lot (including grounding work materials)   |

Table 2-3-11 Details of Existing Substation B Expansion Plan

| Item/Equipment  | Specifications/Quantity  |
|---|--|
| 1. Procurement and Installation of 33 kV Switchgear Panel<br>(1) Type<br>(2) Applicable standards<br>(3) Quantity<br>(4) Circuit breaker<br>(5) Isolator                      | Indoor use metal enclosed-type; air insulation<br>IEC/JIS/JEM<br>33 kV incoming panel: 1<br>Vacuum circuit breaker (36 kV, 630 A, 26 kA)<br>Motor operated (3P-36 kV, 600 A) |
| 2. Procurement and Installation of Remote Control and Protection Panel<br>(1) Type<br>(2) Applicable Standards<br>(3) Quantity  | Indoor use metal enclosed-type; air insulation<br>IEC/JIS/JEM<br>1   |
| 3. Procurement and Installation of DC Supply System<br>(1) Type<br>(2) Battery<br>(3) Rated capacity/voltage<br>(4) Accessories   | Indoor use metal enclosed and independent-type<br>NiCd alkaline-type<br>10 AH/DC 110 V<br>One lot  |
| 4. Procurement and Installation of Low Voltage Power and Control Cables, etc.<br>(1) Low voltage cables<br>(2) Control cables<br>(3) Miscellaneous materials for cabling work | 600 V XLPE insulation; PVC sheath; copper conductor cable<br>600 V XLPE insulation; PVC sheath; copper conductor cable<br>one lot (including grounding work materials)       |

Table 2-3-12 Details of Existing Substation D Expansion Plan

| Item/Equipment  | Specifications/Quantity  |
|---|--|
| 1. Procurement and Installation of 33 kV Switchgear Panel<br>(1) Type<br>(2) Applicable standards<br>(3) Quantity<br>(4) Circuit breaker<br>(5) Isolator                      | Indoor use metal enclosed-type; air insulation<br>IEC/JIS/JEM<br>33 kV incoming panel: 1<br>Vacuum circuit breaker (36 kV, 630 A, 26 kA)<br>Motor operated (3P-36 kV, 600 A) |
| 2. Procurement and Installation of Remote Control and Protection Panel<br>(1) Type<br>(2) Applicable Standards<br>(3) Quantity  | Indoor use metal enclosed-type; air insulation<br>IEC/JIS/JEM<br>1   |
| 3. Procurement and Installation of DC Supply System<br>(1) Type<br>(2) Battery<br>(3) Rated capacity/voltage<br>(4) Accessories   | Indoor use metal enclosed and independent-type<br>NiCd alkaline-type<br>10 AH/DC 110 V<br>One lot  |
| 4. Procurement and Installation of Low Voltage Power and Control Cables, etc.<br>(1) Low voltage cables<br>(2) Control cables<br>(3) Miscellaneous materials for cabling work | 600 V XLPE insulation; PVC sheath; copper conductor cable<br>600 V XLPE insulation; PVC sheath; copper conductor cable<br>one lot (including grounding work materials)       |

**(5) Equipment Procurement Plan for 33 kV Transmission Line and 12.6 kV Distribution Line**

The points described below must be carefully noted in regard to the procurement of equipment and materials for the 33 kV transmission line and 12.6 kV distribution line under the Project.

**1) Basic Issues**

**(a) Easy and Safety of Maintenance**

The specifications of the equipment and materials to be selected for the Project must not exceed the levels of existing transmission and distribution equipment with which EBS engineers are familiar in order to ensure easy and safe maintenance.

**(b) Economy**

In order to ensure an economical design which meets the requirements of Japan's grant aid scheme, the specifications of the equipment and materials should be standardized based on international standards as much as possible. The variety of equipment should be minimised to increase the interchangeability of equipment.

**(c) Exchangeability with EBS Equipment**

The specifications of the equipment and materials to be procured by the Japanese side should be compatible as much as possible with existing equipment and materials in the possession of or use by the EBS in view of uniform management.

**2) Basic Construction Plan for Transmission and Distribution Lines**

**(a) Route Selection**

The routes of the transmission and distribution lines have been jointly decided with EBS engineers for each district following desk work, field reconnaissance and confirmation of tentative routes prepared based on survey maps, existing transmission and distribution route maps and topographical maps, all of which were obtained from the EBS. The basic routes selected are shown in 2.3.2-(6) - Basic Design Drawings GG-02 and GG-03.

**(b) Types of Electric Poles**

Of the equipment and materials to be used under the Project, wooden poles are the only item available locally. As Suriname is endowed with tropical rain forests, a sufficient quantity of raw wood called Bruin Heart is locally available for the



production of wooden poles. While wooden poles of upto 11 m in length are treated for insect control and are preserved, tar is simply applied to the terminal section of any wooden pole of a longer length due to the absence of insect control and preservation facilities for long logs in Suriname. This means that as the 11 m long wooden poles for the 12.6 kV distribution line are treated for insect control and are preserved, they have sufficient strength and life expectancy. Meanwhile, the 15 m long wooden poles for the 33 kV transmission line are inadequate in terms of their strength and life expectancy because of the lack of proper treatment. Consequently, the following poles subject to strong tensile force among the poles for the 33 kV transmission line will be made of steel and will be procured in Japan.

- ① Dead end poles constantly subject to tensile force
- ② Angle poles (15° or more) constantly subject to tensile force
- ③ Inter-connecting poles subject to strong tensile force at the time of construction work

Privately-owned electric pole processing factories in Suriname are generally of a small-scale and the EBS controls the number of factories where it places its orders depending on the scale of the planned procurement. As the procurement of a large number of wooden poles (approximately 1,370 poles) will be necessary for the transmission and distribution lines to be constructed under the Project, the EBS should make the necessary budgetary appropriation as soon as possible to ensure the prompt delivery of poles by the factories to which orders are placed. The scope of the wooden pole procurement to be conducted by the EBS will include such miscellaneous materials as kicking block, number plates, warning signs, etc.

All equipment and materials other than wooden poles which are required for the construction of the new 33 kV transmission line and new 12.6 kV distribution line under the Project will be included in the scope of procurement for the Japanese side.

(c) Types of Bare Conductors for Overhead Transmission and Distribution Lines

ACSR (Aluminum Conductor Steel Reinforced) will be used as the bare conductors for the transmission and distribution lines to be constructed under the

Project to ensure compatibility with the standard EBS specifications and also to avoid any maintenance complications due to the use of different conductors.

**(d) Installation of Pole-Mounted Transformers**

Pole-mounted transformers will be installed to step down from 12.6 kV to 220 - 127 V for distribution to consumers. The transformer details are already described in 2.3.2-(1)-2).

**(e) Protection from Lightning**

33 kV and 12.6 kV arresters will be installed at the dead ends of the relevant transmission and distribution lines and pole-mounted transformer installation points to protect the substation equipment and pole-mounted transformers from lightning damage. Also, overhead ground wires will be installed above the 33 kV transmission line.

**(f) Installation of Open Fuse Cutouts**

In accordance with EBS standard, open fuse cutouts will be installed every 2 km and at the branching points of the distribution lines and also at the primary side (12.6 kV side) of each pole-mounted transformer for the maintenance and inspection of the distribution lines.

**(g) Specifications for Suriname River Crossing Cable at Suriname Bridge**

33 kV triplex cable will be installed on cable hangers which will be installed beside the maintenance footpath for the Suriname Bridge. These hangers should be provided by the Surinamese side.

**(h) 33 kV Underground Cable (Between Existing Substation B and Suriname River Bridge)**

As there are many existing distribution lines along the planned 33 kV transmission route from existing Substation B to the Suriname River Bridge, little space remains for a new overhead line. Moreover, should an overhead line be employed, there will be many crossing points with existing lines, suggesting a high level of risk vis-a-vis the construction work. Consequently, underground cable will be used for this section.

The 33 kV cable in question will be XLPE insulated single core cable with tape armor in view of easy workability and the prevention of external damage after installation and conduits will be employed at road crossing sections.

**(i) Underwater Cable Specifications**

The underwater cable to be used to cross Commewijne River will be “XLPE insulated 3 core cable with single layer galvanized steel (6mm dia with bitumen compound) armor underwater cable” to ensure sufficient resistance to tensile force at the time of cable installation work and to avoid damage due to the anchors of vessels, dumped materials, etc. At river bank sections, the cable will be laid inside cast iron protective pipe (20 m each for each side) in view of further protection.

**(j) Cable Specifications for Saramacca Bridge Section**

The Saramacca Bridge which crosses some 210 m of Saramacca River lies between existing Substation D and the Sidodadiweg Substation to be constructed under the Project. As this bridge is made of steel with sufficient strength to support large vehicles, the planned 33 kV transmission line and 12.6 kV distribution line under the Project will be placed in a cable tray to be attached to the piers of the bridge.

The 33 kV cable and 12.6 kV cable in question will be XLPE insulated single core cable with tape armor in view of easy workability and the prevention of external damage after laying.

**(k) Cables for Substation Feeder Lines**

The specifications of the cable to connect the 33 kV switchgear panel and 33 kV overhead transmission line on the premises of the new substations to be constructed under the Project will be the same as those of the cable to be used between the main transformer and the 33 kV switchgear panel at these substations in order to ensure exchangeability and easy workability as well as procurement. This cable will be XLPE insulated three core cable and protected by protective piping.

### 3) Quantities of Equipment and Materials Required for the Project

#### (a) Bare Conductor for Overhead Transmission and Distribution Lines

The quantities of the conductors required for the overhead transmission and distribution lines are calculated by multiplying the total length of these lines on the drawings by 1.13 which represents the margin. (The conductor length for the down sections from the overhead grounding wires are considered to be part of the polefitting materials.)

The margin used (13%) is based on figures commonly used in Japan and is the total of 3% for wire dip, 3% for work surplus and 7% for supplementary quantity.

The resulting procurement quantities of overhead transmission and distribution conductors and overhead grounding wires for the Project are shown in Table 2-3-13.

Table 2-3-13 Procurement Quantity of Conductors for Overhead Transmission and Distribution Lines and Grounding Wires

(Unit: km)

| Item                         | Commewijne District | Saramacca District | Total |
|------------------------------|---------------------|--------------------|-------|
| 1. 33 kV Transmission Line   | 56.0                | 71.7               | 127.7 |
| 2. 12.6 kV Distribution Line | 38.8                | 154.0              | 192.8 |
| 3. Overhead Grounding Wire   | 18.7                | 35.8               | 54.5  |

#### (b) Pole-Mounted Transformers

The total number of pole-mounted transformers to be procured under the Project is 78 as determined by the selection process described in 2.3.2-(1)-2) and is broken down as shown in Table 2-3-14.

Table 2-3-14 Procurement Quantity of Pole-Mounted Transformers

(Unit: set)

| Item                            | Commewijne District |         | Saramacca District |         | Total  |         |
|---------------------------------|---------------------|---------|--------------------|---------|--------|---------|
|                                 | 50 kVA              | 100 kVA | 50 kVA             | 100 kVA | 50 kVA | 100 kVA |
| For Existing Distribution Lines | 23                  | -       | 6                  | -       | 29     | -       |
| For New Distribution Lines      | -                   | 12      | 37                 | -       | 37     | 12      |
| Total                           | 23                  | 12      | 43                 | -       | 66     | 12      |

(c) Arresters

Arresters will be installed to protect the pole-mounted transformers and high voltage cables. The number of installation places is, therefore, 88 places (55 for pole-mounted transformers, 11 places for 33 kV cable and 22 places for 12.6 kV cable) and the procurement quantities are 33 pcs for 33 kV (11 places x three phase) and 231 pcs for 12.6 kV (77 places x three phase).

(d) Open Fuse Cutout

Open fuse cutout switches will be installed at 2 km intervals along the distribution lines and at each branching point for line inspection and maintenance purposes. They will also be installed at the primary side (12.6 kV side) of each pole-mounted transformer to protect the transformer and also for the opening of a circuit at the time of inspection and maintenance. The procurement quantity of open fuse cutout switches is shown in Table 2-3-15.

Table 2-3-15 Procurement Quantity of Open Fuse Cutout

| (Unit: pcs)                             |                     |                    |       |
|---|---------------------|--------------------|-------|
| Purpose of Use                          | Commewijne District | Saramacca District | Total |
| Maintenance of Distribution Lines       | 18                  | 108                | 126   |
| Protection of Pole-Mounted Transformers | 42                  | 123                | 165   |
| Total                                   | 60                  | 231                | 291   |

Note: The above quantities include work spares (10%).

(e) Insulators and Pole-fitting Materials

In addition to the materials listed above, work-related materials also include insulators and pole-fitting materials. As the required quantities of these items for the Project are detailed in Basic Design Drawings PL1 through PL4 (Material Lists by Electric Pole Type), the quantities given in these drawings must be procured. In principle, the poles will be erected at an interval of some 100 m for the 33 kV transmission line (pole length 15m) and at an interval of some 80 m for the 12.6 kV distribution line (pole length 11m and 15m) in accordance with the relevant EBS standards. As individual erection sites may have special requirements depending on the type of pole (angle pole and branching pole), careful determination of the exact locations will be necessary to finalise the procurement quantity. Insulators, pole-fitting materials and other work-related

materials will include 10% or at least one set equivalent for work supply in addition to the design quantities in consideration of damage, etc. during the work.

Based on the above considerations, the procurement quantities of insulators and electric poles by type are shown in Table 2-3-16 and Table 2-3-17 respectively.

Table 2-3-16 Procurement Quantity of Insulators

(Unit: piece)

| Type of Insulator                            | Commewijne District | Saramacca District | Total |
|--|---------------------|--------------------|-------|
| Suspension Insulator (For 33 kV and 12.6 kV) | 984                 | 2,139              | 3,127 |
| 33 kV Pin Insulator                          | 545                 | 781                | 1,326 |
| 12.6 kV Pin Insulator                        | 513                 | 3,073              | 3,586 |

Note: The above quantities include work spares (10%).

(f) Electric Poles

The quantity of steel poles to be procured by the Japanese side and the wooden poles to be procured by the Surinamese side for the Project are shown in Table 3-3-17.

Table 3-3-17 Quantity of Electric Poles

| Procuring Side | Type of Pole              | Commewijne | Saramacca | Total |
|----------------|---------------------------|------------|-----------|-------|
| Japan          | 33 kV Steel Poles (15 m)  | 38         | 50        | 88    |
| Suriname       | 33 kV Wooden Poles (15 m) | 150        | 222       | 372   |
|                | 12 kV Wooden Poles (15 m) | 2          | 34        | 36    |
|                | 12 kV Wooden Poles (11 m) | 44         | 828       | 872   |
| Total          |                           | 234        | 1,134     | 1,368 |

Table 2-3-18 Purpose of Use and Procurement Quantity by Pole Type

(Unit: poles)

| Pole Type | Material | Purpose of Use                                  | Pole Length (m) | Commewijne | Saramacca | Total |
|-----------|----------|---|-----------------|------------|-----------|-------|
| DM3       | Wood     | 33 kV Intermediate Pole                         | 15              | 44         | 82        | 126   |
| SM3       | Steel    | 33 kV Light Angle Pole                          | 15              | 12         | 10        | 22    |
| HM3       | Steel    | 33 kV Heavy Angle Pole                          | 15              | 2          | 2         | 4     |
| BM3       | Steel    | 33 kV Section Pole                              | 15              | 3          | 13        | 16    |
| OM3       | Steel    | 33 kV Terminal Pole                             | 15              | 2          | 2         | 4     |
| DMC       | Wood     | 33 kV and 12.6 kV Combination Intermediate Pole | 15              | 106        | 140       | 246   |
| SMC       | Steel    | 33 kV and 12.6 kV Combination Light Angle Pole  | 15              | 5          | 19        | 24    |
| HMC       | Steel    | 33 kV and 12.6 kV Combination Heavy Angle Pole  | 15              | 3          | -         | 3     |
| BMC       | Steel    | 33 kV and 12.6 kV Combination Section Pole      | 15              | 9          | -         | 9     |
| OMC       | Steel    | 33 kV and 12.6 kV Combination Terminal Pole     | 15              | 2          | 4         | 6     |
| YM1       | Wood     | 12.6 kV T-off Pole                              | 11              | 14         | 24        | 38    |
| DM1       | Wood     | 12.6 kV Intermediate Pole                       | 11              | 3          | 632       | 635   |
| SM1       | Wood     | 12.6 kV Light Angle Pole                        | 11              | -          | 51        | 51    |
| HM1       | Wood     | 12.6 kV Heavy Angle Pole                        | 11              | 2          | 23        | 25    |
| BM1       | Wood     | 12.6 kV Section Pole                            | 11              | -          | 18        | 18    |
| OM1       | Wood     | 12.6 kV Single Terminal Pole                    | 11              | 5          | 3         | 8     |
| LM1       | Wood     | 12.6 kV Open Fuse Cutout Pole                   | 11              | 6          | 36        | 42    |
| TM1       | Wood     | 12.6 kV Transformer Pole                        | 11              | 14         | 41        | 55    |
| DM1D      | Wood     | 12.6 kV Dual Intermediate Pole                  | 15              | -          | 26        | 26    |
| SM1D      | Wood     | 12.6 kV Dual Light Angle Pole                   | 15              | 2          | 2         | 4     |
| HM1D      | Wood     | 12.6 kV Dual Heavy Angle Pole                   | 15              | -          | 2         | 2     |
| OM1D      | Wood     | 12.6 kV Dual Terminal Pole                      | 15              | -          | 4         | 4     |

Note: The above quantities include work spares (10%).

(g) Suriname River Crossing Cable at Suriname bridge

The following quantity of Suriname River crossing cable at the Suriname Bridge is required in view of the bridge length, distance to the connection point with the overhead transmission line and work margin (10%)

33 kV triplex cable (95 mm<sup>2</sup>): 1,760 m

(h) Underground Cable (From Existing Substation B to Suriname River Bridge)

Underground cable of 1,600 m in length for each phase, including work supply (approximately 10%) will be procured for the some 1,450 m section between the

new 33 kV switchgear panel at existing Substation B and the connection point with the 33 kV cable at the Suriname River Bridge. The total procurement quantity is calculated below.

33 kV XLPE insulated single core with tape armor cable (95 mm<sup>2</sup>): 4,800 m (1,600 m x three phase)

(i) Underwater Cable

The procurement quantities of the 12.6 kV underwater cable to cross Commewijne River are shown in Table 2-3-19, taking into consideration the width and water depth of each river, the side drift of the cable at the time of installation, the distance between the river bank and the cable connection point and work margin (20%).

Table 2-3-19 Procurement Quantity of Underwater Cable

| Item   | Specifications   | Quantity |
|--|--|----------|
| 12.6 kV underwater cable to cross Commewijne River | 8.7/15 kV XLPE steel wire sheathed 66 mm underwater cable (three core 70 mm <sup>2</sup> ) | 1,300 m  |
| Accessories for the above                          | Cable end treatment materials; cast iron cable protection pipe (sprite pipe)               | one lot  |

Note: The sprit pipe will cover 40 m (20 m x both banks) of the 12.6 kV cable.

The equipment and materials listed in Table 2-3-20 will be procured for the Project in connection with the underwater cable installation work. Similarly, the Surinamese side will procure the equipment and materials listed in Table 2-3-21. The Surinamese side will conduct the work using the relevant equipment and materials.



Table 2-3-20 Equipment and Materials for Underwater Cable Installation Work  
(Japanese Portion)

| No        | Descriptions   | Specification/Purpose  | Q'ty | Unit |
|-----------|--|--|------|------|
| <b>1.</b> | <b>On the Barge</b>  |  |      |      |
| (1)       | Sheave   | R3m, L1m×W1.5m   | 1    | set  |
| (2)       | Drum Jack  | 40 tons  | 1    | set  |
| (3)       | Drum Break   | Iron belt breaking system equipment, lever block type                    | 1    | set  |
| (4)       | Cable Guide Pipe   | Steel pipe   | 1    | set  |
| (5)       | Dynamic Break  | Lever braking system equipment, lever block type                         | 1    | set  |
| (6)       | Hauling Machine  | Caterpillar type, 1 ton, 15kW  | 1    | set  |
| (7)       | AC Generator   | 75kVA, Diesel, Potable type, for winch, etc.                             | 1    | set  |
| (8)       | Winch  | 5 ton, 30kW, double drum, winding wire length 500m                       | 1    | set  |
| (9)       | Wire Rope  | Dia. 20mm, with spare wire   | 1000 | m    |
| (10)      | Grease   | 100g/can   | 10   | can  |
| (11)      | Cable Length Counter   | For measurement of cable length  | 1    | set  |
| <b>2.</b> | <b>On the Ground</b>   |  |      |      |
| (1)       | Tube buoy  | φ 1000mm, every 2 m at landing portion of 250 m length including spare   | 150  | pcs  |
| (2)       | Cable Roller   | W225×L305mm, every 3 m at landing portion of 400m length including spare | 100  | sets |
| (3)       | Air Compressor   | For tube buoy, 10HP, 7kg/cm <sup>2</sup> , Tank Volume 200 l             | 1    | set  |
| (4)       | Winch  | Engine type, 1 ton   | 1    | set  |
| (5)       | Anchor Wire  | For winch above, logs will be used as anchor                             | 30   | m    |
| (6)       | Swivel   | For preventing wire twisting   | 2    | pcs  |
| <b>3.</b> | <b>Equipment For Surveying of embedded parts before Installation</b> |  |      |      |
| (1)       | Buoy   | φ 300mm, every 100m including spare                                      | 18   | pcs  |
| (2)       | Rope for buoy  | Nylon type, 10mm   | 160  | m    |
| (3)       | Metal Detector   | For embedded parts   | 1    | set  |

**Table 2-3-21 Equipment and Materials for Underwater Cable Installation Work  
(Suriname Side)**

| No        | Descriptions  | Specification/Purpose                           | Q'ty    | Unit  |
|-----------|---|---|---------|-------|
| <b>1.</b> | <b>Boat and Vehicle</b>   |   |         |       |
| (1)       | Barge   | Approx. L 20m x W 8m, with spats                | 1       | unit  |
| (2)       | Tug Boat  | 1000HP or 1500HP                                | 4       | unit  |
| (3)       | Small working boat with outboard engine                           | For pulling the floating cable                  | 5       | unit  |
| (4)       | Diver's boat  | For diver                                       | 1       | unit  |
| (5)       | Crane   | For rigging, approx. 45ton                      | 1       | unit  |
| (6)       | Crane   | For loading cable drum, approx. 100ton          | 1       | unit  |
| (7)       | Boat for caution  | For watching the traffic on the river           | 1       | unit  |
| (8)       | Diving equipment  | Compressor, air tank, chamber, etc.             | 5       | set   |
| (9)       | Lorry   | For transporting the equipment                  | 1       | unit  |
| <b>2.</b> | <b>Rigging Equipment</b>  |   |         |       |
| (1)       | Container for equipment   | For keeping the tool, air compressor            | 1       | pcs   |
| (2)       | Fairleads   | For laying up the barge                         | 4       | set   |
| (3)       | Trailing cable  | 4 cores, 22mm <sup>2</sup>                      | 100     | m     |
| (4)       | Switching board   | For distribution of power supply                | 1       | set   |
| (5)       | Anchor  | For laying up the barge, 1 ton                  | 3       | pcs   |
| (6)       | Anchor  | For laying up the barge, 3 ton                  | 2       | pcs   |
| <b>3.</b> | <b>Cabling Laying Equipment</b>                                   |   |         |       |
| (1)       | Wire  | For pulling the cables at land portion          | 250     | m     |
| (2)       | Hawser  | For pulling the floating cables                 | 100     | m     |
| (3)       | Nylon Sling   | For pulling the floating cables                 | 5       | pcs   |
| (4)       | Rope  | Nylon, dia. 24mm(approx.), for floating cables  | 200     | m     |
| (5)       | Rope  | Nylon, dia. 10mm(approx.), for tube bouy        | 600     | m     |
| (6)       | Surveying equipment   |   | 1       | set   |
| (7)       | General tool  | Cutter pillar, knife, gasoline torch, etc.      | 1       | set   |
| <b>4.</b> | <b>Equipment for Cable Cutting and Jointing</b>                   |   |         |       |
| (1)       | Electric Wire with reel   |   | 1       | set   |
| (2)       | Rotary Band Saw   | Stainless blade                                 | 1       | pc    |
| (3)       | Stainless Band  | Metal fitting (100sets) with band (30m x 2)     | 1       | lot   |
| (4)       | Waterproofing Cap   | φ 36mm, PVC                                     | 15      | pcs   |
| (5)       | Tape  | NP-S (polyethylene) Tape and FB-W (rubber) Tape | Each 10 | rolls |
| (6)       | Iron Wire   |   | 25      | m     |
| (7)       | Joint Equipment   | Compressing machine                             | 1       | set   |
| <b>5.</b> | <b>Equipment for Survey of embedded parts before Installation</b> |   |         |       |
| (1)       | Measure Tape  | Approx. 50m                                     | 1       | pc    |
| (2)       | Measure Tape  | Approx. 200m                                    | 1       | pc    |

(j) Cable for Saramacca Bridge Section

The following quantity of XLPE insulated single core with tape armor cable will be procured, including that for work supply (10%), for the section between the overhead distribution points near both banks of the Saramacca Bridge (Table 2-3-22).

Table 2-3-22 Procurement Quantity of Cable for Saramacca Bridge Section

| Type                       | Specifications   | Quantity  |
|----------------------------|--|---|
| 33 kV transmission cable   | 33 kV XLPE insulated single core with tape armor cable (95 mm <sup>2</sup> )   | 1,080 m (360 m/phase x three phase)             |
| 12.6 kV distribution cable | 12.6 kV XLPE insulated single core with tape armor cable (70 mm <sup>2</sup> ) | 2,160 m (360 m/phase x three phase x two lines) |

(k) Cables for Substation Feeder Lines

The cables listed in Table 2-3-23 will be procured to cover the distance between the 33 kV switchgear panel and the connection point with the 33 kV overhead transmission line and the distance between the 12.6 kV switchgear panel and the connection point of the 12.6 kV overhead distribution line, including work supply (10%), for each substation.

Table 2-3-23 Procurement Quantity of Cable for Substation Connection

| Item  | Commewijne District | Saramacca District |               | Total |
|---|---------------------|--------------------|---------------|-------|
|   | La Paix SS          | Sidodadiweg SS     | Existing SS-D |       |
| 33 kV triplex cable (95 mm <sup>2</sup> )   | 50 m                | 90 m               | 70 m          | 210 m |
| 12.6 kV triplex cable (70 mm <sup>2</sup> ) | 170 m               | 220 m              | -             | 390 m |

(6) Basic Design Drawings

The Basic Design Drawings for the Project are listed below.

1) General Drawings

| Drawing No. | Title   | Scale     | Remarks |
|-------------|---|-----------|---------|
| GG-01       | Electric Power Network (EPAR System) Diagram  | -         |         |
| GG-02       | Electric Power Network in Commewijne District | 1:160,000 |         |
| GG-03       | Electric Power Network in Saramacca District  | 1:160,000 |         |

2) La Paix Substation

| Drawing No. | Title   | Scale | Remarks                       |
|-------------|---|-------|-------------------------------|
| MS-01       | Equipment Layout                                    | 1:200 | Including control room layout |
| MS-02       | Single-Line Diagram                                 | -     |                               |
| MS-03       | Outline of 33 kV Outdoor Type Switchgear Panel      | 1:50  |                               |
| MS-04       | Outline of 12.6 kV Outdoor Type Switchgear Panel    | 1:50  |                               |
| MS-05       | Outline of Indoor Type Control and Protection Panel | 1:30  |                               |

3) Sidodadiweg Substation

| Drawing No. | Title   | Scale | Remarks                       |
|-------------|---|-------|-------------------------------|
| NS-01       | Equipment Layout                                    | 1:250 | Including control room layout |
| NS-02       | Single-Line Diagram                                 | -     |                               |
| NS-03       | Outline of 33 kV Outdoor Type Switchgear Panel      | 1:50  |                               |
| NS-04       | Outline of 12.6 kV Outdoor Type Switchgear Panel    | 1:50  |                               |
| NS-05       | Outline of Indoor Type Control and Protection Panel | 1:30  |                               |

4) Existing Substation B

| Drawing No. | Title  | Scale      | Remarks |
|-------------|--|------------|---------|
| BS-01       | Equipment Layout in the Existing Switchgear Building                     | 1:100      |         |
| BS-02       | Single-Line Diagram of 33 kV Switchgear Panel                            | -          |         |
| BS-03       | Outline of 33 kV Indoor Type Switchgear and Control and Protection Panel | 1:30, 1:40 |         |

5) Existing Substation D

| Drawing No. | Title  | Scale      | Remarks                                 |
|-------------|--|------------|---|
| DS-01       | General Layout   | 1:300      | Between switchgear panel and No. 1 Pole |
| DS-02       | Equipment Layout in the Existing Switchgear Building                     | 1:100      | Inside existing building                |
| DS-03       | Single-Line Diagram of 33 kV Switchgear Panel                            | -          |   |
| DS-04       | Outline of 33 kV Indoor Type Switchgear and Control and Protection Panel | 1:30, 1:40 |   |

6) Assembly Drawing for 33 kV Transmission Line and 12.6 kV Distribution Line

| Drawing No. | Title  | Scale | Remarks |
|-------------|--|-------|---------|
| PL-1        | Materials List for 33 kV Single Transmission Line  | -     |         |
| DM3         | 33 kV Intermediate Pole                            | -     |         |
| SM3         | 33 kV Light Angle Pole                             | -     |         |
| HM3         | 33 kV Heavy Angle Pole                             | -     |         |
| BM3         | 33 kV Section Pole                                 | -     |         |
| OM3         | 33 kV Terminal Pole                                | -     |         |
| PL-2        | Material List for 33kV and 12.6kV Combination Line | -     |         |
| DMC         | 33 kV and 12.6 kV Combination Intermediate Pole    | -     |         |
| SMC         | 33 kV and 12.6 kV Combination Light Angle Pole     | -     |         |
| HMC         | 33 kV and 12.6 kV Combination Heavy Angle Pole     | -     |         |
| BMC         | 33kV and 12.6kV Combination Section Pole           | -     |         |
| OMC         | 33 kV and 12.6 kV Combination Terminal Pole        | -     |         |
| PL-3        | Material List for 12.6kV Single Distribution Line  | -     |         |
| YM1         | 12.6 kV T-off pole                                 | -     |         |
| DM1         | 12.6 kV Intermediate Pole                          | -     |         |
| SM1         | 12.6 kV Light Angle Pole                           | -     |         |
| HM1         | 12.6 kV Heavy Angle Pole                           | -     |         |
| BM1         | 12.6 kV Section Pole                               | -     |         |
| OM1         | 12.6 kV Terminal Pole                              | -     |         |
| LM1         | 12.6 kV Open Fuse Cutout Pole                      | -     |         |
| TM1         | 12.6 kV Line Distribution Transformer Pole         | -     |         |
| PL-4        | Material List for 12.6 kV Dual Distribution Line   | -     |         |
| DM1D        | 12.6 kV Dual Intermediate Pole                     | -     |         |
| SM1D        | 12.6 kV Dual Light Angle Pole                      | -     |         |
| HM1D        | 12.6 kV Dual Heavy Angle Pole                      | -     |         |
| OM1D        | 12.6 kV Dual Terminal Pole                         | -     |         |

7) Cabling at Suriname River Bridge Section

| Drawing No. | Title                 | Scale | Remarks |
|-------------|-----------------------|-------|---------|
| ALT-CD3-01  | 33kV Cable Route Plan | -     |         |

8) Underwater Cabling

| Drawing No. | Title   | Scale | Remarks |
|-------------|---|-------|---------|
| CD1-52      | 12.6 kV Underwater Cable Plan in Commewijne River | -     |         |

9) Cabling at Saramacca Bridge Section

| Drawing No. | Title                            | Scale | Remarks |
|-------------|----------------------------------|-------|---------|
| SD3-60      | Cabling Plan on Saramacca Bridge | -     |         |








|  |          |         |          |           |
|--|----------|---------|----------|-----------|
| THE PROJECT FOR THE EXPANSION OF<br>TRANSMISSION AND DISTRIBUTION<br>GRID FOR THE DISTRICTS COMMEWIJNE AND SARACACCA |          |         |          | SCALE     |
| コモウエイナ地区送配電網図<br>ELECTRIC POWER NETWORK IN COMMEWIJNE DISTRICT   |          |         |          | 1/160,000 |
|  |          |         |          | DWG No.   |
|  |          |         |          | GG-02     |
| DATE   | DESIGNED | CHECKED | APPROVED | REVISION  |
| 24 July, 99  | Uyeno    | m lc    | NSCOW    |           |
| YACIHO ENGINEERING CO., LTD<br>TOKYO JAPAN   |          |         |          |           |







|   |          |         |          |          |                              |
|---|----------|---------|----------|----------|------------------------------|
| THE PROJECT FOR THE EXPANSION OF<br>TRANSMISSION AND DISTRIBUTION<br>GRID FOR THE DISTRICTS COMMELINE AND SARAMACCA |          |         |          |          | SCALE                        |
|   |          |         |          |          | 1/200                        |
| 機器配置図 [ラバ変電所]   |          |         |          |          | DWG No.                      |
| EQUIPMENT LAYOUT [LA PAIX SUBSTATION]   |          |         |          |          | MS-01                        |
| DATE  | DESIGNED | CHECKED | APPROVED | REVISION |                              |
| 10 Aug. '99   | Yoo      | M. K.   | Y. K.    |          |                              |
| YOO   |          |         |          |          | YACHIYO ENGINEERING CO., LTD |
|   |          |         |          |          | TOKYO JAPAN                  |



|  |          |         |          |          |
|--|----------|---------|----------|----------|
| THE PROJECT FOR THE EXPANSION OF<br>TRANSMISSION AND DISTRIBUTION<br>GRID FOR THE DISTRICTS COMMEWIJNE AND SARAMACCA |          |         |          | SCALE    |
|  |          |         |          | ---      |
| 単線結線図 [ラバ変電所]<br>SINGLE LINE DIAGRAM [LA PAIX SUBSTATION]  |          |         |          | DWG No.  |
|  |          |         |          | MS-02    |
| DATE   | DESIGNED | CHECKED | APPROVED | REVISION |
| 10 Aug. '99  | Urmo     | meib    | ABO      |          |
| YACHIYO ENGINEERING CO., LTD<br>TOKYO JAPAN  |          |         |          |          |

