5 DATABASE

5.1 Reconstruction of GIS/Database System

Based on the request of INGRH for the reconstruction of the destroyed database, particularly the database for well inventory management, JICA has procured a set of hardware/software (GIS software included) not only for data retrieval and well data arrangement, but also for the construction of various databases.

The activities for the construction of the GIS/Database in Cape Verde was carried out twice in Stage 1 of the First Phase. The first time was in June where the activities mainly involved confirming the request from the Cape Verdean side and discussing what type of hardware/software is required. Surveys were also carried out on the existing database system and their use, as well as on spare parts availability in Cape Verde.

Based on the series of discussions and understandings reached pertaining to the operation of the present database in INGRH and in Cape Verde, equipment and material supply procedures were undertaken in Japan. The selected hardware/software were delivered to INGRH in November, after a 1 month operation test was completed in Japan.

The following shows the major software/hardware procured.

Software:

-GIS (Microimages) TNTmipsD40, Printer Driver P8, Digitizer Driver X3

-Operation System (Microsoft) Windows95 (English version)

-Database (Microsoft) Fox Pro

-Office 97 Pro (Microsoft) Word, Excel, Access

Hardware:

-Personal Computer (COMPAQ) DESKPROEP (Desktop/Minitower)

-17" Monitor (COMPAC) Presario5610 (Minitower)

-Total Memory 128 MB

-SCSI Board For connection of JAZ drive

-External back-up memory (IOMEGA) JAZ drive

-Printer (HP) with Cable Deskjet1120C

-Digitizer (CALCOMP) A2 size

-UPS (APC) Smart-UPS700 (Max 700VA/450W)

-Transformer 100-220V

The second set of activities were carried out in Cape Verde: :1) compilation of the operation manual, 2) confirmation of items/number of delivered materials, 3) hardware assembly, and confirming whether the operation system and applications are properly set up and functioning, and 4) explanations on the use and functions of GIS, and training through actual database construction work using GIS on geographical information such as contour line, river system, roads, etc.

Although the training period was limited to only one week due to delays in the custom's office release of the material in November, technology transfer (i.e. hardware operation, database soft conversion) was smoothly carried out, particularly due to the counterpart personnel's adeptness in handling computer hardware.

Thus, database reconstruction for well inventory and management was arranged in INGRH. The system is not only useful for well inventory management but for various database construction as well.

5.2 Database of Hydrogeology and Water Supply Facility

Various data were accumulated and assessed during the course of the Study. The data pertained to hydrogeology (result of pumping test, groundwater level, water quality, result of georesistivity soundings, water quality, etc.) and water supply (village population, ratio of supply service coverage, existing supply facility, etc.), and was input in Microsoft Excel for the construction of a new database. If these data are to be used for the construction of a new database, the only requirement would be converting the files from Excel to the newly installed software.

6 DEVELOPMENT PLANS

6.1 Groundwater Development Plan

6.1.1 Concept for Water Supply Source Development Plan

The water supply project in Santiago Island aims to meet the water demand of the whole island by developing water resources by every possible means. The projected water demand in 2005 for domestic use is about 3600 m³/day (except for Praia City), assuming a unit supply amount of 20 ℓ /c/d for the rural area and 50 ℓ /c/d for the household connection system, in accordance with the Master Plan.

Of the 205 communities in Santiago Island (5 towns and 200 villages, excluding Praia City), 45 have relatively satisfactory water supply service levels, as a result of sufficient and favorable water sources, i.e. springs, boreholes. In the remaining 158 villages, however, the residents (except those who live near the source) are inconvenienced by domestic water sources mainly due to their inaccessibility or a shortage thereof.

In order to cope with such situation, the best way to solve the problem is to increase the intake points and supply volume by constructing wells at villages where groundwater development is technically and economically possible, and also by effectively using water from springs with sufficient yield and in accessible location.

The development of new water sources in certain villages will favorably benefit other villages as well, not because they will be using water from these new sources but because they can acquire more water from the tank lorry as a result of the reduction in the number of tank lorry water distribution recipients (tank lorries distribute water to villages without water sources).

Groundwater development by borehole construction should seriously consider safe pumpage to avoid disturbing the water balance or water quality deterioration — problems encountered in some areas due to excessive groundwater exploitation. Accordingly, allocation of water (for domestic and irrigation use) should be taken into due consideration, especially since irrigation in most areas in Santiago Island usually require twice to four times as much as the amount of water required for domestic use. The national policy on the introduction of sound irrigation techniques should also be accelerated in such areas with little or scarce development potential, particularly in Santa Cruz Municipality (Santa Cruz Basin A and B) and the central-western part of Santa Catarina (Santa Catarina Basin) where the water balance analysis indicated negative development potential.

As for the use of spring water, the effective use of spring yields should be taken into consideration. Since many of the springs are inconveniently located, i.e. very remote

or in places with elevations much lower than the residential area, only less than 2% of the estimated total yield of the springs is practically used for domestic purposes. It is, therefore, important to equip the sources with a collection and conveyance system and/or pumping facility for effective use of the spring sources.

It might be difficult to attain the project goal within a short period. However, the phased implementation of the groundwater resource development project may be the shortest way to extend the water supply services to the entire island of Santiago, except for a few villages where project implementation is quite difficult due to steep geographic features that make vehicular (e.g. construction vehicles, water transportation vehicles) passage impossible.

Candidate villages have been selected for the project and hydrogeological surveys were carried out, and the results were further analyzed to evaluate the availability of water sources in every village concerned. If groundwater resources are available in the area, the depth and location of the well to be drilled, as well as the volume of water to be pumped from the well were determined according to the hydrogeological structure of the area and projected village population. In case groundwater development is impossible or extremely difficult to implement, spring water utilization was taken into consideration. In villages where the development of either water sources is futile, water transportation/distribution services were adopted.

A unit supply amount of 20 ℓ /c/d is the target of the development regardless of water source type.

6.1.2 Groundwater Development Plan

Although groundwater balance is apparently negative in some parts of Santiago Island, as discussed in 4-4, groundwater development is still possible as long as there is rain to recharge the resources. The amount of water for rural water supply is far smaller than the annual recharge, therefore, groundwater development for rural water supply is possible depending on zonal characteristics.

Based on this viewpoint and assuming that groundwater resource development will be carried out for no other reason but the aforementioned, the plan was established according to the following premise:

- a) Target year: End of every project phase
 Year 2003 for the first project phase
- b) Village selection criteria for the first project phase:
 - Villages without public water supply sources and, therefore, urgently needing the project
 - Villages where groundwater resource development is technically feasible (borehole wells and springs)

 Villages where pumping facility operation cost is expected to be comparatively low (not so deep water table for the well, and only slight elevation difference for springs)

c) Required water volume:

The required water volume is to be determined by multiplying the assumed unit supply amount (20 liters/capita/day) by the projected population (2003) of each village. The total amount of groundwater to be developed for each village will be considered the volume to be developed in the first project phase.

d) Facilities to be constructed:

For the villages where borehole well is to be constructed:

- Borehole well with submersible motor pump
- Diesel engine generator or solar energy system with control house/shed
- · Reservoir tank at the villages where existing reservoir is not enough
- 2 sets or more of public faucets (2 taps each), pipelines connected to reservoir tank

For villages using existing spring sources:

- Transmission pipeline installation from the source to the community center
- Reservoir tank and 2 sets of public faucets (2 taps each)
- Intake box equipped with centrifugal pump and control house (to be built at the village where the spring is at an elevation lower than the community

e) Beneficiaries:

Beneficiaries from this first project phase are not limited to the population of selected villages. Water developed in these villages will not be delivered elsewhere, however, other recipients of the tank lorry water delivery services can avail of the water volume formerly appropriated for the target villages of this first project phase.

6.2 Project Formulation Plan

6.2.1 Project Implementation

As discussed in 3-3-4, the Study has revealed that 160 villages (78% of the 205 communities in Santiago Island) will eventually require the implementation of the project. Of these 160 villages, 38 are excluded from the future project formulation plan by the following reasons:

- Improvement projects are ongoing in or being planned for 33 villages
- Topographic features of 5 villages significantly hampers project implementation

The remaining 122 villages are divided into 2 groups, "A" and "B", according to urgent need for the project:

Group A: 59 villages urgently requiring the implementation of the project

Group B: 63 villages also requiring the project but of less urgency than Group A

Since it is almost impossible to cover these villages in one project, it is necessary to sub-divide Group A and B into 4 groups as shown below. The phased implementation of the project has been established according to this group classification.

Group A-1: First phase 34 villages

Group A-2: Second phase 29 villages

(27 from Group A, and 3 from B)

Group B-1: Third phase 29 villages from Group B

Group B-2: Fourth phase 30 villages from Group B

A concrete project formulation plan for the first phase and tentative plans from the second phase onwards have been established in this Study program. Plans formulated for the second phase onwards are tentative on the assumption that the implementation of the first phase might incur changes in current conditions.

6.2.2 Project Formulation Plan

One of the major reasons observed in this study program as to why water supply services in the area are inefficient is the absolute shortage of intake points and water source volume.

The selection of sites for the first project phase (*Group A-1*), therefore, was based on the availability of water sources for development, and the following, which were adopted to ensure the effective implementation of the project:

- Population scale (over 200, to ensure effective project implementation and in view of the establishment of a community based management system.)
- Accessibility for facility construction works

Based on the above criteria, 34 villages were selected and tabulated in Table 6-1. These villages have no public borehole wells, and acquire water from the tank lorry or from nearby springs and dug wells.

Table 6-1 Selected 34 Villages for First Phase Project

No. ZONA	1	Population			Amount 98	Consumption 1998	Water Demand 200
20111	CENSUS 1990	1998	2003		r/d) :	(<i>((/</i> 3)	(Pop.x 202/c/d)
arrafal			:				
9 Curral Velho	324	369	400		8.0	2,952	8,000
19 Trás os Montes	396	349	379		25.0	8,725	7,580
Sub-total	720	718	779	*	16.3	11,677	15,580
São Miguel		:	:				
4 'Chā de Ponta	554	700	757				15,140
10 Monte Bode	277	316	343		(6.0)	(1,896)	4
11 Monte Pousada	402	598	649		11.0		12,980
18 Ribeirão Milho	197	340	367				7,340
Sub-total	1,430	1,954	2,116	*	11.0	6,578	42,320
Santa Catarina		·				i	
12 Boa Entradinha	531	603	658				13,160
13 Bombardeiro	1,023	1,180	1,291				25,820
15 Chā de Tanque	1,013	1,174	1,287				25,740
19 Entre Picos de Reda	295	342	375				7,500
36 Pata Brava	299	345	377				7,540
40 Pingo Chuva	369	417	457				9,140
43 Ribeira da Barca	1,557	1,809	1,987				39,740
47 Saltos Acima	670	769	840			<u> </u>	16,800
57 Covão Grande	492	568	621	:		<u> </u>	12,420
60 Jalalo Ramos	534	607	662			<u> </u>	13,240
63 Leitãozinho	492	561	612			<u> </u>	12,240
Sub-total	7,275	8,375	9,167			I	183,340
Santa Cruz	7,213	0,313	2,101	<u> </u>			103,340
17 Ribeirão Almaço	174	260	283		(2.0)	(520)	5,660
25 Achada Costa	303	360	403		4.7	1,692	8,060
27 Fundura	219	282	311		8.1	2,273	
31 Levada	218	310	336	<u> </u>	2.2	682	6,726
Sub-total	914	1,212	1,333	4	4.9	-	26,666
São Domingos	717	1,212	1,333	<u> </u>	4.7	4,647	20,00
	538	650	732	<u>!</u>	12.3	7,995	14.64
	701	833					i
8 Praia Baixo	255	303	928 337	 	4.5 6.2	3,749	
11 Achada Mitra				<u>i</u> !		1,879	
13 Banana	266	316	351	<u>:</u>	5.9	1,864	+
15 Dacabalaio	210	250	270	<u> </u>	14.6	3,650	
16 Fonte Almeida	698	830	939	<u> </u> 	4.5	3,735	
20 Mato Afonso	386	460	512	1	12.2		
24 Po de Saco	168	210	241	<u> </u>	(9.7)		
27 Rui Vaz	812	956	1,057	<u> </u>	5.8		
Sub-total	4,034	4,808	5,367		7.4	34,029	107,34
Praia				ļ		-	1
10 São Tomé	230	256	274	· 		<u> </u>	5,48
18 Belém	447	495	529			<u> </u>	10,58
27 Santana	906	1,008	1,078	 			21,56
28 Tronco	186	206	221			-	4,47
Sub-total	1,769	1,965	2,102	<u> </u>	:		42,04
Total	16,142	19,032	20,864	*	8.3	56,931	417,28

6.3 Proposed Water Supply Facility

6.3.1 Facility Design for the First Project Phase (34 villages)

The following 4 types of facility are proposed for the 34 villages. Thirty two (32) of these villages will be constructed with borehole wells as a source, while the effective use of existing springs is considered for the remaining 2 villages.

- Type 1: One borehole well and one reservoir tank connected to the source by transmission pipeline are to be constructed at or near the center of the village, or at a different location in consideration of water availability. If the capacity of the existing tank is deemed satisfactory, the reservoir tank will not be constructed. A submersible motor pump will be used to pump up water to the reservoir tank. A diesel engine generator or solar energizing system will be used to operate the pump; the use of the latter will be limited to places with a total pump head of less than 100m.

 2 sets of public faucets each attached with 2 taps will be constructed, one beside the tank and the other 200-300m away.
- Type 2: I borehole well and multiple tanks (for reservoir/distribution and pressure deducing tank) and long distribution pipes are to be laid from the tank all the way to some sets of public faucets.
- Type 3: Intake facility is to be improved at the location of the spring, and the transmission line will be laid to the center of the village. Water is transmitted to the village by natural flow. I reservoir tank and 2 sets of public faucets are to be installed at the center of the village.
- Type 4 Intake facility is to be constructed at the spring with the installation of a centrifugal pump to pump up water to the new reservoir tank to be installed at the center of the village. 2 sets of public faucets with 2 taps each are to be constructed in the community.

The type and dimension of the facilities proposed for the 34 villages are tabulated in Table 6-2, and the facility basic design drawings are in Fig. 6-1 to Fig. 6-9.


6.3.2 Project Cost


For construction of above facilities including 5 sets of solar energizing system, the cost is estimated at 5.78 million US\$, including 20 % of administrative and engineering cost.


With procurement of equipment and materials such as drilling machine, supporting vehicles and others related to facility maintenance, the total project cost approximates 9.78 million US Dollar.


A -1	
of Group	
ŏ	
lages	
34	
르.	
ed facility in 34 vil	
Plane	
ble 6-2	
ble	


						Well		-		Transmissic	n Pipe Line		San Frad	Kese	LVOIT	Reservoir Public Faucer	aucet
No. ZONA		Рорициюн		Water Demand 2003	Target Depth	SWL	Pumping Kate Pump Level	Pump Level	Elevation Difference	Pipe	Pipe Distance	Head Loss	Pump Head	Ensoting	,	Satisfied	
	Chingles rate	8661	2003	(Pop.a 20rio/d)	(CL -m)	(CL -m)	(mi//min)	(CL-m)		(mm)	(m)	(m)	(m)				
Tarratal	720	718	179	15,580					****							. = .	
9 Curral Velho	324	369	8	8,000	250	500	0.02	216.0	20.0	S	001	1.527	241.5	Ļ			r4
19 Trás os Montes	38.	340	370	7,580	84	110	0.02	124.0	5.0	8.	ឧ	0.305	129.3	. 40m³		-	· -
São Miguel	1,430	1,954	2,116	42,320					!								Ĭ -
4 Cha de Ponta	8%	8	757	15,140	220	8	0.03	196.0	600	80	83.	4.851	196.0	ိုင်ဝ		:	C+
10 Monte Bode	77.2	316	343	98'9	8	186	100	176.0	10.0	8	8	0.212	1×6.2		ie.		6)
11 Mowe Pousada	402	365	\$	12,980	500	52	0.03	174.0	0.0	S.	\$.	1.617	195.6		, w		F1
18 Ribeirto Milho *	16 1	35	190	7.340	001	9	0.02	76.0	20.0	50	8	1.527	97.5		15m³		۲.
Santa Catarina	7,275	8,375	6,167	183,340		_											
12 Boa Entradenha	331	609	859	13,160	130	110	, £0.03	124.0	-80.0	80	8	9.701	124.0	40m²		-	; ;
13 Bombardeiro	1,023	1,180	1,291	25,820	011	8	0.05	10.0	-150.0	8	89	5.061	1050		30m		C1
15 Cha de Tanque	1,013	1,174	1,287	25,740	<u>8</u>	8	0.05	76.0	30.0	80	82	0.843	×.96.	W09	1	-	`
19 Entre Picos de Reda	295	342	37.5	7,500	288	170	0.02	184.0	0.09	\$0	718	10,966	255.0	40m³	1	 !	ы
36 Pala Brava	38	345	377	7,540	Spring				-60.0	8	150	2.291	0.0		15m3	: : : !	F1
40 Pingo Chuva	369	417	457	9,140	8	5	0.02	84.0	0.0	S.	8	0.305	84.3	-0-	•		
43 Ribeira da Barca	1,557	1,809	1,987	39,740	FBE-170	25	800	40.0	20.05	901	238	15,612	105.6	.2m	:	: — : —	
47 Sattos Avima	029	769	840	16,800	150	130	20:0	136.0	0.0	50	ጸ	1.01	137.1	40m³	Σ' !		
57 Covão Crande	ફ	\$9S	621	12,420	07.1	140	0.03	156.0	30.0	98	700	2 295	156.0	40m ²		-	;
60 Jalato Ramos *	ž	£0\$	\$62	13,240	8	20	0.03	36.0	30.0	\$0	92	1.617	8.7.k	40m3		: .	. N
63 Leitaozinho	492	19%	612	12,240	021	8	0.03	116.0	-150.0	8	900	19.402	116.0	40m		! !	. (4
Santa Cruz	914	1,212	1,333	26,660			-										r
17 Ribeirdo Almaço	174	260	283	099'5	140	04	10:0	156.0	0.00	\$	200	75%.0	2.6.8	:	LOI		Ç1
25 Achada Costa	363	390	403	8,060	85	130	0.02	4.0	36.0	\$	£4.	1.87	181.9	40m2		: ·	: 61
27 Fundura	219	282	311	6,220	001	110	0.01	124.0	50.0	ક	§.	2.118	176.1	11m	-	Ţ: 	
31 Levada	218	310	336	6,720	From Achada Costa	a Costa								.0m			F4
São Domingos	4.034	4,808	5,367	107,340					 								[
6 Milho Branco	538	059	732	14,640	120	100	0.03	116.0	.30.0	œ Q	1500	4.917	116.0	22m³			
8 Prata Baixo	[0]	833	928	18,560	2	8	300	36.0	40.0	æ	1400	7.814	36.0	22m3		-	
11 Achedo Mitra	235	303	337	6,740	98.	120	0.01	136.0	20.0	8	02	0.042	156.0	22m)			C1
13 Banana	506	316	351	7,020	981	8	0.01	116.0	20.0	œ.	004	1.695	137.7	33m³		-	
15 Dacabalaio	210	250	270	5,400	951	8	0.01	116.0	\$0.0	8	300	0.847	166.8	, m0x			C4
16 Ponte Almeida	869	ж30	636	18,780	180	150	0.0	164.0	10.0	891	<u>8</u>	0.188	174.2	22m³			e1
20 Mato Afonso	386	460	512	10,240	120	8	0.02	104.0	0'09	Š	200	3.055	167.1	23m2		-	
24 Po de Saco	168	210	241	4,K20	150	100	0.01	116.0	-20.0	8.	200	0.847	116.0		10m,		C+
27 Kui Vaz	812	956	1,057	21,140	150	120	40.0	136.0	80.0	180	700	1.318	217.3	33m			
Praia	1,769	1,965	2,102	42,040						-			-				Γ
10 São Tomé	230	256	274	5,480	- 001	99	0.01	76.0	0.08-	8	1.00	5.931		[Qm]	:	-	
18 Belem	447	495	\$25	10,580	120	8	0.02	0.401	20.0	8	32	•	127.1	10m		-	_
27 Santana	8	1,00%	1,078	21,560	Spring				80.0	8	82	3,055	i		.0a		C1
28 Tronco	186	206	223	4,420	160	140	0.01	156.0	30.0	50	95		186.2		10m³		C4
TOTAL	16,142	19,032	20,864	417,280 i	_									-			
 Solar enacized system can be applied. With the system, O/M cost 	n be applied.	With the s	vstem, O/M		will become lower by omitting pump operation cost.	y omitting pu	mp operation	cost.									1























6.3.3 Facilities for the Villages for the 2nd to 4th Project Phase

The execution of the phase I project will provide some villages with improved water transportation services, as the reduction of the recipients of the tank lorry delivery services would lighten up the delivery service schedule, depending of course on the number of villages that will be covered by the phase I project (26 in total: 2 in Tarrafal, 3 in Sao Miguel, 8 in Santa Catarina, 3 in Santa Cruz, 8 in Sao Domingo, and 2 in Praia).

Since the rotation of the transportation service is not analyzed in this study program, it is difficult to point out at the moment which of the villages will indirectly benefit from the phase 1 project. Therefore, the tentative plan for the remaining 88 villages was prepared based on existing conditions.

The facilities and services recommended to improve the existing water supply conditions in the 88 villages are tabulated in Table 6-3 (Facilities for *Group A-2* and *Group B* Villages), and detailed below.

Water supply sources/means:

- Borehole well or spring:
 - At villages where groundwater development is technically and economically feasible. "Well" in the table refers to the possibility of groundwater development by well construction, while "Spring" indicates the possibility of the development of springs as water supply sources.
- Tank lorry:
 In villages where water resource development is infeasible, tank lorry transportation/delivery services will be improved. In the table, "tank lorry" is used to indicate such villages.

Water supply facilities:

- As in Group A-1, at least 2 sets of public faucets will be installed to reduce the
 waiting time when fetching water and to make water fetching possible any time
 of the day. Since all villages will be installed with faucets, no particular
 notation is made in the table.
- Construction of reservoir tank:

A reservoir tank will be constructed in villages having none. If the existing tank capacity is not enough, a new tank with a capacity exceeding the daily water demand (projected population times 20 liters) will be constructed. "Tank 20m3" is used in the table to indicate the villages where this facility will be constructed.

The basic design of the facilities will be similar to those for *Group A-1* (phase 1 project). The number of facilities proposed for the 90 villages by Municipality is presented in the following table 6-4.

Table 6-3 Planed Facility in 29 Villages (Phase II)

No.	ZONA	Grouping	Po	pulation		Supply Amount 1998	Consumption 1998	Water Demand 2003	Propo	sed Supply F	scility
			CENSUS 1980	1,993	2,009	(t/c/d)	(f/d)	(Pop.x 200/e/d-	Water Source	Reservoir tanl	Public Fauc
	rafal			ļ						:	1
São	Miguel	: ::==::::::::::::::::::::::::::::::::		<u>.</u>		: 4	: L	i :			
3	Casa Branca	A-2	711	750	814	8.0	6,000	16,280	Well	20m³	2
9	Moto Correia	A-2	371	424	507	11.0	4,664	10,14 0	Tank Lorry	Existing	2
13	Pedra Barro	A-2	335	382	458	15.0	5,714	9,160	Well	Existing	2
14	Pedra Serrado	A-2	485	553	663	10.3	5,714	13,260	Well	Existing	2
17	Principal	B-1	1,277	1,457	1,750	10.0	14,570	35,000	Spring		1
	Sub-total		3,179	3,566	4,192		36,662	83,840			[
Sar	nta Catarina										
14	Chả đe Lagoa	A-2	476	552	676		;	13,520	Tank Lorry	Existing	2
20	Figueira das Naus	A-2	1,091	1,257	1,531			30,620	Tank Lorry	Existing	2
35	Palha Carga	A-2	1,248	1,444	1,765	:	i	35,300	Tank Lorry	Existing	2
44	Ribeirão Isabel	A-2	519	598	728		: :	14,560	Tank Lorry	15 m ³	2
48	Sedeguma	A-2	302	321	389		<u> </u>	7,780	Spring		i .
49	Serra Malagueta	A-2	478	552	673	 -		13,460	Tank Lorry	Existing	2
·	Burbur	A-2	253	289	349		[6,980	Spring		<u> </u>
64	Manhanga	A-2	235	268	325	ļ — — — — — — — — — — — — — — — — — — —]	6,500	Spring	<u> </u>	i
65	Mato Fortes	A-2	201	230	277	 	İ	5,540	{	10 m ³	2
66	Mato Limão	A-2	246	281	340		<u> </u>	6,800	Tank Lorry	10 m ³	2
33	Mato Gege	B-1	1,196	1,380	1,683			33,660		i	F
t	Picos Acima	B-I	1,499	1,730	2,107		ļ	42,140	i	-	·
1	Sub-total		7,744		10,843	<u> </u>	 	216,860		†	1
Sai	nta Cruz						<u> </u>			†	<u> </u>
5	Boaventura	A-2	477	522	616	4.6	2,401	12,320	Tank Lorry	15 m ³	2
6	Boca Larga	A-2	289	289	349	1.5	434	+	1		·
	Matinho	A-2	579	1,141	1,484	2	2,282	29,680	Spring	 	<u> </u>
14	Rebelo	A-2	147	196	233	17.8	3,489	· · · · · · · · · · · · · · · · · · ·	Tank Lorry	Existing	2
18	Ribeirão Boi	A-2	678	641	754	1.9	1,218	+	Tank Lorry	Existing	Existing
22	São Cristóvão	A-2	603	700	835	4.7	3,290	<u> </u>		Existing	2
	Serelho	A-2	i			<u> </u>	1,817		Tank Lorry		Existing
	Sub-total		3,207	3,955	4,805		14,931		·		<u> </u>
Sã	o Domingos	 								1	İ
4	Chão de Coqueiro	A-2	195	213	242	8.1	1,725	4,840	Tank Lorry	Existing	Existing
	Praia Formosa	A-2	621			+	5,624			Existing	Existing
14	Chaminé	A-2	119				1,980	. 2	Tank Lorry	Existing	2
	Mendes Faleiro Cabra		101			+	1,770		Tank Lorry	· 	Existing
	Sub-total		1,036			·	11,10			<u> </u>	
Pra	ala	 			-,-	 	1	<u> </u>	 	 	
	São Martinho Grande	A-2	861	960	1,117	.]	 	22,34	O Spring		-
	Sub-total		861		·	·	 	22,340		1	
	Total	 	 	18,606		:	1	449,340	+	1	30

Table 6-4 Planed Facility In 29 Villages (Phase III)

No.	ZONA	Grouping	P	opulation	1	Supply Amount 1998	Consumption 1998	Water Demand 2003	Propo	sed Supply Fa	icility
			CENSUS 1990	1,998	2,009	(€/c/d)	(f/d)	(Pop.x 207/c/d)	Water Source	Reservoir tank	Public Fauc
Tarrafa				:		!			· · · · · · · · · · · · · · · · · · ·		
4 Achae	la Meio	B-1	172	196	235	19.0	3,724	4,700	Tank Lorry	Existing	Existing
11 Figue	ira Muita	B-1	103	116	137	16.0	1,856	2,740	Tank Leary	Existing	Existing
16 Ponta	Lobrão	B-1	283	322	385	21.0	6,762	7,700	Well	Existing	2
Sub-to	otal		558	634	757	; 	12,342	15,140		:	
São Mi	guel		!				!			:	:
19 Ribeir	reta	B-1	343	237	282	† ·· · ·- · ·	;	5,640	Tank Lorry	10m³	2
20 Tagar	та	B-1	743	789	947		·	18,940	Well	20m³	2
21 Varan	da	B-1	457	500	568	7.0	3,500	11,360	Spring	i	i
Sub-to	otal		1,543	1,526	1,797	;	;	35,940		in and and an area of a second	†
Santa C	Catarina		i							 	
3 Achae	ja Lazão	B-1	128	148	181			3,620	Spring		
4 Achae	da Leite	B-1	186	216	265	 	f ·	5,300	Spring		
9 Anib	ada	B-1	124	143	174	· -··		3,480	Tank Lorry	Existing	2
10 Banar	na Semedo	B-1	485	562	688	 		13,760	Spring	; :	
11 Boa E	Intrada	B-1	1,063	1,232	1,508	 	<u>:</u>	30,160	Spring	F)
16 Charc	0	B-1	311	361	443	<u> </u>	•	8,860	Spring		·
18 Entre	Picos	B-1	293	339	416			8,320	Tank Lorry	Existing	2
21 Fonte	ana	B-1	1,038	1,200	1,466		<u> </u>	29,320	Spring	<u></u>	
25 Gil B	ispo	B-1	844	977	1,194		 	23,880	Wei		; i
37 Pau V		B-1	289	332	404			8,080	Tank Lorry	Existing	2
38 Pedra	Вагго	B-1	489	567	696		j	13,920	Tank Lorry	Existing	2
39 Pedra	Serrado	B-1	127	144	175]	 	3,500	Tank Lorry	Existing	2
52 Abob		B-1	740	851	1,032	 		20,640		<u> </u>	
59 Favet		B-1	337	386	467		ļ	9,340		10m ³	2
69 Purgu	еіга	B-I	430	495	601	†	İ	12,020	Tank Lorry	Existing	2
Sub-t			6,884	7,953	9,710	† 		194,200	<u>-</u>	1	
Santa (<u> </u>]		1	<u>'</u>
10 Libră		B-1	434	515	604	4.2	2,163	12,080	Tank Lorry	Existing	Existing
12 Mont		B-i	587		967	· · · · · · · · · · · · · · · · · · ·	1,045	}	·	Existing	Existing
28 João		B-1	232	357	425	5.0	1,785	8,500	Weli	Existing	2
Sub-t			1,253	i			4,993		!		
	mingos	<u> </u>		i			1		,	İ	<u> </u>
17 Godi		8-1	277	330	419	11.3	3,729	8,380	Tank Lorry	Existing	Existing
19 Lour		B-1	350		455	-	2,925			10m ³	2
	les Faleiro Rendeiro		218		329	ļ	1,872	i		Existing	Existing
23 Nora		B-1	380		592		5,677	 		Existing	Existing
Sub-t			1,225		1,795	·	14,203	1			†
Praia			, , , , , ,			 	1		 		
l ,	tinho Alves	B-1	113	126	147	ļ	- F	2,940	Well	Existing	2
Sub-		<u> </u>	113				 	2,940		1	ļ
Tot		 	11,576				i	324,040		1	26

Table 6-5 Planed Facility in 30 Villages (Phase IV)

No.	ZONA	Grouping	Po	pulation	l	Supply Amount 1998	Consumption 1993	Water Demand 2003	Propos	ed Supply Fac	ility
10.	7.01.11		CENSUS 1990	1,998	2,009	(€/c/d)	(6/3)	(Pop.x 20//c/d)	Water Source	Reservoir tank	Public Fauce
a	rrafal									· · · · · · · · · · · · · · · · · · ·	
3	Achada Longueira	B-2	869	930	1,114	11.5	10,695	22,280	Well	Existing	Existing
	Sub-total		869	930	1,114		10,695	22,280			
}ã	o Miguel	1	:			:					
	Palha Carga	B-2	628	716	859	11.0	7,880	17,180	Well	Existing	Existing
	Sub-total		628	716	859		7,880	17,180			
Sa	nta Catarina	1	 			}	· · · · · · · · · · · · · · · · · · ·	i	İ		
	Achada Gomes	B-2	350	403	489	1		9,780	Вербительных об Решир	Existing	Existing
5	Achada Lém	B-2	2,390	2,762	3,370	j	! : :	67,400	Replacement of Pump	Existing	Existing
22	Fonte Lima	B-2	823	954	1,168		 	23,360	Spring		
	Furna	B 2	453	521	633	.		12,660	l	······· • • • • • • • • • • • • • • •	
	Gamehemba	B-2	215	249	304	4	ì	6,080	ያ · · · · · · · · · · · · · · · ·		
	Japluma	B-2	193	220	266	·	<u> </u>	5,320	Spring		
	João Dias	B-2	508	590	726			14,520	I		
	Librao	B-2	529	614	754	· <u>-</u>	<u> </u>		Replacement of Pump	Existing	Existing
	Degredo	B-2	204	233	282		1	5,640	1	. —————	
	Leitão Grande	B-2	964	1,101	1,337	· 			Replacement of Pump	Existing	Existing
	Ribeira Acima	B-2	254	295	362			7,240	·		:
	Rebelo	B-2	133	154	188	· i	<u> </u>	3,760	l		
	Sub-total		7,016	8,096	9,879	- ;		197,580	·		
S	anta Cruz		1,010	0,070	2,072			1	 _		!
8	Chã da Silva	B-2	996	1,219	1,515	6.0	7,314	30 300	Replacement of Pump	Existing	Existing
	Longueira	B-2	441	326	388	. }	3,260	÷	I		
	Pico Antónia/Padjom	B-2	659	664	779	-i	8,566		Replacement of Pump	Existing	Existing
-33	Sub-total		2,096	2,209	2,683		19,140	1	·	Daning	1
e.	ão Domingos	- 	2,090	2,209	2,00.	i	; 17,140 i), 33,010 }	1		<u> </u>
		8.2	267	317	40	1 14.6	4,628) R (12)	Replacement of Sump	Existing	Existing
_	Achada Baleia	$- \frac{B-2}{B-2}$	441	524	64		6,653	-	Replacement of Pump	Existing	Existing
2								<u> </u>	Replacement of Pump	Existing	Existing
3		B-2	226	270		- t	3,32		- 	Existing	Existing
	Dobe	$ \frac{B-2}{2}$	140	167		[1,97		Replacement of Pump	Existing	Edsing
18	Lagoa	B-2	190	230	<u> </u>		3,88			<u>i</u>	
_	Sub-total		1,264	1,508	1,90	<u>.</u>	20,46	38,10	1	1	<u>!</u>
	raia	_				<u> </u>		4.54	J	<u> </u>	
	Veneza	B-2	176		{	- ;	 	4,54	 		P • • •
	João Varela	B-2	309		}			7,98		Existing	Existing
	Beatriz Pereira	B-2	185		ļ			t	Replacement of Pump	<u>-</u>	Existing
	Chā de Igreja	B-2	182		-		_{		Replacement of Pump		Existin
-	2 Gouveia	B-2	249		<u>:</u>	<u></u> :			Replacement of Pung		Existing
ŀ	3 Mosquito de Horta	B-2	117	 	+		-		Perforement of Pump	Existing	Existin
	4 Mosquito Grande	B-2	122	<u></u>	4			3,12		1	<u> </u>
2	6 Porto Mosquito	B-2	492	549	63	8			Regiscement of Puro	Existing	Existin
Ĺ	Sub-total		1,832	1,979	2,40)2'	1	48,04	0		•
Г	Total		13,705	15,438	18,84	1		376,82	0		1

Table 6-4 Number of Proposed Facility / Service for 90 Villages

			Vater Source	e	S	Supply Facility	
		Well	Spring	Tank Lorry	Replacement of Pump	Reservoir tank	Public Faucet
	Phase 2	0	0	0	0	0	0
T C. 1	Phase 3	1	0	2	0	0	2
Tarrafal	Phase 4	1	0	0	0	0	0
	Total	2	0	2	0	0	2
	Phase 2	3	l	1	0	20m³x1	8
0* 14"1	Phase 3	1	ì	1	0	20m³x1,10m³x1	4
São Miguel	Phase 4	1	0	0	0	0	0
	Total	5	2	2	0	3	12
	Phase 2	0	5	7	0	15m³x1,10m³x2	14
0 . 0	Phase 3	2	6	7	0	10m³x1	14
Santa Catarina	Phase 4	0	8	0	4	0	0
	Total	2	19	14	4	4	28
C C	Phase 2	0	2	5	0	15m³x1	6
	Phase 3	1	0	2	0	0	2
Santa Cruz	Phase 4	0	1	0	2	0	0
	Total	1	3	7	2	1	8
	Phase 2	1	0	3	0	0	2
n- n ·	Phase 3	l	0	3	0	10m³x1	2
São Domingos	Phase 4	0	1	0	4	0	0
	Total	2	1	6	4	1	4
	Phase 2	0	1	0	0	0	0
Thursday	Phase 3	1	0	0	0	0	2
Praia	Phase 4	0	2	0	6	0	0
	Total	1	3	0	6	0	2
	Phase 2	4	9	17	0	6	30
T-4-1	Phase 3	8	7	15	0	4	26
Total	Phase 4	2	12	0	16	0	0
	Total	13	28	31	16	9	56

6.3.4 Project Coat for 2nd to 4th Phase Projects

The total projects cost including 20% of administrative and engineering cost, and procurement of 5 tank lorries is estimated at 4.43 million US Dollars.

6.4 Operation and Maintenance Plan

6.4.1 Autonomous Management System for O/M Structure

Rural water supply operation and maintenance in Santiago Island is currently being carried out by a central administrative unit and the municipality. Except in some of the villages in the municipality of Praia, users do not participate in the activities, as previously mentioned in Section 3.3.5.

As mentioned in Section 3.3, there is an absolute shortage in water supply source and volume, as well as lack of staff for maintenance services. Because of these limitations many villages do not receive public water supply services; the daily domestic water consumption rate is generally low in most villages in the Island. This, however, is also influenced by the reluctance of the users to actively participate in the operation and maintenance activities. The low consumption rate, on the other hand, may be also attributed to the users' need to budget the household money to accommodate other expenses by limiting their purchase of water (as previously mentioned, water is sold on a "cash on delivery" basis). Water users entirely rely upon municipal services.

Municipal autonomy in water supply services is a recent development in the Republic. From INGRH, responsibilities for rural water supply management were gradually delegated to municipalities. However, extreme shortage in manpower for operation and maintenance and the lack of skilled staff hamper the development of the municipal service level or the expansion of the services within the municipality.

Shortage in water sources may be solved by developing the sources. This development and service expansion, however, would only aggravate already inefficient operation and maintenance services, unless the existing O/M system is totally revamped. Restructuring the system would entail the integration of the user participation concept. It is, therefore, important to conduct activities that would encourage community participation in the operation and maintenance of the rural water supply system. Operation and maintenance activities, however, should always be carried out cooperatively with state and municipal level.

Ongoing rural water supply projects, jointly executed by the government and the United Nations Equipment Fund (FENU) and covering 18 villages in the Island, introduced the community participation ideology and conducted in-depth social studies as well as educational programs prior to the construction works. The construction works will be completed by the end of 1999 and the new management system, which will be based on community participation, will begin operation from the start of 2000. It is, therefore, recommended that the monitoring of the new system

and the conduct of educational activities should be continued until the system is in solid footing.

6.4.2 Establishment of Community-based Organization

In order to take part in the O/M work for the water users level, it is essential to formulate the water users association and management committee in the villages concerned. Since rural areas of Santiago Island have an experience to formulate and manage the farmers association in use of irrigation water, and also, people in rural communities have willingness to participate in O/M of water supply as described in 2-4, it will not be so difficult matter to establish and operate the community-based committee in this area.

The recommended type of the committee and its role in domestic water management are as follows;

1) Composition of water association/committee

All family who wish to utilize the improved water supply facility in the community shall join the water association and elect the following committee members;

- President of the association for general management and responsible for close connection with the Municipal Office
- · Accountant to collect monthly O/M fee and manage it
- Member to operate the facilities and maintain them in good condition for use
- Member responsible for hygiene and health, and also for water quality control

2) O/M fee collection system and management

Under the new management in utilizing the improved water supply system, people will not buy water from the water vendor. The money monthly collected from the association members is used purely for O/M purpose of following;

- Daily operation cost to pay for such materials as fuel, oil, oil filter, etc.
- Cost for minor repair of generator, water taps and others
- Deposit for future heavy repair of generator or motor pump (Either at Municipal Office or at the Committee concerned)
- Deposit for pump replacement (same as above mentioned deposit)
- Cost for maintenance services by the staff of Municipal Office (for such services as periodical inspection and training of committee/association members regarding hygiene, water quality treatment, technique of repair, etc.)
- Water use tax to be paid to the state (for general management of water resources)

 Wages for Committee members (Optional, to pay or not will be discussed in the association)

3) Estimation of operation and maintenance cost

Under the condition that a 20 liters of water is supplied daily to all the person of the association with 500 members (100 families), the averaged O/M cost is calculated as follows just for comparison with the existing water charge per 20liters;

•	Pump/generator operation cost per 20liters:	1.70CVE/20 liters
		(1.45~8.76)
•	Cost for minor repair (assumed as 50CVE/day)	0.10CVE/c/d
		(20 liters consumption)
•	Deposit for heavy repair (20,000CVE/2year)	0.06CVE/c/d
•	Replacement of pump (after12 years, 570,000CVE)	0.28CVE/c/d
•	Maintenance service (Twice a month, 2,333CVE/m)	0.17CVE/c/d
•	Water use tax (8CVE/m3)	0.30CVE/20 liters
•	Wages for committee member (36,000CVE/n/4p.)	2.59CVE/c/d
	Sub-total	5.02CVE/c/d

Above O/M cost per 20-liter consumption varies with number of population served from maximum of 11.42CVE in Tronco of Praia, and minimum of 1.69CVE in Ribeira da Barca of Santa Catarina. Given the condition as voluntary basis for the committee member, maximum will come to 4.33CVE, and minimum 1.11CVE/20 liters. The monthly O/M cost amounts approximately 650CVE/m for 5person-family (Ribeirão Almaço), and 170CVE/m for the same family (Ribeira da Barca).

The O/M cost for 20-liter supply in each of the A-1 grouped villages are tabulated in Table 6-5, which accompanies comparison between the current water charge per 20 liters.

The O/M cost per person is mostly lower than the present water charge, but it is higher at the villages with a smaller population than 300. Also, it must be noted that the O/M cost should be paid at the villages where water charge is so far free.

In order to adjust the uneven O/M cost per person by vitlages, each of Municipal office will have to consider a finantial assistance to the villages concerned by collecting surplus service charge from the largely populated villages, for example.

In determining the O/M cost, thorough discussions between the municipal office and the villages concerned are required, prior to implementation of the project. The discussions pertaining to the service contents are also required.

Table 6-6 presents the estimated pump operation cost for pumping of 10 m³ from the wells and spring.

Table 6-7 O/M Cost in 34 Villages of Group A-1

				10000			AS LOS			•		
	2003	Operation	Minor	Heavy Repair	Pump	a Month	Tax	Committee	Consumption	mption	Water	Comparison
	(Capita)	Cost	Repair (Few/200)	(Ecv/20A)	(Ecv/207)	(Ecv/207)	(Ecv/20f)	(Ecv/202)		(Ecv/200)	(Ecv/200)	
+	8	2.29	0.13	0.07	0.33	0.19	0.30	3.00	6.31	3.31	5.00	Lower (Higher with wages)
1	379	2.29	0,13	0.07	0.34	0.21	0:30	3.17	6.51	3.34	5.00	Lower (Higher with wages)
t	757	2.05	0.00	0.04	0.17	0.10	0.30	1.59	4.32	2.73	5.00	Lower even with wages
	343	3.06	0.15	80.0	0.38	0.23	0.30	3.50	7.70	4.20	0.00	
i	649	2.05	0.08	0.04	0.20	0.12	0.30	1.85	4.64	2.79	5.00	Lower even with wages
	367	1.43	0.14	0.07	0.35	0.21	0.30	3.27	5.77	2.50	0.00	
T	859	1.53	0.08	0.04	0.20	0.12	0.30	1.82	4.09	2.27	5.00	+
<u>. </u>	1,291	0.76	0.04	0.02	0.10	90.0	0.30	0.93	2.21	1.28	0.00	Lower even with wages
	1,287	1.02	0.04	0.02	0.10	90:0	0:30	0.93	2.47	1.54	10.00	Lower even with wages
}	375	2.29	0.13	0.07	0.35	0.21	0.30	3.20	6.55	3.35	8,00	Lower even with wages
[377		0.13	0.07			0:30	3.18	3.68	0.50	0.00	
*	457	4.	0.11	90.0	0.28	0.17	0.30	2.63	4.99	2.36	2,00	Lower even with wages
	1,987	89.0	0.03	0.01	0.07	0.04	0.30	09:0	1.73	1.13	5.00	Lower even with wages
	840	1.15	90.0	0.03	0.15	0.09	0.30	1.43	3.21	1.78	5.00	Lower even with wages
1	621	1.53	0.08	40.0	0.21	0.13	0.30	1.93	4.22	2.29	2.00	Lower even with wages
*	662	96.0	0.08	9.	0.20	0.12	0:30	1.81	3.51	1.70	5.00	Lower even with wages
	612	0.96	80.0	0.04	0.21	0.13	0.30	1.96	3.68	1.72	2.50	Lower (Higher with wages)
	283	3.06	0.18	0.10	0.46	0.27	0.30	4.24	8,61	4.37	0.0	•
<u></u>	403	1,43	0.12	0.07	0.32	0.19	0:30	2.98	5.41	2.43	8	Lower (Higher with wages)
<u> </u>	311	3.05	0.16	0.09	0.42	0.25	0.30	3.86	8.13	4.27	2.8	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
	336	1.43	0.15	80.0	0.39	0.23	0.30	3.57	6.15	2.58	3.00	Lower (Higher with wages)
	732	96.0	0.02	10.0	0.18	0.11	0.30	1.64	3.30	1.66	4.00	Lower even with wages
*	928	0.72	0.05	0.03	0.14	0.08	0:30	1.29	2.61	1.32	5 .00	Lower even with wages
	337	1.92	0.15	0.08	0.39	0.23	0.30	3.56	6.63	3.07	5.00	Lower (Higher with wages)
	351	1.43	0.14	80:0	0.37	0.22	0.30	3.42	5.96	2.54	4.00	Lower (Higher with wages)
<u>. </u>	270	1.91	0.19	0.10	0.48	0.29	0.30	444	7.71	3.27	7.00	
ĺ	939	1.54	0.05	0.03	0.14	80.0	0.30	1.28	3.42	2.14	8.	Lower even with wages
1	512	1.83	0.10	0.05	0.25	0.15	0.30	2.34	5.02	2.68	8.8	Lower even with wages
-	241	1.91	0.21	0.11	0.54	0.32	0:30	4.98	8.37	3.39	0.00	
	1,057	1.23	0.05	0.03	0.12	0.07	0.30	1.14	2.94	1.80	7.00	Lower even with wages
-	274	1.92	0.18	01.0	0.47	0.28	0.30	4.38	7.63	3.25	8.	Lower (Higher with wages)
<u> </u>	529	1.15	0.09	0.05	0.25	0.15	0.30	2.27	4.26	1.99	2.00	Lower even with wages
*	1.078	0.82	0.05	0.03	0.12	0.07	0.30	1.11	2.50	1.39	0.00	
	221	4.58	0.23	0.12	0.59	0.35	0.30	5.43	11.60	6.17	0.00	
r												

* Solar enagized system can be applied. With the system, O/M cost will become lower by omitting pump operation cost.

Cost
ning
Run
0- 8
able

						Ē	el Consumi	Fuel Consumption Rate =	0.127	0.127 l/PS/h,	525 02.	30.04	1 × ×	
r					Pump		Gen	Generator	Fuci		COST			
		Population	Daily Demand			:	Out-Put Power	Power	Consumpti	Total Daily	Daily Cost /	Ришр		NOTE
	ZONA ZONA	2003	5007	Rate	Run, Mours	ort per	Gene.	Engine	s	Cost	Capita	Operation Cost		
,		(Capita)	(20//c/d)	(mi/min)	(Fr	(Kw)	(KVA)	(PS)	(0/0)	(ECV/d)	(ECV/C/d)	(ECV/m)		
اآعا	9 'Curral Velho	400	8,000	0.020	29'9	2.20	18	23.5	19.9	915.40	2.29	114.43		
i Tus I	19 Trás os Montes	379	7,580	0.020	6.32	2.20	18	23.5	18.9	869.40	2.30	114.70		
Įa	4 Châ de Ponta	757	15,140	0.030	8.41	3.70	25	31.5	33.7	1,550.20	2.05	102.40		
nßļ		343	98.9	0.015	7.62	2.30	18	23.5	22.8	1,048.80	3.06	152.89		
W	11 Monte Pousada	649	12,980	0.030	7.21	3.70	25	31.5	28.9	1,329.40	2.05	102.42		
088	18 Ribeirão Milho	367	7,340	0,020	6.12	01.1	2	14.7	11.5	529.00	1.45	72.08		
3	12 Boa Entradinha	859	13,160	0.030	7.31	2.20	18	23.5	21.9	1,007.40	1.54	76.56		
	13 Bombardeiro	1,291	25,820	090'0	7.17	2.20	81	23.5	21.5	00.686	0.77	38.31		
	15 Cha de Tanque	1,287	25,740	0900	7.15	3.70	25	3:.5	28.7	1,320.20	1.03	51.29	:	
E	19 Entre Picos de Roda	375	7,500	0.020	6.25	2.20	18	23.5	18.7	860.20	2.30	114.70		
ine	36 Pata Brava	377	7,540	•	Spring								:	
	40 Pingo Chuva	457	9,140	0.020	7.62	1.10	0	14.7	14.3	657.80	1.44	71.97	:	
	43 Ribeira da Barca	1,987	39,740	0.000	7.36	3.70	X	31.5	29.5	1,357.00	69'0	34.15		
ues	47 Saltos Acima	840	16,800	0.040	7.00	2.20	<u>«</u>	23.5	50.9	24 .1 8 6	1.15	57.23	:	:
<u> </u>	57 Covão Grande	621	12,420	0.030	96'9	2.20	<u>∞</u>	23.5	20.6	947.60	1.53	76.30	:	
<u></u> -	60 Jalalo Ramos	662	13,240	0.030	7.36	1.50	01	14.7	13.8	634.80	96.0	47.95		
	63 Leitāozinho	612	12,240	0:030	6.80	1.50	01	14.7	12.7	584.20	96:0	47.73		
╆		283	5,660	0.015	6.29	2.20	81	23.5	18.8	864.80	3.06	152.80	:	:
<u> </u>	25 Achada Costa	403	8,060	0.020	6.72	2.20	01	14.7	12.6	279.60	<u>4</u> .	71.92	:	
e)(27 Fundura	311	6,220	0.015	16.9	2.20	82	23.5	20.7	952.20	3.07	153.09		
	31 Levada	336	6,720	0.015	7.47	0.75	2	14.7	14.0	644.00	1.92	95.84		
┿		732	648,42	0.030	8.13	1.50	0.1	14.7	15.2	699.20	96'0	47.76	:	
<u>.i.</u>		928	18,560	0.040	7.73	0.55	0	14.7	14.5	00'199	0.72	35.94		
SC	11 Achada Mitra	337	6,740	0.015	7.49	1.50	10	14.7	14.0	848	1.92	95.55	:	
Zu	13 Banana	351	7,020	0.020	5.85	1.50	01	14.7	011	206.00	1.45	72.08		
imo	15 Dacabalaio	270	5,400	0.015	90.9	2.20	01	14.7	11.3	519.80	1.93	96.26	:	
<u> </u>	16 Fonte Almeida	686	18,780	0.040	7.83	3.70	ฆ	31.5	3.4	1,444.40	1.54	76.92		
	20 Mato Afonso	512	10,240	0.025	6.83	2.20	81	23.5	20.4	938.40	1.84	91.65		
•	24 Po de Saco	241	4,820	0.015	5.36	1.10	10	14.7	10.0	460.00	1.91	95. 4.	:	
·	27 Rui Vaz	750,1	21,150	0.050	7.05	3.70	25	31.5	28.2	1,297.20	1.23	61.37		
T	10 Sto Tomé	274	2,480	0,015	60'9	0.75	01	14.7	11.4	524.40	1.92	95.70	:	
<u> </u>	18 Belém	529	10,580	0.025	7.05	1.50	0	14.7	13.2	607.20	1.15	57.40	:	
er4	27 , Santana	1,078	21,560	0.100	3.59	5.50	9	42.0	19.2	883.20	0.82	40.97		
	28 Tronco	221	4,420	0.010	7.37	2.20	82	23.5	22.0	1,012.00	4.58	228.96		
	Total / Average	20,864	417,280	0.031	88.9	2.21	16.2	21.8	19.0	872.88	1.73	86.20		

7 PROJECT EVALUATION

7.1 Introduction

The Project has been designed to satisfy basic human needs of the people residing in rural areas of Santiago island. Out of 206 communities (zonas) in Santiago island, a total of 122 communities in rural areas have been selected as the target communities for the implementation of the Project.

The objectives of the Project are: i) to provide and distribute sufficient and safe potable water to meet the needs of domestic water users in 122 communities by the year 2009; and ii) to establish improved operation and maintenance system in prioritized communities through participation of the communities' residents.

Based on the phased project implementation concept, the Project will be implemented in four phases, each phase covering 29 to 34 communities. Phase-1 project works will be implemented by the year 2003 and Phase-2 to Phase-4 by the year 2009.

7.2 Evaluation of Economic Benefits

7.2.1 Overall Benefits

The Project has been designed to satisfy basic human needs of the people residing in rural areas of Santiago island. The implementation of the Project is expected to yield various kinds of benefits including direct as well as indirect benefits. These benefits include, among others, increased number of beneficiaries, health improvement, time saving, consumer satisfaction and improved quality of life of the people in general. The Project is also expected to yield indirect benefits such as employment generation as a result of time saving, reduction in morbidity and mortality of children as a result of increased time of women for child care, increased activities of rural population for community development as a result of time saving and so on.

Although most of these benefits are difficult to quantify, efforts have been made to evaluate them in qualitative manner.

7.2.2 Increased Beneficiaries

One of the significant effects of the Project is the increased beneficiaries as a result of increased supply of safe water.

Phase-1 Project works will cover 34 communities in Santiago island with the estimated population of 20,900 persons in 2003, which will grow to about 23,300 persons in 2009. Phase-2 to Phase-4 Project works will cover 88 communities with the estimated population of about 57,500 persons in 2009. Total beneficiaries in 2009 are estimated to be 78,400 persons in 2009 as presented in the following table.

	Pha	se-1	Phase-2 to	o Phase-4	Total
	No. of Target	Beneficiaries	No. of Target	Beneficiaries	Beneficiaries
	Communities	in 2003	Communities	in 2009	in 2009
Tarrafal	2	779	4	1,871	2,650
São Miguel	4	2,116	9	6,848	8,964
Santa Catarina	11	9,167	39	30,432	39,599
Santa Cruz	4	1,333	13	9,483	10,816
São Domingos	9	5,367	13	5,210	10,577
Praia	4	2,102	10	3,666	5,768
Total	34	20,864	88	57,510	78,374

Anticipated Beneficiaries in the Project Area

7.2.3 Improvement in Health Conditions

One of the main objectives of rural water supply program is to improve health conditions in rural areas. The proposed Project has also been designed to reduce the incidence of waterborne diseases through provision of improved water quality and increased water use.

The better access to water may change personal hygiene habits, promoting increased bathing and clothes washing. Increased water use for bathing, washing and food preparation can lead to a reduction in water-washed diseases (e.g. skin diseases). Improved water quality can be expected to reduce the incidence of waterborne diseases (e.g. diarrhea). In addition, spending more time on child care and food preparation may lead to a reduction of child mortality and morbidity.

The extent of the effects which provision of clean water will give to water users in their health conditions can be estimated from the result of analyses conducted by USAID and WHO. (Refer to World Development Report, 1992). It is estimated that out of the total reduction in the incidence of diarrheal diseases due to provision of clean water and improvement in sanitation, 78% is attributable to provision of clean water and the remaining is attributable to improvement in sanitation. It is also reported that incidence of diarrhea has been reduced by 22% due to provision of clean water and improvement in sanitation. It can be concluded from these analyses that provision of clean water alone can reduce the incidence of diarrheal diseases at least by 17%. It should be noted, however, that improved water quality alone is not sufficient for eventual impact on human health improvement. Water supply should have links with other activities such as hygiene practice, sanitation, health education, and so on.

7.2.4 Time Saving Effect of Water Collection

One of the main objectives of water supply project is to reduce the workload of the residents, particularly women and children, for water collection. Time for water collection consists of travel time, queuing time and fill time. By providing stable supply of water through the improved facilities, water users will have better access to

water sources. As a result, time for water collection will be significantly improved. Saved time may be used for social, educational, agricultural or commercial activities.

7.3 Financial Analysis

7.3.1 Financial Project Cost

Financial Project costs have been estimated on the basis of the market prices as of March 1999. The Project costs comprise the costs for construction, equipment, and engineering services. Price contingency is not considered. Base costs of the Project at the price level of March 1999 amount to US\$ 14.21 million.

Financial Project Costs

Unit: Million US Dollars (\$)

	Phase-1	Phase-2 to Phase-4	Total
A. Construction	4.62	2.54	7.16
B. Equipment	4.00	0.64	4.64
C. Engineering Services	1.16	1.25	2.41
Total	9.78	4.43	14.21

7.3.2 Financing Plan

(1) Financing of Capital Investment Costs

Financial sources of the Project will be derived from the government budget and financial assistance from foreign countries and international organizations.

In consideration of the investment costs and financial status of the government of Cape Verde, financial assistance from foreign sources will be indispensable. External assistance in terms of grant aid will be necessary to cover the entire foreign currency portion and a part of local currency portion of the Project costs.

(2) The Government's Contributions

1) Financing of Capital Costs

The Government will be responsible for financing a part of capital costs for the implementation of the Project. The State budget allocation for the Project will be arranged through INGRH.

2) Financing of Operation and Maintenance Costs

Presently INGRH and water supply section of each municipality are responsible for the operation and maintenance costs for water production and water supply facilities. The proposed Project recommend that water users in the target communities should form the Water Users Committees (WUCs) for proper operation and maintenance of their facilities. (Refer to Chapter 6). One of the duties of the WUC is to collect the water charge to cover the operation and maintenance costs.

INGRH and each municipality administration are expected to extend technical assistance for these WUCs through training on the operation and maintence, dispatch of mechanics in case of heavy damages of the facilities, hygiene education, etc.

3) Provision of Project Staff

INGRH will be responsible for arranging technical and administrative staff necessary for the implementation of the Project. INGRH will take action to recruit some technical staff from other government agencies (e.g. INERF) when necessary.

7.3.3 Recovery of Capital Cost and Recurrent Cost

(1) Recovery of Capital Cost

It is the policy of the government of Cape Verde that beneficiaries are responsible for covering a part of the investment costs in water supply project. However, in consideration of the present income level of the residents in the Study Area, it is suggested that water charge should be maintained at levels to ensure recovery of the operation and maintenance costs.

(2) Recovery of Operation and Maintenance Costs

Annual operation and maintenance costs (O&M costs) for the water supply facilities are estimated at 5.0 CVE per capita per day including cost for minor repair, deposit for heavy repair, replacement of pump, maintenance service, water use tax and wages for committee members, although O&M costs varies depending on the size of the community. The community with smaller population is compelled to burden higher water charge. To avoid such a situation, it is recommended that the water charge should be fixed at each municipality using the average O&M costs per head.

As mentioned in Chapter 6, the O&M costs include cost for pump/generator operation cost, minor repair, deposit for heavy repair, replacement of pump, maintenance service, water use tax and wages for committee members. If the wages for committee members are excluded from the calculation, water charge will be reduced to 2.4 CVE on the average.

In the case of water charge of 5.0 CVE, the monthly water charge payment will be about 750 CVE per household, which is estimated to be about 11% of the household income. In the case of 2.4 CVE, the monthly payment will be 360 CVE, which is estimated to be about 5.6% of the household income. The latter case is considered to be within the capacity to pay of the residents in rural areas.

7.4 Institutional Evaluation

7.4.1 Existing Institutional Situation

(1) National Level (INGRH)

Based on the national policy of decentralization, INGRH has concluded a concession contract attributing to each municipality the exclusive right to explore the production and distribution units to provide potable water for the population in each municipality. The production and distribution of irrigation water is also the object of a concession. Main tasks of INGRH are to rationalize the exploitation of water

resources and to support the autonomous services of water and energy in each municipality.

With regard to operation and maintenance (O&M) activities, INGRH is responsible for water quality and manpower training on operation and maintenance.

(2) Municipal Level

Each Municipality has a Department of Water and Energy Services, except in the Municipality of Praia where the water supply services are undertaken by EMAP. In Tarrafal, São Miguel, Santa Cruz and São Domingos, the Municipal Water and Energy Services is responsible for the production and distribution of domestic as well as irrigation water to urban and rural population. In Santa Catarina, the Municipal Water and Energy Services is providing domestic water mainly to the town of Assomada and its surroundings, while INGRH branch office is providing water to rural population.

With regard to operation and maintenance activities, each Municipality is responsible for the daily operation of borehole motor pumps and other water supply facilities under INGRH's supervision and technical assistance. In the Municipality of Santa Catarina, the O&M services in rural areas are directly undertalen by INGRH branch office in Assomada.

In the Municipality of Praia, EMAP undertakes systematic O&M work without serious problems thanks to a sufficient number of educated and experienced staff. On the contrary, other Municipalities are not in a position to improve the poor service level due mainly to shortage of adequate manpower and budget.

7.4.2 Proposed Institutional Arrangement

(1) National Level (INGRH)

INGRH will be the project owner and the responsible agency for implementation of the proposed Project. For smooth and effective implementation of the Project, a Project Team will be assigned at INGRH headquarters. A team of technical staff comprising a water supply engineer, a water quality specialist and some administrative staff will be stationed in the office under a Project Director who is responsible for overall management activities of the Project. The Project Team will play an intermediary role between the INGRH, municipalities, and the communities. During the construction stage, the Team will be assisted by a team of engineering consultants.

With regard to operation and maintenance (O&M) activities, INGRH shall be responsible for monitoring on water quality, manpower training on operation and maintenance, and technical assitance to each Municipality on heavy repairs of the existing facilities.

(2) Municipal Level

With regard to operation and maintenance activities, each Municipality will be responsible for monitoring of the existing facilities in the communities, manpower training for water users associations, and technical assistance for heavy repairs on the existing facilities in the communities.

(3) Community Level (Formation of WUCs)

Taking into consideration the existing situation of rural water supply program, it has been recommended that water users themselves should be involved in O&M activities. The participation of villagers who live near the facilities in the daily O&M work will lead to the reduction of O&M services costs burdened by the Municipal offices.

It is recommended, therefore, that a Water Users Committee shall be established in each community where a new water supply facility will be constructed. The construction of the Project facilities will be commenced in the community where the agreement will be made between the community and municipal administration concerning the establishment of a Water Users Committee (WUC).

The activities of WUCs will include collection of O&M cost, daily inspection of water supply facility, periodical cleaning of the facility, repair of minor damage of the facility, check of water flow to report to the municipal administration, and animation of the population in the community.

Establishement of WUCs is expected to stimulate a full sense of ownership of water supply facilities located in the community. It is also expected that the water users are encouraged to make substantial contribution in cash or in kind for operation and maintenance works.

7.5 Technical Evaluation

7.5.1 Concept for Improvement in Water Supply Service

The proposed Project has been designed on the basis of the following concepts.

- (1) Upgrade of the existing water supply service level through additional groundwater development and construction of upgraded water supply facilities, to the level of 20 liters unit daily supply amount per person in average
- (2) Upgrade of the existing water supply service level through expansion of the service coverage area (e.g. increase in source points, increase in the number of tank lorries, etc.)
- (3) Expansion of the service hour to entire daytime

The level of technology adopted in the Project design will not involve any technically special knowledge compared to the present level, and therefore the Project work will be conducted without any difficulty from construction stage to operation and maintenance stage.

7.5.2 Improved Operation and Maintenance System

A distinct difference between the conventional and proposed O&M systems is that preventive maintenance and minor repairs of water supply facilities will be conducted by the committee members of the WUCs to be established in each community.

Municipal Water and Energy Services will be responsible for provision of spare parts to WUCs, training for caretakers, and assistance in case of serious repairs.

Establishement of WUCs is expected to stimulate a full sense of ownership of the Project facilities located in the community. It is also expected that the water users are encouraged to make substantial contribution in cash or in kind to operation and maintenance works for their own water supply facilities.

7.6 Social Evaluation

(1) Improvement in Health Conditions

One of the most important objectives of water supply projects is to improve health conditions and living conditions of the people through provision of safe water. The proposed Project is also designed to reduce the incidence of waterborne diseases through provision of improved water quality and increased water use.

Increased water use for bathing, washing and food preparation can lead to a reduction in water-washed diseases. Improved water quality can be expected to reduce the incidence of waterborne diseases. In addition, spending more time on child care and food preparation may lead to a reduction of child mortality and morbidity.

(2) Time Saving for Water Hauling

One of the main objectives of water supply project is to reduce the workload of the residents, particularly women and children, for water collection. By providing stable water supply in the community, the residents, particularly women and children, no longer have to spend a lot of time to wait for the supply of water. The better access to water sources will lead to the reduction of waiting time for water collection. Saved time may be used for social, educational, agricultural or commercial activities.

(3) Opportunities for Better Farming

The proposed Project will give additional water source for the communities. Therefore, these communities will have surplus water from traditional water sources (e.g. dugwells) which can be used for irrigating food and tree crops grown in the backyard gardens. As a result, farming activities will give more chance for them to increase their agricultural production.

(4) Consideration for Women

Women constitute the majority in the total population because of emigration practices. According to the 1990 Census, women in the Study Area represented 54.2 % of the total population. Close to 41% of households are headed by women whose incomes are 26% lower than those of male headed households. The role of women in agricultural as well as domestic works is considerably important in the Study Area.

In agriculture, women perform planting, weeding and harvesting. Heavy and dangerous tasks such as clearing forest and land preparation are generally performed by men. The daily tasks of cooking, water collection, cleaning the house and washing clothes are usually conducted by women.

Although the Project has been formulated to benefit all the people in the Study Area regardless of sex, the Project will give greater impact on women and children who are playing a major role in water hauling. As mentioned elsewhere, time saving for water collection is estimated at 0.55 hours per day which can be used for social, educational, agricultural and commercial activities.

In addition to time saving for water collection, significant effect on health improvement for women is expected to arise as a result of improved water quality and increased use of water. Improved water quality will reduce the incidence of waterborne diseases. Increased water use for bathing, washing and food preparation will lead to a reduction in water-washed diseases for women.

7.7 ENVIRONMENTAL EVALUATION

7.7.1 Environmental impacts of the Project

As described in former sections, the implementation of the rural water supply project has significant positive socio-environmental impacts on the area. However, the following adverse natural and socio-environmental impacts are also foreseen to occur during and after the implementation of the project:

- 1) Water level drawdown or depletion of shallow wells and reduction of spring yield in the vicinity of the area where new wells will be drilled.
- 2) Acceleration of shallow well water contamination by increase in wastewater as a consequence of increased use of domestic water.
- 3) Opposition from private water vendors who make a living by transporting and selling water to remote rural areas, for fear that they might loose their business.
- 4) Confusion in water management system, especially in water fee collection, due to the dual implementation of the community based management and "cash on delivery" system.
- 5) Damage of plantations when construction equipment and materials are brought in.

7.7.2 Environmental Impact Assessment

In order to duly consider the environmental impacts of the project, natural and socioenvironmental surveys were conducted along with surveys on social aspects and water supply conditions in the villages.

The survey has revealed that the presumed adverce impacts are negligibly small or not so serioous on the 34 candidate villages for Phase 1:

1) Reduction in shallow well and spring yield

6 villages use shallow wells as water source. Deep well construction is presumed to have no adverse effects on the shallow well due to the following:

- In 2 villages (Bombardeiro, and Covao Grande), the deep well will be constructed at a distance of over 600m from the shallow well.
- Different water tables/aquifers: The static water level of the deep well to be constructed in 4 villages (Monte Bode, Cha de Ponta, Ribeirao Almaco, and Fonte Almeida) is estimated at lower than 140m below the ground; water will be pumped up from a different aquifer.

Springs are exploited by 11 villages for domestic purposes. In 2 villages, spring water will be transmitted by pipelines, and the springs used by 7 villages are far from the well drilling points. Well drilling is, therefore, not going to have any adverse impact on the springs used by these 9 villages.

It is possible, however, that borehole well drilling will reduce the yield of springs used by the 3 villages of Monte Bode, Po de Saco, and Belem, since water will be extracted from the same aquifer. Other adverse impacts are not foreseen, however, as the villagers are expected to stop using the springs after the construction of the borehole wells is completed.

2) Acceleration of shallow well water contamination

The implementation of the project is estimated to incur only a very small increase in daily per capita domestic water consumption: from 8~18 liters to 16~22 liters, 20 liters on average. Therefore, increase in contamination levels will be negligible. On the other hand, if contamination does worsen, the villagers can always use the new facility instead of the old.

3) Opposition from private water vendor

This problem is not foreseen to occur in any of the 34 villages for the phase 1 project, since none constantly purchases water from private water vendors. However, the villagers in Mato Fortes (S. Catarina) and Boaventura (S. Cruz) — the target villages for the phase 2 project — constantly buy water from private vendors at a high rate of 16 and 20 CVE/20 liters. And since these vendors have invested a lot in the business with the purchase of a water tank truck, opposition is highly likely. To counter-act this possible problem, contracting these vendors to carry out water transportation/delivery services may need to be considered.

4) Confusion in water management system

The introduction of the community-based autonomous water supply management system is considered to cause confusion, as this would entail the collection of water fees for facility O/M that would differ from village to village. The water fee will be determined by dividing the estimated O/M cost by the village population. It is highly likely, therefore, that villages with a smaller population would pay more per capita than villages with a bigger population. In any case, it is very important for the municipal authorities to explain to the water users prior to the implementation of the project why the water fees vary.

5) Damage of plantations

This problem can be easily avoided by choosing appropriate construction sites through discussions with the representatives of the villages concerned.

CHAPTER 7 PROJECT EVALUATION

8 CONCLUSION AND RECOMMENDATIONS

8.1 Conclusion

The major conclusions derived from the Study are detailed below.

8.1.1 Existing Condition of the Rural Water Supply in Santiago Island

1) Public supply service coverage

Santiago Island comprises of 6 municipalities, 206 communities, 1 city (Praia, the capital of the Republic and Praia Municipality), 5 towns (Capital of each municipality) and 200 villages. As of 1998, the Island is estimated to have a total population of 225,681, 136,001 of which is rural; the rest of the population reside in Praia City.

Of the 206 communities (5 towns and 200 villages), only 145 (70.7%) are covered by the public water supply services. These 145 communities have a total population of approximately 105,000. Accordingly, the public water supply service coverage is 77.1% of the total rural population. However, since not all residents receive public water supply services, the actual percentage of service coverage in some of the municipalities is estimated to be lower, at less than 70% (68~69%); the percentage differs by municipality. Residents not covered by the services collect water from springs and shallow wells, and/or buy water from private water vendors. Rainwater is also stored in individual rainwater storage, for use.

The number of villages without public water supply services is 60 (29.3%), amounting to a population of approximately 31,000 (22.9% of rural population).

2) Type of water supply services and average consumption of potable water

The rural water supply services in the Island basically operates by the following 3 types of supply system, but mostly through public faucets:

- - Household connections (8.3 % in number of communities)
- Public faucets (60.9%)
 Spring as a source
 Borehole well as a source
 Rainwater collection system as a source
 (4)
 Rainwater collection system as a source
- Direct delivery service by tank lorries (1.5%)

The public faucet supply system is divided into 2 types, according to whether the reservoir tank is or not connected to the water source:

- Reservoir tank connected by pipelines to the water supply source, i.e. borehole wells (65), springs (5), and rainwater storage container (4). This is used by a total of 74 communities
- Reservoir tank filled with water transported by tank lorries: 75 communities (36.6% of the entire rural communities)

The percentages, however, vary by municipality.

The daily unit supply amount (liter per person per day: 1/c/d) ranges from 7 to 20 1/c/d: averaging approximately 11 1/c/d for public faucets and 33 1/c/d for household connection. The Master Plan, on the other hand, targets a daily unit supply amount of 20 1/c/d and 50 1/c/d, respectively. In villages not covered by public supply services, daily consumption rate ranges from 4 to over 20 1/c/d, depending on source availability. The shallow wells used as domestic water source are all (100%) contaminated but in varying degrees.

Such poor service level is mainly attributed to the shortage of water supply sources in the Island

3) Water supply sources

Groundwater, through springs and wells, is the most commonly used water supply source in the Island. Rainwater and desalinated seawater are also used, although the latter is only used in Praia City.

There are 102 borehole wells in the island producing an average of approximately 9500 m³/day: 60% for irrigation (5,700m³/day) and 40% for domestic purposes (3,800m³/day). Except for Praia City, nearly 7,600m³/day of well water is used in the Island: 5,700m³/day (75%) for irrigation and 1,900m³/day (25%) for domestic purposes. Since the amount of water for domestic use is much smaller than for irrigation, the number of wells appropriated for domestic use may be expanded regardless of limited availability of groundwater resources in the island. This can be done if the government places higher priority on domestic water use rather than irrigation use.

There are nearly 1,000 springs in the Island and the total yield of these springs as of 1998 is estimated at about 30,000m³/day. The number of springs and their yield tend to decrease annually due to recent decline in rainfall. Since the majority of the springs is inconveniently located for domestic use, only 415m³/day (1.4% of total estimated yield) is used for such purpose. To maximize the use of springs, a detailed survey on these resources seems necessary.

Four community rainwater collection systems have been constructed; additional collection systems are being constructed at the moment. This type of system, however, does not ensure a stable water supply all year round, due to significant fluctuations in rainfall recently. This system is useful though to ease the tight schedule of the tank lorry transportation/delivery services during the rainy season and certain months after the rainy season.

4) Water charge collection system

Water charge for household connections is collected monthly and based on the amount of water consumed. For public faucets, however, a water vendor collects money from the residents under the "cash on delivery" system. This collection method is quite reasonable as it ensures payment every time the faucet is used. However, this payment system does not help improve public health, even if the water supply amount is increased, because it prevents the residents from purchasing the actual water amount they really need due to economic reasons. Conclusively, the "cash on delivery" system is not a suitable means of meeting the residents most basic needs.

8.1.2 Number of communities

The communities with comparatively satisfactory water supply service levels number 45 (22%), including 5 towns. These communities are classified under "C" (no urgent need for the project).

The remaining 160 communities require the project sooner or later; improvement projects are currently being carried out on 20 of these villages with the financial and technical assistance of FENU (17 villages) and UNICEF (1). An additional plan covering 12 communities has also been prepared with the expectation that financial assistance will be obtained from FENU. The 127 communities are, therefore, not covered by any water supply improvement plan.

Out of the 127 villages, 59 (" Λ " villages) have an urgent need for the project, while 63 are given second priority and fall under "B". Five villages, including 1 dispersed village, will be excluded from the project formulation plan due to difficult access conditions; these villages are classified under "D".

The implementation of the project by phase was arranged for the villages in "A" and "B", totaling 124.

8.1.3 Groundwater resources in Santiago Island

1) Hydrogeological structure

Santiago Island is an isolated island that is almost totally made up of rocks of volcanic origin. The hydrogeological basement of the island was formed during tectonic movements and volcanism in the Miocene and Pre-Miocene periods (18 to 26 million years ago, and more). The basement rock is widely or sporadically exposed in the Island, but mostly overlain by volcanic formations of the Miocene and Pliocene periods (the latter probably several to 16 million years ago), and by recent volcanic formations and alluvial deposits.

The groundwater resources in the Island are stored in or flow downwards mostly in overlying formations (especially the Assomada and Pico da Antonia formations alluvium layers). It can be said, therefore, that the volume and locality of groundwater to be developed depend on the: 1) shape of the surface formation, e.g. basin structure, gradient, etc., and 2) distribution pattern of the overlying formation, e.g. extent, covering, thickness etc.

Accordingly, the following 4 areas in the Island were considered promising for groundwater development based on the results of various hydrogeological surveys:

- Assomada highlands
- Lower Tarrafal volcanic plateau
- Lower Praia volcanic plateau
- Mouth of major rivers in the northeastern section of the Island

2) Groundwater balance, recharge, and discharge

Since groundwater resources in Santiago Island all originate from rainwater, the macroscopic water balance analysis was carried out on the 8 hydrogeological basin, based on the assumption that: 1) rainwater permeates into the ground and become

groundwater (infiltration rate differs by place depending on surface geology and topographic features), 2) because there are no perennial rivers, recharge elements are limited to rainwater ground infiltration and some discharge from springs that join the underground stream, 3) rainwater that infiltrates the ground and recharge by underground stream are the inflow used in balance analysis, 4) in consideration of technically and economically exploitable groundwater resources, more or less half of the inflow shall be the groundwater development potential in each hydrogeological basin, 5) the total of artificially exploited volume from wells and spring discharge is the outflow in the balance analysis.

As a result, the balance of apparent groundwater development potential by basin is estimated as follows (unit: million m³/year).

٠	Tarrafal Basin (A) and (B)	2.695
•	Santa Cruz Basin (A), (B), and (C)	-0.976
•	Santa Catarina Basin	-0.051
•	Sao Joao Baptista Basin	0.581
•	Praia Basin	0.226

These figures suggest that a high volume of groundwater can be developed in basins showing positive values. On the contrary, groundwater discharge is observed to be excessive in areas showing negative values. If the present total volume of groundwater discharge is continued, a marked drawdown in well water level or extensive seawater intrusion into the wells are foreseen to occur.

Nonetheless, it is without a doubt that groundwater resources in the Island are limited due to decreasing rainfall amount in the past 3 decades. Therefore, policies for water use prioritization, e.g. allocating some of the water amount currently used for irrigation for domestic use, should be taken by accelerating the use of sound irrigation methods, especially in areas where groundwater development potential is apparently negative or groundwater resources are scarce.

3) Groundwater development plan

The groundwater development plan was established according to the projected water demand for 2003, for 32 of the villages and entails the construction of borehole wells. The water demand projected for 2005 is estimated at 400m³ a day by multiplying the unit supply amount of 20 liters/capita/day by the total population of 32 villages in 2003 (20,000). (The effective use of springs was planned for 2 of the 34 villages; new sources will not be developed in these 2 villages.)

Although majority (26) of the 32 villages are located in the hydrogeological basins of Santa Cruz and Santa Catarina where the potential for the development of groundwater resources is negative, these villages were chosen in view of the absolute shortage of the supply sources and in expectation of the following:

 Groundwater can be exploited even in areas with negative potential, so long as rainfall continues and the amount to be developed for water supply is insignificant when compared with annual rainfall

- Groundwater currently obtained from wells for irrigation is 3 times bigger than the amount allocated for domestic use in the concerned area
- The national policy on the use of sound irrigation methods will be accelerated especially by reducing the unit cost of water for irrigation in accordance with the reduction of water volume for irrigation

8.1.4 Project Formulation Plan

1) Phased project implementation plan

In Santiago Island, 59 villages (classified under "A") urgently require the implementation of the project, followed by 63 villages (classified under "B"). Since it is almost impossible to cover these villages in one project, "A" and "B" were each sub-divided into 2 groups and the 4 phases for project implementation was planned as shown below.

Phase 1 34 villages (32 from *Group A-1* and 1 each from *A-2* and *B-1*)

Phase 2 29 villages (26 from Group A-2 and 3 from Group B-1)

Phase 3 29 villages (from *Group B-1*)

Phase 4 30 villages from Group B-2

Phase I entails a concrete water supply facility/services improvement plan for villages with a shortage in water supply sources, and where water source development is feasible.

An outline of the facilities/services to be improved from the 2rd to the 4th phase was made.

2) Outline of the Phase 1 project

The phase 1 project will cover 34 of the villages mostly in *Group A-1* and aims to meet the water demand in 2003 by constructing water supply facilities in all of the candidate villages assuming that the mediocrity of existing supply services is due mainly to the shortage of water sources. In order to meet the total water demand of the 34 villages in 2003, approximately 400m³/day will be produced in this project through the construction of 30 wells (total drilling depth of about 4,300m, provide water to 31 villages), effective use of 1 existing well, and establishment of a conveyance system from 2 spring spots. 31 wells will be equipped with submersible motor pump energized by a diesel engine generator (25) and solar panels (6). Water conveyance systems from the spring will consist of 1 pump-up and 1 natural flow type. Other major facilities to be installed for the 34 villages are 11 reservoir tanks, 56 sets of public faucets, about 20,000m transmission/distribution pipe, and 32 sets of energy control panel with a shed.

The direct construction cost for the above facilities is estimated at 4.62 million dollars.

The implementation of the phase 1 project will provide 10 villages (total population: about 5,000 in 2003) with water supply services, and 24 villages (total population: about 15,000 in 2003), will have an increase in their water supply amount, from 8.9 1/c/d on average to 20 1/c/d. The residents of the 34 villages (total population of 20,000 in 2003) will be the direct beneficiaries of the project.

24 villages are currently receiving a total daily water amount of 130m³ through the tank lorry transportation/delivery service. If this amount is applied to other villages to supply sufficient water, the indirect beneficiaries of this project will range from 10,000 to 20,000, resulting in a total of at least 30,000 beneficiaries.

3) Outline of projects from phase 2 to 4

The villages to be covered from Phase 2 to 4 will be 88, each phase targeting the years 2005, 2007 and 2009, respectively. Since some of the villages will indirectly benefit from the Phase 1 project, the number of villages classified under Group A-2, B-1 and B-2, will vary, especially affecting villages requiring the planning of a more appropriate transportation service. Among the 88 villages, the availability of new water sources for development by well (12) construction and spring water conveyance (28) is limited in 40 villages. Existing well rehabilitation or pump replacement will be carried out in 16 villages.

For the remaining 32 villages, the only means of increasing the water supply volume is transportation by tank lorries. The rotation schedule of the tank lorry should be rearranged during and after the phase 1 project implementation.

With regard to facilities, a new reservoir tank will be installed or the existing tank capacity will be increased for 9 nine villages, and the villages where public faucet construction is required assuming 2 sets each in the community counts for 50 villages.

The total direct construction cost from phase 2 to 4 is estimated at US\$ 3.28 million, and the total project cost including administrative and engineering cost is estimated at US\$ 4.43 million, including the procurement of 5 tank lorries.

8.1.5 Project Evaluation

Project evaluation in Chapter 7 indicates that the proposed Project is expected to yield various kinds of benefits, which will justify the earlier implementation of the Project. In consideration of the financial status of the government of Cape Verde, however, the recovery of initial investment costs will be quite difficult. Under such a situation, financial assistance from foreign sources will be indispensable. External assistance in terms of grant aid will be necessary to cover the entire foreign currency portion and a part of local currency portion of the Project costs.

8.2 Recommendation

1) Recommendation on groundwater resources conservation

Groundwater in Santiago Island is the only the water supply source in the rural area, and is exploited either through springs or wells. For the sustainable use of groundwater resources for domestic purposes, groundwater exploitation should be carefully controlled, especially since the decline in precipitation in the past decades have restricted groundwater resources.

Since the use of spring water has no adverse impacts on groundwater conservation, other practical ways of using this source should be taken into consideration rather than artificial exploitation by well construction. The inconvenient location of the majority of the springs in this Island, however, limits the amount of spring water used for domestic reasons: less than 2% in volume and less than 8% in number of springs.

The results of the studies seem to indicate the need to conduct a detailed survey on spring development. Also, it is recommended that further developments in long distance conveyance systems for domestic use should be made.

The artificial exploitation of groundwater resources for domestic consumption in the rural area is a very small water amount when compared with the recharge volume by rainwater, different from densely populated urban areas, it would be safe to assume that water for domestic use can be increased. In the rural area, the amount of water used for irrigation is huge, 3 to 4 times the amount for domestic use, somehow causing excessive pumping. Limiting the use of groundwater for irrigation is strongly recommended, therefore, through the introduction of sound irrigation techniques.

2) Recommendations for the operation and maintenance structure

In addition to the absolute shortage in water supply sources, two conditions seriously inconvenience rural water supply operations in Santiago Island. These conditions are: limited service hours and service based on the "cash on delivery" system. These conditions, however, are foreseen to hinder further developments in the social environment and public health, because the residents are very much accustomed to them.

Residents should be able to collect water whenever they need during the day, and freed from any psychological pressure that the economic effects of acquiring a sufficient water amount would inflict.

This may be difficult to realize, however, considering that the municipal administration in charge of rural water supply O/M is suffering from an extreme shortage in manpower.


Therefore, the establishment of a community based autonomous management system and its incorporation into the present O/M structure are recommended.

8,2.1 Recommendation on Establishment of Water Charge Policy


As previously mentioned in section 6-4, money will be collected not as payment for water use but as payment for the O/M of the new water supply facilities, which will be managed by a water association.


The O/M cost to be burdened by the community will depend on the village population, and would widely vary, therefore, from village to vil. ee (from less than ECV1 to more than ECV 5 per 20 liters of water consumed). The huge disparity in the share in the O/M costs is foreseen to result in difficulties in implementing an autonomous management system, as well as difficulties in the management of the municipal department for energy and water.

Therefore, the amount to be paid by the users should be adjusted and the fund management should be properly carried out to keep the municipal water supply office in operation. To solve this issue, a new municipal water charge policy should be established prior to implementation of the Project.



. •





HYDROGEOLOGICAL MAP OF SANTIAGO ISLAND