

Table F.12.1 Outlet of Main Combined Sewer by each Sub-zone

Sub-zone	Type of outlet	Dimension (m)			Area (m ²)	Number
		H	W	D		
Tau Hu - Ben Nghe canal, left bank East side	F-5			0.8	0.63	1
	F-3			1.0	0.79	1
	E-4			1.0	0.79	4
	K-7	1.2	0.8		0.80	2
	K-6	1.4	0.8		0.93	4
	E-3			1.2	0.94	2
	F-2			1.2	0.94	1
	K-5	1.6	0.8		1.07	1
	E-2			1.5	1.18	4
	F-1			1.5	1.18	1
	K-4	1.8	0.8		1.22	1
	E-1			2.0	1.57	1
J-1	2.3	2.1		3.85	1	
Sub total						24
Tau Hu - Ben Nghe canal, left bank West side	B-5	1.0			0.54	1
	A-11	1.0	0.6		0.58	1
	F-5			0.8	0.63	1
	A-10	1.1	0.6		0.64	1
	A-7	1.4	0.6		0.78	1
	F-3			1.0	0.79	1
	K-7	1.2	0.8		0.80	1
	K-6	1.4	0.8		0.93	2
	K-5	1.6	0.8		1.07	1
	F-1			1.5	1.18	1
A-5	1.4	0.8		1.45	1	
Sub total						12
Hung Phu	-			0.4	0.31	1
	-			0.6	0.47	5
	-			0.8	0.63	1
Sub total						7
Tung Thien Vuong	-			0.4	0.31	3
	-			0.6	0.47	10
	-			0.8	0.63	6
	-			1.0	0.79	2
Sub total						21
Rach Ong	-			0.6	0.47	1
	-			0.8	0.63	2
	-			1.0	0.79	2
	-			1.2	0.94	1
Sub total						6
Pham The Hien	-			0.8	0.63	1
	Sub total					
Khanh Hoi	-			0.4	0.31	16
	-			0.5	0.39	2
	-			0.6	0.47	2
	-			0.8	0.63	5
	-			1.0	0.79	5
	K-6	1.4	0.8		0.93	1
	-	2.0	3.0		6.00	1
Sub total						32
Grand total						103

Table F.13.1(1/2) Comparison of Conveyance Route Study

Item	Description		Route A	Route B	Route C
	Main Feature	Length (km)	0.8 km	1.0 km	1.3 km
Canal Crossing	Construction Method	Pipe Jacking & Shield Tunneling	Pipe Jacking & Shield Tunneling	Pipe Jacking & Shield Tunneling	Pipe Jacking & Shield Tunneling
	Advantage	<ul style="list-style-type: none"> - Shortest distance - 1 place of canal crossing 	<ul style="list-style-type: none"> - Little traffic along Tran Tuan Khai road - Sufficient space for work yard is available 	<ul style="list-style-type: none"> - 1/2 of the total length running under the Chanh Hung road 	
	Disadvantage	<ul style="list-style-type: none"> - Difficulty with construction of conveyance near to the Y Bridge - Heavy traffic along Nguyen Bieu road which will be occupied for a vertical shaft - Available space for work yard is limited 	<ul style="list-style-type: none"> - 2 places of canal crossing 	<ul style="list-style-type: none"> - Longest distance - 2 places of canal crossing 	
	Evaluation	<p>Work yard</p> <p>Workability</p> <p>Sub-Total</p>	<p>1</p> <p>2</p> <p>3</p> <p>6.45 km</p>	<p>3</p> <p>3</p> <p>6</p> <p>5.40 km</p>	<p>2</p> <p>2</p> <p>4</p> <p>5.55 km</p>
Conveyance Route from PS to WTP	Main Feature	Total Length (km)	6.45 km	5.40 km	5.55 km
	Existing Condition along the Route	<p>Existing Road</p> <p>Paddy Field</p> <p>Same Stretch</p> <p>Paddy Field</p> <p>River Crossing</p>	<p>3.27 km</p> <p>0.53 km</p>	<p>2.22 km</p> <p>0.53 km</p> <p>2.50 km</p> <p>2 places</p> <p>0.10 km + 0.05 km = 0.15 km</p>	<p>2.90 km</p> <p>-</p>
	Advantage	-	-	- Shortest distance to WTP	<ul style="list-style-type: none"> - 52 % of the total length running under the existing main road - Shorter distance - Little interference with installation of conveyance along Pham The Hiem road which has heavy traffic with a wide width of about 15 m
	Disadvantage	<ul style="list-style-type: none"> - Longest distance to WTP - Difficulty with installation of conveyance with Open Cut Method along Pham The Hiem road which has heavy traffic with a narrow width of about 7 m - Running across paddy field with a length of approx. 3 km. 	<ul style="list-style-type: none"> - Running across paddy field with a length of Approx. 3 km 	<ul style="list-style-type: none"> - Running across paddy field with a length of Approx. 3 km - Far from the 1st priority area 	
Evaluation	Workability	2	2	3	2
	Sub-Total	2	2	3	2

Table F13.1(2/2) Comparison of Conveyance Route Study

Item	Description			Route A	Route B	Route C
	Main Feature	Existing Land Use Land Condition	Available Space (ha)	Da Nam Park Park approx. 0.4 ha Residential Area	Open Space Wetland approx. 2 ha Open Space	Open Space Wetland approx. 0.5 ha Residential Area
Pumping Station	Advantage	Character of Neighborhood		<ul style="list-style-type: none"> Main roads are running around the site Invert level is shallower than other PSs because of shorter distance to downtown 	<ul style="list-style-type: none"> Shortest distance Less impact upon the surroundings No constraint on layout of PS because of larger available area 	<ul style="list-style-type: none"> Sufficient area is available
	Disadvantage			<ul style="list-style-type: none"> The site is being utilized as a memorial park Surroundings are residential area. Cast in situ diaphragm wall may be applied due to a limit of work space Restoration work is necessary. 	<ul style="list-style-type: none"> Improvement of land condition and a access road to PS are necessary 	<ul style="list-style-type: none"> Improvement of land and newly developed areas. The area is next to a school and football stadium.
Evaluation	Land Acquisition			2	3	2
	Construction Method and Cost			1	2	2
	Restoration Work			1	2	2
	Advantage over O/M			2	3	2
	Sub-Total			6	10	8
Total				11	19	14

Table F.15.1 Comparative Study of Design Criteria for Wastewater Treatment

Source	Conventional Activated Sludge Process			Effluent Disinfection
	Primary Sedimentation	Aeration Tank	Secondary Sedimentation	
Wastewater Engineering (Metcalf/Eddy Inc.)	Overflow Rate: $32 \sim 48 \text{ m}^3 / \text{m}^2 \cdot \text{d}$ Removal Efficiency: BOD: 25-40% SS: 50-70% Bacteria: 25-70%	MLSS: 1200 ~ 3000 mg/l FM ratio: 0.2 ~ 0.4 Recirculation Ratio: 0.2 ~ 0.75 HTR: 4 ~ 8 hr Volumetric Loading $0.32 \sim 0.64 \text{ kg} \cdot \text{BOD} / \text{m}^3 \cdot \text{d}$	Overflow Rate $16 \sim 33 \text{ m}^3 / \text{m}^2 \cdot \text{d}$ Solid loading $3.9 \sim 5.9 \text{ kg} / \text{m}^2 \cdot \text{hr}$	Typical Chlorine Dosage Raw Wastewater: $6 \sim 25 \text{ mg} / \text{l}$ Primary Effluent: $5 \sim 20 \text{ mg} / \text{l}$ Activated sludge Effluent: $2 \sim 8 \text{ mg} / \text{l}$ Filtered Effluent: 1-5 mg/l
WEF Manual & ASCE Manual	—	MLSS: 1500-3000 mg/l FM ratio: 0.2 ~ 0.4 Recirculation Ratio: 0.2 ~ 0.5 HTR: 4 ~ 8 hr Volumetric Loading $0.3 \sim 0.6 \text{ kg} \cdot \text{BOD} / \text{m}^3 \cdot \text{d}$	Overflow Rate $16 \sim 29 \text{ m}^3 / \text{m}^2 \cdot \text{d}$ Solid loading $4 \sim 6 \text{ kg} / \text{m}^2 \cdot \text{hr}$	—
Japanese Design Manual	Overflow Rate $25 \sim 50 \text{ m}^3 / \text{m}^2 \cdot \text{d}$ Removal Efficiency BOD: 30% SS: 40%	MLSS: 1500-2000 mg/l BOD-SS Loading: 0.2 ~ 0.4 Recirculation Ratio: 0.25 ~ 0.4 HTR: 6 ~ 8 hr Volumetric Loading: $0.3 \sim 0.8 \text{ kg} \cdot \text{BOD} / \text{m}^3 \cdot \text{d}$	Overflow Rate: $20 \sim 30 \text{ m}^3 / \text{m}^2 \cdot \text{d}$	Activated sludge Effluent: $2 \sim 4 \text{ mg} / \text{l}$ Nos. of Fecal Coli. $< 3,000 \text{ per cm}$
Cerro de la Estrella (WWTP in Mexico DF)	Overflow Rate: $48 \text{ m}^3 / \text{m}^2 \cdot \text{d}$ Design Removal Efficiency BOD: 13% SS: 49%	MLSS: 1650 mg/l BOD-SS Loading: 0.35 Recirculation Ratio: 0.25 Return Sludge Concentration: 8,000 mg/l	Overflow Rate: $36 \text{ m}^3 / \text{m}^2 \cdot \text{d}$	

Table F.15.2(1/2) Comparative Study of Design Criteria for Sludge Treatment

Source	Gravity Thickening				Centrifugal Thickening	Anaerobic Digestion	Lime Stabilization
	Type of Sludge	Feed Solids Concentration	Thickened Sludge Concentration	Solid Loading (kg/m ² ·d)			
Wastewater Engineering (Metcalf/Eddy Inc.)	Primary (PRI)	2-7 %	5-10%	89-136	Thickened Concentration: 4-6%	Solids Residence Time: for 24°C - 20 days for 30°C - 14 days for 35°C - 10 days for 45°C - 10 days	Typical Lime Dosage for stabilizing liquid sludge Ca (OH)2 /dry solids for PRI 0.12 ~ 0.34 for AS 0.42 ~ 0.86
	Trickling Filter (T/F)	1-4 %	3-6%	34-49			
	PRI + T/F	2-6 %	4-9%	59-98			
	PRI + Activated sludge (AS)	2-5 %	2-8%	39-78			
	AS + T/F	0.5-2.5 %	2-4%	12-34			
WEF Manual & ASCE Manual	Primary (PRI)	2.0 ~ 7.0%	5.0 ~ 10%	97-145	Thickened Concentration: (Reported operating results) 1.8 ~ 10%	Solids Residence Time: 20 days	Pilot study determination of lime dosage Ca (OH)2 /dry solids for PRI 0.10 ~ 0.15 for AS 0.30 ~ 0.50
	Trickling Filter (T/F)	1.0 ~ 4.0%	3.0 ~ 6.0%	69-48			
	PRI + iron	2.0%	4.0%	29			
	PRI + T/F	2.0 ~ 6.0%	5.0 ~ 9.0%	58-97			
	PRI + AS	0.5 ~ 1.5%	4.0 ~ 6.0%	24-68			
AS + TF	1.8%	2.0 ~ 4.0%	19-34				
	(PRI + iron) + AS		3.6%	29			
	Overflow Rate for PRI Sludge: 16 ~ 32 m ³ / m ² · d						
Japanese Design Manual	Thickened Solids Concentration: 2.0 ~ 4.0% Solids Loading: 60 ~ 90 kg/m ² · d Effective Depth: 4.0m						
	Thickened Concentration: 4%					Detention Time: 20 days (operating temperature 30°C ~ 35 °C)	

Table F.15.2(2/2) Comparative Study of Design Criteria for Sludge Treatment

Source	Mechanical Dewatering (Belt filter press)				Open Drying Bed		Drying Lagoon
	Type of Sludge	Feed Solids (%)	Cake Solids (%)	Loading per belt width (kg/hr · m)	Type of Sludge	Solids Loading Rate (kg/m ² · Yr)	
Wastewater Engineering (Metcalf/Eddy Inc.)	PRI	3-7	28-44	-	PRI	122-146	- Not suitable for untreated sludges/limed sludges - Sludge depth: 0.75-1.25m - Solids Loading: 36-39 kg/m ² yr - Typical cycle time: 2 years
	PRI + AS	3-6	20-35	-	PRI + TF digested	88-122	
	PRI + TF	3-6	20-35	-	PRI + AS digested	59-98	
	AS	1-4	12-20	-	PRI + chemical coagulation	98-161	
	Anaerobically Digested (PRI + AS)	3-6	20-25	-	Corresponding area for covered beds Vary from 70 to 75% of open beds		
WEF Manual & ASCE Manual	PRI	3-7	28	360-550	Type of sludge	Solids Loading Rate (kg/m ² · Yr)	---
	PRI + AS	3-6	23	180-320	PRI digested	134	
	PRI + TF	3-6	25	180-320	PRI + TF digested	110	
	AS	1-4	15	45-180	PRI + AS digested	73	
	Anaerobically Digested (PRI + AS)	3-6	22	180-320	PRI + chemical coagulation	110	
	AS	3-4	15	45-135			
Japanese Design Manual	Cake Solids Concentration: 25% Operation Results: - loading per meter belt width: 90 ~ 150 kg/hr - cake solids 20 ~ 25%				$A = QT/D$ where, A: drying bed area (m) Q: sludge volume feeded (m ³ / d) D: thickness of feeded sludge (m) 0.15-0.25 T: drying duration (days) 15 ~ 20		---

Table F.16.1 Sewerage Tariff Collection Efficiency

HHs/office by type	District									Total
	Q-1	Q-3	Q-4	Q-5	Q-6	Q-8	Q-10	Q-11	Tan Binh	
Area (ha)	760.0	480.0	400.0	417.1	700.0	1,880.0	570.0	500.0	3,850.0	
Gross Number of HHs, Offices and Institutions by Type										
Households	57,760	53,635	37,620	51,736	56,572	70,362	52,923	49,712	126,723	557,043
Governmental offices	129	124	58	54	44	62	48	75	69	663
Industrial establishments	375	763	523	1,421	2,754	1,137	973	3,274	3,828	15,048
Commercial enterprises	1,009	473	104	516	181	173	304	277	389	3,426
Cultural facilities	13	6	2	2	4	0	3	4	1	35
Medical facilities	337	194	78	158	107	71	225	188	319	1,677
Educational facilities	66	70	40	57	38	47	52	49	112	531
Density (Number/ha)										
Households	76.000	111.740	94.050	124.037	80.817	37.427	92.847	99.424	32.915	
Governmental offices	0.170	0.258	0.145	0.129	0.063	0.033	0.084	0.150	0.018	
Industrial establishments	0.493	1.590	1.308	3.407	3.934	0.605	1.707	6.548	0.994	
Commercial enterprises	1.328	0.985	0.260	1.237	0.259	0.092	0.533	0.554	0.101	
Cultural facilities	0.0171	0.0125	0.0050	0.0048	0.0057	0.0000	0.0053	0.0080	0.0003	
Medical facilities	0.443	0.404	0.195	0.379	0.153	0.038	0.395	0.376	0.083	
Educational facilities	0.087	0.146	0.100	0.137	0.054	0.025	0.091	0.098	0.029	
Ranking Points										
Households	3	8	6	9	4	2	5	7	1	
Governmental offices	8	9	6	5	3	2	4	7	1	
Industrial establishments	1	5	4	7	8	2	6	9	3	
Commercial enterprises	9	7	4	8	3	1	5	6	2	
Cultural facilities	9	8	4	3	6	1	5	7	2	
Medical facilities	9	8	4	6	3	1	7	5	2	
Educational facilities	4	9	7	8	3	1	5	6	2	
Total points	43	54	35	46	30	10	37	47	13	
Ranking Points Adjusted by Recommended Tariff										
Households	3	8	6	9	4	2	5	7	1	
Governmental offices	15	16	11	9	5	4	7	13	2	
Industrial establishments	2	9	7	13	15	4	11	16	5	
Commercial enterprises	37	29	16	33	12	4	20	25	8	
Cultural facilities	16	15	7	5	11	2	9	13	4	
Medical facilities	16	15	7	11	5	2	13	9	4	
Educational facilities	7	16	13	15	5	2	9	11	4	
Adjusted total points	96	108	68	95	58	19	75	94	27	
Weighted points	65	12	60	95	13	7	38	28	1	

Note : Adjustment factors-

12,500 (VND for households)

51,100 (VND for Commercial enterprises)

22,800 (VND for industrial establishments and others)

Table F.16.2 Sewerage Tariff Collection Efficiency Presented by Point

Sub-zone	District									Total	
	Q-1	Q-3	Q-4	Q-5	Q-6	Q-8	Q-10	Q-11	Tan Binh		
East part of left bank of Ben Nghe canal											
1	17										17
2	18	0									18
3	3										3
4	9										9
5	8	1									10
6	6										6
7	3	10		17				12			42
8	1			8							9
9				8				1			9
10				5							5
Sub-total	65	12	0	38	0	0	12	0	0	0	127
West part of left bank of Tau Hu canal											
11				9				5			14
12				3							3
13				30				17	3		50
14				13	1			3	14	0	32
15				1	3				10	1	15
16					9						9
Sub-total	0	0	0	56	13	0	25	28	1	1	123
Isolated area by Tau Hu, Ben Nghe - Doi, Te canals											
Khanh Hoi				59							59
Ong Kieu				1							1
Hung Phu							1				1
Tung Thien Vuong							1				1
Binh Dong							0				0
Sub-total	0	0	60	0	0	2	0	0	0	0	62
Souther area of Doi, Te canal											
Ranch Ong							1				1
Phan The Hien							2				2
Bing Dang							2				2
Sub-total	0	0	0	0	0	0	5	0	0	0	5
Total	65	12	60	95	13	7	38	28	1	1	318

Table F.17.1(1/2) Project Cost of Each Wastewater Treatment Process

(Unit : million VND)

No.	Process	Effluent BOD ₅ (mg/L)	Classification	Work Item	Construction Cost (DCB)	Total Construction Cost ³ (DC)	Land Acquisition Cost ⁴ (LC)	Engineering Cost DC x 0.07	Administration Cost (DC+LC) x 0.01	Physical Contingency DC x 0.1	Total Project Cost
1	Stabilization Pond and Drying Bed	50	(I) Direct Cost	Civil	332,557	624,282	19,500	43,700	9,657	62,428	759,566
				Building	19,199						
				Mechanical	32,448						
				Electricity	21,174						
				Others	48,645						
(II) Indirect Cost ¹⁾	113,506										
(III) Head Office Expenses ²⁾	56,753										
2	Aerated Lagoon and Drying Bed	50	(I) Direct Cost	Civil	278,561	601,034	19,500	42,072	9,308	60,103	752,018
				Building	19,199						
				Mechanical	46,203						
				Electricity	49,835						
				Others	43,318						
(II) Indirect Cost ¹⁾	109,279										
(III) Head Office Expenses ²⁾	54,639										
3	Primary Sedimentation + Stabilization Pond and Drying Bed	50	(I) Direct Cost	Civil	321,811	622,170	19,500	43,552	9,625	62,217	757,064
				Building	19,199						
				Mechanical	41,438						
				Electricity	21,558						
				Others	48,481						
(II) Indirect Cost ¹⁾	113,122										
(III) Head Office Expenses ²⁾	56,561										
4	Modified Activated Sludge and Belt Press Filter	50	(I) Direct Cost	Civil	286,094	691,761	19,500	48,423	10,669	69,176	839,529
				Building	59,333						
				Mechanical	75,392						
				Electricity	49,367						
				Others	32,913						
(II) Indirect Cost ¹⁾	125,775										
(III) Head Office Expenses ²⁾	62,887										

Table F.17.1(2/2) Project Cost of Each Wastewater Treatment Process

Treatment Capacity : 141,000 m³/day
 BOD₅ in : 180 mg/L

(Unit : million VND)

No.	Process	Effluent BOD ₅ (mg/L)	Classification	Work Item	Construction Cost (DC _r)	Total Construction Cost ³⁾ (DC)	Land Acquisition Cost ⁴⁾ (LC)	Engineering Cost DC x 0.07	Administration Cost (DC+LC)x0.015	Physical Contingency DC x 0.1	Total Project Cost
S-1	Conventional Activated Sludge and Drying Bed	20	(I) Direct Cost	Civil	535,459	1,001,241	19,500	70,087	15,311	100,124	1,206,263
				Building	19,199						
				Mechanical	77,996						
				Electricity	54,303						
				Others	41,217						
(II) Indirect Cost ¹⁾	182,044										
			(III) Head Office Expenses ²⁾		91,022						
S-2	Conventional Activated Sludge and Belt Press Filter	20	(I) Direct Cost	Civil	412,239	902,332	19,500	63,163	13,827	90,233	1,089,056
				Building	59,333						
				Mechanical	88,284						
				Electricity	59,240						
				Others	37,146						
(II) Indirect Cost ¹⁾	164,060										
			(III) Head Office Expenses ²⁾		82,030						
S-3	Primary Sedimentation and Drying Bed	125	(II) Indirect Cost ¹⁾	Civil	243,006	496,941	19,500	34,786	7,747	49,694	608,668
				Building	19,199						
				Mechanical	64,801						
				Electricity	18,057						
				Others	16,350						
(III) Head Office Expenses ²⁾	90,353										
			(III) Head Office Expenses ²⁾		45,176						

(Remarks)

- 1) Temporary works and cost of safety and sanitary control : 25 % of (I) Direct cost
- 2) { (I)+(II) } x 10 %
- 3) (I) + (II) + (III)
- 4) Land acquisition of fish pond, so estimate the same cost as farmland (39,000 VND/m²)

Table F.17.2 Power Equipment Comparison in Phase I

Treatment Capacity : 141,000 m³/day
 BOD₅ in : 180 mg/L

(Unit : million VND)

No.	Process	Effluent BOD ₅ (mg/L)	Main Equipment	Required Power (kW)					Total
				Normal	Building	Central Control	Outdoor Lighting	Others	
1	Stabilization Pond and Drying Bed	50	Lifting Pump	800	120	0	300	50	1,270
2			Lifting Pump	800	120	0	200	50	2,989
	Aerated Lagoon and Drying Bed	50	Aerator	1,800					
			Sludge Pump	19					
3	Primary Sedimentation + Stabilization Pond and Drying Bed	50	Lifting Pump	800	120	0	300	50	1,293
4			Sludge Pump	23	120	40	60	50	3,346
	Modified Activated Sludge and Belt and Belt Press Filter	50	Lifting Pump	800	120				
			Blower	1,760					
			Sludge Pump	415.4					
			Dewatering	101					
S-1	Conventional Activated Sludge and Drying Bed	20	Lifting Pump	800	120	40	60	50	3,257
			Blower	1,760					
			Sludge Pump	427					
S-2	Conventional Activated Sludge and Belt Press Filter	20	Lifting Pump	800	120	40	60	50	3,407
			Blower	1,760					
			Sludge Pump	435					
			Dewatering	142					
S-2	Primary Sedimentation and Drying Bed	125	Lifting Pump	800	120	20	60	50	1,083
			Sludge Pump	33					

Note : Aerated Lagoon, Conventional and Modified Activated Sludge Process will need High Voltage Intake Sub-Station.

Table F.17.3 Comparison of Maintenance Cost by Alternatives

No.	Process	Effluent BOD ₅ (mg/L)	Power Consumption			Chemicals Cost						Total Cost (million VND/day)
			Required Power ¹⁾ (kW/day)	Unit cost (VND/kWh)	Cost (million VND/day)	Chlorine ²⁾ (kg/day)	Unit cost (VND/kg)	Cost (million VND/day)	Polymer ³⁾ (kg/day)	Unit cost (VND/kg)	Cost (million VND/day)	
1	Stabilization Pond and Drying Bed	50	24,384	700	17.1	423	7,000	2.961	0	75,000	0	20.0
2	Aerated Lagoon and Drying Bed	50	57,389	700	40.2	423	7,000	2.961	0	75,000	0	45.1
3	Primary Sedimentation + Stabilization Pond and Drying Bed	50	24,826	700	17.4	423	7,000	2.961	0	75,000	0	20.4
4	Modified Activated Sludge and Belt Press Filter	50	62,074	700	43.5	423	7,000	2.961	237	75,000	17.8	64.3
S-1	Conventional Activated Sludge and Drying Bed	20	62,534	700	43.8	423	7,000	2.961	0	75,000	0	46.8
S-2	Conventional Activated Sludge and Belt Press Filter	20	65,318	700	45.7	423	7,000	2.961	300	75,000	22.5	71.2
S-3	Primary Sedimentation and Drying Bed	125	20,794	700	14.6	423	7,000	2.961	0	75,000	0	17.6

(Remarks)

- 1) Supply power x 0.8
- 2) 3 mg/L as chlorine
- 3) 1 % to solid of sludge

Table F.17.4 FEATURES OF WASTEWATER TREATMENT PROCESS

Alternative No.	1	2	3	4	S-1	S-2	S-3
	Stabilization Pond and Drying Bed	Aerated lagoon and Drying Bed	Primary Sedimentation and Stabilization pond	Modified Activated sludge and Belt Press Filter	Conventional Activated sludge and Drying Bed	Conventional Activated sludge and Belt Press Filter	Primary Sedimentation and Drying Bed
Effluent BOD ₅ (mg/L)	50	50	50	50	20	20	125
Construction Cost	Moderate	Moderate	Relatively high	Relatively High	Highest	High	Cheapest
Facility Maintenance	Easy *Need algae removal in facultative pond	Relatively easy *Need maintenance of aerators	Relatively easy *Need maintenance of sludge pumps *Need algae removal in facultative pond	Not easy *Need expert for maintenance blower, sludge pumps and belt press filter	Not easy *Need expert for maintenance blower and sludge pumps	Not easy *Need expert for maintenance blower, sludge pumps and belt press filter	Relatively Easy *Need maintenance of sludge pumps
Operation Technology	Easy	Relatively easy *Need D.O check *Need sludge treatment after three years	Easy	Not easy *Need experts for maintenance of MLSS, solid separation, D.O check, sludge return and polymer for dewatering	Not easy *Need experts for maintenance of MLSS, solid separation, D.O check and sludge return	Not easy *Need experts for maintenance of MLSS, solid separation, D.O check, sludge return and polymer for dewatering	Relatively Easy
Power Consumption	Small	Relatively big *May need special high voltage intake facility.	Small	Relatively Big *May need special high voltage intake facility.	Big *May need special high voltage intake facility.	Biggest *May need special high voltage intake facility.	Smallest
Required Area	Very large	Large	Large	Small	Moderate	Small	Smallest
Possibility of Higher Effluent Quality	Impossible *No space left in any pond	Impossible *No space left in any pond	Impossible *No space left in any pond	Easy *Need expansion of facilities	Very Easy	Very Easy	Not easy *Need aeration tank and Secondary Sedimentation
Excess Sludge	Very small	Relatively big	Relatively small	Large	Large	Large	Relatively Small
Adaptability to Valuation	Moderate *Weaker to toxic due to anaerobic process *Strong to quantity change	Moderate *Weaker to toxic *Strong to quantity change	Moderate *Weaker to toxic due to anaerobic process *Strong to quantity change	Weak *Need thickener and belt press *Weak to change of quantity and quality due to short retention time	Weak *Need thickener *Weak to change of quantity and quality due to short retention time	Weak *Need thickener and belt press *Weak to change of quantity and quality due to short retention time	Weak *Weak to change of quantity and quality due to short retention time
Effluent Quality	Moderate	Moderate	Moderate	Moderate	Good	Good	Not good
Environmental Aspect	*Smell may occur in anaerobic pond and drying bed *Aeration may need to prevent odor in facultative pond once or twice a day. *Algae flowout	*Noise of aerator and smell in drying bed *Algae flowout	*Smell may occur in anaerobic pond *Aeration may need to prevent odor in facultative pond once or twice a day. *Algae flowout	*Noise of belt press	*Smell in drying bed	*Noise of belt press	*Smell in drying bed *Smell of effluent
Initial Performance	Very Bad *Need two or three month operation due to natural bio-process *Need almost parts of land to be developed again	Bad *Need two or three month operation due to natural bio-process *Need almost parts of land to be developed and sludge tank again. *Aerators for this process are no use in A.S.	Very Bad *Need two or three month operation due to natural bio-process *Need almost parts of land to be developed again	Good *Only after two weeks, the process can give regular performance by seeding. *Easy to construct same structure and facilities without re-building sludge storage tank thickener and Dewatering room. *Part of roads should be re-built.	Good *Only after two weeks, the process can give regular performance by seeding. *Easy to construct same structure and facilities without re-building sludge storage tank thickener and Dewatering room. *Part of roads should be re-built.	Good *Only after two weeks, the process can give regular performance by seeding. *Easy to construct same structure and facilities without re-building sludge storage tank thickener and Dewatering room. *Part of roads should be re-built.	Good *Only physical process *Need aeration tanks and Secondary sedimentation. *No need of rebuilding sludge storage tank *Part of roads should be re-built. *Sludge treatment facilities are necessary.
Smoothness of switching to Conventional Activated Sludge Process with bigger capacity in the final stage.							

Table F.17.5 Evaluation of Wastewater Treatment Process

Alternative No.	1 Stabilization Pond and Drying Bed	2 Aerated lagoon and Drying Bed	3 primary Sedimentatio and Stabilization pon and Drying Bed	4(1) onventional Activate Sludge + Drying Bed	4(2) onventional Activate Sludge + Belt Press Filter	5 primary Sedimentatio and Drying Bed	6 Modified Activated Sludge + Belt Press Filter
Effluent BOD ₅ (mg/L)	50	50	50	20	20	125	50
Construction Cost / Removal BOD ₅	4	6	5	1	2	0	3
Facility Maintenance	5	4	5	3	2	4	2
Operation technology	5	3	4	2	1	4	1
Maintenance Cost	5	3	4	2	0	6	1
Required Area	0	2	1	3	5	4	6
Possibility of higher effluent quality with expansio	0	1	0	5	6	2	4
Excess Sludge generation	6	3	4	1	1	4	2
Adaptability to validation	3	4	3	2	2	3	2
Effluent quality	4	4	4	6	6	1	4
Environmental Aspect	2	3	2	4	5	1	4
Initial Performance	1	2	1	5	5	6	5
Smoothness of switching to conventional activated Sludge process with bigger capacity in the final sta	0	1	1	4	6	2	5
Total Evaluation	35	36	34	38	41	37	39
Conclusive Order	⑥	⑤	⑦	③	①	④	②

(Remark) As for the figures above, larger is better except conclusive order.

Table F.17.6 Evaluation of Wastewater Treatment Process

(1) Activated sludge processes are superior to pond processes such as Stabilization Pond, Aerated Lagoon and Stabilization Pond system after primary sedimentation, conclusively.

(2) Construction Cost per BOD₅ Removal

In alternative study, three kinds of effluent BOD₅ are proposed, namely 20 mg/L for Conventional activated sludge process, 50 mg/L for stabilization pond, aerated lagoon, primary sedimentation + stabilization pond, modified activated sludge and 125 mg/L for primary sedimentation.

To compare investment efficiency of each process, construction cost per BOD₅ removal is calculated as below.

- Wastewater Treatment Plant in the Phase I 141,000 m³/day
- Inflow BOD₅ 180 mg/L

Construction cost per BOD₅ Removal

Wastewater Treatment Process	BOD ₅ out (mg/L)	BOD ₅ Removed (kg/day)	Construction Cos (million VND)	Construction Cost per BOD ₅ Removal (million VND/kg-BOD ₅ /day)
Stabilization Pond Process and Drying Bed	50	18,330	624,282	34.1
Aerated Lagoon Process and Drying Bed	50	18,330	601,034	32.8
Primary Sedimentation + Stabilization Pond Process and Drying Bed	50	18,330	622,170	33.9
Conventional Activated Sludge Process and Drying Bed	20	22,560	1,001,241	44.4
Conventional Activated Sludge Process and Belt Press	20	22,560	902,332	40.0
Primary Sedimentation and Belt Press	125	7,755	496,941	64.1
Modified Activated Sludge Process and Belt Press	50	18,330	691,761	37.7

- 1) In the point of investment efficiency towards BOD₅ removal, Primary sedimentation is the worst in the Phase I. Pond processes such as Stabilization pond and aerated lagoon process are superior to conventional activated sludge, but expansion of the facilities to the final stage is difficult due to the limitation of available land.
- 2) Investment efficiency of conventional activated sludge process with belt press is higher than that with drying bed.
- 3) Cost efficiency to BOD₅ removal of the modified activated sludge process with effluent quality of 50 mg/L in terms of BOD₅ is not so much different from that of pond processes.

Recommended wastewater process for the Phase I

Based on the following aspects, modified activated sludge process and belt press filter with design effluent quality of 50 mg/L in terms of BOD₅ is recommended for the Phase I

- (1) From the economical view, the process of primary sedimentation and pond processes are superior to conventional activated sludge process. However, the process of only primary sedimentation is the worst in cost efficiency to BOD₅ removal and the pond processes can't expand the capacity both in quantity and quality. That means the pond processes need dual investment in the final stage. Adding to this, the pond processes have the smell problem in common. Furthermore, the pond processes, if once the bacteria to purify organic matters are killed, more than two or three months will be necessary to recover the performance. As for activated sludge process, maximum two weeks are necessary.
- (2) Therefore, activated sludge process should be recommended from the points of environmental aspects and the flexibility in expanding the facilities in the final stage without dual investment, even though construction and maintenance cost are higher than the pond processes.
- (3) Conventional activated sludge process with drying bed is more economical in maintenance cost but higher in construction cost than that with belt press filter. However, the process with drying bed may cause smell problem from drying bed. Therefore, the conventional process with belt press filter is recommended in environmental aspects.
- (4) Cost efficiency to BOD₅ removal of modified activated sludge process is close to that of pond processes and had flexibility of expanding the capacity both in quantity and quality.




FIG. F.2.1 DISTRIBUTION OF PUBLIC TOILET




FIG. F.2.2 RELEVANT STUDY ON SEWERAGE DEVELOPMENT




Fig. F.3.1 SEPTIC TANK WITH ANAEROBIC UP-FLOW FILTER






Fig. F.3.2 Cross-section of Johkaso



Relation of Population Density and Unit Project Cost
(Eff.BOD : 50 mg/L.)



Relation of Population density and Unit Project Cost
(Eff.BOD 20 mg/L)

FIG. F.3.3 Relation of Population Density and Unit Project Cost







FIG. F.3.4 DIVISION OF PROJECT AREA BY POPULATION DENSITY (FUTURE - 2020)



JICA - Ho Chi Minh City Urban Drainage & Sewerage Project



JICA - Ho Chi Minh City Urban Drainage & Sewerage Project



JICA - Ho Chi Minh City Urban Drainage & Sewerage Project





FIG. F.5.1 ALTERNATIVE I INDIVIDUAL SMALL SCALE TREATMENT SYSTEM



JICA - Ho Chi Minh City Urban Drainage & Sewerage Project




FIG. F.6.1 PROPOSED SEWERAGE DEVELOPMENT




FIG. F.6.2 EXISTING MAIN DRAINAGE PIPE NETWORK





FIG. F.6.3 FLOW CHART OF ACTIVATED SLUDGE PROCESS






FIG. F.6.5 LAYOUT OF TBNDT AND NLTN WASTEWATER TREATMENT PLANTS




FIG. F.6.6 NL-TN SEWERAGE DEVELOPMENT ZONE

JICA - Ho Chi Minh City Urban Drainage & Sewerage Project




FIG. F.6.7 TH - LG SEWERAGE DEVELOPMENT ZONE

JICA - Ho Chi Minh City Urban Drainage & Sewerage Project




FIG. F.6.8 LAYOUT OF THLG WASTEWATER TREATMENT PLANT




FIG. F.6.9 TL-BC SEWERAGE DEVELOPMENT ZONE




FIG. F.6.10 LAYOUT OF THLBC WASTEWATER TREATMENT PLANT




FIG. F.6.11 SW SEWERAGE DEVELOPMENT ZONE

JICA - Ho Chi Minh City Urban Drainage & Sewerage Project




FIG. F.6.12 LAYOUT OF SW WASTEWATER TREATMENT PLANT




FIG. F.6.13 SS SEWERAGE DEVELOPMENT ZONE




FIG. F.6.14 LAYOUT OF SS WASTEWATER TREATMENT PLANT




FIG. F.6.15 SN-1 SEWERAGE DEVELOPMENT ZONE




FIGURE 1-14 Ho Chi Minh City Urban Drainage & Sewerage Project






FIG. F.6.16 LAYOUT OF SN-I WASTEWATER TREATMENT PLANT





1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

FIG. 1. A. B. C. D. E. F. G. H. I. J. K. L. M. N. O. P. Q. R. S. T. U. V. W. X. Y. Z. AA. AB. AC. AD. AE. AF. AG. AH. AI. AJ. AK. AL. AM. AN. AO. AP. AQ. AR. AS. AT. AU. AV. AW. AX. AY. AZ. BA. BB. BC. BD. BE. BF. BG. BH. BI. BJ. BK. BL. BM. BN. BO. BP. BQ. BR. BS. BT. BU. BV. BW. BX. BY. BZ. CA. CB. CC. CD. CE. CF. CG. CH. CI. CJ. CK. CL. CM. CN. CO. CP. CQ. CR. CS. CT. CU. CV. CW. CX. CY. CZ. DA. DB. DC. DD. DE. DF. DG. DH. DI. DJ. DK. DL. DM. DN. DO. DP. DQ. DR. DS. DT. DU. DV. DW. DX. DY. DZ. EA. EB. EC. ED. EE. EF. EG. EH. EI. EJ. EK. EL. EM. EN. EO. EP. EQ. ER. ES. ET. EU. EV. EW. EX. EY. EZ. FA. FB. FC. FD. FE. FF. FG. FH. FI. FJ. FK. FL. FM. FN. FO. FP. FQ. FR. FS. FT. FU. FV. FW. FX. FY. FZ. GA. GB. GC. GD. GE. GF. GG. GH. GI. GJ. GK. GL. GM. GN. GO. GP. GQ. GR. GS. GT. GU. GV. GW. GX. GY. GZ. HA. HB. HC. HD. HE. HF. HG. HH. HI. HJ. HK. HL. HM. HN. HO. HP. HQ. HR. HS. HT. HU. HV. HW. HX. HY. HZ. IA. IB. IC. ID. IE. IF. IG. IH. II. IJ. IK. IL. IM. IN. IO. IP. IQ. IR. IS. IT. IU. IV. IW. IX. IY. IZ. JA. JB. JC. JD. JE. JF. JG. JH. JI. JJ. JK. JL. JM. JN. JO. JP. JQ. JR. JS. JT. JU. JV. JW. JX. JY. JZ. KA. KB. KC. KD. KE. KF. KG. KH. KI. KJ. KK. KL. KM. KN. KO. KP. KQ. KR. KS. KT. KU. KV. KW. KX. KY. KZ. LA. LB. LC. LD. LE. LF. LG. LH. LI. LJ. LK. LL. LM. LN. LO. LP. LQ. LR. LS. LT. LU. LV. LW. LX. LY. LZ. MA. MB. MC. MD. ME. MF. MG. MH. MI. MJ. MK. ML. MM. MN. MO. MP. MQ. MR. MS. MT. MU. MV. MW. MX. MY. MZ. NA. NB. NC. ND. NE. NF. NG. NH. NI. NJ. NK. NL. NM. NN. NO. NP. NQ. NR. NS. NT. NU. NV. NW. NX. NY. NZ. OA. OB. OC. OD. OE. OF. OG. OH. OI. OJ. OK. OL. OM. ON. OO. OP. OQ. OR. OS. OT. OU. OV. OW. OX. OY. OZ. PA. PB. PC. PD. PE. PF. PG. PH. PI. PJ. PK. PL. PM. PN. PO. PP. PQ. PR. PS. PT. PU. PV. PW. PX. PY. PZ. QA. QB. QC. QD. QE. QF. QG. QH. QI. QJ. QK. QL. QM. QN. QO. QP. QQ. QR. QS. QT. QU. QV. QW. QX. QY. QZ. RA. RB. RC. RD. RE. RF. RG. RH. RI. RJ. RK. RL. RM. RN. RO. RP. RQ. RR. RS. RT. RU. RV. RW. RX. RY. RZ. SA. SB. SC. SD. SE. SF. SG. SH. SI. SJ. SK. SL. SM. SN. SO. SP. SQ. SR. SS. ST. SU. SV. SW. SX. SY. SZ. TA. TB. TC. TD. TE. TF. TG. TH. TI. TJ. TK. TL. TM. TN. TO. TP. TQ. TR. TS. TT. TU. TV. TW. TX. TY. TZ. UA. UB. UC. UD. UE. UF. UG. UH. UI. UJ. UK. UL. UM. UN. UO. UP. UQ. UR. US. UT. UV. UW. UX. UY. UZ. VA. VB. VC. VD. VE. VF. VG. VH. VI. VJ. VK. VL. VM. VN. VO. VP. VQ. VR. VS. VT. VU. VV. VW. VX. VY. VZ. WA. WB. WC. WD. WE. WF. WG. WH. WI. WJ. WK. WL. WM. WN. WO. WP. WQ. WR. WS. WT. WU. WV. WW. WX. WY. WZ. XA. XB. XC. XD. XE. XF. XG. XH. XI. XJ. XK. XL. XM. XN. XO. XP. XQ. XR. XS. XT. XU. XV. XW. XX. XY. XZ. YA. YB. YC. YD. YE. YF. YG. YH. YI. YJ. YK. YL. YM. YN. YO. YP. YQ. YR. YS. YT. YU. YV. YW. YX. YY. YZ. ZA. ZB. ZC. ZD. ZE. ZF. ZG. ZH. ZI. ZJ. ZK. ZL. ZM. ZN. ZO. ZP. ZQ. ZR. ZS. ZT. ZU. ZV. ZW. ZX. ZY. ZZ.




FIG. F.6.17 SN-2 SEWERAGE DEVELOPMENT ZONE





FIG. F.6.18 SN-II WASTEWATER TREATMENT PLANT



JICA - Ho Chi Minh City Urban Drainage & Sewerage Project




FIGURE 6-19 SEWERAGE DEVELOPMENT PLAN





FIG. F.6.20 LAYOUT OF SE WASTEWATER TREATMENT PLANT



JICA - Ho Chi Minh City Urban Drainage & Sewerage Project

Sewerage Zone	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
THBNDT	■■■■	■■■■	■■■■	■■■■	■■■■																
NLJTN			■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■												
THLG				■■■■	■■■■	■■■■	■■■■	■■■■	■■■■												
TLBC				■■■■	■■■■	■■■■	■■■■	■■■■	■■■■												
SW											■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■
SS																■■■■	■■■■	■■■■	■■■■	■■■■	■■■■
SN-I																■■■■	■■■■	■■■■	■■■■	■■■■	■■■■
SN-II																■■■■	■■■■	■■■■	■■■■	■■■■	■■■■
SE											■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■	■■■■

■■■■: Engineering Design
 ———: Construction

Fig. F.8.1 IMPLEMENTATION PROGRAM FOR SEWERAGE DEVELOPMENT




FIG.F.11.1 SUB-ZONES AND INTERCEPTOR ROUTE




FIG.F.11.2 3 ALTERNATIVES OF INTERCEPTOR ROUTE FOR EAST AREA OF CALNAL TAU HU - BEN NGHE LEFT BANK.




FIG.F.11.3 SUB-ZONE AND INTERCEPTOR ROUTE FOR ISLANDS AND SOUTHERN AREAS.




FIG.F.11.4 LONGITUDINAL PROFILE OF INTERCEPTOR FOR KHANH HOI AND RACH ONG SUB-ZONES




FIG.F.11.5 LONGITUDINAL PROFILE OF INTERCEPTOR FOR KHANH HOI SUB-ZONES




FIG.F.11.6 LONGITUDINAL PROFILE OF INTERCEPTOR FOR HUNG PHU SUB-ZONES




FIG.F.11.7 LONGITUDINAL PROFILE OF INTERCEPTOR FOR HUNG PHU SUB-ZONES




FIG.F.1.1.8 LONGITUDINAL PROFILE OF INTERCEPTOR FOR BINH DONG, TUNG THIEN VUONG, BINH DANG AND PHAM THE HIEN SUB-ZONES




FIG.F.11.9 LONGITUDINAL PROFILE OF INTERCEPTOR FOR TUNG THIEN VUONG SUB-ZONES