

1.4 COMPONENT FACILITIES

1.4.1 PRIMARY CLARIFIERS

Primary clarifiers specifications are calculated by the following equation.

Average daily flow, Q _{ad}	=	200,000 m ³ /day
Maximum daily flow, Q _{md}	=	235,000 m ³ /day
Maximum hourly flow, Q _{mh}	=	285,000 m ³ /day
Wet weather flow Q _{ww}	=	570,000 m ³ /day
Hydraulic surface load rate	=	35 m ³ /m ² ·day
Totally 4 clusters, each consisting of 2 tanks, total number of basins is		8 units
Hydraulic load on each basin is	$235,000 \div 8 =$	29,375 m ³ /day/basin
Required surface area of each basin	$= 29,375 \div 35 =$	839 m ²

(1) Tank Geometry (In accordance with the Romanian Standards),

Internal diameter	35 m
Effective depth	2.0 m
Number of basins	8 basins
Surface area of a basin	$843 \times 8 = 6,744 \text{ m}^2$
Hydraulic capacity of a basin	$6,744 \times 2 = 13,488 \text{ m}^3$
Check for hydraulic conditions of basins under the different flow rates.	

Retention time

$$Q_{md} \quad 13,488 \times 24 / 235,000 = 1.38 \text{ hours}$$

$$2Q_{mh} \quad 13,488 \times 24 / 570,000 = 0.57 \text{ hours} > 0.5$$

Surface load rate

$$Q_{md} \quad 235,000 / 6,744 = 34.8 \text{ m}^3/\text{m}^2 \cdot \text{day} < 35$$

$$2Q_{mh} \quad 570,000 / 6,744 = 84.5 \text{ m}^3/\text{m}^2 \cdot \text{day} < 96$$

(2) Raw Sludge Pumping Equipment

The pumps will handle the mixture of primary and excess sludge having solids concentration of 2%.

Sludge solids 46.44 t/day, Solids concentration 2 %

Sludge volume 2,322 m³/day = 1.61 m³/min.

Pump type: Centrifugal screw pump

Pump bore size: 100 mm

Delivering capacity: 1 m³/min.

Total dynamic head: 10 m

Number of pumps: 3 Units (including 1 standby)

1.4.2 REACTOR TANKS

Reactor tanks specifications are calculated by the following equation.

Design flow, Q _{md}	=	235,000 m ³ /day
BOD – SS load		0.30 kgBOD/kg SS day
MLSS		1,667 mg/L
Return sludge solids concentration		5,000 mg/L
Sludge return ratio	$= 1,667 \div (5,000 - 1,667) =$	0.50
Inflow BOD to reactors	$= 235,000 \times 170 \times 10^{-3} \text{ kg BOD/day} \times (1 - 0.3)$	$= 27,965 \text{ kg BOD/day}$
Reactor tanks SS	$= V \times 1,667 \times 10^{-3} \text{ kgMLSS}$	
Required tank capacity	$= 27,965 \div 1,667 \div 0.30 =$	55,919 m ³

$$\begin{aligned} \text{Aeration time} &= 55,919 \times 24 \div 235,000 = 5.7 \text{ hours} \\ &\text{At Qmd, aeration time of 6 hours or more is secured.} \\ \text{Required tank capacity} &= 6 \times 235,000 \div 24.00 = 58,750 \text{ m}^3 \\ \text{Tank geometry} & \\ \text{Width} &= 5.5 \text{ m} \\ \text{Effective depth} &= 5.5 \text{ m} \\ \text{Cross sectional area} &= 5.5 \times 5.5 - 1/2 \times 1.0^2 \times 2 - 1/2 \times 0.6^2 \times 2 \\ &= 29 \text{ m}^2 \\ \text{Number of tanks} &= 8 \text{ tanks} \quad 4 \text{ clusters} \quad 32 \text{ tanks} \\ \text{Capacity of one tank} &= 55,919 \div 32 = 1,747 \text{ m}^3 \\ \text{Tank length} &= 1,747 \div 29 = 60.26 \text{ use } 67 \text{ m} \end{aligned}$$

Tank geometry		
W	5.5 m	x 32 Tanks
L	67 m	
H	5.5 m	

$$\begin{aligned} \text{Check of aeration time} & \\ \text{Tank capacity} &= 29 \times 67 \times 32 = 62,176 \text{ m}^3 \\ \text{Aeration time} &= 62,176 \times 24 / 235,000 = 6.3 \text{ hours} \end{aligned}$$

Check for additional tank requirement to upgrade the process

Additional tank capacity required for the advanced treatment process will be provided by adding tanks to the conventional activated sludge aeration tanks. The wastewater inflow will be distributed both to the existing and additional tanks. The wastewater will be distributed in proportion to the treatment capacity of both trains.

The total detention time will be 13.2 hours.

As the detention time in the conventional treatment process is 6.3 hours, the required retention time for additional tanks is

$$13.2 - 6.3 = 6.90 \text{ hours}$$

Check capacity and wastewater distribution ratio

$$\text{Existing tanks} \quad 6.3 / 13.2 = 0.48$$

$$\text{Additional tanks} \quad 6.9 / 13.2 = 0.52$$

Wastewater flow distribution rates

$$\text{Existing tanks} \quad 235,000 \times 0.48 = 113,047 \text{ m}^3/\text{day}$$

$$\text{Additional tanks} \quad 235,000 \times 0.52 = 122,841 \text{ m}^3/\text{day}$$

Additional Reactor Tanks

$$\text{Required tank capacity} = 235,000 \times 6.9 \div 24 = 67,563 \text{ m}^3$$

$$\text{Number of tanks} = 8 \text{ tanks} \quad 4 \text{ clusters} \quad 32 \text{ tanks}$$

$$\text{Tank capacity} = 67,563 \div 32 = 2,111 \text{ m}^3$$

$$\text{Tank length} = 2,111 \div 29.00 = 72.8 \text{ use } 73 \text{ m}$$

Tank geometry		
W	5.5 m	x 32 Tanks
L	73 m	
H	5.5 m	

$$\begin{aligned} \text{Check retention time} & \\ \text{Tank capacity} &= 29 \times 73 \times 32 = 67,744 \text{ m}^3 \\ \text{Retention time} &= 67,744 \times 24 / 235,000 = 6.9 \text{ hours} \end{aligned}$$

1.4.3 FINAL CLARIFIERS

Final clarifiers specifications are calculated by the following equation.

$$\text{Design flow QD} = 235,000 \text{ m}^3/\text{day}$$

$$\text{Surface load rate} = 25 \text{ m}^3/\text{m}^2\cdot\text{day}$$

4 clusters each consisting of 2 tanks, total tank number is: 8 tanks

$$\text{Influent to each tank} = 235,000 \div 8 = 29,375 \text{ m}^3/\text{day}/\text{tank}$$

$$\text{Required surface area of each tank} = 29,375 \div 25 = 1,175 \text{ m}^2$$

(1) Check by the Romanian Standards

Internal diameter 45 m

Effective depth 3.5 m

Tank numbers 8 units

$$\text{Surface area } 1,424 \times 8 = 11,392 \text{ m}^2$$

$$\text{Capacity } 11,392 \times 3.5 = 39,872 \text{ m}^3$$

Surface load rate 21 m³/m²·day

Retention time

$$\text{At Qmd } 39,872 \times 24 / 235,000 = 4.07 \text{ hours}$$

$$\text{Qv} = \text{Qmh} + \text{Qrmax} = 285,000 + 117,500 = 402,500 \text{ m}^3/\text{day}$$

$$39,872 \times 24 / 402,500 = 2.38 > 2.0$$

Surface load rate

$$\text{At Qmd } 235,000 / 11,392 = 21 \text{ m}^3/\text{m}^2\cdot\text{day} < 25$$

$$\text{At Qv } 402,500 / 11,392 = 35.3 \text{ m}^3/\text{m}^2\cdot\text{day} < 52.8$$

Weir loading

$$\text{Weir length } L = \pi \times 42.7 \times 8 = 1,073 \text{ m}$$

$$\text{At Qmd } 235,000 / 1,073 = 219 \text{ m}^3/\text{m}\cdot\text{day}$$

$$\text{At Qv } 402,500 / 1,073 = 375 \text{ m}^3/\text{m}\cdot\text{day}$$

As compared with the Japanese Standards, the weir loading appears to be high side. The weir length may be increased in detailed design.

(2) Check for Advanced Treatment

The advanced treatment will be performed through two trains, existing and advanced treatment process trains.

The wastewater will be distributed to each train in proportion to the reactor tanks hydraulic retention time.

Wastewater distribution

Existing train 113,047 m³/day

Additional train 122,841 m³/day

Check for additional tanks

Surface load rate 15 m³/m²·day or lower

Cluster 4 with 2 tanks, then total tank number is 8 units

$$\text{Flow rate to each tank } 122,841 \div 8 = 15,355 \text{ m}^3/\text{day}/\text{tank}$$

$$\text{Required surface area of each tank} = 15,355 \div 15 = 1,024 \text{ m}^2$$

$$D = 40 \div 2.3 = 37.7 \text{ m}$$

$$\text{According to Romanian Standards } A = 0.785 \times (D^2 - 3^2) = 1,109 \text{ m}^2$$

Diameter 40 m

Effective depth 3.5 m

Number of tanks 8 units

$$\text{Water surface area } 1,109 \times 8 = 8,869 \text{ m}^2$$

$$\text{Capacity } 8,869 \times 3.5 = 31,042 \text{ m}^3$$

Overflow rate 13.9 m³/m²·day

Check the existing tank surface load rate

$$122,841 / 11,392 = 10.8 \text{ m}^3/\text{m}^2\cdot\text{day} < 15$$

(3) Return Sludge Pumps

Return sludge pumps are specified as follows.

Average 50 % sludge return rate is considered, but pump capacity 100 % return rate is provided to prevent and restore sludge bulking.

$$\text{Return sludge volume} = 117,500 \text{ m}^3/\text{day} = 82 \text{ m}^3/\text{min.}$$

60 % and 40 % of sludge will be transported by 4 and 2 pumps respectively, through double pipelines.

$$\begin{aligned} \text{Pump capacity} & 41 \times 0.2 = 8.16 \text{ use } 8.2 \text{ m}^3/\text{minute/unit} \\ \text{"} & 41 \times 0.15 = 6.12 \text{ use } 6.2 \text{ m}^3/\text{minute/unit} \end{aligned}$$

By operating above pumps, the return sludge rates can be adjusted at the order of 5% to 15 %.

Pump type	No.1 Screw centrifugal	No.2 Screw centrifugal
Diameter	250 mm	250 mm
Capacity	6.2 m ³ /min.	8.2 m ³ /min.
TDH	10 m	10 m
Number of pumps	8 units	4 units
Motor output	22 kW	30 kW

(4) Excess Sludge Pumps

Excess sludge pumps are specified as follows.

$$\text{Excess sludge volume} = 5,904 \text{ m}^3/\text{day} = 4.1 \text{ m}^3/\text{min}$$

$$\text{Two lines will be provided, then the capacity of a pump} = 1.02 \text{ m}^3/\text{min}$$

Type of pump	No.1 Screw centrifugal pump
Diameter	250 mm
Capacity	1.1 m ³ /min
TDH	10 m
Number of pumps	6 units (2-standby)
Motor output	22 kW

(5) Chlorine Contact Tanks

Chlorine contact tanks specifications are calculated by the following equation.

$$\text{Design flow rate} = 235,000 \text{ m}^3/\text{day}$$

$$\text{Chlorine contact time} = 15 \text{ minutes}$$

$$\text{Required tank capacity: } 235,000 \div 1,440 \times 15 = 2,448 \text{ m}^3$$

$$\text{Channel width: } 4.0 \text{ m}$$

$$\text{Effective depth: } 3.0 \text{ m}$$

$$\text{Tank length: } 2447.9 \div 4.0 \div 3.0 = 204.0 \text{ m} \rightarrow 204 \text{ m}$$

$$\text{Number of tanks } 1 \text{ unit}$$

Chlorine contact tank geometry

W	4 m	x	H 4.0 m	x	1 Tanks
L	204 m				

1.5 ANAEROBIC SLUDGE DIGESTER**1.5.1 SLUDGE THICKENERS****(1) Hydraulic Capacity of Tanks**

Hydraulic capacity of tanks are specified as follows.

Solids input	=	46.44 t/day
Input sludge volume	=	6,750 m ³ /day
Output sludge volume	=	1,061 m ³ /day
Floor loading	=	60 kg/m ² /day
Required surface area	=	774 m ²
Tank geometry	Circular radial flow type	
Internal diameter	=	16 m
Effective depth	=	4 m
Number of tanks	=	4 units
Water surface area	$3.14/4 \times 16^2 \times 4 = 804 \text{ m}^2$	

(2) Sludge Withdrawal Pumps

Sludge withdrawal pumps are specified as follows.

The pumps will have capacities that can send thickened sludge in around 8 hours.

Pump capacity $Q = 1061 \times 1/8 \times 1/60 = 2.21 \text{ m}^3/\text{min}.$

Pump	Sludge pump
Diameter	100 mm
Discharge capacity	1.20 m ³ /min.
TDH	20 m
Motor output	15 kW
Number of pumps	3 units(including one standby)

(3) Sludge Screens

Sludge screens are specified as follows.

Type	Rotary drum screen
Screen opening	4 mm
Capacity	2 m ³ /min.
Motor output	0.4 kW
Number of screens	1 unit

Screen capacity is so determined that the sludge quantity being sent concomitantly from 2 raw sludge pumps (each $q = 1.0 \text{ m}^3/\text{min}.$) can be screened.

1.5.2 ANAEROBIC SLUDGE DIGESTION TANKS

(1) Hydraulic Capacity of Tanks

Hydraulic capacity of tanks are specified as follows.

Sludge solids input	=	37.15 t/day
Input sludge	=	1,061 m ³ /day
Retention time	=	20 days
Tank temperature	=	35 °c
Required tank capacity	=	$1,061 \times 20 = 21,230 \text{ m}^3$

(2) Tank Geometry

Type	Single stage digestion	
Internal diameter	17.5 m	
Effective tank depth	31 m	
Number of tanks	2 clusters × 2 tanks	
Capacity	5,580 m ³ /tank , 22,321 m ³ total tank capacity	

1.5.3 GAS STORAGE TANKS

(1) Capacity of Tanks

Capacity of tanks are calculated by the following equation.

$$\begin{aligned} \text{Total solids input to digesters} &= 37.15 \text{ t/day} \\ \text{Assuming that 70 \% of the input sludge solids are volatile, and 1 kg of which produce} \\ &0.425 \text{ m}^3 \text{ gas, the total gas production can be estimated as follows:} \\ \text{Total gas production} &= 37.15 \times 0.7 \times 10^3 \times 0.425 = 11,053 \text{ m}^3/\text{day} \\ \text{Storage time} &8 \text{ hours} \\ \text{Tank storage capacity} &= 11,053 \times 8 / 24 = 3,684 \text{ m}^3/\text{day} \end{aligned}$$

(2) Tank Geometry

Type	Dry-seal type steel tanks
Number of tanks	2 units
Diameter	16 m
Effective height	17 m
Storage capacity	2,000 m ³

1.5.4 MECHANICAL SLUDGE DEWATERING

(1) Filter Capacity

Filter capacity is calculated by the following equation.

$$\begin{aligned} \text{Solids input} &= 24.15 \text{ t/day}, \quad \text{Input sludge volume} \quad 805 \text{ m}^3/\text{day} \\ \text{Belt press filter} & \\ \text{Yields per unit length} &130 \text{ kg/m/hr} \\ \text{Filter width} &3 \text{ m} \\ \text{Daily operation time} &6 \text{ hr} \\ \text{Working days/week} &5 \text{ day} \\ \text{Solids loads per hour} &= 24.15 \times 7 / 5 \times 10^3 / 6 = 5,635 \text{ kg/hr} \\ \text{Required number of belt press} & \\ &= 5,635 / 130 / 3 = 14 \text{ use} \rightarrow 14 \text{ units} \end{aligned}$$

Type	: Belt filter press
Filter loading rate	: 130 kg/m/hr
Filter width	: 3 m
Number of filters	: 14 unit

1.6 CHLORINE REQUIREMENTS

Required quantity of hypochlorite solution can be calculated by multiplying the dosing rate by the wastewater flow rate as shown in the following equation:

$$VR = Q \times R \times (100 / C) \times (1 / d) \times 10^{-3}$$

where

VR	Required hypochlorite solution (L / hr.)
Q	Wastewater flow rate (m ³ / hr)
R	Chlorine dosing rate(mg /L)
C	Effective chlorine concentration in chemical (%)
d	Specific gravity of hypochlorite solution (at the effective concentration of C%)

At the maximum daily flow rate, the required hypochlorite solution is:

$$\begin{aligned}
 Q &= 235,000 \text{ m}^3/\text{day} = 9,792 \text{ m}^3/\text{hr} \\
 R &= 3 \text{ mg/L} \\
 C &= 10\% \\
 d &= 1.2 \\
 VR &= Q \times 3 \times (100/10) \times (1/1.2) \times 10^{-3} \\
 &= 0.036 \times Q = 353 \text{ L/hr} = 6 \text{ L/minute}
 \end{aligned}$$

At the wet weather flow (maximum hydraulic rate)

$$\begin{aligned}
 Q_{ww} &= 570,000 \text{ m}^3/\text{day} = 23,750 \text{ m}^3/\text{hr} \\
 R &= 8 \text{ mg/L} \\
 VR &= 0.012 \times 8 \times Q_{ww} = 2,280 \text{ L/hr} = 38 \text{ L/minute}
 \end{aligned}$$

(1) Hypochlorite Solution Storage Tanks

8 days storage capacity for the maximum daily flow rate. Then, the capacity is:

$$V = 0.353 \text{ m}^3/\text{h} \times 24 \times 8 = 67.78 \text{ m}^3$$

Tank specifications

Type	FRP made cylinder type
Internal diameter	2.8 m
Height	3.9 m
Capacity	20 m ³
Number of tanks	4 units

(2) Dosing Pumps Specification

	(No.1)	(No.2)
Type	Diaphragm	Diaphragm
Diameter	20 mm	20 mm
Discharge	6 L/min.	13 L/min.
Motor output	0.2 kW	0.4 kW
No. of unit	2 units	3 units(including 1 standby)

1.7 DIGESTER HEATING SYSTEM

1.7.1 TEMPERATURE

Lowest daily average temperature	0 °c
Soil temperature	15 °c
Input sludge temperature	10 °c
Digester tank temperature	35 °c

1.7.2 REQUIRED CALORIES FOR SLUDGE HEATING SPECIFIC HEAT 1.0 Kcal/KG · °C

Required calories for sludge heating system is calculated by the following equation.

$$Q = 1,061 \times (35 - 10) \times 103 \times 1.0 = 26,537,073 \text{ Kcal/d}$$

1.7.3 HEAT LOSSES TANK INTERNAL DIAMETER 17.5 M

(1) Surface Area of the Digestion Tank

		Internal diameter 17.5 m		
		r	R	h
Top slab (gas portion)	A1	1.00	3.00	2.0
		38.7		m ²
Top slab(liquid portion)	A2	3.00	8.75	5.75
		300.0		m ²
Side wall(above ground)	A3	8.75	8.75	13.05
(down to 1m below ground)		717.1		m ²
Side wall(underground)	A4	8.75	8.75	4.45
(up to 1m from surface)		244.5		m ²
Bottom slab	A5	1.00	8.75	7.75
		338.7		m ²

$$A1 = 35.5(\text{side}) + 3.14(\text{top, r}) = 38.67$$

$$A2 = 300.0, A3 = 717.7, A4 = 244.5, A5 = 335.5 + 3.14 = 338.7$$

(2) Overall Thermal Conductivity Coefficient (kcal/m², °C/hr)

	RC thickness (m)	Water proof motor	Insulation (polyurethane foam)	Concrete block	Spray concrete	Gas portion	Internal α 1 (thermal conductivity)	External α 2 (thermal conductivity)	K
	($\lambda=1.4$)	($\lambda=1.2$)	($\lambda=0.22$)	($\lambda=1.0$)	($\lambda=1.4$)	($\lambda=0.48$)			
Roof slab(gas portion)	0.3	0.03	0.04				20	20	0.464k1
Roof slab(liquid portion)	0.3	0.03	0.04				300	20	0.474k2
Upper side walls (1m underground or higher)	0.3		0.04	0.15		0.26	300	20	0.360k3
Lower sidewalls (1m underground or lower)	0.3						300	5	2.395k4
Bottom slab	0.8				0.1		300	5	1.182k5

The overall thermal conductivity coefficient can be calculated by the following equation:

$$1/K = 1/\alpha_1 \times \delta_1/\lambda_1 + \delta_2/\lambda_2 + 1/\alpha_2$$

where

K	Overall thermal conductivity coefficient (kcal/m ² ·°C·hr.)	
α_1	Thermal conductivity coefficient of gas or sludge (kcal/m ² ·°C·hr.)	
	1/k1 = 2.16	k1 = 0.464
α_2	Thermal conductivity coefficient of air or ground (kcal/m ² ·°C·hr.)	
	1/k2 = 2.11	k2 = 0.474
λ_1, λ_2	Thermal conductivity coefficient of insulation material (kcal/m ² ·°C·hr.)	
	1/k3 = 2.78	k3 = 0.360
δ_1, δ_2	Thickness of insulators (m)	1/k4 = 0.42 k4 = 2.395
		1/k5 = 0.85 k5 = 1.182

(3) Overall Heat Losses

Portion of tank	Heat transfer area	Thermal conductivity coefficient	Number of tanks	Difference of temperature	Total heat losses
	(m ²)	(Kcal/m ² /°C/hr)	(unit)	(°C)	
Roof slab(gas portion)	38.67	0.464	4	35	2,509
Roof slab(liquid portion)	300.0	0.474	4	35	19,899
Upper sidewalls(1m under ground above)	717.1	0.360	4	35	36,146
Lower sidewalls (up to 1m below ground surface)	244.5	2,395	4	35	81,974
Bottom slab	338.7	1.182	4	35	56,035
				Total	196,562

Overall heat losses = 196,562 Kcal / hr

1.7.4 HEATING SYSTEM

24 hours continuous heating. A total of 20 % heat losses from pipes are considered.

$$26,537,073 / 24 + 196,562 \times 1.2 = 1,341,586 \text{ Kcal / hour}$$

Efficiency of water heater = 0.9

$$1,341,586 / 0.9 = 1,490,651 \text{ Kcal / hour}$$

Water heater

$$800,000 \text{ Kcal / hr} \times 3 \text{ units (including 1 standby)}$$

1.8 ANAEROBIC SLUDGE DIGESTION SYSTEM**1.8.1 DIGESTION TANK**

Hydraulic capacity of tanks are specified as follows.

$$\text{Solids input} = 1,061 \text{ m}^3/\text{day}$$

$$\text{Retention time} = 20 \text{ days}$$

$$\text{Temperature} = 35 \text{ }^\circ\text{C}$$

$$\text{Required tank capacity} = 1,061 \times 20 = 21,230 \text{ m}^3$$

1.8.2 TANK GEOMETRY


Tank geometry is specified as follows.

Type	single stage tank	
Internal diameter	17.5 m	
Effective tank depth	31 m	
Number of tanks	2 clusters	4 tanks
	5,580 m ³ /tank	D1 = 17.5 m
	(5,307 m ³ / tank or larger)	D2 = 2 m
		D3 = 6 m

1.8.3 TANK CAPACITY

Tank capacity is calculated by the following equation.

Effective depth	17.5 m	Portion V1
"	7.75 m	Portion V2
"	5.75 m	Portion V3
Total	31m	
V1	= $\pi / 4 \times D1^2 \times D1$	
	= $\pi / 4 \times D1^3 = 4,207 \text{ m}^3$	
V2	= $\pi / 4 \times D1^2 \times (D/2) / 3$	
	= $-\pi / 4 \times D2^2 \times (D2/2) / 3$	
	= $\pi / 4 / 6 (D^3 - D2^3)$	
	= 700 m^3	
V3	= $\pi / 4 / 6 (D1^3 - D3^3)$	
	= 673 m^3	
V total	5,580 m ³	



1.9 REQUIRED OXYGEN

Required oxygen is calculated by the following equation.

Required O₂: OD = OD₁ + OD₂ + OD₃
 where

- OD₁ : Oxygen required for BOD oxygenation (cell synthesis)
- OD₂ : Oxygen required for endogenous respiration
- OD₃ : Oxygen to be utilized for maintaining required dissolved oxygen level

1.9.1 REQUIRED OXYGEN FOR BOD OXIDATION(CELL SYNTHESIS) : OD₁(KG O₂/DAY)

OD₁ = A(kgO₂/kgBOD) × BOD removed (kg BOD/day)
 where

A : kg oxygen required to remove kg BOD (kgO₂/kgBOD), 0.5~0.7 → 0.6

Q = 235,000 m³/day

OD₁ = 0.6 × Q × 101.2 × 10⁻³ = 0.0607 Q kgO₂/day

Influent BOD = 119 - 18 = 101.2 mg/l

1.9.2 OXYGEN REQUIRED FOR ENDOGENOUS RESPIRATION OD₂(KG O₂/DAY)

OD₂ = B(kgO₂/kgMLVSS·day) × VA(m³) × MLVSS(kgMLVSS/m³)
 where

B : Oxygen consumption due to endogenous respiration per unit MLVSS (kgO₂/kgMLVSS·day) 0.05~0.15
 0.05

VA: Capacity of aerobic portion of reactor(m³) Q × 6 ÷ 24 = 0.25 Q
 MLVSS/MLSS = 0.8

OD₂ = 0.05 × 0.25 × Q × 1,500 × 10⁻³ × 0.8
 = 0.0150 Q kgO₂/day

1.9.3 REQUIRED OXYGEN TO MAINTAIN DISSOLVED OXYGEN LEVEL: OD_3 (KGO₂/DAY)

$$OD_3 = COA \times Q \times 10^{-3}$$

where COA : Aeration tank dissolved oxygen 1.5 mg/l concentration

$$OD_3 = 1.5 \times Q \times 10^{-3}$$

$$= 0.0015 Q \text{ kg O}_2/\text{day}$$

1.9.4 TOTAL OXYGEN REQUIREMENTS

$$OD = OD_1 + OD_2 + OD_3$$

$$= 0.0607 Q + 0.015 Q + 0.0015 Q = 0.0772 Q \text{ (kgO}_2/\text{day)}$$

1.9.5 AERATION EQUIPMENT (DIFFUSERS, FINE BUBBLES, SPIRAL FLOW)

Aeration equipment is calculated by the following equation.

$$EA = 7.5, \quad \rho = 1.293, \quad Q_w = 0.233$$

Air volume (Nm³/day)

$$= (\text{Required oxygen (kgO}_2) / (EA(\%) \times 10^{-2} \times \rho (\text{air/Nm}^3) \times Q_w (\text{kgO}_2/\text{kg air})))$$

$$= (0.0772 Q) / (7.5 \times 0.01 \times 1.293 \times 0.233)$$

$$= 3.42 Q = 802,811 \text{ (Nm}^3/\text{day)} = 558 \text{ (Nm}^3/\text{min.)}$$

Install one blower for each train

Required blower capacity $558 \div 4 = 139 \text{ m}^3/\text{tank}\cdot\text{unit}$

Blower spec. Cast-iron made multi-stage turbo blower

Inlet/outlet diameters $\phi 350 / \phi 300$

Capacity 140 m³/min.

Motor output 190 kW

Number of units 5 units (including 1 standby)

1.10 SCREENS AND PUMPING STATION

1.10.1 FLOW RATE

Flow rate is determined as follows.

Q _{ad}	200,000 m ³ /day	2,315 L/s
Q _{md}	235,000 m ³ /day	2,720 L/s
Q _{mh}	285,000 m ³ /day	3,299 L/s
Q _{ww}	570,000 m ³ /day	6,597 L/s

1.10.2 INCOMING SEWER

Incoming sewer is specified as follows.

Friction formula	Manning (n= 0.013)
Size of incoming sewer	ϕ 2,200 mm
Sewer slope	1.2 ‰
Incoming sewer invert elevation	-3.699 m above M.W.L.
Full flow rate of incoming sewer	6.597 m ³ /sec
Full flow velocity in incoming sewer	1.789 m/sec

Item	Wastewater flow rates (m ³ /s)	Flow velocity (m/sec)	Water depth (m)	Water surface elevation at entrance (m)	Head loss ahead of chamber	Gate chamber water elevation (m)
Average	2.315	1.617	0.884	-2.815	0.133	-2.948
daily	0.340	0.904	0.402			
Maximum daily	2.720	1.689	0.981	-2.718	0.146	-2.863
daily	0.440	0.944	0.446			
Maximum hourly	3.299	1.775	1.080	-2.619	0.161	-2.779
hourly	0.485	0.992	0.491			
Wet weather flow	6.597	2.038	1.747	-1.952	0.212	-2.164
	0.970	1.139	0.794			

Note: Ratio of flow to full flow Ratio to full velocity Ratio to full sewer depth From tables

1.10.3 INFLUENT GATE

Influent gate is specified as follows.

Elevation of gate bottom -3.85 M.W.L.
Gate type and size square 1.2 m

Items		Average daily flow	Max. daily flow	Max. hourly flow	Wet weather flow	Remarks
Wastewater Inflow rates (Q)	m ³ /s	2.315	2.720	3.299	6.597	
No. of gates operated (n)	Unit	2	2	3	4	
Wastewater inflow to each gate	m ³ /s/gate	1.157	1.360	1.100	1.649	Q/n
Wastewater elevation ahead of gate	M.W.L.	-2.948	-2.863	-2.779	-2.164	
Wastewater depth at gate (H)	m	0.902	0.987	1.071	1.686	
Wastewater flow area at gate (A)	m ²	1.082	1.184	1.285	1.44	1.2×H
Flow velocity through gate(V)	m/s	1.069	1.149	0.856	1.145	Q/nA
Head losses at gate(Δh)	m	0.087	0.101	0.056	0.100	
Water elevation after gate	M	-3.036	-2.964	-2.836	-2.264	

$$\text{Total head losses at gate } (\Delta h) = 1.5 \times v^2/2g = 0.0765 \times v^2$$

1.10.4 COARSE SCREEN

Coarse screen is specified as follows.

Channel invert elevation -3.85 m M.W.L.
Channel width 1.6 m
Screen clear opening 100 mm
No. of screens 4
Slope of screens 60 degrees from horizontal

Items		Average daily flow	Maximum daily flow	Maximum hourly flow	Wet weather flow	Remarks
Wastewater inflow rates (Q)	m ³ /s	2.315	2.720	3.299	6.597	
No. of channels used (n)		2	2	3	4	
Wastewater inflow to each channel	m ³ /s	1.157	1.360	1.100	1.649	Q/n
Wastewater elevation ahead of screen	m M.W.L.	-3.036	-2.964	-2.836	-2.264	
Wastewater depth ahead of screen	m	0.814	0.886	1.014	1.586	
Flow area in channel(A)	m	1.303	1.417	1.278	2.537	1.6xH
Approaching flow velocity to screen	m/s	0.888	0.960	0.860	0.650	Q/nA
Flow velocity in screen(V2)	m/s	0.941	1.017	0.912	0.689	
Head loss in screen(Δh1)	m	0.002	0.003	0.002	0.001	
Actual head loss in screen(Δh2)	m	0.007	0.008	0.006	0.004	3xΔh1
Allowable head loss at screens (Δh3)	m	0.100	0.100	0.100	0.100	Δh3>h2
Wastewater elevation after screen	m M.W.L.	-3.136	-3.064	-2.936	-2.364	Δh3

$$\delta h = \beta \times (s/d)^{4/3} \times \sin \alpha = 0.0492268$$

$$\beta = 2.42, \quad d = 150 \text{ mm}, \quad s = 9 \text{ mm}, \quad \alpha = 60^\circ, \quad \sin 60 = 0.866$$

$$\text{Loss by screen} = \delta h \times v^2 / 2g = 0.04923 \times v^2 / 2g \quad (\text{hw})$$

$$\text{Flow velocity through screen} \quad V1 \times (s+d) / d = 1.06 \quad V1$$

1.10.5 FINE SCREEN

Fine screen is specified as follows.

Channel invert elevation	-4.0 M.W.L.
Channel width	1.6 m
Bar screen clear opening	20 mm
Thickness of screen bars	8 mm
No. of units	4 units
Slope of screen	75 degrees to horizontal

Items		Average daily flow	Maximum daily flow	Maximum hourly flow	Wet weather flow	Remarks
Wastewater Inflow rate (Q)	m ³ /s	2.315	2.720	3.299	6.597	
No. of channels in use (n)		2	2	3	4	
Flow rate in each channel	m ³ /s	1.157	1.360	1.100	1.649	Q/n
Water elevation ahead of screen	M.W.L.	-3.136	-3.064	-2.936	-2.364	
Water depth ahead of screen (H)	m	0.864	0.936	1.064	1.636	
Sectional area of flow in channel	m ²	1.383	1.497	1.341	2.617	1.6xH
Approaching velocity to screen(V1)	m/s	0.837	0.908	0.820	0.630	Q/nA
Flow velocity through screen(V2)	m/s	1.171	1.272	1.148	0.882	
Head loss through screen(Δh1)	m	0.048	0.057	0.046	0.027	
Actual head loss in screen(Δh2)	m	0.145	0.171	0.139	0.082	3xΔh1
Allowable maximum loss(Δh3)	m	0.100	0.100	0.100	0.100	Δh3<h2
Water surface elevation after screen	M.W.L.	-3.236	-3.164	-3.036	-2.464	Δh2

$$\delta h = \beta \times (s/d)^{4.3} \times \sin \alpha = 0.688907$$

$$\beta = 2.42, \quad d = 20 \text{ mm}, \quad s = 8 \text{ mm}, \quad \alpha = 75^\circ, \quad \sin 75 = 0.9659$$

$$\text{Loss by screen} = \delta h \times v^2 / 2g = 0.68891 \times v^2 / 2g \text{ (hw)}$$

$$\text{Flow velocity through screen} \quad V1 \times (s+d) / d = 1.400 V1$$

1.10.6 PUMPING EQUIPMENT

(1) Design Flow Rate

Flow rate is determined as follows.

Qad	200,000 m ³ /day	139 m ³ /minute
Qmd	235,000 m ³ /day	163 m ³ /minute
Qmh	285,000 m ³ /day	198 m ³ /minute
Qww	570,000 m ³ /day	396 m ³ /minute

(2) Wastewater Pumps

4 units (including 1 standby), mixed flow centrifugal type driven by electric motor.
Storm water pumps: 4 units (including 1 standby), mixed flow centrifugal type, smaller pumps driven by motor, and large pumps driven by diesel engine. Pump operation schedule is as follows:

Wastewater inflows	Wastewater inflow rates (m ³ /minute)	Pump discharges				Total pump discharge (m ³ /minute)
		Wastewater pumps		Storm water pumps		
		50	100	50	100	
		2	2(1)	2	2(1)	No. of units
Qad	139	50	100			150
Qmd	163	100	100			200
Qmh	198	100	100			200
Qww	396	100	100	100	100	400

(3) Pump Size:

No.1 Pumps $Q = 50 \text{ m}^3/\text{minute}$
 $D = 146(Q/V)^{0.5} \quad V = 5 \text{ m/sec}$
 $= 653 \text{ mm use} \rightarrow 600 \text{ mm}$

No.2 Pumps $Q = 100 \text{ m}^3/\text{minute}$
 $D = 146(Q/V)^{0.5}$
 $= 923 \text{ mm use} \rightarrow 900 \text{ mm}$

(4) Wastewater Surface Elevations:

Suction water levels at inflow of

Qad	-3.236	M.W.L.
Qmd	-3.164	M.W.L.
Qmh	-3.036	M.W.L.
Qww	-2.464	M.W.L.

Suction water levels at outflow of

Qad	11.100	M.W.L.
Qmd	11.100	M.W.L.
Qmh	11.100	M.W.L.
Qww	11.100	M.W.L.

(5) Actual Head

Qad	11.100	-	(-3.236)	=	14.336 m
Qmd	11.100	-	(-3.164)	=	14.264 m
Qmh	11.100	-	(-3.036)	=	14.136 m
Qww	11.100	-	(-2.464)	=	13.564 m

(6) Total Head Losses at Pump Equipment:

Pump size		φ600	φ900
Pump bore(m)		0.6	0.9
Pump discharge(m ³ /min)		50	100
Pump discharge(m ³ /sec)		0.833	1.667
Delivery bore sectional area (m ²)		0.283	0.636
Pump velocity(m/s)		2.949	2.621

(7) Loss Coefficients

Inlet		0.15	0.15
Sluice valve		0	0
Check valve		1.0	1.0
Outlet		1.0	1.0
Bend		0.25	0.25
Friction loss	$f \times L / D$	0.781	0.514
Total		3.181	2.914

(8) Head Losses

$\phi 600 = 1.411 \text{ m } F \times V^2 / 2g$
 $\phi 900 = 1.021 \text{ m}$
 Pipe length $L = 15 \text{ m}$
 Friction loss by Darcy-Wiseback Formula
 $hf = f \times L / D \times V^2 / 2g$
 $f = 0.02 + 1 / (2000 \times D)$ (New cast iron pipe)
 For old cast-iron pipes multiply the f by 1.5

	φ600	φ900
D(m)	0.6	0.9
F	0.021	0.021
$f' = 1.5 \times f$	0.031	0.031

(9) Total Head Required

Qad	14.336	+	1.411 (φ600)	=	15.747 m
			1.021 (φ900)	=	15.357 m
Qmd	14.264	+	0.000	=	14.264 m
Qmh	14.136	+	0.000	=	14.136 m
Qww	13.564	+	1.021 (φ900)	=	14.586 m

The required total pump head is then 16.0 m

(10) Shaft Power of Mixed Flow Centrifugal Pumps

$L = k \times \gamma \times Q \times H / \mu$
 where

L	Shaft power of pump
k	0.163 kW or 0.222 PS
Q	Pump discharge (m ³ /min)
H	Pump total dynamic head (m)
γ	Specific gravity of water ($\gamma = 1$)
μ	Pump efficiency

Calculations for shaft power requirements

Items		$\phi 600$	$\phi 900$	$\phi 900$ Engine
Pump discharge(Q)	m ³ /min	50	100	100
TDH (H)	m	16.0	16.0	16.0
Pump efficiency (μ)		0.78	0.81	0.81
Shaft power	kW	167	322	439

(11) Outputs of Pump Drives

$$P = L(1+\alpha) / \mu G$$

where

P	Pump power (kW)
L	Pump shaft power (kW)
α	Allowance for motor 0.15 Allowance for engine 0.2
μG	Transmission efficiency (1.0 for direct connection)

Items	$\phi 600$	$\phi 900$	$\phi 900$ Engine
Shaft power (L)	167	322	439
Allowance (α)	1.15	1.15	1.20
Efficiency of transmission (μG)	1.00	1.00	0.95
Pump drive output (P) kW	192	370	554

(12) Pump Specifications

Items		Vertical mixed flow centrifugal pumps		
Pump bore	mm	600	900	900
Pump discharge	m ³ /min.	50	100	100
Total dynamic head	m	16	16	16
Motor/engine outputs	kW	192	370	554
Pump drive		Motor	Motor	Engine

1.11 GRIT , OIL/GREASE REMOVAL EQUIPMENT

1.11.1 DESIGN WASTEWATER FLOW RATES

Design wastewater flow rates are determined as follows.


$$Q_{ad} = 200,000 \text{ m}^3/\text{day} = 2,315 \text{ L/s}$$

Qmd	235,000 m ³ /day	2,720 L/s
Qmh	285,000 m ³ /day	3,299 L/s
Qww	570,000 m ³ /day	6,597 L/s

1.11.2 GRIT, OIL/GREASE SEPARATION

Grit, oil/grease separation is specified as follows.

4 trains 2 channels each, then totally 8 channels
 Qww 570,000 m³/day = 6,597 L/sec
 Flow to each channel 71,250 m³/day = 825 L/sec
 Retention time 3 minutes
 Capacity $570,000 \times 3 \div 1,440 = 1,187.5 \text{ m}^3$
 Section area 6.8 m²
 Length 22 m
 Capacity $6.8 \times 22 \times 8 = 1,196.8 \text{ m}^3$
 (check for flows)
 At maximum daily flow Qmd 235,000 m³/day
 Retention $(1187.5 \times 1440) / 235,000$
 Time = 7.3 min.



Chamber cross sectional area

1.4	×	0.95	=	1.33
1/2	×	1.4 ²	=	0.98
1.6	×	3.05	=	4.88
-1/2	×	0.5 ²	=	-0.13
-1/2	×	0.7 ²	=	-0.25

Total 6.82 m² use → 6.8 m²

Air supply volume

Romanian Standards $Q = 0.3 \text{ m}^3 \text{ air} / \text{m}^3 \text{ water}$
 $= 0.3 \times 23,750 = 7,125 \text{ m}^3/\text{hour}$
 $= 119 \text{ m}^3/\text{min}$

Japanese Standards $Q = 0.01 \text{ m}^3/\text{sec} \cdot \text{m} \times \text{channel length}/\text{m} (0.005 \sim 0.013)$
 $= 0.01 \times 22 \times 8$
 $= 1.746 \text{ m}^3/\text{sec} = 105 \text{ m}^3/\text{min}$

Then, the total air is 119 m³/min
 Blower equipment
 1 unit each for 1 train
 then, 1 blower capacity = $119 \div 4 = 29.7 \text{ use} \rightarrow 30 \text{ m}^3/\text{min}$
 Air blower specifications
 Roots blower 5 units (including 1 standby)
 $\phi 200\text{mm} \quad 30 \text{ m}^3/\text{min}$
 Grit volume from combined sewage: $0.001 \sim 0.02 \text{ m}^3 \text{ grit}/1000 \text{ m}^3 \text{ sewage}$
 Then, grit volume = $0.02 / 1000 \times 570,000 = 11.4 \text{ m}^3/\text{day}$

1.11.3 GRIT PUMPS

Grit pumps are calculated as follows.

Pump capacity is to remove the grit in 20 minutes. As allowances the capacity is
 Two times of the grit quantity. Then, the pump capacity is

$$11.4 \text{ m}^3/\text{day} \times 2 / 8 \text{ units} \times 20 \text{ minutes} = 0.14 \text{ m}^3/\text{min}.$$

Assuming the grit content in the withdrawn wastewater at 10 %, the required pump
 capacity is ;

$$0.14 \times (100 / 10) = 1.4 \text{ m}^3/\text{min}$$

Assume the pump velocity to be 2.5 m/sec, the pump diameter will be

$$146 \times (1.4 / 2.5)^{0.5} = 109 \text{ use } 100 \text{ mm}$$

1.11.4 FLOW MEASUREMENT

Use two units of Parshall flume

			Flow per each unit(Q / 2)
Q _{ad}	200,000 m ³ /day	=	8,333 m ³ /hour 4,167 m ³ /hour
Q _{mh}	285,000 m ³ /day	=	11,875 m ³ /hour 5,938 m ³ /hour
Q _{ww}	570,00 m ³ /day	=	23,750 m ³ /hour 11,875 m ³ /hour
Select 7 ft flume, range of flow			306 ~ 12,380 m ³ /hour use 2 units

1.12 SLUDGE DIGESTER EQUIPMENT

1.12.1 MIXERS

(1) Specifications

Type	Up/down flow screw mixers (with a draft tube, from manufacturer's catalog)		
Capacity	2,300 m ³ /hour		
Draft tube diameter	500 mm		
Motor output	22 kW		
Quantity	4 units		

(2) Sludge Mixing Capacity

Sludge turn over rate (mixing the whole sludge volume 8 ~ 12 times/day)

$$Q = (8 \sim 12) \times 5,580 \text{ (Tank volume} = 5,580 \text{ m}^3) / 24$$

$$= 1,860 \sim 2,790 \text{ m}^3/\text{hour use} \rightarrow 2,300 \text{ m}^3/\text{hour}$$

1.12.2 TANK APPARATUS(ON ROOF TOP)

Tank apparatus are specified as follows.

Gas collectors(steel made)	$\phi 600 \text{ mm} \times 1 \text{ unit}$
Gas relief valve (wet type)	$\phi 200 \text{ mm} \times 1 \text{ unit}$

Gas relief valve (dry type) $\phi 200$ mm \times 1 unit (including valve and flame arrester)
 Quantity Total 4 units

1.12.3 WATER HEATERS

(1) Specifications

Type	Vacuum type water heater	
Heater capacity	800,000 Kcal/hr.	
Heater transfer area	17.5 m ²	
Fuel	Sludge gas and oil	
Electric motors	Burner motor	3.7 kW
	Oil pump	0.4 kW
	Oil heater	2.0 kW
	Fan	2.2 kW
Quantity	3 units (1standby)	

(2) Nominal Heat Output

Total required heat = 1,341,586 Kcal/hr
 Nominal heater capacity $Q = (1,341,586) / (2 \times 0.9)$
 $= 335,397$ Kcal / hr \rightarrow 800,000 Kcal / hr
 (Heater efficiency 0.9) (No. of units:2)

1.12.4 OIL SERVICE TANKS

(1) Specifications

Type	Steel made rectangular tank
Tank capacity	300 L
Quantity	1 unit

(2) Tank Capacity

Store oil of more than one hour consumption
 $q = (800,000 \times 2) / (10,200 \times 0.85) = 185$ L / hr. use \rightarrow 300 L
 β :Heating value of A-diesel oil 10,200 kcal / kg
 γ :Specific gravity of A-diesel oil 0.85 kg/L

1.12.5 OIL PUMPS

(1) Specifications

Type	Gear pump
Size	ϕ 15 mm
Discharge	10 L/min.
Discharge pressure	3 kg/cm ²
Electric motor	0.4 kW
Quantity	2 units (including 1 standby)

(2) Pump Discharge

Capable of supplying a 300-liter capacity tank within 30 minutes
 $Q = 300 / 30 = 10$ L/minute

1.12.6 OIL STORAGE TANK**(1) Specifications**

Type	Underground cylinder type
Storage capacity	15,000 L
Quantity	1 unit

(2) Tank Capacity

Store more than 3-day oil consumption.

$$V = 185 \times 24 \times 3 = 13,287 \text{ L use } \rightarrow 15,000 \text{ L}$$

1.12.7 GAS BOOSTER FANS**(1) Specifications**

Type	Turbo fan
Capacity	145.5 m ³ /hr.
Pressure (static pressure in water column)	500 mm Aq
Electric motor	1.5 kW
Quantity	2 units (including 1 standby)

(2) Capacity

Sludge gas consumption

$$q = 800,000 / 5,500 = 145.5 \text{ m}^3/\text{hr.}$$

(Sludge gas heat value 5,500 Kcal/m³)

Check for gas consumption

Required energy	Kcal/day	32,198,064
Heater operation time	Hour	20.1
Gas production	m ³ /day	11,053
Gas consumption	m ³ /day	2,927

Required heat energy 1,341,586 Kcal/hr.

Heater output 800,000 Kcal/hr.

No. of units 2 units

1.12.8 HEAT EXCHANGE**(1) Specifications**

Type	Spiral type heat exchanger	
Heat transfer area	25 m ²	
Water temperature	Inlet 70 °c, 60 °c	Outlet 40 °c, 35 °c
Quantity	Total Nos.	4 units

(2) Energy Transfer

Provide an exchanger to each digester

$$\begin{aligned} \text{Required energy per unit, } M &= 32,198,064 \times 1/4 = 8,049,516 \text{ Kcal/day} \\ &= 335,397 \text{ Kcal/hr.} \end{aligned}$$

(3) Required Heat Transfer Area

$$A = (M \times 1.2) / (K \times \Delta t_m) = (335,397 \times 1.2) / (600 \times 27.4)$$

$$\begin{aligned}
 &= 24.5 \text{ m}^2 \text{ use } 25 \text{ m}^2 \\
 M &= \text{Heat transfer} && 335,397 \text{ Kcal/hr.} \\
 K &= \text{Overall heat transfer coefficient} && 600 \text{ Kcal/m}^2 \text{ hr.}^\circ\text{C} \\
 \Delta t_m &= \text{Logarithmic average of temperature difference} \\
 &= (\Delta t_1 - \Delta t_2) / (\ln \Delta t_1 / \Delta t_2) \\
 &= (30 - 25) / (\ln (30/25)) = 27.4^\circ\text{C} \\
 \Delta t_1 &= 70 - 40 = 30^\circ\text{C} \\
 \Delta t_2 &= 60 - 35 = 25^\circ\text{C}
 \end{aligned}$$

(4) Sludge Recirculation

$$\begin{aligned}
 Q_1 &= M / (C \times \Delta t \times \gamma \times 60) = 335397 / (1 \times 5 \times 1,000 \times 60) = 1.12 \text{ m}^3/\text{min.} \\
 C &= \text{Sludge specific heat} && 1 \text{ Kcal/kg}^\circ\text{C} \\
 \Delta t &= \text{Temperature difference between inlet and outlet sludge} \\
 &= 40 - 35 = 5^\circ\text{C} \\
 \gamma &= \text{Unit weight of sludge} && 1,000 \text{ kg/m}^3
 \end{aligned}$$

(5) Water Recirculation

$$\begin{aligned}
 Q_2 &= 335,397 / (1 \times 10 \times 1,000 \times 60) = 0.56 \text{ m}^3/\text{min.} \\
 \Delta t &= \text{Difference of temperature between inlet and outlet} \\
 &= 70 - 60 = 10^\circ\text{C}
 \end{aligned}$$

1.12.9 SLUDGE CIRCULATION PUMPS

(1) Specifications

Type	Sludge pump with suction screw
Size	100 mm
Discharge	1.4 m ³ /min.
TDH	15 m
Motor output	5.5 kW
No. of units	4 units

(2) Capacity

Sludge circulation rate $Q = 1.12 \text{ m}^3/\text{min. use} \rightarrow 1.4 \text{ m}^3/\text{min.}$

(3) Head

Total head = Actual head + pipe losses + losses in heat exchanger (10m)
= 15 m

(4) Motor Output

$P_m = 0.163 \times 0.7 \times 15 \times (1 + 0.2) / 0.4 = 5.13 \text{ kW use} \rightarrow 5.5 \text{ kW}$

1.12.10 HOT WATER CIRCULATION PUMPS

(1) Specifications

Type	Line pump
Size	65 mm
Capacity	0.6 m ³ /min.
TDH	25 m
Motor output	3.7 kW
Quantity	4 units

(2) Capacity

$$\text{Return from exchanger, } Q = 0.56 \text{ m}^3/\text{min.}$$

(3) Head

$$\begin{aligned} \text{Total heads} &= \text{Actual head} + \text{pipe losses} + \text{losses in heat exchanger (20m)} \\ &= \text{use } 25 \text{ m} \end{aligned}$$

(4) Motor Output

$$\begin{aligned} P_m &= 0.163 \times 0.4 \times 25 \times (1 + 0.2) / 0.6 \\ &= 3.26 \text{ kW use } \rightarrow 3.7 \text{ kW} \end{aligned}$$

1.12.11 GAS HOLDER**(1) Specifications**

Type	Steel made dry seal type
Capacity	2000 m ³
Size	15.5m ϕ \times 16.8mH
No. of tanks	2 units

(2) Capacity

Gas generation	11,053 m ³ /day
Retention time	8 hr.
Storage capacity	$11,053 \times 8 / 24 / 2 = 1,842 \text{ m}^3$ use $\rightarrow 2000 \text{ m}^3$

1.12.12 GAS SCRUBBERS**(1) Specifications**

Type	Dry type (intermittent) scrubbers	
Capacity	150 m ³ /hr.	
Size	1,800 mm \times 4,200 m H \times 2 units	
No. of units	2 \times 1,800 mm \times 4,200 m H \times 2 units	4 units

(2) Capacity

Treat all the gas produced

$$Q = 11,053 \times 1 / 24 / 4 = 115 \text{ m}^3/\text{hr. use } \rightarrow 150 \text{ m}^3/\text{hr.}$$

(3) Diameter of Towers

Velocity of gas flow 1 m/min.

$$D = (4 \times 150 / 60 / 3.14 / 1)^{0.5} = 1.785 \text{ m}\phi, \text{ use } \rightarrow 1800 \text{ mm}\phi$$

(4) Chemical Consumption

Inflow and outflow gas H₂S concentrations are 100 ppm and 10 ppm, respectively.

$$\begin{aligned} V_1 &= 0.235 \times 10^{-3} \times Q \times \mu \\ &= 0.235 \times 10^{-3} \times 150 \times 24 \times 0.9 = 0.761 \text{ L/day} \\ &\quad (\mu \text{ Removal efficiency} = 90\%) \end{aligned}$$

$$V_0 = V_1 / (C_0 \times 0.8) = 0.761 / (100 / 1,000) \times 0.8$$

$$= 9.5 \text{ L/day}$$

C₀ : Chemical requirements to absorb 100 kg hydrogen sulfide = 1000 kg

γ : Nominal specific gravity of chemical 0.8

(5) Life of Chemical

$$T = \frac{(V \times 10^3) / V_0}{\text{Volume}} = \frac{(5 \times 10^3) / 9.5}{5 \text{ m}^3} = 525 \text{ days}$$

1.12.13 WASTE GAS BURNERS

(1) Specifications

Type	In furnace
Capacity	500 m ³ /hr.
Size	2,000 mm D x 10,200 mm H
Motor	Cooling fan
"	Gas blower
No. of units	2 units

(2) Treatment Capacity

Capacity: all produced gas

$$Q = 11,053 \times 1/24 \times 2.0 \times 1/2$$

$$= 461 \text{ m}^3/\text{hr. use} \rightarrow 500 \text{ m}^3/\text{hr.}$$

1.12.14 SEED SLUDGE PUMPS(SLUDGE WITHDRAW)

(1) Specifications

Type	Sludge pumps with suction screw
Size	100 mm
Capacity	1 m ³ /min.
T.H.L	15 m
Motor output	7.5 kW
No. of units	2 units

(2) Capacity

$$Q = 1 \text{ m}^3/\text{min.}$$

(3) Total Dynamic head

$$H = 15 \text{ m}$$

(4) Motor Output

$$P_m = 0.163 \times 1 \times 15 \times (1 + 0.2) / 0.4$$

$$= 7.34 \text{ kW use} \rightarrow 7.5 \text{ kW}$$

1.13 APPARATUS FOR SLUDGE DEWATERING EQUIPMENT

1.13.1 SLUDGE STORAGE TANK MIXER

(1) Specifications

Type	Vertical paddle type
Shape	Approximately 7,000mm x 11,500mm x 2,500mmH
Capacity	200 m ³

Blade size	2000 mm ϕ
Motor output	7.5 kW
No. of units	4 units

(2) Tank Capacity

Store average one-day sludge production

$$V = 805 \times 1/4 = 201 \text{ m}^3 \text{ use } 200 \text{ m}^3$$

1.13.2 SLUDGE SUPPLY PUMP**(1) Specifications**

Type	Single-axis screw pump
Size	ϕ 100 mm
Capacity	20 m ³ /hour
TDH	20 m
Motor output	5.5 kW
No. of units	2 units

(2) Discharge Capacity

One pump to each dewater equipment (one-standby pump for all dewatering Equipment)

$$Q1 = 130 \times 3 \times 10^{-3} \times 100 / (3 \times 1.5)$$

$$= 19.5 \text{ m}^3/\text{hour} \text{ use } \rightarrow 20 \text{ m}^3/\text{hour} \quad 0.33 \text{ m}^3/\text{minute}$$

Filter velocity	130 kg/m \cdot hr.
Filter width	3 m
Sludge solid concentration	3 %
Allowance	1.5

(3) Electric Motor Output

$$P_m = 0.163 \times 20 \times 0.33 \times (1+0.3) / 0.3$$

$$= 4.71 \text{ kW} \text{ use } \rightarrow 5.5 \text{ kW}$$

1.13.3 CHEMICAL FEED PUMP**(1) Specifications**

Type	Single-axis screw pump
Size	ϕ 50 mm
Capacity	3 m ³ /hour
TDH	20 m
Motor output	1.5 kW
No. of units	15 units (including one standby)

(2) Discharge Capacity

A pump to each dewater equipment (one standby pump for all dewatering Equipment)

$$Q1 = 130 \times 3 \times 10^{-3} \times 0.01 \times 100 / 0.2 \times 1.5$$

$$= 2.925 \text{ m}^3/\text{hour} \rightarrow 3 \text{ m}^3/\text{hour} \quad 0.05 \text{ m}^3/\text{min.}$$

Filter velocity	130 kg/m \cdot hr.
Filter width	3 m
Solid concentration of sludge	0.2 %

Allowance 1.5

(3) Electric Motor Output

$$P_m = 0.163 \times 20 \times 0.05 \times (1+0.3) / 0.25$$

$$= 0.85 \text{ kW use } \rightarrow 1.5 \text{ kW}$$

1.13.4 CHEMICAL SOLUTION TANKS

(1) Specifications

Tank type	Steel made cylinder type
Tank capacity	15 m ³
Approx. size	2,900 mmφ × 3,000mmH
Electric motor output	7.5 kW (for mixer)
No. of tanks	3 units

(2) Sludge Storage Tank Capacity

Dosing rate	$24.15 \times 10^3 \times 0.008 \times 7/5 = 270.47 \text{ kg/day}$
Dewatered solids	24.15 t/day
Chemical dosing rate (Polymer)	0.8 %/kg-ds
(5 days/week operation)	
Storage capacity.	2 hours of design sludge volume
	3 tanks (alternately used)
$V = (270 \times 100) / (0.2 \times 2 / 6 / 3)$	
	$= 15,026 \text{ L use } \rightarrow 15,000 \text{ L}$
Chemical solution concentration	0.2 %
Operation time a day	6 hours
Retention time	2 hours

1.13.5 CHEMICAL FEEDERS

(1) Specifications

Type	Chemical pump
Supply rate	4 L/min.
Electric motor output	0.4 kW
Quantity	3 units

(2) Supply Rate

One feeder is attached to each solution tank, supplying chemical in 15 to 20 minutes.

$$Q = 15,000 \times 10^3 \times 0.2 / 100 \times 1 / (15 \sim 20) \times 1 / 0.5$$

$$= 4.0 \sim 3.0 \rightarrow 4 \text{ L/min.}$$

Apparent specific gravity of polymer 0.5

1.13.6 CHEMICAL CONTAINERS

(1) Specifications

Type	Stainless steel made, cylinder container
Effective capacity	700 L
Quantity	2 units

(2) Capacity

Provide 2 tanks (alternately used), with capacity of 7-day chemical consumption.

$$V = 270.47 \times 7/5 \times 0.5 \times 7 \times 1/2$$

$$= 663 \text{ L use} \rightarrow 700 \text{ L}$$

1.13.7 FILTER CLOTH WASHING PUMPS**(1) Specifications**

Type	Multi-stage centrifugal pump
Size	ϕ 50 mm
Discharge	0.3 m ³ /min.
Total head	60 m
Electric motor output	7.5 kW
Quantity	15 units (including 1 standby)

(2) Discharge

One pump to each dewatering machine, and one standby pump for all equipment.

$$Q = 100 \times 3 = 300 \text{ L/min. use} \rightarrow 0.3 \text{ m}^3/\text{min.}$$

Then, the pump discharge per 1 m cloth is 100 L/min.

Total dynamic head 60 m

Electric motor output

$$P_m = 0.163 \times 60 \times 0.30 \times (1+0.2) / 0.5$$

$$= 7.04 \text{ kW} \rightarrow 7.5 \text{ kW}$$

1.14 EFFLUENT PUMPING STATION**1.14.1 FLOW RATE**

Flow rate is determined as follows.

Q _{ad}	200,000 m ³ /day	2,315 L/s
Q _{md}	235,000 m ³ /day	2,720 L/s
Q _{mh}	285,000 m ³ /day	3,299 L/s
Q _{ww}	570,000 m ³ /day	6,597 L/s

1.14.2 PUMPING EQUIPMENT**(1) Design Flow Rates:**

Q _{ad}	200,000 m ³ /day	139 m ³ /minute
Q _{md}	235,000 m ³ /day	163 m ³ /minute
Q _{mh}	285,000 m ³ /day	198 m ³ /minute
Q _{ww}	570,000 m ³ /day	396 m ³ /minute

(2) Wastewater Pumps

4 units (including 1 standby), mixed flow centrifugal type driven by electric motor.

(3) Storm Water Pumps

4 units (including 1 standby), mixed flow centrifugal type, smaller pumps driven by motor, and large pumps driven by diesel engine. Pump operation schedule is as follows.

Wastewater inflows	Wastewater inflow rates (m ³ /minute)	Pump discharges				Total pump discharge (m ³ /minute)
		Wastewater pumps		Storm water pumps		
		50	100	50	100	
Q _{ad}	139	50	100			150
Q _{md}	163	100	100			200
Q _{mh}	198	100	100			200
Q _{ww}	396	100	100	100	100	400

(4) Pump Size

No.1 Pumps $Q = 50 \text{ m}^3/\text{minute}$
 $D = 146(Q/V)^{0.5}$ $V = 2.5 \text{ m/sec}$
 $= 653 \text{ mm}$ use $\rightarrow 600 \text{ mm}$

No.2 Pumps $Q = 100 \text{ m}^3/\text{minute}$
 $D = 146(Q/V)^{0.5}$
 $= 923 \text{ mm}$ use $\rightarrow 900 \text{ mm}$

(5) Wastewater Surface Elevations:

Suction water levels at inflow of
 Q_{ad} 7.100 M.W.L.
 Q_{md} 7.100 M.W.L.
 Q_{mh} 7.100 M.W.L.
 Q_{ww} 7.100 M.W.L.

Suction water levels at outflow of
 Q_{ad} 9.100 M.W.L.
 Q_{md} 9.100 M.W.L.
 Q_{mh} 9.100 M.W.L.
 Q_{ww} 9.100 M.W.L.

(6) Actual Head:

Q_{ad} 9.100 - (7.100) = 2.000 m
 Q_{md} 9.100 - (7.100) = 2.000 m
 Q_{mh} 9.100 - (7.100) = 2.000 m
 Q_{ww} 9.100 - (7.100) = 2.000 m

Total head losses at pump equipment:

	$\phi 600$	$\phi 900$
Pump size	0.6	0.9
Pump bore(m)	0.6	0.9
Pump discharge(m ³ /min)	50	100
Pump discharge(m ³ /sec)	0.833	1.667
Delivery bore sectional area (m ²)	0.283	0.636
Pump velocity(m/s)	2.949	2.621
Loss coefficients		
Inlet	0.15	0.15
Sluice valve	0	0
Check valve	1.0	1.0
Outlet	1.0	1.0

Bend		0.25	0.25
Friction loss	$f' \times L/D$	0.781	0.514
Total		3.181	2.914 F

(7) Head Losses

$$\phi 600 = 1.411 \text{ m} \quad F \times V^2/2g$$

$$\phi 900 = 1.021 \text{ m}$$

$$\text{Pipe length } L = 15 \text{ m}$$

Friction loss by Darcy-Wiseback Formula

$$hf = f \times L/D \times V^2/2g$$

$$f = 0.02 + 1/(2000 \times D) \quad (\text{New cast iron pipe})$$

For old cast-iron pipes multiply the 'f' by 1.5

	$\phi 600$	$\phi 900$
D(m)	0.6	0.9
f	0.021	0.021
$f' = 1.5 \times f$	0.031	0.031

(8) Total Head Required

$$Q_{ad} \quad 2.000 + 1.411 (\phi 600) = 3.411 \text{ m}$$

$$1.021 (\phi 900) = 3.021 \text{ m}$$

$$Q_{md} \quad 2.000 + 0.000 = 2.000 \text{ m}$$

$$Q_{mh} \quad 2.000 + 0.000 = 2.000 \text{ m}$$

$$Q_{ww} \quad 2.000 + 1.021 (\phi 900) = 3.021 \text{ m}$$

The required total pump head is then 5.0 m

(9) Shaft Power of Mixed Flow Centrifugal Pumps

$$L = k \times \gamma \times Q \times H / \mu$$

where

L Shaft power of pump

k 0.163 kW or 0.222 PS

Q Pump discharge (m^3/min)

H Pump total dynamic head (m)

γ Specific gravity of water ($\gamma = 1$)

μ Pump efficiency

Calculations for shaft power requirements

Items		$\phi 600$	$\phi 900$	$\phi 900$ Engine
Pump discharge(Q)	m^3/min	50	100	100
TDH (H)	m	5.0	5.0	5.0
Pump efficiency(μ)		0.78	0.81	0.81
Shaft power	kW	52	101	137

(10) Outputs of Pump Drives

$$P = L(1+\alpha) / \mu \times G$$

where

P Pump power (kW)

L Pump shaft power (kW)

α	Allowance for motor	0.15
	Allowance for engine	0.2
μG	Transmission efficiency (1.0 for direct connection)	

	$\phi 600$	$\phi 900$	$\phi 900$ Engine
Shaft power (L)	52	101	137
Allowance (α)	1.15	1.15	1.20
Efficiency of transmission (μG)	1.00	1.00	0.95
Pump drive output (P) kW	60	116	173

(11) Pump Specifications

		Vertical mixed flow centrifugal pumps		
Pump bore	mm	600	900	900
Pump discharge	m ³ /min.	50	100	100
Total dynamic head	m	5	5	5
Motor/engine output	kW	60	116	173
Pump drive		Motor	Motor	Engine

2. RECIRCURATION PROCESS

2.1 DESIGN BASIS

2.1.1 DESIGN WASTEWATER INFLOW RATES

Design wastewater inflow rates are determined as follows.

Average daily flow	Qad	200,000 m ³ /day	2,315 L/s
Maximum daily flow	Qmd	235,000 m ³ /day	2,720 L/s
Maximum hourly flow	Qmh	285,000 m ³ /day	3,299 L/s
Wet weather flow	Qww	570,000 m ³ /day	6,597 L/s

2.1.2 DESIGN WASTEWATER QUALITY

Design wastewater quality is determined as follows.

BOD	=	130 mg/L
SS	=	150 mg/L
T-N	=	20 mg/L
T-P	=	3 mg/L

2.1.3 DESIGN WASTEWATER QUALITY (INCLUDING SIDESTREAM WASTE LOADS)

Design wastewater quality (including sidestream waste loads) calculated as follows.

BOD	=	170 mg/L
SS	=	180 mg/L
T-N	=	25 mg/L
T-P	=	4.5 mg/L

Parameter	Removal Efficiency(%)			Wastewater Quality (mg/L)		
	Primary treatment	Secondary treatment	Overall removal rate	Raw waste-water	Primary effluent	Secondary effluent
BOD	30	91	93.7	150	105	9
SS	40	93	95.8	180	108	8
T-N	10	60	64.0	25	22.5	9
T-P	10	78	80.2	4.5	4.05	0.9

2.1.4 POLLUTANT DISCHARGE LIMITS BY NTPA 001

Pollutant discharge limits by NTPA 001 is regulated as follows.

BOD5	<	20 mg/L
SS	<	60 mg/L
T-N	<	10 mg/L
T-P	<	1.0 mg/L

2.2 CALCULATIONS OF SIDESTREAM POLLUTANT LOADS

2.2.1 RAW SLUDGE VOLUME

Raw sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Solid production (t/day)} &= 235,000 \times 150 \times 10^{-6} \times 0.4 \\ &= 14.1 \text{ t/day} \\ \text{Sludge concentration} &= 2.0 \% \\ \text{Sludge volume} &= 14.1 \times 100 \div 2.0 = 705 \text{ m}^3/\text{day} \end{aligned}$$

2.2.2 WASTE SLUDGE VOLUME

Parameter	Influent quality (mg/L)	Reaction tank influent quality (mg/L)	Primary clarifiers removal Efficiency(%)
BOD	130	91	30
SS	150	90	40

Assuming that the reactor influent S-BOD is 66.7% of the total BOD; then S_{ec} is 60.7 mg/L. Waste sludge production volume can be calculated by the following equation:

$$Q_w \times X_w = (a \times S_{cs} + b \times S_{ss} - c \times \theta \times XA)Q$$

where,

Q_w	Volume of waste sludge (m ³ /day)	
X_w	Average SS concentration of waste sludge (mg/L)	
Q	Influent volume to reactors (m ³ /day)	235,000
XA	MLSS concentration in reactors (mg/L)	3,000
S_{cs}	Influent soluble-BOD concentration to reactors (mg/L)	60.7
S_{ss}	Influent SS concentration to reactors (mg/L)	90
a	Sludge yield coefficient of S-BOD (mg MLSS/mgSS)	0.4-0.6
b	Sludge yield coefficient of SS (mg MLSS/mgSS)	0.9-1.00
c	Coefficient of SS reduction due to indigenous respiration of activated sludge micro-organisms (1/day)	0.03-0.05
		0.04

$$\theta \quad \text{HRT in reactor basins (day)} \quad 13.2 / 24 = 0.55$$

therefore,

$$\begin{aligned} Q_w \times X_w &= (0.5 \times 60.7 + 0.95 \times 90 - 0.04 \times 0.5510621 \times 3,000) \times Q \times 10^{-6} \\ &= 49.72 \times Q \times 10^{-6} = 11.68 \text{ t/day} \\ \text{Solid production} &= 11.68 \text{ t/day} \\ \text{Sludge concentration} &= 0.9 \% \\ \text{Sludge production} &= 11.68 \times 100 \div 0.9 = 1,298 \text{ m}^3/\text{day} \end{aligned}$$

2.2.3 THICKENED SLUDGE

Thickened sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Sludge solids} &= 14.1 + 11.68 = 25.78 \text{ t/day} \\ &\quad \text{Primary sludge} \quad \text{Excess sludge} \\ \text{Sludge volume} &= 705 + 1,298 = 2,003 \text{ m}^3/\text{day} \\ &\quad (2.0\%) \quad (0.9\%) \\ \text{Solids} &= 25.78 \times 0.85 = 21.92 \text{ t/day} \\ \text{Assuming sludge concentration is} & \quad 3.5 \% \\ \text{Sludge volume} &= 21.92 \times 100 \div 3.5 = 626 \text{ m}^3/\text{day} \end{aligned}$$

2.2.4 SLUDGE SUPERNATANT OF THICKENERS

Sludge supernatant of thickeners weight is calculated by the following equation.

$$\begin{aligned} \text{Liquor volume} &= 2,003 - 626 = 1,377 \text{ m}^3/\text{day} \\ \text{Solids weight} &= 25.78 \times 0.15 = 3.87 \text{ t/day} \\ \text{BOD} &= 1,377 \times 2,000 \times 10^{-6} = 2.75 \text{ t/day} \\ \text{BOD is assumed to be of} & \quad 2,000 \text{ mg/L} \\ \text{T-N} &= 1,377 \times 700 \times 10^{-6} = 0.96 \text{ t/day} \\ \text{T-N is assumed to be of} & \quad 700 \text{ mg/L} \\ \text{T-P} &= 1,377 \times 180 \times 10^{-6} = 0.25 \text{ t/day} \\ \text{T-P is assumed to be of} & \quad 180 \text{ mg/L} \end{aligned}$$

2.2.5 DIGESTED SLUDGE

Digested sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Digested sludge solids} &= 21.92 \times (1 - 0.7 \times 0.5) = 14.25 \text{ t/day} \\ \text{Digested sludge volume} & \quad 3.0 \% \\ \text{Sludge volume} &= 14.25 \times 100 / 3.0 = 475 \text{ m}^3/\text{day} \end{aligned}$$

2.2.6 DEWATERED SLUDGE(SLUDGE CAKE)

Dewatered sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Solids} &= 14.25 \times 100 / 0.9 = 12.82 \text{ t/day} \\ &\quad (\text{Assuming } 20.0 \% \text{ solids concentration}) \\ \text{Cake volume} &= 12.82 \times 100 / 20.0 = 64 \text{ m}^3/\text{day} \end{aligned}$$

2.2.7 DIGESTED SLUDGE FILTRATE

Digested sludge filtrated weight is calculated by the following equation.

$$\text{Filtrate volume} = 475 - 64 = 411 \text{ m}^3/\text{day}$$

$$\begin{aligned} \text{Dry solids weight} &= 14.25 \times 0.10 = 1.42 \text{ t/day} \\ \text{BOD} &= 411 \times 1,500 \times 10^{-6} = 0.62 \text{ t/day} \\ &\quad (\text{Assumed BOD concentration} = 1,500 \text{ mg/L}) \\ \text{T-N} &= 411 \times 150 \times 10^{-6} = 0.06 \text{ t/day} \\ &\quad (\text{Assumed BOD concentration} = 150 \text{ mg/L}) \\ \text{T-P} &= 411 \times 80 \times 10^{-6} = 0.03 \text{ t/day} \\ &\quad (\text{Assumed BOD concentration} = 80 \text{ mg/L}) \end{aligned}$$

2.2.8 SIDESTREAM VOLUME AND WASTE LOAD

Sidestream volume and waste load is calculated by the following equation.

	Thickener supernatants	+	Sludge filtrate	=	
Liquor volume	= 1,377	+	411	=	1,788 m ³ /day
Dry solids	= 3.87	+	1.42	=	5.29 t/day
BOD	= 2.75	+	0.62	=	3.37 t/day
T-N	= 0.96	+	0.06	=	1.03 t/day
T-P	= 0.25	+	0.03	=	0.28 t/day

2.2.9 WASTEWATER QUALITY (INCLUDING ALL SIDESTREAMS)

Wastewater quality (including all sidestreams) is calculated by the following equation.

$$\begin{aligned} \text{Overall wastewater flow} &= \text{Influent} + \text{Sidestreams} \\ \text{Maximum daily flow} &= 235,000 + 1,788 = 236,788 \text{ m}^3/\text{day} \end{aligned}$$

Then, the design wastewater flow characteristics are;

$$\begin{aligned} \text{BOD} &= (235,000 \times 130 \times 10^{-6} + 3.37) / 236,788 \\ &= 0.000143252 \times 10^6 = 143 \rightarrow 150 \text{ mg/L} \\ \text{SS} &= (235,000 \times 150 \times 10^{-6} + 7.64) / 236,788 \\ &= 0.000171218 \times 10^6 = 171 \rightarrow 180 \text{ mg/L} \\ \text{T-N} &= (235,000 \times 20 \times 10^{-6} + 1.03) / 236,788 \\ &= 0.000024180 \times 10^6 = 24.2 \rightarrow 25 \text{ mg/L} \\ \text{SS} &= (235,000 \times 3 \times 10^{-6} + 0.28) / 236,788 \\ &= 0.000004163 \times 10^6 = 4.2 \rightarrow 4.5 \text{ mg/L} \end{aligned}$$

2.3 SLUDGE PRODUCTIONS

2.3.1 RAW SLUDGE

Raw sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Solid production (t/day)} &= 235,000 \times 180 \times 10^{-6} \times 0.4 \\ &= 16.92 \text{ t/day} \\ \text{Sludge concentration} &= 2.0\% \\ \text{Sludge volume} &= 16.92 \times 100 \div 2.0 = 846 \text{ m}^3/\text{day} \end{aligned}$$

2.3.2 WASTE SLUDGE VOLUME

Parameter	Influent quality (mg/L)	Reaction tank influent quality (mg/L)	Primary clarifiers removal Efficiency(%)
BOD	170	119	30
SS	180	108	40

Assuming that influent S-BOD to reactor basins is 66.7 % of the raw wastewater BOD, S-BOD concentration is estimated to be; 70.04 mg/L

Waste sludge production volume is calculated by the following equation.

$$Q_w \times X_w = (a \times S_{cs} + b \times S_{ss} - c \times 0 \times X_A) Q$$

where,

Q_w	Volume of excess sludge (m ³ /day)	
X_w	Average SS concentration of waste sludge (mg/L)	
Q	Influent volume to reactors (m ³ /day)	235,000
X_A	MLSS concentration in reactors (mg/L)	3,000
S_{cs}	Influent soluble-BOD concentration to reactors (mg/L)	70.04
S_{ss}	Influent SS concentration to reactors (mg/l)	108
a	Sludge yield coefficient of S-BOD (mg MLSS/mgSS)	0.4-0.6 0.5
b	Sludge yield coefficient of SS (mg MLSS/mgSS)	0.9-1.00 0.95
c	Coefficient of SS reduction due to indigenous respiration of activated sludge micro-organisms (1/day)	0.03-0.05 0.04
θ	HRT in reactor basins (day)	13.2 / 24 = 0.551062

therefore,

$$Q_w \times X_w = (0.5 \times 70.04 + 0.95 \times 108 - 0.04 \times 0.551 \times 3,000) \times Q \times 10^{-6}$$

$$= 71.49 \times Q \times 10^{-6} = 16.80 \text{ t/day}$$

$$\text{Solid production} = 16.80 \text{ t/day}$$

$$\text{Sludge concentration} = 0.9 \%$$

$$\text{Sludge production} = 16.80 \times 100 \div 0.9 = 1,867 \text{ m}^3/\text{day}$$

$$= 1.30 \text{ m}^3/\text{min.}$$

2.3.3 RETURN SLUDGE

Return sludge volume is calculated by the following equation.

$$\text{Sludge return ratio} = 50 \%$$

$$\text{Return sludge volume} = 235,000 \times 0.5 = 117,500 \text{ m}^3/\text{day}$$

$$= 81.6 \text{ m}^3/\text{min.}$$

2.3.4 GRAVITY SLUDGE THICKENERS

Gravity thickened sludge production volume is calculated by the following equation.

$$\text{Solids inflow} = 16.92 + 16.80 = 33.72 \text{ t/day}$$

Primary sludge Excess sludge

$$\text{Sludge inflow} = 846 + 1,867 = 2,713 \text{ m}^3/\text{day}$$

$$\text{Thickened sludge solids} = 33.72 \times 0.8 = 26.98 \text{ t/day}$$

Assume solids content to be 3.5 %

$$\text{Thickened sludge volume} = 26.98 \times 100 / 3.5 = 771 \text{ m}^3/\text{day}$$

2.3.5 ANAEROBIC SLUDGE DIGESTERS

Anaerobic digested sludge production volume is calculated by the following equation.

$$\text{Input solids} = 26.98 \text{ t/day}$$

$$\text{Input sludge volume} = 771 \text{ m}^3/\text{day}$$

Volatile solids content of sludge 70 %

Solids destruction rate 50 %

$$\text{Digested sludge solids} = 26.98 \times (1 - 0.7 \times 0.5) = 17.53 \text{ t/day}$$

Assume solids concentration is 3.0 %
 Digested sludge volume = $17.53 \times 100 / 3.0 = 584 \text{ m}^3/\text{day}$

2.3.6 SLUDGE DEWATERING

Dewatered sludge production volume is calculated by the following equation.

Input solids = 17.53 t/day
 Recovered solids (90%) = $17.53 \times 0.9 = 15.78 \text{ t/day}$
 Assuming solids concentration as 20.0 %
 Sludge cake volume = $15.78 \times 100 / 20.0 = 79 \text{ m}^3/\text{day}$

2.4 COMPONENT FACILITIES

2.4.1 DESIGN BASIS

Design wastewater inflow rate is determined as follows.

Average daily flow $Q_{in} = 200,000 \text{ m}^3/\text{d}$
 (Maximum daily flow in winter season)
 Maximum daily flow $Q_{in-max} = 235,000 \text{ m}^3/\text{d}$

Design wastewater quality :

Influent wastewater quality to reactor tank is calculated as follows.

BOD	105 mg/L	(S-BOD is 71.4 mg/l)	68 %
SS	108 mg/L		(SBOD/BOD)
T-N	22.5 mg/L		

Design discharge wastewater quality :

Design effluent wastewater quality from final sedimentation tank (average quality) is determined as follows.

Removal efficiency			
BOD	9 mg/L	91.4%	96
SS	8 mg/L	92.6%	100
T-N	10 mg/L	55.6%	12.5

T-N condition of Treated water is NOT-N 8.3 mg/L Removal efficiency (T-N) 60~70%
 K-N 1.7

Design water temperature 10 °c

2.4.2 DESIGN CALCULATION

(1) Recirculation Ratio(R)

Recirculation ratio (R) is calculated by the following equation.

Influent concentration of T-N to reactor tank $CTN_{in} = 22.5 \text{ mg/L}$
 (effluent water quality from final sedimentation tank)

NOT-N concentration, $C_{nox-eff} = 8.3 \text{ mg/L}$, Assuming that nitrogen ratio which concerned about nitrification in CTN_{in} is $\alpha = 0.7$, recirculation ratio R is

$$R = \alpha \times CTN_{in} / C_{NOX-eff} - 1$$

$$R = 0.7 \times 22.5 / 8.3 - 1 = 1.90 - 1 = 0.90 \rightarrow 1$$

(2) MLSS Concentration

MLSS concentration is calculated by the following equation.

Assuming that MLSS concentration at reactor tank 3,000 mg/L (2,000-3,000MLSS) and return sludge concentration 9,000 mg/l, so that return sludge ratio R r is

$$9000 R r = 3000 \times (1 + R r)$$

$$R r = (3,000) / (9,000 - 3,000) = 0.5$$

Recirculation flow Qc and return sludge flow Qr are respectively

$$R - R r = 1 - 0.5 = 0.5$$

$$Q_r = Q_{in} \times 0.5 = 100,000 \text{ m}^3/\text{day}$$

$$Q_c = Q_{in} \times 0.5 = 100,000 \text{ m}^3/\text{day}$$

(3) A -SRT

Retention time at aerobic tank is calculated by the following equation.

Assuming that complete nitrification, and to consider daily and seasonally change of water quantity and quality, A-SRT(d) is

$$\delta = 1.5 \text{ (Assuming)}$$

$$T = 10^\circ\text{c (Assuming)}$$

$$\theta_{XA} = \delta \times 20.6 \times \exp(-0.0627 \times T) - 0.627$$

$$= 1.5 \times 20.6 \times 0.534192 = 16.5 \text{ day}$$

(4) Aerobic Tank Capacity VA(m³)

$$VA = (Q_{in} \times \theta_{XA} \times (a \times C_s \cdot \text{BOD} \cdot \text{in} + b \times \text{SS} \cdot \text{in})) / (1 + c \times \theta_{XA}) \times X$$

$$\theta_{XA} = \text{Aerobic solids retention time} \quad 16.5 \text{ day}$$

$$a = \text{Gross yield coefficient of dissolved BOD (0.5-0.6)} \quad 0.55 \text{ gMLSS/gS-BOD}$$

$$C_s \cdot \text{BOD} = \text{Dissolved BOD concentration of influent flow} \quad 71.4 \text{ mg/L}$$

$$b = \text{Gross yield coefficient of SS (0.9-1.0)} \quad 0.95 \text{ gMLSS/gSS}$$

$$c = \text{Autolysis coefficient of sludge (0.025-0.035)} \quad 0.03 \text{ L/d}$$

$$X = \text{MLSS concentration} \quad 3,000 \text{ mg/L}$$

$$VA = 200,000 \times 16.51 \times 142 / 4486 = 104,414 \text{ m}^3$$

$$A \times C_s \cdot \text{BOD} \cdot \text{in} + b \times \text{SS} \cdot \text{in} = 0.55 \times 71.4 + 0.95 \times 108 = 142$$

$$(1 + c \times \theta_{XA}) \times X = (1 + 0.03 \times 16.5) \times 3,000 = 4,486$$

(5) Biological Reaction Tank Capacity V(m³)

Biological reaction tank capacity is calculated by the following equation.

Assuming BOD-SS load(LBOD/x) is 0.06 kgBOD/kgMLSS/day (0.05-0.1)

$$V = (BOD \cdot \text{in} \times Q_{in}) / (LBOD/x \times X)$$

$$= (105 \times 200,000) / (0.06 \times 3,000) = 116,667 \text{ m}^3$$

(6) Anoxic Tank Capacity VDN (m³)

Anoxic tank capacity VDN m³ is calculated by the following equation.

$$VDN = V - VA = 116,667 - 104,414 = 12,253 \text{ m}^3$$

(7) Capacity Ratio of Anoxic Tank and Aerobic Tank

$$VDN : VA = 12,253 : 116,667 = 1 : 9.5$$

(8) Speed Constant of Denitrification KDN (mgN/g MLSS/h)

Speed constant of denitrification KDN is calculated by the following equation.

$$KDN = (LNOX.DN \times 10^3) / (24 VDN \times X)$$

Here

$$CNOX.A = \alpha \cdot CTN \cdot in \times 1 / (1+R)$$

$$= (0.7 \times 22.5 \times 1) / (1 + 1) = 7.9 \text{ mg/L}$$

$$LNOX.DN = CNOX.A \times (Qr + Qc) \times 10^{-3}$$

$$= 7.9 \times (100,000 + 100,000) \times 10^{-3} = 1,575 \text{ kg/d}$$

$$KDN = (1,575 \times 10^3) / (24 \times 12,253 \times 3)$$

$$= 1.785 \text{ (mgN/gMLSS/h)} > 0.872 \text{ OK}$$

Check of denitrification speed

$$\text{Less than } (y') \text{ is NO } \quad y' = 6.2 \times 0.06 + 0.5 = 0.872$$

More than (y') is OK

Calculate	Vdn =	1,575	x	10 ³	
back		24	x	0.872	x 3
					= 25,086 m ³

$$VD : VA = 1 : 4.16$$

$$V = 25,086 + 104,414 = 129,500 \text{ m}^3$$

(9) Biological Reaction Tank Capacity and Retention Time

Biological reaction tank capacity and retention time is calculated by the following equation.

Retention time at biological reaction tank in winter season, t(h) is

$$t = (24 \times 129,500) / 200,000 = 15.5 \text{ h}$$

Retention time at aerobic tank in winter season, tA(h) is

$$t = (24 \times 104,414) / 200,000 = 12.5 \text{ h}$$

Retention time for daily maximum flow at biological reaction tank in winter season, t(h) is

$$t = (24 \times 129,500) / 235,000 = 13.2 \text{ h}$$

(10) Necessary Oxygen Demand Σ D (kg/d)

Necessary oxygen demands is calculated by considering of oxidation of carbonic organic matter, necessary oxygen for endogenous respiration and nitrification reaction of microorganisms in activated sludge, and necessary oxygen for maintain a dissolved oxygen.

$$OD = OD1 + OD2 + OD3 + OD4$$

Here

- OD Necessary oxygen demands (kgO₂/day) (AOR)
- OD1 Necessary oxygen for oxidation of carbonic organic matter (kgO₂/day)
- OD2 Necessary oxygen for endogenous respiration (kgO₂/day)
- OD3 Necessary oxygen for nitrification reaction (kgO₂/day)
- OD4 Necessary oxygen for maintain a dissolved oxygen (kgO₂/day)

$$OD1 = A (\text{kgO}_2/\text{kgBOD}) \times [\text{Removal BOD}(\text{kgBOD}/\text{day}) - \text{Denitrification volume}]$$

$$(\text{kgN/day}) \times K (\text{kgBOD/kgN})$$

Here A : Necessary oxygen for removal of BOD (0.5-0.7)

K : BOD consumption for denitrification (2.86)

$$\text{OD2} = B (\text{kgO}_2/\text{kgMLVSS}\cdot\text{day}) \times \text{VA} (\text{m}^3) \times \text{MLVSS} (\text{kgMLVSS}/\text{m}^3)$$

Here B : Oxygen consumption by endogenous respiration at MLSS unit
(0.05-0.15)

VA : Reaction tank capacity at aerobic part

$$\text{OD3} = C (\text{kgO}_2/\text{kgN}) \times \text{Nitrified Kj-N volume} (\text{kgN/day})$$

Here C : Nitrified oxygen at nitrification reaction (4.57)

Nitrified KJ-N (Inflow Kj-N) - (Outflow Kj - N volume)
- (Removal volume of Kj -N by excess sludge)

$$\text{OD4} = Q \times \text{DO concentration of reaction tank}$$

Here DO : Dissolved oxygen concentration at end point of aerobic tank 1.5mg/L

(Design flow = 200,000 m³/day)

BOD_{in} = 105 mg/L, T-N = 22.5 mg/L

BOD_{out} = 9 mg/L, VA = 104,414 m³

The results of calculation is shown in table below.

		unit		note
Necessary oxygen demands for oxidation of BOD (OD1)	(1) Q	m ³ /day	200,000	
	(2) BOD _{in}	mg/L	105	
	(3) BOD _{out}	mg/L	9	
	(4) $\{(2) - (3)\} \times (1) \times 10^{-3}$	kg/day	19,200	
	(5) Δ DN (denitrification volume)	kg/day	1,575	
	(6) $k \times (5)$ OD1 = $A \times \{(4) - (6)\}$	kg/day kg/day	4,505 882	k = 2.86 A = 0.06
Necessary oxygen demands for endogenous respiration (OD2)	(1) MLSS	mg/L	3,000	
	(2) VA	m ³	104,414	
	(3) $(1) \times (2) \times 10^{-3}$	kg/day	313,241	
	OD2 = B \times (3)	kg/day	31,324	B = 0.1
Necessary oxygen demands for nitrification reaction (OD3)	(1) α (nitrification ratio)		0.7	
	(2) T-N _{in}	mg/L	22.5	
	(3) Q	m ³ /day	200,000	
	OD3 = $4.57 \times (1) \times (2) \times (3) \times 10^{-3}$	kg/day	14,396	C = 4.57
Necessary oxygen demands for maintain dissolved oxygen (OD4)	(1) DO concentration at reaction tank	mg/L	1.5	
	(2) Q	m ³ /day	200,000	
	(3) Q _r + Q _c	m ³ /day	300,000	
	(4) $\{(2) + (3)\}$	m ³ /day	500,000	1.5
	OD4 = $(1) \times (4) \times 10^{-3}$	kg/day	750	
Necessary oxygen (OD) demands	OD = OD1 + OD2 + OD3 + OD4	kg/day	47,351 0.237 Q	

Design of air diffuser (Assuming that diffused air aeration, fine bubble, spiral flow)

$$EA = 7.5, \quad \rho = 1.293$$

$$Q_w = 0.233 \text{ (Assuming)}$$

$$\text{Supplied air (N m}^3\text{/day)} =$$

$$(\text{Necessary oxygen demands (kgO}_2\text{)}) / EA(\%) \times 10^{-2} \times \rho (\text{Air/Nm}^3) \times Q_w (\text{kgO}_2\text{/kgAir)}$$

$$= (0.237 \times Q) / (7.5 \times 0.01 \times 1.293 \times 0.233)$$

$$= 10.48 Q = 2,095,638 \text{ (N m}^3\text{/day)} = 1,455 \text{ (Nm}^3\text{/min)}$$

2.4.3 MEASURE FOR ADVANCED TREATMENT

Way of thinking


Changing from conventional activated sludge process to advanced treatment process (T-N, T-P removal)

Calculate a necessary treatment capacity of advanced treatment process and evaluate a capacity of conventional activated sludge process.
Extend a necessary ponds and equipment in the future.



Necessary treatment capacity of advanced treatment process

—



Treatment capacity of conventional activated sludge process

=



Extend or remodeling of treatment about shortage of capacity

Explanation of measures for advanced treatment

Here showing a treatment capacity of two processes in table below.

- * Conventional activated sludge process
- * Advanced treatment process(Recircuration process)

Explanation of Measures for Advanced Treatment

	unit	Necessary advanced capacity	Facility and equipment for advanced treatment	
			Conventional activated sludge process	Measures for shortage of capacity
• Primary sedimentation tank surface load	m ³ /m ² /day	35	35	—
Facility shape			φ35m × 4 tanks	
• Reaction tank Retention time	hour	13.2	13.2	13.2
Distribution ratio of water	%		6.1/13.2 × 100 = 46	100 - 46 = 54
Facility shape			Making a wall in reaction tank, and divided an anoxic zone and aerobic zone W5.5m × H5.5m × L64m × 32 tanks	Build an extend tank for reaction tank W5.5m × H5.5m × L73m × 32 tanks
• Final sedimentation tank surface load	m ³ /m ² /day	15	9.5	13.9
Facility shape			φ45m × 8 tanks	New ponds φ40m × 8 tanks
• Return sludge flow	%	Usually 50% (Sludge pump Capacity 100%)	Same to the left	Same to the left (New pumps are Necessary)
• Recirculation flow of nitrificated water	%	50%	Provide a recirculation pumps at the outflow point of reaction tank (aerobic tank)	Same to the left
• Supplied air flow	m ³ /min	1,455	558	897 Extend capacity
• Waste sludge volume (Inflow sludge solids of thickener) (exclude T-P removal)	t/day	33.72	46.44 (Sludge products from Conventional activated sludge process)	Not necessary a extend of capacity
(include T-P removal)		37.86		Not necessary a extend of capacity
• T-P removal by addition of coagulant		New equipment is necessary	Same to the left	Same to the left

Waste sludge volume produced from T-P removal

Waste sludge production volume by addition of coagulant

Influent T-P concentration of reaction tank 4.05 mg/L

Additional concentration of aluminum sulfate CA (mg/L) is calculated by following equation

$$CAL = C_{sp-in} \times m \times AL / P$$

Here

C_{sp-in}	Influent dissolved T-N concentration(mg/l)	4.05
P	Valence of phosphorus	31
AL	Valence of aluminum	27
m	Additional molality ratio	1 (assuming)

$$CAL = (4.05 \times 27 \times 1) / (31) = 3.5 \text{ mg/L}$$

Assuming that waste sludge production volume by addition of coagulant is 5 times as Additional phosphorus volume

$$\begin{aligned} \text{Waste sludge volume by addition of coagulant} &= QD \times 5 \times CAL \times 10^{-6} \\ &= 235,000 \times 5 \times 3.5 \times 10^{-6} = 4.14 \text{ t/day} \end{aligned}$$

$$\begin{aligned} \text{Waste sludge volume in case of removal of T-N and T-P simultaneously} \\ &= 33.72 + 4.14 = 37.86 \text{ t/day} \end{aligned}$$

APPENDIX-6 CONSTRUCTION PLAN AND COST ESTIMATE

1. CONSTRUCTION PLAN

1.1 GENERAL

Construction works for the project includes earth work, concrete work, pipe work, mechanical/electrical work, architectural work and miscellaneous work. These works, in general, will be executed by ordinary construction methods using construction equipment readily available in Galati. Major works are planned to be carried out with mechanical equipment for smooth and economical performance.

Construction site for the proposed facilities are located in the north-eastern part of Galati City. There would be no difficulty to transport materials and equipment because the area has adequately provided road networks. There is neither difficulty in obtaining water nor electricity for construction.

1.2 CONSTRUCTION METHOD

Major construction works are construction of WWTP, installation of wastewater pumps, installation of sewer pipes and construction of CSO regulators.

1.2.1 CONSTRUCTION OF WWTP

The major construction works of WWTP are construction of primary and final sedimentation tank, aeration tank, influent pumping station, sludge treatment facilities and administration building.

No special construction method will be applied for the construction of WWTP except placing of Pre-stressed concrete for sludge digester tank. Since there are many experiences to construct pre-stressed concrete structure by Romanian contractors, there would not be any difficulty to construct this kind of structures.

1.2.2 INSTALLATION OF SEWER PIPES

Open trench method would be adopted for installation of sewer pipes in principal. However, application of shield tunneling method and pipe jacking method would be considered in the part where pipe crosses the railway and will be installed in deeper depth.

1.2.3 CONSTRUCTION OF CSO REGULATOR

The CSO regulator is a underground reinforced concrete structure with a excavation depth of 3 to 5 m. Therefore, only ordinary construction methods are used for the construction.

1.3 CONSTRUCTION SCHEDULE

1.3.1 WORKING DAYS

Annual working days are estimated to be 225 days based on the following assumptions:

- Winter season idle period: 3 month (from Dec.15 to Mar. 15)
- Workable period: 275 days
- Sundays in workable period: 9 month x 4 days = 36 days

National holidays in workable period: 1 day
 Rainy days in workable period: 10 days
 (more than 10 mm/day, ave. last 5 years)
 Total work suspension days in workable period: 47 days

- Working days: 275 days - 47 days = 228 days : 225 days

1.3.2 WORK TIME

All the construction works will be done during day time in principle. The working time is eight (8) hours per day

1.3.3 REQUIRED CONSTRUCTION PERIOD AND SEQUENCE OF WORKS

Required construction periods are estimated based on the construction volume and the above mentioned working days and work time assumptions by each construction works/structures by ordinary scale of inputs. Construction plan for the Galati project is presented below.

	Period (Year)	1 st year 2000	2 nd year 2001	3 rd year 2002	4 th year 2003	5 th year 2004
Wastewater Treatment Plant						
Influent Pumping Station	1.5		██████████			
Wastewater Treatment Process	2.5		██████████	██████████		
Sludge Treatment Process	2			██████████	██████████	
Discharge Pumping Station	1.5				██████████	██████████
Power Receiving Facility	1					██████████
Administration Building	1					██████████
Interceptor	2				██████████	██████████

Construction Plan and Sequence of Works for the Galati Project

2. COST ESTIMATE

2.1 BASIS OF COST ESTIMATE

The project cost consists of I) construction cost, II) equipment cost, III) engineering service cost, IV) government administration cost and V) physical contingency, as shown below.

Structure of Project Cost

Item	Remarks
I Construction Cost	
II Engineering Service Cost	10% of (I)
III Government Administration Cost	2% of (I)
IV Contingency	10% of (I+II+III)
V Project Cost	I+II+III+IV

The project cost is estimated under the following conditions.

- All base costs are expressed under the economic conditions that prevailed in June 1999.
- The exchange rates of currencies are US\$1 = ROL15,756 = ¥122.
- Only equipment cost is classified into foreign and local currency portions and their rate is FC : LC = 70% : 30%, because all construction works are done by local products and equipment.

- Engineering service cost is including all services for detailed design, tendering assistance and construction supervision. The cost is assumed at 10% of the construction cost.
- Government administration cost is costs that should be prepared by government and/or executing agency (e.g. cost for personnel and organization for the project management, cost for commission for external loan, etc.). The cost is assumed at 2 % of the construction cost.
- All percentages mentioned above are assumed from former example of the same kind of projects.
- Price escalation is not counted.

2.2 CONSTRUCTION COST

The construction cost consists of 1) mobilization and demobilization cost, 2) cost for preparatory works, 3) cost for main works, and 4) cost for miscellaneous works.

2.2.1 MOBILIZATION AND DEMOBILIZATION COST

Mobilization and demobilization cost is assumed at five (5) percent of the cost for main works.

2.2.2 PREPARATORY WORKS

Cost for preparatory works is assumed at five (5) percent of the cost for main works.

2.2.3 COST FOR MAIN WORKS

The direct cost for main works (cost for civil work, mechanical/electrical equipment cost, mechanical/electrical equipment installation cost, and construction cost for administration building) will be estimated based on the results of preliminary engineering design. Indirect costs such as site expenses and overhead and profit are estimated by percentage.

- The site expense is estimated to be ten (10) percent of the direct cost of main works.
- The overhead and profit are estimated to be ten (10) percent of the direct cost of main works.
- The cost for the miscellaneous works is estimated to be ten (10) percent of the cost for main works.

Structure of Construction Cost

	Item	Remarks
I	Construction Cost	Total of I-1 to I-6
I-1	Mobilization and demobilization	5 % of I-3
I-2	Preparatory works	5 % of I-3
I-3	Main works	Total of I-3-1 to I-3-4
I-3-1	Civil work	
I-3-2	Mechanical/electrical equipment	
I-3-3	Mechanical/electrical equipment installation	
I-3-4	Administration building	
I-4	Miscellaneous works	10 % of I-3
I-5	Site expenses	10 % of I-3
I-6	Overhead and profit	10 % of I-3

(1) Cost for Civil and Architectural Work

The cost for civil and architectural work is estimated by multiplying the quantity of works by unit construction costs. The unit construction costs are estimated by unit prices of labor, construction materials and equipment.

The unit prices of personnel, material and equipment operation are estimated based on prevailing market prices referring the data collected from MPWTP and other organizations concerned. The unit prices that are used in the study are shown in the following tables.

Unit Costs of Personnel

	lei/month	lei/day
Engineer	3,500,000	140,000
Foreman	2,600,000	104,000
Skilled Labor	2,200,000	88,000
Common Labor	1,600,000	64,000
Technician	2,200,000	88,000
Equipment Operater	2,000,000	80,000
Driver	1,800,000	72,000
Administrator/Clark	3,000,000	120,000

Unit Price of Material

Item	Unit	Price (Lei)	
Sand	m3	100,000	
Sõil	m3	100,000	
Crushed stone	m3	200,000	
Asphalt	ton	800,000	
Tack coat	l	15,000	
Reinforcing bar	ton	5,000,000	
Wooden material	m3	700,000	
Ready mix concrete	B50	500,000	
	B200	700,000	
	B250	900,000	
RC pipe	Dia200 mm	m	100,000
	Dia300 mm		150,000
	Dia400 mm		175,000
	Dia500 mm		215,000
	Dia600 mm		250,000
	Dia700 mm		350,000
	Dia800 mm		450,000
	Dia1000 mm		750,000
	Dia1500 mm		2,000,000
	Dia1650 mm		2,350,000
	Dia2000 mm		3,500,000
	Dia2200 mm		4,500,000
Steel Pipe	Dia2800 mm		7,000,000
	Dia3400 mm		12,000,000
	Dia400 mm		500,000

Unit Price of Equipment Operation

Item		Price (Lei/day)
Dump Truck	10t	800,000
Truck		800,000
Concrete Transporter		1,200,000
Concrete Pumping Car		1,200,000
Bulldozer	11t	1,200,000
Backhoe	0.6m ³	1,000,000
Crawler Crane	20t	1,800,000
Truck Crane	20t	1,800,000
Pile Driving Machine		2,500,000
Tire Roller		800,000
Vibration Roller		400,000
Compactor		200,000

(2) Cost for Mechanical/Electrical Equipment and Installation

Since there are no published standard market price list for mechanical/electrical equipment for wastewater treatment, the cost for mechanical/electrical equipment will be obtained from manufacturer that have experience in Romania and/or neighboring countries based on the specifications resulting from preliminary engineering design.

The appropriate cost decided based on the obtained quotation would be used for the mechanical/electrical equipment cost for the project.

(3) Direct Cost for Main Works

The direct cost for main works are estimated for WWTP and interceptor separately as shown in *Tables AII.6.1 and AII.6.2.*

2.3 PROJECT COST

Estimated total project cost is about ROL 1,684,237 million, and its breakdown is shown below. Of the total project cost, ROL 504,061 million or 30% is foreign currency portion, and remaining ROL 1,180,176 million or 70% is local currency portion.

Project Cost (Galati Project)

Item	Cost (million Lei)	FC (million Lei)	LC (million Lei)
I Construction Cost	1,367,075	435,707	931,368
Mobilization and Demobilization	48,824	0	48,824
Preparatory Works	48,824	0	48,824
Main Works	976,482	435,707	540,775
Wastewater Treatment Plant	906,417	435,707	470,710
Influent Pumping Station	89,076	47,677	41,399
Wastewater Treatment Process	387,738	193,589	194,149
Sludge Treatment Process	257,540	146,238	111,302
Discharge Pumping Station	113,202	47,678	65,524
Site Finalization	42,789	0	42,789
Power Receiving Facility	8,592	0	8,592
Administration Building	7,479	525	6,954
Interceptor	70,066	0	70,066
Miscellaneous Works	97,648	0	97,648
Site Expenses	97,648	0	97,648
Overhead and Profit	97,648	0	97,648
II Engineering Service Cost	136,708	68,354	68,354
III Government Administration Cost	27,342	0	27,342
IV Contingency	153,112	0	153,112
V Project Cost	1,684,237	504,061	1,180,176

(unit: million lei)

2.4 OPERATION AND MAINTENANCE (O/M) COST

Major portions of O/M cost of the WWTP are electric power charge for the equipment and cost for personnel. The O/M cost for the Galati project is estimated at ROL 16,518 million as shown in the following table.

Operation and Maintenance Cost for Galati Project

Item	unit	unit price	Q'ty	Total
Personnel	lei/month/person (average)	2,000,000	55	1,320
Electricity	lei/kwh	500	2,134	9,217
Chemical	lei/kg	5,000	1,822,000	911
Excess Sludge Disposal	m ³	20,000	553,578	2,768
Repairing others	0.5% of Mechanical cost 10% of above		40,000	800 1,502
Total				16,518

(unit: million lei)

3. IMPLEMENTATION PROGRAM**3.1 IMPLEMENTATION SCHEDULE**

The project will be completed within five (5) years from 2000. Pre-construction stage of one (1) year is assumed for the detailed design period and tender process followed by four (4) years' construction works.

Proposed implementation schedule is presented below.

	Period (Year)	1 st year 2000	2 nd year 2001	3 rd year 2002	4 th year 2003	5 th year 2004
Detailed Design	1	[Bar spanning 2000]				
Construction	4	[Bar spanning 2001-2004]				
Wastewater Treatment Plant		[Bar spanning 2001-2004]				
Influent Pumping Station	1.5	[Bar spanning 2001-2002]				
Wastewater Treatment Process	2.5	[Bar spanning 2001-2003]				
Sludge Treatment Process	2			[Bar spanning 2002-2004]		
Discharge Pumping Station	1.5			[Bar spanning 2003-2004]		
Power Receiving Facility	1			[Bar spanning 2004]		
Administration Building	1			[Bar spanning 2004]		
Interceptor	2			[Bar spanning 2003-2004]		

Implementation Schedule (Galati Project)

3.2 DISBURSEMENT SCHEDULE

Proposed annual cost disbursement schedule of the Galati project for entire project life is shown in *Table AII.6.3*.

Table AII.6.1 Direct Construction Cost of WWTP (Galati)

Item	Unit	Quantity	Unit Price (Lei)	Amount (million Lei)	FC (million Lei)	LC (million Lei)	
1 Influent Pumping Station							
1-1 Civil Work							
1) Earth Work							
Excavation	m3	17,842	5,000	89	0	89	
Backfill	m3	11,942	22,000	263	0	263	
2) RC Concrete							
RC Concrete I	Floorborad	m3	330	1,543,000	509	0	509
RC Concrete II	Wall	m3	1,168	1,771,000	2,069	0	2,069
3) Pile Work (ave.L=10m, incl. driving work)							
	pcs	119	4,810,000	572	0	572	
1-2 Architectural Work							
	m2	745	4,000,000	2,980	0	2,980	
1-3 Mechanical							
1) Equipment							
	ls	1	68,110,400,000	68,110	47,677	20,433	
2) Installaiton							
	%	15		10,217	0	10,217	
1-4 Electorical							
	ls	1	4,267,089,000	4,267	0	4,267	
2 Wastewater Treatment Process							
2-1 Preliminary Treatment Process							
(1) Civil Work							
1) RC Concrete							
RC Concrete I	Floorborad	m3	4,192	1,543,000	6,468	0	6,468
RC Concrete II	Wall	m3	1,808	1,771,000	3,202	0	3,202
2) Pile Work (ave.L=10m, incl. driving work)							
	pcs	388	4,810,000	1,866	0	1,866	
(2) Mechanical							
1) Equipment							
	ls	1	52,822,400,000	52,822	36,976	15,847	
2) Installaiton							
	%	15		7,923	0	7,923	
(3) Electorical							
	ls	1	167,805,000	168	0	168	
2-2 Secondary Treatment Process							
(1) Civil Work							
1) Earth Work							
Excavation	m3	30,860	5,000	154	0	154	
Backfill	m3	3,385	22,000	74	0	74	
2) RC Concrete							
RC Concrete I	Floorborad	m3	17,147	1,543,000	26,458	0	26,458
RC Concrete II	Wall	m3	14,834	1,771,000	26,271	0	26,271
3) Pile Work (ave.L=10m, incl. driving work)							
	pcs	24	4,810,000	115	0	115	
(2) Architectural Work							
	m2	338	4,000,000	1,352	0	1,352	
(3) Mechanical							
1) Equipment							
	ls	1	213,567,200,000	213,567	149,497	64,070	
2) Installaiton							
	%	15		32,035	0	32,035	
(4) Electorical							
	ls	1	996,812,400	997	0	997	
2-3 Final Treatment Process							
(1) Civil Work							
1) Earth Work							
Excavation	m3	2,745	5,000	14	0	14	
Backfill	m3	795	22,000	17	0	17	
2) RC Concrete							
RC Concrete I	Floorborad	m3	517	1,543,000	798	0	798
RC Concrete II	Wall	m3	778	1,771,000	1,378	0	1,378
(2) Architectural Work							
	m2	90	4,000,000	360	0	360	
(3) Mechanical							
1) Equipment							
	ls	1	10,166,400,000	10,166	7,116	3,050	
2) Installaiton							
	%	15		1,525	0	1,525	
(4) Electorical							
	ls	1	6,102,000	6	0	6	
3 Sludge Treatment Process							
3-1 Civil Work							
1) Earth Work							
Excavation	m3	17,378	5,000	87	0	87	
Backfill	m3	8,929	22,000	196	0	196	
2) RC Concrete							
RC Concrete I	Floorborad	m3	2,642	1,543,000	4,077	0	4,077
RC Concrete II	Wall	m3	431	1,771,000	763	0	763
3) PC Concrete							
	m3	1,707	3,010,700	5,139	0	5,139	
4) Pile Work (ave.L=10m, incl. driving work)							
	pcs	219	4,810,000	1,051	0	1,051	
3-2 Architectural Work							
	m2	1,120	4,000,000	4,480	0	4,480	
3-3 Mechanical							
1) Equipment							
	ls	1	208,911,200,000	208,911	146,238	62,673	
2) Installaiton							
	%	15		31,337	0	31,337	
3-4 Electorical							
	ls	1	1,498,345,800	1,498	0	1,498	
4 Discharge Pumping Station							
4-1 Civil Work							

Table AII.6.1 Direct Construction Cost of WWTP (Galati)

Item	Unit	Quantity	Unit Price (Lei)	Amount (million Lei)	FC (million Lei)	LC (million Lei)	
1) Earth Work							
Excavation	m3	1,514	5,000	8	0	8	
Backfill	m3	682	22,000	15	0	15	
2) RC Concrete							
RC Concrete I	Floorboard	m3	156	1,543,000	241	0	241
RC Concrete II	Wall	m3	654	1,771,000	1,158	0	1,158
4-2 Architectural Work		m2	416	4,000,000	1,664	0	1,664
4-3 Mechanical							
1) Equipment	ls	1	68,111,200,000	68,111	47,678	20,433	
2) Installaiton	%	15		10,217	0	10,217	
4-4 Electorical		ls	1	274,996,800	275	0	275
4-5 Discharge Sewer	dia 2800 mm, EC=2m	m	3,200	9,848,000	31,514	0	31,514
5 Site Finalization							
5-1 Civil Work							
1) Embankment by Excavated soil	m3	44,606	22,000	981	0	981	
2) Embankment by Purchased soil	m3	326,620	128,000	41,807	0	41,807	
6 Power Receiving Facility		ls	1	8,592,315,600	8,592	0	8,592
7 Administration Building							
7-1 Architectural Work							
1) Architectural Work	m2	1,500	4,000,000	6,000	0	6,000	
2) Pile Work (ave.L=10m, incl. driving work)	pcs	104	4,810,000	498	0	498	
7-2 Labo. and Office Equipment							
1) Labo. and Office Equipment	ls	1	750,000,000	750	525	225	
2) Installaiton	%	0		0	0	0	
7-3 Electorical	ls	1	231,600,000	232	0	232	
TOTAL				906,417	435,707	470,710	

701,846

Table All.6.2 Direct Construction Cost of Interceptor (Galati)

Item	Unit	Quantity	Unit Price (Lei)	Amount (million Lei)	FC (million Lei)	LC (million Lei)	
1 Pipe, Manhole and CSO							
1-1 Installation of interceptor pipe (RC pipe)							
1) RC pipe 300 mm	earth coverage 1 to 3 m	m	20	914,000	18.3	0	
2) RC pipe 400 mm	earth coverage 1 to 3 m	m	40	989,000	39.6	0	
3) RC pipe 500 mm	earth coverage 1 to 3 m	m	40	1,109,000	44.4	0	
4) RC pipe 700 mm	earth coverage 1 to 3 m	m	300	1,459,000	437.7	0	
5) RC pipe 800 mm	earth coverage 1 to 3 m	m	20	1,750,000	35.0	0	
7) RC pipe 1500 mm	earth coverage 1 to 3 m	m	282	3,871,000	1,091.6	0	
8) RC pipe 1500 mm	earth coverage 3 to 5 m	m	14	4,155,000	58.2	0	
9) RC pipe 2000 mm	earth coverage 1 to 3 m	m	2,258	5,881,000	13,279.3	0	
10) RC pipe 2200 mm	earth coverage 1 to 3 m	m	517	7,113,000	3,677.4	0	
11) RC pipe 2200 mm	earth coverage 3 to 5 m	m	1,957	7,543,000	14,761.7	0	
12) RC pipe 2200 mm (with sup	earth coverags 3 to 5 m	m	20	9,805,900	196.1	0	
1-2 Sewer construction by shield tunneling method							
1) Dia 2200 mm sewer	shield tunneling method	m	2,734	12,950,000	35,405.3	0	
1-3 Installation of CSO							
1) CSO type I	small type	place	1	22,906,000	22.9	0	
2) CSO type II	large type	place	4	92,960,000	371.8	0	
1-4 Installation of Manhole							
1) Manhole	d=1500mm, EC=2m	place	3	14,370,000	43.1	0	
2) Manhole	d=2000mm, EC=2m	place	10	19,811,000	198.1	0	
3) Manhole	d=2200mm, EC=2m	place	4	22,253,000	89.0	0	
4) Manhole	d=2200mm, EC=4m	place	9	25,945,000	233.5	0	
5) Manhole	d=2200mm, EC=6m	place	1	29,572,000	29.6	0	
6) Manhole	d=2200mm, EC=8m	place	1	33,199,000	33.2	0	
Total					70,065.7	0	70,066

54,252

Table AII.6.3 Disbursement Schedule of Galati Project

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30					
Detailed Design																																			
Total	68,354																																		
FC	34,177																																		
LC	34,177																																		
Construction					240,235	340,454	423,151	395,035																											
Total					48,824	24,412	24,412																												
FC					39,076	43,482	45,264	0	0																										
LC					47,877	15,892	31,785	0	0																										
Watermeter Treatment Plant Construction																																			
Total					41,290	27,599	13,800	0	0																										
FC					387,738	116,378	155,095	116,266	0																										
LC					194,146	26,718	77,436	77,458	0																										
Sludge Treatment Process																																			
Total					237,240	0	51,568	103,016	103,016	0																									
FC					160,238	0	23,248	36,485	36,485	0																									
LC					111,502	0	22,260	44,521	44,521	0																									
Discharge Pumping Station																																			
Total					42,678	0	0	39,572	30,527	0																									
FC					65,524	0	0	15,883	31,785	0																									
LC					42,789	0	0	40,089	42,781	0																									
Site Finalization																																			
Total					42,789	0	0	0	0	42,789	0																								
FC					0	0	0	0	0	0	0																								
LC					42,789	0	0	0	0	42,789	0																								
Power Receiving Facility																																			
Total					8,592	0	0	0	0	8,592	0																								
FC					0	0	0	0	0	0	0																								
LC					8,592	0	0	0	0	8,592	0																								
Administration Building																																			
Total					7,479	0	0	0	0	7,479	0																								
FC					525	0	0	0	0	525	0																								
LC					6,954	0	0	0	0	6,954	0																								
Interceptor Construction																																			
Total					70,066	0	0	35,033	35,033	0																									
FC					0	0	0	0	0	0																									
LC					70,066	0	0	35,033	35,033	0																									
Other Costs																																			
Total					341,789	55,854	88,266	109,861	87,688	0																									
FC					0	0	0	0	0	0																									
LC					341,789	55,854	88,266	109,861	87,688	0																									
Construction Supervision																																			
Total					60,354	17,086	17,086	17,086	0																										
FC					34,177	8,544	8,544	8,544	0																										
LC					26,177	8,544	8,544	8,544	0																										
Government Administration																																			
Total					27,342	4,905	6,809	8,475	7,253	0																									
FC					150,112	6,838	26,213	35,435	44,031	38,698																									
LC					1,551,950	1,161,000	1,161,000	1,161,000	1,161,000	1,161,000																									
C/M Cost																																			
Total					396,950	1,551,950	1,161,000	1,161,000	1,161,000	1,161,000																									
FC					32,206,187	75,189	288,241	400,786	604,246	623,874																									
LC					1,865,091	34,177	82,154	147,012	60,308	99,350																									
LC					1,571,29	41,012	225,187	253,774	523,078	526,325																									

APPENDIX-7 FINANCIAL AND ECONOMIC ANALYSIS

1 FINANCIAL ANALYSIS

1.1 MAJOR PRECONDITIONS AND ASSUMPTIONS

Following preconditions and assumptions were applied in the financial plan.

- The financial plan deals with only the cost and the revenue accrued by the project.
- Currency unit is ROL and the value of ROL is expressed as the June 1999 prices.
- Projection period is 30 years since the start of project implementation.
- Target year is 2010. From 2010 on the values of variables related to revenues and O & M cost are assumed to keep the 2010 level.
- Implementation period is 5 years from 2000 to 2004.
- 38 % of profit before tax is levied as a corporate tax.

Depreciation period is assumed as follows.

Depreciation Period

Item	Mechanical equipment	Civil works and sewer pipes
Depreciation period	8 years	40 years

1.2 TERMS AND CONDITIONS OF EXTERNAL FINANCIAL SOURCES

Conditions of possible external financial sources are assumed as shown in the table below.

Assumed Financing Terms for Possible External Financial Sources

Financial Organs	Financing Ratio (%)	Loan/Grant	Interest Rate (%)	Repayment Period (Years)	Grace Period (Years)
JBIC	70	Loan	2.7	30	10
EBRD	70	Loan	6.5	15	3
ISPA	75	Grant	-	-	-

It should be noted that they are nothing other than an example or assumption. In the case of EBRD, financing ratio depends on the circumstances and interest rate fluctuates in parallel with LIBOR (London Inter-bank Offered Rate).

1.3 BACKGROUND DATA FOR FINANCIAL PLAN

1.3.1 SERVED POPULATION

The sewerage served population in 2010 was estimated 377,000. It was assumed that the present population increases linearly until 2010 and ever since remains 377,000. In addition, the household size was assumed to be constant at present value of 3.1 persons/household.

The numbers of served population and served household were estimated as follows.

Number of Served Population and Household

Year	2005	2006	2007	2008	2009	2010	from 2011
Served population	356,625	360,700	364,775	368,850	372,925	377,000	377,000
Served household	115,040	116,355	117,669	118,984	120,298	121,613	121,613

1.3.2 QUANTITY OF WASTEWATER

Similar to the served population, the quantity of wastewater was assumed to increase linearly from the present value to the estimated value in 2010, and since ever to remain at the level in 2010. Non-domestic wastewater is composed of commercial, institutional and industrial ones.

The estimated quantities of domestic and non-domestic wastewater are as follows.

Quantity of Domestic and Non-domestic Wastewater

Year	(Unit : 1,000 m ³ /year)						
	2005	2006	2007	2008	2009	2010	from 2011
Domestic	34,919	35,354	35,790	36,226	36,664	37,102	37,102
Non-domestic	31,824	32,641	33,455	34,269	35,083	35,898	35,898

The coefficient *b*, the ratio of non-domestic sewerage charge to domestic one, was estimated 3.38 based on the values in 1998 and 1999.

1.3.3 HOUSEHOLD INCOME

The average monthly household income was estimated at ROL 3,063,748 in 1999 based on the result of the people's awareness survey conducted in this study. It was assumed to grow 3 % per year until 2010, and to remain the level of 2010 whereafter. The annual household income was calculated by multiplying the monthly value with 12.

The estimated average annual household income is as follows.

Average Annual Household Income

Year	(Unit : 1,000 ROL/year)						
	2005	2006	2007	2008	2009	2010	from 2011
Annual Household Income	43,899	45,216	46,573	47,970	49,409	50,891	50,891

1.3.4 COLLECTION RATE

The charge collection rate was assumed to linearly increase from 72 % in 1999 to 95% in 2010, then remain 95% ever since.

The collection rate of sewerage charge was estimated as follows.

Sewerage Charge Collection Rate

Year	2005	2006	2007	2008	2009	2010	from 2011
Collection Rate	84.5 %	86.6 %	88.7 %	90.8 %	92.9 %	95.0 %	95.0 %

1.4 FINANCIAL STATEMENTS FOR PROPOSED FINANCIAL PLANS

The financial statements for the proposed financial plans are shown in *Tables AII.7.1 to AII.7.4*.

The structure of applied financial statements is as follows.

Structure of Applied Financial Statements

S.C. APATERM S.A. account	
Revenue	A
Operation and maintenance cost	B
Lease fee	C
Profit before tax	$D = A - B - C$
Corporate tax	$E = D \times 0.38$
Profit after tax	$F = D - E$
Working capital	$G = F$
Cumulative working capital	$H = \Sigma G$
City's sewerage service account	
Revenue from lease fee	$I = C$
Depreciation	J
Payment of interest	K
Profit	$L = I - J - K$
Loan	M
Subsidy from general budget	N
Depreciation	$O = I$
Sources	$P = L + M + N + O$
Investment cost	Q
Payment of principal	R
Applications	$S = Q + R$
Working capital	$T = P - S$
Cumulative working capital	$U = \Sigma T$
City's general account	
City general revenue	V
Corporate tax from S.C. APATERM S.A.	$W = E$
Revenue from lease fee	$X = I$
Total current revenue	$Y = V + W + X$
Subsidy	$Z = N$
Subsidy ratio	$AA = Z/Y$
Repayment ratio	$AB = (K + R)/Y$

It is noted that leveled allocation of lease fee was applied for EBRD cases, taking into consideration of quite intense repayment schedule for relative short period under EBRD conditions.

2 ECONOMIC ANALYSIS

Based on the economic benefit of the project estimated by the people's awareness survey conducted in this study and the project cost, an economic analysis was conducted.

Applied preconditions and assumptions are as follows:

- Currency unit is ROL and the value of ROL is a constant one expressed at the June 1999 prices.
- Project Life: 30 years since the start of project implementation.

- Target Year: 2010. From 2010 on the values of O & M cost variables are assumed to keep the 2010 level.
- Implementation Period: 5 years 2000 to 2004.
- OCC (Opportunity Cost of Capital): 10%.
- Conversion factor: 98.4% to capital cost (initial and replacement cost) taking account of customs duty for foreign components.

The cost benefit stream of the project, which calculates the EIRR (Economic Internal Rate of Return), NPV (Net Present Value), and B/C (Ratio of Benefit to Cost), is shown in *Table AII.7.5*.

Obtained EIRR, NPV, and B/C are as below:

NPV (ROL 1,000,000)	B/C	EIRR (%)
111,708	1.07	13.1

Results of the sensitivity analysis are as shown below:

Conditions	EIRR (%)	NPV (million Lei)	B/C
Cost: +20%	NA	- 210,418	0.89
Cost: +10%, Benefits: -10%	NA	- 221,589	0.87
Benefits: -20%	NA	- 232,760	0.86