

Table All.3.1 List of Mechanical Equipment of Braila WWTP

(1) Screening System Equipment

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total out-put(kW)	Remarks
1	Screen channel influent gates	Cast iron made, manually operated sluice gate	1200W x 1200H	2	-	-	
2	Coarse screens	Manually screened (removable type)	Clear opening 100 mm, 1.6mW x 3.3mH, 60°	2	-	-	
3	Fine screens	Mechanically-cleaned, (intermittently operated)		0	-	-	
4	Grit chamber effluent gates	Cast iron made, manually operated sluice gate	1.2mW x 1.2mH	2	-	-	
5	Gate for pump well influent channel	Cast iron made, manually operated sluice gate	0.8mW x 0.8mH Design depth 5.0 m	1	-	-	
6	Screenings conveyors	Trough belt conveyor		0	-	-	
7	Screenings skip hoist	Wire rope operated		0	-	-	
8	Screenings hopper	Steel made, motor operated	5m ³	0	-	-	
9	Screening hoist	Motor operated hoist with trolley		0	-	-	
	Total motor outputs of (1)					0 kW	

Note: As the lift pumping station is provided with fine bar screens, these are excluded from the WWTP pumping station.

(2) Grit Chamber, Oil Separator, Flow Measurement Equipment

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total out-put (kW)	Remarks
1	Aeration channel Influent gates	Manually operated, cast iron made sluice gate	800mm W x 800mmH Design hydraulic depth; 2 m	8	-	-	
2	Blowers	Turbo blower	φ 125mm x 15m ³	5 (1)	55	220	Standby excluded
3	Grit collectors	Trolley with grit lifting pump	3.8kW x 380v	2	3.8	7.6	
4	Screw conveyors	Lifting of grit from grit channel to grit hopper	2.2kW x 380v	2	2.2	4.4	
5	Aeration chamber effluent channel gates	Manually operated, cast iron made sluice gate	600mm W x 600mm H Design hydraulic depth; 2 m	4	-	-	
6	Flow measurement equipment	Parshall flume	7-ft. type	1	-	-	
	Total motor outputs of (2)					232 kW	

(3) Pumping Equipment

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	total out put(kW)	Remarks
I. INFLUENT PUMPS							
1	No.1 Pumps	Vertical centrifugal mixed pump	450mmΦ x 25m ³ /min. x 11m	4	--		
2	No.1 Pump electric motor	Vertical squirrel cage, water proof type	70kW x 4p x 380v	4	70	280	
3	Suction valves	Manually operated sluice valve	450mmΦ	4	--		
4	Check valves	Slow-closing check valve	450mmΦ	4	--		
5	Discharge valves	Motor-operated butterfly valve	450mmΦ	4	0.2	0.8	
6	No.2 Pumps	Vertical centrifugal mixed pump	600mmΦ * 50m ³ /min. x 11m	2 (1)	--		
7	No.2 Pump electric motor	Vertical squirrel cage, water proof type	132kW x 6p x 380v	2 (1)	132	132	Standby excluded
8	Suction valves	Manually-operated sluice valve	600mmΦ	2	--		
9	Check valves	Slow-closing check valve	600mmΦ	2	--		
10	Discharge valves	Motor-operated butterfly valve	600mmΦ	2	0.2	0.4	
11	No.3 Pumps	Vertical centrifugal mixed pump	600mmΦ * 50m ³ /min. x 11m	2 (1)	--		
12	No.3 Pump diesel engine	Diesel engine	198ps	2 (1)	--		
13	Suction valves	Manually-operated sluice valve	600mmΦ	2	--		
14	Check valves	Slow-closing check valve	600mmΦ	2	--		
15	Discharge valves	Motor-operated butterfly valve	600mmΦ	2	0.2	0.4	
16	Crane for pumps	Manually-operated crane with chain block	3.2 t x 25mH x 7mW x 19mL	1	--		Girders by building works
17	Main pumps sealing water supply unit	Unit of water supply pump with pressure tank	40mmΦ x 0.1m ³ /min. x 35m	1	2.2	2.2	With control panel
18	Pump room floor drain pumps	Submersible pump	65mmΦ x 0.3m ³ /min. x 25m	2 (1)	3.8	3.8	Standby excluded
19	Floor drain pumps	Submersible pump	65mmΦ * 0.3m ³ /min. x 10m	2 (1)	1.5	1.5	Standby excluded
	Total motor outputs of I.					421.1 kW	
II. EFFLUENT PUMPS							
1	No.1 Pumps	Vertical centrifugal mixed pump	450mmΦ x 25m ³ /min. x 5m	4	--		
2	No.1 Pump electric motor	Vertical squirrel cage, water proof type	32kW x 4p x 380v	4	32	128	
3	Suction valves	Manually operated sluice valve	450mmΦ	4	--		
4	Check valves	Slow-closing check valve	450mmΦ	4	--		
5	Discharge valves	Motor-operated butterfly	450mmΦ	4	0.2	0.8	

6	No.2 Pumps	Vertical centrifugal mixed pump	600mmΦ * 50m ³ /min. x 5m	2 (1)	--		
7	No.2 Pump electric motor	Vertical squirrel cage, water proof type	60kW x 6p x 380v	2 (1)	60	60	Standby excluded
8	Suction valves	Manually-operated sluice valve	600mmΦ	2	--		
9	Check valves	Slow-closing check valve	600mmΦ	2	--		
10	Discharge valves	Motor-operated butterfly valve	600mmΦ	2	0.2	0.4	
11	No.3 Pumps	Vertical centrifugal mixed pump	600mmΦ * 50m ³ /min. x 5m	2 (1)	--		
12	No.3 Pump diesel engine	Diesel engine	90 ps	2 (1)	90		
13	Suction valves	Manually-operated sluice valve	600mmΦ	2	--		
14	Check valves	Slow-closing check valve	600mmΦ	2	--		
15	Discharge valves	Motor-operated butterfly valve	600mmΦ	2	0.2	0.4	
16	Crane for pumps	Manually-operated crane with chain block	3.2 t x 25mH x 7mW x 19mL	1	--		Girders by building works
17	Main pumps sealing water supply unit	Unit of water supply pump with pressure tank	40mmΦ x 0.1m ³ /min. x 35m	1	2.2	2.2	With control panel
18	Pump room floor drain pumps	Submersible pump	65mmΦ x 0.3m ³ /min. x 25m	2 (1)	3.8	3.8	Standby excluded
19	Floor drain pumps	Submersible pump	65mmΦ * 0.3m ³ /min. x 10m	2 (1)	1.5	1.5	Standby excluded
	Total motor outputs of II					197.1	kW
	Total motor outputs of (3)					618.2	kW

(4) Primary Clarifiers (4 tanks)

No.	Equipment	Type	Specifications	Qty	Output kW/uni	Total output	Remarks
1	Inlet gates	Sluice gate, manual operation, cast iron, circular	φ 1,000. Design hydraulic depth, 3m	4	—		
2	Sludge collectors	Rotating type scraper, center column supported	35m φ x 2.0mH	4	0.75	3	
4	Sludge draw-off valves	Motor operated eccentric	200mm φ	4	0.2	0.8	
5	Raw sludge pumps	Non-clog centrifugal pumps	100mm φ x 1m ³ /min. x 10	3 (1)	3.7	7.4	Standby excluded
6	Bypass gates	Manually operated, cast iron made, circular sluice gate	φ 2,000mm. Design hydraulic depth, 1.5m	1	—		
7	Raw sludge flow meter	Electro-magnetic flow meter	100mm φ	1	—		
8	Raw sludge densitometer	Ultra-sonic type		1	—		In electric works
Total motor outputs of (4)						11.2 kW	

(5) Aeration Tanks (16 tanks)

No.	Equipment	Type	Size and Specifications	Qty	Output kW/uni	Total output	Remarks
1	Inflow control weirs	Manually operated movable weirs	400W x 600H Design hydraulic depth 1.1 m	16	—		
2	Movable weirs for control of step inflow	Cast iron made, movable weirs	400mmW x 600mmH design depth, 1.1m	96	—		
3	Return sludge inflow control weirs	Cast iron made, movable (separate type)	600mmW x 600mmH design depth 1.1m	16	—		
4	Aeration diffusers	Ceramic made diffuser (fine bubble, 300 μ)	0.82m ³ /min. 8plates/holder header	390	—		SUS holder headers, & butterfly valves
5	Air control valves	Air operated butterfly valve	250mm φ	16	—		Electro-magnetic box
6	Froth spray nozzles	Cast iron made movable type	15mm φ x 8l/min. x 1kg/cm ²	864	—		1.5 m interval 40.5/1.5=27units /tan
7	Air flow meters	Orifice	250mm φ	16	—		Included in electric works
Total motor output of (5)						0 kW	

(6) Final Clarifiers (4 tanks)

No.	Equipment	Type	Size and Specifications	Qty	Output kW/unit	Total output	Remarks	
1	Inlet gates	Sluice gate, manual operation, cast iron	Circular, 1000mm Φ Design hydraulic depth 1.5m	4	—			
2	Sludge collectors	Rotating scraper, central column support	45m Φ x 3.5 m deep	4	0.75	3		
3	Sludge draw-off valves	Motor-operated eccentric valve	200mm Φ	4	0.2	0.8		
4	Return sludge pumps	Non-clog centrifugal	250mm Φ x 6.0m ³ /min. x 10m	4	22	88		
5	"	"	250mm Φ x 8.0m ³ /min. x 10m	7	30	210	5 units for additional 50 % return sludge.	
6	Excess sludge pumps	"	100mm Φ x 1.1m ³ /min. x 10m	6 (2)	3.7	14.8	Standby excluded	
7	Return sludge flow meters	Electronic-magnetic flow meter	250mm Φ	4	—		Included in electric works	
8	Excess sludge flow meters	Electronic-magnetic flow meter	100mm Φ	2	—		"	
9	Return sludge densitometers	Ultra-sonic type	250mm Φ	4	—		"	
	Total motor output of (6)						316.6 kW	

(7) Chlorine Contact Tank

No.	Equipment	Type	Size and Specifications	Qty	Output kW/unit	Total output	Remarks	
1	Influent gates	Manually operated, cast iron, square type	2000mmW x 2000mmH design hydraulic depth, 2 m	1	—			
2	Bypass gates	Manually operated, cast iron, square type	600mmW x 600mmH design hydraulic depth, 1.5m	1	—			
3	Hypochlorite supply pump No.1	Diaphragm pump	Discharge 6L/min.	2	0.2	0.4		
4	Hypochlorite supply pump No.2	Diaphragm pump	Discharge 13L/min.	3 (1)	0.4	0.8	Standby excluded	
5	Hypochlorite storage and supply tank	FRP made	20m ³ ϕ 2.8m x 3.9m H	4	—			
	Total motor output of (7)						1.2 kW	

(8) Sludge Thickeners (4 tanks)

Equipment	Type	Size and Specifications	Qty	Output kW/unit	Total output	Remarks
Sludge thickeners	Rotating scraper, with pickets	12m Φ x 4.0mH	4	0.4	1.6	
Distribution tank, movable weirs	Manually operated, cast iron weir	300mmW	4	—		
Sludge draw-off pump	Non-clog centrifugal pump	100mm Φ x 1.2m ³ /min x 20m	3 (1)	15	30	Standby excluded
Sludge draw-off valves	Air operated eccentric valve	100mm Φ	4	0.2	0.8	
Sludge screen	Drum screen, self cleaning type	2m ³ /min.	1	0.4	0.4	
Total motor outputs of (8)						32.8 kW

(9) Sludge Digestion Facilities (4 digesters)

Equipment	Type	Size and Specifications	Qty	Output kW/unit	Total output	Remarks
Sludge mixer	Draft tube type	Mixing 2,300 m ³ /hr or more	4	22	88	Draft tube 500mm Φ
Gas collectors	600mm Φ steel constructed dome, dry and wet seals		4	—		
Sludge feed pump valves	Motor operated eccentric valve.	150mm Φ	4	0.2	0.8	
Scum draw-off valves	Motor operated eccentric valve.	300mm Φ	4	0.4	1.6	
Digested sludge draw off telescope valves	Motor operated	200mm Φ	2	0.4	0.8	
Sludge circulation draw off valves	Motor operated eccentric valve.	200mm Φ	4	0.2	0.8	
Digested sludge draw off valves	Motor operated eccentric valve.	200mm Φ	4	0.4	1.6	
Thickened sludge pipe control valves	Motor operated eccentric valve.	150mm Φ	12	2.2	26.4	
Seed sludge pipe control valves	Non-clog sludge pump	100mm Φ x 1m ³ /min x 15m	2	7.5	15	
Sludge circulation pumps	Non-clog sludge pump	100mm Φ x 1.4m ³ /min x 15m	6	5.5	33	
Sludge heat exchangers	Spiral type		3 (1)	—		
Water circulation pump	Line pump	65mm Φ x 0.6m ³ /min x 25 m	4	3.7	14.8	
Water heater	Vacuum type	800,000kg/hr.	2 (1)	8.3	8.3	Standby excluded
Gas booster fans	Turbo fan	150m ³ /hr x 500mmq	2 (1)	1.5	1.5	Standby excluded
Oil service tank	Steel construction	300 L	1	—		
Oil pumps	Gear pump	15mm Φ x 10L/min. x 3kg/c	2 (1)	0.4	0.4	Standby excluded
Oil storage tank	Underground cylinder type	15,000 L	1	—		
Desulfide Gas scrubbers	Dry type	500m ³ /hr.	4	—		
Gas holders	Dry seal (membrane), steel construction	2,000m ³	2	—		
Waste gas burners	Forced air combustion type	200m ³ /hr.	2	1.5	3	Cooling fan
			1	2.2	2.2	blower
Floor drain pumps	Submersible pump	65mm Φ x 0.3m ³ /min. x 10 m	2	1.5	3	
Chain block	Geared trolley	1ton	1	—		
Total motor outputs of (9)						201.2 kW

(10) Sludge Dewatering Equipment

No.	Equipment	Type	Size and Specifications	Q'ty	Output kW/unit	Total output	Remarks
1	Sludge storage tank mixers	Vertical paddle type	2,000mm Φ	4	7.5	30	
2	Sludge feed pumps	Positive displacement pump	100mm Φ x 20m ³ /hr. x 20m	9 (1)	5.5	44	Standby excluded
3	Sludge dewatering	Belt filter press	3 m effective belt width, 390 kg per hour load in dry solid basis	8	3.7	29.6	
4	No.1 Cake conveyor	Trough belt	600mmW x 8,500mmL.	4	1.5	6	
5	No.2 Cake conveyors	Horizontal trough belt conveyor	600w * 5500L.	2	1.5	3	
6	Cake hoppers	Motor operated	10m ³	2	3.7	7.4	
7	Chemical containers	Cylinder type	700 L.	2	—		
8	Chemical feeders	Volumetric dry feeder	4l/min.	3	0.4	1.2	
9	Chemical dosage tank	Cylinder type	15m ³ capacity	3	7.5	22.5	
10	Chemical feed pumps	Positive displacement pump	50mm Φ x 3m ³ /hr x 20m	15 (1)	1.5	21	Standby excluded
11	Chemical container hoists	Motor operated	1 ton	1 1	1.5 0.4	1.5 0.4	
12	Pumps for belt filter cleaning water	Centrifugal pump	50mm Φ x 0.3 m ³ /min. x 60 m	4 (1)	7.5	22.5	Standby excluded
13	Maintenance crane	Suspension type	2 ton	2	—		
14	Chain block	Geared trolley type	2 ton	2	—		
15	Floor drain pumps	Submersible non-clog pump	65mm Φ x 0.3m ³ /min. x 10 m	3	1.5	4.5	
	Total motor outputs of (9)					193.6 kW	

(11) Aeration Tank Blower System

No.	Equipment	Type	Size and Specifications	Q'ty	Output kW/unit	Total output	Remarks
1	No.1 Blowers	Steel made, multi-stage turbo blower	ϕ 350mm/ ϕ 300mm 80m ³ /min.	5 (1)	—		
2	Electric motors for No.1 blowers	Horizontal squirrel cage, water proof	200kW	5 (1)	110	440	Standby excluded
3	No.1 blower valves	Electric-operated valve	ϕ 250mm	5 (1)	0.4	1.6	Standby excluded
4	Dry type air filters	Self cleaning type	150m ³ /min.	4	0.2	0.8	
5	Wet type air filters	Auto rolling type	150m ³ /min.	4	0.2	0.8	
6	Maintenance crane	Geared trolley type	3 tons	1	—		
	Total motor outputs of (11)					443.2 kW	
Grand Total of Motor Outputs						2,050 kW	




Figure AII.3.1

Primary Sedimentation Tank of Bralla WWTP




Figure AII.3.3

Final Sedimentation Tank of Braila




Figure All.3.6

Grit Chamber and Oil Separator of Braila WWTP




Figure AII.3.7

Chlorination Chamber of Braila WWTP




Figure AII.3.8

Screening & Pumping Station of Braila WWTP


APPENDIX-4 DESIGN CALCULATIONS OF BRAILA WWTP

1. CONVENTIONAL ACTIVATED SLUDGE PROCESS

1.1 DESIGN BASIS

1.1.1 SCHEMATIC OF THE CONVENTIONAL ACTIVATED SLUDGE PROCESS

Schematic of the conventional activated sludge process is shown as follows.



1.1.2 DESIGN WASTEWATER INFLOW RATES

Design wastewater inflow rates are determined as follows.

Average daily flow	Q _{ad}	98,000 m ³ /day	1,134 L/s
Maximum daily flow	Q _{md}	115,000 m ³ /day	1,331 L/s
Maximum hourly flow	Q _{mh}	140,000 m ³ /day	1,620 L/s
Wet weather flow	Q _{ww}	280,000 m ³ /day	3,241 L/day

1.1.3 DESIGN WASTEWATER QUALITY

Design wastewater quality is determined as follows.

BOD	=	150 mg/L
SS	=	180 mg/L

1.1.4 DESIGN WASTEWATER QUALITY (INCLUDING SIDESTREAM WASTE LOADS)

Design wastewater quality (including sidestream waste loads) is calculated as follows.

BOD	=	195 mg/L
SS	=	215 mg/L

Parameter	Removal Efficiency (%)			Wastewater Quality (mg/L)		
	Primary treatment	Secondary treatment	Overall removal rate	Raw waste-water	Primary effluent	Secondary effluent
BOD	30	85	89.5	195	137	20
SS	40	80	88.0	215	129	26

1.1.5 POLLUTANT DISCHARGE LIMITS BY NTPA 001

Pollutant discharge limits by NTPA 001 is regulated as follows.

BOD	<	20 mg/L
SS	<	60 mg/L
T-N	<	10 mg/L
T-P	<	1.0 mg/L

1.2 CALCULATIONS OF SIDESTREAM POLLUTANT LOADS

1.2.1 RAW SLUDGE VOLUME

Raw sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Solid production (t/day)} &= 115,000 \times 180 \times 10^{-6} \times 0.4 = 8.28 \text{ t/day} \\ \text{Sludge concentration} & 2.0 \% \\ \text{Sludge volume} & 8.28 \times 100 \div 2.0 = 414 \text{ m}^3/\text{day} \end{aligned}$$

1.2.2 WASTE SLUDGE VOLUME

Parameter	Influent quality (mg/L)	Reaction tank influent quality (mg/L)	Primary clarifiers removal Efficiency(%)
BOD	150	105	30
SS	180	108	40

Assuming that the reactor influent S-BOD is 66.7% of the total BOD; then S_{sc} is 70.0 mg/L. Waste sludge production volume is calculated by the following equation:

$$Q_w \times X_w = (a \times S_{cs} + b \times S_{ss} - c \times \theta \times XA) Q$$

where,

Q_w	Volume of waste sludge (m ³ /day)	
X_w	Average SS concentration of waste sludge (mg/L)	
Q	Influent volume to reactors (m ³ /day)	115,000
XA	MLSS concentration in reactors (mg/L)	1,660
S_{cs}	Influent soluble-BOD concentration to reactors (mg/L)	70.0
S_{ss}	Influent SS concentration to reactors (mg/L)	108
a	Sludge yield coefficient of S-BOD (mg MLSS/mgSS)	0.4-0.6
b	Sludge yield coefficient of SS (mg MLSS/mgSS)	0.9-1.00
c	Coefficient of SS reduction due to endogenous respiration of activated sludge micro-organisms (L/day)	0.03-0.05
θ	HRT in reactor basins (day)	6.5/24 = 0.27

therefore,

$$Q_w \times X_w = (0.5 \times 70.0 + 0.95 \times 108 - 0.04 \times 0.27 \times 1660) \times Q \times 10^{-6}$$

$$= 119.63 \times Q \times 10^{-6} = 13.76 \text{ t/day}$$

$$\text{Solid production} = 13.76 \text{ t/day}$$

$$\text{Sludge concentration} = 0.5 \%$$

$$\text{Sludge production} = 13.76 \times 100 \div 0.5 = 2,752 \text{ m}^3/\text{day}$$

1.2.3 THICKENED SLUDGE

Thickened sludge production volume is calculated by the following equation.

$$\text{Sludge solids} = 8.28 + 13.76 = 22.04 \text{ t/day}$$

Primary sludge Excess sludge

$$\text{Sludge volume} = 414 + 2,752 = 3,166 \text{ m}^3/\text{day}$$

(2.0%) (0.5%)

$$\text{Solids} = 22.04 \times 0.85 = 18.73 \text{ t/day}$$

Assuming sludge concentration is 3.5 %

$$\text{Sludge volume} = 18.73 \times 100 \div 3.5 = 535 \text{ m}^3/\text{day}$$

1.2.4 SLUDGE SUPERNATANT OF THICKENERS

Sludge supernatant of thickeners is calculated by the following equation.

$$\text{Liquor volume} = 3,166 - 535 = 2,630 \text{ m}^3/\text{day}$$

$$\text{Solids weight} = 22.04 \times 0.15 = 3.31 \text{ t/day}$$

$$\text{BOD} = 2,630 \times 2000 \times 10^{-6} = 5.26 \text{ t/day}$$

BOD is assumed to be of 2,000 mg/L

1.2.5 DIGESTED SLUDGE

Digested sludge production volume is calculated by the following equation.

$$\text{Digested sludge solids} = 18.73 \times (1 - 0.7 \times 0.5) = 12.18 \text{ t/day}$$

$$\text{Digested sludge volume} = 3.0 \%$$

$$= 12.18 \times 100 / 3.0 = 406 \text{ m}^3/\text{day}$$

1.2.6 DEWATERED SLUDGE(SLUDGE CAKE)

Dewatered sludge production volume is calculated by the following equation.

$$\text{Solids} = 12.18 \times 100 / 0.9 = 10.96 \text{ t/day}$$

(Assuming 20.0 % solids concentration)

$$\text{Cake volume} = 10.96 \times 100 / 20.0 = 55 \text{ m}^3/\text{day}$$

1.2.7 DIGESTED SLUDGE FILTRATE

Digested sludge filtrate weight is calculated by the following equation.

$$\text{Filtrate volume} = 535 - 55 = 480 \text{ m}^3/\text{day}$$

$$\text{Dry solids weight} = 12.18 \times 0.10 = 1.22 \text{ t/day}$$

$$\text{BOD} = 480 \times 1,500 \times 10^{-6} = 0.72 \text{ t/day}$$

(Assumed BOD concentration = 1,500 mg/L)

1.2.8 SIDESTREAM VOLUME AND WASTE LOAD

Sidestream volume and waste load is calculated by the following equation.

	Thickener supernatants		Sludge filtrate	
Liquor volume	= 2,630	+	480	= 3,111 m ³ /day
Dry solids	= 3.31	+	1.22	= 4.52 t/day
BOD	= 5.26	+	0.72	= 5.98 t/day

1.2.9 WASTEWATER QUALITY (INCLUDING ALL SIDESTREAMS)

Wastewater quality (including all sidestreams) is calculated by the following equation.

Overall wastewater flow	=	Influent	+	Sidestreams	
Maximum daily flow	=	115,000	+	3,111	= 118,111 m ³ /day
Then, the design wastewater flow characteristics are;					
BOD	=	(115,000 × 150 × 10 ⁻⁶ + 5.98) / 118,111			
	=	0.0001967 × 10 ⁶	=	197	→ 195 mg/L
SS	=	(115,000 × 180 × 10 ⁻⁶ + 4.52) / 118,111			
	=	0.0002136 × 10 ⁶	=	214	→ 215 mg/L

1.3 SLUDGE PRODUCTIONS

1.3.1 RAW SLUDGE

Raw sludge production volume is calculated by the following equation.

Solid production (t/day)	=	115,000 × 215 × 10 ⁻⁶ × 0.4
	=	9.89 t/day
Sludge concentration		2.0 %
Sludge volume		9.89 × 100 ÷ 2.0 = 495 m ³ /day

1.3.2 EXCESS SLUDGE VOLUME

Parameter	Influent quality (mg/L)	Reaction tank influent quality (mg/L)	Primary clarifiers removal Efficiency(%)
BOD	195	136.5	30
SS	215	129	40

Assuming that influent S-BOD to reactor basins is 66.7% of the raw wastewater BOD, S-BOD concentration is estimated to be; 91.0 mg/L

Waste sludge production volume is calculated by the following equation.

$Q_w \times X_w = (a \times S_{cs} + b \times S_{ss} - c \times \theta \times X_A) Q$	
where,	
Q_w	Volume of excess sludge (m ³ /day)
X_w	Average SS concentration of waste sludge (mg/L)
Q	Influent volume to reactors (m ³ /day) 115,000
X_A	MLSS concentration in reactors (mg/L) 1,667
S_{cs}	Influent soluble-BOD concentration to reactors (mg/L) 91.0
S_{ss}	Influent SS concentration to reactors (mg/L) 129

a	Sludge yield coefficient of S-BOD (mg MLSS/mgSS)	0.4-0.6	0.5
b	Sludge yield coefficient of SS (mg MLSS/mgSS)	0.9-1.00	0.95
c	Coefficient of SS reduction due to indigenous respiration of activated sludge micro-organisms (L/day)	0.03-0.05	0.04
θ	HRT in reactor basins (day)	6.6/24	= 0.27

therefore,

$$Q_w \times X_w = (0.5 \times 91.0 + 0.95 \times 129 - 0.04 \times 0.27 \times 1667) \times Q \times 10^{-6}$$

$$= 149.87 \times Q \times 10^{-6} = 17.24 \text{ t/day}$$

$$\text{Solid production} = 17.24 \text{ t/day}$$

$$\text{Sludge concentration} = 0.5 \%$$

$$\text{Sludge production} = 17.24 \times 100 \div 0.5 = 3,447 \text{ m}^3/\text{day}$$

$$= 2.4 \text{ m}^3/\text{min.}$$

1.3.3 RETURN SLUDGE

Return sludge volume is calculated by the following equation.

$$\text{Sludge return ratio} = 50 \%$$

$$\text{Return sludge volume} = 115,000 \times 0.5 = 57,500 \text{ m}^3/\text{day} = 39.9 \text{ m}^3/\text{min.}$$

1.3.4 GRAVITY SLUDGE THICKENERS

Gravity thickened sludge production volume is calculated by the following equation.

$$\text{Solids inflow} = 9.89 + 17.24 = 27.13 \text{ t/day}$$

$$\text{Sludge inflow} = 495 + 3,447 = 3,942 \text{ m}^3/\text{day}$$

$$\text{Thickened sludge solids} = 27.13 \times 0.8 = 21.70 \text{ t/day}$$

$$\text{Assume solids content to be } 3.5 \%$$

$$\text{Thickened sludge volume} = 21.70 \times 100 / 3.5 = 620 \text{ m}^3/\text{day}$$

1.3.5 ANAEROBIC SLUDGE DIGESTERS

Anaerobic digested sludge production volume is calculated by the following equation.

$$\text{Input solids} = 21.70 \text{ t/day}$$

$$\text{Input sludge volume} = 620 \text{ m}^3/\text{day}$$

$$\text{Volatile solids content of sludge} = 70 \%$$

$$\text{Solids destruction rate} = 50 \%$$

$$\text{Digested sludge solids} = 21.70 \times (1 - 0.7 \times 0.5) = 14.11 \text{ t/day}$$

$$\text{Assume solids concentration is } 3.0 \%$$

$$\text{Digested sludge volume} = 14.11 \times 100 / 3.0 = 470 \text{ m}^3/\text{day}$$

1.3.6 SLUDGE DEWATERING

Dewatered sludge production volume is calculated by the following equation.

$$\text{Input solids} = 14.11 \text{ t/day}$$

$$\text{Recovered solids (90\%)} = 14.11 \times 0.9 = 12.69 \text{ t/day}$$

$$\text{Assuming solids concentration as } 20.0 \%$$

$$\text{Sludge cake volume} = 12.69 \times 100 / 20.0 = 63 \text{ m}^3/\text{day}$$

1.4 COMPONENT FACILITIES

1.4.1 PRIMARY CLARIFIERS

Primary clarifiers specifications are calculated by the following equation.

Average daily flow, Q _{ad}	=	98,000 m ³ /day
Maximum daily flow, Q _{md}	=	115,000 m ³ /day
Maximum hourly flow, Q _{mh}	=	140,000 m ³ /day
Wet weather flow	=	280,000 m ³ /day
Hydraulic surface load rate	=	35 m ³ /m ² ·day
Totally 2 clusters, each consisting of 2 tanks, total number of basins is		4 units
Hydraulic load on each basin is	$115,000 \div 4 =$	28,750 m ³ /day/basin
Required surface area of each basin	$= 28,750 \div 35 =$	821 m ²

(1) Tank Geometry (In accordance with the Romanian Standards),

Internal diameter		35 m
Effective depth		2.0 m
Number of basins		4 basins
Surface area of a basin	$843 \times 4 =$	3,372 m ²
Hydraulic capacity of a basin	$3,372 \times 2 =$	6,744 m ³
Check for hydraulic conditions of basins under the different flow rates.		
Retention time		
Q _{md}	$6,744 \times 24 / 115,000 =$	1.41 hours
2Q _{mh}	$6,744 \times 24 / 280,000 =$	0.58 hours > 0.5
Surface load rate		
Q _{md}	$115,000 / 3,372 =$	34.1 m ³ /m ² ·day < 35
2Q _{mh}	$280,000 / 3,372 =$	83.0 m ³ /m ² ·day < 96

(2) Raw Sludge Pumping Equipment

The pumps will handle the mixture of primary and excess sludge having solids concentration of 2%.

Sludge solids	27.13 t/day,	Solids concentration	2 %
Sludge volume	$1,356 \text{ m}^3/\text{day} =$		0.94 m ³ /min.
Pump type:	Centrifugal screw pump		
Pump bore size:	100 mm		
Delivering capacity:	1 m ³ /min.		
Total dynamic head:	10 m		
Number of pumps:	3 Units (including 1 standby)		

1.4.2 REACTOR TANKS

Reactor tanks specifications are calculated by the following equation.

Design flow, Q _{md}	=	115,000 m ³ /day
BOD-SS load		0.30 kgBOD/kg SS day
MLSS		1,667 mg/L
Return sludge solids concentration		5,000 mg/L
Sludge return ratio	$= 1,667 \div (5,000 - 1,667) =$	0.50
Inflow BOD to reactors	$115,000 \times 195 \times 10^{-3} \text{ kg BOD/day} \times (1 - 0.3)$	
	$=$	15,698 kg BOD/day
Reactor tanks SS	$= V \times 1,667 \times 10^{-3} \text{ kg MLSS}$	
Required tank capacity	$= 15,698 \div 1,667 \div 0.30 =$	31,389 m ³

$$\begin{aligned} \text{Aeration time} &= 31,389 \times 24 \div 115,000 = 6.6 \text{ hours} \\ \text{At Qmd, aeration time of } &6 \text{ hours or more is secured.} \\ \text{Required tank capacity} &= 6 \times 115,000 \div 24.00 = 28,750 \text{ m}^3 \\ \text{Tank geometry} & \\ \text{Width} &= 5.5 \text{ m} \\ \text{Effective depth} &= 5.5 \text{ m} \\ \text{Cross sectional area} &= 5.5 \times 5.5 - 1/2 \times 1.0^2 \times 2 - 1/2 \times 0.6^2 \times 2 \\ &= 29 \text{ m}^2 \\ \text{Number of tanks} &= 8 \text{ tanks } \quad 2 \text{ clusters } \quad 16 \text{ tanks} \\ \text{Capacity of one tank} &= 31,389 \div 16 = 1,962 \text{ m}^3 \\ \text{Tank length} &= 1,962 \div 29 = 67.65 \text{ use } 68 \text{ m} \end{aligned}$$

Tank geometry		
W	5.5 m	× 16 Tanks
L	68 m	
H	5.5 m	

$$\begin{aligned} \text{Check of aeration time} & \\ \text{Tank capacity} &= 29 \times 68 \times 16 = 31,552 \text{ m}^3 \\ \text{Aeration time} &= 31,552 \times 24 / 235,000 = 6.6 \text{ hours} \end{aligned}$$

Check for additional tank requirement to upgrade the process

Additional tank capacity required for the advanced treatment process will be provided by adding tanks to the conventional activated sludge aeration tanks. The wastewater inflow will be distributed both to the existing and additional tanks. The wastewater will be distributed in proportion to the treatment capacity of both trains.

The total retention time will be 15.4 hours.

As the retention time in the conventional treatment process is 6.6 hours, the required retention time for additional tanks is $15.4 - 6.6 = 8.80$ hours

$$\begin{aligned} \text{Check capacity and wastewater distribution ratio} & \\ \text{Existing tanks} & \quad 6.6 / 15.4 = 0.43 \\ \text{Additional tanks} & \quad 8.8 / 15.4 = 0.57 \\ \text{Wastewater flow distribution rates} & \\ \text{Existing tanks} & \quad 115,000 \times 0.43 = 49,172 \text{ m}^3/\text{day} \\ \text{Additional tanks} & \quad 115,000 \times 0.57 = 65,828 \text{ m}^3/\text{day} \end{aligned}$$

Additional Reactor Tanks

$$\begin{aligned} \text{Required tank capacity} &= 115,000 \times 8.8 \div 24 = 42,240 \text{ m}^3 \\ \text{Number of tanks} &= 8 \text{ tanks } \quad 2 \text{ clusters } \quad 16 \text{ tanks} \\ \text{Tank capacity} &= 42,240 \div 16 = 2,640 \text{ m}^3 \\ \text{Tank length} &= 2,640 \div 29.00 = 91.0 \text{ use } 91 \text{ m} \end{aligned}$$

Tank geometry		
W	5.5 m	× 16 Tanks
L	91 m	
H	5.5 m	

$$\begin{aligned} \text{Check retention time} & \\ \text{Tank capacity} &= 29 \times 91 \times 16 = 42,224 \text{ m}^3 \\ \text{Retention time} &= 42,224 \times 24 / 115,000 = 8.8 \text{ hours} \end{aligned}$$

1.4.3 FINAL CLARIFIERS

Final clarifiers specifications are calculated by the following equation.

$$\begin{aligned} \text{Design flow QD} &= 115,000 \text{ m}^3/\text{day} \\ \text{Surface load rate} &= 25 \text{ m}^3/\text{m}^2\cdot\text{day} \\ \text{2 clusters each consisting of 2 tanks, total tank number is} &: 4 \text{ tanks} \\ \text{Influent to each tank} &= 115,000 \div 4 = 28,750 \text{ m}^3/\text{day}/\text{tank} \\ \text{Required surface area of each tank} &= 28,750 \div 25 = 1,150 \text{ m}^2 \end{aligned}$$

(1) Check by the Romanian Standards

$$\begin{aligned} \text{Internal diameter} & 45 \text{ m} \\ \text{Effective depth} & 3.5 \text{ m} \\ \text{Tank numbers} & 4 \text{ units} \\ \text{Surface area} & 1,424 \times 4 = 5,696 \text{ m}^2 \\ \text{Capacity} & 5,696 \times 3.5 = 19,936 \text{ m}^3 \\ \text{Surface load rate} & 20 \text{ m}^3/\text{m}^2\cdot\text{day} \\ \text{Retention time} & \\ \text{At Qmd} & 19,936 \times 24 / 115,000 = 4.16 \text{ hours} \\ \text{Qv=Qmh + Qmax} & = 140,000 + 57,500 = 197,500 \text{ m}^3/\text{day} \\ & 19,936 \times 24 / 197,500 = 2.42 > 2.0 \\ \text{Surface load rate} & \\ \text{At Qmd} & 115,000 / 5,696 = 20 \text{ m}^3/\text{m}^2\cdot\text{day} < 25 \\ \text{At Qv} & 197,500 / 5,696 = 34.7 \text{ m}^3/\text{m}^2\cdot\text{day} < 52.8 \\ \text{Weir loading} & \\ \text{Weir length} & L = \pi \times 42.7 \times 4 = 536 \text{ m} \\ \text{At Qmd} & 115,000 / 536 = 214 \text{ m}^3/\text{m}\cdot\text{day} \\ \text{At Qv} & 197,500 / 536 = 368 \text{ m}^3/\text{m}\cdot\text{day} \end{aligned}$$

As compared with the Japanese Standards, the weir loading appears to be high side. The weir length may be increased in detailed design.

(2) Check for Advanced Treatment

The advanced treatment will be performed through two trains, existing and advanced treatment process trains.

The wastewater will be distributed to each train in proportion to the reactor tanks hydraulic retention time.

$$\begin{aligned} \text{Wastewater distribution} & \\ \text{Existing train} & 49,172 \text{ m}^3/\text{day} \\ \text{Additional train} & 65,828 \text{ m}^3/\text{day} \end{aligned}$$

Check for additional tanks

$$\begin{aligned} \text{Surface load rate} & 15 \text{ m}^3/\text{m}^2\cdot\text{day} \text{ or lower} \\ \text{Cluster} & 2 \text{ with 2 tanks, then total tank number is 4 units} \\ \text{Flow rate to each tank} & 65,828 \div 4 = 16,457 \text{ m}^3/\text{day}/\text{tank} \\ \text{Required surface area of each tank} & = 16,457 \div 15 = 1,097 \text{ m}^2 \\ & D = 45 - 2.3 = 42.7 \text{ m} \end{aligned}$$

$$\begin{aligned} \text{According to Romanian Standards} & A = 0.785 \times (D^2 - 3^2) = 1,424 \text{ m}^2 \\ \text{Diameter} & 45 \text{ m} \\ \text{Effective depth} & 3.5 \text{ m} \\ \text{Number of tanks} & 4 \text{ units} \\ \text{Water surface area} & 1,424 \times 4 = 5,696 \text{ m}^2 \\ \text{Capacity} & 5,696 \times 3.5 = 19,936 \text{ m}^3 \\ \text{Overflow rate} & 11.6 \text{ m}^3/\text{m}^2\cdot\text{day} \end{aligned}$$

Check the existing tank overflow rate

$$65,828 / 5,696 = 11.6 \text{ m}^3/\text{m}^2/\text{day} < 15$$

(3) Return Sludge Pumps

Return sludge pumps are specified as follows.

Average 50 % sludge return rate is considered, but pump capacity 100 % return rate is provided to prevent and restore sludge bulking.

$$\text{Return sludge volume} = 57,500 \text{ m}^3/\text{day} = 40 \text{ m}^3/\text{min.}$$

60 % and 40 % of sludge will be transported by 4 and 2 pumps respectively, through double pipelines.

Pump capacity	20	×	0.2	=	3.99	use	4.0 m ³ /minute/unit
"	20	×	0.15	=	2.99	use	3.0 m ³ /minute/unit

By operating above pumps, the return sludge rates can be adjusted at the order of 5% to 15 %.

Pump type	No.1 Screw centrifugal	No.2 Screw centrifugal
Diameter	200 mm	200 mm
Capacity	3.0 m ³ /min.	4.0 m ³ /min.
TDH	10 m	10 m
Number of pumps	8 units	4 units
Motor output	11 kW	11 kW

(4) Excess Sludge Pumps

Excess sludge pumps are specified as follows.

$$\text{Excess sludge volume} = 3,447 \text{ m}^3/\text{day} = 2.4 \text{ m}^3/\text{min}$$

$$\text{Two lines will be provided, then the capacity of a pump} = 0.60 \text{ m}^3/\text{min}$$

Type of pump	No.1 Screw centrifugal pump
Diameter	100 mm
Capacity	1.0 m ³ /min
TDH	10 m
Number of pumps	6 units (2-standby)
Motor output	3.7 kW

(5) Chlorine Contact Tanks

Chlorine contact tanks specifications are calculated by the following equation.

Design flow rate	=	115,000 m ³ /day
Chlorine contact time	=	15 minutes
Required tank capacity:	$115,000 \div 1,440 \times 15 =$	1,198 m ³
Channel width:		4.0 m
Effective depth:		3.0 m
Tank length:	$1,198 \div 4.0 \div 3.0 =$	99.8 m → 100 m
Number of tanks		1 unit

Chlorine contact tank geometry

W	4 m	×	H	4.0 m	×	1 Tank
L	100 m					

1.5 ANAEROBIC SLUDGE DIGESTERS

1.5.1 SLUDGE THICKENERS

(1) Hydraulic Capacity of Tanks

Hydraulic capacity of tanks are specified as follows.

Solids input	=	27.13 t/day
Input sludge volume	=	3,942 m ³ /day
Output sludge volume	=	620 m ³ /day
Floor loading	=	60 kg/m ² /day
Required surface area	=	452 m ²
Tank geometry	Circular radial flow type	
Internal diameter	=	12 m
Effective depth	=	4 m
Number of tanks	=	4 units
Water surface area	$3.14 / 4 \times 12^2 \times 4 = 452 \text{ m}^2$	

(2) Sludge Withdrawal Pumps

Sludge withdrawal pumps are specified as follows.

The pumps will have capacities that can send thickened sludge in around 8 hours.

$$\text{Pump capacity } Q = 620 \times 1/8 \times 1/60 = 1.29 \text{ m}^3/\text{min.}$$

Pump	Sludge pump
Diameter	100 mm
Discharge capacity	1.20 m ³ /min.
TDH	20 m
Motor output	15 kW
Number of pumps	3 units(including one standby)

(3) Sludge Screens

Sludge screens are specified as follows.

Type	Rotary drum screen
Screen opening	4 mm
Capacity	2 m ³ /min.
Motor output	0.4 kW
Number of screens	1 unit

Screen capacity is so determined that the sludge quantity being sent concomitantly from 2 raw sludge pumps (each q = 1.0 m³/min.) can be screened.

1.5.2 ANAEROBIC SLUDGE DIGESTION TANKS

(1) Hydraulic Capacity of Tanks

Hydraulic capacity of tanks are specified as follows.

Sludge solids input	=	21.70 t/day
Input sludge	=	620 m ³ /day
Detention time	20 days	
Tank temperature	35 °c	
Required tank capacity	$620 \times 20 = 12,400 \text{ m}^3$	

(2) Tank Geometry

Tank geometry is specified as follows.

Type	Single stage digestion
Internal diameter	15 m
Effective tank depth	26 m
Number of tanks	2 clusters × 2 tanks
Capacity	3,503 m ³ /tank , 14,013 m ³ total tank capacity

1.5.3 GAS STORAGE TANKS

(1) Capacity of Tanks

Capacity of tanks are calculated by the following equation.

Total solids input to digesters = 21.70 t/day
 Assuming that 70 % of the input sludge solids are volatile, and 1 kg of which produce 0.425 m³ gas, the total gas production can be estimated as follows:
 Total gas production = 21.70 × 0.7 × 10³ × 0.425 = 6,456 m³/day
 Storage time = 8 hours
 Tank storage capacity = 6,456 × 8 / 24 = 2,152 m³/day

(2) Tank Geometry

Tank geometry is specified as follows.

Type	Dry-seal type steel tanks
Number of tanks	2 units
Diameter	12.6 m
Effective height	13.3 m
Storage capacity	1,000 m ³

1.5.4 MECHANICAL SLUDGE DEWATERING

(1) Filter Capacity

Filter capacity is calculated by the following equation.

Solids input = 14.11 t/day , Input sludge volume 470 m³/day
 Belt press filter
 Yields per unit length 130 kg/m/hr
 Filter width 3 m
 Daily operation time 6 hr
 Working days/week 5 day
 Solids loads per hour = 14.11 × 7 / 5 × 10³ / 6 = 3,291 kg/hr
 Required number of belt press = 3,291 / 130 / 3 = 8 use → 8 units

Type	: Belt filter press
Filter loading rate	: 130 kg/m/hr
Filter width	: 3 m
Number of filters	: 8 unit

1.6 CHLORINE REQUIREMENTS

Required quantity of hypochlorite solution can be calculated by multiplying the dosing rate by the wastewater flow rate as shown in the following equation:

$$VR = Q \times R \times (100 / C) \times (1 / d) \times 10^{-3}$$

where

VR	Required hypochlorite solution (L / hr.)
Q	Wastewater flow rate (m ³ / hr)
R	Chlorine dosing rate(mg / L)
C	Effective chlorine concentration in chemical (%)
d	Specific gravity of hypochlorite solution (at the effective concentration of C %)

At the maximum daily flow rate, the required hypochlorite solution is:

$$\begin{aligned} Q &= 115,000 \text{ m}^3/\text{day} = 4,792 \text{ m}^3/\text{hr} \\ R &= 3 \text{ mg/L} \\ C &= 10 \% \\ d &= 1.2 \\ VR &= Q \times 3 \times (100 / 10) \times (1 / 1.2) \times 10^{-3} \\ &= 0.036 \times Q = 173 \text{ L/hr} = 3 \text{ L/minute} \end{aligned}$$

At the wet weather flow (maximum hydraulic rate)

$$\begin{aligned} Q_{ww} &= 280,000 \text{ m}^3/\text{day} = 11,667 \text{ m}^3/\text{hr} \\ R &= 8 \text{ mg/L} \\ VR &= 0.012 \times 8 \times Q_{ww} = 1,120 \text{ L/hr} = 19 \text{ L/minute} \end{aligned}$$

(1) Hypochlorite Solution Storage Tanks

Hypochlorite solution storage tanks are specified as follows.

8 days storage capacity for the maximum daily flow rate. Then, the capacity is:

$$V = 0.1725 \text{ m}^3/\text{h} \times 24 \times 8 = 33.1 \text{ m}^3$$

Tank specifications

Type	FRP made cylinder type
Internal diameter	2.8 m
Height	3.9 m
Capacity	20 m ³
Number of tanks	4 units

(2) Dosing Pumps Specification

	(No.1)	(No.2)
Type	Diaphragm	Diaphragm
Diameter	20 mm	20 mm
Discharge	6 L/min.	13 L/min.
Motor output	0.2 kw	0.4 kw
No. of unit	2 units	3 units(including 1 standby)

1.7 DIGESTER HEATING SYSTEM

1.7.1 TEMPERATURE

Lowest daily average temperature	0 °c
Soil temperature	15 °c

Input sludge temperature	10 °c
Digester tank temperature	35 °c

1.7.2 REQUIRED CALORIES FOR SLUDGE HEATING SPECIFIC HEAT 1.0 Kcal/kg.°C

Required calories for sludge heating specific is calculated by the following equation.

$$Q = 620 \times (35 - 10) \times 103 \times 1.0 = 15,500,209 \text{ Kcal/d}$$

1.7.3 HEAT LOSSES TANK INTERNAL DIAMETER 15 M

(1) Surface Area of the Digestion Tank

		Internal diameter 15 m		
		r	R	h
Top slab (gas portion)	A1	1.00	3.00	2.0
		38.67 m ²		
Top slab(liquid portion)	A2	3.00	7.50	4.50
		496.9 m ²		
Side wall(above ground)	A3	7.50	7.50	10.55
(down to 1m below ground)		717.1 m ²		
Side wall(underground)	A4	7.50	7.50	4.45
(up to 1m from surface)		209.6 m ²		
Bottom slab	A5	1.00	7.50	6.50
		248.5 m ²		

$$A1 = 35.5(\text{side}) + 3.14(\text{top, r}) = 38.67$$

$$A2 = 209.8, A3 = 496.9, A4 = 209.6, A5 = 245.3 + 3.14 = 248.5$$

(2) Overall Thermal Conductivity Coefficient (kcal/m², °C/hr)

	RC thickness (m)	Water proof motor	Insulation (polyurethane foam)	Concrete block	Spray concrete	Gas portion	Internal α 1 (thermal conductivity)	External α 2 (thermal conductivity)	K
	(λ=1.4)	(λ=1.2)	(λ=0.22)	(λ=1.0)	(λ=1.4)	(λ=0.48)			
Roof slab(gas portion)	0.3	0.03	0.04				20	20	0.464k1
Roof slab(liquid portion)	0.3	0.03	0.04				300	20	0.474k2
Upper side walls (1m underground or higher)	0.3		0.04	0.15		0.26	300	20	0.360k3
Lower sidewalls (1m underground or lower)	0.3						300	5	2.395k4
Bottom slab	0.8				0.1		300	5	1.182k5

The overall thermal conductivity coefficient can be calculated by the following equation:

$$1/K = 1/\alpha^1 \times \delta^1/\lambda^1 + \delta^2/\lambda^2 + 1/\alpha^2$$

where

K Overall thermal conductivity coefficient (Kcal/m².°c.hr)

- α_1 Thermal conductivity coefficient of gas or sludge (Kcal/m²·°c·hr.)
1 / k1 = 2.16 k1 = 0.464
- α_2 Thermal conductivity coefficient of air or ground (Kcal/m²·°c·hr.)
1 / k2 = 2.11 k2 = 0.474
- λ_2, λ_2 Thermal conductivity coefficient of insulation material (Kcal/m²·°c·hr.)
1 / k3 = 2.78 k3 = 0.360
- δ_1, δ_2 Thickness of insulators (m) 1 / k4 = 0.42 k4 = 2.395
1 / k5 = 0.85 k5 = 1.182

(3) Overall Heat Losses

Portion of tank	Heat transfer area	Thermal conductivity coefficient	Number of tanks	Difference of temperature	Total heat losses
	(m ²)	(Kcal/m ² °c/hr)	(unit)	(°c)	
Roof slab(gas portion)	38.67	0.464	4	35	2,509
Roof slab(liquid portion)	209.8	0.474	4	35	13,916
Upper sidewalls(1m under ground above)	496.9	0.360	4	35	25,047
Lower sidewalls (up to 1m below ground surface)	209.6	2,395	4	35	70,263
Bottom slab	248.5	1.182	4	35	41,111
				Total	152,847

Overall heat losses = 152,847 Kcal / hr

1.7.4 HEATING SYSTEM

24 hours continuous heating. A total of 20 % heat losses from pipes are considered.

$15,500,209 / 24 + 152,847 \times 1.2 = 829,258 \text{ Kcal / hour}$

Efficiency of water heater 0.9

$829,258 / 0.9 = 921,398 \text{ Kcal / hour}$

Water heater

$450,000 \text{ Kcal / hr} \times 3 \text{ units (including 1 standby)}$

1.8 ANAEROBIC SLUDGE DIGESTION SYSTEM

1.8.1 DIGESTION TANK

Hydraulic capacity of tanks are specified as follows.

Solids input = 620 m³/day

Detention time 20 days

Temperature 35 °c

Required tank capacity $620 \times 20 = 12,400 \text{ m}^3$

1.8.2 TANK GEOMETRY


Tank geometry is specified as follows.

Type	single stage tank	
Internal diameter	15 m	
Effective tank depth	26 m	
Number of tanks	2 clusters	4 tanks
	3,503 m ³ /tank	D1 = 15 m
	(3,100 m ³ / tank or larger)	D2 = 2 m
		D3 = 6 m

1.8.3 TANK CAPACITY

Tank capacity is calculated by the following equation.

Effective depth	15.0 m	Portion V1
"	6.5 m	Portion V2
"	4.5 m	Portion V3
Total	26m	
V1	= $\pi / 4 \times D1^2 \times D1$	
	= $\pi / 4 \times D1^3 = 2,649 \text{ m}^3$	
V2	= $\pi / 4 \times D1^2 \times (D1/2) / 3$	
	= $\pi / 4 \times D2^2 \times (D2/2) / 3$	
	= $\pi / 4 / 6 (D1^3 - D2^3)$	
	= 441 m ³	
V3	= $\pi / 4 / 6 (D1^3 - D2^3)$	
	= 413 m ³	
V total	3,503 m ³	



1.9 REQUIRED OXYGEN

Required oxygen is calculated by the following equation.

$$\text{Required } O_2 : OD = OD_1 + OD_2 + OD_3$$

where

- OD₁ : Oxygen required for BOD oxygenation (cell synthesis)
- OD₂ : Oxygen required for endogenous respiration
- OD₃ : Oxygen to be utilized for maintaining required dissolved oxygen level

1.9.1 REQUIRED OXYGEN FOR BOD OXIDATION(CELL SYNTHESIS) : OD1(KGO₂/DAY)

$$OD1 = A(\text{kgO}_2/\text{kgBOD}) \times \text{BOD removed (kg BOD/day)}$$

where

- A : kg oxygen required to remove kg BOD (kgO₂/kgBOD), 0.5~0.7 → 0.6
- Q = 115,000 m³/day
- OD₁ = 0.6 × Q × 116.0 × 10⁻³ = 0.0696 Q kgO₂/day
- Influent BOD = 137 - 20 = 116.0 mg/L

1.9.2 OXYGEN REQUIRED FOR ENDOGENOUS RESPIRATION OD₂(KGO₂/DAY)

$$OD_2 = B(\text{kgO}_2/\text{kgMLVSS}\cdot\text{day}) \times VA(\text{m}^3) \times \text{MLVSS}(\text{kgMLVSS}/\text{m}^3)$$

where

- B : Oxygen consumption due to endogenous respiration per unit MLVSS
0.05~0.15 (kgO₂/kgMLVSS·day) 0.05
- VA : Capacity of aerobic portion of reactor(m³) Q × 6.6 ÷ 24 = 0.27 Q

$$MLVSS/MLSS = 0.8$$

$$OD_2 = 0.05 \times 0.27 \times Q \times 1,500 \times 10^{-3} \times 0.8$$

$$= 0.0165 Q \text{ kgO}_2 / \text{day}$$

1.9.3 REQUIRED OXYGEN TO MAINTAIN DISSOLVED OXYGEN LEVEL: OD_3 (KGO₂/DAY)

$$OD_3 = COA \times Q \times 10^{-3}$$

where COA : Aeration tank dissolved oxygen 1.5 mg/l concentration
Return sludge ratio R 0.5

$$OD_3 = 1.5 \times Q(1 + 0.5) \times 10^{-3}$$

$$= 0.00225 Q \text{ kg O}_2 / \text{day}$$

1.9.4 TOTAL OXYGEN REQUIREMENTS

$$OD = OD_1 + OD_2 + OD_3$$

$$= 0.0607 Q + 0.0165 Q + 0.00225 Q = 0.0795 Q \text{ (kgO}_2 / \text{day)}$$

1.9.5 AERATION EQUIPMENT (DIFFUSERS, FINE BUBBLES, SPIRAL FLOW)

Aeration equipment is calculated by the following equation.

$$EA = 7.5, \quad \rho = 1.293, \quad Q_w = 0.233$$

Air volume (N m³/day)

$$= (\text{Required oxygen (kgO}_2) / (EA(\%) \times 10^{-2} \times \rho (\text{air/Nm}^3) \times Q_w (\text{kgO}_2 / \text{kg air}))$$

$$= (0.0795 Q) / (7.5 \times 0.01 \times 1.293 \times 0.233)$$

$$= 4.00 Q = 459,920 \text{ (N m}^3 / \text{day)} = 319 \text{ (N m}^3 / \text{min.)}$$

Install one blower for each train

Required blower capacity $319 \div 4 = 80 \text{ m}^3 / \text{tank} \cdot \text{unit}$

Blower spec. Cast-iron made multi-stage turbo blower

Inlet/outlet diameters $\phi 300 / \phi 300$

Capacity 80 m³/min.

Motor output 110 kW

Number of units 5 units (including 1 standby)

1.10 SCREENS AND PUMPING STATION

1.10.1 FLOW RATE

Flow rate is determined as follows.

Q _{ad}	98,000 m ³ /day	1,134 L/s
Q _{md}	115,000 m ³ /day	1,331 L/s
Q _{mh}	140,000 m ³ /day	1,620 L/s
Q _{ww}	280,000 m ³ /day	3,241 L/s

1.10.2 INCOMING SEWER

Incoming sewer is specified as follows.

Friction formula	Manning (n= 0.013)
Size of incoming sewer	$\phi 1,650 \text{ mm}$
Sewer slope	1.3 ‰
Incoming sewer invert elevation	1.425 m above M.W.L.

Full flow rate of incoming sewer 3.241 m³/sec
 Full flow velocity in incoming sewer 1.835 m/sec

Item	Wastewater flow rates (m ³ /s)	Flow velocity (m/sec)	Water depth (m)	Water surface elevation at entrance (m)	Head loss ahead of chamber	Gate chamber water elevation (m)
Average daily	1.134 0.345	0.642 0.418	0.670 0.406	2.095	0.021	2.074
Maximum daily	1.331 0.405	0.754 0.495	0.733 0.444	2.158	0.029	2.129
Maximum hourly	1.620 0.493	0.917 0.597	0.818 0.496	2.243	0.143	2.200
Wet weather flow	3.241 0.986	1.591 0.867	1.333 0.808	2.758	0.129	2.629

Note: Ratio of flow to full flow Ratio to full velocity Ratio to full sewer depth From tables

1.10.3 INFLUENT GATE

Influent gate is specified as follows.

Elevation of gate bottom 1.35 M.W.L.
 Gate type and size square 1.2 m

Items		Average daily flow	Max. daily flow	Max. hourly flow	Wet weather flow	Remarks
Wastewater Inflow rates (Q)	m ³ /s	1.134	1.331	1.620	3.241	
No. of gates operated (n)	Unit	2	2	3	4	
Wastewater inflow to each gate	m ³ /s/gate	0.567	0.666	0.540	0.810	Q/n
Wastewater elevation ahead of gate	M.W.L.	2.074	2.129	2.200	2.629	
Wastewater depth at gate (H)	m	0.724	0.779	0.850	1.279	
Wastewater flow area at gate (A)	m ²	0.869	0.934	1.021	1.44	1.2×H
Flow velocity through gate (V)	m/s	0.653	0.712	0.529	0.563	Q/nA
Head losses at gate (Δh)	m	0.033	0.039	0.021	0.024	
Water elevation after gate	M	2.041	2.090	2.179	2.605	

Total head losses at gate (Δh) $1.5 \times v^2/2g = 0.0765 \times v^2$

1.10.4 COARSE SCREEN

Coarse screen is specified as follows.

Channel invert elevation 1.35 m M.W.L.
 Channel width 1.6 m
 Screen clear opening 100 mm
 No. of screens 4
 Slope of screens 60 degrees from horizontal

Items		Average daily flow	Maximum daily flow	Maximum hourly flow	Wet weather flow	Remarks
Wastewater inflow rates (Q)	m ³ /s	1.134	1.331	1.620	3.241	
No. of channels used (n)		2	2	3	4	
Wastewater inflow to each channel	m ³ /s	0.567	0.666	0.540	0.810	Q/n
Wastewater elevation ahead of screen	m M.W.L.	2.041	2.090	2.179	2.605	
Wastewater depth ahead of screen	m	0.691	0.740	0.829	1.255	
Flow area in channel(A)	m	1.106	1.184	1.045	2.008	1.6 x H
Approaching flow velocity to screen	m/s	0.513	0.562	0.517	0.404	Q/n A
Flow velocity in screen(V2)	m/s	0.544	0.596	0.548	0.428	
Head loss in screen(Δh1)	m	0.001	0.001	0.001	0.000	
Actual head loss in screen(Δh2)	m	0.002	0.003	0.002	0.001	3 x Δh1
Allowable head loss at screens (Δh3)	m	0.100	0.100	0.100	0.100	Δh3 > h2
Wastewater elevation after screen	m M.W.L.	1.941	1.990	2.079	2.505	Δh3

$$\delta h = \beta \times (s/d)^{4/3} \times \sin \alpha = 0.0492268$$

$\beta = 2.42$, $d = 150 \text{ mm}$, $s = 9 \text{ mm}$, $\alpha = 60^\circ$, $\sin 60 = 0.866$
 Loss by screen = $\delta h \times v^2 / 2g = 0.04923 \times v^2 / 2g \text{ (hw)}$
 Flow velocity through screen $V1 \times (s+d) / d = 1.06 \text{ V1}$

1.10.5 FINE SCREEN

Fine screen is specified as follows.

Channel invert elevation 1.2 M.W.L.
 Channel width 1.6 m
 Bar screen clear opening 20 mm
 Thickness of screen bars 8 mm
 No. of units 4 units
 Slope of screen 75 degrees to horizontal

Items		Average daily flow	Maximum daily flow	Maximum hourly flow	Wet weather flow	Remarks
Wastewater Inflow rate (Q)	m ³ /s	1.134	1.331	1.620	3.241	
No. of channels in use (n)		2	2	3	4	
Flow rate in each channel	m ³ /s	0.567	0.666	0.540	0.810	Q/n
Water elevation ahead of screen	M.W.L.	1.941	1.990	2.079	2.505	
Water depth ahead of screen	m	0.741	0.790	0.879	1.305	
Sectional area of flow in channel	m ²	1.186	1.264	1.108	2.088	1.6 x H
Approaching velocity to screen (V1)	m/s	0.478	0.527	0.488	0.388	Q/nA
Flow velocity through screen(V2)	m/s	0.669	0.737	0.683	0.543	
Head loss through screen(Δh1)	m	0.016	0.019	0.016	0.010	
Actual head loss in screen(Δh2)	m	0.047	0.057	0.049	0.031	3 x Δh1
Allowable maximum loss(Δh3)	m	0.100	0.100	0.100	0.100	Δh3 < h2
Water surface elevation after screen	M.W.L.	1.841	1.890	1.979	2.405	Δh2

$$\delta h = \beta \times (s/d)^{4/3} \times \sin \alpha = 0.688907$$

Q_{ww} 10.900 M.W.L.

(6) Actual Head

Q _{ad}	10.900	-	(1.841)	=	9.059 m
Q _{md}	10.900	-	(1.890)	=	9.010 m
Q _{mh}	10.900	-	(1.979)	=	8.921 m
Q _{ww}	10.900	-	(2.405)	=	8.495 m

(7) Total Head Losses at Pump Equipment

Pump size		φ450	φ600
Pump bore(m)		0.45	0.6
Pump discharge(m ³ /min)		25	50
Pump discharge(m ³ /sec)		0.417	0.833
Delivery bore sectional area (m ²)		0.159	0.283
Pump velocity(m/s)		2.621	2.949

(8) Loss Coefficients

Inlet		0.15	0.15
Sluice valve		0	0
Check valve		1.0	1.0
Outlet		1.0	1.0
Bend		0.25	0.25
Friction loss	$f \times L/D$	1.056	0.781
Total		3.456	3.181 F

(9) Head losses

$\phi 450 = 1.211 \text{ m } F \times V^2/2g$
 $\phi 600 = 1.411 \text{ m}$
 Pipe length L = 15 m
 Friction loss by Darcy-Wiseback Formula
 $hf = f \times L/D \times V^2/2g$
 $f = 0.02 + 1/(2000 \times D)$ (New cast iron pipe)
 For old cast-iron pipes multiply the 'f' by 1.5

	φ450	φ600
D(m)	0.45	0.6
F	0.021	0.021
$f' = 1.5 \times f$	0.032	0.031

(10) Total Head Required

Q _{ad}	9.059	+	1.211 (φ450)	=	10.270 m
			1.411 (φ600)	=	10.470 m
Q _{md}	9.010	+	0.000	=	9.010 m
Q _{mh}	8.921	+	0.000	=	8.921 m
Q _{ww}	8.495	+	1.411 (φ600)	=	9.907 m

The required total pump head is then 11.0 m

(11) Shaft Power of Mixed Flow Centrifugal Pumps

$$L = k \times \gamma \times Q \times H / \mu$$

where

L	Shaft power of pump
k	0.163 kW or 0.222 PS
Q	Pump discharge (m ³ /min)
H	Pump total dynamic head (m)
γ	Specific gravity of water ($\gamma = 1$)
μ	Pump efficiency

Calculations for shaft power requirement

Items		$\phi 450$	$\phi 600$	$\phi 600$ Engine
Pump discharge(Q)	m ³ /min	25	50	50
TDH (H)	m	11.0	11.0	11.0
Pump efficiency (μ)		0.74	0.78	0.78
Shaft power	kW	61	115	157

(12) Outputs of Pump Drives

$$P = L(1+\alpha) / \mu G$$

where

P	Pump power (kW)
L	Pump shaft power (kW)
α	Allowance for motor 0.15 Allowance for engine 0.2
μG	Transmission efficiency (1.0 for direct connection)

	$\phi 450$	$\phi 600$	$\phi 600$ Engine
Shaft power (L)	61	115	157
Allowance (α)	1.15	1.15	1.20
Efficiency of transmission (μG)	1.00	1.00	0.95
Pump drive output (P) kW	70	132	198

(13) Pump Specifications

		Vertical mixed flow centrifugal pumps		
Pump bore	mm	450	600	600
Pump discharge	m ³ /min.	25	50	50
Total dynamic head	m	11	11	11
Motor/engine outputs	kW	70	132	198
Pump drive		Motor	Motor	Engine

1.11 GRIT OIL/GREASE REMOVAL EQUIPMENT

1.11.1 DESIGN WASTEWATER FLOW RATES


Design wastewater flow rates are determined as follows.

Q _{ad}	98,000	m ³ /day	1,134	L/s
Q _{md}	115,000	m ³ /day	1,331	L/s
Q _{mh}	140,000	m ³ /day	1,620	L/s
Q _{ww}	280,000	m ³ /day	3,241	L/s

1.11.2 GRIT, OIL/GREASE SEPARATION

Grit, oil/grease separation is specified as follows.

4 trains 1 channels each, then totally 4 channels
 Q_{ww} 280,000 m³/day = 3,241 L/sec
 Flow to each channel 70,000 m³/day = 810 L/sec
 Retention time 3 minutes
 Capacity 280,000 × 3 ÷ 1,440 = 583.3 m³
 Section area 6.8 m²
 Length 22 m
 Capacity 6.8 × 22 × 4 = 598.4 m³
 (check for flows)
 At maximum daily flow Q_{md} 115,000 m³/day
 Retention (598.4 × 1440) / 115,000
 Time = 7.5 min.



Chamber cross sectional area

1.4	×	0.95	=	1.33
1/2	×	1.4 ²	=	0.98
1.6	×	3.05	=	4.88
-1/2	×	0.5 ²	=	-0.13
-1/2	×	0.7 ²	=	-0.25

Total 6.82 m² use → 6.8 m²
 Air supply volume

Romanian Standards $Q = 0.3 \text{ m}^3 \text{ air} / \text{m}^3 \text{ water}$
 $= 0.3 \times 11,667 = 3,500 \text{ m}^3/\text{hour}$
 $= 58 \text{ m}^3/\text{min}$

Japanese Standards $Q = 0.01 \text{ m}^3/\text{sec} \cdot \text{m} \times \text{channel length/m}$
 $(0.005-0.013)$
 $= 0.01 \times 22 \times 4$
 $= 0.88 \text{ m}^3/\text{sec} = 53 \text{ m}^3/\text{min}$

Then, the total air is $58 \text{ m}^3/\text{min}$
 Blower equipment: 1 unit each for 1 train
 then, 1 blower capacity $= 58 \div 4 = 14.6 \text{ use} \rightarrow 15 \text{ m}^3/\text{min}$
 Air blower specifications
 Roots blower 5 units (including 1 standby)
 $\phi 125\text{mm}$ $15 \text{ m}^3/\text{min}$

Grit volume from combined sewage: $0.001-0.02 \text{ m}^3 \text{ grit} / 1000 \text{ m}^3 \text{ sewage}$
 Then, grit volume $= 0.02 / 1000 \times 280,000 = 5.6 \text{ m}^3/\text{day}$

1.11.3 GRIT PUMPS

Grit pumps are calculated as follows.

Pump capacity is to remove the grit in 20 minutes. As allowances the capacity is two times of the grit quantity. Then, the pump capacity is:

$$5.6 \text{ m}^3/\text{day} \times 2 / 4 \text{ units} \times 20 \text{ minutes} = 0.14 \text{ m}^3/\text{min}.$$

Assuming the grit content in the withdrawn wastewater at 10 %, the required pump capacity is:

$$0.14 \times 100 / 10 = 1.4 \text{ m}^3/\text{min}.$$

Assume the pump velocity to be 2.5 m/sec, the pump diameter will be:

$$146 \times (1.4 / 2.5)^{0.5} = 109 \text{ use } 100 \text{ mm}$$

1.11.4 FLOW MEASUREMENT

Use two units of Parshall flume

			Flow per each unit(Q / 2)
Q _{ad}	98,000 m ³ /day	=	4,083 m ³ /hour
Q _{mh}	115,000 m ³ /day	=	4,792 m ³ /hour
Q _{mh}	140,000 m ³ /day	=	5,833 m ³ /hour
Q _{wv}	280,00 m ³ /day	=	11,667 m ³ /hour
Select 7 ft flume, range of flow			306 ~ 12,380 m ³ /hour
			2 units

1.12 SLUDGE DIGESTER EQUIPMENT

1.12.1 MIXERS

(1) Specifications

Type Up/down flow screw mixers (with a draft tube, from manufacturer's catalogue)
 Capacity 1,200 m³/hour
 Draft tube diameter 400 mm
 Motor output 11 kW
 Quantity 4 units

(2) Sludge Mixing Capacity

Sludge turn over rate (mixing the whole sludge volume 8 ~ 12 times/day)

$$Q = (8-12) \times 3,503 \text{ (Tank volume} = 3,503 \text{ m}^3) / 24$$

$$= 1,168 \sim 1,752 \text{ m}^3/\text{hour use} \rightarrow 1,200 \text{ m}^3/\text{hour}$$

1.12.2 TANK APPARATUS(ON ROOF TOP)

Tank apparatus are specified as follows.

Gas collectors(steel made)	φ600 mm × 1 unit
Gas relief valve (wet type)	φ200 mm × 1 unit
Gas relief valve (dry type)	φ200 mm × 1 unit (including valve and flame arrester)
Quantity	Total 4 units

1.12.3 WATER HEATERS

(1) Specifications

Type	Vacuum type water heater
Heater capacity	450,000 Kcal/hr.
Heater transfer area	9.9 m ²
Fuel	Sludge gas and oil
Electric motors	Burner motor 1.5 kW
	Oil pump 0.4 kW
	Oil heater 1.0 kW
	Fan 1.5 kW
Quantity	3 units (Istandby)

(2) Nominal Heat Output

$$\begin{aligned} \text{Total required heat} &= 892,258 \text{ Kcal/hr} \\ \text{Nominal heater capacity } Q &= (892,258) / (2 \times 0.9) \\ &= 460,699 \text{ Kcal / hr.} \rightarrow 450,000 \text{ Kcal / hr} \\ &\text{(Heater efficiency 0.9) (No. of units:2)} \end{aligned}$$

1.12.4 OIL SERVICE TANKS

(1) Specifications

Type	Steel made rectangular tank
Tank capacity	150 L
Quantity	1 unit

(2) Tank Capacity

$$\begin{aligned} \text{Store oil of more than one hour consumption:} \\ q &= (450,000 \times 2) / (10,200 \times 0.85) = 104 \text{ L / hr. use} \rightarrow 150 \text{ L} \\ \beta &:\text{Heating value of A-diesel oil } 10,200 \text{ kcal / kg} \\ \gamma &:\text{Specific gravity of A-diesel oil } 0.85 \text{ kg/L} \end{aligned}$$

1.12.5 OIL PUMPS

(1) Specifications

Type	Gear pump
Size	φ 15 mm
Discharge	5 L/min.
Discharge pressure	3 kg/cm ²
Electric motor	0.4 kW
Quantity	2 units (including 1 standby)

(2) Pump Discharge

Capable of supplying a 300-liter capacity tank within 30 minutes

$$Q = 150 / 30 = 5 \text{ L/minute}$$

1.12.6 OIL STORAGE TANK**(1) Specifications**

Type	Underground cylinder type
Storage capacity	7,500 L
Quantity	1 unit

(2) Tank Capacity

Store more than 3-day oil consumption.

$$V = 104 \times 24 \times 3 = 7,474 \text{ L use } \rightarrow 7,500 \text{ L}$$

1.12.7 GAS BOOSTER FANS**(1) Specifications**

Type	Turbo fan
Capacity	81.8 m ³ /hr.
Pressure (static pressure in water column)	500 mm Aq
Electric motor	1.5 kW
Quantity	2 units (including 1 standby)

(2) Capacity

Sludge gas consumption

$$q = 450,000 / 5,500 = 81.8 \text{ m}^3/\text{hr.}$$

(Sludge gas heat value 5,500 kcal/m³)

Check for gas consumption

Required energy	Kcal/day	9,902,195
Heater operation time	Hour	22.1
Gas production	m ³ /day	6,456
Gas consumption	m ³ /day	1,809

Required heat energy 829,258 Kcal/hr.

Heater output 450,000 Kcal/hr.

No. of units 2 units

1.12.8 HEAT EXCHANGE**(1) Specifications**

Type	Spiral type heat exchanger			
Heat transfer area	15 m ²			
Water temperature	Inlet	35 °c,	Outlet	40 °c
	"	70 °c,	"	60 °c
Quantity	Total Nos.	4 units		

(2) Energy Transfer

Provide an exchanger to each digester

$$\begin{aligned} \text{Required energy per unit, } M &= 19,902,195 \times 1/4 = 4,975,549 \text{ Kcal/day} \\ &= 207,315 \text{ Kcal/hr.} \end{aligned}$$

(3) Required Heat Transfer Area

$$\begin{aligned} A &= (M \times 1.2) / (K \times \Delta t_m) = (207,315 \times 1.2) / (600 \times 27.4) \\ &= 15.1 \text{ m}^2 \text{ use } 15 \text{ m}^2 \end{aligned}$$

M = Heat transfer 207,315 Kcal/hr.

K = Overall heat transfer coefficient 600 Kcal/m² hr. °C

Δt_m Logarithmic average of temperature difference

$$= (\Delta t_1 - \Delta t_2) / (\ln \Delta t_1 / \Delta t_2)$$

$$= (30 - 25) / (\ln (30/25)) = 27.4 \text{ }^\circ\text{C}$$

$$\Delta t_1 = 70 - 40 = 30 \text{ }^\circ\text{C}$$

$$\Delta t_2 = 60 - 35 = 25 \text{ }^\circ\text{C}$$

(4) Sludge Recirculation

$$\begin{aligned} Q_1 &= M / (C \times \Delta t \times \gamma \times 60) = 207,315 / (1 \times 5 \times 1,000 \times 60) \\ &= 0.69 \text{ m}^3/\text{min.} \end{aligned}$$

C Sludge specific heat 1 Kcal/kg.°C

Δt Temperature difference between inlet and outlet sludge

$$40 - 35 = 5 \text{ }^\circ\text{C}$$

γ Unit weight of sludge 1,000 kg/m³

(5) Water Recirculation

$$Q_2 = 207,315 / (1 \times 10 \times 1,000 \times 60) = 0.35 \text{ m}^3/\text{min.}$$

Δt Difference of temperature between inlet and outlet

$$70 - 60 = 10 \text{ }^\circ\text{C}$$

1.12.9 SLUDGE CIRCULATION PUMPS

(1) Specifications

Type	Sludge pump with suction screw
Size	100 mm
Discharge	0.7 m ³ /min.
TDH	15 m
Motor output	5.5 kW
No. of units	4 units

(2) Capacity

$$\text{Sludge circulation rate } Q = 0.69 \text{ m}^3/\text{min use } \rightarrow 0.7 \text{ m}^3/\text{min.}$$

(3) Head

$$\begin{aligned} \text{Total head} &= \text{Actual head} + \text{pipe losses} + \text{losses in heat exchanger (10m)} \\ &= 15 \text{ m} \end{aligned}$$

(4) Motor Output

$$P_m = 0.163 \times 0.7 \times 15 \times (1 + 0.2) / 0.4 = 5.13 \text{ kW use } \rightarrow 5.5 \text{ kW}$$

1.12.10 HOT WATER CIRCULATION PUMPS**(1) Specifications**

Type	Line pump
Size	65 mm
Capacity	0.34 m ³ /min.
TDH	25 m
Motor output	3.7 kW
Quantity	4 units

(2) Capacity

Return from exchanger, $Q = 0.35 \text{ m}^3/\text{min}.$

(3) Head

Total heads = Actual head + pipe losses + losses in heat exchanger (20m)
= Use 25 m

(4) Motor Output

$$P_m = (0.163 \times 0.4 \times 25 \times (1 + 0.2)) / 0.6 = 3.26 \text{ kW use } \rightarrow 3.7 \text{ kW}$$

1.12.11 GAS HOLDER**(1) Specifications**

Type	Steel made dry seal type
Capacity	1,100 m ³
Size	12.6m ϕ \times 13.3mH
No. of tanks	2 units

(2) Capacity

Gas generation 6,456 m³/day
Retention time 8 hr.
Storage capacity $6,456 \times 8 / 24 / 2 = 1,076 \text{ m}^3 \text{ use } \rightarrow 1,100 \text{ m}^3$

1.12.12 GAS SCRUBBERS**(1) Specifications**

Type	Dry type (intermittent) scrubbers
Capacity	150 m ³ /hr.
Size	1,800 mm \times 4,200 m H \times 2 units
No. of units	2 \times 1,800 mm \times 4,200 m H \times 2 units 2 units

(2) Capacity

Treat all the gas produced
 $Q = 6,456 \times 1 / 24 / 2 = 134 \text{ m}^3/\text{hr use } \rightarrow 150 \text{ m}^3/\text{hr}.$

(3) Diameter of Towers

Velocity of gas flow 1 m/min.
 $D = (4 \times 150 / 60 / 3.14 / 1)^{0.5} = 1.785 \text{ m}\phi, \text{ use } \rightarrow 1800 \text{ mm}\phi$

(4) Chemical Consumption

Inflow and outflow gas H₂S concentrations are 100 ppm and 10 ppm, respectively.

$$V_1 = 0.235 \times 10^{-3} \times Q \times \mu$$

$$= 0.235 \times 10^{-3} \times 150 \times 24 \times 0.9 = 0.761 \text{ L/day}$$

(μ Removal efficiency = 90%)

$$V_0 = V_1 / (C_0 \times 0.8) = 0.761 / (100 / 1,000) \times 0.8$$

$$= 9.5 \text{ L/day}$$

C₀ : Chemical requirements to absorb 100 kg hydrogen sulfide = 1000 kg

γ : Nominal specific gravity of chemical 0.8

(5) Life of Chemical

$$T = (V \times 10^3) / V_0 = (5 \times 10^3) / 9.5 = 525 \text{ days}$$

$$V = \text{Volume } 5 \text{ m}^3$$

1.12.13 WASTE GAS BURNERS

(1) Specifications

Type	In furnace
Capacity	300 m ³ /hr.
Size	3,600 mm × 4,200 mm H
Motor	Cooling fan
"	Gas blower
No. of units	2 units

(2) Treatment Capacity

Capacity: all produced gas

$$Q = 6,456 \times 1/24 \times 2.0 \times 1/2$$

$$= 269 \text{ m}^3/\text{hr use} \rightarrow 300 \text{ m}^3/\text{hr.}$$

1.12.14 SLUDGE SEED PUMPS(SLUDGE SEEDING / WITHDRAW)

(1) Specifications

Type	Sludge pumps with suction screw
Size	100 mm
Capacity	1 m ³ /min.
T.H.L.	15 m
Motor output	7.5kW
No. of units	2 units

(2) Capacity

$$Q = 1 \text{ m}^3/\text{min.}$$

(3) Total Dynamic Head

$$H = 15 \text{ m}$$

(4) Motor Output

$$P_m = 0.163 \times 1 \times 15 \times (1 + 0.2) / 0.4$$

$$= 7.34 \text{ kW use} \rightarrow 7.5 \text{ kW}$$

1.13 APPARATUS FOR SLUDGE DEWATERING EQUIPMENT

1.13.1 SLUDGE STORAGE TANK MIXER

(1) Specifications

Type	Vertical paddle type
Shape	Approximately 6,000mm x 11,500mm x 2,500mmH
Capacity	170 m ³
Blade size	1,500 mmφ
Motor output	5.5 kW
No. of units	3 units

(2) Tank Capacity

Store average one-day sludge production

$$V = 470 \times 1/3 = 157 \text{ m}^3 \text{ use } 170 \text{ m}^3$$

1.13.2 SLUDGE SUPPLY PUMP

(1) Specifications

Type	Single-axis screw pump
Size	φ 100 mm
Capacity	20 m ³ /hour
TDH	20 m
Motor output	5.5 kW
No. of units	9 units

(2) Discharge Capacity

One pump to each dewater equipment (one-standby pump for all dewatering Equipment)

$$Q_1 = 130 \times 3 \times 10^{-3} \times 100 / (3 \times 1.5)$$

$$= 19.5 \text{ m}^3/\text{hour} \text{ use } \rightarrow 20 \text{ m}^3/\text{hour} \quad 0.33 \text{ m}^3/\text{minute}$$

Filter velocity	1	30 kg/m ² ·hr.
Filter width		3 m
Sludge solid concentration		3 %
Allowance		1.5

(3) Electric Motor Output

$$P_m = 0.163 \times 20 \times 0.33 \times (1 + 0.3) / 0.3$$

$$= 4.71 \text{ kW} \text{ use } \rightarrow 5.5 \text{ kW}$$

1.13.3 CHEMICAL FEED PUMP

(1) Specifications

Type	Single-axis screw pump
Size	φ 50 mm
Capacity	3 m ³ /hour
TDH	20 m
Motor output	1.5 kW
No. of units	9 units (including one standby)

(2) Discharge Capacity

One pump to each dewater equipment (one standby pump for all dewatering Equipment)

$$Q1 = 130 \times 3 \times 10^{-3} \times 0.01 \times 100 / 0.2 \times 1.5$$

$$= 2.925 \text{ m}^3/\text{hour} \rightarrow 3 \text{ m}^3/\text{hour} \text{ } 0.05 \text{ m}^3/\text{min.}$$

Filter velocity	130 kg/m ² ·hr.
Filter width	3 m
Solid concentration of sludge	0.2 %
Allowance	1.5

(3) Electric Motor Output

$$Pm = 0.163 \times 20 \times 0.05 \times (1+0.3) / 0.25$$

$$= 0.85 \text{ kW use} \rightarrow 1.5 \text{ kW}$$

1.13.4 CHEMICAL SOLUTION TANKS

(1) Specifications

Tank type	Steel made cylinder type
Tank capacity	14 m ³
Approx. size	2,300 mmφ × 3,000mmH
Electric motor output	5.5 kW (for mixer)
No. of tanks	2 units

(2) Sludge Storage Tank Capacity

$$\text{Dosing rate} = 14.11 \times 10^3 \times 0.008 \times 7/5 = 157.98 \text{ kg/day}$$

$$\text{Dewatered solids} = 14.11 \text{ t/day}$$

$$\text{Chemical dosing rate (Polymer)} = 0.8 \text{ \%/kg·ds}$$

(5 days/week operation)

Storage capacity. 2 hours of design sludge volume
2 tanks (alternately used)

$$V = (158 \times 100) / (0.2 \times 2 / 6 / 2)$$

$$= 13,165 \text{ L use} \rightarrow 14,000 \text{ L}$$

$$\text{Chemical solution concentration} = 0.2 \%$$

$$\text{Operation time a day} = 6 \text{ hours}$$

$$\text{Retention time} = 2 \text{ hours}$$

1.13.5 CHEMICAL FEEDERS

(1) Specifications

Type	Chemical pump
Supply rate	3 L/min.
Electric motor output	0.4 kW
Quantity	2 units

(2) Supply Rate

One feeder is attached to each solution tank, supplying chemical in 15 to 20 minutes.

$$Q = 14,000 \times 10^3 \times 0.2 / 100 \times 1 / (15 \sim 20) \times 1 / 0.5$$

$$= 3.7 \sim 2.8 \rightarrow 3 \text{ L/min.}$$

$$\text{Apparent specific gravity of polymer} = 0.5$$

1.13.6 CHEMICAL CONTAINERS**(1) Specifications**

Type	Stainless steel made, cylinder container
Effective capacity	400 L
Quantity	2 units

(2) Capacity

Provide 2 tanks (alternately used), with capacity of 7-day chemical consumption.

$$V = 157.98 \times 7/5 \times 0.5 \times 7 \times 1/2$$

$$= 387 \text{ L use} \rightarrow 400 \text{ L}$$

1.13.7 FILTER CLOTH WASHING PUMPS**(1) Specifications**

Type	Multi-stage centrifugal pump
Size	ϕ 50 mm
Discharge	0.3 m ³ /min.
Total head	60 m
Electric motor output	7.5 kW
Quantity	9 units (including 1 standby)

(2) Discharge

One pump to each dewatering machine, and one standby pump for all equipment.

$$Q = 100 \times 3 = 300 \text{ L/min. use} \rightarrow 0.3 \text{ m}^3/\text{min.}$$

Then, the pump discharge per 1 m cloth is 100 L/min.

$$\text{Total dynamic head} = 60 \text{ m}$$

Electric motor output

$$P_m = 0.163 \times 60 \times 0.30 \times (1+0.2) / 0.5$$

$$= 7.04 \text{ kW} \rightarrow 7.5 \text{ kW}$$

1.14 EFFLUENT PUMPING STATION**1.14.1 FLOW RATE**

Flow rates are determined as follows.

Q _{ad}	98,000 m ³ /day	1,134 L/s
Q _{md}	115,000 m ³ /day	1,331 L/s
Q _{mh}	140,000 m ³ /day	1,620 L/s
Q _{ww}	280,000 m ³ /day	3,241 L/s

1.14.2 PUMPING EQUIPMENT**(1) Design Flow Rates**

Q _{ad}	98,000 m ³ /day	68 m ³ /minute
Q _{md}	115,000 m ³ /day	80 m ³ /minute
Q _{mh}	140,000 m ³ /day	97 m ³ /minute
Q _{ww}	280,000 m ³ /day	194 m ³ /minute

(2) Wastewater Pumps

4 units (including 1 standby), mixed flow centrifugal type driven by electric motor.

(3) Storm Water Pumps:

4 units (including 1 standby), mixed flow centrifugal type, smaller pumps driven by motor, and large pumps driven by diesel engine. Pump operation schedule is as follows:

Wastewater inflows	Wastewater inflow rates (m ³ /minute)	Pump discharges				Total pump discharge (m ³ /minute)
		Wastewater pumps		Storm water pumps		
		25	50	25	50	
		2	2(1)	2	2(1)	No. of units
Qad	68	25	50			75
Qmd	80	50	50			100
Qmh	97	50	50			100
Qww	194	50	50	50	50	200

(4) Pump Size:

No.1 Pumps $Q = 25 \text{ m}^3/\text{minute}$
 $D = 146(Q/V)^{0.5}$ $V = 2.5 \text{ m/sec}$
 $= 462 \text{ mm use} \rightarrow 450 \text{ mm}$

No.2 Pumps $Q = 50 \text{ m}^3/\text{minute}$
 $D = 146(Q/V)^{0.5}$
 $= 653 \text{ mm use} \rightarrow 600 \text{ mm}$

(5) Wastewater Surface Elevations:

Suction water levels at inflow of
 Qad 6.900 M.W.L.
 Qmd 6.900 M.W.L.
 Qmh 6.900 M.W.L.
 Qww 6.900 M.W.L.

Suction water levels at outflow of
 Qad 8.800 M.W.L.
 Qmd 8.800 M.W.L.
 Qmh 8.800 M.W.L.
 Qww 8.800 M.W.L.

(6) Actual Head:

Qad 8.800 - (6.900) = 1.900 m
 Qmd 8.800 - (6.900) = 1.900 m
 Qmh 8.800 - (6.900) = 1.900 m
 Qww 8.800 - (6.900) = 1.900 m

Total head losses at pump equipment:

Pump size	$\phi 450$	$\phi 600$
Pump bore (m)	0.45	0.6
Pump discharge (m ³ /min)	25	50
Pump discharge (m ³ /sec)	0.417	0.833
Delivery bore sectional area (m ²)	0.159	0.283

(10) Outputs of Pump Drives

$$P = L(1+\alpha) / \mu \times G$$

where

- P Pump power (kW)
- L Pump shaft power (kW)
- α Allowance for motor 0.15
- Allowance for engine 0.2
- μG Transmission efficiency (1.0 for direct connection)

	$\phi 450$	$\phi 600$	$\phi 600$ Engine
Shaft power (L)	28	52	71
Allowance (α)	1.15	1.15	1.20
Efficiency of transmission (μG)	1.00	1.00	0.95
Pump drive output (P) kW	32	60	90

(11) Pump Specifications

		Vertical mixed flow centrifugal pumps		
Pump bore	mm	450	600	600
Pump discharge	m ³ /min.	25	50	50
Total dynamic head	m	5	5	5
Motor/engine output	kW	32	60	90
Pump drive		Motor	Motor	Engine

2. RECIRCURATION PROCESS

2.1 DESIGN BASIS

2.1.1 DESIGN WASTEWATER INFLOW RATES

Design wastewater inflow rates are determined as follows.

Average daily flow	Q _{ad}	98,000 m ³ /day	1,134 L/s
Maximum daily flow	Q _{md}	115,000 m ³ /day	1,331 L/s
Maximum hourly flow	Q _{mh}	140,000 m ³ /day	1,620 L/s
Wet weather flow	Q _{ww}	280,000 m ³ /day	3,241 L/day

2.1.2 DESIGN WASTEWATER QUALITY

Design wastewater quality is determined as follows.

BOD	=	150 mg/L
SS	=	180 mg/L
T-N	=	25 mg/L
T-P	=	4 mg/L

2.1.3 DESIGN WASTEWATER QUALITY (INCLUDING SIDESTREAM WASTE LOADS)

Design wastewater quality (including sidestream waste loads) is calculated as follows.

BOD = 170 mg/L
 SS = 210 mg/L
 T-N = 30 mg/L
 T-P = 5.5 mg/L

Parameter	Removal Efficiency (%)			Wastewater Quality (mg/L)		
	Primary treatment	Secondary treatment	Overall removal rate	Raw waste-water	Primary effluent	Secondary effluent
BOD	30	91	93.7	170	119	11
SS	40	93	95.8	210	126	9
T-N	10	65	68.5	30	27.0	9.5
T-P	10	80	82.0	5.5	4.95	1.0

2.1.4 POLLUTANT DISCHARGE LIMITS BY NTPA 001

Pollutant discharge limits by NTPA 001 is regulated as follows.

BOD < 20 mg/L
 SS < 60 mg/L
 T-N < 10 mg/L
 T-P < 1.0 mg/L

2.2 CALCULATIONS OF SIDESTREAM POLLUTANT LOADS

2.2.1 RAW SLUDGE VOLUME

Raw sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Solid production (t/day)} &= 115,000 \times 180 \times 10^{-6} \times 0.4 \\ &= 8.28 \text{ t/day} \\ \text{Sludge concentration} &= 2.0 \% \\ \text{Sludge volume} &= 8.28 \times 100 \div 2.0 = 414 \text{ m}^3/\text{day} \end{aligned}$$

2.2.2 WASTE SLUDGE VOLUME

Parameter	Influent quality (mg/L)	Reaction tank influent quality (mg/L)	Primary clarifiers removal Efficiency (%)
BOD	150	105	30
SS	180	108	40

Assuming that the reactor influent S-BOD is 66.7% of the total BOD; then S_{cc} is 70.0 mg/L
 Waste sludge production volume can be calculated by the following equation:

$$Q_w \times X_w = (a \times S_{cs} + b \times S_{ss} - c \times \theta \times X_A)Q$$

where,

Q_w Volume of waste sludge (m³/day)
 X_w Average SS concentration of waste sludge (mg/L)
 Q Influent volume to reactors (m³/day) 115,000
 X_A MLSS concentration in reactors (mg/L) 3,000
 S_{cs} Influent soluble-BOD concentration to reactors (mg/L) 70.0
 S_{ss} Influent SS concentration to reactors (mg/L) 108

a	Sludge yield coefficient of S-BOD (mg MLSS/mgSS)	0.4~0.6	0.5
b	Sludge yield coefficient of SS (mg MLSS/mgSS)	0.9~1.00.	0.95
c	Coefficient of SS reduction due to indigenous respiration of activated sludge micro-organisms (L/day)	0.03~0.05	0.04
0	HRT in reactor basins (day)	15.4 / 24	= 0.64

therefore,

$$Q_w \times X_w = (0.5 \times 70.0 + 0.95 \times 108 - 0.04 \times 0.643 \times 3,000) \times Q \times 10^{-6}$$

$$= 60.43 \times Q \times 10^{-6} = 6.95 \text{ t/day}$$

Solid production = 6.95 t/day
 Sludge concentration = 0.9 %
 Sludge production = $6.95 \times 100 \div 0.9 = 772 \text{ m}^3/\text{day}$

2.2.3 THICKENED SLUDGE

Thickened sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Sludge solids} &= 8.28 + 6.95 = 15.23 \text{ t/day} \\ &\quad \text{Primary sludge} \quad \text{Excess sludge} \\ \text{Sludge volume} &= 414 + 772 = 1,186 \text{ m}^3/\text{day} \\ &\quad (2.0\%) \quad (0.9\%) \\ \text{Solids} &= 15.23 \times 0.85 = 12.95 \text{ t/day} \\ \text{Assuming sludge concentration is} & \quad 3.5 \% \\ \text{Sludge volume} &= 12.95 \times 100 \div 3.5 = 370 \text{ m}^3/\text{day} \end{aligned}$$

2.2.4 SLUDGE SUPERNATANT OF THICKENERS

Sludge supernatant of thickeners weight is calculated by the following equation.

$$\begin{aligned} \text{Liquor volume} &= 1,186 - 370 = 816 \text{ m}^3/\text{day} \\ \text{Solids weight} &= 15.23 \times 0.15 = 2.28 \text{ t/day} \\ \text{BOD} &= 816 \times 2000 \times 10^{-6} = 1.63 \text{ t/day} \\ \text{BOD is assumed to be of} & \quad 2,000 \text{ mg/L} \\ \text{T-N} &= 816 \times 700 \times 10^{-6} = 0.57 \text{ t/day} \\ \text{T-N is assumed to be of} & \quad 700 \text{ mg/L} \\ \text{T-P} &= 816 \times 180 \times 10^{-6} = 0.15 \text{ t/day} \\ \text{T-P is assumed to be of} & \quad 180 \text{ mg/L} \end{aligned}$$

2.2.5 DIGESTED SLUDGE

Digested sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Digested sludge solids} &= 12.95 \times (1 - 0.7 \times 0.5) = 8.41 \text{ t/day} \\ \text{Digested sludge volume} & \quad 3.0 \% \\ \text{Sludge volume} &= 8.41 \times 100 / 3.0 = 280 \text{ m}^3/\text{day} \end{aligned}$$

2.2.6 DEWATERED SLUDGE(SLUDGE CAKE)

Dewatered sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Solids} &= 8.41 \times 0.9 = 7.57 \text{ t/day} \\ & \quad (\text{Assuming } 20.0 \% \text{ solids concentration}) \\ \text{Cake volume} &= 7.57 \times 100 / 20.0 = 38 \text{ m}^3/\text{day} \end{aligned}$$

2.2.7 DIGESTED SLUDGE FILTRATE

Digested sludge filtrated weight is calculated by the following equation.

$$\begin{aligned}
 \text{Filtrate volume} &= 280 - 38 = 243 \text{ m}^3/\text{day} \\
 \text{Dry solids weight} &= 8.41 \times 0.10 = 0.84 \text{ t/day} \\
 \text{BOD} &= 243 \times 1,500 \times 10^{-6} = 0.36 \text{ t/day} \\
 &\quad (\text{Assumed BOD concentration} = 1,500 \text{ mg/L}) \\
 \text{T-N} &= 243 \times 150 \times 10^{-6} = 0.04 \text{ t/day} \\
 &\quad (\text{Assumed BOD concentration} = 150 \text{ mg/L}) \\
 \text{T-P} &= 243 \times 80 \times 10^{-6} = 0.02 \text{ t/day} \\
 &\quad (\text{Assumed BOD concentration} = 80 \text{ mg/L})
 \end{aligned}$$

2.2.8 SIDESTREAM VOLUME AND WASTE LOAD

Sidestream volume and waste load is calculated by the following equation.

	Thickener supernatants	Sludge filtrate	
Liquor volume	= 816	+ 243	= 1,059 m ³ /day
Dry solids	= 2.28	+ 0.84	= 3.13 t/day
BOD	= 1.63	+ 0.36	= 2.00 t/day
T-N	= 0.57	+ 0.04	= 0.61 t/day
T-P	= 0.15	+ 0.02	= 0.17 t/day

2.2.9 WASTEWATER QUALITY (INCLUDING ALL SIDESTREAMS)

Wastewater quality (including all sidestreams) is calculated by the following equation.

$$\begin{aligned}
 \text{Overall wastewater flow} &= \text{Influent} + \text{Sidestreams} \\
 \text{Maximum daily flow} &= 115,000 + 1,059 = 116,059 \text{ m}^3/\text{day} \\
 \text{Then, the design wastewater flow characteristics are;} \\
 \text{BOD} &= (115,000 \times 150 \times 10^{-6} + 2.00) / 116,059 \\
 &= 0.00016584 \times 10^6 = 166 \rightarrow 170 \text{ mg/L} \\
 \text{SS} &= (115,000 \times 180 \times 10^{-6} + 3.13) / 116,059 \\
 &= 0.000205292 \times 10^6 = 205 \rightarrow 210 \text{ mg/L} \\
 \text{T-N} &= (115,000 \times 25 \times 10^{-6} + 0.61) / 116,059 \\
 &= 0.000030009 \times 10^6 = 30.0 \rightarrow 30 \text{ mg/L} \\
 \text{SS} &= (115,000 \times 4 \times 10^{-6} + 0.17) / 116,059 \\
 &= 0.000005397 \times 10^6 = 5.4 \rightarrow 5.5 \text{ mg/L}
 \end{aligned}$$

2.3 SLUDGE PRODUCTIONS

2.3.1 RAW SLUDGE

Raw sludge production volume is calculated by the following equation.

$$\begin{aligned}
 \text{Solid production (t/day)} &= 115,000 \times 210 \times 10^{-6} \times 0.4 \\
 &= 9.66 \text{ t/day} \\
 \text{Sludge concentration} &= 2.0\% \\
 \text{Sludge volume} &= 9.66 \times 100 \div 2.0 = 483 \text{ m}^3/\text{day}
 \end{aligned}$$

2.3.2 WASTE SLUDGE VOLUME

Parameter	Influent quality (mg/L)	Reaction tank influent quality (mg/L)	Primary clarifiers removal Efficiency(%)
BOD	170	119	30
SS	210	126	40

Assuming that influent S-BOD to reactor basins is 66.7 % of the raw wastewater BOD, S-BOD concentration is estimated to be; 79.37 mg/L

Waste sludge production volume is calculated by the following equation.

$$Q_w \times X_w = (a \times S_{cs} + b \times S_{ss} - c \times \theta XA)Q$$

where,

Q_w	Volume of excess sludge (m ³ /day)	
X_w	Average SS concentration of waste sludge (mg/L)	
Q	Influent volume to reactors (m ³ /day)	115,000
XA	MLSS concentration in reactors (mg/L)	3,000
S_{cs}	Influent soluble-BOD concentration to reactors (mg/L)	79.37
S_{ss}	Influent SS concentration to reactors (mg/L)	126
a	Sludge yield coefficient of S-BOD (mg MLSS/mgSS)	0.4-0.6 0.5
b	Sludge yield coefficient of SS (mg MLSS/mgSS)	0.9-1.00 0.95
c	Coefficient of SS reduction due to indigenous respiration of activated sludge micro-organisms (1/day)	0.03-0.05 0.04
θ	HRT in reactor basins (day)	15.4 / 24 = 0.64

therefore,

$$Q_w \times X_w = (0.5 \times 79.37 + 0.95 \times 126 - 0.04 \times 0.643 \times 3,000) \times Q \times 10^{-6}$$

$$= 82.20 \times Q \times 10^{-6} = 9.45 \text{ t/day}$$

$$\text{Solid production} = 9.45 \text{ t/day}$$

$$\text{Sludge concentration} = 0.9 \%$$

$$\text{Sludge production} = 9.45 \times 100 \div 0.9 = 1,050 \text{ m}^3/\text{day}$$

$$= 0.73 \text{ m}^3/\text{min.}$$

2.3.3 RETURN SLUDGE

Return sludge volume is calculated by the following equation.

$$\text{Sludge return ratio} = 50 \%$$

$$\text{Return sludge volume} = 115,000 \times 0.5 = 57,500 \text{ m}^3/\text{day}$$

$$= 40 \text{ m}^3/\text{min.}$$

2.3.4 GRAVITY SLUDGE THICKENERS

Gravity thickened sludge production volume is calculated by the following equation.

$$\text{Solids inflow} = 9.66 + 9.45 = 19.11 \text{ t/day}$$

Primary sludge Excess sludge

$$\text{Sludge inflow} = 483 + 1,050 = 1,533 \text{ m}^3/\text{day}$$

$$\text{Thickened sludge solids} = 19.11 \times 0.8 = 15.29 \text{ t/day}$$

Assume solids content to be 3.5 %

Thickened sludge volume = $15.29 \times 100 / 3.5 = 437 \text{ m}^3/\text{day}$

2.3.5 ANAEROBIC SLUDGE DIGESTERS

Anaerobic digested sludge production volume is calculated by the following equation.

Input solids = 15.29 t/day
 Input sludge volume = 437 m³/day
 Volatile solids content of sludge 70 %
 Solids destruction rate 50 %
 Digested sludge solids = $15.29 \times (1 - 0.7 \times 0.5) = 9.94 \text{ t/day}$
 Assume solids concentration is 3.0 %
 Digested sludge volume = $9.94 \times 100 / 3.0 = 331 \text{ m}^3/\text{day}$

2.3.6 SLUDGE DEWATERING

Dewatered sludge production volume is calculated by the following equation.

Input solids = 9.94 t/day
 Recovered solids (90%) = $9.94 \times 0.9 = 8.95 \text{ t/day}$
 Assuming solids concentration as 20.0 %
 Sludge cake volume = $8.95 \times 100 / 20.0 = 45 \text{ m}^3/\text{day}$

2.4 COMPONENT OF FACILITIES

2.4.1 DESIGN BASIS

Design wastewater inflow rate is determined as follows.

Average daily flow $Q_{in} = 98,000 \text{ m}^3/\text{d}$
 (Maximum daily flow in winter season)
 Maximum daily flow $Q_{in \text{ max}} = 115,000 \text{ m}^3/\text{d}$

Design wastewater quality : Influent wastewater quality to reactor tank is calculated As follows.

BOD	119 mg/L	(S-BOD is 80.92 mg/L)	68 %
SS	126 mg/L		(SBOD/BOD)
T-N	27 mg/L		

Design discharge wastewater quality :

Design effluent wastewater quality from final sedimentation tank (average quality) is Determined as follows.

Removal efficiency

BOD	9 mg/L	92.4 %	110
SS	8 mg/L	93.7 %	118
T-N	10 mg/L	63.0 %	17

T-N condition of Treated water is NOT-N 8.3 mg/L Removal efficiency (T-N) 60~70%
 K-N 1.7

Design water temperature 10 °c

(5) Biological Reaction Tank Capacity V(m³)

Biological reaction tank capacity is calculated by the following equation.

Assuming BOD-SS load(LBOD/x) is 0.06 kgBOD/kgMLSS/day (0.05-0.1)

$$V = (\text{BOD-in} \times Q_{in}) / (\text{LBOD/x} \times X) \\ = (119 \times 98,000) / (0.06 \times 3,000) = 64,789 \text{ m}^3$$

(6) Anoxic Tank Capacity VDN m³

Anoxic tank capacity VDN m³ is calculated by the following equation.

$$VDN = V - V_A = 64,789 - 59,218 = 5,571 \text{ m}^3$$

(7) Capacity Ratio of Anoxic Tank and Aerobic Tank

$$VDN : V_A = 5,571 : 64,789 = 1 : 11.6$$

(8) Speed Constant of Denitrification KDN (mgN/ g MLSS/h)

Speed constant denitrification KDN is calculated by the following equation.

$$KDN = (\text{LNOX.DN} \times 10^3) / (24 \text{ VDN} \times X)$$

Here

$$\text{CNOX.A} = \alpha \cdot \text{CTN} \cdot \text{in} \times 1 / (1+R) \\ = (0.7 \times 27 \times 1) / (1+1) = 9.5 \text{ mg/L}$$

$$\text{LNOX.DN} = \text{CNOX.A} \times (Q_r + Q_c) \times 10^{-3} \\ = 9.5 \times (49,000 + 49,000) \times 10^{-3} = 926 \text{ kg/d}$$

$$KDN = (926 \times 10^3) / (24 \times 5,571 \times 3) \\ = 2.309 \text{ (mgN/gMLSS/h)} > 0.872 \text{ OK}$$

Check of denitrification speed

$$\text{Less than } (y') \text{ is NO } \quad y' = 6.2 \times 0.06 + 0.5 = 0.872$$

More than (y') is OK

Calculate	$V_{dn} = \frac{926 \times 10^3}{24 \times 0.872 \times 3}$	=	14,751 m ³
back			

$$VD : V_A = 1 : 4.01$$

$$V = 14,751 + 59,218 = 73,968 \text{ m}^3$$

(9) Biological Reaction Tank Capacity and Retention Time

Biological reaction tank capacity and retention time is calculated by the following equation.

Retention time at biological reaction tank in winter season, t(h) is

$$t = (24 \times 73,968) / 98,000 = 18.1 \text{ h}$$

Retention time at aerobic tank in winter season, tA(h) is

$$t = (24 \times 59,218) / 98,000 = 14.5 \text{ h}$$

Retention time for daily maximum flow at biological reaction tank in winter season, t(h) is

$$t = (24 \times 73,968) / 115,000 = 15.4 \text{ h}$$

(10) Necessary Oxygen Demand ΣD (kg/d)

Necessary oxygen demands is calculated by considering of oxidation of carbonic organic matter, necessary oxygen for endogenous respiration and nitrification reaction of microorganisms in activated sludge, and necessary oxygen for maintain a dissolved oxygen.

$$OD = OD1 + OD2 + OD3 + OD4$$

Here

- OD Necessary oxygen demands (kgO₂/day) (AOR)
- OD1 Necessary oxygen for oxidation of carbonic organic matter (kgO₂/day)
- OD2 Necessary oxygen for endogenous respiration (kgO₂/day)
- OD3 Necessary oxygen for nitrification reaction (kgO₂/day)
- OD4 Necessary oxygen for maintain a dissolved oxygen (kgO₂/day)

$$OD1 = A(\text{kgO}_2/\text{kgBOD}) \times \{ \text{Removal BOD}(\text{kgBOD}/\text{day}) - \text{Denitrification volume}(\text{kgN}/\text{day}) \times K(\text{kgBOD}/\text{kgN}) \}$$

- Here A: Necessary oxygen for removal of BOD (0.5~0.7)
- K: BOD consumption for denitrification(2.86)

$$OD2 = B(\text{kgO}_2/\text{kgMLVSS} \cdot \text{day}) \times VA(\text{m}^3) \times \text{MLVSS}(\text{kgMLVSS}/\text{m}^3)$$

- Here B: Oxygen consumption by endogenous respiration at MLSS unit (0.05~0.15)

VA: Reaction tank capacity at aerobic part

$$OD3 = C(\text{kgO}_2/\text{kgN}) \times \text{Nitrificated Kj-N volume}(\text{kgN}/\text{day})$$

- Here C: Nitrificated oxygen at nitrification reaction (4.57)
- Nitrificated Kj-N (Inflow Kj-N) - (Outflow Kj - N volume) - (Removal volume of Kj -N by excess sludge)

$$OD4 = Q \times \text{DO concentration of reaction tank}$$

- Here DO: Dissolved oxygen concentration at end point of aerobic tank 1.5mg/L
- (Design flow = 98,000 m³/day)
- BOD_{in} = 119 mg/L, T-N = 27 mg/L
- BOD_{out} = 9 mg/L, VA = 59,218 m³

The results of calculation is shown in table bellow.

		unit		note
Necessary oxygen demands for oxidation of BOD (OD1)	(1) Q	m ³ /day	98,000	
	(2) BOD _{in}	mg/L	119	
	(3) BOD _{out}	mg/L	9	
	(4) $\{(2) - (3)\} \times (1) \times 10^{-3}$	kg/day	10,780	
	(5) ΔDN (denitrification volume)	kg/day	926	
	(6) $k \times (5)$ OD1 = $A \times \{(4) - (6)\}$	kg/day	2,649 488	k = 2.86 A = 0.06
Necessary oxygen demands for endogenous respiration (OD2)	(1) MLSS	mg/L	3,000	
	(2) VA	m ³	59,218	
	(3) $(1) \times (2) \times 10^{-3}$	kg/day	177,653	
	OD2 = B × (3)	kg/day	17,765	B = 0.1
Necessary oxygen demands for nitrification reaction (OD3)	(1) α (nitrification ratio)		0.7	
	(2) T-N _{in}	mg/L	27.0	
	(3) Q	m ³ /day	98,000	
	OD3 = $4.57 \times (1) \times (2) \times (3) \times 10^{-3}$	kg/day	8,465	C = 4.57
Necessary oxygen demands for maintain dissolved oxygen (OD4)	(1) DO concentration at reaction tank	mg/L	1.5	
	(2) Q	m ³ /day	98,000	
	(3) Q _r + Q _c	m ³ /day	147,000	
	(4) $\{(2) + (3)\}$	m ³ /day	245,000	1.5
	OD4 = $(1) \times (4) \times 10^{-3}$	kg/day	368	
Necessary oxygen(OD) demands	OD = OD1 + OD2 + OD3 + OD4	kg/day	27,085	
			0.276 Q	

Design of air diffuser (Assuming that diffused air aeration, fine bubble, spiral flow)

$$EA = 7.5, \quad \rho = 1.293$$

$$Q_w = 0.233 \text{ (Assuming)}$$

Supplied air (N m³/day) =

$$\text{(Necessary oxygen demands (kgO}_2\text{))} / EA(\%) \times 10^{-2} \times \rho \text{ (Air/Nm}^3\text{)} \times Q_w \text{ (kgO}_2\text{/kgAir)}$$

$$= (0.276 \times Q) / (7.5 \times 0.01 \times 1.293 \times 0.233)$$

$$= 12.23 Q = 1,198,718 \text{ (N m}^3\text{/day)} = 832 \text{ (Nm}^3\text{/min)}$$


2.4.3 MEASURE FOR ADVANCED TREATMENT

Way of thinking

Changing from conventional activated sludge process to advanced treatment process (T-N,T-P removal)

Calculate a necessary treatment capacity of advanced treatment process and evaluate a capacity of conventional activated sludge process.

Extend a necessary ponds and equipment in the future.



Explanation of measures for advanced treatment

Here showing a treatment capacity of two processes in table below.

- * Conventional activated sludge process
- * Advanced treatment process (Recirculation process)

Explanation of Measures for Advanced Treatment

	unit	Necessary advanced capacity	Facility and equipment for advanced treatment	
			Conventional activated sludge process	Measures for shortage of capacity
• Primary sedimentation tank surface load	m ³ /m ² /day	35	35	—
Facility shape			φ35m × 4 tanks	
• Reaction tank Retention time	hour	15.4	15.4	15.4
Distribution ratio of water	%		6.6/15.4 × 100 = 43	100 - 43 = 57
Facility shape			Making a wall in reaction tank, and divided an anoxic zone and aerobic zone W5.5m × H5.5m × L68m × 16 tanks	Build an extend tank for reaction tank W5.5m × H5.5m × L71m × 16 tanks
• Final sedimentation Tank surface load	m ³ /m ² /day	15	8.6	11.6
Facility shape			φ45m × 4 tanks	New ponds φ45m × 4 tanks
• Return sludge flow	%	Usually 50% (Sludge pump capacity 100%)	Same to the left	Same to the left (New pumps are necessary)
• Recirculation flow of Nitrified water	%	50%	Provide a recirculation pumps at the outflow point of reaction tank (aerobic tank)	Same to the left
• Supplied air flow	m ³ /min	832	312	520 Extend capacity
• Waste sludge volume (Inflow sludge solids of thickener) (exclude T-P removal)	t/day	19.11	27.21 (Sludge products from Conventional activated sludge process)	Not necessary a extend of capacity
(include T-P removal)		21.59		Not necessary a extend of capacity
• T-P removal by addition of coagulant		New equipment is necessary	Same to the left	Same to the left

Waste sludge volume produced from T-P removal

Waste sludge production volume by addition of coagulant

Influent T-P concentration of reaction tank 4.95 mg/L

Additional concentration of aluminum sulfite CA(mg/L) is calculated by following equation

$$CAL = C_{sp-in} \times m \times AL / P$$

Here

C_{sp-in}	Influent dissolved T-N concentration(mg/l)	4.95
P	Valence of phosphorus	31
AL	Valence of aluminum	27
m	Additional molality ratio	1 (assuming)

$$CAL = (4.95 \times 27 \times 1) / (31) = 4.3 \text{ mg/L}$$

Assuming that waste sludge production volume by addition of coagulant is 5 times as Additional phosphorus volume.

$$\begin{aligned} \text{Waste sludge production volume by addition of coagulant} &= QD \times 5 \times CAL \times 10^{-6} \\ &= 115,000 \times 5 \times 4.3 \times 10^{-6} = 2.48 \text{ t/day} \end{aligned}$$

$$\begin{aligned} \text{Waste sludge volume in case of removal of T-N and T-P simultaneously} \\ &= 19.11 + 2.48 = 21.59 \text{ t/day} \end{aligned}$$