

Table 7.1 Input Parameters to The 3-D Simulation Model

| Model Layer | Aquifer Unit | Aquifer Type | Top and Bottom Elevation (masl) | Effective Porosity | Specific Storage (m ⁻¹) | Hydraulic Conductivity | | Initial Heads (masl) | Recharge Rate (mm/day) | Pumping Rate (1991) (m ³ /day) |
|-------------|-----------------|---------------------|---|--------------------|-------------------------------------|------------------------|------------------|----------------------|------------------------|---|
| | | | | | | Horizontal (m/day) | Vertical (m/day) | | | |
| Layer-1 | First Aquitard | Confined/Unconfined | Top: 8.1 to 30.2 Btm: -1.5 to -17.3 | 0.25 | 1.00E-04 | 0.1 | 0.01 (0.03)* | 3.36 to 4.47 | 1.1 | 0 |
| Layer-2 | First Aquifer | Confined/Unconfined | Top: -1.5 to -17.3 Btm: -7.8 to -33.9 | 0.25 | 1.00E-04 | 10.0 to 35.4 | 1.0 to 3.54 | -6.33 to 7.95 | 0 | 0 |
| Layer-3 | Second Aquitard | Confined | Top: -7.8 to -33.9 Btm: -21.7 to -49.4 | 0.25 | 1.00E-04 | 0.01 | 0.001 (0.04)* | -10.63 to 5.19 | 0 | 0 |
| Layer-4 | Second Aquifer | Confined | Btm: -21.7 to -49.4 Btm: -50.5 to -110.6 | 0.25 | 1.00E-04 | 20.1 to 70.9 | 2.01 to 7.09 | -10.63 to 5.19 | 0 | 383,034 |

*: Modified value by the model calibration

Table 7.2 Groundwater Pumpage in Hanoi Area from 1990 to 1996

(Unit: m³/day)

| Year | 1990 | 1991 | 1992 | 1993 | 1994 | 1995 | 1996 |
|-----------------------------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| HWBC Major Well Field | | | | | | | |
| PHAP VAN | 46,248 | 37,968 | 39,120 | 32,544 | 28,752 | 34,548 | 21,360 |
| MAI DICH | 42,240 | 55,728 | 61,176 | 65,112 | 59,400 | 56,904 | 55,800 |
| NGOC HA | 39,576 | 57,672 | 40,752 | 44,640 | 39,000 | 45,720 | 44,328 |
| LUONG YEN | - | - | 25,968 | 79,056 | 77,016 | 74,160 | 57,744 |
| TUONG MAI | - | - | 30,744 | 26,736 | 26,496 | 27,648 | 23,184 |
| HA DINH | - | - | 30,696 | 27,504 | 30,720 | 31,032 | 29,232 |
| NGO SY LIEN | 49,200 | 53,160 | 45,240 | 44,592 | 42,168 | 33,672 | 30,504 |
| YEN PHU | 49,032 | 46,584 | 45,960 | 47,928 | 37,728 | 39,096 | 29,328 |
| Total of Major Well Fields | 226,296 | 251,112 | 319,656 | 368,112 | 341,280 | 342,780 | 291,480 |
| Other Total | 133,986 | 131,922 | 135,930 | 142,500 | 149,070 | 155,640 | 162,210 |
| Grand Total | 360,282 | 383,034 | 455,586 | 510,612 | 490,350 | 498,420 | 453,690 |

[Data source]
 Hanoi Dept. of Sci. & Enviro. Tech. and Hanoi Univ. of Mining and Geology (1998)
 Dept. of Geology and Minerals of Vietnam (1998)
 Nguyen Van Hoang (1993)






Figure 7.1 Model Grid for Groundwater Simulation Applied to Hà Nội Aquifer System

THE STUDY ON GROUNDWATER DEVELOPMENT IN THE RURAL PROVINCES OF NORTHERN PART IN THE SOCIALIST REPUBLIC OF VIETNAM

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

Boundary Conditions of Layer-1




Constant-Head Boundary

Constant-Head Boundaries are set at Red River (Sông Hồng), Duong River (Sông Đuống) and West Lake (Hồ Tây).
 No Constant-Head Boundaries are set in Layer-2, Layer-3, and Layer-4.
 Water levels at Constant-Head Boundaries are given from the data of Surface Water Observation Points.

| | |
|--|---|
| Figure 7.2 | Boundary Conditions of Hà Nội Groundwater Simulation Model |
| THE STUDY ON GROUNDWATER DEVELOPMENT IN THE RURAL PROVINCES OF NORTHERN PART IN THE SOCIALIST REPUBLIC OF VIETNAM | |
| JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) | |

Steady-State 3-D Simulation



Top View: Layer 4 (Main Confined Aquifer)

Cross-Section

Projection Row = 17

Projection Column = 13

■ Pumped Cell

■ Constant Head

■ Dried Cell

→ Flow Vector

--- Simulated Groundwater Table

-10- Equal Line of Simulated Piezometric Surface (masl)


Figure 7.3

Simulated Piezometric Surface by Steady-State Calibration

THE STUDY ON GROUNDWATER DEVELOPMENT IN THE RURAL PROVINCES OF NORTHERN PART IN THE SOCIALIST REPUBLIC OF VIETNAM

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

Transient 3-D Simulation




Top View: Layer 4 (Main Confined Aquifer)

Cross-Section
 Projection Row = 17
 Projection Column = 13

- Pumped Cell
- Constant Head
- Dried Cell
- Flow Vector
- Simulated Groundwater Table
- Equal Line of Simulated Piezometric Surface (masl)

| | |
|---|---|
| Figure 7.4 | Simulated Piezometric Surface in 1996 by Transient Calibration |
| THE STUDY ON GROUNDWATER DEVELOPMENT IN THE RURAL PROVINCES OF NORTHERN PART IN THE SOCIALIST REPUBLIC OF VIETNAM | |
| JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) | |

Future Major Groundwater Well Fields in Hà Nội Area



- Proposed Well Location of Cao Dinh Well Field
- ▲ Proposed Well Location of Yen Phu Well Field

| | Name of Well Fields | Number of Wells | Pumping Rate (m ³ /day) |
|---|----------------------|-----------------|------------------------------------|
| 1 | Cao Dinh | 26 | 97,964 |
| 2 | Yen Phu (additional) | 13 | 60,777 |
| | TOTAL | 39 | 158,741 |

[Data source: NHEGD-DGM (1998)]

- Existing Well Field
- Proposed Well Field
(Symbol size is proportional to its pumpage.)


Figure 7.5

Future Well Fields in Hà Nội Area for Future Prediction (Case-0)

THE STUDY ON GROUNDWATER DEVELOPMENT IN THE RURAL PROVINCES OF NORTHERN PART IN THE SOCIALIST REPUBLIC OF VIETNAM

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

Transient 3-D Simulation (Case-0, after 10 years)



Top View: Layer 4 (Main Confined Aquifer)

Cross-Section
 Projection Row = 17
 Projection Column = 13

- Pumped Cell
- Constant Head
- Dried Cell
- Flow Vector
- Simulated Groundwater Table
- Equal Line of Simulated Piezometric Surface (masl)

Groundwater pumpage for Case-0 is the actual pumpage in 1996 with proposed pumpage in Cao Dinh well field and additional pumpage in Yen Phu well field.

1996 Q = 453,960 m³/day
 Cao Dinh Q = 97,964 m³/day
 Additional Yen Phu Q = 60,777 m³/day

[Data source: NHEGD-DGM(1998)]


Figure 7.6

Simulated Piezometric Surface by Case-0 (after 10 years)

THE STUDY ON GROUNDWATER DEVELOPMENT IN THE RURAL PROVINCES OF NORTHERN PART IN THE SOCIALIST REPUBLIC OF VIETNAM

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

Simulated Piezometric Drawdown (Case-1, after 10 years)



Top View: Layer 4 (Main Confined Aquifer)

Cross-Section
 Projection Row = 9
 Projection Column = 14

- Pumped Cell
- Constant Head
- Dried Cell
- Flow Vector
- Simulated Groundwater Table
- Equal Line of Simulated Piezometric Drawdown (m)

Case-1 Pumping Plan:

Pumpage of Case-0 with following pumpage:
 Đông Ngạc (I=9, J=13) Q = 1,260 m³/day
 Xuân Đỉnh (I=9, J=14) Q = 2,850 m³/day
 Pumping from Layer-4.

Maximum Drawdown = 2.36 m


Figure 7.7

Simulated Piezometric Drawdown by Case-1 (after 10 years)

THE STUDY ON GROUNDWATER DEVELOPMENT IN THE RURAL PROVINCES OF NORTHERN PART IN THE SOCIALIST REPUBLIC OF VIETNAM

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

Simulated Piezometric Drawdown (Case-2, after 10 years)



Top View: Layer 4 (Main Confined Aquifer)

Cross-Section

Projection Row = 9

Projection Column = 14

- Pumped Cell
- Constant Head
- Dried Cell
- Flow Vector
- Simulated Groundwater Table
- Equal Line of Simulated Piezometric Drawdown (m)

Case-2 Pumping Plan:

Pumpage of Case-0 with following pumpage:

Đồng Ngọc (I=9, J=13) Q = 1,890 m³/day

Xuân Định (I=9, J=14) Q = 4,275 m³/day

Pumping from Layer-4.

Maximum Drawdown = 3.54 m


Figure 7.8

**Simulated Piezometric Drawdown
by Case-2 (after 10 years)**

THE STUDY ON GROUNDWATER DEVELOPMENT IN
THE RURAL PROVINCES OF NORTHERN PART IN
THE SOCIALIST REPUBLIC OF VIETNAM

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

Simulated Groundwater Flow and Pathlines (Case-1, after 10 years)



Top View: Layer 4 (Main Confined Aquifer)

- Pathline to Cao Dinh Wells
- Pathline to Dong Ngac and Xuan Dinh Wells

- Pumped Cell
- Constant Head
- Dried Cell
- Flow Vector
- Simulated Groundwater Table
- - - -10 - - - Equal Line of Simulated Piezometric Surface (masl)

Case-1 Pumping Plan:
 Pumpage of Case-0 with following pumpage:
 Dong Ngac (I=9, J=13) $Q = 1,260 \text{ m}^3/\text{day}$
 Xuan Dinh (I=9, J=14) $Q = 2,850 \text{ m}^3/\text{day}$
 Pumping from Layer-4.

Maximum Drawdown = 2.36 m


Figure 7.9

Simulated Groundwater Flow and Pathlines by Case-1 (after 10 years)

THE STUDY ON GROUNDWATER DEVELOPMENT IN
 THE RURAL PROVINCES OF NORTHERN PART IN
 THE SOCIALIST REPUBLIC OF VIETNAM

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

Simulated Groundwater Flow and Pathlines (Case-1, after 10 years)



Top View: Layer 4 (Main Confined Aquifer)

- Pathline to Cao Dinh Wells
- Pathline to Dong Ngac and Xuan Dinh Wells

- Pumped Cell
- Constant Head
- Dried Cell
- Flow Vector

- Simulated Groundwater Table
- 10 — Equal Line of Simulated Piezometric Surface (masl)

Case-1 Pumping Plan:

Pumpage of Case-0 with following pumpage:

Dong Ngac (I=9, J=13) $Q = 1,260 \text{ m}^3/\text{day}$

Xuan Dinh (I=9, J=14) $Q = 2,850 \text{ m}^3/\text{day}$

Pumping from Layer-4.

Maximum Drawdown = 2.36 m

Figure 7.9


Simulated Groundwater Flow and Pathlines by Case-1 (after 10 years)

THE STUDY ON GROUNDWATER DEVELOPMENT IN THE RURAL PROVINCES OF NORTHERN PART IN THE SOCIALIST REPUBLIC OF VIETNAM

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

PART III

MASTER PLAN



PART III MASTER PLAN

CHAPTER 1 MASTER PLAN FRAMEWORK

1.1 Basic Policy for M/P Formulation

The National Program for Rural Water Supply and Environmental Sanitation (NPRWSS, No. 237/1998/QD-TTg) of the Government of Vietnam was formulated with the aim to provide clean and safe water to 80 % of the rural residents by 2005. The M/P was formulated in accordance with this program (priority plan) and incorporates a long term water supply plan for the 20 communes in the five northern provinces of Vietnam.

The majority of the existing water sources in these 20 communes are insanitary, insufficient in quantity, and inconvenient in terms of location and use. In view of these conditions, the master plan proposes the development of alternative water supply sources in order to provide every household with drinking water.

Each of the 20 communes was provided with water supply facilities which they have to operate and maintain on their own. The guidelines adopted for the formulation of plans were such that would make the plans applicable in other regions nationwide. The water supply facilities constructed under this M/P act as a model to promote the plan nationwide.

The following are the specifications for the construction of water supply facilities under the M/P.

1.1.1 Construction, O&M

- Short construction period
- Inexpensive in terms of construction and operation costs
- Easy to operate, manage, and maintain

1.1.2 Water Quality

- Chlorination of water prior to distribution
- Supply constant pressure to distribution pipes and service pipes to prevent the intrusion of contaminants from outside.

1.2 Target Areas and Water Use Conditions

The M/P targets the 20 communes in the five northern provinces of Thai Nguyen, Hanoi, Ninh Binh, Thanh Hoa, and Ha Tinh. The population and area coverage of the target communes are shown in Table 1.1.

Table 1.1 Population & Area Coverage of Target Communes

| Province | Commune | 1998 Population | Area (km ²) |
|-------------|----------------|-----------------|-------------------------|
| Thai Nguyen | Hoa Thuong | 12,800 | 11.7 |
| | Dong Bam | 5,279 | 4.03 |
| | Thinh Duc | 6,236 | 20.0 |
| | Nam Tien | 6,270 | 9.2 |
| Ha Noi | Dong Ngac | 6,900 | 3.62 |
| | Xuan Dinh | 15,774 | 5.57 |
| Ninh Binh | Dong Phong | 10,000 | 7.4 |
| | Quang Son | 7,500 | 25.4 |
| | Yen Thang | 8,530 | 11.7 |
| Thanh Hoa | Vin Loc Town | 5,075 | 0.74 |
| | Vinh Thanh | 5,984 | 3.97 |
| | Dinh Tuong | 6,518 | 6.14 |
| | Thie Hung | 6,750 | 5.45 |
| | Thieu Do | 7,010 | 4.00 |
| | Nong Cong Town | 5,461 | 1.00 |
| | Van thang | 6,664 | 9.16 |
| Ha Tinh | Yen Ho | 5,254 | 7.96 |
| | Trung Le | 3,396 | 3.85 |
| | Bui Xa | 4,313 | 6.49 |
| | Duc Yen | 3,722 | 3.37 |
| Total | | 139,436 | 150.75 |

All 20 communes are without water supply facilities, and residents extract water from shallow wells, deep wells, rivers, ponds, and rainfall for domestic use.

1.3 Target Objectives and Goals

The M/P is formulated targeting the year 2010 and a 90 % diffusion rate. The ultimate objective of the M/P is to provide the residents with a healthy and sanitary living

environment, improve standard of living, and generally promote agricultural production, all these through the provision of clean and safe domestic water.

A water supply plan was formulated for every target commune. Regardless of problems in water quality, most households have wells which when attached with small pumps and installed with pipelines would help attain the pressure required to supply water which is seen to consequently improve living conditions. Even if clean and safe water is provided, the construction of water supply facilities, mainly public faucets, at a distance of 100-200 m would only be used by a few and therefore would not contribute to meeting the desired level of sanitary improvement.

The M/P, therefore, aims to establish a 24 hour water supply service by 2010 and a diffusion rate as shown in the table below.

Table 1.2 Water Supply by Household Connection

| Year | Unit Production (l/c/d) | Diffusion Rate (%) |
|------|-------------------------|--------------------|
| 2002 | 80 | 50 |
| 2005 | 90 | 80 |
| 2010 | 110 | 90 |

1.4 Population Forecast

The present population of every commune was obtained from and confirmed with the Peoples Committee. Population forecast is an essential factor in the formulation of the M/P. With population growth, future land use planning has also become a factor of significance. In particular, city outskirts are forecast to undergo urbanization. Although new town and housing development plans and industrial development plans exist, the existing communes are not obliged to supply water. Consequently, forecasting population growth in these communes would suffice for the formulation of the M/P.

There are various ways of forecasting population. Based on the 1989 national census, the trend for the next 10 years was analyzed by dividing the nation into 8 regions to forecast the high, medium, and low birth rates for every 5 years until 2024 —the results are arranged under April 1999 (see Table 1.3). This study adopts the estimated medium birth rate and forecasts that the present population growth rate of 1.63 % will fall to 0.77 % in 2024. Using this growth rate as a basis, the future population of each commune was forecast (see Table 1.4).

Table 1.3 Growth Rate by Region

| Region | Annual Growth Rate | | | | | |
|----------------------|--------------------|-----------|-----------|-----------|-----------|-----------|
| | 1994-1999 | 1999-2004 | 2004-2009 | 2009-2014 | 2014-2019 | 2019-2024 |
| VARIANT 1 | | | | | | |
| All country | 1.26 | 1.14 | 1.07 | 0.99 | 0.83 | 0.63 |
| 1.Red River Delta | 0.95 | 0.87 | 0.82 | 0.73 | 0.59 | 0.43 |
| 2.Northeast | 1.25 | 1.15 | 1.15 | 1.11 | 0.93 | 0.67 |
| 3.Northwest | 1.39 | 1.28 | 1.32 | 1.35 | 1.18 | 0.88 |
| 4.North Central | 1.46 | 1.28 | 1.22 | 1.18 | 1.05 | 0.85 |
| 5.Central Coast | 1.53 | 1.32 | 1.18 | 1.09 | 0.97 | 0.82 |
| 6.Central Highlands | 2.07 | 1.51 | 1.41 | 1.3 | 1.21 | 1 |
| 7.Southeast | 1.21 | 1.05 | 0.91 | 0.78 | 0.62 | 0.47 |
| 8.Mekong River Delta | 1.26 | 1.26 | 1.22 | 1.09 | 0.86 | 0.61 |
| VARIANT 2 | | | | | | |
| All country | 1.63 | 1.31 | 1.23 | 1.11 | 0.95 | 0.77 |
| 1.Red River Delta | 1.34 | 1.04 | 0.97 | 0.88 | 0.71 | 0.52 |
| 2.Northeast | 1.76 | 1.4 | 1.37 | 1.28 | 1.08 | 0.88 |
| 3.Northwest | 1.93 | 1.6 | 1.63 | 1.49 | 1.32 | 1.06 |
| 4.North Central | 1.91 | 1.55 | 1.44 | 1.29 | 1.16 | 1.02 |
| 5.Central Coast | 1.79 | 1.49 | 1.27 | 1.11 | 1.01 | 0.9 |
| 6.Central Highlands | 1.22 | 1.11 | 1.18 | 1.27 | 1.15 | 0.85 |
| 7.Southeast | 1.49 | 1.22 | 1.07 | 0.92 | 0.74 | 0.55 |
| 8.Mekong River Delta | 1.74 | 1.4 | 1.37 | 1.23 | 1.02 | 0.82 |
| VARIANT 3 | | | | | | |
| All country | 1.76 | 1.57 | 1.41 | 1.22 | 1 | 0.79 |
| 1.Red River Delta | 1.4 | 1.27 | 1.17 | 1.02 | 0.78 | 0.55 |
| 2.Northeast | 1.87 | 1.72 | 1.61 | 1.44 | 1.16 | 0.89 |
| 3.Northwest | 2.14 | 1.91 | 1.74 | 1.53 | 1.32 | 1.06 |
| 4.North Central | 1.89 | 1.72 | 1.57 | 1.46 | 1.28 | 1.1 |
| 5.Central Coast | 1.99 | 1.77 | 1.5 | 1.25 | 1.09 | 0.97 |
| 6.Central Highlands | 2.29 | 2.03 | 1.91 | 1.77 | 1.49 | 1.16 |
| 7.Southeast | 1.58 | 1.34 | 1.13 | 0.93 | 0.73 | 0.52 |
| 8.Mekong River Delta | 1.88 | 1.7 | 1.51 | 1.23 | 0.99 | 0.79 |

Source : POPULATION PROJECTIONS OF VIETNAM, 1994-2024.

GENERAL STATISTICAL OFFICE, PROJECT VIE/97/P14.

Table 1.4 Population Forecast

| Province | Commune | 1998 | 2002 | 2005 | 2010 | 2015 | 2020 | 2025 |
|-------------|---------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | Populatio | Populatio | Populatio | Populatio | Populatio | Populatio | Populatio |
| Thai Nguyen | Hoa Thuong | 12,800 | 13,600 | 14,200 | 15,200 | 16,200 | 17,100 | 17,900 |
| | Dong Bam | 5,279 | 5,600 | 5,900 | 6,400 | 6,800 | 7,200 | 7,500 |
| | Thinh Duc | 6,236 | 6,600 | 6,900 | 7,400 | 7,900 | 8,300 | 8,700 |
| | Nam Tien | 6,270 | 6,700 | 7,000 | 7,500 | 8,000 | 8,400 | 8,800 |
| | Sub total | 30,585 | 32,500 | 34,000 | 36,500 | 38,900 | 41,000 | 42,900 |
| Ha Noi | Dong Ngac | 6,900 | 7,300 | 7,600 | 8,100 | 8,400 | 8,700 | 8,900 |
| | Xuan Dinh | 15,774 | 16,600 | 17,200 | 18,200 | 19,000 | 19,600 | 20,100 |
| | Sub total | 22,674 | 23,900 | 24,700 | 26,300 | 27,400 | 28,300 | 29,000 |
| Ninh Binh | Dong Phong | 10,000 | 10,500 | 10,800 | 11,300 | 11,800 | 12,200 | 12,500 |
| | Quang Son | 7,500 | 7,900 | 8,200 | 8,700 | 9,100 | 9,400 | 9,600 |
| | Yen Thang | 8,530 | 9,000 | 9,300 | 9,800 | 10,200 | 10,500 | 10,800 |
| | Sub total | 26,030 | 27,400 | 28,300 | 29,800 | 31,100 | 32,100 | 32,900 |
| Thanh Hoa | Vinh Loc Town | 5,075 | 5,500 | 5,800 | 6,300 | 6,700 | 7,100 | 7,500 |
| | Vinh Thanh | 5,984 | 6,400 | 6,700 | 7,200 | 7,700 | 8,100 | 8,500 |
| | Dinh Tuong | 6,518 | 6,900 | 7,200 | 7,700 | 8,200 | 8,700 | 9,200 |
| | Thieu Hung | 6,750 | 7,200 | 7,500 | 8,000 | 8,500 | 9,000 | 9,500 |
| | Thieu Do | 7,010 | 7,500 | 7,800 | 8,300 | 8,800 | 9,300 | 9,800 |
| | Nong Cong Tow | 5,461 | 5,900 | 6,200 | 6,700 | 7,100 | 7,500 | 7,900 |
| | Van Thang | 6,664 | 7,100 | 7,400 | 7,900 | 8,400 | 8,900 | 9,400 |
| | Sub total | 43,462 | 46,500 | 48,600 | 52,100 | 55,400 | 58,600 | 61,800 |
| Ha Tinh | Yen Ho | 5,254 | 5,600 | 5,900 | 6,400 | 6,800 | 7,200 | 7,600 |
| | Trung Le | 3,396 | 3,700 | 4,000 | 4,500 | 4,800 | 5,100 | 5,400 |
| | Bui Xa | 4,313 | 4,700 | 5,000 | 5,500 | 5,900 | 6,200 | 6,500 |
| | Duc Yen | 3,722 | 4,100 | 4,400 | 4,900 | 5,200 | 5,500 | 5,800 |
| | Sub total | 16,685 | 18,100 | 19,300 | 21,300 | 22,700 | 24,000 | 25,300 |
| Total | | 139,436 | 148,400 | 154,900 | 166,000 | 175,500 | 184,000 | 191,900 |

Source : JICA Study Team

1.5 Water Demand Forecast

1.5.1 Water Use Classification

Water use in the study area is classified as follows:

(1) Domestic Use

Refers to the use of water for household chores such as drinking, cooking, laundry, bathing, etc.

(2) Non-domestic Use

For water supply in rural villages, the following demands for water may be considered for non-domestic use:

- Use in schools
- Amount of water used by offices and small restaurants in shopping districts
- Other use
- Fire extinguishing activities

1.5.2 Water Use Conditions in the Communes

The results of the questionnaire survey on actual water use conditions in the 20 communes are compiled in Table 1.5.

The daily water consumption per household totaled 400 to 500 liters: 32 to 34 liters for cooking, 116 to 134 liters for laundry, 118 to 158 liters for bathing, 60 to 70 liters for livestock raising, and 100 to 109 liters for miscellaneous use.

Considering that a household consumes 12 to 15 m³ of water per month, water shortage is not a problem in the communes. The problem lies in the quality of the water produced, e.g. unpleasant odor and color due to iron content, and the sanitary problems that this water condition generates.

Table 1.5. Present Average Water Usage in Dry Season. (Household Survey)

| Province | Commune | Cooking | | Laundry | | Shower/Bath | | Cooking+ Laundry+ | | Livestock | | Other | | Total | |
|-------------|---------------|------------------------------|----|------------------------------|-----|------------------------------|-----|------------------------------|-----|------------------------------|-----|------------------------------|-----|------------------------------|---|
| | | Number of /house/da Anser | y | Number of /house/da Anser | y | Number of /house/da Anser | y | Number of /house/da Anser | y | Number of /house/da Anser | y | Number of /house/da Anser | y | Number of /house/da Anser | y |
| Thai Nguyen | Dong Bam | 5 | 25 | 5 | 161 | 5 | 156 | 342 | 4 | 156 | 4 | 163 | 5 | 661 | |
| | Hoa Thuong | 21 | 49 | 21 | 81 | 21 | 75 | 205 | 14 | 38 | 13 | 42 | 21 | 285 | |
| | Nam Tien | 23 | 39 | 23 | 129 | 22 | 134 | 302 | 22 | 73 | 16 | 117 | 23 | 491 | |
| | Thinh Duc | 5 | 23 | 5 | 59 | 5 | 41 | 123 | 3 | 22 | 5 | 60 | 5 | 205 | |
| | Average | 54 | 40 | 54 | 107 | 53 | 104 | 251 | 43 | 66 | 38 | 89 | 54 | 400 | |
| Hanoi | Xuan Dinh | 51 | 57 | 50 | 126 | 50 | 112 | 296 | 33 | 67 | 37 | 81 | 51 | 444 | |
| | Dong Ngac | 81 | 12 | 81 | 145 | 80 | 127 | 285 | 62 | 51 | 81 | 132 | 81 | 468 | |
| | Average | 132 | 30 | 131 | 138 | 130 | 122 | 289 | 95 | 56 | 118 | 116 | 132 | 458 | |
| Ninh Binh | Quang Son | 29 | 37 | 29 | 152 | 29 | 152 | 342 | 21 | 56 | 17 | 95 | 29 | 494 | |
| | Yen Thang | 40 | 33 | 40 | 94 | 40 | 142 | 269 | 39 | 129 | 21 | 89 | 40 | 487 | |
| | Dong Phong | 34 | 25 | 34 | 86 | 34 | 86 | 197 | 31 | 38 | 16 | 100 | 34 | 335 | |
| | Average | 103 | 31 | 103 | 108 | 103 | 127 | 266 | 91 | 81 | 54 | 94 | 103 | 335 | |
| | Nong Con Town | 20 | 24 | 20 | 93 | 19 | 105 | 222 | 18 | 60 | 14 | 85 | 20 | 367 | |
| Thanh Hoa | Van Thanh | 22 | 30 | 21 | 115 | 22 | 114 | 259 | 22 | 51 | 20 | 67 | 22 | 377 | |
| | Thieu Hung | 35 | 24 | 35 | 105 | 34 | 127 | 256 | 34 | 66 | 25 | 76 | 35 | 397 | |
| | Thieu Do | 27 | 60 | 23 | 126 | 25 | 139 | 325 | 27 | 95 | 22 | 231 | 27 | 651 | |
| | Dinh Tuong | 24 | 32 | 24 | 100 | 24 | 110 | 242 | 24 | 59 | 24 | 57 | 24 | 358 | |
| | Vin Loc Town | 13 | 61 | 12 | 118 | 12 | 109 | 288 | 10 | 106 | 6 | 77 | 13 | 470 | |
| Ha Tinh | Vinh Thanh | 29 | 66 | 29 | 77 | 29 | 79 | 222 | 25 | 61 | 5 | 78 | 29 | 361 | |
| | Average | 170 | 42 | 164 | 103 | 165 | 112 | 257 | 160 | 69 | 116 | 101 | 170 | 425 | |
| | Duc Yen | 26 | 35 | 26 | 145 | 26 | 166 | 346 | 25 | 111 | 21 | 156 | 26 | 613 | |
| | Yen Ho | 26 | 19 | 26 | 143 | 25 | 121 | 283 | 26 | 50 | 26 | 74 | 26 | 406 | |
| | Bui Xa | 22 | 30 | 21 | 94 | 21 | 95 | 219 | 19 | 40 | 19 | 40 | 22 | 298 | |
| Average(2) | Trung Le | 16 | 11 | 16 | 106 | 14 | 80 | 197 | 15 | 37 | 11 | 51 | 16 | 285 | |
| | Average | 90 | 25 | 89 | 125 | 86 | 121 | 272 | 85 | 63 | 77 | 85 | 90 | 418 | |
| | Average(2) | 549 | 34 | 541 | 116 | 537 | 118 | 268 | 474 | 67 | 403 | 100 | 549 | 436 | |

Source : JICA Study Team

1.5.3 Unit Water Demand

(1) Domestic Water Use

The estimation of the domestic water demand is extremely significant to the formulation of the water supply facility construction plan. Although looking at past figures would be most favorable for the estimation, only a few of the rural villages are connected to the distribution net (pipelines) and this would not reflect the actual demand but only the distribution amount. The results of the previously mentioned questionnaire survey were used therefore to estimate the water demand.

The construction of a water supply system in the communes would enable the provision of safe tap water for cooking, laundry and bathing, while the present source would be used for livestock raising and other miscellaneous use. The amount that will be converted into tap water is estimated to total 60 to 70 *l/c/d*.

The design standards adopted in Vietnam indicate the temporal changes in the water supply service level as shown in the table below. As shown in the table, water consumption in the communes currently amounts to 60 to 70 *l/c/d*. It is assumed, however, that a water demand of 80 *l/c/d* will result from the water supply operation in consideration of the convenience this would provide the residents.

Assuming that the increase is in proportion to economic growth, the unit water demand 10 years after is estimated at 120 *l/c/d*. No increase is expected after this period as the water supply system will be used to provide a truly clean and safe drinking water, and the old well for sprinkling, livestock raising etc. Water to be provided from public faucets is estimated at 50 *l/c/d*.

Table 1.6 Temporal Changes in Water Service Level

| Urban Level | Design Standard | | | |
|-------------|--------------------------|---------------------------------------|--------------------------|---------------------------------------|
| | 10 years from completion | | 20 years from completion | |
| | Coverage (%) | Unit Water Demand (<i>l/c/d</i>) | Coverage (%) | Unit Water Demand (<i>l/c/d</i>) |
| I | 75~90 | 130~150 | 85~90 | 160~180 |
| II | 75~85 | 110~130 | 80~90 | 140~150 |
| III, IV, V | 70~80 | 80~100 | 80~90 | 120~130 |

Source: Quy Chuan Xay Dung Viet Nam Tap 1. Nha Xuat Ban Xay Dung, 1997.
This was carried out in levels III, IV, and V.

From the above, the water supply unit water demand is set as shown below.

Table 1.7 Per Capita Water Demand Forecast

| Year | 2002 | 2005 | 2010 |
|--------------------------|------|------|------|
| House connection (l/c/d) | 80 | 90 | 110 |
| Public tap (l/c/d) | 50 | 50 | 50 |

(2) Non-domestic Water Use

The unit water demand for non-domestic use is set as shown in the table below, based on past study results.

Table 1.8 Unit Water Demand for Non-domestic Use

| Water Use Category | Unit Water Demand |
|--|------------------------------|
| Schools | 12 l/c/d |
| Small markets, restaurants, offices, shopping center | 6 l/c/d |
| Miscellaneous | 2 % of domestic water amount |

Source: Study on Hanoi Water Supply Systems in the Socialist Republic of Vietnam, JICA

The water demand for fire extinguishing purposes is not as large as estimated beforehand. However, as a huge amount of water will be required temporarily, considerations will be placed on the distribution pond capacity and the diameter of distribution pipelines.

1.5.4 Water Demand Forecast

(1) Forecast Method

Water demand was calculated by multiplying the unit water demand by the service population and the service area.

(2) Service Level

Water supply will be provided for 24 hours through household connections. In areas that are remote or where the population is scattered, the construction of public faucets was considered.

The water supply service level until 2010 is as shown in Table 1.9.

(3) Average Daily Water Demand

The average daily water demand is calculated by adding together the water demand.

$\{\text{average daily water demand}\}5\{\text{domestic water demand}\}1\{\text{water demand for other uses}\}$

(4) Average Daily Supply

Leakage from these new facilities is estimated at 15 %.

$\{\text{average daily supply}\}5\{\text{average daily water demand}\}40.85$

(5) Maximum Daily Supply

$\{\text{maximum daily supply}\}5K3\{\text{average daily supply}\}$

Based on the design standards in Viet Nam, K is set at 1.35.

(6) Maximum Daily Production

$\{\text{maximum daily production}\}5K3\{\text{average daily supply}\}$

K is set at 1.05 with due consideration of the water amount to be treated in the filtering pond.

The forecast water demand in 2002, 2005, and 2001 is shown in Tables 1.10, 1.11, and 1.12, respectively.

Table 1.9 Service Conditions of Water Supply

| | 2002 | | 2003 | | 2004 | | 2005 | | 2006 | | 2007 | | 2008 | | 2009 | | 2010 | |
|---|-------------------|----------------|-------------------|----------------|-------------------|----------------|-------------------|----------------|-------------------|----------------|-------------------|----------------|-------------------|----------------|-------------------|----------------|-------------------|----------------|
| | Unit Water Demand | Population n % | Unit Water Demand | Population n % | Unit Water Demand | Population n % | Unit Water Demand | Population n % | Unit Water Demand | Population n % | Unit Water Demand | Population n % | Unit Water Demand | Population n % | Unit Water Demand | Population n % | Unit Water Demand | Population n % |
| Population Served % | 50 | | 60 | | 70 | | 80 | | 82 | | 84 | | 86 | | 88 | | 90 | |
| Densely Populated Area | 80 | 90 | 84 | 90 | 88 | 90 | 90 | 90 | 96 | 90 | 100 | 90 | 104 | 90 | 108 | 90 | 110 | 90 |
| Sparsely Populated or Separated | 50 | 10 | 50 | 10 | 50 | 10 | 50 | 50 | 50 | 50 | 50 | 10 | 50 | 10 | 50 | 10 | 50 | 10 |
| House Connected Public Tap or House Connected Public Tap or | 80 | 0 | 84 | 0 | 88 | 0 | 90 | 96 | 96 | 5 | 100 | 5 | 104 | 5 | 108 | 5 | 110 | 10 |
| Public Tap or | 50 | 100 | 50 | 100 | 50 | 100 | 50 | 50 | 50 | 95 | 50 | 50 | 50 | 95 | 50 | 95 | 50 | 90 |

Source : JICA Study Team

Table 1.10 Water Demand Forecast in 2002

| Province | Commune | 2002 | | | | | | |
|--------------|----------------|------------|-----------------------------|-------------------|--|--|--|--|
| | | Population | Rate of Population Served % | Population Served | Average Water Demand m ³ /day | Average Daily Supply m ³ /day | Maximum Daily Supply m ³ /day | Maximum Daily Production m ³ /day |
| Thai Nguyen | Hoa Thuong | 13,600 | 50 | 6,800 | 440 | 520 | 700 | 740 |
| | Dong Bam | 5,600 | 50 | 2,800 | 210 | 250 | 340 | 360 |
| | Thinh Duc | 6,600 | 50 | 3,300 | 190 | 220 | 300 | 320 |
| | Nam Tien | 6,700 | 50 | 3,400 | 250 | 290 | 390 | 410 |
| | Sub total | 32,500 | | 16,300 | 1,070 | 1,280 | 1,730 | 1,830 |
| Ha Noi | Đông Ngạc | 7,300 | 50 | 3,700 | 300 | 350 | 470 | 490 |
| | Xuan Dinh | 16,600 | 50 | 8,300 | 670 | 790 | 1,070 | 1,130 |
| | Sub total | 23,900 | | 12,000 | 970 | 1,140 | 1,540 | 1,620 |
| Ninh Binh | Dong Phong | 10,500 | 50 | 5,300 | 410 | 480 | 650 | 680 |
| | Quang Son | 7,900 | 50 | 4,000 | 310 | 360 | 490 | 520 |
| | Yen Thang | 9,000 | 50 | 4,500 | 350 | 410 | 550 | 580 |
| | Sub total | 27,400 | | 13,800 | 1,070 | 1,250 | 1,690 | 1,780 |
| Thanh Hoa | Vinh Loc Town | 5,500 | 50 | 2,800 | 280 | 330 | 450 | 470 |
| | Vinh Thanh | 6,400 | 50 | 3,200 | 250 | 290 | 390 | 410 |
| | Dinh Tuong | 6,900 | 50 | 3,500 | 270 | 320 | 430 | 450 |
| | Thieu Hung | 7,200 | 50 | 3,600 | 280 | 330 | 450 | 470 |
| | Thieu Do | 7,500 | 50 | 3,800 | 290 | 340 | 460 | 480 |
| | Nong Cong Town | 5,900 | 50 | 3,000 | 300 | 350 | 470 | 490 |
| | Van Thang | 7,100 | 50 | 3,600 | 280 | 330 | 450 | 470 |
| | Sub total | 46,500 | | 23,500 | 1,950 | 2,290 | 3,100 | 3,240 |
| Ha Tinh | Yen Ho | 5,600 | 50 | 2,800 | 220 | 260 | 350 | 370 |
| | Trung Le | 3,700 | 50 | 1,900 | 140 | 160 | 220 | 230 |
| | Bui Xa | 4,700 | 50 | 2,400 | 180 | 210 | 280 | 290 |
| | Duc Yen | 4,100 | 50 | 2,100 | 160 | 190 | 260 | 270 |
| | Sub total | 18,100 | | 9,200 | 710 | 820 | 1,110 | 1,160 |
| Total | | 148,400 | | 74,800 | 5,780 | 6,780 | 9,170 | 9,630 |
| l/day/capita | | | | | 77 | 91 | 123 | 129 |

Source : JICA Study Team

Table 1.11 Water Demand Forecast in 2005

| Province | Commune | 2005 | | | | | | |
|--------------|----------------|------------|-----------------------------|-------------------|--|--|--|--|
| | | Population | Rate of Population Served % | Population Served | Average Water Demand m ³ /day | Average Daily Supply m ³ /day | Maximum Daily Supply m ³ /day | Maximum Daily Production m ³ /day |
| Thai Nguyen | Hoa Thuong | 14,200 | 80 | 11,400 | 760 | 890 | 1,200 | 1,260 |
| | Dong Bam | 5,900 | 80 | 4,700 | 380 | 450 | 610 | 640 |
| | Thinh Duc | 6,900 | 80 | 5,500 | 330 | 390 | 530 | 560 |
| | Nam Tien | 7,000 | 80 | 5,600 | 450 | 530 | 720 | 760 |
| | Sub total | 34,000 | | 27,200 | 1,920 | 2,260 | 3,060 | 3,220 |
| Ha Noi | Dong Ngac | 7,600 | 80 | 6,100 | 530 | 620 | 840 | 880 |
| | Xuan Dinh | 17,200 | 80 | 13,800 | 1,210 | 1,420 | 1,920 | 2,020 |
| | Sub total | 24,700 | | 19,900 | 1,740 | 2,040 | 2,760 | 2,900 |
| Ninh Binh | Dong Phong | 10,800 | 80 | 8,600 | 720 | 850 | 1,150 | 1,210 |
| | Quang Son | 8,200 | 80 | 6,600 | 550 | 650 | 880 | 930 |
| | Yen Thang | 9,300 | 80 | 7,400 | 620 | 730 | 990 | 1,040 |
| | Sub total | 28,300 | | 22,600 | 1,900 | 2,230 | 3,020 | 3,180 |
| Thanh Hoa | Vinh Loc Town | 5,800 | 80 | 4,600 | 460 | 540 | 730 | 770 |
| | Vinh Thanh | 6,700 | 80 | 5,400 | 450 | 530 | 720 | 760 |
| | Dinh Tuong | 7,200 | 80 | 5,800 | 490 | 580 | 780 | 820 |
| | Thieu Hung | 7,500 | 80 | 6,000 | 500 | 590 | 800 | 840 |
| | Thieu Do | 7,800 | 80 | 6,200 | 520 | 610 | 820 | 860 |
| | Nong Cong Town | 6,200 | 80 | 5,000 | 500 | 590 | 800 | 840 |
| | Van Thang | 7,400 | 80 | 5,900 | 500 | 590 | 800 | 840 |
| | Sub total | 48,600 | | 38,900 | 3,420 | 4,030 | 5,450 | 5,730 |
| Ha Tinh | Yen Ho | 5,900 | 80 | 4,700 | 400 | 470 | 630 | 660 |
| | Trung Le | 4,000 | 80 | 3,200 | 270 | 320 | 430 | 450 |
| | Bui Xa | 5,000 | 80 | 4,000 | 340 | 400 | 540 | 570 |
| | Duc Yen | 4,400 | 80 | 3,500 | 290 | 340 | 460 | 480 |
| | Sub total | 19,300 | | 15,400 | 1,290 | 1,530 | 2,060 | 2,160 |
| Total | | 154,900 | | 124,000 | 10,280 | 12,090 | 16,350 | 17,190 |
| l/day/capita | | | | | 83 | 98 | 132 | 139 |

Source : JICA Study Team

Table 1.12 Water demand forecast in 2010

| Province | Commune | 2010 | | | | | | |
|-------------|----------------|------------|-----------------------------|-------------------|--|--|--|--|
| | | Population | Rate of Population Served % | Population Served | Average Water Demand m ³ /day | Average Daily Supply m ³ /day | Maximum Daily Supply m ³ /day | Maximum Daily Production m ³ /day |
| Thai Nguyen | Hoa Thuong | 15,200 | 90 | 13,700 | 1,030 | 1,210 | 1,630 | 1,720 |
| | Dong Bam | 6,400 | 90 | 5,800 | 550 | 650 | 880 | 930 |
| | Thinh Duc | 7,400 | 90 | 6,700 | 440 | 520 | 700 | 740 |
| | Nam Tien | 7,500 | 90 | 6,800 | 640 | 750 | 1,010 | 1,060 |
| | Sub total | 36,500 | | 33,000 | 2,650 | 3,130 | 4,220 | 4,450 |
| Ha Noi | Dong Ngac | 8,100 | 90 | 7,300 | 760 | 890 | 1,200 | 1,260 |
| | Xuan Dinh | 18,200 | 90 | 16,400 | 1,710 | 2,010 | 2,710 | 2,850 |
| | Sub total | 26,300 | | 23,700 | 2,470 | 2,900 | 3,910 | 4,110 |
| Ninh Binh | Dong Phong | 11,300 | 90 | 10,200 | 1,010 | 1,190 | 1,610 | 1,690 |
| | Quang Son | 8,700 | 90 | 7,800 | 770 | 910 | 1,230 | 1,290 |
| | Yen Thang | 9,800 | 90 | 8,800 | 870 | 1,020 | 1,380 | 1,450 |
| | Sub total | 29,800 | | 26,800 | 2,660 | 3,120 | 4,220 | 4,430 |
| Thanh Hoa | Vinh Loc Town | 6,300 | 90 | 5,700 | 650 | 760 | 1,030 | 1,080 |
| | Vinh Thanh | 7,200 | 90 | 6,500 | 640 | 750 | 1,010 | 1,060 |
| | Dinh Tuong | 7,700 | 90 | 6,900 | 680 | 800 | 1,080 | 1,140 |
| | Thieu Hung | 8,000 | 90 | 7,200 | 710 | 840 | 1,130 | 1,190 |
| | Thieu Do | 8,300 | 90 | 7,500 | 740 | 870 | 1,170 | 1,230 |
| | Nong Cong Town | 6,700 | 90 | 6,000 | 680 | 800 | 1,080 | 1,140 |
| | Van Thang | 7,900 | 90 | 7,100 | 700 | 820 | 1,110 | 1,170 |
| | Sub total | 52,100 | | 46,900 | 4,830 | 5,640 | 7,610 | 8,010 |
| Ha Tinh | Yen Ho | 6,400 | 90 | 5,800 | 580 | 680 | 920 | 970 |
| | Trung Le | 4,500 | 90 | 4,100 | 410 | 480 | 650 | 680 |
| | Bui Xa | 5,500 | 90 | 5,000 | 500 | 590 | 800 | 840 |
| | Duc Yen | 4,900 | 90 | 4,400 | 440 | 520 | 700 | 740 |
| | Sub total | 21,300 | | 19,300 | 1,910 | 2,270 | 3,070 | 3,230 |
| Total | | 166,000 | | 149,700 | 14,520 | 17,060 | 23,030 | 24,230 |
| /day/capita | | | | | 97 | 114 | 154 | 162 |

Source : JICA Study Team

1.6 Water Source

1.6.1 Priority Water Sources

Groundwater is the water source exploited in this study, and since shallow wells are frequently contaminated, deep wells are developed. In the 4 communes in Ha Tinh, river water was exploited as the use of water from deep wells is deemed impossible based on the study results.

1.6.2 Water Quality

The results indicate that samples from a number of wells contain total dissolved solids, sodium ion, and chloride ion exceeding the levels specified for drinking water. Although none of these properties are toxic, high concentrations lead to unpleasant taste that make the water unsuitable for drinking. To use these wells, there is a need to dilute the water. Except for these properties, other items analyzed met the standards for drinking water.

1.6.3 Target Water Quality Treatment

There are several water quality guidelines in Vietnam. This study adopts those for drinking water and domestic water (Quy định 505/BYT/QĐ ngày 13-4-1992). Comparing the well water quality analysis results with the guidelines showed problems in iron and manganese levels. The removal of these substances would depend on their concentration and other organisms that depend on these substances for survival. Aeration sand filter, the most common method used in Viet Nam, was adopted in this study. Biological treatment by the use of bacteria is also considered a possible removal means.

1.7 Water Supply Facility Design

The fundamental issues regarding the water supply facility construction plan for rural villages are as detailed hereafter.

1.7.1 Water Supply System

Uncontaminated groundwater is the target water supply source. The supply of water by gravity after chlorination is the most desired supply system. However, there are only a few areas that are topographically suited to the development of this system. The most commonly

developed system is one which consists of treatment facilities, supply and distribution pumps. Regardless of the nature of the facility construction plan, the following conditions must be met to use pipelines for water distribution.

- Chlorination of water prior to distribution
- Supply constant pressure to distribution pipes and service pipes to prevent the intrusion of contaminants from outside.

The water supply facility plan was prepared intending to provide 24 hour services, ease in facility operation and maintenance, and inexpensive service expenses.

1.7.2 Water Source

The number of deep wells to be developed is decided in accordance with the target water supply amount; no reserves were constructed. Submersible motor pumps were used (see Chapter 2 for the target deep well pumpage for every commune established based on the test boring results).

1.7.3 Treatment Facilities

Treatment facilities were established for the removal of iron and manganese in the water. Although there are various removal methods, the water quality analysis results indicate the suitability of the use of aeration sand filter (the most commonly used in Viet Nam) or biological treatment. If iron and manganese levels are high, chlorination will be adopted.

Since water quality analysis was only carried out once and not all the required wells have been drilled, the treatment method has not been concluded. The issue of whether to adopt biological or chemical treatment will all depend on the problems that may arise in the operation of the facilities; either method of treatment is applicable to similar facilities. The M/P basically proposes the adoption of biological treatment.

1.7.4 Distribution and Service Pipelines

The distribution facilities consist of a distribution pond and pipelines. The distribution pond will have the capacity to provide 8 hours worth of the daily average water supply. Distribution will be carried out by gravity in consideration of a stable supply and to exploit topographic conditions. In addition, the construction of an elevated tank is also considered in view of the topography and water supply conditions.

The water supply pipelines will be installed at the expense of the beneficiaries. Pipelines are a problematic aspect of the water supply system, particularly because leakage usually originates from these pipes. The standards adopted for pipeline installation and the pipeline operation and maintenance affect future service operations, and would therefore requires careful consideration in the implementation stage.

1.7.5 Power Source

The power required for the well pump and distribution pumps will be acquired from the public electric company. Private generators usually handy in case of emergency will not be provided as the gravity distribution system is considered partially advantageous in times like this.

1.7.6 Public Taps

Basically, water will be supplied to every household (household connection), hence public taps will be installed in restricted confines such as markets, etc. Majority of the target communes consist of several densely populated hamlets. Public taps will also be considered in areas where the population is scattered or in remote areas where the set up of household connections is not possible.

1.7.7 Meter

Meters will be installed to monitor water demand. Measurements and recording of water consumption allows administrative analysis that not only contributes to the stabilization of the services, but also enables accurate technical analysis. The use of meters will not be limited to gauge household consumption, but also to gauge distribution volume, and other factors that would necessitate its installation.

1.7.8 Fire Hydrants

Fire hydrants will be installed in accordance with the standards in force in Vietnam.