



STATION NO.	0	187	250
TOTAL DISTANCE (M)	0	187	250
PARTIAL DISTANCE (M)	0	187	250
GROUND ELEVATION (M)	34.0	35.0	
INVERT ELEVATION (M)	35.4	35.4	




STATION NO.	250	303	500
TOTAL DISTANCE (M)		6060	
PARTIAL DISTANCE (M)		2320	
GROUND ELEVATION (M)		35.0	
INVERT ELEVATION (M)		35.4	




CROSS SECTION S=1/50


Figure-5.2 (1/3) Profile of Bypass Box Culvert



STATION NO.	500	570	668	750
TOTAL DISTANCE (M)		11400	11360	
PARTIAL DISTANCE (M)		5340	1980	
GROUND ELEVATION (M)		35.0	40.0	
INVERT ELEVATION (M)		37.8	40.4	




STATION NO.	750	813+10	1000
TOTAL DISTANCE (M)		16770	
PARTIAL DISTANCE (M)		2910	
GROUND ELEVATION (M)		40.0	
INVERT ELEVATION (M)		40.4	




CROSS SECTION S=1/50

Figure-5.2 (2/3) Profile of Bypass Box Culvert



STATION NO.	1000	1024	1195	1250
TOTAL DISTANCE (M)		20480	21970	
PARTIAL DISTANCE (M)		4210	1440	
GROUND ELEVATION (M)		45.0	45.0	
INVERT ELEVATION (M)		45.4	45.9	



STATION NO.	1250	1382	1386
TOTAL DISTANCE (M)		27840	27770
PARTIAL DISTANCE (M)		3720	90
GROUND ELEVATION (M)		55.0	61.0
INVERT ELEVATION (M)		55.9	61.0




Figure-5.2 (3/3) Profile of Bypass Box Culvert

CHAPTER 6 CONSTRUCTION PLAN

6.1 Outline of Diversion Works

There are, in general, three methods of temporary diversion works, namely 1) Diversion flowing in half of a river section, 2) Tunnel diversion and 3) Open channel diversion. The first method, diversion flowing half of river section was adopted in this plan, taking into account of 200 m³/s of design discharge (2-year return period) and topographic feature of the dam site. In following view points, type of diversion works is designed as half cofferdam + open channel.

- 1) Dimension of the diversion tunnel is 8.4m in diameter and 600m in total length adopting standard horseshoe shaped section. It is difficult to apply the diversion tunnel above in view points of construction cost, construction period and safe construction work.
- 2) Considering the topographical characteristics that the river is winding with 50m width of the river floor while 150m width of the valley, method of half cofferdam + diversion channel will be adopted. Dimension of the diversion tunnel is 1:1.0 in slope gradient and 15m in width of the channel base. Considering the method of concrete placing for the dam body, the diversion channel should be constructed by excavating the river terrace deposits.

Procedure of the diversion works is shown below. Outline of the procedure is shown in Figure-6.1 and Figure-6.2. Color of the figures are; red - excavation, yellow - banking of cofferdam, green - concrete placing of dam body, light blue - river flow.

Step-1: Considering the hauling route for concrete aggregate and the necessary area for placing construction facilities, concrete batching plant should be placed in the left bank, and dam body construction also should be commenced from the left bank side. Consequently the diversion channel should be constructed in the right bank side as right as possible. A tributary course joining the main river at the just below the dam body from the right bank side should be shifted to the down-stream area for the effective construction works. Mucks from the excavation of the diversion channel should be used for the cofferdam construction along the upstream and the down stream of the dam body.

Step-2: After the river flow is transferred into the diversion channel along the right bank side, the excavation on the right bank side and concrete placing of the dam body should be commenced.

Step-3: Diversion channel will be constructed inside the dam body at the elevation of 20m. The channel will be constructed to shift the river course to the left bank side.

Step-4: After the construction work of the diversion channel inside the dam body in the left bank side, the river flow will be shifted to the left bank side, then the dam construction will be commenced in the right bank side. The diversion channel along the right bank side will be closed at its tip and end. As the shifted river flows through the diversion channel inside the dam body, on the apron and through the channel in the downstream, an temporary training wall is needed along the energy dissipater. The abutment of the right bank side can be excavated in advance as long as it does not obstruct the diversion channel.




Figure-6.1 Diversion Works (Plane)




Figure-6.2 Diversion Works (Longitudinal Section of Dam Axis, Upstream)

6.2 Design of Diversion Works

(1) Design Condition

Design discharge = 200m³/s (2-year return period)

Channel bed slope = 1/1000

Channel bed elevation = EL. 20m

Coefficient of roughness = 0.022 (open channel on soil, strait, uniform section)

Slope gradient = 1:1.0

(2) Design of Open Channel

Necessary water depth is calculated by uniform flow calculation assuming that width of the channel is 15m referring to the actual river width.

$$Q = A \times V = (1/n) \times A \times R^{(2/3)} \times I^{0.5}$$

where

Q	:	design discharge (m ³ /s)
A	:	flow area (m ²)
V	:	velocity (m/s)
n	:	coefficient of roughness
R	:	hydraulic mean depth (m)
I	:	channel bed slope

If water depth h = 3.8m, then A = 71.44m², R = 2.77m

$$Q = (1/0.022) \times 71.44 \times 2.77^{(2/3)} \times 0.001^{0.5} = 202.9\text{m}^3/\text{s} > 200\text{m}^3/\text{s} \quad \text{OK}$$

From the result of the calculation, water level is EL.20m+3.8m = EL.23.8m in case of design discharge of 200m³/s. However, water level becomes EL.24.2m inside the channel due to the water level of the river which is calculated as EL.24.2m. Elevation at the top of the slope of the channel is EL.25.2m which was obtained by adding 1m of freeboard as well as the case of the cofferdam.

(3) Design of Diversion Channels in the Dam

During concrete placing of the dam body, the river flow will be shifted to the left bank side, then the river will flow through the diversion channel inside the dam body. The section of the diversion channel will be too large if it is designed as open channel, hence it should be designed as a pipeline. The discharge of the pipeline is given by formula below;

$$Q = A \times V$$

$$V = ((2gh) / (o + e + fL / 4R))^{0.5}$$

$$f = 8gn^2 / R^{(1/3)}$$

where

Q	:	design discharge (m ³ /s)
A	:	flow area (m ²)
V	:	velocity (m/s)
g	:	gravity acceleration (9.8m ² /s)
h	:	head (m)
o	:	outlet loss
e	:	entrance loss
f	:	coefficient of friction loss
L	:	length of auxiliary fluid way (m)
n	:	coefficient of roughness (concrete = 0.015)
R	:	hydraulic mean depth (m)

Assuming that water level of the downstream is EL.24.2m and the total length the diversion channel inside the dam body is 29m with EL.20m, the relationship between the dimension of the channel section and the upstream water level is as follows;

Table-6.1 Relationship between Dimension of Channel Section and Upstream Water Level

Upstream water level	EL.(m)	33.3	29	27	25.9
Size of channel	W × H (m)	3 × 3	3.5 × 3.5	4 × 4	4.5 × 4.5
Velocity	(m/s)	11.1	8.2	6.3	5
Discharge	(m ³ /s)	100.3	100.3	101	100.2
Number of channel		2	2	2	2

As the diversion channel will be constructed inside the dam body, the maximum size of the channel becomes about 5m (1/3 of the one block of 15m). However, large section of the channel will make plug works difficult, on the other hand small section can not secure the design discharge of 200m³/s unless water level of upstream is made higher or the number of the channels is increased. As the design of the diverse channel gives a great influence to the plan of the construction works, it is considered enough for this study to give only the outline of the diversion channel as shown in Table-6.1.

(4) Height of Cofferdam

Up to step-3 explained above, the channel along the right bank side will be available and the water level of the channel is EL.24.2m. If freeboard for the cofferdam is set as 1m following the CEMIG criteria, the elevation at the cofferdam crest will become EL.25.2m.

Then in step-4, after the channel is shifted to the left bank side, the water level of upstream of the dam body will rise up to higher than EL. 24.2m. Therefore, the height of the cofferdam must be raised corresponding to the water level rising.

If cofferdam is constructed using soil materials, the cofferdam must be made as high as possible because of poor resistance of the soil materials against overflow.

6.3 Construction Plan

Construction Plan of the dam during three years between 2004 and 2006 is shown in Table-6.2.

Table-6.2 Construction Plan of the Dam

Work Item	Construction Amount	2004	2005	2006
Main Dam Works				
1) Temporary Diversion	1 set			
2) Foundation Excavation	380,000 m ³			
3) Grouting	4,800 m			
4) Concrete Placing	260,000 m ³			
5) Discharge Outlet facilities	1 set			
6) Closing Works	1 set			
Construction Facilities/Plant				
1) Site Road	km			
2) Construction Facilities	1 set			
Others				
1) Check Dam	1 set			
2) Low Flow Bypass	1 set			
3) Test of Water Filling	1 set			

CHAPTER 7 ESTIMATION OF CONSTRUCTION QUANTITY

7.1 Vaza Barris Dam

7.1.1 Concrete

(1) Dan Body and Dissipater

1) Dam Body

Section	Distance m	Area m ²	Mean area m ²	Volume m ³	Accumulate m ³
a		10			
b	40	654	332.0	13,280	13,280
c	35	654	654.0	22,890	36,170
d	90	1034	844.0	75,960	112,130
e	40	1034	1,034.0	41,360	153,490
f	75	20	527.0	39,525	193,015
Total				193,015	

2) Footing

Footings of 3m × 3m × 3m are placed on the rock surface in the upstream and the downstream.

$$V = 3\text{m}^3 \times 280\text{m} \times 2 = 15,120 \text{ m}^3$$

3) Apron

$$V = 2\text{m} \times 150\text{m} \times 32\text{m} = 9,600 \text{ m}^3$$

4) Training wall (Dam downstream face)

$$V = 5.6\text{m}^2 \times 45\text{m} \times 2 = 504 \text{ m}^3$$

5) Training wall (Dissipater)

$$V = 27\text{m}^2 \times 32\text{m} \times 2 = 1,728 \text{ m}^3$$

6) Volume decrease of overflow section

$$V = -26\text{m}^2 \times 150\text{m} = -3,900 \text{ m}^3$$

7) Summitry of concrete volume

$$V = 216,067 \text{ m}^3$$

8) Displaced foundation concrete

$$V = 1331\text{m}^2 \times 32\text{m} = 42,592 \text{ m}^3$$

7.1.2 Excavation

Section	Distance m	Area m ²	Mean area m ²	Volume m ³	Accumulate m ³
g		0			
a	12	154	77.0	924	924
b	40	1,600	877.0	35,080	36,004
h	15	1,125	1,362.5	20,438	56,442
c	20	1,125	1,125.0	22,500	78,942
i	78	1,309	1,217.0	94,926	173,868
d	12	2,125	1,717.0	20,604	194,472
e	40	2,125	2,125.0	85,000	279,472
f	75	324	1,224.5	91,838	371,310
j	12	0	162.0	1,944	373,254
Total				373,254	

7.1.3 Grouting

(1) Consolidation Grouting

Section	Distance m	Length of dam base m	Mean length m	Area m ²	Accumulate m ²
a		5			
b	40	34	19.5	780	780
c	35	34	34.0	1,190	1,970
d	90	43	38.5	3,465	5,435
e	40	43	43.0	1,720	7,155
f	75	5	24.0	1,800	8,955
Total				8,955	

Each borehole in 5m × 5m area. Borehole length is 10m depth.
 $L = A/(5 \times 5) \times 10 \text{ m} = 3,582 \text{ m}$

(2) Curtain Grouting

Curtain grouting area = 6825m²
Interval of grout hole = 1.5m
 $L = 6825 / 1.5 = 4450 \text{ m}$

7.1.4 Form

(1) Dam Body

Section	Distance m	Dam height m	Form		
			Joint m ²	Upstream face m ²	Downstream face m ²
J.0		3.0			
J.1	10	11.8	72.3	74.0	98.6
J.2	15	25.0	286.0	276.0	367.7
J.3	15	38.2	653.1	474.0	631.4
J.4	15	38.2	653.1	573.0	763.3
J.5	15	38.2	653.1	573.0	763.3
J.6	15	38.2	653.1	573.0	763.3
J.7	15	40.2	722.1	588.0	783.3
J.8	15	42.2	794.6	618.0	823.2
J.9	15	44.2	870.6	648.0	863.2
J.10	15	46.2	950.2	678.0	903.1
J.11	15	48.2	1,033.2	708.0	943.1
J.12	15	48.2	1,033.2	723.0	963.1
J.13	15	48.2	1,033.2	723.0	963.1
J.14	15	43.2	832.1	685.5	913.1
J.15	15	28.2	360.9	535.5	713.3
J.16	15	29.4	391.3	432.0	575.5
J.17	15	20.6	197.7	375.0	499.5
J.18	15	11.8	72.3	243.0	323.7
J.19	15	3.0		111.0	147.9
Total	280		11,262.1	9,611.0	12,802.7

(2) Training Wall

$A = 567 \text{ m}^2 \times 4 = 2268 \text{ m}^2$

7.2 Check Dam

(1) Concrete

Object	Cross section (m ²)	Width (m)			Volume (m ³)
		Left bank	River bed	Right bank	
Main dam body	236.0	20.0	80.0	20.0	23,600.0
Main dam wing	15.0	26.0	0.0	25.0	765.0
Sub dam body	6.9	3.0	72.0	1.5	512.3
Sub dam wing	6.0	10.0	0.0	7.0	102.0
Total					24,979.3

Object	Cross section (m ²)		Length (m)	Volume (m ³)
	Main dam side	Sub dam side		
Left bank wing wall	20.0	7.0	30.0	405.0
Right bank wing wall	27.0	7.0	60.0	1,020.0
Total				1,425.0

Object	Cross section (m ²)	Length (m)	Volume (m ³)
Spillway	10.0	20.0	200.0

Object	Area (m ²)	Thickness (m)	Volume (m ³)
Apron	2,500.0	0.7	1,750.0

Summitry of concrete volume 28,354.3 m³

(2) Excavation

Object	Area (m ²)	Length (m)	Volume (m ³)
Main dam	958.0	20.0	19,160.0
Sub dam	536.0	3.0	1,608.0
Total			20,768.0

(3) Form

Object	Area (m ²)
Main dam	5,029.0
Sub dam	651.0
Wing wall	1,397.0
Total	7,077.0




Figure-7.1 Section for Calculation

JAPAN INTERNATIONAL COOPERATION AGENCY

**STATE SECRETARIAT OF PLANNING, SCIENCE AND TECHNOLOGY
THE STATE OF SERGIPE, THE FEDERATIVE REPUBLIC OF BRAZIL**

**THE STUDY
ON
WATER RESOURCES DEVELOPMENT
IN THE STATE OF SERGIPE
IN
THE FEDERATIVE REPUBLIC OF BRAZIL**

**FINAL REPORT
SUPPORTING
(VOLUME II)
FEASIBILITY STUDY**

[G] PLAN AND DESIGN OF WATER CONVEYANCE

MARCH 2000

YACHIYO ENGINEERING CO., LTD. (YEC)

**THE STUDY ON WATER RESOURCES DEVELOPMENT
IN THE STATE OF SERGIPE
IN THE FEDERATIVE REPUBLIC OF BRAZIL**

**SUPPORTING REPORT (G)
PLAN AND DESIGN OF WATER CONVEYANCE**

Table of Contents

Table of Contents

List of Tables

List of Figures

	Page
CHAPTER 1 INTRODUCTION.....	G-1
CHAPTER 2 CRITERIA FOR PLAN AND DESIGN.....	G-1
2.1 Planning Criteria.....	G-1
2.1.1 Components Included.....	G-1
2.1.2 Water Pump Station, WPS.....	G-1
2.1.3 Connecting Reservoir.....	G-2
2.1.4 Water Conveyance Pipeline	G-2
2.2 Design Criteria.....	G-3
2.2.1 Codes and Standards	G-3
2.2.2 Units of Measurements	G-3
2.2.3 Method of Design of Facilities.....	G-3
2.2.4 Materials to be Used.....	G-3
2.2.5 Loads to be Considered.....	G-3
2.2.6 Design Parameters and Water Supply Volume.....	G-4
2.2.7 Calculation of Head Loss	G-4
2.2.8 Motor Power of Pumps	G-5
CHAPTER 3 WATER CONVEYANCE PLAN	G-6
3.1 Water Demand	G-6
3.1.1 Population	G-6
3.1.2 Total Required Water Supply Volume.....	G-6
3.2 Water Conveyance Plan.....	G-7
3.2.1 Pipeline Routing.....	G-7
3.2.2 Pump Station, PS.....	G-7
3.2.3 Connecting Reservoir.....	G-9
3.2.4 Other Required Facilities	G-9
CHAPTER 4 DESIGN OF WATER CONVEYANCE FACILITY	G-10
4.1 Water Intake Pump Station	G-10
4.1.1 General	G-10
4.1.2 Design Conditions.....	G-10
4.1.3 Location of WIPS.....	G-10
4.1.4 Design of Water Intake Pump House	G-12

4.1.5	Technical Description of Water Intake Pumps.....	G-12
4.1.6	Method of Operation.....	G-12
4.1.7	Pump Unit Specification.....	G-16
4.2	Connecting Reservoir.....	G-17
4.2.1	General.....	G-17
4.2.2	Design Conditions.....	G-17
4.2.3	Design of Connecting Reservoir.....	G-17
4.2.4	Sequence of Construction and Method of Operation.....	G-19
4.3	Water Lift Pump Station.....	G-19
4.3.1	General.....	G-19
4.3.2	Preliminary Study.....	G-19
4.3.3	Water Lift Pump Station for Piauitinga, WLPS2.....	G-21
4.3.4	Water Lift Pump Station for Agreste, WLPS1.....	G-28
4.4	Piauitinga Water Conveyance Pipeline.....	G-33
4.4.1	Characteristics of Pipeline.....	G-33
4.4.2	Auxiliary Structures.....	G-36
4.5	Agreste Water Conveyance Pipeline.....	G-38
4.5.1	Characteristics of Pipeline.....	G-38
4.5.2	Auxiliary Structures.....	G-40
4.6	Electric Power Supply.....	G-41
4.6.1	Existing Electric Power Supply System.....	G-41
4.6.2	Vaza Barris Substation.....	G-42
4.6.3	Layout Plan.....	G-45
4.6.4	Transmission Line.....	G-45

List of Tables

	Page
Table-3.1	Projected Population of Benefited Area: 1997 – 2020 G-6
Table-3.2	Municipal/Industrial Water Supply in Piauitinga and Agreste Areas..... G-6
Table-4.1	Technical Description G-12
Table-4.2	Summary of Cases for Study G-20
Table-4.3	Result of the Preliminary Study..... G-20
Table-4.4	Investment, Annual Expense and Net Present Value for Piauitinga Pipeline G-20
Table-4.5	Investment, Annual Expense and Net Present Value for Agreste Pipeline..... G-21
Table-4.6	Description of Pump System G-22
Table-4.7	Description of Pump System G-29
Table-4.8	Electric Power Failure in Cajaiba S/S G-42

List of Figures

	Page
Figure-2.1	General Conceptual Sketch of Water Supply System G-1
Figure-3.1	Pipeline Routes G-8
Figure-3.2	Vertical profile of Agreste Pipeline G-9
Figure-3.3	Vertical profile of Piauitinga Pipeline G-9
Figure-4.1	Location of Water Intake Pump Station G-11
Figure-4.2 (1/3)	Water Intake Pump Station G-13
Figure-4.2 (2/3)	Water Intake Pump Station G-14
Figure-4.2 (3/3)	Water Intake Pump Station G-15
Figure-4.3	Vertical profile of Pipeline..... G-16
Figure-4.4	System Curve for Water Intake Pump System G-16
Figure-4.5	Connecting Reservoir G-18
Figure-4.6	Location of Water Lift Pump Station G-23
Figure-4.7	Water Lift Pump Station G-24
Figure-4.8	Vertical Profile of Piauitinga Pipeline in Phase 1 G-25
Figure-4.9	Vertical Profile of Piauitinga Pipeline in Phase 2 G-25
Figure-4.10	System Curve of Piauitinga Pipeline G-26
Figure-4.11	Result of Water Hammer Analysis without Countermeasures G-27
Figure-4.12	Result of Water Hammer Analysis with Countermeasures G-28
Figure-4.13	Vertical Profile of Agreste Pipeline in Phase 1 G-29
Figure-4.14	Vertical Profile of Agreste Pipeline in Phase 2 G-30
Figure-4.15	System Curve of Agreste Pipeline..... G-30
Figure-4.16	Result of Water Hammer Analysis without Countermeasures G-31
Figure-4.17	Result of Water Hammer Analysis with Countermeasures G-32
Figure-4.18	Vertical Profile of Piauitinga Pipeline G-35
Figure-4.19	Surge Tank G-37
Figure-4.20	Vertical Profile of Agreste Pipeline..... G-39
Figure-4.21	Central Control Building G-43

Figure 1 consists of a 3x3 grid of line graphs. Each graph plots the percentage of correct responses (y-axis, 0 to 100) against three conditions (x-axis, labeled 1, 2, and 3). The graphs are organized by group (A, B, C) in rows and conditions (1, 2, 3) in columns. Each graph shows a general upward trend in correct responses across conditions. The lines are labeled with group letters (A, B, C) and condition numbers (1, 2, 3).

Group	Condition	Approx. % Correct
A	1	20
	2	40
	3	60
B	1	30
	2	50
	3	70
C	1	40
	2	60
	3	80

1. *Chlorophyll a* (Chl *a*)

Figure 1 consists of nine scatter plots arranged in a 3x3 grid. Each plot shows the relationship between the 'Number of children' (x-axis) and the 'Number of mothers' (y-axis). The top row shows a positive correlation, the middle row shows a weak correlation, and the bottom row shows a negative correlation. Each plot has a different set of data points, represented by small circles.

the 1990s, the number of people in the world who are under 15 years of age is expected to increase from 1.1 billion to 1.5 billion. The number of people aged 65 and over is expected to increase from 200 million to 400 million. The number of people aged 15 and over is expected to increase from 3.5 billion to 4.5 billion. The number of people aged 15 and over is expected to increase from 3.5 billion to 4.5 billion. The number of people aged 15 and over is expected to increase from 3.5 billion to 4.5 billion.

the 1990s, the number of people in the world who are under 15 years of age is expected to increase from 1.1 billion to 1.5 billion. The number of people aged 65 and over is expected to increase from 250 million to 450 million. The number of people aged 15 and over is expected to increase from 3.5 billion to 4.5 billion. The number of people aged 15 and over is expected to increase from 3.5 billion to 4.5 billion. The number of people aged 15 and over is expected to increase from 3.5 billion to 4.5 billion.

CHAPTER 1 INTRODUCTION

This Supporting Report (G) explains the details of Plan and Design of Water Conveyance Facility included in the Feasibility Study on the Priority Projects in the Master Plan.

CHAPTER 2 CRITERIA FOR PLAN AND DESIGN

2.1 Planning Criteria

2.1.1 Components Included

The components included in the Water Supply Systems are as follows:

- Vaza Barris Dam
- Water Pump Station, WPS
- Conveyance Pipeline
- Water Treatment Station, WTS
- Distribution pipeline
- Distribution network

General conceptual sketch of the system is as shown in Figure-2.1. The facilities shown by thick line in Figure-2.1 are considered as the water conveyance facility included in the Feasibility Study.




Figure-2.1 General Conceptual Sketch of Water Supply System

2.1.2 Water Pump Station, WPS

(1) Criteria for Selection of Location of WPS

Location of PS is selected considering the following points:

- Vicinity of Vaza Barris Dam
- Direct intake from Vaza Barris Reservoir
- Water to be conveyed by pipeline both in the right and left banks of Vaza Barris River, namely Agreste (Itabaiana) and Piauitinga (Lagarto) regions
- Existing electric power supply facility is located in the left bank near Cajaiba village
- No existing access road to construction site for WPS

(2) Criteria for Plan and Design of Pump System

Pump system is designed taking the following items into consideration:

- Length of pipeline
- Suction head
- Total head
- Required discharge capacity of pump and adaptability to fluctuation of discharge volume
- Fluctuation of intake water level
- Siphon effect
- Easy countermeasures against water hammer
- Easy operation and maintenance
- High reliability and redundancy of pump system
- Pump head-discharge curve
- Prevention of cavitation in pump
- Specific speed of pump
- Transmission system for motor to the rotating vane and type of reduction gear
- Occupied installed area of pump

2.1.3 Connecting Reservoir

Connecting reservoir is required if a system with only one pump is not advantageous. Storage capacity of connecting reservoir is determined by the following items:

- Operational condition of pumps
- Frequency and condition of maintenance works of pumps
- Possibility of occurrence of electric power failure and duration of electric power outage

2.1.4 Water Conveyance Pipeline

Diameter of pipeline is determined by life cost of water conveyance system including pump facilities. Concept of annual cost and net present value are introduced for this evaluation.

Pipeline routing is planned based on the following criteria:

- Low life cost
- Easy installation and maintenance works
- Existing pump stations and pipelines
- Location of villages on the way to final destination
- Total length of pipeline as short as possible
- Topographic condition
- Hydraulic gradient in pipeline
- Effect of water hammer
- Thickness of pipes to be designed in accordance with loading conditions
- Auxiliary facility such as valves, drains, etc. where required

2.2 Design Criteria

2.2.1 Codes and Standards

Facilities to be required in the Feasibility Study are designed in accordance with the Codes and Standards published and authorized by federal, regional, state, municipal and/or any other public organizations or authorities in Brazil.

When applicable Codes and Standards are not specified by the related organizations mentioned above, the Codes, Standards and Regulations in Japan are used with some adjustment in accordance with the local conditions in the State of Sergipe.

The following codes and standards are used for the design of water conveyance facilities:

- Brazilian Norms (NBR), Brazilian Association of Technical Norms (ABNT)
- Japan Water Works Association (JWWA)
- Japan Society of Civil Engineers (JSCE)
- Japanese Industrial Standard (JIS)
- American Water Works Association (AWWA)
- American Standard of Testing Materials (ASTM)

2.2.2 Units of Measurements

Units of measurements used in design or specification of materials are in SI/MKS metric system.

2.2.3 Method of Design of Facilities

In principle, allowable stress design method is applied for all structural design of the facilities.

2.2.4 Materials to be Used

All materials to be used for construction of facilities required in the Feasibility Study are in accordance with Brazilian Technical Standards (ABNT) or equivalent Japanese Industrial Standards (JIS) or other internationally accepted standards.

2.2.5 Loads to be Considered

In principle, the following loads are considered in the design of structures in the Water Conveyance Systems:

- Dead Weight
- Live loads including floor loads
- Equipment loads
- Earth pressure
- Groundwater pressure
- Hydrostatic pressure
- Uplift pressure
- Wind loads
- Seismic body force : Not to be considered.
- Hydrodynamic pressure : Not to be considered.

2.2.6 Design Parameters and Water Supply Volume

- Projected population at the target year, P (person): Refer to Table-3.1
- Design daily water supply volume per capita :
 - Urban area $q = 160$ liter/capita/day
 - Large Rural area $q = 120$ liter/capita/day
- Coefficient of daily variation of consumption : $k1 = 1.2$
- Coefficient of hourly variation of consumption : $k2 = 1.5$
- Rate of water loss : $r_L = 0.42$ in 1,998
 $= 0.25$ in 2,020
- Daily maximum water supply volume, Q_{DM} (litter/day)

$$Q_{DM} = \frac{P \times q \times k1}{1 - r_L}$$

- Hourly maximum water supply volume, Q_{HM} (litter/day)

$$Q_{HM} = Q_{DM} \times k2 = \frac{P \times q \times k1 \times k2}{1 - r_L}$$

2.2.7 Calculation of Head Loss

The head loss is the hydraulic head loss such as pipeline friction loss, shape loss and fluid friction loss.

(1) Friction Loss in Pipelines and Open Channels

In principle, Darcy-Weisbach formula can be applied.

$$h_f = f \cdot \frac{L}{D} \cdot \frac{v^2}{2g}$$

- where
- h_f : friction loss in straight pipes (m),
 - f : coefficient of friction loss,
 - L : length of straight pipes around pumps (m),
 - D : diameter of each straight pipe (m),
 - v : velocity in pipes (m/s),
- and
- g : acceleration of gravity (m/s²).

f for pipeline will be calculated by Colebrook-White formula.

$$\frac{1}{\sqrt{f}} = -2 \cdot \log_{10} \left(0.27 \cdot \frac{K}{D} + \frac{2.51}{Re \sqrt{f}} \right)$$

- where
- f : coefficient of friction loss,
 - D : diameter of each straight pipe (m),
- and
- K : equivalent roughness
 New cast iron pipe $K = 0.25$ mm
 Used cast iron pipe $K = 1.00$ mm.

Manning formula is applied to open channel, culvert, siphon, etc.

$$h_f = I \cdot L$$

$$I = \frac{v^2 n^2}{R^{4/3}}$$

where hf : friction loss in open channel, etc. (m),
 I : hydraulic gradient,
 L : length of open channel, etc. (m),
 v : velocity in open channel, etc. (m/s),
 n : coefficient of roughness,
 and R : hydraulic depth (m).

(2) Shape Loss and Fluid Friction Loss

These head loss can be expressed in the following formula:

$$h_f = f \cdot \frac{v^2}{2g}$$

where hf : friction loss (m),
 f : coefficient of head loss,
 v : flow velocity (m/s),
 and g : acceleration of gravity (m/s²).

Coefficient of head loss can be given in various technical references.

2.2.8 Motor Power of Pumps

Motor power of pumps can be given by calculation using the following formula:

$$L = \frac{\rho \cdot g \cdot Q \cdot H \cdot (1 + \alpha)}{\eta_P \cdot \eta_G}$$

where L : Motor power (kW),
 ρ : density of liquid (t/m³),
 g : acceleration of gravity (m/s²),
 Q : discharge capacity of pump (m³/s),
 H : total head (m),
 α : redundancy rate,
 η_P : pump efficiency,
 and η_G : transmission efficiency.

CHAPTER 3 WATER CONVEYANCE PLAN

3.1 Water Demand

3.1.1 Population

Water supply population in the Project areas is in accordance with the Population Projection discussed in the Master Plan Study. Population increase is based on the Strategic scenario proposed by JICA study team.

Table-3.1 Projected Population of Benefited Area: 1997 – 2020

Unit: 1,000 persons

Benefited Area	Census 1996	Projected Population				
		1997	2000	2010	2020	% (*)
Agreste						
Areia Branca	14.0	14.9	22.3	47.1	77.2	7.4
C. do Brito	14.9	15.3	17.7	25.9	36.2	3.8
Itabaiana	72.2	73.8	84.8	123.7	173.2	3.7
Macambira	5.4	5.5	5.9	7.3	9.1	2.2
S. Domingos	8.3	8.5	9.1	11.2	14.1	2.2
Sub-Total	114.8	118.0	139.8	215.2	309.8	4.2
Piauitinga						
Poco Verde	17.6	17.6	17.6	18.5	21.0	0.7
Simao Dias	33.7	34.0	35.1	39.6	46.4	1.3
Lagarto	75.3	76.0	82.8	107.3	139.0	2.6
R. do Dantas	17.8	18.0	18.5	20.6	23.3	1.1
Sub-Total	144.4	145.6	154.0	186.0	229.7	2.0
Grand-Total	259.2	263.6	293.8	401.2	539.5	3.1

Note: * Population Growth Rate between 1996 and 2020

3.1.2 Total Required Water Supply Volume

Total water supply volume required in the Project areas is in accordance with the Population Projection shown in Table-3.1.

Table-3.2 Municipal/Industrial Water Supply in Piauitinga and Agreste Areas

Area Covered By	Agreste Integrated Pipeline System (System 2)		Piauitinga Integrated Pipeline System (System 1)		Total Supply		Total Source*
	(m ³ /day)	(m ³ /s)	(m ³ /day)	(m ³ /s)	(m ³ /day)	(m ³ /s)	(m ³ /s)
Required Water Supply Volume in 2020	74,286	0.860	79,664	0.922	153,950	1.782	2.138
Present Capacity	12,810	0.148	12,130	0.141	24,940	0.289	0.346
PROAGUA Project	22,200	0.257	30,200	0.349	52,400	0.606	0.728
Vaza Barris Dam Project	39,276	0.455	37,334	0.432	76,610	0.887	1.064

Note : Total Source = k1 x Total Supply

3.2 Water Conveyance Plan

3.2.1 Pipeline Routing

(1) Agreste Pipeline

Pipeline is installed, as much as possible, along the existing pathways or tracks and the existing pipelines passing from Ribeira through Cajaiba and Carrilho Villages leading to Itabaiana. Pipeline route is also planned so as to reduce the number of summits (high points) and concave sections (low points) in pipeline. The route and vertical profile of the Agreste pipeline is shown in Figure-3.1 and Figure-3.2, respectively.

(2) Piauitinga Pipeline

Pipeline is installed, as much as possible, along the existing pathways or tracks which run near the construction site of Pump Station and lead toward Jenipapo. From Jenipapo to Lagarto, the pipeline is laid along the existing roads. Jenipapo, Brasilia, Acuvelho and Urubutinga villages are located along the pipeline route. Pipeline route is planned so as to reduce the number of summits (high points) and concave sections (low points) in the pipeline. The route and vertical profile of the Piauitinga pipeline is shown in Figure-3.1 and Figure-3.3, respectively.

3.2.2 Pump Station, PS

(1) Selection of Location of PS

Water Intake pump station is installed facing the Vaza Barris Reservoir near to Vaza Barris Dam in order to pump up water directly from the Reservoir.

Although the Agreste and Piauitinga pipelines run in right and left banks of Vaza Barris River, respectively, the Water Intake Pump Station for both pipelines, WIPS, is located jointly on the right bank of the river due to the following reasons:

- Water Intake Pump Station for Vaza Barris Irrigation Project, WIPSI, is constructed on the right bank to facilitate the water supply to the Irrigation Project Area located on the right bank of Vaza Barris River.
- The pump capacity for WIPSI is much larger than those required for WIPS.
- In the case that the pump station WIPS is constructed separately on the right and left banks of the Vaza Barris reservoir, the cost for construction, operation and maintenance of the pump stations, including the construction of substation for electric power supply for the pumps are much higher than three pump stations constructed at the same place on the right bank.

(2) Type of Pumps

Water intake pump is a vertical flow type to cope with the high suction head of 30m and high fluctuation of seasonal change of 19m in water intake level in the reservoir. Number of the water intake pumps is three for normal operation plus one for stand-by considering the assurance of high reliability and redundancy of pump system and high applicability for fluctuation of water supply volume. Uni-type pump system composed of vertical pumps to cover the whole conveyance system is not recommendable when the high total head of the system, which is caused by geographical difference in intake and discharge water levels and high friction head due to long distance pipeline, will be expected. In order to mitigate the water hammer effect in the system and to make the pump system simple, two types in function of pumps are introduced in each System, namely,

- Water intake pumps composed of vertical pumps
- Water lift pumps composed of horizontal pumps

The above two systems are connected with the connecting reservoir as specified in the proceeding section.




Figure-3.1 Pipeline Routes




Figure-3.2 Vertical profile of Agreste Pipeline




Figure-3.3 Vertical profile of Piauitinga Pipeline

3.2.3 Connecting Reservoir

Volume of connecting reservoir is capable of storage of water to be discharged at least in one hour and half of operation of pumps. This duration of time is determined based on the possible operational condition of pumps and the possibility of occurrence of electric power outage. The electric power outage is expected to occur on average once in every 25 days, and its averaged duration of 1.5 hour at Cajaiba S/S. For details of electric power supply condition, refer to Section 4.6.

3.2.4 Other Required Facilities

The following countermeasures will be provided where required to mitigate the technical problems caused by the long distance and the frequent vertical ups and downs in the pipelines and to make easy maintenance work of pipelines:

- Air release valves
- Level invert tee
- Stop valves
- Surge tanks

CHAPTER 4 DESIGN OF WATER CONVEYANCE FACILITY

4.1 Water Intake Pump Station

4.1.1 General

Piauitinga and Agreste Water conveyance systems are used for domestic and industrial water supply. The construction works are implemented in two phases in each route. Water intake pumps are a vertical type composed of 3 pumps for normal operation and 1 pump for stand-by for each phase. These pumps are used commonly for water supply for both regions.

4.1.2 Design Conditions

(1) Water Intake Level in the Vaza Barris Reservoir

- High Water Level : EL. 52.7 m
- Normal Water Level : EL. 47.5 m
- Low Water Level : EL. 35.2 m
- Sedimentation Surface Level : EL. 28.6 m

(2) Water Intake Volume

- Phase 1 stage : 0.533m³/s
(0.260 for Piauitinga and 0.273 for Agreste)
- Phase 2 stage : 0.533m³/s
(0.260 for Piauitinga and 0.273 for Agreste)
- Total : 1.066m³/s
(0.520 for Piauitinga and 0.546 for Agreste)

4.1.3 Location of WIPS

WIPS is constructed in the Vaza Barris Reservoir at the right bank of the river. The location of WIPS is selected as shown in Figure-4.1 taking the following technical aspects into consideration:

- To avoid the interference with dam construction work
- To secure the lowest water intake level of EL. 28.6m
- To secure smooth water intake from the reservoir
- To intake as much as possible the water from Trairas River Basin




Figure-4.1 Location of Water Intake Pump Station

4.1.4 Design of Water Intake Pump House

Water Intake Pump House is designed as shown in Figure-4.2 considering the following technical points:

- The house is designed as reinforced concrete structure.
- Intake tower is required to assure direct intake from the reservoir by vertical pumps.
Bridge to the House is required for transportation of equipment and materials as well as support for pipelines to the Connecting Reservoirs.
- Floor level is almost 5 meters above H.W.L. so as not to be affected by the waves in the reservoir
Floor level is taken as EL. 57.5m.
- Surface water intake is assured during normal operation
Stop logs are used for surface water intake. Screens are also installed.
- Installation and maintenance of pumps, fittings, accessories, stop logs, screens, etc. are performed by over-head travelling crane.
- Intake tower and spaces for pumps in Phase 2 are constructed in Phase 1 stage.
Pumps in Phase 2 are installed in dry work by closing water intake tower by stop logs.
- Intermediate stage or floor is required to support the shafts of vertical pumps in position.
Intermediate floors at around 10m in height are provided.

4.1.5 Technical Description of Water Intake Pumps

Table-4.1 Technical Description

Pump Name	WIP 1 & 2	
Use	Domestic and Industrial	
Treatment	Raw	
Phase	1	2
Quantity	3 + 1	3 + 1
Total head	41 m	41 m
Actual head	40 m	40 m
Head loss	1 m	1 m
Max. Suction head	30 m	30 m
Discharge	0.533 (0.178)	0.533 (0.178)
Pipeline Dia.	700 mm	700 mm
Pipeline Length	80 m	80 m

Note 1 : Discharge of pumps to be a total discharge with 3 pumps in operation.
Discharge in () to be per one pump
Unit of discharge : m³/s

Note 2 : The pipeline in Phase 2 is constructed beside the pipeline constructed in Phase 1.



Vertical profile and system curve of the system are shown in Figure-4.3 and Figure-4.4.

4.1.6 Method of Operation

The pumps are operated for 24 hours a day.

Water intake pumps are operated automatically in accordance with the discharge water level in the connecting reservoir, which is constructed down stream of water lift pump station. Numbers of pumps in operation at water intake pump station are also selected automatically in accordance with the discharge water level in the connecting reservoir. Water intake pumps are also controlled to stop their operation automatically when the suction water level in the dam reservoir falls down to the Sedimentation Surface Level.

The pumps and pipeline to be constructed in Phase 2 are completely the same as those to be constructed in Phase 1. Total discharge volume in Phase 2 is double volume in Phase 1. The electrical stoppage is expected to occur in every 25 days and its duration is 1.5 hours on average according to the registered record in 1998 and 1999 as shown in 4.6.



EXTERIOR FINISH SCHEDULE		INTERIOR FINISH SCHEDULE	
ROOF	FIBERCEMENT ROOFING CANALETE 49 TYPE OR EQUIVALENT	FLOOR	CONCRETE STEEL TROWEL WITH SILICON PAINT
WALL	PLASTER WITH LATEX PAINT	WALL	PLASTER WITH LATEX PAINT
		COLUMN	SILICON PAINT
		BEAM	DITTO

Figure-4.2(1/3) Water Intake Pump House




Figure-4.2(2/3) Water Intake Pump House




Figure-4.2(3/3) Water Intake Pump House




Figure-4.3 Vertical profile of Pipeline




Figure-4.4 System Curve for Water Intake Pump System

4.1.7 Pump Unit Specification

(1) Pump

- Units : 3 + 1R per one construction phase
- Type : vertical mixed flow
- Discharge : 0.178 m³/s per one pump
- Total head : 41 m

(2) Electric Motor

- Rotation : 1160 rpm
- Voltage : 440V
- Power : 110kW (150 PS)

4.2 Connecting Reservoir

4.2.1 General

Connecting reservoir are required for smooth conveyance of water from WIPS to the Water Lift Pump Stations and for provision of buffer reservoir against troubles in operation of Water Intake Pumps.

4.2.2 Design Conditions

(1) Finished Ground Level

- F.G.L. : EL. 65.0m

(2) Required Storage Capacity

- Phase 1
 $\max(0.260, 0.273) \text{ m}^3/\text{s} \times 60 \text{ min/s} \times 60 \text{ min/hr} \times 1.5 \text{ hr} = 1,500 \text{ m}^3$
- Phase 2
 $\max(0.260, 0.273) \text{ m}^3/\text{s} \times 60 \text{ min/s} \times 60 \text{ min/hr} \times 1.5 \text{ hr} = 1,500 \text{ m}^3$
- Total
 $\max(0.519, 0.546) \text{ m}^3/\text{s} \times 60 \text{ min/s} \times 60 \text{ min/hr} \times 1.5 \text{ hr} = 3,000 \text{ m}^3$

4.2.3 Design of Connecting Reservoir

Connecting Reservoir is designed as shown in Figure-4.5. The reservoir is reinforced concrete reservoir.

Water Level in the Connecting Reservoir is decided as H.W.L. EL. 68.0m and L.W.L. EL. 63.0m based on the finished ground level of EL. 65.0m. The reservoir is divided into two basins, so that the easy maintenance work of one basin during operation is secured without interruption of water supply.

Therefore, the dimensions of one basin of the reservoir are determined as 17.4m(W) x 17.3m(L) x 5.0m(H).

The following facilities are provided in the connecting reservoir.

- Inlet and outlet pipes
- Overflow pit and pipe for emergency overflow
- Drain pit for discharge at maintenance work
- Gate valve with float for water level control in the reservoir
- ventilation pipes






Figure-4.5 Connecting Reservoir

4.2.4 Sequence of Construction and Method of Operation

Connecting Reservoir with the storage capacity of 3,000m³ is required for each Water Conveyance System, namely CR1 for Agreste and CR2 for Piauitinga, after completion of Phase 2 construction work. In Phase 1 construction stage, the Connecting Reservoir CR1 is constructed and is used one basin for Agreste and the other for Piauitinga. In Phase 2, CR2 is constructed for Piauitinga use and CR1 is converted for Agreste use only. The conversion work is managed by combination of valve operation.

4.3 Water Lift Pump Station

4.3.1 General

Water lift pumps are composed of horizontal type pumps suitable for high total head with long distance conveyance. Pumps for Agreste and Piauitinga regions are operated separately with 2 pumps for normal operation and 1 pump for stand-by in each route in each phase. Pumps installed in Phase 1 are used continuously in Phase 2 with higher total head than in Phase 1.

4.3.2 Preliminary Study

(1) Cases for the Study

The preliminary study on the selection of combination of different diameters of pipelines and the associated pumps was elaborated considering the technical requirement for the systems described in 2.1. The result of Piauitinga pipeline is shown in this report. The Agreste pipeline has almost the same result because of the similar vertical profile.

The following three cases of combination of pipes were studied:

CASE-1 : All construction works of the system are finished in Phase 1. Diameter of pipe is 700 mm, which gives the optimum life cost for the system with specified water supply volume, in the whole length of the pipeline. The conveyance of water from the connecting reservoir to Brasilia is by pressure and the rest of pipeline is by gravity. Although the construction works are divided into two phases due to the financial limitation of the Government of Sergipe, this case is also studied for reference.

CASE-2 : Construction works are divided into two phases. Exactly the same system is constructed in each phase, resulting in the parallel operation of two water conveyance systems after the completion of Phase 2. Diameter of pipe is 500 mm and 600 mm in part to decrease the friction head loss in the pipeline, so that the water level in the connecting reservoir at Brasilia is acceptable. The conveyance of water from Brasilia to Lagarto is by gravity as same as in CASE-1.

CASE-3 : Combination of CASE-1 and CASE-2. The pipeline from the connecting reservoir to Brasilia has the diameter of 700 mm and is constructed in Phase 1. This pipeline is used in Phase 2 to convey water supply volume of 2 times greater than in Phase 1. The rest of the pipeline is constructed in each phase with the same diameter, resulting in the parallel operation of two water conveyance systems after the completion of Phase-2 works. Diameters of pipe are 500 mm and 600 mm to reduce the total friction head loss in the pipeline.

Cases for the preliminary study are summarized in Table-4.2.

Table-4.2 Summary of Cases for Study

Case	Phase	Diameter of Pipelines			
		Dam	Brasilia	SE-104	Lagarto
CASE-1	1	1- ϕ 700	1- ϕ 700	1- ϕ 700	
CASE-2	1	1- ϕ 500	1- ϕ 500	1- ϕ 600	
	2	1- ϕ 500	1- ϕ 500	1- ϕ 600	
CASE-3	1	1- ϕ 700	1- ϕ 500	1- ϕ 600	
	2	-	1- ϕ 500	1- ϕ 600	

(2) Result of the Preliminary Study

Investment, Annual Expense and Net Present Value (NPV) are calculated for each case and are summarized as shown in Table-4.3. Details of calculation of annual expense and net present value for each case are shown in Table-4.4 and Table-4.5 for Piauitinga and Agreste, respectively.

Table-4.3 Result of the Preliminary Study

Unit : millions R\$

Case	Investment (R\$ million)				Annual Expense			Net Present Value
	Pipeline	Pump Civil	Pump Equipment	Total	Interest	O & M	Total	
CASE-1	14.86	0.92	3.69	19.47	1.747	1.390	3.137	33.748
CASE-2	17.16	1.02	4.07	22.25	1.997	1.636	3.633	33.417
CASE-3	16.57	0.90	3.80	21.27	1.912	1.548	3.460	32.317

Although CASE-1 gives the lowest construction cost and annual expense, NPV is highest among all cases. This means that CASE-1 is not competitive in the view point of investment. In addition, CASE-1 is not feasible due to financial reason mentioned above. CASE-3 is the most competitive for the investment in spite of its construction cost, annual expense and NPV are higher than in CASE-1.

Table-4.4 Investment, Annual Expense and Net Present Value for Piauitinga Pipeline

Case	Pipeline Route	Flow Volume m ³ /s	Water Elevation m	Highest Elevation m	Geographical difference in Elevation m	Length of Pipeline km	Pipe Dia. m	Head Loss m	Total Head m	Pump Power kW	Investment (R\$ millions)				Annual Expense (R\$ millions)			NPV (R\$ millions)
											Pipe	Pump Civil	Pump Equip	Total	AEc	AEo	Total	
CASE-1	One phase																	
	Vaza Barris - Brasilia	0.519	35.2	195.1	159.9	11.1	0.70	28.6	188.5	399.5	6.47	0.92	3.69	11.08	0.977	1.390	2.367	
	Brasilia - Lagarto	0.519	195.1	158.0	0.0	14.5	0.70	37.1	37.1		8.39	0.00	0.00	8.39	0.770	0.000	0.770	
	Total										14.86	0.92	3.69	19.47	1.747	1.390	3.137	33.748
CASE-2	1st Phase																	
	Vaza Barris - Brasilia	0.260	35.2	202.7	167.5	11.1	0.50	40.9	208.4	221.3	3.53	1.02	2.04	6.59	0.561	0.818	1.379	
	Brasilia - IMP	0.260	202.7	158.6	0.0	10.9	0.50	39.9	39.9		3.46	0.00	0.00	3.46	0.317	0.000	0.317	
	IMP - Lagarto	0.260	158.6	155.0	0.0	3.6	0.60	5.4	5.4		1.59	0.00	0.00	1.59	0.146	0.000	0.146	
	Subtotal										8.58	1.02	2.04	11.64	1.023	0.818	1.841	
	2nd Phase																	
	Vaza Barris - Brasilia	0.260	35.2	202.7	167.5	11.1	0.50	40.9	208.4	221.3	3.53	0.00	2.04	5.57	0.511	0.818	1.329	
	Brasilia - IMP	0.260	202.7	158.6	0.0	10.9	0.50	39.9	39.9		3.46	0.00	0.00	3.46	0.317	0.000	0.317	
	IMP - Lagarto	0.260	158.6	155.0	0.0	3.6	0.60	5.4	5.4		1.59	0.00	0.00	1.59	0.146	0.000	0.146	
	Subtotal										8.58	0.00	2.04	10.62	0.973	0.818	1.791	
	Total										17.16	1.02	4.07	22.25	1.997	1.636	3.633	33.418
CASE-3	1st Phase																	
	Vaza Barris - Brasilia	0.260	35.2	200.2	165.0	11.1	0.70	8.0	173.0	183.7	6.47	0.90	1.69	9.06	0.793	0.737	1.530	
	Vaza Barris - Brasilia	0.228	35.2	200.2	165.0	11.1	0.70	28.6	193.6	180.2	0.00	0.00	0.00	0.00	0.000	0.710	0.710	
	Brasilia - IMP	0.260	200.2	160.4	0.0	10.9	0.50	39.9	39.9		3.46	0.00	0.00	3.46	0.317	0.000	0.317	
	IMP - Lagarto	0.260	160.4	155.0	0.0	3.6	0.60	5.4	5.4		1.59	0.00	0.00	1.59	0.146	0.000	0.146	
	Subtotal										11.52	0.90	1.69	14.11	1.256	0.710	1.966	
	2nd Phase																	
	Vaza Barris - Brasilia	0.291	35.2	200.2	165.0	11.1	0.70	28.6	193.6	230.0	0.00	0.00	2.11	2.11	0.194	0.837	1.031	
	Brasilia - IMP	0.260	200.2	160.4	0.0	10.9	0.50	39.9	39.9		3.46	0.00	0.00	3.46	0.317	0.000	0.317	
	IMP - Lagarto	0.260	160.4	155.0	0.0	3.6	0.60	5.4	5.4		1.59	0.00	0.00	1.59	0.146	0.000	0.146	
	Subtotal										5.05	0.00	2.11	7.16	0.657	0.837	1.494	
	Total										16.57	0.90	3.80	21.27	1.912	1.548	3.460	32.317

Table-4.5 Investment, Annual Expense and Net Present Value for Agreste Pipeline

CASE	Pipeline Route	Flow Volume	Water Elevation	Highest Elevation	Geographical difference in Elevation	Length of Pipeline	Pipe Dia.	Head Loss	Total Head	Pump Power	Investment (R\$ millions)				Annual Expense (R\$ millions)			NPV (R\$ millions)
		m ³ /s	m	m	m	km	m	m	m	kW	Pipe line	Pump Civil	Pump Equip	Total	AEc	AEo	Total	
CASE-1	One phase																	
	Vaza Barris - Ribeira	0.546	35.2	257.8	222.6	8.8	0.70	24.7	247.3	551.4	5.09	1.27	5.09	11.44	0.996	1.734	2.730	
	Ribeira - Itabaiana	0.546	257.8	215.0	0.0	15.2	0.70	42.8	42.8		8.81	0.00	0.00	8.81	0.808	0.000	0.808	
	Total										13.90	1.27	5.09	20.26	1.805	1.734	3.539	38.275
CASE-2	1st Phase																	
	Vaza Barris - Ribeira	0.273	35.2	257.0	221.8	8.8	0.50	35.3	257.1	286.6	2.78	1.32	2.65	6.76	0.564	0.958	1.523	
	Ribeira - IMP	0.273	257.0	228.3	0.0	7.1	0.50	28.7	28.7		2.27	0.00	0.00	2.27	0.207	0.000	0.207	
	IMP - Itabaiana	0.273	228.3	215.0	0.0	8.1	0.60	13.3	13.3		3.55	0.00	0.00	3.55	0.326	0.000	0.326	
	Subtotal										8.60	1.32	2.65	12.58	1.098	0.958	2.056	
	2nd Phase																	
	Vaza Barris - Ribeira	0.273	35.2	257.0	221.8	8.8	0.50	35.3	257.1	286.6	2.78	0.00	2.65	5.43	0.497	0.958	1.455	
	Ribeira - IMP	0.273	257.0	228.3	0.0	7.1	0.50	28.7	28.7		2.27	0.00	0.00	2.27	0.207	0.000	0.207	
	IMP - Itabaiana	0.273	228.3	215.0	0.0	8.1	0.60	13.3	13.3		3.55	0.00	0.00	3.55	0.326	0.000	0.326	
	Subtotal										8.60	0.00	2.65	11.25	1.031	0.958	1.989	
	Total										17.20	1.32	5.30	23.83	2.129	1.916	4.045	37.284
CASE-3	1st Phase																	
	Vaza Barris - Ribeira	0.273	35.2	257.0	221.8	8.8	0.70	6.9	228.7	254.9	5.09	1.23	2.34	8.66	0.743	0.889	1.632	
	Vaza Barris - Ribeira	0.234	35.2	257.0	221.8	8.8	0.70	24.7	246.5	235.5	0.00	0.00	0.00	0.00	0.000	0.829	0.829	
	Ribeira - IMP	0.273	257.0	228.3	0.0	7.1	0.50	28.7	28.7		2.27	0.00	0.00	2.27	0.207	0.000	0.207	
	IMP - Itabaiana	0.273	257.0	215.0	0.0	8.1	0.60	13.3	13.3		3.55	0.00	0.00	3.55	0.326	0.000	0.326	
	Subtotal										10.91	1.23	2.34	14.48	1.277	0.829	2.106	
	2nd Phase																	
	Vaza Barris - Ribeira	0.312	35.2	257.0	221.8	8.8	0.70	24.7	246.5	314.0	0.00	0.00	2.90	2.90	0.265	1.054	1.319	
	Ribeira - IMP	0.273	257.0	228.3	0.0	7.1	0.50	28.7	28.7		2.27	0.00	0.00	2.27	0.207	0.000	0.207	
	IMP - Itabaiana	0.273	257.0	215.0	0.0	8.1	0.60	13.3	13.3		3.55	0.00	0.00	3.55	0.326	0.000	0.326	
	Subtotal										5.82	0.00	2.90	8.72	0.799	1.054	1.853	
	Total										16.72	1.23	5.24	23.19	2.076	1.884	3.959	36.741

4.3.3 Water Lift Pump Station for Piauitinga, WLPS2**(1) Design Conditions**

- 1) Water Intake Level : EL. 68.0m
- 2) Water Discharge Volume
 - Phase 1 : 0.260 m³/s
 - Phase 2 : 0.260 m³/s
 - Total : 0.520 m³/s

(2) Location of WLPS2

WLPS2 is constructed next to the connecting reservoir CR2 as shown in Figure-4.6.

(3) Design of Water Lift Pump House

Water Lift Pump House is designed as shown in Figure-4.7 considering the following technical points:

- The house is designed as reinforced concrete frame with masonry wall.
- Reinforced suction pit is provided for smooth intake of water from the connecting reservoir.
Internal dimension of suction pit is 1.2m(W) x 17.8m(L) x 6.1m(H). H.W.L. is EL. 68.0m as same as in the connecting reservoir and bottom level is EL. 62.5m to secure water flow by gravity from the connecting reservoir.
- Floor level of pump pit is EL. 62.5 m as same as in the suction pit.
- Installation and maintenance of pumps, fittings, accessories, etc. are performed by manual monorail chain block of 2 ton capacity.

(4) Description of the Pump System

Table-4.6 Description of Pump System

Pump Name	Lift 1		
Use	Domestic and industrial		
Treatment	Raw		
Phase	1*	1*	2
Quantity	2 + 1	2 + 1	2 + 1
Total head	140 m	161 m	161 m
Actual head	132 m	132 m	132 m
Head loss	8 m	29 m	29 m
Suction head	2 m	2 m	2 m
Discharge	0.260 (0.130)	0.519 (0.130)	0.519 (0.130)
Pipeline Dia.	700 mm	700 mm	700 mm
Pipeline Length	11.1 km	11.1 km	11.1 km

Note 1 : Discharge of pumps to be total discharge with 2 pumps in operation. Discharge in () to be per one pump. Unit of discharge in m³/s

Note 2 : Pumps installed in Phase 1 stage to be operated with higher total head in Phase 2 stage.

Vertical profiles and system curve of the system is shown in Figure-4.8, Figure-4.9 and Figure-4.10.

(5) Method of Operation

In principle, the pumps are operated for 24 hours a day. Water lift pumps are stopped their operation automatically when the water level in the connecting reservoir is lower than three meters below normal water level in the connecting reservoir. The pipeline constructed in Phase 1 is used in Phase 2 with the flow volume 2 times greater than that in Phase 1, which results in the increase in total head in the system. The pumps installed in Phase 1 are operated continuously in Phase 2 with total head higher than that in Phase 1. The pumps installed in Phase 2 are operated parallel with the pumps installed in Phase 1. The condition of electrical stoppage is the same as for the water intake pumps.







Figure-4.6 Location of Water Lift Pump Station



A-A SECTION 1/100



B-B SECTION 1/100



GROUND FLOOR PLAN 1/100

EXTERIOR FINISH SCHEDULE		INTERIOR FINISH SCHEDULE	
ROOF	FIBERCEMENT ROOFING CANALETE 49 TYPE OR EQUIVALENT	FLOOR	CONCRETE STEEL TROWEL WITH SILICON PAINT
WALL	PLASTER WITH LATEX PAINT	WALL	PLASTER WITH LATEX PAINT
		COLUMN	SILICON PAINT
		BEAM	DITTO
		SUCTION PIT	WATER PROOFING WITH ACRYLIC BASE CRYSTALIZED CEMENT

Figure-4.7 Water Lift Pump House




Figure-4.8 Vertical Profile of Piauitinga Pipeline in Phase 1




Figure-4.9 Vertical Profile of Piauitinga Pipeline in Phase 2




Figure-4.10 System Curve of Piauitinga Pipeline

(6) Water Hammer

In general, water hammer is expected to occur when designing a high head pump, large capacity pump, pump conveying water to a long distance, etc. Water lift pumps have the characteristics most likely to occur water hammering. Water hammer analysis was executed to grasp the occurrence of water hammering in the pump system.

(a) Water Hammer Analysis without Countermeasures

1) Input data

- Pipeline data
 - length : 11,100 m
 - diameter : 700 mm
 - material : ductile cast iron
 - flow rate : 31.2 m³/min
- Pump Data
 - quantity : 4
 - total head : 161 m
 - flow rate : 7.8 m³/min
 - motor : 294 kW
 - GD² : 30kg·m²
 - speed : 1,780 rpm
- Profile of pipeline

Length (m)	Level (EL. m)	Length (m)	Level (EL. m)
0	68	4,000	150
800	122	6,200	185
1,100	70	8,000	165
1,750	135	9,300	170
2,300	140	10,000	185
2,600	123	11,000	185
3,300	150	11,100	200

2) Result of analysis

The result of analysis is shown in Figure-4.11. It is obvious that negative pressure is generated in most of the pipeline and the countermeasures against water hammer are required.




Figure-4.11 Result of Water Hammer Analysis without Countermeasures

(b) Water Hammer Analysis with Countermeasures

1) Countermeasures against water hammer

Through various trial-and-error of water hammer analysis, it was found that the following countermeasures are effective.

- provision of flywheel to the pumps
- one way surge tanks in two locations

2) Input data

- Pipeline data
no change in input data
- Pump Data
no change in input data except for flywheel $GD^2 : 100\text{kg} \cdot \text{m}^2$
- One Way Surge Tank

No.	Head	Section Area (m^2)
1	92	10
2	127	10
- Profile of pipeline
no change in input data

3) Result of analysis

The result of analysis is shown in Figure-4.12. Although still there exists some negative pressure zones, it is judged that the combination of flywheel and one way surge tanks is effective.




Figure-4.12 Result of Water Hammer Analysis with Countermeasures

(c) Countermeasures to be adopted

- flywheel with $GD^2=100\text{kg}\cdot\text{m}^2$
- one way surge tank

No.	Location(m)	W.L.(El., m)	Cross section Area (m^2)	Height(m)
1	3,300	> 160.0	10	> 3.0
2	6,200	> 195.0	10	> 5.0

(7) Pump Specification

(a) Pump

- Units : 2 + 1R
- Type : horizontal
- Discharge : $0.130\text{ m}^3/\text{s}$ per one pump
- Total head : 140 m (Phase 1) and 161 m (Phase 2)
- Flywheel : $100\text{ kg}\cdot\text{m}^2$

(b) Motor

- Rotation : 1,775 rpm
- Voltage : 440 V
- Power : 294 kW (400 PS)

4.3.4 Water Lift Pump Station for Agreste, WLPS1

(1) Design Conditions

- (a) Water Intake Level : EL. 68.0m
- (b) Water Discharge Volume
 - Phase 1 : $0.273\text{ m}^3/\text{s}$

- Phase 2 : 0.273 m³/s
- Total : 0.546 m³/s

(2) Location of WLPS1

WLPS1 is constructed next to the connecting reservoir CR1 as shown in Figure-4.6.

(3) Design of Water Lift Pump House

Water Lift Pump House is designed as same as WLPS2 shown in Figure-4.7.

(4) Description of the Pump System

Table-4.7 Description of Pump System

Pump Name	Lift 2		
Use	Domestic		
Treatment	Raw		
Phase	1*	1*	2
Quantity	2 + 1	2 + 1	2 + 1
Total head	196 m	214 m	214 m
Actual head	189 m	189 m	189 m
Head loss	7 m	25 m	25 m
Suction head	2 m	2 m	2 m
Discharge	0.273 (0.137)	0.546 (0.137)	
Pipeline Dia.	700 mm	700 mm	
Pipeline Length	8.8 km	8.8 km	

Note 1 : Discharge of pumps to be total discharge with 2 pumps in operation.
Discharge in () to be per one pump. Unit of discharge in m³/s

Note 2 : Pumps installed in Phase 1 stage to be operated with higher total head in Phase 2 stage.

Vertical profiles and system curve of the system are shown in Figure-4.13, Figure-4.14 and Figure-4.15.




Figure-4.13 Vertical Profile of Agreste Pipeline in Phase 1




Figure-4.14 Vertical Profile of Agreste Pipeline in Phase 2




Figure-4.15 System Curve of Agreste Pipeline

(5) Method of Operation

Method of operation in the Agreste system is as same as in the Piauitinga system.

(6) Water Hammer

Water hammer analysis was executed to grasp the occurrence of water hammering in the pump system.

(a) Water Hammer Analysis without Countermeasures

1) Input data

– Pipeline data
 length : 8,800 m
 diameter : 700 mm
 material : ductile cast iron
 flow rate : 32.8 m³/min

– Pump Data
 quantity : 4
 total head : 214 m
 flow rate : 8.2 m³/min
 motor : 294 kW
 GD2 : 50kg·m²
 speed : 3,500 rpm

– Profile of pipeline

Length (m)	Level (EL. m)	Length (m)	Level (EL. m)
0	68	4,100	105
450	100	4,500	100
800	60	4,800	50
1,000	100	6,000	180
1,700	60	6,900	180
2,000	90	7,800	80
3,000	75	8,700	235
3,300	40	8,800	257

2) Result of analysis

The result of analysis is shown in Figure-4.16. It is obvious that negative pressure will be occurred some of the pipeline and the countermeasure against water hammer will be required.




Figure-4.16 Result of Water Hammer Analysis without Countermeasures

(b) Water Hammer Analysis with Countermeasures

1) Countermeasures against water hammer

Through various trial-and-error of water hammer analysis, it was found that the following countermeasures are effective.

- one way surge tank in one location

2) Input data

- Pipeline data
no change in input data

- Pump Data
no change in input data

- One Way Surge Tank

No.	Head	Section Area (m ²)
1	120	20

- Profile of pipeline
no change in input data

3) Result of analysis

The result of analysis is shown in Figure-4.17. It was shown that one way surge tank is effective.




Figure-4.17 Result of Water Hammer Analysis with Countermeasures

(c) Countermeasures to be Adopted

- one way surge tank

No.	Location(m)	W.L.(EL. m)	Cross section Area (m ²)	Height(m)
1	6,000	> 188.0	20	> 2.0

(7) Pump Specification

(a) Pump

- Units : 2 + 1R
- Type : horizontal
- Discharge : 0.137 m³/s
- Total head : 196 m (Phase 1) and 214 m (Phase 2)

(b) Motor

- - Rotation : 3,500 rpm
- - Voltage : 440 V
- - Power : 294 kW (400 PS)

4.4 Piauitinga Water Conveyance Pipeline

4.4.1 Characteristics of Pipeline

Characteristics of Pipeline route determined based on the water conveyance plan in CHAPTER 3 are as follows:

(1) Design Conditions

Service Pressure in the Pipeline

- Permissible Service Pressure : 1.58Mpa
- Maximum Service Pressure : 1.58Mpa

(2) Materials

Unless otherwise specified, all pipe materials are ductile cast iron.

Class of Push-on Joint Type pipe is K7 in accordance with the Service pressure in the pipeline.

(3) Length

- ϕ 700 : 10,416 m
- ϕ 600 : 7,783 m per Phase (total length in two phases 15,566 m)
- ϕ 500 : 7,206 m per Phase (total length in two phases 14,412 m)

(4) Ground Elevation

Vertical profile of the pipeline is shown in Figure-4.18.

- Lowest elevation : EL. 60m
- Highest elevation : EL. 190m

(5) Conditions of Ground Surface in Pipeline Route

Type of ground surface and its length is as follows:

- Pasture : 4,324 m
- Bare land : 20,911 m
- Pavement : 80 m
- Over-pass : 90 m

(6) Details of Over-pass

(a) Urubu River Crossing

- 40m of river crossing
- Pipes to be supported by the steel support anchored at each 6m to the side of existing reinforced concrete bridge with span length of approximately 35m

(b) Urubutinga River Crossing

- 6m of river crossing
- Pipes to span over the river without any support from the existing reinforced concrete box culvert with span length of approximately 6m

(c) Machado River Crossing

- 40m of river crossing
- Pipes to be supported by the steel support anchored at each 6m to the side of existing reinforced concrete bridge with span length of approximately 35m

(7) Road Crossings

Major road crossings are as follows:

(a) SE-214

Crossing with SE-214 coming from Itaporanga d'Ajuda at the intersection of road from Jenipapo. Crossing width is 20m.

(b) Brasilia

Crossing with branch road from SE-214 in Brasilia. Crossing width is 30m.

(c) SE-104

Crossing with SE-104 at intersection of road from Brasilia. Crossing width is 10m.

(d) Lagarto Water Treatment Station

Crossing with internal road just before Lagarto Water Treatment Station. Crossing width is 20m.

