


2-3. ILLUMINATION



Rupsa Bridge and Approach Road


Recommended Design Criteria as per CIE publication no.12 (second Edition 1977) for lighting of roads for motorized traffic is as follows :

- L_{av} (Cd/m^2) – Average Luminance = 2
- U_o – Overall Uniformity ≥ 0.4
- U_l – Lengthwise Uniformity ≥ 0.5 & 0.6
- G – Glare mark ≥ 4 & 6
- T_1 (%) – Threshold Increment ≥ 10

3. Summary

3.1 Main Road

Luminaire Type	:	SGS 102/250T
Lamp Type	:	1 * SON-T+ 250W
Lamp Flux	:	32000 lumen
Tilt θ	(T)	5.0 deg
Project Maintenance Factor	:	0.90



Carriageway	:	Single Carriageway
Road Width	(W)	17.50 m
Number of Lanes	:	2
Reflection Table	:	Asphalt CIE C2
Q0 of Table	:	0.07
Installation	:	Opposite
Height	(H)	10.75 m
Spacing	(S)	26.00 m
Overhang	(O)	1.80 m

Luminance

Average	=	3.33 cd/m ²
Minimum	=	2.46 cd/m ²
Maximum	=	4.24 cd/m ²
Minimum/Maximum	=	0.58
Minimum/Average	=	0.74
UI-1 (4.38,-60.00, 1.50)	=	0.88
UI-2 (13.13,-60.00, 1.50)	=	0.88

Glare

TI. (4.38,-51.42, 1.50)	=	8.6 %
G	=	4.1

Surround Ratios

SR-Left	=	0.63
SR-Right	=	0.63

Horizontal Illuminance


Average	=	54.7 lux
Minimum	=	40.6 lux
Maximum	=	71.8 lux
Minimum/Maximum	=	0.57

3.2 Additional Calculations

(II) Luminance Calculations:

Calculation	Type	Unit	Ave	Min	Max	Min/Ave	Min/Max
General	Surface Illuminance	lux	54.0	30.2	71.9	0.56	0.42

1.2 Top Project Overview



A → SGS 102/250T

Scale
1:200

2. Overview of Schemes


The overall maintenance factor used for this project is 0.90.

Code	Luminaire Type	Lamp Type	Power (W)	Flux (lm)
A	SGS 102/250T	1 * SON-T+ 250W	274.0	1 * 32000

	Unit	Scheme 1
Carriageway		Single Carriageway
Road Width	m	17.50
Number of Lanes		2
Reflection Table		Asphalt CIE C2
Q0 of Table		0.07
Luminaire Code		A
Installation		Opposite
Height	m	10.75
Spacing	m	26.00
Overhang	m	1.80
Tilt90	deg	5.0
L ave	cd/m2	3.33
L min	cd/m2	2.46
L max	cd/m2	4.24
L min/max		0.58
L min/ave		0.74
UI-1		0.88
UI-2		0.88
TI	%	8.6
G		4.1
Eh ave	lux	54.7
Eh min	lux	40.6
Eh max	lux	71.8
Eh min/max		0.57
SR-left		0.63
SR-right		0.63

4.4 General: Mountain Plot

Grid : General at Z = 0.00 m
 Calculation : Surface Illuminance (lux)



Average	Minimum	Maximum	Min/Ave	Min/Max	Project maintenance factor
54.0	30.2	71.9	0.56	0.42	0.90

4.7 Main Eh: Textual Table

Grid : Main at Z = 0.00 m
 Calculation : Horizontal Illuminance (lux)

X (m)	0.63	1.88	3.13	4.38	5.63	6.88	8.13	9.38	10.63	11.88	13.13	14.38
Y (m)												
23.40	64	70	72	71	68	64	62	62	65	68	71	72
20.80	57	61	63	62	60	57	55	55	57	60	62	63
18.20	47	50	51	51	49	47	46	46	47	49	51	51
15.60	42	45	45	45	44	43	42	42	43	44	45	45
13.00	41	43	44	44	43	42	42	42	42	43	44	44
10.40	42	45	45	45	44	43	42	42	43	44	45	45
7.80	47	50	51	51	49	47	46	46	47	49	51	51
5.20	57	61	63	62	60	57	55	55	57	60	62	63
2.60	64	70	72	71	68	64	62	62	65	68	71	72
0.00	64	69	68	67	65	64	63	63	64	65	67	68

Continue >

Average
54.7

Min/Ave
0.74

Min/Max
0.57

Project maintenance factor
0.90

< Continue

Grid : Main at Z = 0.00 m
 Calculation : Horizontal Illuminance (lux)

X (m)	15.63	16.88
Y (m)		
23.40	70	64
20.80	61	57
18.20	50	46
15.60	45	42
13.00	43	41
10.40	45	42
7.80	50	46
5.20	61	57
2.60	70	64
0.00	69	64

Average
54.7


Min/Ave
0.74

Min/Max
0.57

Project maintenance factor
0.90

1. Project Description

1.1 3-D Project Overview



2. Overview of Schemes

The overall maintenance factor used for this project is 0.90.



Code	Luminaire Type	Lamp Type	Power (W)	Flux (lm)
A	SGS 102/250T	1 * SON-T+ 250W	274.0	1 * 32000

	Unit	Scheme 1
Carriageway		Single Carriageway
Road Width	m	16.88
Number of Lanes		2
Reflection Table		Asphalt CIE C2
Q0 of Table		0.07
Luminaire Code		A
Installation		Opposite
Height	m	10.75
Spacing	m	26.00
Overhang	m	1.80
Tilt90	deg	5.0
L ave	cd/m2	3.43
L min	cd/m2	2.50
L max	cd/m2	4.31
L min/max		0.58
L min/ave		0.73
UI-1		0.88
UI-2		0.88
TI	%	8.9
G		4.1
Eh ave	lux	56.2
Eh min	lux	41.2
Eh max	lux	73.2
Eh min/max		0.56
SR-left		0.62
SR-right		0.62

3. Summary

3.1 Main Road

Luminaire Type	:	SGS 102/250T
Lamp Type	:	1 * SON-T+ 250W
Lamp Flux	:	32000 lumen
Tilt90	(T)	5.0 deg
Project Maintenance Factor	:	0.90



Carriageway	:	Single Carriageway
Road Width	(W)	16.88 m
Number of Lanes	:	2
Reflection Table	:	Asphalt CIE C2
Q0 of Table	:	0.07
Installation	:	Opposite
Height	(H)	10.75 m
Spacing	(S)	26.00 m
Overhang	(O)	1.80 m

Luminance	
Average	= 3.43 cd/m ²
Minimum	= 2.50 cd/m ²
Maximum	= 4.31 cd/m ²
Minimum/Maximum	= 0.58
Minimum/Average	= 0.73
UI-1 (4.22,-60.00, 1.50)	= 0.88
UI-2 (12.66,-60.00, 1.50)	= 0.88

Glare	
TI (4.22,-51.42, 1.50)	= 8.9 %
G	= 4.1

Surround Ratios	
SR-Left	= 0.62
SR-Right	= 0.62

Horizontal Illuminance	
Average	= 56.2 lux
Minimum	= 41.2 lux
Maximum	= 73.2 lux
Minimum/Maximum	= 0.56


3.2 Additional Calculations

(II) Illuminance Calculations:

Calculation	Type	Unit	Ave	Min	Max	Min/Ave	Min/Max
General	Surface Illuminance	lux	58.9	40.8	73.5	0.69	0.56

4.4 General: Mountain Plot

Grid : General at Z = 0.00 m
 Calculation : Surface Illuminance (lux)



Average	Minimum	Maximum	Min/Ave	Min/Max	Project maintenance factor
58.9	40.8	73.5	0.69	0.56	0.90

4.7 Main Eh: Textual Table

Grid : Main at Z = 0.00 m
 Calculation : Horizontal Illuminance (lux)

X (m)	0.60	1.81	3.01	4.22	5.42	6.63	7.84	9.04	10.25	11.46	12.66	13.87
Y (m)												
23.40	65	71	73	73	71	67	65	65	67	71	73	73>
20.80	58	62	64	64	62	60	58	58	60	62	64	64
18.20	47	51	52	52	51	49	48	48	49	51	52	52
15.60	42	45	46	46	46	44	44	44	44	46	46	46
13.00	41<	44	45	45	45	44	44	44	44	45	45	45
10.40	42	45	46	46	46	44	44	44	44	46	46	46
7.80	47	51	52	52	51	49	48	48	49	51	52	52
5.20	58	62	64	64	62	60	58	58	60	62	64	64
2.60	65	71	73	73	71	67	65	65	67	71	73	73
0.00	65	70	69	69	67	67	66	66	67	67	69	69

Continue >

Average
56.2

Min/Ave
0.73

Min/Max
0.56

Project maintenance factor
0.90

< Continue

Grid : Main at Z = 0.00 m
 Calculation : Horizontal Illuminance (lux)

X (m)	15.07	16.28
Y (m)		
23.40	71	65
20.80	62	58
18.20	51	47
15.60	45	42
13.00	44	41
10.40	45	42
7.80	51	47
5.20	62	58
2.60	71	65
0.00	70	65

Average
56.2


Min/Ave
0.73

Min/Max
0.56

Project maintenance factor
0.90

1. Project Description

1.1 3-D Project Overview



2. Overview of Schemes

The overall maintenance factor used for this project is 0.90.



Code	Luminaire Type	Lamp Type	Power (W)	Flux (lm)
A	SGS 102/250T	1 * SON-T+ 250W	274.0	1 * 32000

	Unit	Scheme 1
Carriageway		Single Carriageway
Road Width	m	29.00
Number of Lanes		2
Reflection Table		Asphalt CIE C2
Q0 of Table		0.07
Luminaire Code		A
Installation		Opposite
Height	m	10.75
Spacing	m	26.00
Overhang	m	1.80
Tilt90	deg	5.0
L ave	cd/m2	2.17
L min	cd/m2	0.98
L max	cd/m2	3.83
L min/max		0.25
L min/ave		0.45
UI-1		0.90
UI-2		0.90
TI	%	8.0
G		3.9
Eh ave	lux	35.5
Eh min	lux	18.6
Eh max	lux	62.1
Eh min/max		0.30
SR-left		0.66
SR-right		0.66

3. Summary

3.1 Main Road

Luminaire Type	:	SGS 102/250T
Lamp Type	:	1 * SON-T+ 250W
Lamp Flux	:	32000 lumen
Tilt90	(T) :	5.0 deg
Project Maintenance Factor	:	0.90



Carriageway	:	Single Carriageway
Road Width	(W) :	29.00 m
Number of Lanes	:	2
Reflection Table	:	Asphalt CIE C2
Q0 of Table	:	0.07
Installation	:	Opposite
Height	(H) :	10.75 m
Spacing	(S) :	26.00 m
Overhang	(O) :	1.80 m

Luminance		
Average	=	2.17 cd/m ²
Minimum	=	0.98 cd/m ²
Maximum	=	3.83 cd/m ²
Minimum/Maximum	=	0.25
Minimum/Average	=	0.45
UI-1 (7.25,-60.00, 1.50)	=	0.90
UI-2 (21.75,-60.00, 1.50)	=	0.90

Horizontal Illuminance		
Average	=	35.5 lux
Minimum	=	18.6 lux
Maximum	=	62.1 lux
Minimum/Maximum	=	0.30

Glare		
TI (7.25,-51.42, 1.50)	=	8.0 %
G	=	3.9

Surround Ratios		
SR-Left	=	0.66
SR-Right	=	0.66


3.2 Additional Calculations

(II) Luminance Calculations:

Calculation	Type	Unit	Ave	Min	Max	Min/Ave	Min/Max
General	Surface Illuminance	lux	37.7	18.5	62.5	0.49	0.30

4.4 General: Mountain Plot

Grid : General at Z = 0.00 m
Calculation : Surface Illuminance (lux)



Average	Minimum	Maximum	Min/Ave	Min/Max	Project maintenance factor
37.7	18.5	62.5	0.49	0.30	0.90

4.7 Main Eh: Textual Table

Grid : Main at Z = 0.00 m
 Calculation : Horizontal Illuminance (lux)

X (m)	0.66	1.98	3.30	4.61	5.93	7.25	8.57	9.89	11.20	12.52	13.84	15.16
Y (m)												
23.40	58	62>	61	57	50	43	36	31	27	25	23	23
20.80	51	54	54	51	45	38	32	28	24	22	21	21
18.20	42	44	44	41	37	32	28	24	21	20	19	19
15.60	37	38	38	36	33	29	26	23	21	20	19	19
13.00	36	37	37	35	32	29	26	23	21	20	19	19
10.40	37	38	38	36	33	29	26	23	21	20	19<	19<
7.80	42	44	44	41	37	32	28	24	21	20	19	19
5.20	51	54	54	51	45	38	32	28	24	22	21	21
2.60	58	62	61	57	50	43	36	31	27	25	23	23
0.00	58	61	57	53	48	42	36	31	27	25	23	23

Continue >

Average
35.5

Min/Ave
0.52

Min/Max
0.30

Project maintenance factor
0.90

< Continue

Grid : Main at Z = 0.00 m
 Calculation : Horizontal Illuminance (lux)

X (m)	16.48	17.80	19.11	20.43	21.75	23.07	24.39	25.70	27.02	28.34
Y (m)										
23.40	25	27	31	36	43	50	57	61	62	58
20.80	22	24	28	32	38	45	51	54	54	51
18.20	20	21	24	28	32	37	41	44	44	42
15.60	20	21	23	26	29	33	36	38	38	37
13.00	20	21	23	26	29	32	35	37	37	36
10.40	20	21	23	26	29	33	36	38	38	37
7.80	20	21	24	28	32	37	41	44	44	42
5.20	22	24	28	32	38	45	51	54	54	51
2.60	25	27	31	36	43	50	57	61	62	58
0.00	25	27	31	36	42	48	53	57	61	58

Average
35.5

Min/Ave
0.52


Min/Max
0.30

Project maintenance factor
0.90

5. Luminaire Details

5.1 Project Luminaires

Luminaire Name : SGS 102/250T
 Lamp name : SON-T+ 250W
 Number of lamps/luminaire : 1
 Lamp flux : 32000 lm
 Ballast : Standard
 Light output ratios
 DLOR : 0.71
 ULOR : 0.00
 TLOR : 0.71
 Luminaire wattage : 274.0 W
 Measurement code : MIR6050000



Rural Area Road and Intersection Lighting

Recommended Design Criteria are as follows :

- L_{av} (Cd/m^2) – Average Luminance = 1
- U_o – Overall Uniformity ≥ 0.4
- U_l – Lengthwise Uniformity ≥ 0.5 & 0.6
- G – Glare mark ≥ 4 & 6
- T_1 (%) – Threshold Increment ≥ 10

2. Overview of Schemes


The overall maintenance factor used for this project is 0.90.

Code	Luminaire Type	Lamp Type	Power (W)	Flux (lm)
B	SGS 102/150T	1 * SON-T+ 150W	168.0	1 * 16500
	Unit	Scheme 1		
Carriageway		Single Carriageway		
Road Width	m	17.50		
Number of Lanes		2		
Reflection Table		Asphalt CIE C2		
Q0 of Table		0.07		
Luminaire Code		B		
Installation		Opposite		
Height	m	10.75		
Spacing	m	26.00		
Overhang	m	1.80		
Tilt90	deg	5.0		
L ave	cd/m2	1.79		
L min	cd/m2	1.18		
L max	cd/m2	2.13		
L min/max		0.55		
L min/ave		0.66		
TI	%	6.8		
G		5.2		
Eh ave	lux	30.5		
Eh min	lux	19.2		
Eh max	lux	38.2		
Eh min/ave		0.63		
SR-left		0.53		
SR-right		0.53		

3. Summary

3.1 Main Road

Luminaire Type	:	SGS 102/150T
Lamp Type	:	1 * SON-T+ 150W
Lamp Flux	:	16500 lumen
Tilt θ	(T)	: 5.0 deg
Project Maintenance Factor	:	0.90



Carriageway	:	Single Carriageway
Road Width	(W)	: 17.50 m
Number of Lanes	:	2
Reflection Table	:	Asphalt CIE C2
Q0 of Table	:	0.07
Installation	:	Opposite
Height	(H)	: 10.75 m
Spacing	(S)	: 26.00 m
Overhang	(O)	: 1.80 m

Luminance	
Average	= 1.79 cd/m ²
Minimum	= 1.18 cd/m ²
Maximum	= 2.13 cd/m ²
Minimum/Maximum	= 0.55
Minimum/Average	= 0.66

Glare	
TI (4.38, -51.42, 1.50)	= 6.8 %
G	= 5.2

Surround Ratios	
SR-Left	= 0.53
SR-Right	= 0.53

Horizontal Illuminance	
Average	= 30.5 lux
Minimum	= 19.2 lux
Maximum	= 38.2 lux
Minimum/Average	= 0.63

3.2 Additional Calculations


(I) Illuminance Calculations:

Calculation	Type	Unit	Ave	Min	Max	Min/Ave	Min/Max
General	Surface Illuminance	lux	28.8	13.1	38.4	0.45	0.34

5. Luminaire Details

5.1 Project Luminaires

Luminaire Name : SGS 102/150T
Lamp name : SON-T+ 150W
Number of lamps/luminaire : 1
Lamp flux : 16500 lm
Ballast : Standard
Light output ratios
DLOR : 0.70
ULOR : 0.00
TLOR : 0.70
Luminaire wattage : 168.0 W
Measurement code : MIR5969000



2. Overview of Schemes

The overall maintenance factor used for this project is 0.90.


Code	Luminaire Type	Lamp Type	Power (W)	Flux (lm)
B	SGS 102/150T	1 * SON-T+ 150W	168.0	1 * 16500

	Unit	Scheme 1
Carriageway		Single Carriageway
Road Width	m	16.88
Number of Lanes		2
Reflection Table		Asphalt CIE C2
Q0 of Table		0.07
Luminaire Code		B
Installation		Opposite
Height	m	10.75
Spacing	m	26.00
Overhang	m	1.80
Tilt90	deg	5.0
L ave	cd/m2	1.83
L min	cd/m2	1.20
L max	cd/m2	2.17
L min/max		0.55
L min/ave		0.66
UF-1		0.88
UF-2		0.88
TI	%	7.0
G		5.2
Eh ave	lux	31.3
Eh min	lux	19.5
Eh max	lux	39.1
Eh min/max		0.50
SR-left		0.53
SR-right		0.53

3. Summary

3.1 Main Road

Luminaire Type : SGS 102/150T
 Lamp Type : 1 * SON-T+ 150W
 Lamp Flux : 16500 lumen
 Tilt90 (T) : 5.0 deg
 Project Maintenance Factor : 0.90



Carriageway : Single Carriageway
 Road Width (W) : 16.88 m
 Number of Lanes : 2
 Reflection Table : Asphalt CIE C2
 Q0 of Table : 0.07
 Installation : Opposite
 Height (H) : 10.75 m
 Spacing (S) : 26.00 m
 Overhang (O) : 1.80 m

Luminance

Average = 1.83 cd/m²
 Minimum = 1.20 cd/m²
 Maximum = 2.17 cd/m²
 Minimum/Maximum = 0.55
 Minimum/Average = 0.66
 UI-1 (4.22, -60.00, 1.50) = 0.88
 UI-2 (12.66, -60.00, 1.50) = 0.88

Horizontal Illuminance

Average = 31.3 lux
 Minimum = 19.5 lux
 Maximum = 39.1 lux
 Minimum/Maximum = 0.50

Glare

Tl (4.22, -51.42, 1.50) = 7.0 %
 G = 5.2

Surround Ratios

SR-Left = 0.53
 SR-Right = 0.53

3.2 Additional Calculations

(II) Illuminance Calculations:

Calculation	Type	Unit	Ave	Min	Max	Min/Ave	Min/Max
General	Surface Illuminance	lux	32.4	19.2	39.1	0.59	0.49

RUPSA BRIDGE PROJECT

DESIGN CALCULATION
(ELECTRICAL)

DESIGN CALCULATION
 (STA 6 + 560 TO STA 8 + 890)
 [Approach Road, Rupsa Bridge and Toll Plaza]

CCT-1 Load (L1-L26) = 26 Nos. x (250 x 1.25) Watt/No. = 8,125 W

Load of R-Phase = 9 Nos. x (250 x 1.25) Watt/No.
 = 2812.5 Watt.

Current I = $\frac{2812.5}{230 \times 0.8}$

Breaker = 15.285 Amps.
 = 15.285 x 1.3
 = 19.87 Amps.
 = 20 A TP MCCB

Cable size = 4 x 25.0 mm² NYY.
 (Selected from Voltage drop Calculation)

CCT-2 Same as CCT-1

CCT-3 Load (L105-L130) = 26 Nos. x (250 x 1.25) Watt/No.
 = 8125 Watt.

Load of R Phase = 315 Watt

Current I = $\frac{315}{230 \times 0.8}$ Amps.
 = 16.98 Amps.

Breaker = 20A TP MCCB

Cable size = 4C-16.00 mm² NYY (Selected from Voltage drop calculation)

DESIGN CALCULATION
(STA 6 + 560 TO STA 8 + 890)
[Approach Road, Rupsa Bridge and Toll Plaza]

CCT-4 and CCT-5 are similar to CCT-1

CCT-6

Load (L131-L155)	=	25 Nos. x (250 x 1.25) Watt./No.
	=	7812.5 Watt.
Load of R Phase	=	2812.5 Watt.
Current, I	=	$\frac{2812.5}{230 \times 0.8}$
	=	15.28 Amps.
Breaker	=	20 A TP MCCB
Cable size	=	4 x 25.0 mm ² NYY Cable (Selected from V.D. Calculation)

CCT-7 Same as CCT-6

DESIGN CALCULATION
(STA 6 + 560 TO STA 8 + 890)
[Approach Road, Rupsa Bridge and Toll Plaza]

CCT-8

PIER LIGHTING

Load (FL1 to FL8)	=	8 Nos. x (400 x 1.25) Watt/No.
	=	4000 Watt.
Load of R/Y Phase	=	2000 Watt.
Current, I	=	$\frac{2000}{230 \times 0.8}$
	=	10.86 Amp
Breaker	=	30A DP MCB
Cable size	=	3 x 50.0 mm ² NYY (Selected from V.D. Calculation)

DESIGN CALCULATION

(STA 6 + 560 TO STA 8 + 890)

[Approach Road, Rupsa Bridge and Toll Plaza]

V.D. Calculation (According to IEE Wiring Regulation)
PIER LIGHTING (3 – 50 mm² NYY)

$$\begin{aligned}\text{CCT-9 Load of each Phase (FL1, FL2, F5, FL6)} &= 4 \text{ Nos.} \times (400 \times 1.25) \text{ Watt/No.} \\ &= 2000 \text{ Watt.} \\ &= 10.86 \text{ Amps}\end{aligned}$$

R-Phase

$$\begin{aligned}\text{V.D. from S/S to FL1} &= 0.00093 \text{ V/m/A} \times 640\text{m} \times 10.86 \text{ A} = 6.4638 \text{ Volt.} \\ \text{V.D. from FL1 to F5} &= 0.00093 \text{ V/m/A} \times 232\text{m} \times 5.43\text{A} = 1.1715768 \text{ Volt.} \\ \text{Total Voltage drop of R Phase} &= 7.6353768 \text{ Volt} \\ &= 3.31\%\end{aligned}$$

Y-Phase

$$\begin{aligned}\text{V.D. from S/S to FL3} &= 0.00093 \text{ V/m/A} \times 756\text{m} \times 10.86\text{A} = 7.6354488 \\ \text{Volt.} \\ \text{V.D. from FL3 to F7} &= 0.00093 \text{ V/m/A} \times 232\text{m} \times 5.43\text{A} = 1.1715768 \text{ Volt.} \\ \text{Total Voltage drop of Y Phase} &= 8.8070256 \text{ Volt} \\ &= 3.82\%\end{aligned}$$

DESIGN CALCULATION
 (STA 6 + 560 TO STA 8 + 890)
 [Approach Road, Rupsa Bridge and Toll Plaza]

V.D. Calculation (According to IEE WIRING REGULATION 16th Edition)

CCT-1 (Y – Phase – 25.0 mm² NYY Cable)

V.D. from T X R1 to L2	=	0.00175 V/m/A x (76+26)m x 15.285A
	=	2.7283725 Volt.
V.D. from L2 to L5	=	0.00175 V/m/A x 78m x 13.587A
	=	1.8546255 Volt.
V.D. from L5 to L8	=	0.00175 V/m/A x 78m x 11.889A
	=	1.6228485 Volt.
V.D. from L8 to L11	=	0.00175 V/m/A x 78m x 10.191A
	=	1.3910715 Volt.
V.D. from L11 to L14	=	0.00175 V/m/A x 78m x 8.493A
	=	1.1592945 Volt.
V.D. from L14 to L17	=	0.00175 V/m/A x 78m x 6.795A
	=	0.9275175 Volt.
V.D. from L17 to L20	=	0.00175 V/m/A x 78m x 5.097A
	=	0.6957405 Volt.
V.D. from L20 to L23	=	0.00175 V/m/A x 78m x 3.399A
	=	0.4639635 Volt.
V.D. from L23 to L26	=	0.00175 V/m/A x 78m x 1.698A
	=	0.231777 Volt.
Total voltage drop	=	11.0752 Volt.
	=	4.815%
	=	4.81%

Note : V.D. Calculation for CCT-2, CCT4, CCT5, CCT-6 and CCT-7 will be similar to CCT-1.

DESIGN CALCULATION
 (STA 6 + 560 TO STA 8 + 890)
 [Approach Road, Rupsa Bridge and Toll Plaza]

V.D. Calculation (According to IEE WIRING REGULATION 16th Edition)

CCT-1 (R – Phase – 25.0 mm² NYY Cable)

V.D. from T X R1 to L1	=	0.00175 V/m/A x 76m x 15.285A
	=	2.032905 Volt.
V.D. from L1 to L4	=	0.00175 V/m/A x 78m x 13.587A
	=	1.8546255 Volt.
V.D. from L4 to L7	=	0.00175 V/m/A x 78m x 11.889A
	=	1.6228485 Volt.
V.D. from L7 to L10	=	0.00175 V/m/A x 78m x 10.191A
	=	1.3910715 Volt.
V.D. from L10 to L13	=	0.00175 V/m/A x 78m x 8.493A
	=	1.1592945 Volt.
V.D. from L13 to L16	=	0.00175 V/m/A x 78m x 6.795A
	=	0.9275175 Volt.
V.D. from L16 to L19	=	0.00175 V/m/A x 78m x 5.097A
	=	0.6957405 Volt.
V.D. from L19 to L22	=	0.00175 V/m/A x 78m x 3.399A
	=	0.4639635 Volt.
V.D. from L22 to L25	=	0.00175 V/m/A x 78m x 1.698A
	=	0.231777 Volt.
Total voltage drop	=	10.3797435 Volt.
	=	4.51%

DESIGN CALCULATION
 (STA 6 + 560 TO STA 8 + 890)
 [Approach Road, Rupsa Bridge and Toll Plaza]

V.D. Calculation (According to IEE WIRING REGULATION 16th Edition)

CCT-3 (R – Phase – 16 mm² NYY Cable)

V.D. from T X R1 to L105	=	0.0028 V/m/A x 50m x 16.98A
	=	2.3772 Volt.
V.D. from L105 to L106	=	0.0028 V/m/A x 26m x 15.282A
	=	1.1125296 Volt.
V.D. from L106 to L108	=	0.0028 V/m/A x 6.792m x 6.792A
	=	0.9889152 Volt.
V.D. from L108 to L111	=	0.0028 V/m/A x 78m x 5.094A
	=	0.7416864 Volt.
V.D. from L111 to L114	=	0.0028 V/m/A x 78m x 3.396A
	=	1.1592945 Volt.
V.D. from L114 to L117	=	0.0028 V/m/A x 78m x 1.698A
	=	0.3708432 Volt.
Total voltage drop	=	6.703704 Volt.
	=	2.91%

DESIGN CALCULATION
 (STA 6 + 560 TO STA 8 + 890)
 [Approach Road, Rupsa Bridge and Toll Plaza]

Load of DB (W)

(i)

No. of Light Fitting from centre of the bridge to west approach Road	=	78 Nos. 250 Watt. HPS
∴ Road and Bridge Lighting Load	=	78 Nos. x (250x1.25) Watt/No.
	=	24375 Watt.
(ii) Stair and Plaza Load	=	3675 Watt.
(iii) Spare Load	=	2,000 Watt.
Total Load of DB (W)	=	30,050 Watt.
Current, I	=	$\frac{30,050}{415 \times 1.732 \times 0.8}$
	=	52.25 amps
Breaker	=	80A TP MCCB
Cable size	=	4 x 35.0 mm ² NYY (DB(W) is Nearer to transformer so V.D. Calculation for selecting the Cable size does not arise]

DESIGN CALCULATION
 (STA 6 + 560 TO STA 8 + 890)
 [Approach Road, Rupsa Bridge and Toll Plaza]

Load of DB (E)

(i)

No. of Light Fitting from centre of the bridge to east approach Road	=	102 Nos. 250 Watt. HPS
∴ Road and Bridge Lighting Load	=	102 Nos. x (250x1.25) Watt/No.
	=	31875 Watt.
(ii) Pier Lighting Load	=	8 Nos. x (400 x 1.25) Watt./No.
	=	4000 Watt.
(iii) Stair and Plaza Load	=	3675 Watt.
(iv) Spare Load	=	2,000 Watt.
Total Load of DB (E)	=	(i) + (ii) + (iii) + (iv)
	=	(31875 + 4000 + 3675 + 2000)
	Watt.	
	=	41550 Watt.
Current, I	=	$\frac{41,550}{415 \times 1.732 \times 0.8}$
	=	72.25 Amps
Breaker	=	100A TP MCCB
Cable size	=	4 x 50.0 mm ² NYY [(DB (E) is Nearer to sub-station so V.D. Calculation for selecting the Cable size does not arise.]

DESIGN CALCULATION
(STA 6 + 560 TO STA 8 + 890)
[Approach Road, Rupsa Bridge and Toll Plaza]

Load for Engineer's Office and Other Building for Bridge Authority:

- (i) Area of Engineer's Office Building = 882.73
(ii) Area of Engineer's Laboratory Building = 425.56 sq.m.

Total area of Engineer's Office and Laboratory Building
= (882.73 + 425.56) sq.m.
= 1308.29 sq.m.

Minimum Load of Engineer's Office and
Laboratory Building as per BNBC
= 1308.29 sq.m. x 35 Watt/sq.m.
= 45790.15 W
= 45790 Watt.

- (iii) Area of Staff Quarter (Building) = 207.06 sq.m./No. x 18 Nos.
= 3727.08 sq.m.

- (iv) Area of Engineers Mess and Dormitory Building = (1002.38 + 953.73)
= 1956.11 sq.m.

Total Area of Staff Quarters,
Mess and Dormitory Building
= (3727.08 + 1956.11) sq.m.
= 5683.19 sq.m.

Minimum load of staff quarter, Mess and
Dormitory Building as per Bangladesh
National Building Code (BNBC)
= 5683.19 sq.m. x 25 Watt/sq.m.
= 142080 Watt.

**Total Load of Engineers Office, laboratory,
Staff Quarter, Mess and Dormitory Building**
= (45790 + 142080) Watt
= 187870 Watt.

DESIGN CALCULATION
(STA 6 + 560 TO STA 8 + 890)
[Approach Road, Rupsa Bridge and Toll Plaza]

Load of sub-station

- (i) Load of DB (E) = 41550 Watt.
- (ii) Load of Toll Plaza = 10,000 Watt.
- (iii) Load of Engineer's Office
Laboratory, Staff Quarter,
Mess and Dormitory Building
for Bridge Authority = 187870 Watt.

Total Load of Sub-station

$$\begin{aligned} &= (i) + (ii) + (iii) \\ &= (41550 + 10,000 + 187870) \text{ Watt.} \\ &= 239420 \text{ Watt.} \\ &= 239 \text{ kw} \end{aligned}$$

$$\text{KVA rating of Transformer} = \frac{239}{0.9}$$

$$= 265.55 \text{ KVA}$$

$$\therefore \text{Transformer Rating} = 315 \text{ kVA.}$$

DESIGN CALCULATION

BATIA GHATA INTERSECTION AND HATIA BRIDGE

STA 2 + 517 TO STA 3 + 100

$$\begin{aligned} \text{CCT-1 Load (L181-L198)} &= 18 \text{ Nos.} \times 188 \text{ W / No.} = 3384 \text{ Watt.} \\ \text{Load of R-Phase} &= 6 \text{ Nos.} \times 188 \text{ Watt. / No.} \\ &= 1128 \text{ Watt.} \end{aligned}$$

$$\text{Current I} = \frac{1128}{220 \times 0.8}$$

$$= 6.409 \text{ Amps.}$$

$$= 15 \text{ ATP Amps.}$$

$$\text{Cable size} = 4\text{C} - 10.0 \text{ mm}^2 \text{ NYY.}$$

(Selected from Voltage drop Calculation)

$$\begin{aligned} \text{CCT-2 Load (L199-L218)} &= 20 \text{ Nos.} \times 188 \text{ Watt. / No.} \\ &= 3760 \text{ Watt.} \end{aligned}$$

$$\begin{aligned} \text{Load of B Phase} &= 7 \text{ Nos.} \times 188 \text{ Watt. / No.} \\ &= 1316 \text{ Watt.} \end{aligned}$$

$$\text{Current I} = \frac{1316}{220 \times 0.8} \text{ Amps.}$$

$$= 7.477 \text{ Amps.}$$

$$\text{Breaker} = 15\text{A TP MCCB}$$

$$\text{Cable size} = 4\text{C}-10.00 \text{ mm}^2 \text{ NYY (Selected from Voltage drop calculation)}$$

DESIGN CALCULATION
BATIA GHATA INTERSECTION AND HATIA BRIDGE

$$\begin{aligned} \text{CCT-3 Load (L219-L221)} &= 3 \text{ Nos. x } 188 \text{ Watt. / No.} \\ &= 564 \text{ W} \end{aligned}$$

$$\begin{aligned} \text{Current} &= \frac{564}{220 \times 0.8} \\ &= 3.20 \text{ Amps.} \end{aligned}$$

$$\begin{aligned} \text{CCT-4 Load (L222-L225)} &= 4 \text{ Nos. x } 188 \text{ Watt. / No.} \\ &= 752 \text{ W} \end{aligned}$$

$$\begin{aligned} \text{Current} &= \frac{752}{220 \times 0.8} \\ &= 4.27 \text{ Amps.} \end{aligned}$$

$$\begin{aligned} \text{CCT-5 Load (L226-L230)} &= 5 \text{ Nos. x } 188 \text{ Watt. / No.} \\ &= 940 \text{ W} \end{aligned}$$

$$\begin{aligned} \text{Current} &= \frac{940}{220 \times 0.8} \text{ Amps.} \\ &= 5.34 \text{ Amps.} \end{aligned}$$

Breaker for CCT-3-CCT5 = 15A SP MCB

Cable size CCT-3 – CCT-5 = 2C – 6.0 mm² NYY
 (Selected from V.D. Calculation)

$$\begin{aligned} \text{Load of DB-1} &= (3384 + 3760 + 564 + 752 + 940) \text{ Watt.} \\ &= 9400 \text{ Watt.} \end{aligned}$$

$$\text{Spare Load} = 1000 \text{ Watt.}$$

$$\therefore \text{Total Load of DB-1} = 10400 \text{ Watt.}$$

DESIGN CALCULATION
BATIA GHATA INTERSECTION AND HATIA BRIDGE

$$\begin{aligned} \text{Current I} &= \frac{10400}{1.732 \times 415 \times 0.8} \\ &= 18.08 \text{ Amps.} \\ \text{Breaker} &= 18.08 \times 1.3 \\ &= 23.504 \text{ Amp} \\ &= 30\text{A TP MCCB} \\ \text{Cable size} &= 4\text{C} - 10.0 \text{ mm}^2 \text{ NY Y (Selected for 1\% V.D.)} \end{aligned}$$

V.D. CALCULATION
 (According to IEE Wiring Regulation)

CCT-2 (L199 to L218), 4C – 10.0 mm² NY Y Cable.

B-Phase voltage drop:

$$\begin{aligned} \text{V.D. from DB-1 to L203} &= 0.0038 \text{ V/m/A} \times 97\text{m} \times 7.477\text{A} = 2.7560222 \text{ Volt.} \\ \text{V.D. from L203 to L206} &= 0.0038 \text{ V/m/A} \times 78\text{m} \times 5.341\text{A} = 1.5830724 \text{ Volt.} \\ \text{V.D. from L206 to L209} &= 0.0038 \text{ V/m/A} \times 78\text{m} \times 4.273\text{A} = 1.2665172 \text{ Volt.} \\ \text{V.D. from L209 to L212} &= 0.0038 \text{ V/m/A} \times 78\text{m} \times 3.205\text{A} = 0.949962 \text{ Volt.} \\ \text{V.D. from L212 to L215} &= 0.0038 \text{ V/m/A} \times 78\text{m} \times 2.137\text{A} = 0.6334068 \text{ Volt.} \\ \text{V.D. from L215 to L218} &= 0.0038 \text{ V/m/A} \times 78\text{m} \times 1.068\text{A} = 0.3165552 \text{ Volt.} \end{aligned}$$

DESIGN CALCULATION
BATIA GHATA INTERSECTION AND HATIA BRIDGE

Total Voltage drop of B-Phase = 7.50553612 Volt. = 3.41%

Voltage drop of R and Y will be similar of B-Phase

Voltage drop of CCT-1 (L181 – L198) will be similar to CCT-2 (L199 – L218)

CCT-5 (L225 to L230), For 2C – 6.0 mm² NYY

V.D. from DB-1 to L228 = 0.0073 V/m/A x 40m x 5.34A = 1.55928 Volt.

V.D. from L228 to L227 = 0.0073 V/m/A x 26m x 4.272A = 0.8108256 Volt.

V.D. from L227 to L226 = 0.0073 V/m/A x 26m x 3.204A = 0.6081192 Volt.

V.D. from L226 to L229 = 0.0073 V/m/A x 26m x 2.136A = 0.4054128 Volt.

V.D. from L229 to L230 = 0.0073 V/m/A x 26m x 1.068A = 0.2027064 Volt.

Total voltage drop = 3.586344 Volt. = 1.630%

Voltage drop for main incoming Line (4C – 16.0 mm²NYY)

= 0.0024 V/m/A x 100m x 18.08A = 4.339 Volt.

= 1.045%

DESIGN CALCULATION

Molonghata Bridge and Related Approach Road

$$\begin{aligned} \text{CCT-1 (L273-L287)} &= 15 \text{ Nos. x } 188 \text{ W / No.} \\ &= 2820 \text{ Watt.} \end{aligned}$$

$$\begin{aligned} \text{Load of each Phase} &= 5 \text{ Nos. x } 188 \text{ Watt. /No.} \\ &= 940 \text{ Watt.} \end{aligned}$$

$$\text{Current I} = \frac{940}{220 \times 0.8}$$

$$= 5.34 \text{ Amps.}$$

$$\text{Breaker} = 10 \text{ A TP MCCB}$$

$$\text{Cable size} = 2\text{C} - 6.0 \text{ mm}^2 \text{ NYY.}$$

$$\text{CCT-2 (L288-L303, L327)} = \text{Same as CCT-1}$$

$$\text{Load of DB4} = (2820 + 2820) \text{ Watt.} = 5640 \text{ Watt.}$$

$$\text{Spare Load} = 1500 \text{ Watt.}$$

$$\therefore \text{Total Load of DB-4} = 7140 \text{ Watt.}$$

$$\text{Current I} = \frac{7140}{3 \times 415 \times 0.8}$$

$$= 12.41 \text{ Amps.}$$

$$\text{Breaker} = 20\text{A TP MCCB}$$

$$\text{Cable size} = 4\text{C} - 6.0 \text{ mm}^2 \text{ NYY}$$

The Electric source is approximately 1 km away from the STA10 + 495, So we have to construct a new 11 KV 3 ϕ , 4 wire line.

DESIGN CALCULATION

MOLONGHATA BRIDGE AND RELATED ROAD) DESGIN CALCULATION

V.D. CALCULATION

According to IEE Wiring Regulation

CCT-1 (L273-287)

R (Phase) [L273, L276, L279, L282, L285], For 4C – 6.0 mm² NYY

$$\text{V.D. from DB-4 to L273} = 0.0064 \text{ V/m/A} \times 31\text{m} \times 5.34\text{A} = 1.059456 \text{ Volt.}$$

$$\text{V.D. from L273 to L276} = 0.0064 \text{ V/m/A} \times 78\text{m} \times 4.272\text{A} = 1.1325824 \text{ Volt.}$$

$$\text{V.D. from L276 to L279} = 0.0064 \text{ V/m/A} \times 78\text{m} \times 3.204\text{A} = 1.5994368 \text{ Volt.}$$

$$\text{V.D. from L279 to L282} = 0.0064 \text{ V/m/A} \times 78\text{m} \times 2.136\text{A} = 1.0662912 \text{ Volt.}$$

$$\text{V.D. from L282 to L285} = 0.0064 \text{ V/m/A} \times 78\text{m} \times 1.068\text{A} = 0.5331456 \text{ Volt.}$$

$$\text{Total Voltage drop of R Phase} = 6.390912 \text{ Volt.} = 2.90\%$$

Y-(Phase) [L274, L277, L280, L283, L286], For 6.0 mm² NYY

$$\text{V.D. from DB-4 to L274} = 0.0064 \text{ V/m/A} \times 57\text{m} \times 5.34\text{A} = 1.948032 \text{ Volt.}$$

$$\text{V.D. from L274 to L277} = 0.0064 \text{ V/m/A} \times 78\text{m} \times 4.272\text{A} = 2.1325824 \text{ Volt.}$$

$$\text{V.D. from L277 to L280} = 0.0064 \text{ V/m/A} \times 78\text{m} \times 3.204\text{A} = 1.5994368 \text{ Volt.}$$

$$\text{V.D. from L280 to L283} = 0.0064 \text{ V/m/A} \times 78\text{m} \times 2.136\text{A} = 1.0662912 \text{ Volt.}$$

$$\text{V.D. from L283 to L285} = 0.0064 \text{ V/m/A} \times 78\text{m} \times 1.068\text{A} = 0.5331456 \text{ Volt.}$$

$$\begin{aligned} \therefore \text{Total Voltage drop for Y-Phase} &= 7.279488 \text{ Volt.} \\ &= 3.308\% \\ &= 3.3\% \end{aligned}$$

DESIGN CALCULATION

V.D. CALCULATION

According to IEE Wiring Regulation

B (Phase) (L275 – L278, L281, L284, L287), [For 6.0 mm² NYY Cable]

$$\text{V.D. from DB-4 to L275} = 0.0064 \text{ V/A/m} \times 83\text{m} \times 5.34\text{A} = 2.836608 \text{ Volt.}$$

$$\text{V.D. from L275 to L278} = 0.0064 \text{ V/A/m} \times 78\text{m} \times 4.272\text{A} = 2.1325824 \text{ Volt.}$$

$$\text{V.D. from L278 to L281} = 0.0064 \text{ V/A/m} \times 78\text{m} \times 3.204\text{A} = 1.5994368 \text{ Volt.}$$

$$\text{V.D. from L281 to L284} = 0.0064 \text{ V/A/m} \times 78\text{m} \times 2.136\text{A} = 1.0662912 \text{ Volt.}$$

$$\text{V.D. from L284 to L287} = 0.0064 \text{ V/A/m} \times 78\text{m} \times 1.068\text{A} = 0.533156 \text{ Volt.}$$

Total Voltage drop of B Phase = 8.168064 Volt. = 3.71%

V.D. for CCT.-2 (L288 to L302) will be similar to CCT-1 (L273 to L287).

DESIGN CALCULATION

Stair Case & Plaza

ILLUMINATION CALCULATION (Stair Case)

$$\text{Area of stair case} = 15.6 \times 7.6 - \frac{1}{2} (3.8 \times 2)4 = 103.36 \text{ sq.m.}$$

$$\text{Required Lumens} = \frac{\text{Area in sq.m.} \times \text{illuminance}}{\text{Coefficient of utilization} \times \text{Maintenance facton}}$$

$$\text{Average Co-efficient of Utilization} = 0.7$$

$$\text{Average Maintenance facton} = 0.6, \text{ Illuminance} = 100 \text{ Lux.}$$

$$\begin{aligned} \therefore \text{Required Lumens} &= \frac{103.36 \times 100}{0.7 \times 0.6} \\ &= 24609 \text{ Lumens} \end{aligned}$$

$$\text{Selected Lamps} = 70\text{W HPs (E)}$$

$$\text{Lamps Lumens} = 5,800$$

$$\begin{aligned} \text{No. of Luminaires} &= \frac{\text{Required Lumens}}{\text{Lumens / No.}} \\ &= \frac{24609}{5800} \\ &= 4.24 \\ &= 4 \text{ Nos.} \end{aligned}$$

DESIGN CALCULATION

Stair Case & Plaza

ILLUMINATION CALCULATION (Plaza)

$$\begin{aligned}\text{Approximate Area of Plaza} &= (16.480 \times 48) \text{ sq.m.} + (2 \times 28 \times 8.5) \text{ sq.m.} \\ &= (791.04 + 476) \text{ sq.m.} \\ &= 1267.04 \text{ sq.m.} \\ &= 1267 \text{ sq.m.}\end{aligned}$$

$$\text{Required Lumens} = \frac{\text{Area in sq.m.} \times \text{Illuminance}}{\text{Coefficient of utilization} \times \text{Maintenance Factor}}$$

$$\text{Average co-efficient of Utilization} = 0.7$$

$$\text{Average Maintenance factor} = 0.6$$

$$\text{Illuminance} = 15 \text{ Lux.}$$

$$\begin{aligned}\text{Required Lumens} &= \frac{1267 \times 15}{0.7 \times 0.6} \\ &= 45,250\end{aligned}$$

$$\text{Selected Lamps} = 125 \text{ W HPMV}$$

$$\text{Lamps Lumen} = 5800$$

$$\begin{aligned}\text{No. of Luminaire} &= \frac{\text{Required Lumens}}{\text{Lumens / No.}} \\ &= \frac{45250}{5800} \\ &= 7.801 \\ &= 8 \text{ Nos.}\end{aligned}$$

DESIGN CALCULATION

Stair Case & Plaza

CCt-1

Load (B1 and B2 – 1st, 3rd and 5th Landing) = 6 Nos. x (70 x 1.25) W / No.

= 525 Watt.

Current I = $\frac{525}{220 \times 0.8}$

= 2.98 Amps.

Breaker = 10 A SP MCB

Cable size = 2C – 4.00 mm² NYY (for less than 1% V. drop)

CCt-2

Load (B3 and B4 – 2nd +4th Landing and Column to Light)

= 5 Nos. x (70 x 1.25) Watt. / No.

= 437.5 Watt.

Current I = $\frac{437.5}{220 \times 0.8}$

= 2.485 Amps.

Breaker = 10A SP MCB

Cable size = 2c – 4.0 mm² NYY Cable
(for less than 1% voltage drop)

CCt-3 and CCt-4 are similar to CCt-1 and CCt-2 respectively.

DESIGN CALCULATION

Stair Case & Plaza

CCT-5 Load (PL1 – PL8)	=	8 Nos. x (125 x 1.25) Watt. / No.
	=	1250 Watt.
Current, I	=	$\frac{1250}{220 \times 0.8}$
	=	7.10 Amps.
Breaker	=	15A SP MCB
Cable size	=	2C – 10.0 mm ² NYY (Selected from V.D. Calculation of less than 1%).
Load of SDB (S)	=	[(525 + 437.5) x 2 + 1250] Watt.
	=	3175 Watt.
Spare Load	=	500 Watt.
Total Load of SDB(S)	=	3675 Watt.
Current, I	=	$\frac{3675}{220 \times 0.8}$
	=	20.88 Amps.
Breaker	=	30A DP MCB
Cable size	=	Single core – 2 x 50.0 mm ² NYY (Selected for 3.44% voltage drop from V.D. calculation)

DESIGN CALCULATION

Stair Case & Plaza

Voltage drop (V.D.) Calculation (According to IEE wiring (Regulation))

$$\begin{aligned}\text{Distance between sub-station and SDB(S)} &= 414 \text{ meter} \\ \text{V.D. for 1C-50.0 mm}^2\text{NYY cable} &= 0.00093 \text{ V/m/A} \times 414\text{m} \times 20.88\text{A} \\ &= 8.039 \text{ Volt.} \\ &= 3.65\%\end{aligned}$$

CCt-5 Load (PL1 – PL8) For 2C – 10.0 mm² NYY Cable

$$\begin{aligned}\text{V.D. from DBS to PL}_1 &= 0.0044 \text{ V/A/m} \times 15\text{m} \times 7.1\text{A} = 0.4686 \text{ Volt.} \\ \text{V.D. from PL}_1 \text{ to PL}_2 &= 0.0044 \text{ V/A/m} \times 20\text{m} \times 5.324 \text{ A} = 0.468512 \text{ Volt.} \\ \text{V.D. from PL}_2 \text{ to PL}_3 &= 0.0044 \text{ V/A/m} \times 15\text{m} \times 4.437 \text{ A} = 0.292842 \text{ Volt.} \\ \text{V.D. from PL}_3 \text{ to PL}_4 &= 0.0044 \text{ V/A/m} \times 15\text{m} \times 3.55 \text{ A} = 0.2343 \text{ Volt.} \\ \text{V.D. from PL}_4 \text{ to PL}_5 &= 0.0044 \text{ V/A/m} \times 11\text{m} \times 2.663 \text{ A} = 0.1288892 \text{ Volt.} \\ \text{V.D. from PL}_5 \text{ to PL}_6 &= 0.0044 \text{ V/A/m} \times 10\text{m} \times 1.776 \text{ A} = 0.078144 \text{ Volt.} \\ \text{V.D. from PL}_6 \text{ to PL}_7 &= 0.0044 \text{ V/A/m} \times 10\text{m} \times 0.887 \text{ A} = 0.039028 \text{ Volt.} \\ \text{Total Voltage drop} &= 1.7103152 \text{ Volt} = 0.777\%\end{aligned}$$

DESIGN CALCULATION
SATKHIRA ROAD INTERSECTION

CCT-1 (L231-L234) = 4 Nos. x 188 W / No.
= 752 Watt.

Current, I = $\frac{752}{220 \times 0.8}$

= 4.27 Amps.

Cable size = 2C – 4.0 mm² NYY

Breaker = 15 A SP MCB

CCT-2 (L235-L239) = (1 x 2 x 188 + 4 x 188) Watt.

= 1128 W

Current I = $\frac{1128}{220 \times 0.8}$

= 6.40 Amps.

Cable size = 2C – 4.0 mm² NYY

Breaker = 15A SP MCB

CCT-3 (L240-L243) = (1 x 2 x 188 + 3 x 188) Watt.

= 940 W

Current = $\frac{940}{220 \times 0.8}$

= 5.34 Amps.

Cable size = 2C – 4.0 mm² NYY

Breaker = 15A SP MCB

DESIGN CALCULATION
SATKHIRA ROAD INTERSECTION

$$\text{CCT-4 (L244-L250)} = 7 \text{ Nos.} \times 188 \text{ Watt / No.}$$

$$= 1316 \text{ Watt.}$$

$$\text{Current, I} = \frac{1316}{220 \times 0.8}$$

$$= 7.47 \text{ Amps.}$$

$$\text{Cable size} = 2\text{C} - 6.0 \text{ mm}^2 \text{ NYY (Selected from V.D. Calculation)}$$

$$\text{Breaker} = 15\text{A SP MCB}$$

$$\text{Total Load of DB-2} = \text{CCT-1} + \text{CCT-2} + \text{CCT-3} + \text{CCT-4} = (752 + 1128 + 940 + 1316) \text{ Watt.}$$
$$= 4136 \text{ Watt.}$$

$$\text{Spare Load} = 1000 \text{ Watt.}$$

$$\therefore \text{Total Load of DB-2} = (4136 + 1000) \text{ Watt.}$$

$$= 5136 \text{ Watt.}$$

$$\text{Current I} = \frac{5136}{220 \times 0.8}$$

$$= 29.18 \text{ Amps.}$$

$$\text{Breaker} = 29.18 \times 1.3$$

$$= 37.934 \text{ amp}$$

$$= 40\text{A DP MCB}$$

Approximate distance of BPDB source = 100 meter

$$\text{Cable size} = 2\text{C} - 25.0 \text{ mm}^2 \text{ NYY}$$

DESIGN CALCULATION

SATKHIRA ROAD INTERSECTION

V.D. CALCULATION
[According to IEE Wiring Regulation]

CCT-4 (L244 to L250), Cable 2C – 6.0 mm² NYY

$$\begin{aligned} \text{V.D. from DB-2 to L244} &= 0.0073 \text{ V/m/A} \times 35\text{m} \times 7.47\text{A} = 1.908 \text{ Volt.} \\ \text{V.D. from L244 to L245} &= 0.0073 \text{ V/m/A} \times 26\text{m} \times 6.402\text{A} = 1.2150 \text{ Volt.} \\ \text{V.D. from L245 to L246} &= 0.0073 \text{ V/m/A} \times 26\text{m} \times 5.334\text{A} = 1.0123 \text{ Volt.} \\ \text{V.D. from L246 to L247} &= 0.0073 \text{ V/m/A} \times 26\text{m} \times 4.226 \text{A} = 0.80968 \text{ Volt.} \\ \text{V.D. from L247 to L248} &= 0.0073 \text{ V/m/A} \times 26\text{m} \times 3.158 \text{A} = 0.5993 \text{ Volt.} \\ \text{V.D. from L248 to L249} &= 0.0073 \text{ V/m/A} \times 26 \text{m} \times 2.09\text{A} = 0.3966 \text{ Volt.} \\ \text{V.D. from L249 to L250} &= 0.0073 \text{ V/m/A} \times 26 \text{m} \times 1.068\text{A} = 0.2027 \text{ Volt.} \end{aligned}$$

$$\begin{aligned} \text{Total Voltage drop} &= 6.143 \text{ Volt} \\ &= 2.79\% \end{aligned}$$

V.D. for main incoming line for 100 meter and 2C – 25.0 mm² NYY cable

$$\begin{aligned} &= 0.00175 \text{ V/A/m} \times 29\text{A} \times 100\text{m} \\ &= 5.075 \text{ Volt} \\ &= 2.30\% \end{aligned}$$

$$\begin{aligned} \therefore \text{Total Voltage drop} &= (2.79 + 2.30) \% \\ &= 5.09\% \\ &= 5\% \text{ which is} \end{aligned}$$

within the permissible limit as per IEE WIRING REGULATION.

DESIGN CALCULATION
JABUSHA ROAD INTERSECTION

CCT-1 (L251-L256) = 6 Nos. x 188 W / No.
= 1128 Watt.

Current I = $\frac{1128}{220 \times 0.8}$

= 6.40 Amps.

Breaker = 15 A SP MCB

Cable size = 2C – 4.0 mm² NYY (Selected V.D. calculation)

CCT-2 (L257-L261) = 5 Nos. x 188 Watt. / No.
= 940 Watt.

Current I = $\frac{940}{220 \times 0.8}$

= 5.34 Amps.

Breaker = 15A SP MCB

Cable size = 2C – 4.0 mm² NYY (Selected from V.D. calculation)

CCT-3 (L262-L266) = 5 Nos. x 188 Watt. / No.
= 940 Watt.

Current = $\frac{940}{220 \times 0.8}$

= 5.34 Amps.

Breaker = 15A SP MCB

Cable size = 2C – 4.0 mm² NYY (Selected from V.D. Calculation)

DESIGN CALCULATION
JABUSHA ROAD INTERSECTION

CCT-4 (L267-L272) = 6 Nos. x 188 Watt / No.
= 1128 Watt.

Current, I = $\frac{1128}{220 \times 0.8}$
= 6.40 Amps.

Breaker = 15A SP MCB

Cable size = 2C – 6.0 mm² NYY Cable
(According to V.D. Calculation)

Total Load = CCT-1 + CCT-2 + CCT-3 + CCT-4
= (1128 + 940 + 940 + 1128) Watt.
= 4136 Watt.

Spare Load = 1000 Watt.

∴ Total Load of DB-3 = 5136 Watt.

Current I = $\frac{5136}{220 \times 0.8}$
= 29.18 Amps.

Breaker = 29.13 x 1.3
= 37.869
= 40A DP MCB

Cable size = 2C – 35.0 mm² NYY (According to V.D. Calculation)

DESIGN CALCULATION

JABUSHA ROAD INTERSECTION

V.D. CALCULATION

[According to IEE Wiring Regulation]

CCT-2 (L257-L261), For 2C – 4.0 mm² NYY Cable.

$$\text{V.D. from DB-3 to L258} = 0.011 \text{ V/A/m} \times 45\text{m} \times 5.344\text{A} = 2.6452 \text{ Volt.}$$

$$\text{V.D. from L258 to L259} = 0.011 \text{ V/A/m} \times 26\text{m} \times 3.208\text{A} = 0.9174 \text{ Volt.}$$

$$\text{V.D. from L 259 to L260} = 0.011 \text{ V/A/m} \times 26\text{m} \times 2.14\text{A} = 0.612 \text{ Volt.}$$

$$\text{V.D. from L 260 to L261} = 0.011 \text{ V/A/m} \times 26\text{m} \times 1.068\text{A} = 0.3054 \text{ Volt.}$$

$$\text{Total Voltage drop} = 4.48 \text{ Volt}$$

$$= 2.036\%$$

CCT-4 (L267-L272), For 2C – 6.0 mm² NYY.

$$\text{V.D. from DB-3 to L268} = 0.0073 \text{ V/A/m} \times 45\text{m} \times 6.404\text{A} = 2.1024 \text{ Volt.}$$

$$\text{V.D. from L268 to L269} = 0.0073 \text{ V/A/m} \times 26\text{m} \times 4.264\text{A} = 0.8093 \text{ Volt.}$$

$$\text{V.D. from L269 to L270} = 0.0073 \text{ V/A/m} \times 26\text{m} \times 3.196\text{A} = 0.6066 \text{ Volt.}$$

$$\text{V.D. from L270 to L271} = 0.0073 \text{ V/A/m} \times 26\text{m} \times 2.128\text{A} = 0.4038 \text{ Volt.}$$

$$\text{V.D. from L271 to L272} = 0.0073 \text{ V/A/m} \times 26\text{m} \times 1.068\text{A} = 0.2027064 \text{ Volt.}$$

$$\text{Total Voltage drop} = 4.1248 \text{ Volt}$$

$$= 1.8749\%$$

DESIGN CALCULATION
JABUSHA ROAD INTERSECTION

V.D. CALCULATION
(According to IEE Wiring Regulation)

CCT-3 (L262-L266), For 2C – 4.0 mm² NYY Cable

$$\begin{aligned} \text{V.D. from DB-3 to L262} &= 0.011 \text{ V/m/A} \times 30\text{m} \times 5.34\text{A} = 1.7622 \text{ Volt.} \\ \text{V.D. from L262 to L263} &= 0.011 \text{ V/m/A} \times 26\text{m} \times 4.272\text{A} = 1.221792 \text{ Volt.} \\ \text{V.D. from L263 to L264} &= 0.011 \text{ V/m/A} \times 26\text{m} \times 3.204\text{A} = 0.91634 \text{ Volt.} \\ \text{V.D. from L264 to L265} &= 0.011 \text{ V/m/A} \times 26\text{m} \times 2.136\text{A} = 0.61089 \text{ Volt.} \\ \text{V.D. from L265 to L266} &= 0.011 \text{ V/m/A} \times 26\text{m} \times 1.068\text{A} = 0.305448 \text{ Volt.} \end{aligned}$$

$$\begin{aligned} \text{Total Voltage drop} &= 4.8166 \text{ Volt} \\ &= 2.18\% \end{aligned}$$

Maximum Voltage drop for any CCT = 2.18%

∴ Remaining Voltage drop (within 5% Limitation) for main incoming line from DPDB source = (5-2.18)% = 2.82%

Approximate distance of source from DB-3 = 150 meter

$$\begin{aligned} \therefore \text{V.D. for 2C – 35 mm}^2 \text{ NYY Cable} & \\ &= 0.00125 \text{ V/m/A} \times 150\text{m} \times 29\text{A} \\ &= 5.43 \text{ Volt} \\ &= 2.47\% \end{aligned}$$

DESIGN CALCULATION

KHULNA MONGLA ROAD INTERSECTION

CCT-1 (L303-L312) = 10 Nos. x 188 W / No.
= 1880 Watt.

Current I = $\frac{1880}{220 \times 0.8}$
= 10.68 Amps.

Breaker = 20 A SP MCB

Cable size = 2C – 10.0 mm² NYY Cable (Selected from V.D. calculation)

CCT-2 (L313-L319, L327) = 7 Nos. x 188 Watt. / No. + 2 x 188
= 1692 Watt.

Current I = $\frac{1692}{220 \times 0.8}$
= 9.61 Amps.

Breaker = 15A SP MCB

Cable size = 2C-6.0 mm² NYY (Selected from V.D. Calculation)

CCT-3 (L320-L326, L328) = (7 + 2) Nos. x 188 Watt. / No.
= 1692 Watt.

Current = $\frac{1692}{220 \times 0.8}$
= 9.61 Amps.

Breaker = 15A SP MCB

Cable size = 2C – 6.0 mm² NYY (Selected from V.D. Calculation)

DESIGN CALCULATION
KHULNA MONGLA ROAD INTERSECTION

Total Load = Load of (CCT-1 + CCT-2 + CCT-3)
= (1880 + 1692 + 1692) Watt.
= 5264 Watt.

Spare Load = 1000 Watt.

Total Load = (5264 + 1000) Watt.
= 6264 Watt.

Current, I = $\frac{6264}{220 \times 0.8}$
= 35.59 Amps.

Breaker = 50A DP MCB

Cable size = Single cone 50.0 mm² NYY Cable
(Selected from V.D. Calculation)

DESIGN CALCULATION
KHULNA MONGLA ROAD INTERSECTION

Voltage drop = 2% for CCT + 3% for maining line

V.D. Calculation (According to IEE Wiring Regulation)

CCT-1 (L303-L312) = [For twin core – 10.0 mm² NYY Cable]

V.D. from DB-4 to L308 = 0.0044 V/A/m x 35m x 10.68A = 1.64472 Volt.

V.D. from L308 to L307 = 0.0044 V/A/m x 26m x 5.34 A = 0.610 Volt.

V.D. from L307 to L306 = 0.0044 V/A/m x 26m x 4.272 A = 0.4887168 Volt.

V.D. from L306 to L305 = 0.0044 V/A/m x 26m x 3.204 A = 0.3665 Volt.

V.D. from L305 to L304 = 0.0044 V/A/m x 26m x 2.136 A = 0.2443584 Volt.

V.D. from L304 to L303 = 0.0044 V/A/m x 26m x 1.068 A = 0.1221792 Volt.

Total Voltage drop = 3.4764 Volt

= 1.58%

DESIGN CALCULATION

KHULNA MONGLA ROAD INTERSECTION

V.D. CALCULATION (According to IEE Wiring Regulation)

$$\begin{aligned} \text{CCT-2 (L312 - L319, L327)} &= [\text{For } 2\text{C} - 4.0 \text{ mm}^2 \text{ NYY Cable}] \\ \text{V.D. from DB-5 to L327} &= 0.011 \text{ V/A/m} \times 5\text{m} \times 9.61\text{A} = 0.52855 \text{ Volt.} \\ \text{V.D. from L327 to L318} &= 0.011 \text{ V/A/m} \times 26\text{m} \times 7.474\text{A} = 2.137564 \text{ Volt.} \\ \text{V.D. from L318 to L315} &= 0.011 \text{ V/A/m} \times 45\text{m} \times 3.202\text{A} = 1.58499 \text{ Volt.} \\ \text{V.D. from L315 to L314} &= 0.011 \text{ V/A/m} \times 26\text{m} \times 2.136\text{A} = 0.610896 \text{ Volt.} \\ \text{V.D. from L314 to L313} &= 0.011 \text{ V/A/m} \times 26\text{m} \times 1.068\text{A} = 0.305448 \text{ Volt.} \\ \text{Maximum Voltage drop} &= 5.167448 \text{ Volt.} \\ &= 2.34884\% \end{aligned}$$

Voltage drop for 2C - 6.0 mm² NYY Cable

$$\begin{aligned} &= 1.55877 \text{ Volt} \\ &= 1.56\% \end{aligned}$$

DESIGN CALCULATION

KHULNA-MONGLA-ROAD INTERSECTION

V.D. CALCULATION (According to IEE Wiring Regulation)

Main Incoming source may be 200 meter away from the DB-5. So 3% Voltage drop is considered for main incoming line and 2% is considered from DB-5 to any point of a circuit.

CCT-3 (L320 – L326, L328)	[For 2C – 6.0 mm ² NYY Cable]
V.D. from DB-5 to L328	= 0.0073 V/m/A x 35m x 9.61A = 2.45535 Volt.
V.D. from L328 to L323	= 0.0073 V/m/A x 26m x 3.204A = 0.81096 Volt.
V.D. from L323 to L322	= 0.0073 V/m/A x 26m x 2.136A = 0.4054128 Volt.
V.D. from L322 to L321	= 0.0073 V/m/A x 26m x 3.204A = 0.81096 Volt.
V.D. from L321 to L320	= 0.0073 V/m/A x 26m x 1.068A = 0.2027064 Volt.

$$\begin{aligned} \therefore \text{Maximum Voltage drop} &= 4.4825392 \text{ Volt.} \\ &= 2.0375\% \\ &= 2\% \end{aligned}$$

$$\begin{aligned} \text{V.D. for main incoming single core} &= 50.0 \text{ mm}^2 \text{ NYY} \\ &= 0.00095 \text{ V/m/A x 200m x 35.59A} \\ &= 6.7621 \text{ Volt} \\ &= 3.073 \% \\ &= 3 \% \end{aligned}$$

JICA