

## ANNEX 5.3.1

### THE PROJECT AND ITS FEASIBILITY STUDY

**THE STUDY ON WATER SUPPLY SYSTEM  
FOR SIEM REAP REGION IN CAMBODIA**

**FINAL REPORT  
Vol. III SUPPORTING REPORT**

**ANNEX 5.3.1 THE PROJECT AND ITS FEASIBILITY STUDY**

**Table of Contents**

	<u>Page</u>
1. Introduction.....	A5.3.1 - 1
2. Future Water Supply Facilities .....	A5.3.1 - 1
2.1 System Flow.....	A5.3.1 - 1
2.2 Production Facilities.....	A5.3.1 - 3
2.2.1 Well Field .....	A5.3.1 - 3
2.2.2 Well Connecting Pipe.....	A5.3.1 - 12
2.2.3 Well Submersible Pump.....	A5.3.1 - 14
2.3 Distribution Center.....	A5.3.1 - 16
2.3.1 Location and Plan of Distribution Center .....	A5.3.1 - 16
2.3.2 Receiving Well .....	A5.3.1 - 16
2.3.3 Disinfection Facilities .....	A5.3.1 - 18
2.3.4 Clear Water Reservoir.....	A5.3.1 - 18
2.3.5 Distribution Pumping Station .....	A5.3.1 - 21
2.3.6 Power Source .....	A5.3.1 - 21
2.4 Distribution System .....	A5.3.1 - 22
2.4.1 Hydraulic Network Analysis.....	A5.3.1 - 22
2.4.2 Cost Comparison of Distribution Trunk Mains .....	A5.3.1 - 37
2.4.3 Meter District .....	A5.3.1 - 38
2.4.4 Service Main .....	A5.3.1 - 42
2.4.5 House Connection.....	A5.3.1 - 42

## List of Tables

		<u>Page</u>
Table 1.1	Basis of Facility Planning for the Stage 1 Project .....	A5.3.1 - 1
Table 2.2.1	Results of Hydraulic Analysis on Well Connecting Pipe .....	A4.5.1 - 13
Table 2.2.2	Length of Well Connecting Pipe .....	A5.3.1 - 14
Table 2.2.3	Total Head Required at Each Submersible Pump.....	A5.3.1 - 15
Table 2.2.4	Capacity of Each Submersible Pump.....	A5.3.1 - 15
Table 2.2.5	Summary of Submersible Pumps Required under Stage 1.....	A5.3.1 - 15
Table 2.2.6	Number of Operating Pumps in Each Year .....	A5.3.1 - 15
Table 2.3.1	List of Distribution Pumps .....	A5.3.1 - 21
Table 2.3.2	Pump Operation Plan.....	A5.3.1 - 21
Table 2.3.3	List of Generators Required .....	A5.3.1 - 21
Table 2.4.1	Domestic Water Demand Distribution to Each Node (Ratio in % ).....	A5.3.1 - 24
Table 2.4.2	Domestic Water Demand Distribution (Hourly Peak Demand Base in l/sec) .....	A5.3.1 - 25
Table 2.4.3	Non Domestic Water Demand Distribution to Each Node (Ratio in % ).....	A5.3.1 - 26
Table 2.4.4	Non Domestic Water Demand Distribution (Hourly Peak Demand Base in l/sec) .....	A5.3.1 - 27
Table 2.4.5	Total Water Discharge at Each Node in Year 2010 Hourly Peak Base in l/sec .....	A5.3.1 - 28
Table 2.4.6	Results of hydraulic Analysis.....	A5.3.1 - 29
Table 2.4.7	Length of Distribution Pipeline by Diameter .....	A5.3.1 - 23
Table 2.4.8	Comparison of PVC VS. PE .....	A5.3.1 - 35
Table 2.4.9	Distribution Trunk Main Required for Each Case.....	A5.3.1 - 37
Table 2.4.10	Costs of Distribution Trunk Main Required for Each Case.....	A5.3.1 - 37
Table 2.4.11	Estimated Water Consumption in Each Meter District.....	A5.3.1 - 39
Table 2.4.12	Length of Trunk Main Required Parallel Service Main.....	A5.3.1 - 42
Table 2.4.13	Number of Connections .....	A5.3.1 - 43

## List of Figures

	<u>Page</u>
Figure 2.1.1	Water Supply System Flow.....A5.3.1 - 2
Figure 2.2.1	Plan of Well Field .....A5.3.1 - 4
Figure 2.2.2	Pumping Test Results of PP-99-1.....A5.3.1 - 5
Figure 2.2.3	Pumping Test Results of PP-99-2.....A5.3.1 - 6
Figure 2.2.4	The Simulated Monthly Groundwater Level Fluctuation under Projected Pumping.....A5.3.1 - 8
Figure 2.2.5	Well Design Type-A .....A5.3.1 -9
Figure 2.2.6	Well Design Type-B .....A5.3.1 -10
Figure 2.2.7	Well Design Type-C .....A5.3.1 -11
Figure 2.2.8	Schematic Plan of Well Connecting Pipe .....A5.3.1 - 12
Figure 2.3.1	Layout of Proposed Distribution Center .....A5.3.1 - 17
Figure 2.3.2	Structure of Receiving Well.....A5.3.1 - 19
Figure 2.3.3	Structure of Clear Water Reservoir .....A5.3.1 - 20
Figure 2.4.1	Stage 1 Distribution Network .....A5.3.1 - 33
Figure 2.4.2	Network Diagram of Stage 1 Distribution Network.....A5.3.1 - 34
Figure 2.4.3	Proposed Meter District in Stage 1.....A5.3.1 - 40
Figure 2.4.4	Piping and Valve Arrangement for Meter District IV.....A5.3.1 - 41
Figure 2.4.5	District Meter.....A5.3.1 - 41
Figure 2.4.6	Typical House Connection .....A5.3.1 - 44
Figure 2.4.7	Number of House Connection .....A5.3.1 - 45

## ANNEX 5.3.1 THE PROJECT AND ITS FEASIBILITY STUDY

### 1. Introduction

Future water supply system, which will be constructed under the Stage 1 Project, is described in this Annex. Target year of the Stage 1 Project is year 2006. Basis of the facility planning is as shown on Table 1.1.

**Table 1.1 Basis of Facility Planning for the Stage 1 Project**

Description	Figures in Year 2006
Population in Service Area	39,244
Service Ratio	65 %
Served Population	25,508
Domestic Water Demand (Daily Average)	3,061 m <sup>3</sup> /day
Tourism Water Demand (Daily Average)	2,060 m <sup>3</sup> /day
Special Water Demand (Daily Average)	156 m <sup>3</sup> /day
Total Water Demand (Daily Average)	5,277 m <sup>3</sup> /day
Peak Factor for Domestic/Special Water Demand	1.2
Peak Factor for Tourism Water Demand	1.573
Total Water Demand (Daily Maximum)	8,352 m <sup>3</sup> /day
Hourly Peak Factor	1.2
Number of Domestic Connection	4,475
Total Number of Connection	4,797




### 2. Future Water Supply Facilities

#### 2.1 System Flow

Future water supply system flow which will use groundwater as its source is as shown on Figure 2.1.1.

Groundwater abstracted from each well will be sent to receiving well through connecting pipeline. Each five wells connected by one connecting pipeline and these five wells will form one unit. The water meter equipped on each well will measure quantity of groundwater abstraction. Liquid chlorine will be dosed for disinfection in the receiving well. Disinfected groundwater will be stored in the clear water reservoir to buffer hourly peak water demand. Water will be pumped to distribution network, after measurement by the main water meter. Method of water distribution is direct pumping and new/additional elevated tank will not be constructed.

Water production facilities such as wells, receiving well, clear water reservoir, and disinfection facilities were planned based on the Daily Maximum Water Demand. Distribution system such as distribution pumping station and distribution network were planned based on the Hourly Maximum Water Demand.



W : Well  
M : Water Meter

**Figure 2.1.1**  
Water Supply System Flow

## **2.2 Production Facilities**


### **2.2.1 Well Field**

10 wells to be constructed under the Stage 1 will be located along the National Road No. 6 with 400 m intervals. Additional 5 wells to be constructed under stage 2 will be located along the branch road from the National Road No. 6 to the West Baray Reservoir. Plan of the well field is shown on Figure 2.2.1

The specification of the wells is based on the groundwater simulation analysis and pumping test result. The well is designed to meet the drawdown depth requirement with safety clearance, well interference, and diameter of the submersible pump to be installed. The material for the casing and screen pipes is PVC, which is durable against corrosion by low pH groundwater.

#### Detail Well Design

The safe yield from each well is around 800 m<sup>3</sup>/day considering a drawdown of 5 meter. This is also confirmed from the critical state of well as shown in Figure 2.2.2 and 2.2.3. First stage total demand of 8,000 m<sup>3</sup>/day can be met by 10 wells. The groundwater simulation result in the Main Report Section 4.2.4 states that additional groundwater lowering may arise by the well interference effects caused by the steady operation of the total 15 well. The simulation result confirmed that with this modification there would be no impact on surrounding wells and Angkor heritage.




The Study on Water Supply System for Siem Reap Region in Cambodia

Figure 2.2.1  
Plan of Well Field



Item	Discharge			Drawdown (m)	Remarks
	(liter/sec)	(liter/min)	(m <sup>3</sup> /day)		
1st Step	5.0	300	432	1.17	
2nd Step	10.0	600	864	6.14	
3rd Step	11.6	700	1,000	7.79	Continuous test
4th Step	15.0	900	1,300	10.24	
5th Step	21.7	1,300	1,875	17.00	Preliminary test





Note

Analyzed by Jacob Method

Permeability Coefficient  $k = 7 \times 10^{-3}$  cm/sec in average from the above 2 data (#1 and #2)

The data was used for the Groundwater simulation




The Study on Water Supply System  
for Siem Reap Region in Cambodia

Japan International Cooperation Agency.

Figure 2.2.2  
Pumping Test Results of PP-99-1

Item	Discharge			Drawdown (m)	Remarks
	(liter/sec)	(liter/min)	(m <sup>3</sup> /day)		
1st Step	3.22	194	280	0.55	
2nd Step	5.98	360	517	3.65	
3rd Step	9.00	540	780	4.94	Continuous test
4th Step	9.10	545	785	6.64	
5th Step	11.70	700	1,011	15.88	Preliminary test




Note

Analyzed by Jacob Method

Case-1 was adopted for simulation analysis, case-2 was judged that discharge was changed  
Permeability Coefficient  $k = 1 \times 10^{-2}$  cm/sec in average from the above 2 data (#1 and #2)

The data was used for the Groundwater simulation



The Study on Water Supply System  
for Siem Reap Region in Cambodia

Japan International Cooperation Agency

Figure 2.2.3  
Pumping Test Results of PP-99-2



Because of the different drawdown in different wells, some modification is done in the well design. The detail of the well design is summarized below based on Figure 2.2.4. Each well is designed as the yield capacity of 800 m<sup>3</sup>/day (9.3 liters/sec/well in average).

Well Nos.      Expected Groundwater Lowering by Composite Cone of depression

1-1 (Type-A)	0.5 m	(SWL: 1.5 m, PWL: 7.5m, Pump set depth: 9 m)
1-2 (Type-A)	0.5-1.0 m	(SWL: 2.0 m, PWL: 7.5m, Pump set depth: 9 m)
1-3 (Type-A)	1.0 m	(SWL: 2.0 m, PWL: 7.5m, Pump set depth: 9 m)
1-4 (Type-A)	1.0-1.5 m	(SWL: 2.5 m, PWL: 7.5m, Pump set depth: 9 m)
1-5 (Type-A)	1.5 m	(SWL: 2.5 m, PWL: 7.5m, Pump set depth: 9 m)
1-6 (Type-B)	2.0 m	(SWL: 3.0 m, PWL: 8.0m, Pump set depth: 10 m)
1-7 (Type-C)	2.5 m	(SWL: 4.5 m, PWL: 10.0m, Pump set depth: 12 m)
1-8 (Type-C)	2.5 m	(SWL: 4.5 m, PWL: 10.0m, Pump set depth: 12 m)
1-9 (Type-B)	2.0 m	(SWL: 3.0 m, PWL: 8.0m, Pump set depth: 10 m)
1-10 (Type-A)	0.5 m	(SWL: 1.5 m, PWL: 6.5m, Pump set depth: 9 m)
2-1 (Type-B)	2.0 m	(SWL: 3.5 m, PWL: 8.5m, Pump set depth: 11 m)
2-2 (Type-C)	3.0 m	(SWL: 4.5 m, PWL: 9.5m, Pump set depth: 13 m)
2-3 (Type-C)	3.0 m	(SWL: 4.5 m, PWL: 9.5m, Pump set depth: 13 m)
2-4 (Type-B)	2.5 m	(SWL: 3.5 m, PWL: 8.5m, Pump set depth: 10 m)
2-5 (Type-A)	1.0 m	(SWL: 1.5 m, PWL: 6.5m, Pump set depth: 9 m)

(SWL: Static Water Level, in the lowest PWL: Pumping Water Level)

The variation of drawdown, the static water level and dynamic water level of each production well is estimated based on the effects of composite cone depression of the groundwater table, the well alignment and the hydrogeological condition of the well field. Pump set depth is designed after considering the clearance of 1.5 to 3.5 m for a safety. Further the clearance between the upper-most depth of the screen and the pump set depth is designed as 1 to 4 m for a safety. Well design of Type-A, Type-B and Type-C are described in Figure 2.2.5, Figure 2.2.6 and Figure 2.2.7 respectively.




drawdowns in detail

The Study on Water Supply System  
for Siem Reap Region in Cambodia

Japan International Cooperation Agency

Figure 2.2.4  
The Simulated Drawdown Contours  
in 5 Years




- Note**
- 1: Opening ratio of the Screen shall be approximately 2 %.  
The size of slit in screen is 1.0 mm wide and 100 mm in length.
  - 2: Gravel packing quantity is around 5.3 m<sup>3</sup> (200 bags).
  - 3: Sand filter by using medium river sand for 7-9 m shall be put to purify shallow groundwater
  - 4: This design shall be applied for the 6 wells in the stage-1(No.1-1, N0.1-2, N0.1-3 N0.1-4, N0.1-5 and N0.1-10), and the 1 well in the stage-2(N0.2-5)

The Study on Water Supply System  
for Siem Reap Region in Cambodia

Japan International Cooperation Agency

**Figure 2.2.5**  
**Well Design Type-A**




- Note 1:** Opening ratio of the Screen shall be approximately 2 % .  
The size of slit in screen is 1.0mm wide and 100mm in length.
- 2:** Gravel packing quantity is around 5.3 m<sup>3</sup> (200 bags).
- 3:** Sand filter by using medium river sand for 7 - 9m shall be put to purify shallow groundwater
- 4:** This design shall be applied for the 2 wells in the stage-1(No.1-6 and No.1-9), and the 2 wells in the stage-2(No.2-1 and No.2-4)

The Study on Water Supply System  
for Siem Reap Region in Cambodia

**Figure 2.2.6**  
Well Design Type-B

Japan International Cooperation Agency



- Note**
- 1: Opening ratio of the Screen shall be approximately 2 % .  
The size of slit in screen is 1.0mm wide and 100 mm in length.
  - 2: Gravel packing quantity is around 5.3 m<sup>3</sup> (200 bags).
  - 3: Sand filter by using medium river sand for 7 - 9m shall be put to purify shallow groundwater
  - 4: This design shall be applied for the 2 wells in the stage-1(No.1-7 and No.1-8), and the 2 wells in the stage-2(No.2-2 and No.2-3)

The Study on Water Supply System  
for Siem Reap Region in Cambodia


Japan International Cooperation Agency

**Figure 2.2.7**  
**Well Design Type-C**


**2.2.2 Well Connecting Pipe**

Schematic plan of well connecting pipes is shown on Figure 2.2.8. Every five wells are connected by one connecting pipe of which diameter is 150 mm to 250 mm. Ductile Cast Iron Pipe (DIP) will be recommended for the material of the connecting pipe because of its reliability and easy installation work, especially in rainy season.

The results of hydraulic analysis of the well connecting pipe is shown on Table 2.2.1. Based on the results of the analysis, specifications of submersible pump in respective wells are decided.



**Figure 2.2.8 (1/2) Schematic Plan of Well Connecting Pipe :  
Unit 1 (Well Number 1-1 to 1-5)**



**Figure 2.2.8 (2/2) Schematic Plan of Well Connecting Pipe :  
Unit 2 (Well Number 1-6 to 1-10)**



**Table 2.2.1 (1/2) Results of Hydraulic Analysis on Well Connecting Pipe  
Unit 1 (Well Number 1-1 to 1-5)**

NODE NO	Type	Q l/sec	WL m	GL m	EH m
0	1	46.295	16.00	14.00	2.00
11	0	-9.259	25.26	15.00	10.26
12	0	-9.259	23.91	15.00	8.91
13	0	-9.259	22.71	15.00	7.71
14	0	-9.259	20.16	15.00	5.16
15	0	-9.259	18.70	15.00	3.70
30	0		25.20	14.00	11.20
31	0		23.85	14.00	9.85
32	0		22.65	14.00	8.65
33	0		20.11	14.00	6.11
34	0		18.65	14.00	4.65

PIPE NO(u)	NO(d)	Dia mm	Length m	C	Q l/sec	V m/sec	I o/oo
11	30	150	20	120	9.26	0.52	2.70
12	31	150	20	120	9.26	0.52	2.70
13	32	150	20	120	9.26	0.52	2.70
14	33	150	20	120	9.26	0.52	2.70
15	34	150	20	120	9.26	0.52	2.70
30	31	150	500	120	9.26	0.52	2.70
31	32	200	500	120	18.52	0.59	2.40
32	33	200	500	120	27.78	0.88	5.09
33	34	250	500	120	37.04	0.75	2.92
34	0	250	600	120	46.30	0.94	4.41

**Table 2.2.1 (2/2) Results of Hydraulic Analysis on Well Connecting Pipe  
Unit 2 (Well Number 1-6 to 1-10)**

NODE NO	Type	Q l/sec	WL m	GL m	EH m
0	1	46.295	16.00	14.00	2.00
16	0	-9.259	18.70	15.00	3.70
17	0	-9.259	20.16	15.00	5.16
18	0	-9.259	22.71	15.00	7.71
19	0	-9.259	23.91	14.00	9.91
110	0	-9.259	25.26	14.00	11.26
35	0		18.65	14.00	4.65
36	0		20.11	14.00	6.11
37	0		22.65	14.00	8.65
38	0		23.85	13.00	10.85
39	0		25.20	13.00	12.20

PIPE NO(u)	NO(d)	Dia mm	Length m	C	Q l/sec	V m/sec	I o/oo
16	35	150	20	120	9.26	0.52	2.70
17	36	150	20	120	9.26	0.52	2.70
18	37	150	20	120	9.26	0.52	2.70
19	38	150	20	120	9.26	0.52	2.70
110	39	150	20	120	9.26	0.52	2.70
39	38	150	500	120	9.26	0.52	2.70
38	37	200	500	120	18.52	0.59	2.40
37	36	200	500	120	27.78	0.88	5.09
36	35	250	500	120	37.04	0.75	2.92
35	0	250	600	120	46.29	0.94	4.41

Length of well connecting pipe is summarized as shown on Table 2.2.2.

**Table 2.2.2 Length of Well Connecting Pipe**

Diameter (mm)	Unit 1 (Well No. 1-1 to 1-5)	Unit 2 (Well No. 1-6 to 1-10)	Total Length (m)
250	1,000	1,000	2,000
200	800	800	1,600
150	500	500	1,000
Total	2,300	2,300	4,600

### 2.2.3 Well Submersible Pump

Specifications of well submersible pumps are designed from the head loss in the well connecting pipes and level of groundwater. Head loss in the well connecting pipes are already shown in Table 2.2.1 above. Static groundwater level and groundwater level draw down by continuous pumping are shown on Table 2.2.3 together with calculated total head required for each submersible pump.

From the calculated total head required, capacity of each submersible pump is obtained as shown on Table 2.2.4 and submersible pumps required is summarized in Table 2.2.5.

Number of operating pumps will increase year by year along with water demand increase. Table 2.2.6 shows the number of operating pumps in each year.

**Table 2.2.3 Total Head Required at Each Submersible Pump**

Well Number	Abstraction (m <sup>3</sup> /min)	Ground Level (m) (above sea)	Static Water Level (m) (above sea)	Draw down by Pumping (m)	Head Required at Well (m) (above sea)	Total Head Required (m)
1-1	0.56	15	13.5	6.0	25.26	17.8
1-2	0.56	15	13.0	5.5	23.91	16.4
1-3	0.56	15	13.0	5.5	22.71	15.2
1-4	0.56	15	12.5	5.0	20.16	12.7
1-5	0.56	15	12.5	5.0	18.70	11.2
1-6	0.56	15	12.0	5.0	18.70	11.7
1-7	0.56	15	10.5	5.5	20.16	15.2
1-8	0.56	15	10.5	5.5	22.71	17.7
1-9	0.56	14	11.0	5.0	23.91	17.9
1-10	0.56	14	12.5	5.0	25.26	17.8

**Table 2.2.4 Capacity of Each Submersible Pump**

Well Number	Abstraction (m <sup>3</sup> /min)	Total Head Required (m)	Calculated Power Required (kW)	Standard Output (kW)
1-1	0.56	17.8	3.1	3.7
1-2	0.56	16.4	2.8	3.7
1-3	0.56	15.2	2.6	3.7
1-4	0.56	12.7	2.2	2.2
1-5	0.56	11.2	1.9	2.2
1-6	0.56	11.7	2.0	2.2
1-7	0.56	15.2	2.6	3.7
1-8	0.56	17.7	3.1	3.7
1-9	0.56	17.9	3.1	3.7
1-10	0.56	17.8	3.1	3.7

**Table 2.2.5 Summary of Submersible Pumps Required under Stage 1**

Submersible Pumps	Number of Pumps Required
Q 0.56 m <sup>3</sup> /min x H11.2-12.2 x 2.2kW	3 units
Q 0.56 m <sup>3</sup> /min x H14.7-17.8 x 3.7kW	7 units

**Table 2.2.6 Number of Operating Pumps in Each Year**

Year	Daily Maximum Water Demand		Number of Operating Pumps
	m <sup>3</sup> /day	m <sup>3</sup> /min	
2002	2,773	1.9	4
2003	4,217	2.9	6
2004	5,905	4.1	8
2005	7,308	5.1	10
2006	8,352	5.8	10

## **2.3 Distribution Center**

### **2.3.1 Location and Plan of Distribution Center**

Distribution Center will consist of receiving well, clear water reservoir, disinfection facilities, distribution pumping station and generators. The center will require about 1 ha land space to accommodate these facilities. Proposed location of the center was selected after consultation with local government and PDIME. Location will be at the side of the branch road to the West Baray Reservoir from the National Road No. 6. Distance from the center to the Road No. 6 is about 200 m. The center will be located at the middle of the proposed well field.

Figure 2.3.1 shows the layout of the Distribution Center. As shown in the figure, reserved space will be required for the expansion of clear water reservoir for the Stage 2.

According to the results of the water quality analysis of groundwater adjacent to the proposed well field, no iron removal facilities will be required. However, should iron concentration become high in future, it is recommended to remove iron by slow sand filtration. Iron will be oxidized and removed by the iron bacteria layer developed on the surface of the slow sand filters. To accommodate required slow sand filtration system, additional 0.5 ha land space might be required if iron concentration becomes high in future. Furthermore, replacement of submersible pumps in wells with higher pump head and reconstruction of the receiving well will be required.


It should be noted that these iron removal facilities and modification of the system flow are not included in Stage 1 Project.

### **2.3.2 Receiving Well**

From the two units of wells under Stage 1, each unit consisting of five wells, groundwater will be conveyed to the receiving well. Purpose of the receiving well is to regulate the water flow and to dose and mix chlorine solution for disinfection.

Capacity of the receiving well is 42 m<sup>3</sup> (effective depth 3 m, area 14 m<sup>2</sup>) and this is equivalent to 5 minutes of Stage 2 production capacity of 12,000 m<sup>3</sup>/day. The receiving well with the capacity of the Stage 2 will be constructed under the Stage 1 because the size of the well is small and can not be constructed separately for each stage. Structures will be RC made and high water level of the receiving well will be +16.0 m.

Structure of the receiving well will be as shown on Figure 2.3.2. The receiving well will be equipped with over flow pipe and drain.



The Study on Water Supply System  
for Siem Reap Region in Cambodia  
Japan International Cooperation Agency

Figure 2.3.1  
Layout of Proposed  
Distribution Center

AS.3.1-17

Lime solution feeder will also be equipped at the receiving well for pH control . Value of pH will be checked daily basis and if pH value is too low, lime solution will be dosed.

### **2.3.3 Disinfection Facilities**


Chlorine gas will be fed by solution-feed chlorinators. Solution-feed chlorinators take gaseous chlorine evaporated in the container, measure it, and mix it with water to form a strong chlorine solution. The chlorine solution will be fed in the receiving well mentioned above.

Two sets of chlorinators will be installed in the Chlorinator House under Stage 1. The Chlorinator House will also have a space for storage of the gas cilliynders.


### **2.3.4 Clear Water Reservoir**

Clear water reservoir will be constructed to balance the fluctuating demand from the distribution system against the output from the wells, and to act as a safeguard for the continuation of the supply should there be any breakdown at the source or on the main trunk distribution pipelines.

Detention time of the reservoir is about 8 hours. Reservoir volume is calculated from the detention time. The clear water reservoir will consist from three basins. Two of them will be constructed under Stage 1 and the other will be constructed under Stage 2. Structure of the reservoir will be RC made and dimension of the each basin will be W 15 m x L 25 m x Depth 3.5 m. In the reservoir, buffer walls will be installed to avoid dead water space and pump suction well will be constructed as part of the reservoir. Structure of the clear water reservoir is as shown on Figure 2.3.3.




Plan




Section

<p>The Study on Water Supply System for Siem Reap Region in Cambodia</p>	<p>Figure 2.3.2 Structure of Receiving Well</p>
<p>Japan International Cooperation Agency</p>	



Plan



Section

The Study on Water Supply System  
for Siem Reap Region in Cambodia

Japan International Cooperation Agency

Figure 2.3.3

Structure of Clear Water Reservoir



### 2.3.5 Distribution Pumping Station

Distribution pumping station will be constructed to store distribution pumps that will transmit water to distribution system in Siem Reap Town area through distribution trunk main.

Flow of transmitting water will be controlled by number of operating pumps. Therefore, capacity of each pump will be planned rather small. List of distribution pumps is shown on Table 2.3.1.

**Table 2.3.1 List of Distribution Pumps**

Distribution Pumps	Number Required for Stage 1
1.0 m <sup>3</sup> /min x H35 m, 11kW	3
1.82 m <sup>3</sup> /min x H35 m, 18.5kW	4

Number of operating distribution pumps will be decided by quantity of hourly maximum water demand. Pump operation plan is as shown on Table 2.3.2. As shown on the Table, one stand-by for small and large pumps is available respectively.

**Table 2.3.2 Pump Operation Plan**

Year	Hourly Max		Distribution Pumps						
	l/sec	m <sup>3</sup> /min	SP1	SP2	SP3	LP1	LP2	LP3	LP4
2002	38.51	2.31	OP			OP			
2003	57.43	3.45				OP	OP		
2004	79.56	4.77	OP	OP		OP	OP		
2005	98.35	5.90	OP			OP	OP	OP	
2006	112.4	6.74	OP	OP		OP	OP	OP	

SP: Small Pump of which capacity is 1.0 m<sup>3</sup>/min

LP: Large Pump of which capacity is 1.82 m<sup>3</sup>/min

OP: Operating

### 2.3.6 Power Source

Own generator system is proposed to supply electricity for well pumps, distribution pumps and lighting etc. of new water supply system, considering the current situation that public electric supply in Siem Reap is not stable and reliable, and the capacity of the public supply will not be guaranteed for future power requirement. List of generators required for the new system is as shown on Table 2.3.3.

**Table 2.3.3 List of Generators Required**

Generator	Number Required for Stage 1
For Submergible Pumps (3P75kVA w/Fuel Tank)	4
For Distribution Pumps (3P150kVA w/Fuel Tank)	4