

2.1 Asin Pumping Station



2.1.5 Structural Calculation of Pumping Station

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	1/42
CONTENTS					
1.	General Layout				
2.	Design Criteria				
2.1	Materials				
2.2	Loads				
2.3	Cases of Analysis				
3.	Stability Analysis				
3.1	Weight of Screw				
3.2	Weight of Machine and Other Structures				
3.3	Weight of Pump Control Building				
3.4	Weight of Civil Structure				
3.5	Weight of Water				
3.6	Hydrostatic Pressure				
3.7	Earth Pressure				
3.8	Seismic Force				
3.9	Total Forces				
3.10	Pile Foundation Analysis				
3.11	Safety Against Buoyancy				
4.	Reinforcing Bar Calculation				
4.1	Stress Calculation of Members				
4.2	Reinforcing Bar Calculation				

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	2/42
<p>1. General Layout</p> <p>The dimension of pump house is determined by layout of machine. The general layout is shown in Fig.1.</p> <p>(1) Up/down stream direction</p> <p>L1: space for stop log</p> <p>L2: space for inspection road for stop log</p> <p>L3: space for screen belt conveyor (in future)</p> <p>L4: space for inspection road for screw and gates</p> <p>L5: space for screw</p> <p>L6: space for gear and engine</p> <p>L7: space for pump control building</p> <p>(2) Design water level</p> <p>WL1: design high water level Semarang River Side</p> <p>WL2: design high water level behind the screen</p> <p>WL3: design low water level behind the screen</p> <p>WL4: design high water in the pump pond</p> <p>WL5: design low water level in the pump pond</p> <p>(3) Design structure elevation</p> <p>EL1: pumping station ground level</p> <p>EL2: pump pond bottom elevation</p> <p>EL3: screen bottom elevation</p> <p>(4) Right/left bank direction</p> <p>W1: space for inspection road</p> <p>W2: space for screw/engine system</p>					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	3/42
-------------------	----------------------	----------------------	---------------------	------	------

Figure 1 General Layout



Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	4/42
<p>(5) Structure configuration</p> <p>The total length of the pump house including the intake basin is 35 m and it is too long to construct in one piece of concrete structure, considering the development of cracks caused by contraction of concrete.</p> <p>Looking at the location of machines and the force distribution, it is reasonable to make a contraction joint between the screen floor and the screw floor. As the screw is supported by both top slab and the bottom slab of the pump house, it is necessary to make the two slabs act as one structure.</p> <p>This main structure has a total length of 25 meter, but because of difference of elevation, the whole concrete can not be cast at one time. Therefore, no excess thermal stress is expected in the structure, although the length is longer than the standard value stated in the design criteria (15m).</p> <p>Thus, the structural configuration of the pump house is designed as follows;</p> <p><u>Front Structure</u>: independent structure to support the weight of intake basin, maintenance bridge No.2 and screen and belt conveyor (in future).</p> <p><u>Main Structure</u>: single structure to support the weight of screw, gear system engine and all the building load.</p> <p>The contraction joint of the two structures shall be equipped with water stop made of vinyl chloride</p>					
<p>2. Design Criteria</p> <p>Design Criteria is described in "Design Criteria", Vol.III, Interim Report(4).</p>					
<p>2.1 Materials</p> <p>Materials applied in calculation is as follows;</p> <ul style="list-style-type: none"> - Reinforced Concrete <ul style="list-style-type: none"> unit weight 2.50 m³/t compressive strength $C_1 = \sigma_{28} = 225 \text{ kgf/cm}^2$ $C_2 = \sigma_{28} = 225 \text{ kgf/cm}^2$ - Reinforcing Bar (SII U-30 or JIS SD-30) <ul style="list-style-type: none"> allowable stress <ul style="list-style-type: none"> above ground elevation : 1800 kgf/cm² below ground elevation : 1600 kgf/cm² - Soil (sandy soil, compacted) <ul style="list-style-type: none"> unit weight wet $\gamma = 1.9 \text{ tf/m}^3$ submerged $\gamma = 0.9 \text{ tf/m}^3$ internal friction angle $\phi = 25.6^\circ (N=7.5)$ 					
<p>2.2 Loads</p> <p>Loads to be considered are listed below.</p>					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	5/42
-------------------	----------------------	----------------------	---------------------	------	------

Normal condition


Wc: weight of concrete slab including inspection path no.1 and no.2

Ww: weight of water

Wm: weight of machine and other structures

Pe: earth pressure

Pws: hydro-static pressure



Seismic condition

Wc: weight of concrete slab including inspection path no.1 and no.2

Ww: weight of water


Wm: weight of machine and other structures

Ic, Im: seismic inertia of above all items except water

Pes: seismic earth pressure

Pws: hydro-static pressure

Pwd: hydro-dynamic pressure



Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	6/42
-------------------	----------------------	----------------------	---------------------	------	------

2.3 Cases of Analysis

(1) Seismic status

Structural analysis is to be made in both normal condition (without earthquake) and seismic condition (with earthquake).

(2) Operation status

Since an operated screw generates dynamic force, the analysis is to be made in both cases of with pump operation and without pump operation.

(3) Stoplog status

When stop log is closed, hydrostatic pressure acts on the stoplog. Therefore, both stoplog-open and stoplog-closed status should be considered.

(4) Combination of status

When the stop log is closed, the screw pump is not operated for maintenance purpose. Therefore, combination of status is as follows;

Case	Seismic status	Pump operation status
1	Normal	Not operated
2	Normal	Operated
3	Earthquake	Operated
4	Earthquake	Not operated

3. Stability Analysis

3.1 Weight of Screw

3.1.1 General

In the design of civil structure, all forces acting from machine shall be taken into account. They include weight of screw itself, weight of water lifted and reaction from the water lifted. There are three calculation cases as follows;

- (case 1) normal condition without operation
- (case 2) normal condition with operation
- (case 3) seismic condition with operation
- (case 4) seismic condition without operation

3.1.2 Weight of screw

Calculation of screw weight is done for the shaft and the screw as shown below.

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	7/42
-------------------	----------------------	----------------------	---------------------	------	------

(1) Weight of the shaft

Weight of the shaft is calculated as follows;

$$W = 1 \times 3.14 \times \frac{(D_o + D_i)}{2} \times t \times W_s$$

where

- l ; length of shaft
- Do ; outer diameter
- Di ; inner diameter
- t ; thickness of plate
- ws ; unit weight of steel

here for Asin Pumping station

- l = 13 m
- Do = 1.500 m
- Di = 1.490 m
- t = 0.012 m
- Ws = 7.85 t/m³

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	8/42
-------------------	----------------------	----------------------	---------------------	------	------

therefore

$$W = 1 \times 3.14 \times \frac{(1.500 + 1.488)}{2} \times 0.0012 \times 7.85$$

$$= 5.74 \text{ t}$$

(2) Weight of propeller

Weight of propeller is calculated as follows;

$$W = n \times 3.14 \times \frac{(D_o \times D_o - D_i \times D_i)}{4} \times t \times W_s \times \sqrt{2}$$

where
n : number of screw
Do : outer diameter of screw
Di : inner diameter of screw
t : thickness of plate
Ws : unit weight of steel

here
n = length of screw/pitch \times number of flight
 $= \frac{12}{3} \times 3$
 $= 12$

Do = 3.0m
Di = 1.5m
t = 0.010m
Ws = 7.85 t/m³

therefore

$$W = 12 \times 3.14 \times \frac{(3 \times 3 - 1.5 \times 1.5)}{4} \times 4 \times 0.010 \times 7.85 \times \sqrt{2}$$

$$= 4.99 \times \sqrt{2}$$

$$= 7.06$$

(3) Total weight of screw

Total weight of screw = weight of shaft + weight of propeller
 $= 5.74 + 7.06$
 $= 12.80$

By adding 10% for other parts

total weight of screw system = $12.80 \times 1.1 = 14.1 \text{ t}$

The direction of the force is vertical and it is divided into axial and radial components.

Axial component = $14.1 \times \sin 30^\circ = 7.05 \text{ t}$

Radial component = $14.1 \times \cos 30^\circ = 12.21 \text{ t}$

3.1.3 Weight of water lifted

The weight of water lifted is calculated as follows;

$$W = 12 \times 3.14 \times \frac{(3 \times 3 - 1.5 \times 1.5)}{4} \times 4 \times 0.010 \times 7.85 \times \sqrt{2}$$

$$= 4.99 \times \sqrt{2}$$

$$= 7.06$$


Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	9/42
<p>where</p> <p>W : weight of water lifted (t)</p> <p>l : length of shaft (m)</p> <p>Dp : diameter of propeller (m)</p> <p>Ds : diameter of shaft (m)</p> <p>Ww : unit weight of water (t/m³)</p> $W = 12 \times 3.14 \times \frac{1}{2} \times \frac{(1.5 \times 1.5 - 0.75 \times 0.75)}{4} \times W_w$ $= 7.948 \text{ t}$ <p>The weight is divided into axial component and radial component</p> <p>Axial component = $7.948 \times \sin 30^\circ = 3.97 \text{ t}$ (supported by the propeller)</p> <p>Radial component = $7.948 \times \cos 30^\circ = 6.88 \text{ t}$ (supported by the concrete bed)</p> <p>3.1.4 Reaction of water lifted</p> <p>The reaction of water lifter is calculated as follows;</p> <p>Fr = $Q \times v \times W_w$</p> <p>where</p> <p>Fr : reaction of water lifted (t)</p> <p>Q : discharge (m³/s)</p> <p>v : velocity of water (m/s)</p> <p>Ww : unit mass of water (t/m³)</p> <p>here</p> <p>Q = 3 m³/s</p> <p>v = Q/A</p> <p>A = section area of flow</p> $= \frac{1}{2} \times 3.14 \times (1.5^2 - 0.75^2)$ $= 2.649 \text{ m}^2$ $= \frac{3}{2.649} = 1.13 \text{ m/s}$ <p>Ww = 1.0 t/m³</p> <p>therefore</p> <p>Fr = $3 \times 1.13 \times 1$</p> $= 3.39 \text{ t}$ <p>The direction of the force is axial.</p> <p>3.1.5 Combination of force</p> <p>(case-1) normal condition without operation</p> <p>weight of screw : axial component = 7.05 ~ 8 t</p> <p>radial component = 12.21 ~ 13 t</p> <p>(case-2) normal condition with operation</p> <p>weight of screw : axial component = 7.05 t</p> <p>radial component = 12.21 t</p> <p>weight of water lifted : axial component = 3.97 t</p>					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	10/42
		radial component	= 6.88t		
		axial component	= 0		
		radial component	= 3.39 t		
		axial component	= 7.05+3.97+0= 11.02 ~ 12t		
		radial component	= 12.21+6.88+3.39=22.48 ~ 23t		
(case-3) seismic condition with operation					
		axial component	= 7.05 t		
		radial component	= 12.21 t		
		axial component	= 3.97t		
		radial component	= 6.88t		
		seismic force acting on the screw			
		seismic force (horizontal)= 14.08(weight)×0.11(seismic coefficient)=1.55 t			
		axial component	= 1.55×COS30° = 1.34 t		
		radial component	= 1.55 × SIN30°=0.78 t		
		seismic force acting on water			
		seismic force (horizontal) = 7.948(weight)×0.11(scismic coefficient)=0.87t			
		axial component	= 0.87 × COS30° = 0.75 t		
		radial component	= 0.87 × SIN30° = 0.44 t		
		axial component	= 0		
		radial component	= 3.39 t		
		axial component	= 7.05+3.97+1.34+0.75 = 13.11~14 t		
		radial component	=12.21+6.88+0.78+0.44+3.39=23.17~24t		
(case-4) seismic condition without operation					
		axial component	= 7.05 t		
		radial component	= 12.21 t		
		axial component	= 1.34 t		
		radial component	= 0.78 t		
		axial component	= 7.05 + 1.34 = 8.39 t ~ 9 t		
		radial component	= 12.21 + 0.78 = 12.99 ~ 13 t		

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	11/42
The conclusion is					
case(1) normal without operation		axial force	= 8 t		
		radial force	= 13 t		
case(2) normal with operation		axial force	= 12 t		
		radial force	= 23 t		
case(3) seismic with operation		axial force	= 14 t		
		radial force	= 24 t		
case(4) seismic without operation		axial force	= 9 t		
		radial force	= 13 t		
All cases and acting points are shown in Table – 1.					
In structural analysis of concrete slab, the axial forces shall be applied on both ends of the screw shaft as the full force, considering the uncertainty of force distribution. However, the radial forces shall be applied on both ends of the screw as the half of the force as it is certainly distributed evenly .					
3.2 Weight of Machine and Other Structures					
The location of machine and other structure is shown in Fig. 2.					
The weight of machine and other structures are shown in Table - 2.					
The machines to be considered are screw, gear box, engine and screen. For gear box, engine and screen, estimation by factories are adopted. For screen system, future installation is taken into account.					
Stop log		3 t			
Imbeded material		3 t			
Inspection bridge		12 t			
Screen		8 t			
Belt conveyor		50 t			
Secondary concrete		91 t			
Gear box		2 t			
Engine		17 t			
Bridge		47 t			
The seismic force acting on each machine can be calculated by multiplying seismic coefficient $K_h = 0.11$ to the weight of machine.					
3.3 Weight of Pump Control Building					
The weight of the Pump Control Building (architectural design) is adssumed as 2.5 t/m².					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	12/42
-------------------	----------------------	----------------------	---------------------	------	-------

Fig. 2 Location of Machines and Other Structures



Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	14/42
-------------------	----------------------	----------------------	---------------------	------	-------

Table - 2 Weight of Machine and Other Structures



name	Y ₀ = -6.5 weight	x	Mx	acting point y	My	z	Mz
front structure							
stop log no.1	-3.00	1.15	-3.45	4.20	-12.60	3.00	-9
stop log no.2	-3.00	1.15	-3.45	4.20	-12.60	8.00	-24
stop log no.3	-3.00	1.15	-3.45	4.20	-12.60	13.00	-39
imbeded material no.1	-3.00	1.15	-3.45	4.20	-12.60	3.00	-9
imbeded material no.2	-3.00	1.15	-3.45	4.20	-12.60	8.00	-24
imbeded material no.3	-3.00	1.15	-3.45	4.20	-12.60	13.00	-39
inspection bridge-No.1-1	-12.00	3.00	-36.00	7.50	-90.00	3.00	-36
inspection bridge-No.1-2	-12.00	3.00	-36.00	7.50	-90.00	8.00	-96
inspection bridge-No.1-3	-12.00	3.00	-36.00	7.50	-90.00	13.00	-156
screen no.1	-8.00	6.50	-52.00	2.80	-22.40	3.00	-24
screen no.2	-8.00	6.50	-52.00	2.80	-22.40	8.00	-64
screen no.3	-8.00	6.50	-52.00	2.80	-22.40	13.00	-104
beltconbeyor	-56.00	9.25	-518.00	7.70	-431.20	8.00	-448
total	-134.00	5.99	-802.70	6.30	-844.00	8.00	-1072
main structure A							
inspection bridge-No.2-1	-12.00	11.50	-138.00	7.50	-90.00	3.00	-36
inspection bridge-No.2-2	-12.00	11.50	-138.00	7.50	-90.00	8.00	-96
inspection bridge-No.2-3	-12.00	11.50	-138.00	7.50	-90.00	13.00	-156
screw system no.1(bottom)	-7.05	13.38	-94.34	1.80	-12.69	3.00	-21.15
screw system no.2(bottom)	-7.05	13.38	-94.34	1.80	-12.69	8.00	-56.4
screw system no.3(bottom)	-7.05	13.38	-94.34	1.80	-12.69	13.00	-91.65
total	-57.15	12.20	-697.03	5.39	-308.07	8.00	-457.2
main structure B				1.64			
secondary concrete no.1	-90.95	16.81	-1,528.48	6.21	-564.86	3.00	-272.8369
secondary concrete no.2	-90.95	16.81	-1,528.48	6.21	-564.86	8.00	-727.5651
secondary concrete no.3	-90.95	16.81	-1,528.48	6.21	-564.86	13.00	-1182.293
bridge-Cno.1	-6.50	25.35	-164.79	11.55	-75.08	3.00	-19.5
bridge-Cno.2	-6.50	25.35	-164.79	11.55	-75.08	8.00	-52
bridge-Cno.3	-6.50	25.35	-164.79	11.55	-75.08	13.00	-84.5
total	-292.34	17.38	-5079.79	6.57	-1919.82	8.00	-2338.70
main structure C							
screw system no1.(top)	-7.05	27.00	-190.35	9.66	-68.12	3.00	-21.15
screw system no.2(top)	-7.05	27.00	-190.35	9.66	-68.12	8.00	-56.4
screw system no3.(top)	-7.05	27.00	-190.35	9.66	-68.12	13.00	-91.65
gear box no.1	-2	29.10	-58.20	10.44	-20.87	3.00	-6
gear box no.2	-2	29.10	-58.20	10.44	-20.87	8.00	-16
gear box no.3	-2	29.10	-58.20	10.44	-20.87	13.00	-26
engine no.1	-13	31.00	-403.00	10.44	-135.68	3.00	-39
engine no.2	-13	31.00	-403.00	10.44	-135.68	8.00	-104
engine no.3	-13	31.00	-403.00	10.44	-135.68	13.00	-169
bridge-Cno.1-1	-10.00	27.50	-275.00	11.55	-115.50	3.00	-30
bridge-Cno.2-1	-10.00	27.50	-275.00	11.55	-115.50	8.00	-80
bridge-Cno.3-1	-10.00	27.50	-275.00	11.55	-115.50	13.00	-130
bridge-Cno.2-2	-31.63	31.50	-996.19	9.15	-289.37	3.00	-94.875
bridge-Cno.2-2	-31.63	31.50	-996.19	9.15	-289.37	8.00	-253
bridge-Cno.3-2	-31.63	31.50	-996.19	9.15	-289.37	13.00	-411.125
total	-191.03	30.20	-5768.21	9.89	-1888.64	8.00	-1528.20

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	15/42
-------------------	----------------------	----------------------	---------------------	------	-------

3.4 Weight of Civil Structure

Weight of civil structure is calculated by dividing it into small parts as show in the figure below.

Table 3 shows the forces acting from civil structure.



Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	16/42
-------------------	----------------------	----------------------	---------------------	------	-------

Table - 3 Force Acting from Civil Structure

weight of concrete

$\gamma_c = -6.50$

slab name	name	weight	inertia	acting point						direction	
				x	Mx	y	My	z	Mz		
front structure	wall no.1-1	-122.50	-13.48	5.00	-67.38	5.25	-70.74	0.50	-6.74	-z	
	wall no.1-2	-0.76	-0.08	9.63	-0.80	2.43	-0.20	0.50	-0.04	-z	
	wall no.2-1	-122.50	-13.48	5.00	-67.38	5.25	-70.74	5.50	-74.11	-z	
	wall no.2-2	-0.76	-0.08	9.63	-0.80	2.43	-0.20	5.50	-0.46	-z	
	wall no.3-1	-122.50	-13.48	5.00	-67.38	5.25	-70.74	10.50	-141.49	-z	
	wall no.3-2	-0.76	-0.08	9.63	-0.80	2.43	-0.20	10.50	-0.87	-z	
	wall no.4-1	-122.50	-13.48	5.00	-67.38	5.25	-70.74	15.50	-208.86	-z	
	wall no.4-2	-0.76	-0.08	9.63	-0.80	2.43	-0.20	15.50	-1.29	-z	
	bottom slab 1	-296.00	-32.56	4.63	-150.59	2.40	-78.14	8.00	-260.48	-z	
	bottom slab 2	-6.40	-0.70	9.38	-6.61	2.27	-1.60	8.00	-5.63	-z	
	bottom slab 3	-49.00	-5.39	8.95	-48.24	1.65	-8.89	8.00	-43.12	-z	
	bottom slab 4	-2.50	-0.28	8.42	-2.31	1.13	-0.31	8.00	-2.20	-z	
	bottom slab 5	-30.00	-3.30	9.25	-30.53	1.05	-3.47	8.00	-26.40	-z	
	total	-876.93	-96.46	5.30	-510.98	3.90	-376.19	8.00	-771.69	-z	
main structure-A	wall no.1-1	-121.58	-13.37	13.80	-184.56	4.50	-60.18	0.50	-6.69	-z	
	wall no.2-1	-121.58	-13.37	13.80	-184.56	4.50	-60.18	5.50	-73.56	-z	
	wall no.3-1	-121.58	-13.37	13.80	-184.56	4.50	-60.18	10.50	-140.43	-z	
	wall no.4-1	-121.58	-13.37	13.80	-184.56	4.50	-60.18	15.50	-207.30	-z	
	bottom slab-1	-395.15	-43.47	13.80	-599.81	0.65	-28.25	8.00	-347.73	-z	
	bottom slab-2	-24.54	-2.70	17.04	-46.00	1.62	-4.38	8.00	-21.60	-z	
	total	-906.03	-99.66	13.89	-1384.04	2.74	-273.37	8.00	-797.30	-z	
main structure-B	wall no.1-1	-114.03	-12.54	21.80	-273.45	6.95	-87.17	0.50	-6.27	-z	
	wall no.1-2	1.22	0.13	25.57	3.43	12.05	1.62	0.50	0.07	-z	
	wall no2-1	-114.03	-12.54	21.80	-273.45	6.95	-87.17	5.50	-68.99	-z	
	wall no2-2	1.22	0.13	25.57	3.43	12.05	1.62	5.50	0.74	-z	
	wall no3-1	-114.03	-12.54	21.80	-273.45	6.95	-87.17	10.50	-131.70	-z	
	wall no3-2	1.22	0.13	25.57	3.43	12.05	1.62	10.50	1.41	-z	
	wall no4-1	-114.03	-12.54	21.80	-273.45	6.95	-87.17	15.50	-194.42	-z	
	wall no4-2	1.22	0.13	25.57	3.43	12.05	1.62	15.50	2.08	-z	
	top slab-1	-19.52	-2.15	25.35	-54.42	11.55	-24.79	8.00	-17.17	-z	
	bottom slab-1	-310.45	-34.15	21.80	-744.47	4.24	-144.66	8.00	-273.19	-z	
	total	-781.19	-85.93	21.87	-1878.94	5.95	-511.67	8.00	-687.45	-z	
	main structure-C	wall no.1-1	-34.30	-3.77	27.00	-101.88	9.00	-33.96	0.39	-1.46	-z
		wall no1-2	-68.58	-7.54	31.50	-237.63	7.80	-58.84	0.39	-2.92	-z
		wall no.2-1	-28.00	-3.08	27.00	-83.17	9.00	-27.72	5.50	-16.94	-z
wall no.2-2		-55.98	-6.16	31.50	-193.98	7.80	-48.03	5.50	-33.87	-z	
wall no.3-1		-28.00	-3.08	27.00	-83.17	9.00	-27.72	10.50	-32.34	-z	
wall no.2-2		-55.98	-6.16	31.50	-193.98	7.80	-48.03	10.50	-64.66	-z	
wall no4-1		-28.00	-3.08	27.00	-83.17	9.00	-27.72	15.50	-47.74	-z	
wall no4-2		-55.98	-6.16	31.50	-193.98	7.80	-48.03	15.50	-95.45	-z	
bottom-1		-215.95	-23.75	30.50	-724.54	6.60	-156.78	7.89	-187.37	-z	
bottom-2		-4.24	-0.47	26.14	-12.19	7.23	-3.37	8.00	-3.73	-z	
bottom-3		-8.62	-0.95	26.67	-25.29	7.32	-6.94	8.00	-7.59	-z	
bottom-4		-3.71	-0.41	26.50	-10.82	7.06	-2.88	8.00	-3.27	-z	
total		-587.36	-64.61	30.09	-1943.81	7.58	-490.04	7.70	-497.34	-z	
house structure		bottom	-112.48	-12.37	30.50	-377.37	9.15	-1029.15	21.00	-259.82	-z
Total Weight		-3263.98	-359.04								
total volume		1305.59									

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	17/42
-------------------	----------------------	----------------------	---------------------	------	-------

3.5 Weight of Water


Water weight is calculated as shown in Table - 4.

Table - 4 Weight of Water

water level = -2.60 m

$Y_0 = -6.1$

water body name	name	weight	acting point						direction
			x	Mx	y	My	z	Mz	
front structure	water no1-1	-44.00	5.00	-220.00	2.95	-129.80	3.00	-132.00	-y
	water no1-2	-2.25	9.75	-21.94	1.90	-4.28	3.00	-6.75	-y
	water no2-1	-44.00	5.00	-220.00	2.95	-129.80	8.00	-352.00	-y
	water no2-2	-2.25	9.79	-22.02	1.90	-4.28	8.00	-18.00	-y
	water no3-1	-44.00	5.00	-220.00	2.95	-129.80	13.00	-572.00	-y
	water no3-2	-2.25	9.79	-22.02	1.90	-4.28	13.00	-29.25	-y
	total	-138.75	5.23	-725.99	2.90	-402.23	8.00	-1110.00	-y
main structure-A	water no1-1	-79.03	13.80	-1090.57	2.25	-177.82	3.00	-237.09	-y
	water no1-2	3.27	17.04	55.76	1.22	4.01	3.00	9.82	-y
	water no2-1	-79.03	13.80	-1090.57	2.25	-177.82	8.00	-632.24	-y
	water no2-2	3.27	17.04	55.76	1.22	4.01	8.00	26.18	-y
	water no3-1	-79.03	13.80	-1090.57	2.25	-177.82	13.00	-1027.38	-y
	water no3-2	3.27	17.04	55.76	1.22	4.01	13.00	42.54	-y
	total	-227.27	13.66	-3104.44	2.29	-521.43	8.00	-1818.17	-y
main structure-C	wall no.1	-22.40	30.50	-683.22	6.45	-144.48	3.00	-67.20	-y
	wall no.2	-22.40	30.50	-683.22	6.45	-144.48	8.00	-179.20	-y
	wall no.3	-22.40	30.50	-683.22	6.45	-144.48	13.00	-291.20	-y
	total	-67.20	30.50	-2049.67	6.45	-433.44	8.00	-537.60	-y



Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	18/42
<p>3.6 Hydrostatic Pressure</p> <p>Hydrostatic pressure is lateral pressure and uplift. Lateral pressure is calculated in Table - 5 while uplift is calculated in Table - 6.</p> <p>3.7 Earth Pressure</p> <p>The earth pressure coefficient is calculated in Table - 7.</p> <p>The earth pressure is calculated in Table - 8.</p> <p>3.8 Seismic Forces</p> <p>3.8.1 Calculation of Seismic Coefficient</p> <p>According to the Design Criteria of the Project, earthquake load is calculated as follows:</p> $G = E \times M$ <p>where</p> <p>G : earthquake load E : horizontal earthquake factor M : total dead load</p> <p>the earthquake factor is calculated using the following equation;</p> $E = a_d/g$ $a_d = n(a_c \times Z)^m$ <p>where</p> <p>a_d : design shock acceleration (cm/s²) a_c : basic shock acceleration (cm/s²) where a_c : 160 cm/s² by taking 100 years for return period Z : factor depending on geographical position and equal 0.56 taking northern Java Island n,m : factor determined by soil type and taken as 0.29 and 1.32 respectively, for soft alluvium</p> <p>Finally, we get E = 0.11 for the design.</p>					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	19/42
Table - 5 Water Pressure (normal condition) to the Stop Log					
water sressure(normal condition) to the stop log					
water -1.00					
Y ₀ = -6.5					
earth pressure name	height	width	P	direction	
				acting point	
				x	Mx
				y	My
				z	Mz
front slab	wp	3.50	16.00	98.00	1.15
				112.70	4.67
				457.33	8.00
				784.00	x
Table - 6 Uplift					
water level(U/S) = -1.00 m					
water level(D/S)= -0.48 m *					
Y ₀ = -6.1					
water body name	uplift	x	Mx	direction	
				acting point	
				y	My
				z	Mz
front slab	uplift	594.56	5.00	2,972.80	1.95
				4,756.48	y
main slab-A	uplift	683.30	13.80	9,429.23	0.00
				5,466.42	y
main slab-B	uplift	264.86	21.80	5,774.14	3.35
				2,118.90	y
main slab-C	wall no.1	109.49	30.50	3,339.69	5.80
				875.96	y
uplift pre the water pressure inside of the steel sheet pile					

Name of Structure	ASIN PUMPING STATION				Category Calculation	Structural Analysis	Page	20/42
-------------------	----------------------	--	--	--	----------------------	---------------------	------	-------

Table - 7 Calculation of Earth Pressure Coefficient ($\phi=25.6^\circ$)									
normal condition		25.6	conversion(3.14/180)	0.0174444	Kas				
phai	8.533	0	cos(pahi-theta)	0.9019304	Kp				
delta	0	0	cos(theta)	0.9889409	1				
alpha	0	0	cos(theta+delta)	0.5608706					
phai-theta	25.6	25.6	sin(pahi-alpha)	0.4318815					
theta+delta	8.533	34.13	cos(theta-alpha)	0.9019304	1				
phai+delta	34.13	25.6	cos(pahi+theta)	0.2933399					
phai-alpha	25.6	0	sin(pahi-delta)	0.4318815					
theta-alpha	0	25.6	sin(pahi+alpha)						
phai+theta	17.07	25.6							
phai-delta	25.6								
phai+alpha									

Table - 8 Force Acting from Earth (normal condition)									
ground level= 1.20		phai= 25.60		over burden = 1.00 t/m ²					
g.water level= 0.35		(natural soil)							
Y ₀ = -6.5									
earth pressure	name	height	width	wight of soil wet	submerged	Ka	P	x	Mx
front slab	ep-1	5.90	10.00	1.90	0.90	0.37	77.45	5.00	-387.27
main slab-A	ep-1	7.70	7.599	1.90	0.90	0.37	95.25	13.80	-1,314.42
main slab-B	ep-1	3.950	8.403	1.90	0.90	0.37	17.67	21.80	-385.16
main slab-C	ep-1	1.50	8.998	1.90	0.90	0.37	-6.97	30.50	-212.53

acting point		direction							
y	My	z	Mz						
3.72	288.13	16.00	-1,239.25	-z					
2.57	244.48	16.00	-1,524.02	-z					
5.98	-105.71	16.00	-282.68	-z					
6.70	-46.69	16.00	-111.49	-z					

seismic condition		seismicity(kn)		conversion(3.14/180)		0.11		0.0174444	
phai	25.6	0	cos(pahi-theta)	0.9437448	0.0174444	0.9437448	0.9437448	0.9437448	0.9437448
delta	0	0	cos(theta)	0.9940044	0.9940044	0.9940044	0.9940044	0.9940044	0.9940044
alpha	6.28	6.28	cos(theta+delta)	0.9940044	0.9940044	0.9940044	0.9940044	0.9940044	0.9940044
theta+delta	19.32	19.32	sin(pahi-alpha)	0.4318815	0.4318815	0.4318815	0.4318815	0.4318815	0.4318815
phai+delta	6.28	6.28	cos(theta-alpha)	0.3306746	0.3306746	0.3306746	0.3306746	0.3306746	0.3306746
phai-alpha	25.6	25.6	cos(pahi-theta)	0.9437448	0.9437448	0.9437448	0.9437448	0.9437448	0.9437448
theta-alpha	19.32	19.32	cos(theta-theta)	0.9940044	0.9940044	0.9940044	0.9940044	0.9940044	0.9940044
phai+theta	19.32	19.32	sin(pahi-delta)	0.4318815	0.4318815	0.4318815	0.4318815	0.4318815	0.4318815
theta-delta	-6.28	-6.28	sin(pahi+alpha-theta)	0.3306746	0.3306746	0.3306746	0.3306746	0.3306746	0.3306746
phai-delta	25.6	25.6							
phai+alpha-theta	19.32	19.32							

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	21/42
-------------------	----------------------	----------------------	---------------------	------	-------

3.9 Total Forces

Total forces which would act on the structure are shown in Table 9 ~ (1/4 ~ 4/4)

For pile analysis, critical cases were selected according to Table 10.

Table 9 (1/4) Total Forces
(case-1-1) normal condition and stop log open (pump operated)

slab name	Total Force	point of action			direction			Moment footing C.		
		x	y	z	X	Y	Z	Mx	My	Mz
front	-555.12	5.77	6.32	8.00	*	*		0	0	427
	-77.45	5.00	3.72	16.00			*	133	0	0
main-A	-48.42	13.38	1.80	8.00	*			0	0	87
	-959.34	13.56	4.30	8.00		*		0	0	-230
	-104.09	13.76	2.50	15.32			*	260	1,037	0
main-C	-48.42	27.00	9.66	8.00	*			0	0	168
	-1,727.29	29.41	8.82	7.90		*		173	0	1,883
	-15.81	28.54	8.36	11.53			*	34	31	0
house	-337.43	30.50	10.18	16.00		*		0	0	0

Table 9 (2/4) Total Forces
(case-1-2) normal condition and stop log closed (pump not operation)

slab name	Total Force	point of action			direction			Moment footing C.		
		x	y	z	X	Y	Z	Mx	My	Mz
front	98.00	1.15	4.67	8.00	*	*		0	0	588
	-416.37	5.95	7.46	8.00		*		0	0	396
	-77.45	5.00	3.72	16.00			*	133	0	0
main-A	-30.53	13.38	1.80	8.00	*			0	0	55
	-713.10	13.53	5.01	8.00		*		0	0	-192
	-104.09	13.76	2.50	15.32			*	260	1,037	0
main-C	-1,612.22	29.43	8.90	7.89		*		177	0	1,725
	-15.81	28.54	8.36	11.53			*	34	31	0

Table 9 (3/4) Total Forces
(case-2-1) earthquake condition and stop log open (pump operated)

slab name	Total Force	point of action			direction			Moment footing C.		
		x	y	z	X	Y	Z	Mx	My	Mz
front	111.20	5.39	4.22	8.00	*	*		0	0	667
	-555.12	5.77	6.32	8.00		*		0	0	427
	-349.87	5.12	3.79	11.27			*	626	42	0
main-A	-278.41	13.54	2.22	8.00	*			0	0	618
	-963.66	13.56	4.29	8.00		*		0	0	-231
	-379.09	13.38	2.83	11.72			*	1,073	3,632	0
main-C	-203.71	28.31	9.03	7.90	*			0	20	576
	-1,679.42	29.48	8.80	7.89		*		185	0	1,713
	-218.70	29.06	9.04	8.28			*	621	315	0
house	37.12	30.50	10.18	16.00	*			0	0	9
	-337.43	30.50	10.18	16.00		*		0	0	0
	37.12	30.50	10.18	16.00			*	9	0	0

Table 9 (4/4) Total Forces
(case-2-2) earthquake condition and stop log closed (pump not operated operation)

slab name	Total Force	point of action			direction			Moment footing C.		
		x	y	z	X	Y	Z	Mx	My	Mz
front	209.20	3.40	4.43	8.00	*	*		0	0	1,255
	-416.37	5.95	7.46	8.00		*		0	0	396
	-222.29	5.20	3.97	12.00			*	438	44	0
main-A	-254.57	13.55	2.26	8.00	*			0	0	575
	-713.10	13.53	5.01	8.00		*		0	0	-192
	-285.56	13.38	2.53	8.00			*	722	2,736	0
main-C	-285.31	28.58	9.19	8.00	*			0	0	853
	-1,641.10	29.39	8.91	7.89		*		181	0	1,822
	-218.70	29.06	9.04	8.28			*	621	315	0

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	22/42
-------------------	----------------------	----------------------	---------------------	------	-------


Table 10 Total Forces (Summary)

case no.	slab name	V	H	critical case
		t	t	
normal, stoplog open	F	555	77	
	A	959	104	
	C	1,727	48	*
	H	337	0	*
normal, stoplog closed	F	416	98	*
	A	713	104	*
	C	1,612	16	
	H	337	0	
earthquake, stoplog open	F	555	350	*
	A	964	379	*
	C	1,679	219	
	H	337	37	*
earthquake, stoplog closed	F	416	222	
	A	713	285	
	C	1,641	219	*
	H	337	37	

normal condition: no earthquake
earthquake condition: earthquake

in stop log open condition, water weight is included
in stop log closed condition, water pressure on stop log is included
in earthquake condition, inertia on screw has vertical component
in stop log open condition, driving force of screw is included

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	23/42
<p>3.10 Pile Foundation Analysis</p> <p>3.10.1 Pile Stress Analysis</p> <p>(1) N-value for design of pile foundation</p> <p>Geological condition at the site is assumed as shown in Figure-11.</p> <p>N-value at pile tip (Nt): 50 average N-value 3.75D above the tip to pile tip (N2): $3.75 D = 3.75 \times 0.5 = 1.875$ $N2 = (0.875 \times 10 + 1.0 \times 50) / 1.875 = 31.3 \rightarrow 31$ N-value for pile design (N): $N = (50 + 31) / 2 = 40.5 \rightarrow 40$</p> <p>(2) Estimation of internal friction angle</p> $\phi = 15 + \sqrt{(15 \times N)} = 15 + \sqrt{(15 \times 40)} = 39.5 \rightarrow 40$ <p>(3) Allowable compressive bearing capacity (Ra)</p> $Ra = \frac{\{qd \times A + u(li \times fi)\}}{SF}$ <p>qd : ultimate bearing capacity per unit area at pile tip (tf/m²) A : Area of pile tip ($= \pi R^2 / 4 = 0.196 \text{ m}^2$) li : stratum depth ($l_1 = 11.0 \text{ m}, l_2 = 10 \text{ m}, l_3 = 1 \text{ m}$) u : circumferential length of pile ($= 1.571 \text{ m}$) fi : maximum skin friction of stratum ($f_1 = 2.5 \text{ tf/m}^2, f_2 = 3 \text{ tf/m}^2, f_3 = 3 \text{ tf/m}^2$) SF : safety factor (normal: 3, earthquake: 2)</p> <p>- ultimate bearing capacity (qd)</p> $qd = 1.3 \times c \times N + 0.3 \times R \times \gamma_1 + N_\gamma \times Df \times Nq$ <p>c : cohesion ($= 0$) Nc, N_γ, Nq : bearing capacity factors Nc = 92, N_γ = 110, Nq = 85 γ₁ : unit weight of soil below pile tip ($= 0.8 \text{ tf/m}^3$) γ₂ : unit weight of soil above pile tip ($= 0.8 \text{ tf/m}^3$) R : diameter of pile ($= 0.5 \text{ m}$) Df : Pile length ($= 22.0 \text{ m}$)</p> $qd = 0.3 \times 0.5 \times 0.8 \times 110 + 0.8 \times 22.0 \times 85 = 1509.2 \text{ tf/m}^2$ $Ra = \frac{\{1509.2 \times 0.196 + 1.571 \times (11.00 \times 2.5 + 10 \times 3 + 1 \times 3)\}}{SF} = \frac{390.8}{SF}$ <p>- Normal condition: Ra = 130 tf - Earthquake condition: Ra = 195 tf</p>					



Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	24/42
(4) Allowable pull-out capacity (Pa)					
$Pa = \frac{Pu}{SF + \bar{w}}$					
Pu: ultimate axial pull-out capacity of pile determined by ground conditions (tf) $Pu = U \sum (li \times fi) = 95$ w : effective weight of pile (= 1.6 tf/m x 22.0 m = 35.2 tf) SF: safety factor (normal: 6, earthquake:3) -Normal condition: Pa = 51.0 tf -Earthquake condition: Pa = 69.9 tf					
(5) Allowable lateral bearing capacity (Ha)					
$Ha = (k \times D / \beta) \times \delta a$					
k: coefficient of lateral reaction of foundation ground (kgf/cm ³) D: pile diameter(= 0.5 m) β: charactaristic value of pile (cm ⁻¹) $\beta = \sqrt{\frac{k \cdot D}{4 \cdot E \cdot I}}$ E: coefficient of elasticity of pile body (= 400,000 kgf/cm ²) I: momet of inertia of corss section of pile body (= 260,604.6 m ⁴) δa: allowable displacement of pile (normal: 1.0 cm, earthquake: 1.5 cm)					
(5)-1 Estimation of coefficient of lateral reaction of foundation ground (k)					
$k = k_0(B_H/30)^{-3/4}$					
$k_0 = \frac{1}{30} \times \alpha \times E_0$					
E0 = 28N = 140, α=1 (normal), α=2 (earthquake)					
$B_H = \sqrt{\frac{D}{\beta}}$					
D = 0.5 m					
k = 1.70 (normal condition) k = 3.40 (earthquake condition)(details see table-5)					
(5)-2 Allowable lateral bearing capacity (Ha)					
$Ha = \left(K \times \frac{D}{\beta} \right) \times \delta a$					
K: 1.70 kgf/cm ³ (normal), 3.40 kgf/cm ³ (earthquake) D: pile diameter(= 50 cm) β: 0.0038 cm ⁻¹ , 1/β= 264.5 cm δa: allowable displacement of pile (normal: 1.0 cm, earthquake: 1.5 cm)					
Ha = 22.5 t (normal), Ha = 67.4 t (earthquake)					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	25/42
-------------------	----------------------	----------------------	---------------------	------	-------

6) Load and moment for a pile

6)-1 Load and moment at footing center

Load and moment at footing center is calculated as follows:

Name of Structure	normal(X)			normal(Z)			seismic(ZX)			seismic(ZZ)			seismic(XX)			seismic(XZ)		
	V	H	M	V	H	M	V	H	M	V	H	M	V	H	M	V	H	M
Front Structure	-416	98	984	-416	-77	133	-555	0	427	-555	-350	626	-555	111	1094	-555	-77	133
Main Structure-A	-713	-31	-137	-713	-104	260	-964	-48	-144	-964	-379	1073	-964	-278	387	-964	-104	260
Main Structure-B	-1727	-48	-143	-1727	-16	34	-1641	0	1822	-1641	-219	802	-1641	-285	853	-1641	-16	215
House Slab	-337	0	0	-337	0	0	-337	37	9	-337	37	9	-337	0	0	-337	0	0

6)-2 Layout of pile

Layout of piles is shown below

Name of Structure	Pile Arrangement		
	X	Z	total
Front Structure	6	9	54
Main Structure-A	5	10	50
Main Structure-B	3	6	18
Main Structure-C	4	7	28
House Slab	3	4	12

6)-3 Calculation of displacement

Displacement calculated is shown below

Displacement of Piles and Load on Piles (Asin Pumping Station)

Front Structure displacement

	delta H(cm)				alpha H(10-5 radian)		
	delta y	delta x	delta z	delta H	alpha x	alpha z	alpha H
normal	-0.031	0.082	-0.064	0.10	1.55	-0.4	1.60
earthquake: z	-0.042	0.00005	-0.17	0.17	0.05	-1.52	1.52
earthquake: x	-0.042	0.056	-0.038	0.07	1.49	-0.334	1.53

load on

	Pv(t)		Ph(t)	Mo(tm)	Mm(tm)
	Pvmax	Pvmin			
normal	8.5	6.9	2.31	3.06	-0.6
earthquake: z	12.9	7.9	6.48	7.28	-1.5
earthquake: x	11.7	12.2	2.50	2.81	-0.6

beta(normal)= 0.00378
beta(quake)= 0.004449

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	26/42
-------------------	----------------------	----------------------	---------------------	------	-------

Main Structure-A displacement

	delta H(cm)			delta H	alpha H(10-5 radian)		
	delta y	delta x	delta z		alpha x	alpha z	alps H
normal	-0.057	-0.028	-0.093	0.097	-0.73	-0.58	0.93
earthquake: z	-0.078	-0.026	-0.202	0.204	-0.95	-1.76	2.00
earthquake: x	-0.078	-0.153	-0.055	0.163	-5.27	-0.48	5.29

load

	Pv(t)		Ph(t)	Mo(tm)	Mm(tm)
	Pvmax	Pvmin			
normal	15.6	12.6	2.17	2.87	-0.5968
earthquake: z	23.0	15.7	7.61	8.47	-1.7618
earthquake: x	23.2	15.4	5.94	6.61	-1.3752

beta(normal)= 0.00378
beta(quake)= 0.00449

Main Structure- C displacement

	delta H(cm)			delta H	alpha H(10-5 radian)		
	delta y	delta x	delta z		alpha x	alpha z	alps H
normal	-0.249	-0.078	-0.025	0.082	-1.65	-0.15	1.66
earthquake: z	-0.237	0.001	-0.208	0.208	-0.46	-1.74	1.80
earthquake: x	-0.237	-0.277	-0.015	0.277	-7.81	-0.12	7.81

load

	Pv(t)		Ph(t)	Mo(tm)	Mm(tm)
	Pvmax	Pvmin			
normal	59.5	56.9	0.56	0.74	-0.154
earthquake: z	62.1	51.2	7.82	8.71	-1.8104
earthquake: x	60.4	53.1	10.18	11.34	-2.3568

beta(normal)= 0.00378
beta(quake)= 0.00449

House Slab displacement

	delta H(cm)			delta H	alpha H(10-5 radian)		
	delta y	delta x	delta z		alpha x	alpha z	alps H
normal	-0.11	0.000	0.000	0.000	0.00	0.00	0.00
earthquake: z	-0.11	0.000	-0.083	0.083	0.00	-1.74	1.74
earthquake: x	-0.11	-0.083	0.000	0.083	-1.66	0.00	1.66

load

	Pv(t)		Ph(t)	Mo(tm)	Mm(tm)
	Pvmax	Pvmin			
normal	27.2	27.2	0	0.00	0
earthquake: z	28.9	25.6	3.08	3.43	-0.7131
earthquake: x	28.7	25.8	3.08	3.43	-0.7131

beta(normal)= 0.00378
beta(quake)= 0.00449

Allowable: normal condition; $\delta y = \delta H = 1.0 \text{ cm}$, $\alpha = 1/1000 = 1 \times 10^{-3}$

earthquake condition; $\delta y = 1.0 \text{ cm}$, $\delta H = 1.5 \text{ cm}$, $\alpha = 1/1000 = 1 \times 10^{-3}$


7) Stress of a Pile

Pile stress are calculated as follows :

Name of Structure	ASIN PUMPING STATION		Category Calculation	Structural Analysis		Page	27/42
Pile stress(slab F 6*9)							
normal							
c	41 +	3.06 x	100000 /	10416.2 +	8.5 x	1000 /	1182.4 = 77.6
c'	41 -	3.06 x	100000 /	10416.2 +	8.5 x	1000 /	1182.4 = 18.8
p	8152.5 +	321.3 x	100000 /	260604.6 -	42.5 x	1000 /	1182.4 = 8,239.8
earthquake Z							
c	41 +	7.28 x	100000 /	10416.2 +	12.9 x	1000 /	1182.4 = 121.8
c'	41 -	7.28 x	100000 /	10416.2 +	12.9 x	1000 /	1182.4 = -18.0
p	8152.5 +	764.4 x	100000 /	260604.6 -	64.5 x	1000 /	1182.4 = 8,391.3
earthquake X							
c	41 +	2.81 x	100000 /	10416.2 +	11.7 x	1000 /	1182.4 = 77.9
c'	41 -	2.81 x	100000 /	10416.2 +	11.7 x	1000 /	1182.4 = 23.9
p	8152.5 +	295.1 x	100000 /	260604.6 -	58.5 x	1000 /	1182.4 = 8,216.2
Pile stress(slab A 5x10)							
normal							
c	41 +	2.87 x	100000 /	10416.2 +	15.6 x	1000 /	1182.4 = 81.7
c'	41 -	2.87 x	100000 /	10416.2 +	15.6 x	1000 /	1182.4 = 26.6
p	8152.5 +	301.35 x	100000 /	260604.6 -	78 x	1000 /	1182.4 = 8,202.2
earthquake Z							
c	41 +	8.47 x	100000 /	10416.2 +	23 x	1000 /	1182.4 = 141.8
c'	41 -	8.47 x	100000 /	10416.2 +	23 x	1000 /	1182.4 = -20.9
p	8152.5 +	889.35 x	100000 /	260604.6 -	115 x	1000 /	1182.4 = 8,396.5
earthquake X							
c	41 +	6.61 x	100000 /	10416.2 +	23.2 x	1000 /	1182.4 = 124.1
c'	41 -	6.61 x	100000 /	10416.2 +	23.2 x	1000 /	1182.4 = -2.8
p	8152.5 +	694.05 x	100000 /	260604.6 -	116 x	1000 /	1182.4 = 8,320.7

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	28/42
Pile stress(slab C 4x7)					
normal					
c	41 + 0.74	x 100000 /	10416.2 + 62.4 x 1000 /	1182.4 =	100.9
c'	41 - 0.74	x 100000 /	10416.2 + 62.4 x 1000 /	1182.4 =	86.7
p	8152.5 + 77.7	x 100000 /	260604.6 - 312 x 1000 /	1182.4 =	7,918.4
earthquake Z					
c	41 + 8.71	x 100000 /	10416.2 + 63.3 x 1000 /	1182.4 =	178.2
c'	41 - 8.71	x 100000 /	10416.2 + 63.3 x 1000 /	1182.4 =	10.9
p	8152.5 + 914.55	x 100000 /	260604.6 - 316.5 x 1000 /	1182.4 =	8,235.8
earthquake X					
c	41 + 11.34	x 100000 /	10416.2 + 61.8 x 1000 /	1182.4 =	202.1
c'	41 - 11.34	x 100000 /	10416.2 + 61.8 x 1000 /	1182.4 =	-15.6
p	8152.5 + 1190.7	x 100000 /	260604.6 - 309 x 1000 /	1182.4 =	8,348.1
Pile stress(slab H 3x4)					
normal					
c	41 + 0	x 100000 /	10416.2 + 27.2 x 1000 /	1182.4 =	64.0
c'	41 - 0	x 100000 /	10416.2 + 27.2 x 1000 /	1182.4 =	64.0
p	8152.5 + 0	x 100000 /	260604.6 - 136 x 1000 /	1182.4 =	8,037.5
earthquake Z					
c	41 + 3.43	x 100000 /	10416.2 + 28.9 x 1000 /	1182.4 =	98.4
c'	41 - 3.43	x 100000 /	10416.2 + 28.9 x 1000 /	1182.4 =	32.5
p	8152.5 + 360.15	x 100000 /	260604.6 - 144.5 x 1000 /	1182.4 =	8,168.5
earthquake X					
c	41 + 3.43	x 100000 /	10416.2 + 28.7 x 1000 /	1182.4 =	98.2
c'	41 - 3.43	x 100000 /	10416.2 + 28.7 x 1000 /	1182.4 =	32.3
p	8152.5 + 360.15	x 100000 /	260604.6 - 143.5 x 1000 /	1182.4 =	8,169.3
3.10.2 Pile Cap Calculation					
(1) General					
As the horizontal force acting on the piles are large in this structure, a rigid type connection method is applied in the pile cap treatment. The pile cap design criteria is described in "Design Criteria Report (1)". The concept of the pile cap treatment is shown in a figure below.					


Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	29/42
-------------------	----------------------	----------------------	---------------------	------	-------




(2) Structural Analysis

Structural analysis is made for each check items as follows;

- (a) normal stress in the footing concrete
- (b) shearing stress in the footing concrete
- (c) horizontal punching stress in the footing concrete
- (d) horizontal punching stress in the pile
- (e) stress in the imaginary concrete section
- (f) reinforcing bar for inserted concrete
- (g) height of inserted concrete





Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	32/42
-------------------	----------------------	----------------------	---------------------	------	-------

F-F

- (a) normal stress in the footing concrete

$$P_{Nmax} = 8.5 \text{ tf/pile (in case of normal condition)}$$

$$P_{Nmax} = 12.6 \text{ tf/pile (in case of earthquake condition)}$$

$$\delta_{cv} = \frac{P_{Nmax}}{\pi \frac{D^2}{4}} = \frac{12900}{\frac{\pi}{4} \times 50^2} = 6.6 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2$$

- (b) shearing stress in the footing concrete

$$\tau_v = \frac{P_{Nmax}}{\pi(D+h)h} = \frac{12900}{\pi(50+70) \times 70} = 0.49 \text{ kgf/cm}^2 < \tau_{ca} = 8.8 \text{ kgf/cm}^2 \dots\dots\dots O.K.$$

- (c) horizontal punching stress in the footing concrete

$$\delta_{ch} = \frac{H}{D\ell}$$

ℓ = inserted pile length (cm)

M = Moment (kgf.cm)

H = Axial Force

$$P_{Nmax} = 11.7 \text{ tf/pile} \quad M_x = 2.81 \text{ tf.m} \quad S_x = 2.50 \text{ tf}$$

$$P_{Nmax} = 12.9 \text{ tf/pile} \quad M_z = 7.28 \text{ tf.m} \quad S_z = 6.48 \text{ tf}$$

$$\delta_{ch-x} = \frac{2500}{50 \times 10} = 5.0 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \dots\dots\dots O.K$$

$$\delta_{ch-z} = \frac{6480}{50 \times 10} = 12.96 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \dots\dots\dots O.K$$


- (d) horizontal punching stress in the pile

$$\tau_h = \frac{H}{h'(2\ell + D + 2h')}$$


h' = effective thickness of footing concrete against horizontal punching

$$h' = 45 \text{ cm (z direction)}$$


Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	33/42
$\tau_h = \frac{6480}{45 \times (2 \times 10 + 50 + 2 \times 45)} = 0.90 \text{ kg/cm}^2 < \tau_{03} = 8.8 \text{ kg/cm}^2 \dots\dots\dots O.K$ <p>(e) stress in the imaginary concrete section</p> <p>$N = N_{min} = 7.9 \text{ tf}$ (in case of earthquake condition)</p> <p>$M = 7.28 \text{ tf.m}$</p> <p>$D = 50 + 10 \times 2 = 70.0 \text{ cm}$</p> <p>$a = 11.0 \text{ cm} \times 2 = 22.0 \text{ cm}$</p> <p>$d = 24.0 \text{ cm}$</p> <p>$\delta_c = 75.0 \text{ kg/cm}^2 < \delta_{ca} = 75 \times 15 = 112.5 \text{ kg/cm}^2 \dots\dots\dots O.K$</p> <p>$\delta_s = 1722 \text{ kg/cm}^2 < \delta_{sa} = 2400 \text{ kg/cm}^2 \dots\dots\dots O.K$</p> <p>D16 – 8 bars</p> <p>(f) reinforcing bar for inserted concrete</p> <p>$L_1 \geq L_0$</p> <p>bond length in footing $L_0 = 35\phi$ (mm) $\phi =$ reinforcing bar diameter (mm)</p> <p>$L_1 = 35 \times 16 = 560 \div 600 \text{ mm}$</p> <p>bond length in footing $L_2 = 50\phi + L_0$ $\phi =$ PC cable diameter (mm)</p> <p>$L_2 = 50 \times 9.0 + 35 \times 16 = 1010 \text{ mm}$ $\div 1050 \text{ mm}$</p> <p>Stirrup : D13 per 150 mm pitch</p> <p>(g) height of inserted concrete</p> <p>$L_2 \geq 1050 \text{ mm}$</p>					




Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	34/42
<u>A-A</u>					
(a) normal stress in the footing concrete					
$P_{Nmax} = 15.6 \text{ tf/pile (in case of normal condition)}$					
$P_{Nmax} = 23.2 \text{ tf/pile (in case of earthquake condition)}$					
$\delta_{cv} = \frac{P_{Nmax}}{\pi D^2/4} = \frac{23200}{\frac{\pi}{4} \times 50^2} = 11.8 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2$					
(b) shearing stress in the footing concrete					
$\tau_v = \frac{P_{Nmax}}{\pi(D+h)h} = \frac{23200}{\pi(50+70) \times 70} = 0.88 \text{ kgf/cm}^2 < \tau_{ca} = 8.8 \text{ kgf/cm}^2 \dots\dots O.K.$					
(c) (c) horizontal punching stress in the footing concrete					
$\delta_{ch} = \frac{H}{D\ell}$					
ℓ = inserted pile length (cm)					
M = Moment (kgf.cm)					
H = Axial Force					
$P_{Nmax} = 23.2 \text{ tf/pile} \quad M_x = 6.61 \text{ tf.m} \quad S_x = 5.94 \text{ tf}$					
$P_{Nmax} = 23.0 \text{ tf/pile} \quad M_z = 8.47 \text{ tf.m} \quad S_z = 7.61 \text{ tf}$					
$\delta_{ch-x} = \frac{5940}{50 \times 10} = 11.9 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \dots\dots O.K$					
$\delta_{ch-z} = \frac{7610}{50 \times 10} = 15.2 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \dots\dots O.K$					
(d) horizontal punching stress in the pile					
$\tau_h = \frac{H}{h'(2\ell + D + 2h')}$					
h' = effective thickness of footing concrete against horizontal punching					
$h' = 45 \text{ cm (z direction)}$					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	35/42
$\tau_h = \frac{7610}{45 \times (2 \times 10 + 50 + 2 \times 45)} = 1.06 \text{ kgf/cm}^2 < \tau_{os} = 8.8 \text{ kgf/cm}^2 \dots\dots\dots O.K$ <p>(e) stress in the imaginary concrete section</p> <p>$N = N_{min} = 15.7 \text{ tf}$ (in case of earthquake condition)</p> <p>$M = 8.47 \text{ tf.m}$</p> <p>$D = 50 + 10 \times 2 = 70.0 \text{ cm}$</p> <p>$a = 11.0 \text{ cm} \times 2 = 22.0 \text{ cm}$</p> <p>$d = 24.0 \text{ cm}$</p> <p>$\delta_c = 79.2 \text{ kgf/cm}^2 < \delta_{cu} = 75 \times 15 = 112.5 \text{ kgf/cm}^2 \dots\dots\dots O.K$</p> <p>$\delta_s = 1534 \text{ kgf/cm}^2 < \delta_{su} = 2400 \text{ kgf/cm}^2 \dots\dots\dots O.K$</p> <p>D16 – 8 bars</p>  <p>(f) reinforcing bar for inserted concrete</p> <p>$L_1 \geq L_0$</p> <p>bond length in footing $L_0 = 35\phi$ (mm) $\phi =$ reinforcing bar diameter (mm)</p> <p>$L_1 = 35 \times 16 = 560 \div 600 \text{ mm}$</p> <p>bond length in footing $L_2 = 50\phi + L_0$ $\phi =$ PC cable diameter (mm)</p> <p>$L_2 = 50 \times 9.0 + 35 \times 16 = 1010 \text{ mm}$ $\div 1050 \text{ mm}$</p> <p>Stirrup : D13 per 150 mm pitch</p> <p>(g) height of inserted concrete</p> <p>$L_2 \geq 1050 \text{ mm}$</p>					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	36/42
<u>C-C</u>					
(a) normal stress in the footing concrete					
$P_{Nmax} = 59.5 \text{ tf/pile (in case of normal condition) } \checkmark$					
$P_{Nmax} = 62.1 \text{ tf/pile (in case of earthquake condition) } \checkmark$					
$\delta_{cv} = \frac{P_{Nmax}}{\pi \frac{D^3}{4}} = \frac{62100}{\frac{\pi}{4} \times 50^3} = 31.6 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \checkmark$					
(b) shearing stress in the footing concrete					
$\tau_v = \frac{P_{Nmax}}{\pi(D+h)h} = \frac{62100}{\pi(50+70) \times 70} = 2.35 \text{ kgf/cm}^2 < \tau_{ca} = 8.8 \text{ kgf/cm}^2 \dots\dots O.K. \checkmark$					
(c) horizontal punching stress in the footing concrete					
$\delta_{ch} = \frac{H}{D\ell}$					
ℓ = inserted pile length (cm)					
M = Moment (kgf.cm)					
H = Axial Force					
$P_{Nmax} = 60.4 \text{ tf/pile} \quad M_x = 11.3 \text{ tf.m} \checkmark \quad S_x = 10.2 \text{ tf} \checkmark$					
$P_{Nmax} = 62.1 \text{ tf/pile} \checkmark \quad M_z = 8.71 \text{ tf.m} \checkmark \quad S_z = 7.82 \text{ tf} \checkmark$					
$\delta_{ch-x} = \frac{10200}{50 \times 10} = 20.4 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \dots\dots O.K. \checkmark$					
$\delta_{ch-z} = \frac{7820}{50 \times 10} = 15.6 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \dots\dots O.K. \checkmark$					
(d) horizontal punching stress in the pile					
$\tau_h = \frac{H}{h'(2\ell + D + 2h')}$					
h' = effective thickness of footing concrete against horizontal punching					
$h' = 45 \text{ cm (z direction)}$					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	37/42
$\tau_h = \frac{10200}{45 \times (2 \times 10 + 50 + 2 \times 45)} = 1.42 \text{ kgf/cm}^2 < \tau_{u3} = 8.8 \text{ kgf/cm}^2, \dots\dots\dots O.K$					
(e) stress in the imaginary concrete section					
$N = N_{min} = 51.2 \text{ tf (in case of earthquake condition)}$					
$M = 8.71 \text{ tf.m}$					
$D = 50 + 10 \times 2 = 70.0 \text{ cm}$					
$a = 11.0 \text{ cm} \times 2 = 22.0 \text{ cm}$					
$d = 24.0 \text{ cm}$					
					
$\delta_c = 45.2 \text{ kgf/cm}^2 < \delta_{cu} = 75 \times 15 = 112.5 \text{ kgf/cm}^2, \dots\dots\dots O.K$					
$\delta_s = 41 \text{ kgf/cm}^2 < \delta_{su} = 2400 \text{ kgf/cm}^2, \dots\dots\dots O.K$					
D16 – 8 bars					
(f) reinforcing bar for inserted concrete					
$L_1 \geq L_0$					
bond length in footing $L_0 = 35\phi \text{ (mm)}$ $\phi = \text{reinforcing bar diameter (mm)}$					
$L_1 = 35 \times 16 = 560 \div 600 \text{ mm}$					
bond length in footing $L_2 = 50\phi + L_0$ $\phi = \text{PC cable diameter (mm)}$					
$L_2 = 50 \times 9.0 + 35 \times 16 = 1010 \text{ mm}$					
$\div 1050 \text{ mm}$					
Stirrup : D13 per 150 mm pitch					
(g) height of inserted concrete					
$L_2 \geq 1050 \text{ mm}$					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	38/42
H-H					
(a) normal stress in the footing concrete					
$P_{Nmax} = 27.2 \text{ tf/pile (in case of normal condition)}$					
$P_{Nmax} = 28.9 \text{ tf/pile (in case of earthquake condition)}$					
$\delta_{cv} = \frac{P_{Nmax}}{\pi D^3/4} = \frac{28900}{\pi \times 50^3} = 14.7 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2$					
(b) shearing stress in the footing concrete					
$\tau_v = \frac{P_{Nmax}}{\pi(D+h)h} = \frac{28900}{\pi(50+70) \times 70} = 1.10 \text{ kgf/cm}^2 < \tau_{ca} = 8.8 \text{ kgf/cm}^2 \dots\dots\dots O.K.$					
(c) horizontal punching stress in the footing concrete					
$\delta_{ch} = \frac{H}{D\ell}$					
ℓ = inserted pile length (cm)					
M = Moment (kgf.cm)					
H = Axial Force					
$P_{Nmax} = 28.7 \text{ tf/pile} \quad M_x = 3.43 \text{ tf.m} \quad S_x = 3.08 \text{ tf}$					
$P_{Nmax} = 28.9 \text{ tf/pile} \quad M_z = 3.43 \text{ tf.m} \quad S_z = 3.08 \text{ tf}$					
$\delta_{ch-x} = \frac{3,080}{50 \times 10} = 6.2 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \dots\dots\dots O.K$					
$\delta_{ch-z} = \frac{3,080}{50 \times 10} = 6.2 \text{ kgf/cm}^2 < \delta_{ca} = 60.0 \times 1.5 = 90.0 \text{ kgf/cm}^2 \dots\dots\dots O.K$					
(d) horizontal punching stress in the pile					
$\tau_h = \frac{H}{h'(2\ell + D + 2h')}$					
h' = effective thickness of footing concrete against horizontal punching					
$h' = 45 \text{ cm (z direction)}$					

Name of Structure	ASIN PUMPING STATION	Category Calculation	Structural Analysis	Page	39/42
$\tau_h = \frac{3,080}{45 \times (2 \times 10 + 50 + 2 \times 45)} = 0.43 \text{ kgf/cm}^2 < \tau_{u3} = 8.8 \text{ kgf/cm}^2 \dots\dots\dots O.K$					
(e) stress in the imaginary concrete section					
$N = N_{min} = 25.6 \text{ tf (in case of earthquake condition)}$					
$M = 3.43 \text{ tf.m}$					
$D = 50 + 10 \times 2 = 70.0 \text{ cm}$					
$a = 11.0 \text{ cm} \times 2 = 22.0 \text{ cm}$					
$d = 24.0 \text{ cm}$					
					
$\delta_C = 17.3 \text{ kgf/cm}^2 < \delta_{ca} = 75 \times 15 = 112.5 \text{ kgf/cm}^2 \dots\dots\dots O.K$					
$\delta_S = 34 \text{ kgf/cm}^2 < \delta_{sa} = 2400 \text{ kgf/cm}^2 \dots\dots\dots O.K$					
D16 – 8 bars					
(f) reinforcing bar for inserted concrete					
$L_1 \geq L_0$					
bond length in footing $L_0 = 35\phi \text{ (mm)}$ $\phi = \text{reinforcing bar diameter (mm)}$ $L_1 = 35 \times 16 = 560 \div 600 \text{ mm}$					
bond length in footing $L_2 = 50\phi + L_0$ $\phi = \text{PC cable diameter (mm)}$ $L_2 = 50 \times 9.0 + 35 \times 16 = 1010 \text{ mm}$ $\div 1050 \text{ mm}$					
Stirrup : D13 per 150 mm pitch					
(g) height of inserted concrete					
$L_2 \geq 1050 \text{ mm}$					