

MECHANICAL AND ELECTRICAL

PROJECT :- ABU JABER HOUSE

AREA :- GROUND FLOOR

SUBJECT :- LIGHT LEVEL CALCULATION TABLE

ROOM NO.	DIM:- L X W X H	ROOM INDEX	INITIAL LUM. OUT PUT	MAIN FACTOR	UTILIZ. FACTOR	ARRANGEMENT DESIGN E/ in LUX.	RECOMMENDED E/ in LUX.	PURPOSE
G7	4.7*3.5*3.0	0.7	9753.0	0.8	0.335	158.90	150	GEN.LIGHT
(*)	2.15*1.25*2.15	0.4	11050	0.8	0.20	657.80	400	COUNTER
G12	6*4.4*3.0	0.85	18600.0	0.8	0.60	338.20	250	UTILITY
G13	3.75*5.0*3.0	0.7	11040	0.8	0.32	150.70	150	GENERAL
G14/1	3.1*4.0*3.0	0.58	24500	0.8	0.50	790.00	500	EXHIPIT.
G14/2	2.5*3.75*3.0	0.5	11040	0.8	0.20	188.00	150	GENERAL
G15	9.4*3.9*3.0	0.92	30920	0.8	0.60	404.80	400	EXHIPIT
G16	6.75*5.75*3.0	1.035	11870	0.8	0.63	154.14	150	GEN.LIGHT
*	5.0*1.5*2.15	0.54	23200	0.8	0.27	668.00	500	EXHIPIT
G17	6.0*5.6*3.0	0.97	14720	0.8	0.35	123	100	GENERAL
G18	5.5*3.7*3.0	0.52	10840	0.8	0.23	96.00	75	GENERAL
G19	5.37*4.325*3.0	0.81	20160	0.8	0.60	411.00	400	EXHIPIT

$$E_{av} = \frac{I_{nl} \times MF \times UF}{A}$$

WHERE:-
 I_{nl} = INITIAL LUMENS OUT PUT
 MF = MAINTENANCE FACTOR
 UF = UTILIZATION FACTOR

$$R_i = \frac{L \times W}{H(L + W)}$$

WHERE:-
 R_i = ROOM INDEX
 H = HEIGHT OF WORKING PLAN
 L = ROOM LENGTH
 W = ROOM WIDTH

SUBJECT :- LIGHT LEVEL CALCULATION TABLE

ROOM NO.	DIM:- LXW XH	ROOM INDEX	INITIAL LUM. OUT PUT	MAIN FACTOR	UTILIZ. FACTOR	ARRANGEMENT DESIGN E/ in LUX.	RECOMMENDED E/ in LUX.	PURPOSE
F2	5.0*4.5*3.0	0.7	25140	0.8	0.56	500	500	EXHIPIT
F3	6.25*3.75*3.0	0.8	8280	0.8	0.60	169	150	GENERAL
F3*	3.125*2.5*3.0	0.5	18880	0.8	0.45	850	500	EXHIPIT
F4	5.0*3.75*1.85	1.16	23760	0.8	0.61	618	500	EXHIPIT
F1	7.5*5.0*3.0	1.0	23100	0.8	0.60	296	15	GENERAL
F1	3.75*2.5*1.85	0.8	16200	0.8	0.55	760	500	EXHIPIT
F5	4.125*3.375*3.0	0.62	9660	0.8	0.35	194	150	GENERAL
F6	3.125*2.5*3.0	0.5	4730	0.7	0.25	105	100	UTILITY
F7/1	5.6*3.75*2.2	1.0	5520	0.8	0.60	126	90	CORREDOR
F7/2	10*5.0*2.2	1.5	11340	0.8	0.62	112	90	BALCONY
F9	6.25*1.25*3.0	2.0	4140	0.8	0.65	275	120	STAIR WAY
F10/1	4.375*3.12*1.85	1.0	23760	0.8	0.60	835	500	EXHIPIT
F10/2	7.5*3.5*1.85	1.3	37200	0.8	0.63	714	500	EXHIPIT
F11	3.125*2.5*3.0	0.46	6700	0.7	0.20	120	100	UTILITY
F12	3.4*2.5*1.85	0.78	10500	0.8	0.58	573	500	EXHIPIT
F13/1	3.75*3.1*1.85	0.92	11880	0.8	0.60	490	500	EXHIPIT
F13/2	4.25*2.5*1.85	0.85	14700	0.8	0.60	664	500	EXHIPIT
F14	5.0*4.7*3.0	0.8	15180	0.8	0.60	310	300	PUBLIC
F16	4.25*2.5*3.0	0.54	9660	0.7	0.25	159	150	TOILET
F17	9.4*3.75*1.85	1.34	39400	0.8	0.62	554	500	EXHIPIT
F18	6.75*4.5*1.85	1.45	29280	0.8	0.63	486	500	GEN.+EXH.
F19	5.0*3.12*1.85	1.00	26520	0.8	0.60	816	500	EXHIPIT
F20	4.8*3.25*1.85	1.00	26520	0.8	0.60	816	500	EXHIPIT

PROJECT :- ABU JABER HOUSE

AREA :- SECOND FLOOR

SUBJECT :- LIGHT LEVEL CALCULATION TABLE

ROOM NO.	DIM:- L X W X H	ROOM INDEX	INITIAL LUM. OUT PUT	MAIN FACTOR	UTILIZ. FACTOR	ARRANGEMENT DESIGN E/ In LUX.	RECOMMENDED E/ In LUX.	PURPOSE
S1	5.0*5.6*2.2	1.2	5520	0.8	0.65	94.00	90-100	YARD
S2	6.0*2.5*3.0	0.6	13260	0.8	0.40	339	300	PUBLIC
S3	5.0*4.0*3.0	0.75	16760	0.8	0.45	301	300	GEN.+EXH.
S4	4.85*4.0*3.0	0.75	21000	0.8	0.45	389	300	GEN.+EXH.
S5	6.25*5.6*3.0	1.0	8280	0.8	0.60	113	100-120	PUBLIC
S6	4.75*3.5*3.0	0.7	34400	0.8	0.38	629	500	EXHIPIT
S7	4.376*3.75*3.0	0.6	16020	0.8	0.40	312	300	GEN.+EXH.
S10	5.6*3.12*3.0	0.7	15180	0.8	0.38	264	150-200	PUBLIC
S11	7.5*3.75*3.0	0.8	24400	0.8	0.50	347	300	PUBLIC+RECEP.
S12	12.0*5.0*3.0	1.1	45500	0.8	0.60	437	400	EX.+CHILDREN
S14	5.25*4.5*3.0	0.8	16020	0.8	0.5	271	250	RECEP.
S18	5.7*4.4*3.0	0.82	12420	0.8	0.50	124	100	COURT YARD
S19	10*4.0*3.0	0.95	26220	0.8	0.8	420	400	MADAFAH
S20	5.7*5.1*3.0	0.9	12420	0.8	0.5	170	150	PUBLIC
S21	5.0*3.75*3.0	0.7	6900	0.8	0.38	111	100	REC.ROOM
S22	4.2*4.5*3.0	0.72	16020	0.8	0.4	271	200-250	DINNING RD.
S23	4.4*2.5*3.0	0.53	5520	0.8	0.30	120	100	MONEH

SOLAR GAIN FACTORS

JOB NAME :- BET ABU JABER
ESTIMATE FOR :- AUG. MONTH
ELEVATION :- 980
EQUIP OPER :- 12 HRS/DAY

LOCATION :- AL-SALT JORDAN
3PM TIME

1- EXPOSURE	NORTTH	EST	SOUTH	WEST	HORS
2- SOLAR GAIN	11	165	63	165	235
3- CORR.STEEL SASH	1.17	1.17	1.17	1.17	1.17
4- CORR.HAZE	1.0	1.0	1.0	1.0	1.0
5- CORR.ALTITUDE	1.006	1.006	1.006	1.006	1.006
6- CORR.DEW POINT	0.998	0.998	0.998	0.998	0.998
7- CORR.SOUTH LAT	1	1	1	1	1
8- STORAGE FACTOR	0.98	0.21	0.65	0.36	0.5
9- SUN GAIN	12.79	39.8	48	70	9.2
10- SHADE FACTOR	0.54	0.54	0.54	0.54	0.54

ملاحظة:-

- Design Temp (out) 90°F
- " " (in) 70°F

درجات الحرارة التصميمية الخارجية ٩٠. فهرنت

درجات الحرارة التصميمية الداخلية ٧٠. فهرنت

EQUIVALENT TEMPERATURE DIFFERENCE

COLOR	MON.LAT	CALCULTION
MEDIUM	AUG . 32	$ETD=0.78 (RS/RM)+\Delta tem+(1-0.78Rs/Rm)\Delta tes$

	ROOF TABL	WALL EXPOSURE TABLE				
		NORT H	EAST	SOUT H	WEST	
1- DESIGN MONTH	AUG	-	-	-	-	
2- DESIGN TIME	3PM	-	-	-	-	
3- COLOR	MED	-	-	-	-	
4- WEIGHT	70	60	-	-	-	
5- DES.D.B.TABLE-1	90	-	-	-	-	JORDAINIAN CODE
6-CORR. TABL-3	0	-	-	-	-	
7- 3PM.DB =5+6	90	-	-	-	-	
8- ROOM DES.DB	70	-	-	-	-	JORDAINIAN CODE
9- $\Delta t = 7-8$	20					
10- daily RANGE	15	-	-	-	-	
11-TABLE 20 A.COOR	7.5	-	-	-	-	
12- Δt (EX.POS) TABLE (19-20)	28	3	20	15	10	
13- Δt (EM) =12+11	35.5	10.5	27.5	22.5	17.5	
14- Rs.TABLE6 (MON-LAT)	211.2	12.8	164.4	70.8	164.4	
15- Rm.tab.6(JUL-40N)	233	15	164	69	164	
16- Rs/Rm	0906	0.85	1.002	1.02	1.02	
17- Δt (SHADE)TABLE 19OR20	4	3	3	3	3	
18- $\Delta tes=17+11$	11.5	10.5	10.5	10.5	10.5	
19 $ETD=0.78(Rs/Rm)\Delta tem+(1-0.78Rs/Rm)\Delta tes$	28.40	10.5	29.6	20.4	16.06	

PROJECT NAME: ABU Jaber
 SPACE NUMBER: 1 FLOOR: 1st
 AREA: 475 sq Ft
 VOLUME: _____
 LAT. 321 SUN NR. 3 MONTH: Aug.

CONDITION	DB	WB	RH	GR/LB	BTU/LB
OUTSIDE AIR TEMP	90	68	36%		
SPACE AIR TEMP	76	59	50%		
DIFFERENCE					
OPERATING TIME	12 HOURS				

SHEET 1 OF 6
 PROJECT NO. _____
 DATE _____
 COMPUTED BY _____
 CHECKED BY _____

CEC - AIR CONDITIONING - LOAD ESTIMATE SHEET

ITEMS	AREA OR QUANTITY	GAIN ΔT	FACTOR	BTUS/HR			ITEMS	BTUS/HR		
GLASS	N CLASS 58	x 12,8	x 1			765	LATEST HEAT GAINS	INFILTRATION	CFM x CR/LB @ 0.68	
	S CLASS 24	x 48	x 1			1185		PEOPLE 15 x 205		307
	GLASS	x	x					PEOPLE	x	
	GLASS	x	x					STEAM	LB/HR. x 1000	
	GLASS	x	x					APPLIANCES		
	SMD GLASS	x	x					SUBTOTAL		
	SMD GLASS	x	x					SAFETY FACTOR	5.1	
SKYLIGHT	x	x				SPACE LATENT HEAT GAINS (CSLH)		13	017	
WALLS & ROOFS	N WALL 72	x 10,5	x 0,25			190	DUCT LEAKAGE LOSSES			
	WALL 106	x 20,4	x 0,25			546	B.P.F. AIR	CFM x GR/LB @ 0.68		
	WALL	x	x				EFFECTIVE SPACE LATENT HEAT GAINS (CSLH)		3	22
	WALL	x	x				EFFECTIVE SPACE SENS. HEAT GAINS (CSSH)		22	121
	WALL	x	x				EFFECTIVE SPACE TOTAL HEAT GAINS (ESTH)		24	59
	SMD WALL	x	x				SENSIBLE HEAT FACTOR	21315		
	SUN ROOF	x	x				INDICATED ADP 48 °F, SELECTED ADP 48		24590	(CSSH) - 0,8
SMD ROOF	x	x				DEHUMIDIFIED AIR TEMPERATURE RISE (ΔT) - 22			(ESRH)	
EXP FLOOR	x	x				(1 - 0.8) x (space 70°F - adp 48°F) - 22			48	
TRANSMISSION & INFILTRATION	CLASS 82	x 20	x 1			1690	DEHUMIDIFIED AIR VOLUME			
	CLASS	x	x				24590 (ESRH)			
	CLASS	x	x				1.08 x °F DEH. AIR ΔT 22 = 1115			
	PARTITION 356	x 15	x 0,2			1070	OUTLET TEMPERATURE DIFFERENCE (SPACE T - OUTLET AIR T)			
	PARTITION	x	x				(SSH)			
	PARTITION	x	x				1.08 x CFM DEH. AIR			
	FLOOR 475	x 1,5	x 0,3			2140	SUPPLY AIR VOLUME			
CEILING	x	x				(SSH)				
INFILTRATION	CFM x	x	x 1.08				1.08 x °F DESTROY ΔT			
PEOPLE 15	x 245				3675	ENTERING AIR: °F DB °F WB LEAVING AIR: °F DB °F WB				
PEOPLE	x									
POWER	HP OR KW x									
LIGHTS 475	x 1,25	x 3,4			7280	FRESH AIR 15 x 15		225		
APPLIANCES	x									
SUBTOTAL					18535	FASH 225 CFM x 20 °F (1 - 0.8) x 1.08		4860		
SAFETY FACTOR 1.5					27800	FALM - CFM x CR/LB (1 - 0.8) x 0.68				
SPACE SENSIBLE HEAT GAINS (CSSH)					21315	FA TOTAL HEAT GAINS		4860		
LEAKAGE, DUCT AND FAN GAINS						EFFECTIVE SPACE TOTAL HEAT GAINS		24590		
B.P.F. AIR	CFM x	x 0.68 x 1.08				GRAND TOTAL HEAT GAINS		29400		
EFFECTIVE SPACE SENSIBLE HEAT GAINS (ESSH)					21315	TONNAGE	129400	2.5		
							12.000	10015		

NOTES:

PROJECT NAME Asu-Jaber
 SPACE NUMBER 2 FLOOR First
 AREA 413 sq ft
 VOLUME _____
 LAT. 32 SUN HR. 3 MONTH Aug.

CONDITION	DB	WB	RAH	GR/LB	BTU/LB
OUTSIDE AIR TEMP	90	68	36%		
SPACE AIR TEMP	70	69	50%		
DIFFERENCE					
OPERATING TIME	HOURS				

SHEET 2 OF 6
 PROJECT NO. _____
 DATE _____
 COMPUTED BY _____
 CHECKED BY _____

SEC - AIR CONDITIONING LOAD ESTIMATE SHEET

HEAT GAIN	ITEMS	AREA OR QUANTITY	GAIN ΔT	FACTOR	BTUS/HR			ITEMS			BTUS/HR				
GLASS	N GLASS	50	x 12.8	x 1			660	LATEST HEAT GAINS	INFILTRATION	CFM X CR/LB 20.68					
	W GLASS	66	x 7.0	x 1			4760		PEOPLE	9 X 205			1840		
	S GLASS	24	x 4.8	x 1			1190		PEOPLE	X					
	GLASS	X	X	X					STEAM	LB/HR. X 1000					
	GLASS	X	X	X					APPLIANCES						
	SND GLASS	X	X	X					SUBTOTAL						
	SND GLASS	X	X	X					SAFETY FACTOR		5			840	
	SKYLIGHT	X	X	X					SPACE LATENT HEAT GAINS (ESLI)					1910	
WALLS & ROOFS	N WALL	145	x 19.5	x 0.25			300	DUCT LEAKAGE LOSSES							
	W WALL	225	x 16	x 0.25			720	B.P.F. AIR	CFM X CF/LB X 10.68						
	S WALL	138	x 29.4	x 0.25			560	EFFECTIVE SPACE LATENT HEAT GAINS (ESLI)				7935			
	WALL	X	X	X				EFFECTIVE SPACE SENS. HEAT GAINS (ESSI)				124680			
	SND WALL	X	X	X				EFFECTIVE SPACE TOTAL HEAT GAINS (ESTH)				26615			
	SUN ROOF	X	X	X				SENSIBLE HEAT FACTOR		24680			(ESSI)		
	SND ROOF	X	X	X				INDICATED ADP	49	OF 26615			SELECTED ADP	49	
	EXP FLOOR	X	X	X				DEHUMIDIFIED AIR TEMPERATURE RISE (ΔT)		-21			(ESRH)	0.4	
TRANSMISSION & INFILTRATION	GLASS	140	x 20	x 1			2890	(1 - bf) X (space T70°F - ADP49°F)		-21					
	GLASS	X	X	X				DEHUMIDIFIED AIR VOLUME							
	GLASS	X	X	X				26615 (ESTH)							
	PARTITION	X	X	X				1.08 X OF DEH. AIR ΔT		21		1170	CFM		
	PARTITION	X	X	X				OUTLET TEMPERATURE DIFFERENCE (SPACE 1 - OUTLET AIR T)							
	PARTITION	X	X	X				(ESSI)							
	FLOOR	413	x 15	x 0.3			1860	1.08 X CFM DEH. AIR							
	CEILING	X	X	X				SUPPLY AIR VOLUME							
INFILTRATION	CFM	X	X	1.08			(ESSI)								
PEOPLE & APPLIANCES	PEOPLE	9	x 245				2260	1.08 X OF DESIRED ΔT							
	PEOPLE	X	X					ENTERING AIR: °F DB °F WB LEAVING AIR: °F DB °F WB							
	POWER	HP OR KW	X					FRESH AIR	9 X 15			135	CFM		
	LIGHTS	413 X 1.2 X 3	X	3.4			6320	FASH	135 CFM X 20 °F (1 - bf) X 1.08			2916			
SUBTOTAL	SUBTOTAL						21466	FALM	CFM X CR/LB (1 - bf) X 0.68			2916			
	SAFETY FACTOR	1.5					3220	FA TOTAL HEAT GAINS				2916			
	SPACE SENSIBLE HEAT GAINS (SSH)						24680	EFFECTIVE SPACE TOTAL HEAT GAINS				26615			
LEAKAGE, DUCT AND FAN GAINS	LEAKAGE, DUCT AND FAN GAINS							GRAND TOTAL HEAT GAINS				29530			
	B.P.F. AIR	CFM X bf X 1.08						TONNAGE	12.5330			52.5	TONS		
EFFECTIVE SPACE SENSIBLE HEAT GAINS (ESSI)							24680								

NOTES:

PROJECT NAME: Abu Jaber
 SPACE NUMBER: 3 FLOOR: First
 AREA: 270 sq ft
 VOLUME: _____
 LAT: 32.1 SUN HR: 3 MONTH: Aug

CONDITION	DB	WB	RH	GR/LB	BTU/LB
OUTSIDE AIR TEMP	90	68	36%		
SPACE AIR TEMP	70	59	50%		
DIFFERENCE					
OPERATING TIME	HOURS				

SHEET 3 OF 6
 PROJECT NO: _____
 DATE: _____
 COMPUTED BY: _____
 CHECKED BY: _____

SEC - AIR CONDITIONING LOAD ESTIMATE SHEET

HEAT GAINS	ITEMS	AREA OR QUANTITY	GAIN ΔT	FACTOR	BTUS/HR		
GLASS	E GLASS	20	x 29.8	x 1			820
	GLASS	x	x	x			
	GLASS	x	x	x			
	GLASS	x	x	x			
	GLASS	x	x	x			
	SND GLASS	x	x	x			
	SND GLASS	x	x	x			
	SKYLIGHT	x	x	x			
WALLS & ROOFS	E WALL	142	x 29.6	x 0.25			846
	S WALL	195	x 20.4	x 0.25			780
	WALL	x	x	x			
	WALL	x	x	x			
	WALL	x	x	x			
	SND WALL	x	x	x			
	SUN ROOF	x	x	x			
	SND ROOF	x	x	x			
	EXP FLOOR	x	x	x			
TRANSMISSION & INFILTRATION	GLASS	20	x 20	x 1			410
	GLASS	x	x	x			
	GLASS	x	x	x			
	PARTITION	195	x 15	x 0.2			730
	PARTITION	x	x	x			
	PARTITION	x	x	x			
	FLOOR	270	x 15	x 0.3			1010
CEILING	x	x	x				
	INFILTRATION	CFM	x	x 1.00			
	PEOPLE	20	x 2us	x			4900
	PEOPLE	x	x	x			
	POWER	HP OR KW	x	x			
	LIGHTS	270 x 1.25 x 24 x 3.4					3200
	APPLIANCES	x	x	x			
	SUBTOTAL						14270
	SAFETY FACTOR	1.5					21000
	SPACE SENSIBLE HEAT GAINS (SSH)						16370
	LEAKAGE, DUCT AND FAN GAINS						
	D.P.F. AIR	CFM	x	x bf x 1.00			
	EFFECTIVE SPACE SENSIBLE HEAT GAINS (ESSH)						16370

ITEMS		BTUS/HR	
LATENT HEAT GAINS	INFILTRATION	CFM x GR/LB x 0.68	
	PEOPLE	20 x 205	4100
	PEOPLE	x	
	STEAM	LBS/HR. x 1000	
	APPLIANCES		
SUBTOTAL			4100
SAFETY FACTOR		5	20500
SPACE LATENT HEAT GAINS (SLH)			14270
DUCT LEAKAGE LOSSES			
D.P.F. AIR		CFM x GR/LB x 0.68	
EFFECTIVE SPACE LATENT HEAT GAINS (ESLH)			4270
EFFECTIVE SPACE SENS. HEAT GAINS (ESSH)			16370
EFFECTIVE SPACE TOTAL HEAT GAINS (ESTH)			20670
SENSIBLE HEAT FACTOR		16370	(ESSH)
INDICATED ADP		us	(ESPH) - 79
DEHUMIDIFIED AIR TEMPERATURE RISE (ΔT)		-25	
(1 - bf) x (space T - 70°F - ADP us)		-25	
DEHUMIDIFIED AIR VOLUME			
1.00 x OF DEH. AIR ΔT		825	CFM
OUTLET TEMPERATURE DIFFERENCE (SPACE T - OUTLET AIR T)			
(SSH)			
1.00 x CFM DEH. AIR			
SUPPLY AIR VOLUME			
(SSH)			
1.00 x OF DESIRED ΔT			
ENTERING AIR: °F DB °F WB LEAVING AIR: °F DB °F WB			
FRESH AIR		20 x 15 = 300	CFM
FASH		20 CFM x 20 x (1 - bf) x 1.00	
FALH		CFM x GR/LB (1 - bf) x 0.68	
FA TOTAL HEAT GAINS			6400
EFFECTIVE SPACE TOTAL HEAT GAINS			20670
GRAND TOTAL HEAT GAINS			27070
TONNAGE		27070	12,000 - 2

NOTES:

PROJECT NAME: Abu-Jaber
 SPACE NUMBER: 4 FLOOR: First
 AREA: 475 SQ. FT.
 VOLUME: _____
 LAT. 32 SUN HR: 2 MONTH: Aug

CONDITION	DB	WB	DRH	GR/LB	BTU/LB
OUTSIDE AIR TEMP	90	68	36%		
SPACE AIR TEMP	70	59	50%		
DIFFERENCE					
OPERATING TIME	HOURS				

SHEET 4 OF 6
 PROJECT NO: _____
 DATE: _____
 COMPUTED BY: _____
 CHECKED BY: _____

CEC - AIR CONDITIONING LOAD ESTIMATE SHEET

GLASS	ITEMS	AREA OR QUANTITY	GAIN ΔT	FACTOR	BTUS/HR			ITEMS	BTUS/HR			
GLASS	N GLASS	486	12.8	1			6400	INFILTRATION	CFM X CR/LB 90.68			
	GLASS	X	X	X				PEOPLE	20 X 205		205	
	GLASS	X	X	X				PEOPLE	X			
	GLASS	X	X	X				STEAM	LB/HR. X 1000			
	GLASS	X	X	X				APPLIANCES				
	SND GLASS	X	X	X				SUBTOTAL			205	
	SND GLASS	X	X	X				SAFETY FACTOR	5.1		1050	
WALLS & ROOFS	S WALL	259	29.6	0.25			1530	SPACE LATENT HEAT GAINS (SLII)			2150	
	W WALL	130	10.5	0.25			270	DUCT LEAKAGE LOSSES				
	W WALL	X	X	X				B.P.F. AIR	CFM X CR/LB X 10.68			
	W WALL	X	X	X				EFFECTIVE SPACE LATENT HEAT GAINS (ESLI)			2150	
	SND WALL	X	X	X				EFFECTIVE SPACE SENS. HEAT GAINS (ESSII)			2023.5	
	SUN ROOF	X	X	X				EFFECTIVE SPACE TOTAL HEAT GAINS (ESTII)			2248.5	
	SND ROOF	X	X	X				SENSIBLE HEAT FACTOR	2025	(ESSII)		9.9
TRANSMISSION & INFILTRATION	GLASS	486	20	1			10000	INDICATED ADP	49	OF SELECTED ADP	49	OF
	GLASS	X	X	X				DEHUMIDIFIED AIR TEMPERATURE RISE (ΔT)	2φ			
	GLASS	X	X	X				(1 - SE) X (SPACE 70°F - ADP 49°F)	21			
	PARTITION	259	15	0.2			885	DEHUMIDIFIED AIR VOLUME				
	PARTITION	X	X	X				2248.5 (ESTII)			1070	CFM
	PARTITION	X	X	X				1.08 X OF DEH. AIR ΔT				
	FLOOR	475	15	0.3			1780	OUTLET TEMPERATURE DIFFERENCE (SPACE T - OUTLET AIR T)				
PEOPLE & APPLIANCES	CEILING	475	15	0.3			1780	(SSII)				
	INFILTRATION	CFM X	X	1.08				1.08 X CFM DEH. AIR				
	PEOPLE	10	245	X			2450	SUPPLY AIR VOLUME				
	PEOPLE	X	X	X				(SSII)				
	POWER	HP OR KW X	X	X				1.08 X OF DESIRED ΔT				
	LIGHTS	475 X 1.25 W X 3.4					5800	ENTERING AIR: °F DB °F WB LEAVING AIR: °F DB °F WB				
	APPLIANCES	X	X	X				FRESH AIR 10 X 15 = 150				
SUBTOTAL	SUBTOTAL						17680.5	FAN 60 CFM X 20 OF (1 - SE) X 1.08			3200	
	SAFETY FACTOR	1.5					26520.8	FAN - CFM X CR/LB (1 - SE) X 0.68				
	SPACE SENSIBLE HEAT GAINS (SSII)						2023.5	FA TOTAL HEAT GAINS			3200	
EFFECTIVE SPACE SENSIBLE HEAT GAINS (ESSII)	LEAKAGE, DUCT AND FAN GAINS							EFFECTIVE SPACE TOTAL HEAT GAINS			2248.5	
	B.P.F. AIR	CFM X	X	SE X 1.08				GRAND TOTAL HEAT GAINS			2568.5	
	EFFECTIVE SPACE SENSIBLE HEAT GAINS (ESSII)						2023.5	TONNAGE	2568.5	11,000	2	TONS

NOTES:

PROJECT NAME Abu-Jaber
 SPACE NUMBER 1 FLOOR SECOND
 AREA 237 SQ FT
 VOLUME _____
 LAT. 221 SUN. NR. 3 MONTH Aug

CONDITION	DB	WB	GRH	GR/LB	BTU/LO
OUTSIDE AIR TEMP	90	68	36%		
SPACE AIR TEMP	70	59	50%		
DIFFERENCE					
OPERATING TIME	HOURS				

SHEET 5 OF 6
 PROJECT NO. _____
 DATE _____
 COMPUTED BY _____
 CHECKED BY _____

SEC - AIR CONDITIONING LOAD ESTIMATE SHEET

ITEMS	AREA OR QUANTITY	GAIN ΔT	FACTOR	BTU/HR			
GLASS	W GLASS 48.6	x 70	x 1			3500	
	GLASS	x	x				
	GLASS	x	x				
	GLASS	x	x				
	GLASS	x	x				
	SMD GLASS	x	x				
	SMD GLASS SKYLIGHT	x	x				
WALLS & ROOFS	W WALL 130	x 16	x 0.25			410	
	S WALL 130	x 20.4	x 0.25			520	
	WALL	x	x				
	WALL	x	x				
	WALL	x	x				
	SMD WALL	x	x				
	SUN ROOF 237	x 28	x 0.3			1990	
SMD ROOF	x	x					
EXP FLOOR	x	x					
TRANSMISSION & INFILTRATION	GLASS 48.6	x 20	x 1			1000	
	GLASS	x	x				
	GLASS	x	x				
	PARTITION 178	x 15	x 0.2			535	
	PARTITION	x	x				
	PARTITION	x	x				
	FLOOR 237	x 15	x 0.8			1065	
CEILING	x	x					
INFILTRATION	CFM	x	x 1.00				
LATENT HEAT GAINS	PEOPLE 5	x 265				1225	
	PEOPLE	x					
	POWER	HP OR KW x					
	LIGHTS 237 x 1.25 x 3.4					2900	
APPLIANCES	x						
SUBTOTAL						12765	
SAFETY FACTOR 1.5						1915	
SPACE SENSIBLE HEAT GAINS (SSSH)						14680	
LEAKAGE, DUCT AND FAN GAINS							
D.P.F. AIR	CFM x	x DF x 1.00					
EFFECTIVE SPACE SENSIBLE HEAT GAINS (ESSSH)						14680	

ITEMS	BTU/HR
INFILTRATION	CFM x CR/LB x 0.68
PEOPLE	5 x 205
PEOPLE	x
STEAM	LOS/HR. x 1000
APPLIANCES	
SUBTOTAL	
SAFETY FACTOR 1.5	
SPACE LATENT HEAT GAINS (ESLH)	1020
DUCT LEAKAGE LOSSES	
D.P.F. AIR	CFM x CR/LB x 0.68
EFFECTIVE SPACE LATENT HEAT GAINS (ESLH)	1020
EFFECTIVE SPACE SENS. HEAT GAINS (ESSH)	14680
EFFECTIVE SPACE TOTAL HEAT GAINS (ESTH)	15700
SENSIBLE HEAT FACTOR	14680 (ESSH) / 15700 (ESTH) = 0.93
INDICATED ADP	50 °F, SELECTED ADP 50 °F
DEHUMIDIFIED AIR TEMPERATURE RISE (ΔT)	20
(1 - SF) x (space ΔT of 50 °F)	20
DEHUMIDIFIED AIR VOLUME	14680 (ESTH) / 1.08 x ΔT 20 = 720 CFM
OUTLET TEMPERATURE DIFFERENCE (SPACE 1 - OUTLET AIR T)	(SSH)
1.08 x CFM DEH. AIR	
SUPPLY AIR VOLUME	(SSH)
1.08 x °F DESIRED ΔT	
ENTERING AIR: °F DB °F WB LEAVING AIR: °F DB °F WB	
FRESH AIR	5 x 10
FAN 75 CFM x 20 °F (1 - DF) x 1.08	
FAN	CFM x CR/LB (1 - DF) x 0.68
FA TOTAL HEAT GAINS	1620
EFFECTIVE SPACE TOTAL HEAT GAINS	15700
GRAND TOTAL HEAT GAINS	17320
TONNAGE	17320 / 12000 = 1.44

NOTES:

PROJECT NAME Abu-Jaber
 SPACE NUMBER 2 FLOOR second
 AREA 564 sq. ft.
 VOLUME _____
 LAT. 32.1 SUN HR. 3 MONTH Aug

CONDITION	DB	WB	SRH	GR/LB	BTU/LB
OUTSIDE AIR TEMP	90	68	36%		
SPACE AIR TEMP	70	59	50%		
DIFFERENCE					
OPERATING TIME	HOURS				

SHEET 6 OF 6
 PROJECT NO. _____
 DATE _____
 COMPUTED BY _____
 CHECKED BY _____

CEC - AIR CONDITIONING LOAD ESTIMATE SHEET

HEAT GAIN	ITEMS	AREA OR QUANTITY	GAIN ΔT	FACTOR	BTUS/HR					ITEMS	BTUS/HR										
					1	2	3	4	5		1	2	3	4	5						
GLASS	N GLASS	64.8	12.8	1				856													
	W GLASS	32.4	7.0	1				2340													
	GLASS																				
	GLASS																				
	GLASS																				
	SND GLASS																				
	SND GLASS																				
	SKYLIGHT																				
WALLS & ROOFS	N WALL	254	10.5	0.25				540													
	W WALL	180	16	0.25				420													
	S WALL	162	20.4	0.25				660													
	WALL																				
	WALL																				
	SND WALL																				
	SUN ROOF	564	28	0.3				4740													
	SND ROOF																				
	EXP FLOOR																				
TRANSMISSION & INFILTRATION	GLASS	97.2	20	1				1950													
	GLASS																				
	GLASS																				
	PARTITION	178	15	0.2				536													
	PARTITION																				
	PARTITION																				
	FLOOR																				
	CEILING																				
	INFILTRATION																				
		CFM																			
LATENT HEAT GAINS	PEOPLE	15	245					3675													
	PEOPLE																				
	POWER																				
	LIGHTS	564	125					7140													
	LIGHTS																				
	APPLIANCES																				
	SUBTOTAL							22860													
	SAFETY FACTOR	1.5						34290													
	SPACE SENSIBLE HEAT GAINS (SSSH)							26290													
	LEAKAGE, DUCT AND FAN GAINS																				
B.P.F. AIR																					
EFFECTIVE SPACE SENSIBLE HEAT GAINS (ESSSH)								26290													
LATENT HEAT GAINS	INFILTRATION																				
	PEOPLE	15	205					3075													
	PEOPLE																				
	STEAM APPLIANCES																				
	SUBTOTAL							3075													
	SAFETY FACTOR	1						3075													
	SPACE LATENT HEAT GAINS (ESLH)							3075													
	DUCT LEAKAGE LOSSES																				
	B.P.F. AIR																				
	EFFECTIVE SPACE LATENT HEAT GAINS (ESLH)								3075												
EFFECTIVE SPACE SENS. HEAT GAINS (ESSH)								26290													
EFFECTIVE SPACE TOTAL HEAT GAINS (ESTH)								29515													
SENSIBLE HEAT FACTOR $\frac{26290}{29515} = 0.89$ (ESSH) (ESGH)										INDICATED ADP 49 OF, SELECTED ADP 49 OF											
DEHUMIDIFIED AIR TEMPERATURE RISE (ΔT) 2.1										(1 - SF) × (SPACE T ₇₀ OF - ADP 49 OF) = 2.1											
DEHUMIDIFIED AIR VOLUME 29515 (ESTH)										1.08 × OF DEH. AIR ΔT 2.1 = 1450 CFM											
OUTLET TEMPERATURE DIFFERENCE (SPACE T - OUTLET AIR T) (SSH)										1.08 × CFM DEH. AIR											
SUPPLY AIR VOLUME (SSH)										1.08 × OF DESIRED ΔT											
ENTERING AIR: °F DB °F WB LEAVING AIR: °F DB °F WB										FRESH AIR $15 \times 15 = 225$ CFM											
FASH 225 CFM × 20 °F (1 - SF) × 1.08										FALH 225 CFM × GR/LB (1 - SF) × 0.68											
FA TOTAL HEAT GAINS										EFFECTIVE SPACE TOTAL HEAT GAINS											
GRAND TOTAL HEAT GAINS										TONNAGE $\frac{29515}{11,000} = 2.68$											

NOTES:

Two units of 1.5 Tons each were added.