

JAPAN INTERNATIONAL COOPERATION AGENCY

BASIC DESIGN PACKAGE OF

RECOMMENDABLE WASTEWATER TREATMENT PLANT

FOR


EL NASR CO. FOR STEEL PIPES AND FITTINGS

February 2000





CHIYODA DAMES AND MOORE CO.

CHIYODA CORPORATION

1. Galvanising plant (0.5-4 inch pipes)
2. Pipe workshop
3. 0.5-4 inch pipe mill
4. Main spare parts store
5. Administration
6. Electric substation
7. Small fittings foundry (includes chemical store)
8. Galvanising plant (small fittings)
9. Covered store for waste oils
10. Product store (0.5-4 inch pipe)
11. Store for foundry raw materials
12. Product store (pipes) and scrap yard
13. Water cooling system (0.5-4 inch pipes)
14. Garage (includes car workshop)
15. Workshop
16. Transport department
17. Clinic
18. Product store (pipe fitting)
19. Large fitting foundry
20. Large fittings finishing area/workshop
21. Cooling for foundries
22. Casting foundries
23. Administration
24. Central material store
25. Main electrical substation
26. Coko store, scrap and limestone
27. Raw material store (coils)
28. Raw material store (coils)
29. Product stores (2-8 inch and spiral pipes)
30. Spiral pipe mill (6-18 and 6-60 inch)
31. 2-8 inch pipemill
32. Painting shop
33. Old spiral pipe mill (6-24 inch)
34. Raw material store (coils)
35. Fuel dispensing station
36. Oxygen plant
37. Central gas cylinder store
38. Zinc dress distillation
39. Open yard for waste dry solids (core sand, slag, etc)



EL MASR CO. FOR STEEL PIPES & FITTINGS
 LOCATION OF WASTEWATER TREATMENT PLANT
 DWG. NO. SP-BD-12-00



JICA	Check	Tech	Appr	Rev	Description	Dsgn	Check	Appr	Dt
Sign									
Date									
CHSL	Dsgn	Check	Appr						
Sign									
Date									

REVISION

Rev	Description	Dsgn	Check	Appr	Dt

CLIENT
JAPAN INTERNATIONAL COOPERATION AGENCY
INDUSTRIAL DEVELOPMENT STUDY DIVISION

CONSULTANT
CHIYODA DAMES & MOORE CO.
CHIYODA CORPORATION

PROJECT
THE STUDY ON INDUSTRIAL WASTE WATER
POLLUTION CONTROL IN
THE ARAB REPUBLIC OF EGYPT


TITLE
FOR
ENGINEERING FLOW DIAGRAM
LEAD SHEET(1/2)

ISSUED DATE

DWG NO

SCALE
None

REV.
0



Dwg No. SP-BD-15-01

Item	Stream No	(1)	(2)	(3)	Low 48/82	Low 93/62	Non Potable
Flow Rate Av.	[m ³ /D]	1700	1200	48			
Flow Rate Av.	[m ³ /h]	50	50	2.0			
Flow Rate Max	[m ³ /h]	150	150	3.0			
pH	[-]	6.5-8	6.5-8	6.5-8	6-10	6-9	60
SS	[mg/l]	30	10	550	<500	<100	100
BOD	[mg/l]	30	<30	186	<400	<100	60
COD	[mg/l]	80	<80	496	<700	<100	100
Oil & Grease	[mg/l]	5	<0.1	83	<100	<10	10
Pb	[mg/l]	Nil	Nil	Nil	<10	<10	35
Zn	[mg/l]	Nil	Nil	Nil	<10	<10	35
Water Temperature	[°C]	20-35	---	20-35	<40	<40	35

JCA	Check	Tech	Appr	Rev	Description	Drawn	Checked	Appr	Date

CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION

CONSULTANT: CHIRODA DAMES & MOORE CO.

PROJECT: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT


TITLE: FOR EL. WASH. CO. FOR STEEL PIPES AND FITTINGS PROCESS FLOW DIAGRAM FOR W.W.T. DEMONSTRATION PLANT (1/7)

DESIGNED DATE: SP-BD-15-01

DWG NO: SP-BD-15-01

SCALE: 1:1


REV: 0



JICA	Disc	Tech	Appr	Rev	Rev	Rev	Rev	Rev	Rev
Sign	Draw	Draw	Appr	Appr	Appr	Appr	Appr	Appr	Appr
DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE
DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE
REVISION									
CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION									
CONTRACT: CHITODA DAIKES & MOORE CO. CHITODA CORPORATION									
PROJECT: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT									
TITLE: FOR E. MASCOR CO. FOR STEEL PIPES AND FITTINGS ENGINEERING FLOW DIAGRAM FOR No. 1 W.W.T. RECOMMENDABLE PLANT (1/1)									
ISSUED DATE	SCALE	REV.	REV.	REV.	REV.	REV.	REV.	REV.	REV.
DWG NO	SP-80-14-01								

ITEM No.	2-101	2-102	2-103	PU-101A/B	PU-102A/B	PU-103A/B	MZ-101
SERVICE	No. 1 Wastewater Pfl	No. 2 Wastewater Pfl	No. 3 Wastewater Pfl	No. 1 Wastewater Pump	No. 2 Wastewater Pump	No. 3 Wastewater Pump	Belt Dr Summer
SIZE (m)	4.0m x 5.0m x 3.5mH	3.0m x 5.0m x 3.5mH	2.0m x 3.0m x 3.5mH	48m ³ /hr	36m ³ /hr	12m ³ /hr	W=300 D. 14W
DESIGN PRESSURE	Full Water	Full Water	Full Water	1.0	1.0	1.0	None
DESIGN TEMP. (C)	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.
MATERIAL TYPE	RC/Open Basin	RC/Open Basin	RC/Open Basin	SCS/Centrifugal	SCS/Centrifugal	SCS/Centrifugal	Vertical

D-01 MZ-01 D-01 D-02 MX-01



ITEM No.	PU-03A/B	MX-01
SERVICE	Neutralized W.W. Pump	No. 1 Line Mixer
SIZE (m)	48m ³ /hr @ 0.15m/s	1.5m x 1.2m
DESIGN PRESS (w/m)	0.5	Full Water
DESIGN TEMP (C)	Amb.	Amb.
MATERIAL/TYP	SS/Centrif. Horiz.	CS/Verti.
ITEM No.	D-01	D-07
SERVICE	Line Hopper	No. 1 Line Drum
SIZE (m)	1.3m x 0.15m	1.5m x 1.5m
DESIGN PRESS (w/m)	0.5	Full Water
DESIGN TEMP (C)	Amb.	Amb.
MATERIAL/TYP	CS/Cylindrical Verti.	CS/Cylindrical Verti.

ITEM No.	I-01	I-02	I-03	MZ-02	PU-01A/B	PU-02A/B
SERVICE	Neutralization Tank	No. 1 Sedimentation Tank	Neutralized W.W. Tank	No. 1 Sludge Roks	No. 1 Line Pump	No. 1 Sludge Pump
SIZE (m)	2.8m x 5.2m x 3.0m	5.8m x 3.0m	2.5m x 1.7m x 3.0m	1.5m	10.0m x 0.5m x 0.75m	4m ³ /hr @ 0.25m/s
DESIGN PRESS (w/m)	0.5	Full Water	Full Water	Nont	0.5	0.5
DESIGN TEMP (C)	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.
MATERIAL/TYP	CS + Resin Lining	CS + Resin Lining/Circul.	CS + Lining	CS/Centr. Drive	D/Centrif. Horiz.	SS/Centrif. Horiz.

Rev	Description	Design	Check	Appr	Date
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY
INDUSTRIAL DEVELOPMENT STUDY DIVISION

CONSULTANT: CHYUOYA DAIKES & MOORE CO.
CHYUOYA CORPORATION

PROJECT: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT

TITLE: FOR EL NASR CO. FOR STEEL PIPES AND FITTINGS ENGINEERING P.O. DIAGRAM FOR No. 1 W.W.T. RECYCLING TREATMENT PLANT (1/3)

ISSUED DATE: SCALE: DRAWING NO: SP-80-18-02

REV. NO: 0




Z-01

Z-02

Z-03

PU-05

I-04




ITEM No.	Z-01	Z-02	Z-03	I-04	PU-04A/B	PU-05
DEVICE	Oil Separator T.W.P.H	Oil Separator T.W.P.H	Oil Separator T.W.P.H	Skummed Oil Tank	Oil Separator T.W.P.H	Recovered Oil Pump
SIZE (m)	1.5mWx2.5mLx3.0mD	2.4mWx2.5mLx3.0mD	1.5mWx2.0mLx3.0mD	3.4mDx6.1mL	3.6mWx1.8mLx2.5mD	1.5mWx1.5mHx2.2mW
DISCH PRESSURE	Full Water	Full Water	Full Water	Full Water	Full Water	Full Water
DISCH TEMP (°C)	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.
MATERIAL/TYP	RC/API	RC/Open Basin	RC/Closed Basin	CS/Cont Roof Tank	SCS/Centrif. Vert.	CI/Centrif. Vert.

JICA	Check	Tech	Appr	Sign	Deliv	Draw	Check	Appr	Sign	Deliv	Draw	Check	Appr	Sign	Deliv	Draw

INDUSTRIAL DEVELOPMENT STUDY DIVISION
 JAPAN INTERNATIONAL COOPERATION AGENCY
 CONSULTANT
 CHYODA DAIKES & MOORE CO.
 CHYODA CORPORATION
 PROJECT
 THE STUDY ON INDUSTRIAL WASTE WATER TREATMENT FACILITY AT THE WASTE PLANT OF THE ARAB REPUBLIC OF EGYPT
 TITLE
 FOR EL-HAKR CO. FOR STEEL PIPES AND FITTINGS EXPANDED FOR EXPANSION FOR No. 1 W.P.H. RECOVERED OIL PUMP (1/A)
 ISSUED DATE
 DWG NO
 SP-BD-11-03
 REV.
 0

D-04A/B
MX-02A/B PU-06A/B

D-05A/B
MX-03A/B PU-07A/B



ITEM No.	1-06
SERVICE	Eq. Water Pump
SIZE(m)	9.0mDx1.0mH
DESIGN PRESSURE	1.0
DESIGN TEMP.(°C)	Amb.
MATERIAL/TYPE	CS/Horizontal
SERVICE	Eq. Water Pump
SIZE(m)	9.0mDx1.0mH
DESIGN PRESSURE	1.0
DESIGN TEMP.(°C)	Amb.
MATERIAL/TYPE	CS/Horizontal

ITEM No.	PU-03A/B	PU-04A/B	PU-103A/B	PU-18A/B	PU-08A/B	PU-07A/B	PU-08A/B
SERVICE	Water Pump	Water Pump	Water Pump	Water Pump	Water Pump	Water Pump	Water Pump
SIZE(m)	0.7mDx1.5mH	0.7mDx1.5mH	0.7mDx1.5mH	0.7mDx1.5mH	0.7mDx1.5mH	0.7mDx1.5mH	0.7mDx1.5mH
DESIGN PRESSURE	1.0	1.0	1.0	1.0	1.0	1.0	1.0
DESIGN TEMP.(°C)	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.
MATERIAL/TYPE	CS/Horizontal	CS/Horizontal	CS/Horizontal	CS/Horizontal	CS/Horizontal	CS/Horizontal	CS/Horizontal


NO.	DATE	BY	CHK	APP	REV	DESCRIPTION

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION
CONSULTANT	CHYODA DAIKES & MOORE CO. CHYODA CORPORATION
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT
TITLE	FOR D. HASR CO. FOR STEEL PIPES AND FITTINGS PACKAGING FLOW DIAGRAM FOR INDUSTRIAL WASTE WATER PLANT (1/2)
ISSUED DATE	SP-80-15-04
DWG NO.	SP-80-15-04
SCALE	
REV.	

D-06A/B
MX-04A/B

D-07A/B
MX-05A/B

D-08A/B
MX-06A/B



ITEM No.	DESCRIPTION	UNIT	QTY	REMARKS
D-06A/B	No.2 Lime Drum 1.4mDx1.8mH Full Water	CS/Vert.	2	
D-07A/B	No.1 Coagulant Drum 1.2mDx1.8mH Full Water	CS+HR/Vert.	1	
D-08A/B	No.2 Coagulant Drum 1.2mDx1.8mH Full Water	CS/Vert.	2	
MX-04A/B	No.2 Lime Mixer 1.5WxL=1.2m None	SUS/Vertical	2	
MX-05A/B	No.2 Lime Mixer 0.75WxL=1.2m None	SUS/Vertical	2	
MX-06A/B	No.2 Lime Mixer 0.75WxL=1.0m None	SUS/Vertical	2	
PU-09A/B	No.2 Limit Pump 0.8L/minx0.5HPx0.4KW 1.0	AMB.	2	
PU-10A/B	No.2 Limit Pump 0.3L/minx0.5HPx0.4KW 1.0	AMB.	2	
PU-11A/B	No.2 Limit Pump 0.3L/minx0.5HPx0.4KW 1.0	AMB.	2	

JICA	Drawn	Check	Appr.	Rev.	Date

CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY
INDUSTRIAL DEVELOPMENT STUDY DIVISION

CONSULTANT: CHIRODA DAMES & MOORE CO.
CHIRODA CORPORATION

PROJECT: THE STUDY ON INDUSTRIAL WASTE WATER
POLLUTION CONTROL IN
THE ARAB REPUBLIC OF EGYPT

TITLE: FOR E. WASCOR CO. FOR STEEL PIPES AND FITTINGS
ENGINEERING FLOW DIAGRAM FOR
No. 1 W.W.T. RECOMMENDABLE PLANT(S/A)

ISSUED DATE: _____ SCALE: _____


DWG NO: SP-80-14-08 REV. _____

I-07
MX-07

I-08
MX-08

Z-05

Z-06




ACI	Dist	Yr	Appr	Rev	Rev

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION
CONSULTANT	CHITODA DAMES & MOORE CO. CHITODA CORPORATION
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER TREATMENT AND REUSE AT THE JAWH REFINERY OF EGYPT
TITLE	FOR EL MASR CO. FOR STEEL PIPES AND FITTINGS EXPANSION AND REPAIR WORK No. 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, 132, 133, 134, 135, 136, 137, 138, 139, 140, 141, 142, 143, 144, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160, 161, 162, 163, 164, 165, 166, 167, 168, 169, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 190, 191, 192, 193, 194, 195, 196, 197, 198, 199, 200, 201, 202, 203, 204, 205, 206, 207, 208, 209, 210, 211, 212, 213, 214, 215, 216, 217, 218, 219, 220, 221, 222, 223, 224, 225, 226, 227, 228, 229, 230, 231, 232, 233, 234, 235, 236, 237, 238, 239, 240, 241, 242, 243, 244, 245, 246, 247, 248, 249, 250, 251, 252, 253, 254, 255, 256, 257, 258, 259, 260, 261, 262, 263, 264, 265, 266, 267, 268, 269, 270, 271, 272, 273, 274, 275, 276, 277, 278, 279, 280, 281, 282, 283, 284, 285, 286, 287, 288, 289, 290, 291, 292, 293, 294, 295, 296, 297, 298, 299, 300, 301, 302, 303, 304, 305, 306, 307, 308, 309, 310, 311, 312, 313, 314, 315, 316, 317, 318, 319, 320, 321, 322, 323, 324, 325, 326, 327, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 341, 342, 343, 344, 345, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360, 361, 362, 363, 364, 365, 366, 367, 368, 369, 370, 371, 372, 373, 374, 375, 376, 377, 378, 379, 380, 381, 382, 383, 384, 385, 386, 387, 388, 389, 390, 391, 392, 393, 394, 395, 396, 397, 398, 399, 400, 401, 402, 403, 404, 405, 406, 407, 408, 409, 410, 411, 412, 413, 414, 415, 416, 417, 418, 419, 420, 421, 422, 423, 424, 425, 426, 427, 428, 429, 430, 431, 432, 433, 434, 435, 436, 437, 438, 439, 440, 441, 442, 443, 444, 445, 446, 447, 448, 449, 450, 451, 452, 453, 454, 455, 456, 457, 458, 459, 460, 461, 462, 463, 464, 465, 466, 467, 468, 469, 470, 471, 472, 473, 474, 475, 476, 477, 478, 479, 480, 481, 482, 483, 484, 485, 486, 487, 488, 489, 490, 491, 492, 493, 494, 495, 496, 497, 498, 499, 500, 501, 502, 503, 504, 505, 506, 507, 508, 509, 510, 511, 512, 513, 514, 515, 516, 517, 518, 519, 520, 521, 522, 523, 524, 525, 526, 527, 528, 529, 530, 531, 532, 533, 534, 535, 536, 537, 538, 539, 540, 541, 542, 543, 544, 545, 546, 547, 548, 549, 550, 551, 552, 553, 554, 555, 556, 557, 558, 559, 560, 561, 562, 563, 564, 565, 566, 567, 568, 569, 570, 571, 572, 573, 574, 575, 576, 577, 578, 579, 580, 581, 582, 583, 584, 585, 586, 587, 588, 589, 590, 591, 592, 593, 594, 595, 596, 597, 598, 599, 600, 601, 602, 603, 604, 605, 606, 607, 608, 609, 610, 611, 612, 613, 614, 615, 616, 617, 618, 619, 620, 621, 622, 623, 624, 625, 626, 627, 628, 629, 630, 631, 632, 633, 634, 635, 636, 637, 638, 639, 640, 641, 642, 643, 644, 645, 646, 647, 648, 649, 650, 651, 652, 653, 654, 655, 656, 657, 658, 659, 660, 661, 662, 663, 664, 665, 666, 667, 668, 669, 670, 671, 672, 673, 674, 675, 676, 677, 678, 679, 680, 681, 682, 683, 684, 685, 686, 687, 688, 689, 690, 691, 692, 693, 694, 695, 696, 697, 698, 699, 700, 701, 702, 703, 704, 705, 706, 707, 708, 709, 710, 711, 712, 713, 714, 715, 716, 717, 718, 719, 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000

ITEM No.	1-07	1-08	2-05	2-06	MX-07	MX-08	MZ-04	PU-12A/B	PU-17
SERVICE	Coagulation/Flocculation tank	No. 3 Sedimentation Tank	Sludge Pli	Treated Water Pli	Coagulation Mixer	Flocculation Mixer	No. 3 Sludge Rake	Sludge Feed Pump	T.W. Reuse Pump
SIZE (m)	1.4m x 2.8m x 6.1m	8.8m Dia x 5.5m	2.0m W x 3.0m L x 3.0m D	3.0m W x 3.2m L x 2.5m D	2.7m W x 1.5m L	2.2m W x 1.5m L	1.5m W x 3.1m L	7m ² x 1.5m x 2.2m	60m ² x 1.5m x 2.2m
DESIGN PRESS (bars)	Full Water	Full Water	Full Water	Full Water	None	None	None	1.0	1.0
DESIGN TEMP (°C)	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.	Amb.
MATERIAL/TYPE	CS+Epoxy/Refractor	CS+Epoxy/Refractor	RC/Open	RC/Open	SUS/Vertical	SUS/Vertical	CS+Epoxy/Center Dinet	SCS/Cmf/Vertil.	SCS/Cmf/Horiz.

Z-07
 D-09
 I-09
 D-10
 MZ-06
 MX-10
 MZ-07



ITEM No.	DESCRIPTION	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	SERVICE	MATERIAL/TYP	ITEM No.	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	SERVICE	MATERIAL/TYP
PU-13	Settling Aid Pump	0.11/m ²	0.54/0.14W	1.0	Ful Water	CS/Verti.	PU-13	0.11/m ²	0.54/0.14W	1.0	Ful Water	CS/Verti.
PU-14A/B	Centrifuge Feed Pump	1.0	1.0	Amb.	Ful Water	CS/Horizontal	PU-14A/B	1.0	1.0	Amb.	Ful Water	CS/Horizontal
PU-15A/B	Filter Aid Pump	1.0	1.0	Amb.	Ful Water	CS/Vertical	PU-15A/B	1.0	1.0	Amb.	Ful Water	CS/Vertical
PU-16A/B	W.W. Return Pump	5.0m ² /hr	0.75kW	1.0	Ful Water	SCS/Horizontal	PU-16A/B	5.0m ² /hr	0.75kW	1.0	Ful Water	SCS/Horizontal
PU-17A/B	Wastewater PH	3.0m ²	0.14/0.35m ²	Amb.	Ful Water	RC/Open Basin	PU-17A/B	3.0m ²	0.14/0.35m ²	Amb.	Ful Water	RC/Open Basin
PU-18A/B	W.W. Return Pump	5.0m ² /hr	0.75kW	1.0	Ful Water	SCS/Horizontal	PU-18A/B	5.0m ² /hr	0.75kW	1.0	Ful Water	SCS/Horizontal
PU-19A/B	Filter Aid Pump	1.0	1.0	Amb.	Ful Water	CS/Vertical	PU-19A/B	1.0	1.0	Amb.	Ful Water	CS/Vertical
W1	Sludge Cake	SP-BD 16-04										
AP	Sludge Cake	SP-BD 16-06										
AJ	Sludge Cake	SP-BD 16-08										

JICA	Doc. No.	Rev.	Appr.	Rev.	Appr.	Date

CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY
 INDUSTRIAL DEVELOPMENT STUDY DIVISION
 CONSULTANT: CHYODA DAMES & MOORE CO.
 CHYODA CORPORATION
 PROJECT: THE STUDY ON INDUSTRIAL WASTE WATER
 POLLUTION CONTROL IN
 THE ARAB REPUBLIC OF EGYPT
 TITLE: FDM D. M&S CO. FOR STEEL PIPES AND FITTINGS
 No. 1 & 2 W.W. RECYCLING PLANT (1/1)

ITEM No.	DESCRIPTION	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	SERVICE	MATERIAL/TYP
W1	Sludge Cake	SP-BD 16-04				
AP	Sludge Cake	SP-BD 16-06				
AJ	Sludge Cake	SP-BD 16-08				

ITEM No.	DESCRIPTION	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	SERVICE	MATERIAL/TYP
W1	Sludge Cake	SP-BD 16-04				
AP	Sludge Cake	SP-BD 16-06				
AJ	Sludge Cake	SP-BD 16-08				

ITEM No.	DESCRIPTION	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	SERVICE	MATERIAL/TYP
W1	Sludge Cake	SP-BD 16-04				
AP	Sludge Cake	SP-BD 16-06				
AJ	Sludge Cake	SP-BD 16-08				


ITEM No.	DESCRIPTION	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	SERVICE	MATERIAL/TYP
W1	Sludge Cake	SP-BD 16-04				
AP	Sludge Cake	SP-BD 16-06				
AJ	Sludge Cake	SP-BD 16-08				

ITEM No.	DESCRIPTION	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	SERVICE	MATERIAL/TYP
W1	Sludge Cake	SP-BD 16-04				
AP	Sludge Cake	SP-BD 16-06				
AJ	Sludge Cake	SP-BD 16-08				

ITEM No.	DESCRIPTION	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	SERVICE	MATERIAL/TYP
W1	Sludge Cake	SP-BD 16-04				
AP	Sludge Cake	SP-BD 16-06				
AJ	Sludge Cake	SP-BD 16-08				

C-01


B-01A/B



ITEM No.	B-01A/B	C-01
SERVICE	AP Blower	AI Compressor
SIZE (m)	8.5mm ³ /min@1.5kW	D.3m ³ /min@D.7HP@1.5kW
DESIGN PRESS (kg/cm ²)	1	1
DESIGN TEMP. (C)	200	200
MATERIAL TYPE	C/Fluor	C/Fluor

ACD. Sign	Check	Task	Appr	Rev	Description	Design	Check	Appr	Date
REVISION									
CLIENT JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION									
CONSULTANT CHIFUDA DANIES & MOORE CO. CHIFUDA CORPORATION									
PROJECT THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT									
TITLE FOR EL NASR CO. FOR STEEL PIPES AND FITTINGS FACILITATING FLOW DIAGRAM FOR H.A.1 W.W.T. RECYCLABLE PLANT(B/S)									
ISSUED DATE									
DWG NO.	SP-80-11-08								
SCALE									
REV.	0								

MK-201A/B




ITEM No.	D-201X/B	MK-201X/B	PU-202A/B	Z-201	PU-201A/B
SERVICE	No.2 Coagulant Drum	No.2 Coagulant Mixer	No.2 Coagulant Pump	No.4 Wastewater Pit	No.4 Wastewater Pump
SIZE(m)	1.2mDx1.5mH	0.75mW L=1.2m	0.5m/minD SUPHEAD:1W	1.5mWx3.0mLx3.5mD	60m ³ /hr17mHx0.5W
DESIGN PRESSURE	Full Water	none	Amb.	Full Water	1
DESIGN TEMP.(C)	Amb.	Amb.	Amb.	Amb.	Amb.
MATERIAL/TYPE	CS-410L/Verf.	SUS Verti.	SCS/Pumpster	RC/Open Basin	SCS/Centri.Vert.

ACR.	Check	Appr.	Rev.	Description	Begin	Check	Appr.	Date	
CLIENT JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION									
CONSULTANT CHYODA DAMES & MOORE CO. CHYODA CORPORATION									
PROJECT THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL OF THE PAROS REFINERY OF THE PAROS REPUBLIC OF GREECE									
TITLE FOR EL. M.S.R. CO. FOR STEEL PIPES AND FITTINGS ENGINEERING FLOW DIAGRAM FOR No.2 W.W.T. RECLAIMABLE PLANT(1/2)									
ISSUED DATE								SCALE	Sheet
DWG NO								REV.	0

F-201A/B/C

Z-202



ITEM NO	DESCRIPTION	SIZE (mm)	DESIGN PRESSURE	DESIGN TEMP (°C)	MATERIAL/TYPE	7-202	B-201	Z-201	PU-204A/B	PU-203A/B	PU-205
	Filtered Water Pk	3.0mWd x 3.0mH	Full Water	Amb.	RC/Obstr				Backwash W.W. Filter Pump	Backwashing Pump	Recovered Water Pump
	Sand Filter	2.1mWd x 4.5mH	Full Water	Amb.	C/Floor				Backwash W.W. Filter Pump	Backwashing Pump	Recovered Water Pump
	Full Water					200	3.0mWd x 3.0mH	Full Water	5.0m ³ /hr @ 0.1m/s	1.55m ³ /hr @ 0.1m/s	80m ³ /hr @ 0.1m/s
	CS+Epoxy/Convtl										

REV	DATE	BY	CHKD	APPD	TRN	ACD

CLIENT	CONSULTANT	PROJECT	TITLE	ISSUED DATE	DWG NO	SCALE	REV
JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION	CHYODA DAMES & MOORE CO. CHYODA CORPORATION	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT	FOR EL HUSR CO. FOR STEEL PIPES AND FITTINGS IN EL HUSR CO. FOR STEEL PIPES AND FITTINGS NO. 3 (W.W.T. RECYCLING PLANT) (P. 1/1)		SP-80-11-10		0



NOTE:

- 1) Type: Cylindrical Tank (Open Top Tank)
- 2) Materials: Carbon Steel inside Epoxy Coating
- 3) Accessories: Stairway Inside Ladder Air Bubbling

Tube

Loading Data

Weight Empty: 14.5ton
Full Water 450ton



N-7	Manhole	500A	1
N-6	Level Instrument	6B	1
N-5	Over Flow	8B	1
N-4	Drain	4B	1
N-3	Bubbling Air Inlet	2B	1
N-2	Raw Water Outlet	6B	2
N-1	Raw Water inlet	6B	1
No	Name	Size	No
Note			



CLIENT JAPAN INTERNATIONAL COOPERATION AGENCY

FOR: EL NASR Co. for STEEL PIPES & FITTINGS
450 m³ EQUALIZATION TANK (T-5)
WASTEWATER TREATMENT PLANT

DWG. NO SP - BD - 22 - SK01 REV.0

NOTE:


Material: Reinforced Concrete
 Accessories: Skimming Pipe
 Hand rail, Inside Ladder
 Option: Flight Scraper (Surface, Bottom)



N-3	Level Instrument	6B	1	
N-2	Skimmed Oily	6B	1	
N-1	Raw Water inlet	6B	1	
Nozzle No	Name	Size	No	Note
CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY				
FOR: EL NASR STEEL PIPES & FITTINGS				
TYTLE: OIL SEPARATOR (Z-01/03/04)				
WASTEWATER TREATMENT PLANT				
DWG. NO	SP - BD - 51 - SK01	REV.0		



Materials: Carbon Steel/Epoxy coating
 Accessories: Sludge Collection Rake
 Operating Stage
 Stairway

- T-02: No.1 Sedimentation Tank
 D=5,811 H=3,000
- T-06: No.2 Sedimentation Tank
 D=9,688 H=4,000
- T-08: No.3 Sedimentation Tank
 D=5,811 H=3,000



N-3	Sludge Outlet	6B	1	
N-2	Treated Water Outlet	6B	1	
N-1	Raw Water inlet	6B	1	
Nozzle No	Name	Size	No	Note
CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY				
TYTLE: FOR: EL NASR STEEL PIPES & FITTINGS OIL SEPARATOR (2-01) WASTEWATER TREATMENT PLANT				
DWG. NO	SP - BD - 22 - SK02	REV.0		


Materials: Reinforced Concrete
 Accessories: Operating Stage
 Stairway
 Air Distributing pipings



N-3	Air Inlet	3B	1
N-2	T. Water Outlet	6B	1
N-1	Inlet	6B	1
Nozzle No	Name	Size	No
CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY			
FOR: EL NASR CO. FOR STEEL PIPES & FITTINGS			
TYTLE: AERATION BASIN (2-04)			
WASTEWATER TREATMENT PLANT			
DWG. NO	SP - BD - 51 - SK02 REV.0		

Materials: Carbon Steel/Epoxy coating
 Accessories: Sludge Collection Rake
 Operating Stage
 Stairway

- T-02: No.1 Sedimentation Tank
 D=5,811 H=3,000
 T-06: No.2 Sedimentation Tank
 D=9,688 H=4,000
 T-08: No.3 Sedimentation Tank
 D=5,811 H=3,000




N-3	Sludge Outlet	6B	1	
N-2	Treated Water Outlet	6B	1	
N-1	Raw Water Inlet	6B	1	
Nozzle No	Name	Size	No	Note
CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY				
FOR: EL NASR CO. FOR STEEL PIPES & FITTINGS				
TYTLE: SEDIMENTATION TANK (T-02/06/08)				
WASTEWATER TREATMENT PLANT				
DWG. NO	SP - BD - 22 - SK02			REV.0

Material: Carbon steel/Epoxy Coating


Filter Media: Anthracite + Sand/Gravel

Accessories: Operating Stage
Ladder



No	Name	Size	No	Note
N-8	Handhole	200A	1	
N-7	Manhole	500A	1	
N-6	Over Flow	6B	1	
N-5	Air Inlet	4B	1	
N-4	B.Water Outlet	8B	1	
N-3	B. Water Inlet	8B	1	
N-2	F.Water Outlet	4B	1	
N-1	C.Water Inlet	4B	1	



CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY			
TYTLE	FOR: EL NASR CO. FOR STEEL PIPES & FITTINGS SAND FILTER (F-01A/B/C) WASTEWATER TREATMENT PLANT			
DWG. NO	SP - BD - 22 - SK03 REV.0			



Rev	Chk	Appr	Date	Rev	Chk	Appr	Date

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY
CONSULTANT	CHIYODA DAMES & MOORE CO. CHIYODA CORPORATION
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT
TITLE	FOR Nominated Factory W.W.T Control Room
ISSUED DWG	00-BD-56-01
SCALE	REV
NO. 0	0

FROM EXISTING
 30" DIA. MAIN
 30" DIA. MAIN




SEE SHE. NO. PF-CD-60-201

33	NO. 1 INFILTRATION MOTOR	NO. 1	NO. 1 INFILTRATION MOTOR
32	NO. 2 INFILTRATION MOTOR	NO. 2	NO. 2 INFILTRATION MOTOR
31	NO. 3 INFILTRATION MOTOR	NO. 3	NO. 3 INFILTRATION MOTOR
30	NO. 1 LINE MOTOR	NO. 1	NO. 1 LINE MOTOR
29	NO. 2 LINE MOTOR	NO. 2	NO. 2 LINE MOTOR
28	NO. 3 LINE MOTOR	NO. 3	NO. 3 LINE MOTOR
27	NO. 1 CONDENSATE MOTOR	NO. 1	NO. 1 CONDENSATE MOTOR
26	NO. 2 CONDENSATE MOTOR	NO. 2	NO. 2 CONDENSATE MOTOR
25	NO. 3 CONDENSATE MOTOR	NO. 3	NO. 3 CONDENSATE MOTOR
24	NO. 1 WETLAND AB MOTOR	NO. 1	NO. 1 WETLAND AB MOTOR
23	CONDENSATE MOTOR	NO. 1	CONDENSATE MOTOR
22	CONDENSATE AB MOTOR	NO. 1	CONDENSATE AB MOTOR
21	CONDENSATE MOTOR	NO. 1	CONDENSATE MOTOR
20	NO. 3 LINE MOTOR	NO. 3	NO. 3 LINE MOTOR
19	NO. 2 LINE MOTOR	NO. 2	NO. 2 LINE MOTOR
18	NO. 1 LINE MOTOR	NO. 1	NO. 1 LINE MOTOR
17	NO. 1 INFILTRATION PUMP	NO. 1	NO. 1 INFILTRATION PUMP
16	NO. 2 INFILTRATION PUMP	NO. 2	NO. 2 INFILTRATION PUMP
15	NO. 3 INFILTRATION PUMP	NO. 3	NO. 3 INFILTRATION PUMP
14	CONDENSATE FEED PUMP	NO. 1	CONDENSATE FEED PUMP
13	CONDENSATE FEED PUMP	NO. 1	CONDENSATE FEED PUMP
12	CONDENSATE AB PUMP	NO. 1	CONDENSATE AB PUMP
11	CONDENSATE PUMP	NO. 1	CONDENSATE PUMP
10	NO. 3 LINE PUMP	NO. 3	NO. 3 LINE PUMP
9	NO. 2 LINE PUMP	NO. 2	NO. 2 LINE PUMP
8	NO. 1 LINE PUMP	NO. 1	NO. 1 LINE PUMP
7	SLUDGE COLLECTOR PUMP	NO. 1	SLUDGE COLLECTOR PUMP
6	INFILTRATION PUMP	NO. 1	INFILTRATION PUMP
5	INFILTRATION PUMP	NO. 1	INFILTRATION PUMP
4	RECYCLED OIL PUMP	NO. 1	RECYCLED OIL PUMP
3	OIL SEPARATOR L.R. PUMP	NO. 1	OIL SEPARATOR L.R. PUMP
2	REFRAINER W.P. PUMP	NO. 1	REFRAINER W.P. PUMP
1	NO. 1 SLUDGE PUMP	NO. 1	NO. 1 SLUDGE PUMP
	NO. 2 SLUDGE PUMP	NO. 2	NO. 2 SLUDGE PUMP
	NO. 3 SLUDGE PUMP	NO. 3	NO. 3 SLUDGE PUMP
	NO. 1 LINE PUMP	NO. 1	NO. 1 LINE PUMP

REV	DATE	BY	CHK

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY
CONSULTANT	CHITRA DINESH AND MOORE CO.
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER TREATMENT PLANT FOR THE CITY OF CHITRA DINESH
DRAWN	
CHECKED	
DATE	
SCALE	
SHEET NO.	PF-CD-60-001
TOTAL SHEETS	




SEE SHEET NO. PF-CO-60-001
 14 18 JANU 1972



CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY
CONSULTANT	CHITEDA JAMES AND HORSE CO. CHITEDA CORP.
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN BE ARAB REPUBLIC OF EGYPT
DATE	0 1968 FOR STEEL PIPES & FITTINGS 0 1968 FOR SINGLE LINE DIAGRAM 0 1968 FOR MOTOR CONTROL BOARD (1/2)
DESIGNER	PF-CO-60-002
SCALE	1/4" = 1'-0"
SHEET NO.	1
TOTAL SHEETS	1

DESIGNED BY	CHKD BY	APP'D BY
DATE	DATE	DATE
SCALE	SCALE	SCALE
SHEET NO.	SHEET NO.	SHEET NO.
TOTAL SHEETS	TOTAL SHEETS	TOTAL SHEETS

FROM EXISTING
MOTOR ROOM
24-11-2001




JCS	Chk	Des	App
Shp			
Del.			
Comm.	Drp	Chk	App
Shp			
Del.			

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY
CONSULTANT	CHITRA DAIKES AND HORSE CO. CHITRA CORP.
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE JARAI REPUBLIC OF CAMBODIA
TITLE	FOR 0.4 MGD CAP. FOR STEEL PIPES & FITTINGS SINGLE LINE DIAGRAM 380V MOTOR CONTROL BOARD
DESIGN UNIT	PF-CO-60-003
DATE	REV.
	SCALE
	NO. 6

CONFIGURATION OF ELECTRICAL & INSTRUMENTATION SYSTEM FOR DEMONSTRATION PLANT

- *1: PLANT EARTH
- *2: SHIELD EARTH
- *3: LIGHTNING



*3

EQUIPMENT LIST for El Nasr Co. for Steel Pipes & Fittings

Doc. No. SP-BD-L-01-(1/6)

CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Ind. W. W. Pollution Control
 PLANT : W. W. T. Recommendation Plant
 WASTE W. : Industrial Wastewater/Sanitary W.

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req' d	Type of Equipment	Remarks
T-01	Neutralization Tank	1	Rectangular 2.6mWx5.2mLx3.0mH	Carbon Steel/Resin Lining
T-02	No.1 Sedimentation Tank	1	Circular 5.8mIDx3.0mH	Carbon Steel/Resin Lining
T-03	Neutralized W. W. Tank	1	Rectangular 2.5mWx3.2mLx3.0mH	Carbon Steel/Resin Lining
T-04	Skimmed Oil Tank	1	Cone Roof Tank 3.4mIDx6.1mH	Carbon Steel
T-05	Equalization Tank	1	Open Top Tank 8.71mIDx7.6mH	Carbon Steel/Epoxy Coating
T-06	No.2 Sedimentation Tank	1	Circular 9.67mIDx4.0mH	Carbon Steel/Epoxy Coating
T-07	Coagulation/Flocculation Tank	1	Rectangular 1.4mWx2.8mLx6.1mH	Carbon Steel/Epoxy Coating
T-08	No.3 Sedimentation Tank	1	Circular 5.8mIDx4.5mH	Carbon Steel/Epoxy Coating
T-09	Sludge Thickener	1	Circular 3.2mIDx3.0mH	Carbon Steel/Epoxy Coating
D-01	Lime Hopper	1	Cylindrical, Vrtical 1.3mIDx1.5mH	Carbon Steel
D-02	No.1 Lime Drum	1	Cylindrical, Vertical 1.5mIDx1.5mH	Carbon Steel
D-03	Lime Receiver	1	Cylindrical, Horizontal 1.4mIDx1.5mH	Carbon Steel
D-04A/B	Nutrient (N) Drum	2	Cylindrical, Vertical 0.7mIDx1.5mH	Carbon Steel
D-05A/B	Nutrient (P) Drum	2	Cylindrical, Vertical 0.7mIDx1.5mH	C. S + H. R. Lining
D-06A/B	No.2 Lime Drum	2	Cylindrical, Vertical 1.4mIDx1.8mH	Carbon Steel
D-07A/B	No.1 Coagulant Drum	2	Cylindrical, Vertical 1.2mIDx1.8mH	C. S. +H. R. Lining

NOTE:

EQUIPMENT LIST for El Nasr Co. for Steel Pipes & Fittings

Doc. No. SP-BD-L-01-(2/6)
 CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Ind. W. W. Pollution Control
 PLANT : W. W. T. Recommendation Plant
 WASTE W. : Industrial Wastewater/Sanitary W.

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
D-08A/B	Coagulant Aid Drum	2	Cylindrical, Vertical 1.2mIDx1.5mH	Carbon Steel
D-09	Settling Aid Drum	1	Cylindrical, Vertical 0.7mIDx1.0mH	Carbon Steel
D-10	Filtered Aid Drum	1	Cylindrical, Vertical 1.2mIDx1.5mH	Carbon Steel
D-201A/B	NO. 2 Coagulant Drum	2	Cylindrical, Vertical 1.2mIDx1.5mH	C. S. +H. R. Lining
Z-101	No. 1 Wastewater Pit	1	Open Basin/Underground 4.0mWx5.0mLx3.5mH	R. C. (out of Battery)
Z-102	No. 2 Wastewater Pit	1	Open Basin/Underground 3.0mWx5.0mLx3.0mH	R. C. (out of Battery)
Z-103	No. 3 Wastewater Pit	1	Open Basin/Underground 2.0mWx3.0mLx3.5mH	R. C. (out of Battery)
Z-01	Oil Separator	1	API Standard/underground 1.5mWx1.0mDx8.0mL	R. C.
Z-02	Oil Separator T. W. Pit	1	Open Basin/Underground 2.4mWx2.5mLx3.0mD	R. C.
Z-03	Skimmed Oil Pit	1	Closed Basin/Underground 1.5mWx2.0mLx3.0mD	R. C.
Z-04	Aeration Basin	1	Rectangular/Aboveground 5.0mWx15.0mLx3.5mH	R. C. with Air Bubbling
Z-05	Sludge Pit	1	Rectangular/Underground 2.0mWx3.0mLx3.0mD	R. C.
Z-06	Treated Water Pit	1	Rectangular/Aboveground 3.0mWx5.2mLx2.5mH	R. C.
Z-07	Wastewater Pit	1	Rectangular/Underground 3.0mWx6.0mLx3.0mH	R. C.
Z-201	No. 4 Wastewater Pit	1	Open Basin/Underground 1.5mWx3.0mLx3.5mH	R. C.
Z-202	Filtered Water Pit	1	Rectangular/Aboveground 3.0mWx5.0mLx3.0mH	R. C.

NOTE:

EQUIPMENT LIST for El Nasr Co. for Steel Pipes & Fittings

Doc. No. SP-BD-L-01-(3/6)

CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Ind. W. W. Pollution Control
 PLANT : W. W. T. Recommendation Plant
 WASTE W. : Industrial Wasterwater/Sanitary W.

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
Z-203	Backwash W.W. Pit	1	Rectangular/Underground 3.0mWx5.0mLx3.0mH	R. C.
PU-101A/B	No. 1 Wastewater Pump	2	Centri. Vertical , L=3.5m 48m ³ /hx30mHx11kW	SCS Outside of Battery
PU-102A/B	NO. 2 Wastewater Pump	2	Centri. Vertical , L=3m 36m ³ /hx25mHx7.5kW	SCS Outside of Battery
PU-103A/B	NO. 4 Wastewater Pump	2	Centri. Vertical , L=3m 12m ³ /hx25mHx2.2kW	SCS Outside of Battery
PU-01A/B	No. 1 Lime Pump	2	Centri. Horizontal 10L/minx0.5MPax0.75kW	CI
PU-02A/B	No. 1 Sludge Pump	2	Centri. Horizontal 4m ³ /hx30mHx2.2kW	SCS
PU-03A/B	Neutralized W.W. Pump	2	Centri. Horizontal 48m ³ /hx18mHx5.5kW	SCS
PU-04A/B	Oil Separator T.W. Pump	2	Centri. Vertical 36m ³ /hx18mHx5.5kW	SCS
PU-05	Recovered Oil Pump	1	Centri. Vertical 15m ³ /hx15mHx2.2kW	CI
PU-06A/B	Nutrient (N) Pump	2	Recipro. Plunger 0.1L/minx0.5MPax0.4kW	SCS
PU-07A/B	Nutrient (P) Pump	2	Recipro. Plunger 0.1L/minx0.5MPax0.4kW	SCS
PU-08A/B	Sludge Circulation Pump	2	Centri. Horizontal 36m ³ /hx12mHx3.7kW	SCS
PU-09A/B	No. 2 Lime Pump	2	Recipro. Diaphragm 0.6L/minx0.5MPax0.75kW	Teflon/SCS
PU-10A/B	Coagulant Pump	2	Recipro. Plunger 0.3L/minx0.5MPax0.4kW	SCS
PU-11A/B	Coagulant Aid Pump	2	Recipro. Plunger 0.3L/minx0.5MPax0.4kW	SCS
PU-12A/B	Sludge Feed Pump	2	Centri. Vertical 2m ³ /hx15mHx2.2kW	SCS

NOTE:

EQUIPMENT LIST for El Nasr Co. for Steel Pipes & Fittings

Doc. No. SP-BD-L-01-(4/6)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Ind. W. W. Pollution Control

PLANT : W. W. T. Recommendation Plant

WASTE W. : Industrial Wastewater/Sanitary W.

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
PU-13	Settling Aid Pump	1	Recipro. Plunger 0.1L/minx0.5MPax0.4kW	SCS
PU-14A/B	Centrifuge Feed Pump	2	Centri. Horizontal 1.5m ³ /hx15mHx3.7kW	SCS
PU-15A/B	Filter Aid Pump	2	Recipro. Plunger 3L/minx0.5MPax0.75kW	SCS
PU-16A/B	W. W. Return Pump	2	Centri. Vertical 5m ³ /hx15mHx0.75kW	SCS
PU-17	T. W. Reuse Pump	1	Centri. Horizontal 60m ³ /hx30mHx15kW	SCS
PU-18A/B	Equalized Water Pump	2	Centri. Horizontal 80m ³ /hx10mHx5.5kW	SCS
PU-201A/B	No. 4 Wastewater Pump	2	Centri. Vertical, L=3m 60m ³ /hx12mHx5.5kW	CI Coating Factory
PU-202A/B	No. 2 Coagulant Pump	2	Recipro. 0.5L/min. x0.5MPax0.4kW	SCS Coating Factory
PU-203A/B	Backwashing Pump	2	Centri. Horizontal 155m ³ /hx12mHx11kW	CI Coating Factory
PU-204A/B	Backwash W. W. Feed Pump	2	Centri. Horizontal 5m ³ /hx40mHx1.5kW	CI Coating Factory
PU-205	Recovered Water Pump	1	Centri. Horizontal, L=3m 60m ³ /hx30mHx11kW	CI Coating Factory
B-01A/B	AP Blower	2	Root 9.5Nm ³ /minx7mHx15kW	CI
B-201	Backwashing Blower	2	Root 3.0Nm ³ /minx5mHx5.5kW	CI
C-01	AI Compressor	2	Baby Compressor 0.3m ³ /minx0.7MPax1.5kW	CI, with Air Tank
MZ-101	Belt Oil Skimmer	1	Vertical 0.4kWx0.7MPax0.75kW	SUS
MZ-01	Lime Feeder	1	Disc 30kg/hx0.75kW	CS

NOTE:

EQUIPMENT LIST for El Nasr Co. for Steel Pipes & Fittings

Doc. No. SP-BD-L-01-(5/6)

CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Ind. W. W. Pollution Control
 PLANT : W. W. T. Recommendation Plant
 WASTE W. : Industrial Wasterwater/Sanitary W.

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
MZ-02	No. 1 Sludge Rake	1	Center Driven 1.5kW	CS+Epoxy Coating
MZ-03	No. 2 Sludge Rake	1	Center Driven 1.5kW	CS+Epoxy Coating
MZ-04	No. 3 Sludge Rake	1	Center Driven 1.5kW	CS+Epoxy Coating
MZ-05	No. 4 Sludge Rake	1	Center Driven 0.75kW	CS+Epoxy Coating
MZ-06	No. 1 Centrifuge	1	Horizontal 3m ³ /hx15kWx3,000rpm	SCS
MZ-07	No. 2 Centrifuge	1	Horizontal 1.5m ³ /hx7.5kWx3,000rpm	SCS
MZ-08	Belt Conveyer	1	Horizontal 20kg/minx0.75kW	CS+Rubber
MX-01	No. 1 Lime Mixer	1	Vertical 1.5kW, L=1.2m	SUS
MX-02A/B	Nutrient (N) Mixer	2	Vertical 0.4kW, L=1.0m	SUS
MX-03A/B	Nutrient (P) Mixer	2	Vertical 0.4kW, L=1.0m	SUS
MX-04A/B	No. 2 Lime Mixer	2	Vertical 1.5kW, L=1.2m	SUS
MX-05A/B	No. 1 Coagulant Mixer	2	Vertical 0.75kW, L=1.2m	SUS
MX-06A/B	Coagulant Aid Mixer	2	Vertical 0.75kW, L=1.0m	SUS
MX-07	Coagulation Mixer	1	Vertical 2.2kW, L=1.5m	SUS
MX-08	Flocculation Mixer	1	Vertical 2.2kW, L=1.5m	SUS
MX-09	Settling Aid Mixer	1	Vertical 0.75kW, L=0.8m	SUS

NOTE:

INSTRUMENT LIST for EL. NASR Co. for STEEL PIPES and FITTINGS

Doc. No. SP-BD-L2-(1/4)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial W. W. Pollution Control

PLANT : W. W. T. DEMONSTRATION PLANT

WASTE W. : Process Water & Sanitary/Domestic Water

REV	1	2	3	MADE	
BY				CHKD	
APVE				APVE	
DATE				DATE	

Instrument NO.	Service	No. Req'd	Type of Instrument	Remarks
AR-01	pH Analyzer	1	Electrode, inline	Inlet of T-01
			pH 1-10	C. P.
AR-02	pH Analyzer	1	Electrode	Surface T-01
			pH 1-10	C. P.
AR-03	pH Analyzer	1	Electrode	Outlet T-02
			pH 1-10	C. P.
AR-04	DO Analyzer	1	Electrode	Z-04
			0-15mg/L as O ₂	C. P.
AR-05	pH Analyzer	1	Electrode	Outlet T-07
			pH 4-9	C. P.
FR-01	Flow Recorder	1	Orifice, 4B	Outlet of PU-04
			0-60m ³ /h, WW	C. P.
FR-02	Flow Recorder	1	Orifice, 3B	Outlet of PU-05
			0-45m ³ /h, WW	C. P.
FR-03	Flow Recorder	1	Orifice, 1-1/2B	Outlet of PU-204
			0-5m ³ /h, WW	C. P.
FIC-04	Flow Controller	1	Electro-magnetic, 6B	Outlet of PU-08
			0-60m ³ /h, WS	C. P.
FIC-05	Flow Controller	1	Orifice, 3B	Inlet of Z-04
			0-10Nm ³ /min, AP	C. P.
FRC-06	Flow Recorder/Controller	1	Orifice, 6B	Inlet of T-07
			0-90m ³ /h, WW	C. P.
FRC-07	Flow Recorder/Controller	1	Electro-magnetic, 2B	Outlet of PU-12
			0-5m ³ /h, WS	C. P.
FRS-08	Flow Integrated Indicator	1	Orifice, 6B	Outlet of PU-17
			0-90m ³ /h, WW	C. P.
			0-1,000,000m ³ /c	

NOTE: C. P. = Center Panel Mount

INSTRUMENT LIST for EL. NASR Co. for STEEL PIPES and FITTINGS

Doc. No. SP-BD-L2-(2/4)
 CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Industrial W. W. Pollution Control
 PLANT : W.W.T. DEMONSTRATION PLANT
 WASTE W. : Process Water & Sanitary/Domestic Water

REV	1	2	3	MADE	
BY				CHKD	
APVE				APVE	
DATE				DATE	

Instrument NO.	Service	No. Req'd	Type of Instrument	Remarks
FI-09	Flow Indicator	1	Orifice, 4B	Inlet of MZ-061
			5m ³ /h, WS	Center Panel Mount
FI-10	Flow Indicator	1	Electro-magnetic, 2B	Inlet of MZ-07
			5m ³ /h, WS	C.P.
FIC-51	Flow Controller	1	Orifice, 1B	Inlet of D-02
			3m ³ /h, WI	
FRC-52	Flow Controller	1	Electro-magnetic, 2B	Inlet of T-01
			1m ³ /h, 10% Lime	
FI-53	Flow Indicator	1	Orifice, 1-1/2B	Inlet of T-01
			5Nm ³ /min, AP	
FI-54	Flow Indicator	1	Orifice, 1-1/2B	Inlet of T-05
			10N/min, AP	
FS-55	Flow Integrator	1	Rotor Type for WD supply	Intake of WD
			2B,	
FI-56	Flow Indicator	1	Orifice, 4B	Outlet of B-01
			10N/min, AP	
FI-151	Flow Indicator	1	Orifice, 4B	Outlet of PU-101
			60m ³ /h, WW	
FI-152	Flow Indicator	1	Orifice, 3B	Outlet of PU-102
			45m ³ /h, WW	
FI-201	Flow Indicator	1	Orifice, 4B	Outlet of PU-201
			90m ³ /h, WW	L.P.
FIS-202	Flow Integrator	1	Orifice, WW	Outlet of PU-205
			90m ³ /h, WW	L.P.
FI-251A-C	Flow Inficator	3	Orifice, WW	Inlet of F-201ABC
			50m ³ /h, 3B	
FI-252	Flow Indicator	1	Orifice, WW	Outlet of PU-203
			180m ³ /h, 8B	
FI-253	Flow Indicator	1	Orifice, WW	Outlet of PU-204
			5m ³ /h, WS	

NOTE: C.P. =Center Panel Mount
 L.P. =Local Panel Mount

INSTRUMENT LIST for EL. NASR Co. for STEEL PIPES and FITTINGS

Doc. No. SP-BD-L2-(3/4)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial W. W. Pollution Control

PLANT : W. W. T. DEMONSTRATION PLANT

WASTE W. : Process Water & Sanitary/Domestic Water

REV	1	2	3	MADE	
BY				CHKD	
APVE				APVE	
DATE				DATE	

Instrument NO.	Service	No. Req' d	Type of Instrument	Remarks
LA-01	Level Alarm	1	Float	T-03
			H-L	C. P.
LA-02	Level Alarm	1	Float	Z-02
			H-L	C. P.
LIA-03	Level Indicator/Alarm	1	Displacer	T-04
			H-Alarm	C. P.
LIA-04	Level Indicator/Alarm	1	Displacer	T-05
			H-Alarm	C. P.
LIA-05	Level Indicator/Alarm	1	Displacer	Z-05
			H-L Alarm	C. P.
LICA-201	Level Controller/Alarm	1	Float	Z-201
			H-L Alarm	L. P.
LA-202	Level Alarm	1	Float	Z-202
			L-Alarm	L. P.
LA-203ABC	Level Alarm	3	Electrode	F-201ABC
			H-Alarm	L. P.
LI-51	Level Indicator	1	Lime Pouder	D-01
LS-52	Level Switch	1	Lime 10% Milk	D-02
LS-53	Level Switch	1	Lime Pouder	D-03
LS-54	Level Switch	1	Float, WW, H-L	T-03
LS-55	Level Switch	1	Float, WW, H-L	Z-02
LS-56	Level Switch	1	Float, WW, H-L	Z-03
LS-57	Level Switch	1	Float, WW, H-L	Z-05
LS-58	Level Switch	1	Float, WW, H-L	Z-06
LS-59	Level Switch	1	Float, WW, H-L	Z-07
LS-151	Level Switch	1	Float, WW, H-L	Z-101
LS-152	Level Switch	1	Float, WW, H-L	Z-102
LS-251	Level Switch	1	Float, WW, H-L	Z-203

NOTE: C. P. =Center Panel Mount
L. P. =Local Panel Mount

INSTRUMENT LIST for EL. NASR Co. for STEEL PIPES and FITTINGS

Doc. No. SP-BD-L2-(4/4)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial W. W. Pollution Control

PLANT : W. W. T. DEMONSTRATION PLANT

WASTE W. : Process Water & Sanitary/Domestic Water

REV	1	2	3	MADE	
BY				CHKD	
APVE				APVE	
DATE				DATE	

Instrument NO.	Service	No. Req'd	Type of Instrument	Remarks
LG-51	Level Gage	1	Tubular, L=1.5m	D-03
LG-52AB	Level Gage	2	Tubular, L=1.5m	D-04AB
LG-53AB	Level Gage	2	Tubular, L=1.5m	D-05AB
LG-54AB	Level Gage	2	Tubular, L=1.8m	D-06AB
LG-55AB	Level Gage	2	Tubular, L=1.8m	D-07AB
LG-56AB	Level Gage	2	Tubular, L=1.8m	D-08AB
LG-57	Level Gage	1	Tubular, L=1.0m	D-09
LG-58	Level Gage	1	Tubular, L=1.5m	D-10
LG-251AB	Level Gage	2	Tubular, L=1.5m	D-201AB
TQA-1	Torque Alarm	1	Limit Switch, kg-m	T-02
TQA-2	Torque Alarm	1	Limit Switch, kg-m	T-06
TQA-3	Torque Alarm	1	Limit Switch, kg-m	T-08
TQA-4	Torque Alarm	1	Limit Switch, kg-m	T-09
TQA-5	Torque Alarm	1	Limit Switch, kg-m	MZ-06
TQA-6	Torque Alarm	1	Limit Switch, kg-m	MZ-07
PI	For Lime milk and Sludge Pumps		Diaphragm Type	
PI	Others		Buldon Tube Type	

NOTE: C.P. =Center Panel Mount
L.P. =Local Panel Mount

INDUCTION MOTOR LIST

DOC. NO.	: SP-IBD-60-L1-(1/3)
CLIENT	: Japan International Cooperation Agency
PROJECT	: The Study on Industrial Waste Water Plant
PLANT	: El Nasr Co. for Steel Pipes & Fittings
WASTE W.	: Industrial W.W./Sanitary-Domestic W.W.

Motor No.	Service	No. Required	Type	Output		Speed Chrst	Revolu tion r.p.m	V-Φ-Hz	Time Rating	Starting		Insula tion	Enclose	Cable	Mounting	Drive	Bearing	Acc.	Location	Color Finish	Remarks
				Estimate	Final					Current	Torque										
PU-01-A/B-M	No.1 Lime Pump	2	SC	0.8	0.8	C	1500	380-3-50	C			TEFC		H	D			OD			
PU-02A/B-M	No.1 Sludge Pump	2	SC	2.2	2.2	C	1500	380-3-50	C			TEFC		H	D			OD			
PU-03A/B-M	Neutralized W.W. Pump	2	SC	5.5	5.5	C	1500	380-3-50	C			TEFC		H	D			OD			
PU-04A/B-M	Oil Separator T.W. Pump	2	SC	5.5	5.5	C	1500	380-3-50	C			TEFC		V	D			OD			
PU-05-M	Recovered Oil Pump	1	SC	1.5	1.5	C	1500	380-3-50	C			TEFC		V	D			OD			
PU-06A/B-M	Nutrient(N) Pump	2	SC	0.4	0.4	C	1500	380-3-50	C			TEFC		H	G			OD			
PU-07A/B-M	Nutrient(P) Pump	2	SC	0.4	0.4	C	1500	380-3-50	C			TEFC		H	G			OD			
PU-08A/B-M	Sludge Circulation Pump	2	SC	3.7	3.7	C	1500	380-3-50	C			TEFC		H	D			OD			
PU-09A/B-M	No.2 Lime Pump	2	SC	0.8	0.8	C	1500	380-3-50	C			TEFC		H	G			OD			
PU-10A/B-M	Coagulant Pump	2	SC	0.4	0.4	C	1500	380-3-50	C			TEFC		H	G			OD			
PU-11A/B-M	Coagulant Aid Pump	2	SC	0.4	0.4	C	1500	380-3-50	C			TEFC		H	G			OD			
PU-12A/B-M	Sludge Feed Pump	2	SC	2.2	2.2	C	1500	380-3-50	C			TEFC		V	D			OD			
PU-13-M	Settling Aid Pump	1	SC	0.4	0.4	C	1500	380-3-50	C			TEFC		H	G			OD			
PU-14A/B-M	Centrifuge Feed Pump	2	SC	3.7	3.7	C	1500	380-3-50	C			TEFC		H	G			OD			
PU-15A/B-M	Filter Aid Pump	2	SC	0.8	0.8	C	1500	380-3-50	C			TEFC		H	G			OD			
PU-16A/B-M	W.W. Return Pump	2	SC	0.8	0.8	C	1500	380-3-50	C			TEFC		V	D			OD			
PU-17-M	T.W. Return Pump	1	SC	1.5	1.5	C	1500	380-3-50	C			TEFC		H	D			OD			
PU-18A/B-M	Equalized Water Pump	2	SC	5.5	5.5	C	1500	380-3-50	C			TEFC		H	D			OD			
B-01A/B-M	AP Blower	2	SC	1.5	1.5	C	1500	380-3-50	C			TEFC		H	B			OD			
C-01-M	AI Compressor	1	SC	1.5	1.5	C	1500	380-3-50	C			TEFC		B	B			ID			
MZ-01-M	Lime Feeder	1	SC	0.8	0.8	C	1500	380-3-50	C			TEFC		H	G			OD			
MZ-02-M	No.1 Sludge Rake	1	SC	1.5	1.5	C	1500	380-3-50	C			TEFC		V	G			OD			
MZ-03-M	No.2 Sludge Rake	1	SC	1.5	1.5	C	1500	380-3-50	C			TEFC		V	G			OD			
MZ-04-M	No.3 Sludge Rake	1	SC	1.5	1.5	C	1500	380-3-50	C			TEFC		V	G			OD			
MZ-05-M	No.4 Sludge Rake	1	SC	0.8	0.8	C	1500	380-3-50	C			TEFC		V	G			OD			
MZ-06-M	No.1 Centrifuge	1	SC	1.5	1.5	C	3000	380-3-50	C			TEFC		H	D			OD			
MZ-07-M	No.2 Centrifuge	1	SC	7.5	7.5	C	3000	380-3-50	C			TEFC		H	D			OD			
MZ-08-M	Belt Conveyor	1	SC	0.8	0.8	C	1500	380-3-50	C			TEFC		H	B			OD			

Notes:

1. Type : SC = Squirrel Cage, W = Wound Rotor.
2. Speed : C = Constant, M = Multi, A = Adjustable, V = Varying.
3. Revolution Direction : Direction when viewed from coupling side.
CW = Clockwise, CCGW = Counter-Clockwise.
4. Voltage : Rated Voltage
5. Time Rating : C = Continuous, ST = Short Time, P = Periodic.

6. Enclosure : TEFC = Totally-Enclosed Fan-Cooled.

DR = Drip-Proof.

7. Cable(or Wire) : T = Top, B = Bottom, S = Side, H = Hub for conduit tube or flexible tube.

8. Mounting : H = Horizontal, V = Vertical

9. Drive : D = Direct, B = Belt, C = Chain, G = Gear.

10. Location : ID = Indoor, OD = Outdoor.

INDUCTION MOTOR LIST

DOC. NO. : SP-110-60-1.1-(2/3)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial Waste Water Plant

PLANT : El Nasr Co. for Steel Pipes & Fittings

WASTE W. : Industrial W.W./Sanitary-Domestic W.W.

REV	1	2	3	DATE
BY				
APVE				
DATE				

Motor No.	Service	No. Required	Type	Output		Speed Chrst	Revolu tion r.p.m	V-φ-Hz	Time Rating	Starting Current	Starting Torque	Insula tion	Enclose	Cable	Mounting	Drive	Bearing	Acc.	Location	Color Finish	Remarks
				Estimate	Final																
MX-01-M	Urea Tank Mixer	1	SC	1.5		C	4 1500	380-3-50	C				TEFC		V	G			OD		
MX-02A/B-M	Nutrient(R) Mixer	2	SC	0.4		C	4 1500	380-3-50	C				TEFC		H	G			OD		
MX-03A/B-M	Nutrient(P) Pump	2	SC	0.4		C	4 1500	380-3-50	C				TEFC		H	G			OD		
MX-04A/B-M	NO.2 Lime Mixer	2	SC	1.5		C	4 1500	380-3-50	C				TEFC		V	G			OD		
MX-05A/B-M	No.1 Coagulant Mixer	2	SC	0.8		C	4 1500	380-3-50	C				TEFC		H	G			OD		
MX-08A/B-M	Coagulant Aid Mixer	2	SC	0.8		C	4 1500	380-3-50	C				TEFC		H	G			OD		
MX-07-M	Coagulation Mixer	1	SC	2.2		C	4 1500	380-3-50	C				TEFC		V	G			OD		
MX-08-M	Flocculation Mixer	1	SC	2.2		C	4 1500	380-3-50	C				TEFC		V	G			OD		
MX-09-M	Settling Aid Mixer	1	SC	0.8		C	4 1500	380-3-50	C				TEFC		H	G			OD		
MX-10-M	Filter Aid Mixer	1	SC	0.8		C	4 1500	380-3-50	C				TEFC		H	G			OD		
PU-101A/B-M	No.1 Wastewater Pump	2	SC	1.1		C	2 3000	380-3-50	C				TEFC		V	D			OD		
PU-102A/B-M	No.2 Wastewater Pump	2	SC	7.5		C	2 3000	380-3-50	C				TEFC		V	D			OD		
PU-103A/B-M	No.3 Wastewater Pump	2	SC	2.2		C	4 3000	380-3-50	C				TEFC		V	D			OD		
MZ-101-M	Belt Oil Skimmer	1	SC	0.4		C	4 1500	380-3-50	C				TEFC		H	G			OD		

Notes:

1. Type : SC = Squirrel Cage, W = Wound Rotor.
2. Speed : C = Constant, M = Multi, A = Adjustable, V = Varying.
3. Revolution Direction : Direction when viewed from coupling side.
CW = Clockwise, CCW = Counter-Clockwise.
4. Voltage : Rated Voltage
5. Time Rating : C = Continuous, ST = Short Time, P = Periodic.

6. Enclosure : TEFC = Totally-Enclosed Fan-Cooled.
DR = Drip-Proof.

7. Cable(or Wire) : T = Top, B = Bottom, S = Side, H = Hub for conduit tube or flexible tube.

8. Mounting : H = Horizontal, V = Vertical


9. Drive : O = Direct, B = Belt, C = Chain, G = Gear.

10. Location : ID = Indoor, OD = Outdoor.

Overall Schedule for Implementation of Demonstration Plant (Preliminary)

Dec. 11, 1998

Phase 1 Study



ESTIMATION COST FOR EL NASR CO. for STEEL PIPES FITTINGS

		Yen Portion [¥1000]	LE Portion [LE]	Total
1	Direct Cost			
	1.1. Equipment & Materials			
	(1)Machinery	98,100		
	(2)Piping Materials	10,500		
	(3)Electrical Equipment & Materials	26,000		
	(4)Instrument & Materials	34,000		
	(5)Mini. Labo. Analyzer & Others	4,700		
	1. 1 Sub-total	173,300	0	
	1.2. Field Work Cost			
	(1) Steel Tank & Drum		967,000	
	(2) Equipment Installation		142,000	
	(3) Piping		842,000	
	(4) Civil Work (Foundation, Pit, Pave)		1,494,000	
	(5) Building, Shelter, Steel Structure		541,000	
	(6) Lining, Coating, Painting		537,000	
	(7) Electrical, Instrumentation		498,000	
	(8) Commissioning/ Test		50,000	
	1. 2 Sub-Toatal	0	5,071,000	
2	Indirect Cost			
	(1) Export Packing, Ocean Transport	18,100		
	(2) Import Duty, Inland Transport*1		1,407,353	
	(3) Temporary Facilities*2		304,260	
	(4) Sub-contractor Expense*3		1,267,750	
	(5) Insurance, Social Tax*4		369,354	
	(6) Supervisor Expense	10,000		
	2. Sub-Total	28,100	3,348,717	
3	(1 + 2) Total	201,400	8,419,717	
	(1 + 2) Total [¥1000]	201,400	286,270	487,670
	[LE]	5,923,529	8,419,717	14,343,246

Note: Above cost includes outside battery except utilities supply.

*1: $\{(1.1\text{Sub-total}) + 2(1)\} \times 25\%$

*2: $(1.2) \times 6\%$

*3: $(1.2) \times 25\%$

*4: $\{(1.1)+(1.2)\} + \{2(1)+2(2)+2(3)+2(4)\} \times 2.7\%$

Unit Cost for Estimation of W.W.T. Demonstration Plant (Reference)

Factory Name: El Nasr Co. for Steel Pipes and Fittings.

Design Case: Basic Design

1. Major Equipment

<u>Equipment Name</u>	<u>Unit Cost [x10³Yen]</u>	<u>Note</u>
(1) Acid water pumps	1,500	Material: SCS
(2) Filter	3,000	3 sets
(3) Sludge Rake	6,000	1 set
(4) Centrifuge	10,000	1 sets
(5) Motor Control Center	16,500	
(7) Center Control Panel	3,000	1 set

2. Field Work

<u>Work Item</u>	<u>unit</u>	<u>unit Cost[LE]</u>	<u>Note</u>
(1) Site Preparation	[m ²]	8	
(2) Civil (Earth Work)	[m ³]	34	
(3) RC Work	[m ³]	1,500	Foundation, Water Basin
(3) Storage Tank	[ton]	3,430	Equalization Tank, Chemical tank Neutralization Tanks
(4) Structural Steel	[ton]	2,000	Pipe rack, Operating Stage
(5) Equipment Installation	[ton]	400	Pumps, Clarifier rakes, Dehydrator
(6) Piping	[ton]	3,970	Except valves
	[in-m]	30	Except valves
(7) Painting	[m ²]	50	
(8) Local Building	[m ²]	2,600	W.W.T Control Room
(9) Electrical	[cable-m]	3	

Running Cost-EL NASR CO. FOR STEEL PIPES & FITTINGS

* Unit cost is not fixed yet

Items	Treating Capacity (m ³ /h)	Feeding Ratio (mg/L)	Consump. (kg/h)	Unit Cost (LE/kg)	Cost-1 (LE/h)	Cost-2 (LE/day)	Cost-3 (LE/year)	Unit Cost (LE/m ³)	Remarks
1 Chemical Cost									
1) Alum =Al ₂ (SO ₄) ₂ ·18H ₂ O(Clarifier)	77	30	2.31	0.3	0.69	17	5,489		
* 2) Lime = Ca(OH) ₂ (Neutralization)	30	1000	30	0.1	3.00	72	23,760		
3) Polymer-A (Clarifier)	77	0.3	0.02	27	0.62	15	4,940		
4) Polymer-A (Thickener)	2.34	100	0.23	27	6.32	152	50,039		
5) Polymer-B (No.1 Centrifuge)	60	1%	0.6	27	16.20	130	42,768		
Polymer-B (No.2 Centrifuge)	75	1%	0.75	28	21.00	168	55,440		
5) CO(NH ₂) ₂	77	110	8.47	0.6	5.08	122	40,249		
* 6) H ₃ PO ₄	77	30	2.31	0.6	1.39	33	10,977		
7) NaOCl	77	4	2.31	0.385	0.89	21	7,044		
Sub-Total	77	—	—	—	55.19	729	240,705	0.717	
2 Filter Media									
* 1) Anthracite (3 Sets)	Loading 10.5 m ³	Loss 20 %/year	Loss/h 2.1	1	2.10	50	16,632	0.027	
* 2) Sand (3 Sets)	4.2 m ³	10 %/year	0.5	0.3	0.15	4	1,188	0.005	
* 3) Activated Carbon (1 Set)	0m ³	14 days	0.0	14.7	0.00	0	0	0	
Sub-Total	—	—	—	—	2.25	54	17,820	0.029	
3 Power Consumption									
			kWh/d 2,120	LE/kWh 0.12	10.60	254.40	83,952	0.138	
4 Industrial Water or Potable Water			m ³ /day 50	m ³ 0.7	1.46	35.00	11,550	0.019	
5 Operator	4 Person*3 Shift+1s		Person/d 16	LE/P/year 10,000	20.20	484.85	160,000	0.262	
6 Maintenance Fee									
(Plant Cost * 3 %/year)					44.56	1069.52	352,940	0.579	
400,000,000*0.03/34=352,940 LE									
Total Operation Cost	—	—	—	—	134.27	2,627.17	866,967	1.74	

Power Consumption

Tag No.	kW	Operation	Consump.
PU-01	0.75	24	18.00
PU-02	2.2	24	52.80
PU-03	5.5	24	132.00
PU-04	5.5	24	132.00
PU-05	2.2	2	4.40
PU-06	0.4	24	9.60
PU-07	0.4	24	9.60
PU-08	3.7	24	88.80
PU-09	0.75	24	18.00
PU-10	0.4	24	9.60
PU-11	0.4	24	9.60
PU-12	2.2	24	52.80
PU-13	0.4	24	9.60
PU-14	3.7	8	29.60
PU-15	0.75	8	6.00
PU-16	0.75	24	18.00
PU-17	15	24	360.00
PU-18	5.5	12	66.00
PU-101	11	24	264.00
PU-102	7.5	24	180.00
PU-103	2.2	24	52.80
PU-201	5.5	24	132.00
PU-202	0.4	24	9.60
PU-203	11	1	11.00
PU-204	1.5	24	36.00
B-01	15	24	360.00
B-201	5.5	1	5.50
C-01	0.75	12	9.00
MZ-01	0.75	24	18.00
MZ-02	1.5	24	36.00
MZ-03	1.5	24	36.00
MZ-04	1.5	24	36.00
MZ-05	0.75	24	18.00
MZ-06	15	9	135.00
MZ-07	7.5	7	52.50

MZ-08	0.75	9	6.75
MZ-101	0.75	24	18.00
MX-01	1.5	24	36.00
MX-02	0.4	2	0.80
MX-03	0.4	2	0.80
MX-04	1.5	24	36.00
MX-05	0.75	2	1.50
MX-06	0.75	2	1.50
MX-07	2.2	24	52.80
MX-08	2.2	24	52.80
MX-09	0.75	2	1.50
MX-10	0.75	8	6.00
MX-201	0.75	24	18.00
Total	--	--	2,650.25
Actual Consumption		0.8	2120.2

Client: JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
Project Name: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL
IN THE ARAB REPUBLIC OF EGYPT

Factory Name: EL NASR CO. FOR STEEL PIPES AND FITTINGS

BASIC DESIGN

Document Title:

CALCULATION SHEET

FOR

W.W.T. RECOMMENDABLE PLANT

Issued Date

September 2000

Consultant:

JICA STUDY TEAM

CHIYODA DAMES AND MOORE CO.

CHIYODA CORPORATION

1. Object

This design calculation sheet is applied to the study of W.W.T. Recommendation Plant planning for [El Nasr Co. for Steel Pipes and Fittings] .

2. Wastewater to be treated

- (1) RW-1:[Neutralization Unit Outlet]+[Sanitary/Domestic of Foundry]
- (2) RW-2: Skimmed Oily Water of C.W. Oil Separator
- (3) RW-3: Wastewater in the Collection Pit from Foundry Factory
- (4) RW-4: Wastewater in the Collection Pit from Spiral Pipe/Coating Factories

3. Design Conditions

- (1) The existing facilities of wastewater sources should be maintained, repaired, as original or revised design basis.
- (2) Waste management system in the Factory should be organized, and operated adequately under the responsible managers.
- (3) Suitable routine works, periodical maintainances should be conducted in the whole company.
- (4) Quality and quantity of RW-3 are assumptivel data as same as RW-4, because there was no flow during water sampling.
- (5) Calculation result figures may be changed in the layout planning stage.

4. Contents of Wastewater Treating Facility

- (1) Pre-treatment : Neutralization Unit, Oil Separator, Equalization Tank
- (2) Primary Treatment: Chemical Clarifier, Sand Filter
- (3) Secondary Treatment: Activated Sludge Treatment

5. Design Basis

5.1 Quality and Quantity of Influent Wastewater: Shown on Table-1.

5.2 Quality and Quantity of Treated Water

The following regulations are applied to Basic Design.

- (1) Existing Plant: Law93/62 Discharge to Sewer System
- (2) Recommendation Plant: Law48/82 Non Potable Surface Water (Industrial)

Table-1 Design Basis of Wastewater Quality and Quantity

	Raw Water 1	Raw Water 2	Raw Water 4	Raw Water 3	Law48/82
Flow Rate Av. [m ³ /h]	40	30	50	5	
Flow Rate Max [m ³ /h]	50	40	150	10	
p H [-]	2 ~7	7 ~8	6.5 ~8	6.5 ~8	6 ~9
S S [mg/L]	250	200	30	30	60
B O D [mg/L]	100	100	30	30	60
C O D [mg/L]	200	200	80	80	100
Oil&Grease [mg/L]	5	1,000	5	5	10
T D S [mg/L]	5,800	400	390	390	2,000
Water Temp. [°C]	25 ~35	25 ~35	25 ~30	25 ~35	35

6. Unit Design

6.1. Wastewater Collection (Out of Battery)

6.1.1 No.1 Waste Water Pit

(1) Purpose

Raw water 1 is taken from the outlet of Sedimentation Pit and is stored to pump up to the new Neutralization Unit.

(2) Design Conditions

- 1) Wastewater: Outlet of the Sedimentation Pit
- 2) Flow Rate(Q) $40 \text{ m}^3/\text{h} = 0.67 \text{ m}^3/\text{min}$
- 3) Retention Time: 30 min.
- 4) Shape, Materials, No. : Rectangular, RC(Semi-Underground), 1 set

(3) Sizing

(3-1) No.1 Wastewater Pit (Z-101)

- 1) Req'd Vol. 20 m^3
- 2) Effective Height $1 \text{ m}(\text{take})$
- 3) Cross Sectional Area $A_c = Q/Ah = 20 \text{ m}^2$
Take: $4,000^w \times 5,000^l \times 1,500^h$ *

* Actual height is based on the depth of buried pipe.

(3-2) No.1 Wastewater Pump (PU-101AB)

- | | | | |
|------------------------|-------------------|------------------|--|
| 1) Capacity Allowance | 20% | Design Flow Rate | $48 \text{ m}^3/\text{h}$ |
| 2) Required Total Head | 15 m | (take) | |
| 3) efficiency of pump | 0.6 | | |
| 4) Motor Allowance | 0.3 | | |
| 5) Motor Power | 4.24 kW | \rightarrow | 5.5 kW <u>PU-101AB=48m³/hx0.15MPax5.5kW</u> |

6.1.2 No.2 Waste Water Pit

(1) Purpose

Raw water 2 is taken from the outlet of Oil Separator and is stored to pump up to the new Oil Separator.

(2) Design Conditions

- 1) Wastewater: : Outlet pipe of the Oil Separator
- 2) Flow Rate(Q) $30 \text{ m}^3/\text{h} = 0.5 \text{ m}^3/\text{min}$
- 3) Retention Time: 30 min.
- 4) Shape, Materials, No. : Rectangular, RC(Semi-Underground), 1 set

(3) Sizing

(3-1) No.2 Wastewater Pit (Z-102)

- 1) Required Vol. $A_v = 15 \text{ m}^3$
- 2) Effective H of Pit $A_h = 1 \text{ m}(\text{take})$
- 3) Cross Section Area $A_c = Q/Ah = 15 \text{ m}^2$
Take: $3,000^w \times 5,000^l \times 1,500^h$ *

* Actual height is based on the depth of buried pipe.

(3-2) No.2 Wastewater Pump (PU-102AB)

- | | | | |
|-----------------------|--------|------------------|---------------------------|
| 1) Capacity Allowance | 20% | Design Flow Rate | $36 \text{ m}^3/\text{h}$ |
|-----------------------|--------|------------------|---------------------------|

2) Required Total Head	15	m (take)	
3) efficiency of pump	0.6		
4) Motor Allowance	0.3		
5) Motor Power	3.18	kW →	3.7 kW <u>PU-102AB=36m³/hx0.15MPax3.7kW</u>

6.2 Pre-treatment

6.2.1 Neutralization Unit

(1) Purpose

To neutralize Wastewater which is not neutralized by the existing Neutralization Unit completely.

(2) Design Conditions

1) Wastewater: Neutralization Unit Outlet and Sanitary/Domestic Wastewater from Foundry.

2) Flow Rate: Neutralization Unit	30	m ³ /h	0.5	m ³ /min
Sanitary/Domestic W.	10	m ³ /h	0.17	m ³ /min
Total	40	m ³ /h	0.67	m ³ /min

(3) Sizing

(3-1) Neutralization Tank (T-01)

1) Reaction Time	1	h
2) Reactor Vol.	40	m ³
3) Reactor effct. Height	3	m (take)
4) Reactor Area	13.33	m ²
5) Length =	2	width W= 2.58

Width x Length = 2.6m x 5.2m

T-01=2.6m x 5.2m x 3.5mH

(3-2) No.1 Sedimentation Tank (T-02)/No.1 Sludge Pump (PU-02)

1) Settling velocity	36	m ³ /m ² /d	1.5	m ³ /m ² /h
2) Tank Surface Area	26.67	m ²		
3) Diameter of Tank:	5.83	m →	5.8	m (Standard)
4) Retention Time	2	h (take)		
5) Tank Vol.	80	m ³		
6) Height (linear)	3.03	m →	3	m
7) Sludge/Treated Water	2.5	%	(based on settling test)	
8) Sludge generation rate	1	m ³ /h=	20	kg/h as SS content 20 kg/m ³
9) Sludge Storage Height	1	m (take)		
10) Sludge Storage Vol.	28.26	m ³		
11) Sludge Retention Time	28.26	h	<u>T-02=5.8mID x 3.0mH (linear)</u>	
12) Sludge Draw-off Period	8	hours/d		
13) Pump Capacity	3	m ³ /h	<u>PU-02=4m³/hx20mHx</u>	

(3-3) Lime Feeder (MZ-01)/No.1 Lime Pump (PU-01AB)

1) Lime Requirement	1	g-Lime/L-W.W.	
	30	kg/h	
2) Lime Milk Conc.	5	% →	0.05 kg/L MZ-01= 30kg/h
3) Lime Milk Feed Rate	600	L/h →	10 L/min <u>PU-01AB=10L/minx0.5MPax0.75kW</u>

(3-4) Lime Hopper (D-01)

- 1) Required Lime

1

 day
 - | |
|-----|
| 720 |
|-----|

 kg/d
 - 2) Density

0.5

 kg/L
 - 3) Allowance

30

 %
 - 4) Hopper Vol.

1872

 L →

2,000

 L
 - 5) Hopper Height

1.5

 m (take)
 - Hopper Cross Section Area

1.33

 m²
 - Hopper Diameter

1.30

 m →

1.3

 m
- D-01=1.3m^{I.D.} x 1.5m^H

(3-5) No.1 Lime Drum (D-02)

- 1) Lime Conc.

10

 %

100

 kg/m³
 - 2) Preparation Period

8

 h
 - 3) Required Lime

240

 kg
 - 4) Drum Vol.

2.4

 m³
 - 5) Drum Height (Take)

1.5

 m
 - Diameter

1.43

 m →

1.45

 m
- D-02=1.45m^{I.D.} x 1.5m^H

(3-6) Neutralized W.W. Tank (T-03)

- 1) Retention Time

30

 min
 - 2) Required Vol.

20

 m³
 - 3) Effective H of Pit

2.5

 m (take)
 - 4) Cross Section Area $Ac = Q/Ah =$

8

 m²
- Take: 2.5m^H × 3.2m^L × 3.0m^D

(3-7) Neutralized W.W. Pump (PU-03AB)

- 1) Capacity=

48

 m³/h, Head=

18

 mH (take)
- 2) Motor Power=

5.09

 kW →

5.5

 kW PU-03=48m³/hx18mHx5.5kW

6.2.2 Oil Separator

(1) Object

To remove floatable oil from the skimmed oily water of existing Oil Separator

(2) Design Conditions

- 1) Wastewater: Wastewater from PU-02AB
- 2) Flow Rater: Qm

30

 m³/h =

0.5

 m³/min
- 3) Design Base: API Standard
- 4) Wastewater
 - (a) Water Temp.

30

 °C
 - (b) Specific gravity of Water: Sw

0.995

 - (c) Absolute viscosity: μ

0.0076

 poise
 - (e) Maximum allowable horizontal velocity : VH=15Vt, not exceed 3f/min.
- 5) Oil globles in wastewater
 - (a) Oil globules to be remove:

150

 μ =

0.015

 cm
 - (b) Specific gravity of Oil: So

0.9

 - (c) Rate of rise in wastewater: Vt

0.30

 f/min =

0.09

 m/min
 - (d) Maximum allowable VH:

4.52

 f/min > 3f/min

2 f/min(take) 0.61 m/min

6) Design Factors

(a) For turbulence with: VH/Vt 6.64

(b) Turbulence and Short-circuit Factor: 1.43 (Fig.5-3 of Manual)

(3) Sizing

(3-1) Oil Separator (Z-01)

- 1) Minimum Cross-section Area: $Ac=Qm/VH$ 0.83 m²
- 2) Width: 1.2 m (take) 1.5 m
- 3) Depth(effct.): 0.69 m → 0.8 m
- 4) Length: 7.60 m → 8 m

API Separator: 1.5m^w x 0.8m^d x 8.0m^L (1channel)

(3-2) Oil Separator T.W. Pit (Z-02)

- 1) Retention Time 30 min
- 2) Required Vol. 15 m³
- 3) Effective H of Pit 2.5 m(take)
- 4) Cross Section Area $Ac= Q/Ah=$ 6 m²

Take: 2.4m^w x 2.5m^L x 3.0m^H

(3-3) Skimmed Oil Pit (Z-03)

- 1) Design Conditions Oil Contents in Wastewater 1 L/m³
Oil Contents in Skimmed Water 10%
- 2) Quantity of Skimmed Oily Wat 7.2 m³/d
- 3) Retention Time 1 day
- 4) Required Vol. 7.2 m³
- 5) Effective H of Pit 2.5 m(take)
- 6) Cross Section Area $Ac= Q/Ah=$ 2.88 m²

Take: 1.5m^w x 2.0m^L x 3.0m^H

(3-4) Skimmed Oil Tank (T-04)

- 1) Retention Time 7 days
- 2) Required Vol. 50.4 m³
- 3) Height 6 m(take) Reuired Area 8.4 m²
- 4) Diameter of Tank: 3.27 m → 3.4 m (Standard)

T-03=3.4m^{LD} x 6.0m^H

(3-5) Oil Separator T.W. Pump (PU-4)

- 1) Capacity= 36 m³/h, Head= 18 mH(take)
- 2) Motor Power= 3.81 kW → 5.5 kW PU-04=36m³/hx18mHx5.5kW

(3-6) Recovered Oil Pump (PU-05)

- 1) Design Conditions Working Hour= 1 h/day
- 1) Capacity= 7.2 m³/h → 10 m³/h Head= 15 mH(take)
- 2) Motor Power= 1.06 kW → 1.5 kW PU-05=10m³/hx15mHx1.5kW

6.3 Equakization Tank

(1) Object

To equalize quality and quantity of 2 wastewaters.

(2) Design Conditions

- 1) Quantity and Quality of Wastewater: Shown on Table-2
- 2) Shape: Open Top Tank, Materials: CS /Epoxy Coating , Required No.: 1 set
- 3) Retention Time: h
- 4) Others: Air bubbling device

Table-2 Quantity and Quality of Wastewater

	RW -1	RW -2	BackWash W.W.	RW -3	Equalized W.
Flow Rate [m ³ /h]	40	30	2	5	77
pH [-]	6 ~7.5	7 ~8	6.5 ~8	6.5 ~8	6.5 ~8
SS [mg/L]	250	200	550	30	224
BOD [mg/L]	100	100	186	30	98
COD [mg/L]	200	200	496	80	200
Oil&Grease [mg/L]	5	30	83	5	17

(3) Sizing

A. Equalization Tank

- 1) Required Vol.: m³
 - 2) Height: H= m (take)
 - 3) Section Area: A= m² D= m → m (Standard)
- Take: $8.71\text{m}^{\text{ID}} \times 7.6\text{m}^{\text{H}}$

B. Air Bubbling Device

- 1) Required Air (design base): Nm³/m²/h
- 2) Required Air Quantity: Nm³/h= Nm³/min(take)

6.4 Biological Treating Unit (Activated Sludge Treatment)

(1) Purpose

To remove Organic Substances (BOD,COD) by aerobic micro bacteria.

(2) Design Conditions

- 1) Wastewater: Equalized Wastewater
- 2) Treating Method: Activated Sludge Treatment
- 3) Capacity: m³/h
- 4) Water Quality:

Table-4 Water Quality

	Inlet	Outlet	Law93/62 Sewer System	Law48/82 Non Potable
p H [-]	6.5~8	6.5~8	6 ~10	6~9
S S [mg/L]	224	30	< 500	60
B O D [mg/L]	98	30	< 400	60
C O D [mg/L]	200	50	< 700	100
Oil & Grease [mg/L]	17	5	< 100	10
Water Temp. [°C]	20~35	20~35	< 40	35

5) Shape, Materials, Req'd No.

- (a) Aeration Basin: Rectangular/Above ground, RC, 1 set

(b) Sedimentation Basin: Circular/Above ground, CS+Epoxy coating, 1 set

6) Chemicals

N and P are injected in case of lack of nutrient.

(3) Sizing

(3-1) Aeration Basin(Z-04)

- 1) BOD Loading $0.5 \text{ kg-BOD/m}^3/\text{day}$ (take)
- 2) Vol. of Basin $V_{as} = 250.18 \text{ m}^3$
- 3) Height of Basin $H_{as} = 3.5 \text{ m}$ (take) $A_{as} = 71.48 \text{ m}^2$
 $L = 3 \text{ W}$ (take) $W = 4.88 \text{ m} \rightarrow 5 \text{ m}$
 $L = 15 \text{ m}$

Take: $5.0m^W \times 15.0^L \times 3.5^H$

4) BOD Removal : $R_{BOD} = 125.09 \text{ kg/day}$

5) MLSS : $Ca = 2,000 \text{ mg/L}$

(3-2) No.2 Sedimentation Basin(T-06)

- 1) Surface Loading $L_{as} = 1 \text{ m}^3/\text{m}^2/\text{h}$ (take) = $24 \text{ m}^3/\text{m}^2/\text{day}$
- 2) Surface Area $A_{ss} = 77 \text{ m}^2$
- 3) Height of Basin $H_{ss} = 3 \text{ m}$ (take)
- 4) Vol. of Basin $V_{ss} = 231 \text{ m}^3$ $T_{ss} = 3 \text{ h}$
- 5) Diameter of Basin: $D_{ss} = 9.90 \text{ m} \rightarrow 10 \text{ m}$
 Take: $10m^D \times 4.0m^H$ Act. Surf. Loading = $0.98 \text{ m}^3/\text{m}^2/\text{h}$

(3-3) Surplus Sludge

- 1) BOD→SS Conversin Rate 0.4 (take)
- 2) Sludge from Act. Sludge T. $W_{ss} = 2.08 \text{ kg/h}$ from BOD
 $W_{ss} = 14.94 \text{ kg/h}$ from SS
 Total $W_{ss} = 17.02 \text{ kg/h}$
 SS content 8 kg/m^3 (take) $2.13 \text{ m}^3/\text{h} = 51.07 \text{ m}^3/\text{d}$

(3-4) Air Requirement for Aeration

- 1) Oxygen Demand: $W_{O_2} = a \cdot R_{BOD} + b \cdot Sa = 95.07 \text{ kg/day}$
 $a = \text{BOD Factor} = 0.55 \text{ kg-O}_2/\text{kg-O}_2$
 $b = \text{MLVSS Factor} = 0.07$
 $Sa = 0.75 \cdot \text{MLSS} \cdot \text{Vol. of Basin} / 1,000 = 375.26$
 $R_{BOD} = \text{BOD Removal} = 125.09 \text{ kg/day}$
- 2) Required Air : $Q_{air} = (W_{O_2} \cdot 3.57 \text{ m}^3/\text{kg-O}_2 \cdot 1.3) / (0.08 \cdot 24 \cdot 60)$
 $= 3.54 \text{ Nm}^3/\text{min} \rightarrow 3.6 \text{ Nm}^3/\text{min}$
 : Misceraneous Purpose $1 \text{ Nm}^3/\text{min}$
- 3) Blower(B-01) $Q_{ta} = 9.12 \text{ Nm}^3/\text{min}$
 Take: $9.5 \text{ Nm}^3/\text{min} \times 7 \text{ mH} \times 15 \text{ kW}$

(3-5) Sludge Circulation Pump(PU-08)

- 1) Return Sludge Ratio $R_s = Ca / (Cr - Ca) = 33.33 \%$
- 2) Pump Capacity $33.4 \text{ m}^3/\text{h}$ $PU-08 = 36 \text{ m}^3/\text{hx} \times 12 \text{ mH} \times 3.7 \text{ kW}$

(3-6) Nutrient as N $\text{CO}(\text{NH}_2)_2$ Injection Unit

- 1) Dosage : BOD : N = 100 : 5
 : BOD : $\text{CO}(\text{NH}_2)_2 = 100 : 11$

- 2) Concentration : 12.5 wt %
 - 3) Specific gravity: 1.069
 - 4) Injection rate : $Q_{CO} = 4.3$ L/h (PU-06)
 - 5) Storage Vol. : $V_{CO} = 0.7$ m³ (7days)
 - 6) Dimension : Take: 0.9m¹⁰X1.2m^H (D-04)
- (3-7) Nutrient as P H₃PO₄ Injection Unit
- 1) Dosage : BOD : P = 100 : 1
: BOD : H₃PO₄ = 100 : 3
 - 2) Conc. : 12.5 wt %
 - 3) Specific gravity: 1.189
 - 4) Injection rate : $Q_{ph} = 1.1$ L/h (PU-07)
 - 5) Storage Vol. : $V_{ph} = 0.2$ m³ (7days)
 - 6) Dimension : Take: 0.9m¹⁰X1.2m^H (D-05)

6.4 Chemical Clarifier

(1) Purpose

To remove Suspended Solids(SS), slice of oil and color. Clarifier is not necessary, because A.S.Treated Water meets to the Regulation.

(2) Design Conditions

- 1) Wastewater: W.W. after equalized in T-04.
- 2) Capacity: 77 m³/h
- 3) Water Quality of Inlet and outlet of Clarifier: Shown on Table-3.
- 4) Chemicals: (a)Coagulant= Al₂(SO₄)₃
(b)pH Controller=Ca(OH)₂
(c)Coagulant Aid=Polymer

Table-3 Water Quality

	A. S T. Water	Out let of Clarifier	Law93/62 Sewer System	Law48/82 Non Potable
Flow Rate [m ³ /h]	77	77		
pH [-]	6.5 ~8	7 ~8	6 ~10	6 ~9
SS [mg/L]	30	20	< 500	60
BOD [mg/L]	30	25	< 400	60
COD [mg/L]	50	45	< 700	100
Oil&Grease [mg/L]	3	2	< 100	10

(3) Sizing

(3-1) Treated Water Pit(Z-06)

- 1) Retention Time: 30 min
- 2) Req'd Vol. of Pit 38.5 m³
- 3) Dimension H= 2.5 m (take) A= 15.40 m²
W= 3 m L= 5.13 m Z-06=3.0mWx5.2mLx3mH

(3-2) Coagulation Part(T-07)

- 1) Rapid Mixing Time 3 min (take)
- 2) Reuired Vol. Vfl= 3.85 m³

3) Shape=Cylindrical, Vertical, Materials=CS/Epoxy Coating

Required No. 1 Set

4) Demension: Hfl= 2 m (take) Req'd Area 1.93 m²
 D= 1.57 m → 1.60 m

Take: 1.5m^{1D}x2.0m^H

(3-3) Flocculation (+T-07)

1) Slow Mixing Time 20 min (take)

2) Required Vol. Vf1= 25.67 m³

3) Shape=Rectangular, Vertical, Materials=CS/Epoxy Coating

Required No. 1 Set

4) Demension: Hfl= 3 m (take) Req'd Area 8.56 m²
 L= 2 W (take) W= 2.07 m, L= 4.14 m

T-07= 2.1m^Wx4.2m^Lx3.0m^H

(3-4) No.3 Sedimentation Basin(T-08)

1) Surface Load Ls= 3 m³/m²/h (take)

2) Req'd Area As= 25.67 m²

3) Shape=Circular, Materials=CS/Epoxy Coating, Req'd No. 1 Set


4) Retention Time Ts= 1 h (take)= 60 min

5) Req'd Vol. Vs= 77 m³ H= 3.00 m

6) Dimensions D = 5.72 m → 5.8 m (Standard)

Take: 5.8m^{1D}x4.5m^H (linear=3.0m)

<Act. Surface Load = 2.92 m³/m²/h >



(3-5) Sludge Draw-off

1) SS Removal 2.31 kg/h= 55.44 kg/d

2) Concentration of SS in Draw-off Sludge 0.75 % (take)= 10 kg/m³

3) Sludge Draw-off 0.23 m³/h 0.30 %

(3-6) Coagulant Al₂(SO₄)₃ · 18H₂O Injection Unit

1) Dosing Rate: 30 mg/L, Max. 50 mg/L

2) Concentration: 20 wt % = 222.4 g/L

3) Specific Gravity: 1.112

4) Injection Rate: Q_{p0}= 10.4 L/h= 0.17 L/min (PU-10)

5) Drum Vol. : V_{p0}= 1.7 m³ (for 7days)

Height: H_{p0}= 1.5 m (take) A_{p0}= 1.16 m²

Diameter D_{p0}= 1.2 m

Take: 1.2m^{1D}x1.5m^Hx2 sets (D-07)

(3-7) pH Controller: Ca(OH)₂ Injection Unit

1) Dosing Rate: 20 mg/L, Max. 50 mg/L

2) Concentration: 10 wt % = 100 g/L

3) Specific Gravity: 1

4) Injection Rate: Q_{p0}= 15.4 L/h= 0.26 L/min (PU-09)

5) Drum Vol. : V_{p0}= 2.6 m³ (for 7days)

Height: H_{p0}= 1.5 m (take) A_{p0}= 1.72 m²

Diameter D_{p0}= 1.5 m

Take: $1.4m^{ID} \times 1.5m^H \times 2$ sets (D-06)

(3-8) Coagulant Aid: Polymer Injection Unit

- 1) Dosing Rate: 0.3 mg/L, Max. 0.5 mg/L
- 2) Concentration: 0.5 wt % = 5 g/L
- 3) Specific Gravity: 1
- 4) Injection Rate: $Q_{p0} = 7.7$ L/h = 0.13 L/min (PU-11)
- 5) Drum Vol. : $V_{p0} = 1.3$ m³ (for 7days)
- Height: $H_{p0} = 1.2$ m (take) $A_{p0} = 1.08$ m²
- Diameter: $D_{p0} = 1.2$ m

Take: $1.2m^{ID} \times 1.5m^H \times 2$ sets (D-08)

6.5 Sand Filter Unit

(1) Purpose

To remove overflow floc(SS) from RW-3, and reuse for Cooling Water

(2) Design Conditions

- 1) Wastewater: Wastewater in Collection Pit in Spiral Welding Factory.
- 2) Capacity: 50 m³/h = 25 m³/h \times 3 sets (1 stand-by)
- 3) Water Quality

Table-5 Water Quality

	Inlet	Outlet	Law93/62	Law48/82
p H [-]	6.5~8	6.5~8	6~10	6~9
S S [mg/L]	30	10	< 500	60
B O D [mg/L]	30	< 30	< 400	60
C O D [mg/L]	80	< 80	< 700	100
Oil & Grease [mg/L]	5	2	< 100	10
Water Temp. [°C]	20~35	20~35	< 40	35

4) Shape: Cylindrical/Vertical/Gravity Type.

Materials: Carbon Steel + Epoxy coating, Req'd No.: 3 sets (1 stand-by)

5) Filter Media: Anthracite + Sand/Gravel

6) Backwashing: Air(Blower) + Water (Pump)

(3) Sizing

(3-1) No.3 Wastewater Pit(Z-201)

- 1) Retention Time: 15 min(take)
- 2) Existing Collection Pit: $3m \times 5m \times 3mD = 45$ m³
- 3) Required Vol.: 12.5 m³ Net Retention Time = 69 min
- 4) Dimension: Depth = 3 m(take) Area = 4.17 m²
 $L = 2$ W $W = 1.44$ m $Z-103 = 1.5m \times 3.0m \times 3.5mD$

(3-2) Sand Filter(F-01ABC)

- 1) Filter Velocity: $V_f = 180$ m/day = 7.5 m/h (take)
- 2) Filter Area/Diameter: $A_f = 3.33$ m² $D_f = 2.06$ m
- 3) Height: $H_f =$ Upper of Trough 1 m
 <Linear part> Trough 0.3 m
 Trough-Anthracite 0.7 m

Anthracite	0.7	m
Sand+Gravel	0.8	m
Support+Under	0.7	m
Allowance	0.3	m
Total Height	4.5	m

Take: $2.1 \text{ m}^{\text{ID}} \times 4.5 \text{ m}^{\text{H}}$ → $3.46 \text{ m}^2 \text{ (net)}$

(3-3) Filtered Water Pit (Z-202)

- 1) Vol. of Pit Vfb= 45 min (take) 37.5 m^3
- 2) Depth of Pit Hfb= 2.5 m (take) Surface Area 15 m^2
- 3) L= 2 m W(take) W= 2.74 m L= 5.48 m

Take: $3.0 \text{ m}^{\text{W}} \times 5.0 \text{ m}^{\text{L}} \times 3.0 \text{ m}^{\text{H}}$

(3-4) Backwashing Pump (PU-203)

- 1) Backwashing Velocity Ubw= 40 m/h (take)
- 2) Backwashing Flow rate Qbw= $138.47 \text{ m}^3/\text{h}$
- 3) Backwashing Time Tbw= 10 min (take)
- 4) Backwashing Water Vbw= $23.08 \text{ m}^3/\text{h/Cycle}$
- 5) Backwashing Pump Qp= $152.32 \text{ m}^3/\text{h}$ Hp= 12 mH (take)
P= 9.93 kW → 11 kW PU-203= $155 \text{ m}^3/\text{h} \times 12 \text{ mH} \times 11 \text{ kW}$

(3-5) Backwashing W.W. Pit (Z-203)

- 1) Vol. of Pit Vfb= $1.5 \text{ Backwashing water}$ 34.62 m^3
- 2) Depth of Pit Hfb= 2.5 m (take) Surface Area 13.85 m^2
- 3) L= 2 m W(take) W= 2.63 m L= 5.26 m

Take: $3 \text{ m}^{\text{W}} \times 5.0 \text{ m}^{\text{L}} \times 3.0 \text{ m}^{\text{H}}$

(3-6) Backwash Blower (B-201)

- 1) Backwash Air Rate $20 \text{ Nm}^3/\text{m}^2/\text{h}$
- 2) Req'd Air $1.4 \text{ m}^3/\text{min}$ → Blower= $1.5 \text{ Nm}^3/\text{min} \times 5 \text{ mH} \times 3.7 \text{ kW}$

(3-7) Backwash wastewater Feed

- 1) Max. Backwashing W.W. $34.62 \text{ m}^3/\text{C}$ Av. Backwashing W.W. $23.08 \text{ m}^3/\text{C}$
- 2) Treating Time: 23 h/d Backwash 2 times/d
- 3) Av. Flow Rate: $2.01 \text{ m}^3/\text{h}$ Max. Flow Rate $3.01 \text{ m}^3/\text{h}$
- 4) SS to be removed: 24 kg/d SS Contents: 0.52 kg/m^3
SS contents in WW RW-3 30 mg/L → 550 mg/L
- 5) BOD removal 10% BOD to be removed 3.6 kg/d = 0.16 kg/m^3
BOD contents in WW RW-3 30 mg/L → 186 mg/L
- 6) COD removal 10% BOD to be removed 9.6 kg/d = 0.416 kg/m^3
COD Contents in WW RW-3 80 mg/L → 496 mg/L
- 7) Oil to be removed 3.6 kg/d Oil Contents 0.078 kg/m^3
Oil Contents in WW 5 mg/L → 83 mg/L

6.5 Sludge Treating Unit

(1) Purpose

To reduce sludge volume by thickening and dewatering

(2) Design Conditions

- 1) Sludge: (a) Neutralization sludge (direct No.1 Centrifuge)
- (b) Activated surplus sludge
- (c) Clarifier Sludge (only design)

- 2) Thickener=conineous operation
Centrifuge=6h/day operation


(3) Sizing

(3-1) Sludge Thickener(T-09)

- 1) Surface Load $L_{ss} = \frac{60 \text{ kg/m}^2/\text{d}}{2.5} = 2.5 \text{ kg/m}^2/\text{h}$
- Draw-off Sludge Conc. 40 kg/m^3
- SS Contents of Overflow $300 \text{ mg/L} = 0.3 \text{ kg/m}^3$

2) Sludge Rate (In)

- (a) Act. Sludge Treat. $L_{ac} = 17.02 \text{ kg/h} = 2.13 \text{ m}^3/\text{h}$
- (b) Clarifier $L_{cl} = 2.31 \text{ kg/h} = 0.23 \text{ m}^3/\text{h}$
- Total $L_{to} = 19.33 \text{ kg/h} = 2.36 \text{ m}^3/\text{h}$ SS Conc. av = 8.20 kg/m^3




- 3) Req'd Surface Area $A_{th} = 7.73 \text{ m}^2$ $D_f = 3.14 \text{ m}$
- 4) Thickener Height
 Water Retention 4 h (take) , $H_c = 1.22 \text{ m}$
 Sludge Retention 18 h (take) , $H_s = 1.09 \text{ m}$
Take: $3.2 \text{ m}^{10} \times 2.5 \text{ m}^H$


(3-2) Polymer Injection Unit for Thickener

- 1) Dosage 300 mg/L
- 2) Concentration $0.1 \text{ wt \%} = 1 \text{ g/L}$ (D-09)
- 3) Specific gravity 1
- 4) Req'd Polymer $0.71 \text{ g/h} = 0.71 \text{ L/h}$ (PU-13)
- 5) Req'd Vol. $V_{p0} = 0.04 \text{ m}^3$ (7days)
- 6) Demension : Take: $0.4 \text{ m ID} \times 1.0 \text{ m H} \times 2 \text{ sets}$

(3-3) NO.1 Centrifuge

- 1) Sludge Feed Rate: (Sludge generation/day)/ 8 h Operation
 $1.00 \text{ m}^3/\text{h} = 20 \text{ kg/h}$ Centrifuge Cap. = $1.5 \text{ m}^3/\text{h}$
- 2) Solid content of Cake $20 \text{ \%} = 200 \text{ kg/m}^3$
- Solid content of Water $500 \text{ mg/L} = 0.5 \text{ kg/m}^3$





3) Sludge cake ratio

9.77

 % of Feed Sludge

4) Generation of Cake

2.34

 m³/d

(3-4) NO.2 Centrifuge

1) Sludge Feed Rate: (Sludge generation/day)/

6

 h Operation

0.47

 m³/h =

18.72

 kg/h Centrifuge Cap. = 2.0 m³/h

2) Solid content of Cake

20

 % =

200

 kg/m³


Solid content of Water

500

 mg/L

0.5

 kg/m³



3) Sludge cake ratio

19.39

 % of Feed Sludge

4) Generation of Cake

2.18

 m³/d

(3-5) Polymer Injection Unit for Centrifuge

1) Dosage

1

 % as Dry SS =

0.60

 kg/h

2) Concentration

1

 wt % =

10

 g/L

3) Specific gravity

1

4) Injection rate Q_{p0} =

60

 L/h =

1.00

 L/min (PU-15)

5) Req'd Vol. V_{p0} =

1.08

 m³ (for 3days)

6) Drum Dimension H_{p0} =

1.50

 m (take) A_{p0} =

0.72

 m²

D_{p0} =

0.96

 m

: Take: 1.2m¹⁰ x 1.8m^H, 1 set (D-10)

6.6 Sterilization

(1) Purpose

To sterilize treated water including sanitary wastewater

(2) Design Condition

1) Wastewater: Filtered water

2) Disinfectant: NaClO Conc

12

 wt% Sp. Gra

1.0155

3) Dosage

4

 mg/L (Max. 6mg/L)

4) Contact Time

15

 min

(3) Sizing

- 1) Injection Rate $\boxed{1.64}$ L/h
- 2) Req'd Drum Vol. $\boxed{0.28}$ m³ (for 7days)
- 3) Drum Dimension: Take: 0.6m^{1D} x 1.0m^H
- 4) Sterilization Basin Vol. $\boxed{12.5}$ m³
- 5) Basin Dimension H= $\boxed{2.5}$ m (take) A= $\boxed{5}$ m²
- Take: 2.0m^W x 3.5m^L x 2.5m^H