

JAPAN INTERNATIONAL COOPERATION AGENCY

BASIC DESIGN PACKAGE OF

RECOMMENDABLE WASTEWATER TREATMENT PLANT


FOR

MANSOURA CO. FOR RESINS AND CHEMICALS

February 2000

CHIYODA DAMES AND MOORE CO.

CHIYODA CORPORATION





NO.	DATE	DESCRIPTION	BY	CHECKED	DATE

Item No.	Service	Size (m)	Design Press (kg/cm ²)	Material/Type	Item No.	Service	Size (m)	Design Press (kg/cm ²)	Material/Type
Z-02	Aeration Pond	14.05 x 20.05 x 5.8	1.400	R.C/Open	Z-04	Inaerated/Sandwich Water Pond	3.05 x 4.25 x 3.05	3.0	R.C/Open
Z-03	Clarifier	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-05	Sand Filter	1.65 x 4.05 x 6.0	3.5	C.S/Epoxy Coating
Z-04	Clarifier	7.05 x 4.05 x 1.20	3.0	R.C/Open	T-07	Activated Carbon Filter	1.65 x 4.55 x 9.0	3.5	C.S/Epoxy Coating
Z-05	Full Water	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-08	Blower	2200	35	FC/Roat Type
Z-06	Full Water	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-09	Blower	2200	35	FC/Roat Type
Z-07	Full Water	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-10	Blower	2200	35	FC/Roat Type
Z-08	Full Water	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-11	Blower	2200	35	FC/Roat Type
Z-09	Full Water	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-12	Blower	2200	35	FC/Roat Type
Z-10	Full Water	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-13	Blower	2200	35	FC/Roat Type
Z-11	Full Water	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-14	Blower	2200	35	FC/Roat Type
Z-12	Full Water	2.05 x 2.05 x 3.05	3.0	R.C/Open	T-15	Blower	2200	35	FC/Roat Type


JAPAN INTERNATIONAL COOPERATION AGENCY
INDUSTRIAL DEVELOPMENT STUDY (MISSION)
CLIENT
CONSULTANT
PROJECT
TITLE
ISSUED DATE
DWG NO

NOTE: Vertical Cylindrical Tank
 1) Type : (Open Top Tank)
 2) Materials : Carbon Steel
 inside Epoxy Coating
 3) Accessories: Stairway
 Inside Ladder
 Air Bubbling Tube

Loading Data :
 : Empty Weight 9.7 ton
 : Full Water 130 ton




M-2	Manhole	500Φ	1
M-1	Manhole	500Φ	1
N-6	Level Instrument	2"	1
N-5	Over Flow	4"	1
N-4	Drain	2"	1
N-3	Bubbling Air Inlet	2"	1
N-2	Raw Water Outlet	4"	1
N-1	Raw Water inlet	4"	1
No	Name	Size	No
Note			
CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY		
TYTLE	FOR: MANSOURA CO., FOR RESINS AND CHEMICALS 120 m ³ EQUALIZATION TANK (T - 01) WASTEWATER TREATMENT PLANT		
DWG. NO	RC - BD - 22 - SK01	REV.	0



NOTE:
 1) Type : Vertical Cylindrical Tank
 (Open Top Tank)
 2) Materials : Carbon Steel
 inside Epoxy Coating
 3) Accessories: Stairway
 Inside Ladder
 Air Bubbling Tube



Equipment No	Service	D	H ₁	H ₂	W ₁	W ₂
T-04	Sedimentation Tank	4,000	3,500	4,500	3.2	48.2
T-05	Clarifier	7,000	3,000	4,000	6.2	128.2
T-08	Thickener	2,400	3,000	4,000	1.5	14.5

W₁ : Empty Weight ton
 W₂ : Full Water ton



N-4						
N-3	Sludge Outlet		2B	1		
N-2	Water Outlet		6B	1		
N-1	Water inlet		6B	1		
No	Name	Size	No	No	Note	
CLIENT JAPAN INTERNATIONAL COOPERATION AGENCY						
FOR: MANSOURA CO., FOR RESINS AND CHEMICALS						
TYTLE SEDIMENTATION TANK, CLARIFIER & THICKENER						
WASTEWATER TREATMENT PLANT						
DWG. NO	RC - BD - 22 - SK02	REV.				0

NOTE:
 1) Type : Vertical Cylindrical Tank
 (Open Top Tank)
 2) Materials : Carbon Steel
 inside Epoxy Coating
 3) Accessories: Stairway
 Inside Ladder
 Air Bubbling Tube





Equipment No	Service	D	H ₁	H ₂	W ₁	W ₂
T-06A/B/C	Sand Filter	1,800	4,000	6,000	8.9	18.5
T-05A/B	Activated Carbon Filter	1,800	4,500	6,500	6.8	17.8

W₁ : Empty Weight ton
 W₂ : Full Water ton

M-3	Manhole	500Φ	1		
M-2	Manhole	500Φ	1		
M-1	Manhole	500Φ	1		
N-3	Surface Wash water Inlet	2"	1		
N-2	Filtered Water Outlet/ Backwash Water Inlet	4"	1		
N-1	Clarified Water inlet/ Backwash Waste Outlet	8"	1		
No	Name	Size	No	No	Note

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY				
TYTLE	FOR: MANSOURA CO. FOR RESINS AND CHEMICALS SAND FILTER & ACTIVATED CARBON FILTER WASTEWATER TREATMENT PLANT				
DWG. NO	RC - BD - 22 - SK03	REV.	0		



NOTE:
 1) Type : Vertical Cylindrical Tank
 (Open Top Tank)
 2) Materials : Carbon Steel
 inside Epoxy Coating
 3) Accessories: Stairway

Equipment No	Service	D	H	W ₁	W ₂
T-02	Coagulant Tank	1,430	2,000	1	4
T-03	Flocculation Tank	2,800	3,000	3	18



W₁ : Empty Weight ton
 W₂ : Full Water ton

N-3	Drain	1"	1	
N-2	Water Outlet	4"	1	
N-1	Water inlet	4"	1	
No	Name	Size	No	Note
CLIENT : JAPAN INTERNATIONAL COOPERATION AGENCY				
FOR: MANSOURA CO., FOR RESINS AND CHEMICALS				
TYTLE : COAGULATION/FLOCCULATION TANK (T-02/03)				
WASTEWATER TREATMENT PLANT				
DWG. NO	RC - BD - 22 - SK05			REV.0

NOTE: : Vertical Cylindrical Tank
 1) Type : Vertical Cylindrical Tank
 2) Materials : FRP
 3) Accessories: Level Gage
 Man-hole



Equipment No	Service	D	H ₁	H ₂	W ₁	W ₂
T-09A/B	Coagulation Tank	1,000	1,300	6,000	0.08	1
T-10A/B	Lime Tank	1,000	1,300	6,500	0.08	1
T-11A/B	Polymer-A Tank	800	1,000	6,000	0.04	0.5
T-12A/B	Phosphate Tank	800	1,000	6,500	0.04	0.5
T-13A/B	Urea Tank	1,200	1,800	6,000	0.1	2
T-14A/B	Polymer-B Tank	800	1,000	6,500	0.04	0.5
T-15A/B	NaOCl Tank	800	1,000	6,000	0.04	0.5

W₁ : Empty Weight ton
 W₂ : Full Water ton




M-1	Manhole	400Φ	1	
N-5	Vent	1"	1	
N-4	Drain	1"	1	
N-3	Level Gage	3/4"	1	
N-2	Level Gage	3/4"	1	
N-1	Water Inlet	1"	1	
No	Name	Size	No	Note
CLIENT JAPAN INTERNATIONAL COOPERATION AGENCY				
FOR: MANSOURA CO. FOR RESINS AND CHEMICALS				
TYTILE CHEMICAL TANK				
WASTEWATER TREATMENT PLANT				
DWG. NO	RC - BD - 22 - SK04	REV.	0	




Material : Reinforced Concrete
 Accessories : Operating Stage
 Stairway
 Air Distributing pipings



N-3	Drain	1"	1	
N-2	Water Outlet	4"	1	
N-1	Water inlet	4"	1	
No	Name	Size	No	Note
CLIENT JAPAN INTERNATIONAL COOPERATION AGENCY				
TYTLE FOR: MANSOURA CO.,FOR RESINS AND CHEMICALS AERATION POND (Z-02)				
DWG. NO WASTEWATER TREATMENT PLANT				
RC - BD - 22 - SK08			REV:0	

CONFIGURATION OF ELECTRICAL & INSTRUMENTATION SYSTEM FOR DEMONSTRATION PLANT





- PANEL SPECIFICATION
1. SELF STANDING TYPE FOR INDOOR
 2. STRUCTURE : 3.2MM STEEL
 3. COLOR : YELLOW GREEN
 4. CABLE ENTRY : BOTTOM

CONTROL PANEL OUTLINE FOR DEMONSTRATION PLANT
 (SCALE : NONE)
 (UNIT : MM)

JICA	Check	Tech.	Appr.	REVISION			
Sign							
Date							
CNSLT	Design	Check	Appr.				
Sign				Re.	Descr.	Draw	Chc
Date							Appr
							Date
CLIENT				JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION			
CONSULTANT				CHIYODA DAMES & MOORE CO. CHIYODA CORPORATION			
PROJECT				THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT			
TITLE				FOR MANSOURA CO. FOR RASINS AND CHEMICALS CONTROL PANEL OUTLINE FOR W.W.T. DEMONSTRATION PLANT			
ISSUED DATE				SCALE		NONE	
DWG NO				RC - BD - 70 - 1		REV. 0	

EQUIPMENT LIST for Mansoura Co. for Resins and Chemicals

DOC. NO. RC-BD-L1

(1/5)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial Waste Water Plant

PLANT : Monsoura Co. for Resins and Chemicals

WASTE W. : End of Pipe (Sanitary Waste W. + Waste Water)

REV	1	2	3	MADE	
BY				CKD	<i>[Signature]</i>
APVE				APVE	
DATE				DATE	08.16.99

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
T-01	Equalization Tank	1	Vertical Cylindrical Type	Carbon Steel/Epoxy
			5,811 ^φ × 6,105 ^H × 120 m ³	Coating
T-02	Coagulation Tank	1	Vertical Cylindrical Type	Carbon Steel/Epoxy
			1,430 ^φ × 2,000 ^H × 3 m ³	Coating
T-03	Flocculation Tank	1	Vertical Cylindrical Type	Carbon Steel/Epoxy
			2,860 ^φ × 3,000 ^H × 15 m ³	Coating
T-04	Sedimentation Tank	1	Vertical Cylindrical Type	Carbon Steel/Epoxy
			4,000 ^φ × 4,500 ^H × 45 m ³	Coating
T-05	Clarifier	1	Vertical Cylindrical Type	Carbon Steel/Epoxy
			7,000 ^φ × 4,000 ^H × 120 m ³	Coating
T-06A/B/C	Sand Filter	3	Vertical Cylindrical Type	Carbon Steel/Epoxy
			1,600 ^φ × 4,000 ^H × 8 m ³	Coating
T-07A/B	Activated Carbon Filter	2	Vertical Cylindrical Type	Carbon Steel/Epoxy
			1,600 ^φ × 4,500 ^H × 9 m ³	Coating
T-08	Thickener	1	Vertical Cylindrical Type	Carbon Steel/Epoxy
			2,400 ^φ × 4,000 ^H × 13 m ³	Coating
T-09A/B	Coagulant Tank	2	Vertical Cylindrical Type	FRP
			1,000 ^φ × 1,300 ^H × 1 m ³	
T-10A/B	Lime Tank	2	Vertical Cylindrical Type	FRP
			1,000 ^φ × 1,300 ^H × 1 m ³	
T-11A/B	Polymer-A Tank	2	Vertical Cylindrical Type	FRP
			800 ^φ × 1,000 ^H × 0.5 m ³	
T-12A/B	Phosphate Tank	2	Vertical Cylindrical Type	FRP
			800 ^φ × 1,000 ^H × 0.5 m ³	

Note:

EQUIPMENT LIST for Mansoura Co. for Resins and Chemicals

DOC. NO. RC-BD-L1

(2/5)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial Waste Water Plant

PLANT : Monsoura Co. for Resins and Chemicals

WASTE W. : End of Pipe (Sanitary Waste W. + Waste Water)

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
T-13A/B	Urea Tank	2	Vertical Cylindrical Type $1,200^{\phi} \times 1,800^H \times 2 \text{ m}^3$	FRP
T-14	Polymer-B	1	Vertical Cylindrical Type $800^{\phi} \times 1,000^H \times 0.1 \text{ m}^3$	FRP
T-15	NaOCl Tank	1	Vertical Cylindrical Type $800^{\phi} \times 1,000^H \times 0.1 \text{ m}^3$	FRP
Z-01	Waste Water Pit	1	Vertical Square Type $4,000^{\text{V}} \times 4,000^{\text{L}} \times 2,000^{\text{H}} \times 16 \text{ m}^3$	Reinforced Concrete
Z-02	Aeration Pond	1	Vertical Rectangular Type $14,000^{\text{V}} \times 20,000^{\text{L}} \times 5,800^{\text{H}} \times 1,400 \text{ m}^3$	Reinf. Coating
Z-03	Clarified Water Pond	1	Vertical Square Type $2,000^{\text{V}} \times 2,000^{\text{L}} \times 3,000^{\text{H}} \times 8 \text{ m}^3$	Reinforced Concrete
Z-04	Treated/Sterilizing Water P.	1	Vertical Rectangular Type $3,000^{\text{V}} \times 5,250^{\text{L}} \times 3,000^{\text{H}} \times 30 \text{ m}^3$	Reinforced Concrete
Z-05	Waste Water Pond	1	Vertical Rectangular Type $3,000^{\text{V}} \times 4,000^{\text{L}} \times 3,000^{\text{H}} \times 30 \text{ m}^3$	Reinforced Concrete
Z-06	Sludge Pond	1	Vertical Square Type $2,000^{\text{V}} \times 2,000^{\text{L}} \times 3,000^{\text{H}} \times 8 \text{ m}^3$	Reinforced Concrete
Z-07	Dewatered Sludge Storage	1	Vertical Square Type $3,000^{\text{V}} \times 3,000^{\text{L}} \times 2,000^{\text{H}} \times 14 \text{ m}^3$	Reinforced Concrete

Note:

EQUIPMENT LIST for Mansoura Co. for Resins and Chemicals

DOC. NO. RC-BD-L1

(3/5)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial Waste Water Plant

PLANT : Monsoura Co. for Resins and Chemicals

WASTE W. : End of Pipe(Sanitary Waste W. + Waste Water)

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
PU-01	Raw Water Pump	3	Submergible Type	SCS14/SCS14
A/B/C			30 m ³ /h×20 m×3.7 kW	
PU-02A/B	Coagulation Tank Feed Pump	2	Horizontal Centrifugal Type	SCS13/SCS13
			30 m ³ /h×12 m×2.2 kW	
PU-03A/B	Filter Feed Pump	2	Horizontal Centrifugal Type	SCS13/SCS13
			30 m ³ /h×25 m×3.7 kW	
PU-04A/B	Backwash Pump	2	Horizontal Centrifugal Type	SCS13/SCS13
			80 m ³ /h×15 m×5.5 kW	
PU-05A/B	Sludge Pump	2	Horizontal Centrifugal Type	SCS13/SCS13
			0.5 m ³ /h×15 m×1.5 kW	
PU-06A/B	Return Sludge Pump	2	Horizontal Centrifugal Type	SCS13/SCS13
			15 m ³ /h×15 m×2.2 kW	
PU-07A/B	Backwashed Water Pump	2	Horizontal Centrifugal Type	SCS13/SCS13
			2 m ³ /h×12 m×1.5 kW	
PU-08A/B	Centrifuge Feed Pump	2	Horizontal Centrifugal Type	SCS13/SCS13
			1.5 m ³ /h×15 m×1.5 kW	
PU-09A/B	Coagulant Pump	2	Reciprocating Type	SCS14/SCS14
			7 L/h×0.3 Mpa×0.4 kW	
PU-10A/B	Lime Pump	2	Reciprocating Type	SCS13/SCS13
			10 L/h×0.3 MPa×0.4 kW	
PU-11A/B	Polymer-A Pump	2	Reciprocating Type	SCS13/SCS13
			3 L/h×0.3 MPa×0.4 kW	
PU-12A/B	Phosphate Pump	2	Reciprocating Type	SCS13/SCS13
			5 L/h×0.3 MPa×0.4 kW	

Note:

EQUIPMENT LIST for Mansoura Co. for Resins and Chemicals

DOC. NO. RC-BD-L1

(4/5)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial Waste Water Plant

PLANT : Monsoura Co. for Resins and Chemicals

WASTE W. : End of Pipe(Sanitary Waste W. + Waste Water)

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
PU-13A/B	Urea Pump	2	Reciprocating Type 15 L/h×0.3 MPa×0.4 kW	SCS13/SCS13
PU-14A/B	Polymer-B Pump	2	Reciprocating Type 1 L/h×0.3 MPa×0.4 kW	SCS13/SCS13
PU-15A/B	NaClO	2	Reciprocating Type 2 L/h×0.3 MP×0.4 kW	PVC/PVC
PU-16A/B	Treated Water Pump	2	Horizontal Centrifugal Type 30 m ³ /h×12 m×2.2 kW	SCS13/SCS13
B-01A/B	Blower	2	Root Type 22 Nm ³ /min×0.05 MPa×37 kW	FC/FC
MZ-01	Dehydrator	1	Centrifuge Type 45 kg-Dry/h×7.5 kW+1.5 kW Sharples/Super-D-Canter	SCS13/SCS13
MX-01	Rapid Mixer	1	Vertical Type, 0.4 kW	SUS304
MX-02	Flocculator	1	Vertical Type, 2.2 kW	SUS304
MX-03	Sedimentation Tank Rake	1	Center Drive Type, 0.4 kW	Carbon Steel /Epoxy Coating
MX-04	Clarifier Rake	1	Center Drive Type, 0.75 kW	Carbon Steel /Epoxy Coating
MX-05	Thickener Rake	1	Center Drive Type, 0.4 kW	Carbon Steel /Epoxy Coating
MX-06A/B	Coagulant Tank Mixer	2	Vertical Type, 0.2 kW	SUS304
MX-07A/B	Lime Tank Mixer	2	Vertical Type, 0.2 kW	SUS304
MX-08A/B	Polymer-A Tank Mixer	2	Vertical Type, 0.1 kW	SUS304
MX-09A/B	Phosphate Tank Mixer	2	Vertical Type, 0.1 kW	SUS304

Note:

INSTRUMENT LIST for Mansoura Co. for Resins and Chemicals

DOC. NO. :RC-BD-L2-(1/3)

(1/3)

CLIENT :Japan International Cooperation Agency

PROJECT :The Study on Industrial W. W. Pollution Control

PLANT :Monsoura Co. for Resins and Chemicals

WASTE W. :End of Pipe(Sanitary Waste W. + Waste Water)

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	DEC. 16, '89

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
AR-01	WW, T-02 Coagulation T. Out	1	pH 4~10 pH Analyzer	C. P.
AR-02	WW, Z-02 Aeration Pond	1	0~10 mg/L Dissolved Oxygen Analyzer	C. P.
FIC-01	Sedimentation line	1	10 m ³ /h~50 m ³ /h Flow Indicating Controller	
FI-01	AS, BL-01A/B Blower Outlet	1	15 Nm ³ /min~30 Nm ³ /min Flow Meter	
FI-02	WW, Z-02 Aeration Pond Inlet	1	5 m ³ /h~30 m ³ /h Magnetic Flow Meter	
FI-03	WW, PU-08A/B Feed Pump Out.	1	0.5 m ³ /h~3 m ³ /h Flow Meter	
LS-01	WW, Z-01 Waste Water Pit	1	500 mm~1,000 mm Level Switch HH, H, L	
LC-01	WW, T-01 Equalization Tank	1	1,000 mm~4,500 mm Level Controller	
LI-01	WW, T-01 Equalization Tank	1	500 mm~5,500 mm Level Indicator	
LS-02	WW, Z-03 Clarified Water Pond	1	1,000 mm~1,500 mm Level Switch H, L	
LS-03	CHL, Z-04 Treated Water Pond	1	1,000 mm~2,000 mm Level Switch H, L	
LS-04	WW, Z-06 Sludge Pond	1	500 mm~2,000 mm Level Switch H, L	
LS-05	WW, Z-05 Wastewater Pond	1	500 mm~2,500 mm Level Switch H, L	

Note: C. P. = Center Panel Mount
L. P. = Local Panel Mount

INSTRUMENT LIST for Mansoura Co. for Resins and Chemicals

DOC. NO. : RC-BD-L2-(2/3)

(2/3)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial W. W. Pollution Control

PLANT : Monsoura Co. for Resins and Chemicals

WASTE W. : End of Pipe(Sanitary Waste W. + Waste Water)

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
LG-01A/B	T-09A/B Coagulant Tank	2	Tubular	
			Level Gage	
LG-02A/B	T-10A/B Lime Tank	2	Tubular	
			Level Gage	
LG-03A/B	T-11A/B Polymer-A Tank	2	Tubular	
			Level Gage	
LG-04A/B	T-12A/B Phosphate Tank	2	Tubular	
			Level Gage	
LG-05A/B	T-13A/B Urea Tank	2	Tubular	
			Level Gage	
LG-06	T-14 Polymer-B Tank	1	Tubular	
			Level Gage	
LG-07	T-15 NaOCl Tank	1	Tubular	
			Level Gage	
PI-01A/B/C	WW, PU-01A/B/C Outlet	3	Buldon Tube	
			Pressure Indicator	
PI-02A/B	WW, PU-02A/B Outlet	2	Buldon Tube	
			Pressure Indicator	
PI-05A/B	WW, PU-05A/B Outlet	2	Diaphragm	
			Pressure Indicator	
PI-06A/B	WW, PU-06A/B Outlet	2	Diaphragm	
			Pressure Indicator	
PI-17A/B	AS, BL-01A/B Outlet	2	Buldon Tube	

Note: C.P. = Center Panel Mount
L.P. = Local Panel Mount

INSTRUMENT LIST for Mansoura Co. for Resins and Chemicals

DOC. NO. : RC-BD-L2-(3/3)

(3/3)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial W. W. Pollution Control

PLANT : Monsoura Co. for Resins and Chemicals

WASTE W. : End of Pipe(Sanitary Waste W. + Waste Water)

REV	1	2	3	MADE	
BY				CKD	
APVE				APVE	
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
PI-03A/B	WW, PU-03A/B Outlet	2	Buldon Tube Pressure Indicattor	
PI-04A/B	WW, PU-04A/B Outlet	2	Buldon Tube Pressure Indicattor	
PI-16A/B	WW, PU-16A/B Outlet	2	Buldon Tube Pressure Indicattor	
PI-08A/B	WW, PU-08A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-07A/B	WW, PU-07A/B Outlet	2	Buldon Tube Pressure Indicattor	
PI-09A/B	Coagulant, PU-09A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-10A/B	Lime, PU-10A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-11A/B	Polymer, PU-11A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-12A/B	Phosphate, PU-12A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-13A/B	Urea, PU-13A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-14A/B	Polymer, PU-14A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-15A/B	NaOCl, PU-15A/B Outlet	2	Diaphragm Pressure Indicattor	

Note: C. P. = Center Panel Mount
L. P. = Local Panel Mount

INDUCTION MOTOR LIST

CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Industrial Waste Water Plant
 PLANT : Monsanto Co. for Resins and Chemicals
 WASTE W. : End of Pipes (Sanitary Waste W. + Waste Water)

REVISED	1	2	3	MADE
BY				CKD
APPROVED				APVE
DATE				DATE

Motor No.	Service	No. Required	Type	Output		Speed Chrst	Revolution r.p.m	V-0-Hz	Time Rating	Starting		Insulation	Enclosure	Cable	Mounting	Drive	Bearing	Acc.	Location	Color Finish	Remarks
				Estimate	Final					Current	Torque										
PU-01-A-C-M	Raw Water Pump	3	SC	3.7		C	CW	380-3-50	C			TEFC		H	D			OD			
PU-02A/B-M	Coagulation Tank Feed Pump	2	SC	2.2		C	CW	380-3-50	C			TEFC		H	D			OD			
PU-03A/B-M	Filter Feed Pump	2	SC	3.7		C	CW	380-3-50	C			TEFC		H	D			OD			
PU-04A/B-M	Backwash Pump	2	SC	5.5		C	CW	380-3-50	C			TEFC		H	D			OD			
PU-05A/B-M	Sludge Pump	2	SC	1.5		C	CW	380-3-50	C			TEFC		H	D			OD			
PU-06A/B-M	Return Sludge Pump	2	SC	2.2		C	CW	380-3-50	C			TEFC		H	D			OD			
PU-07A/B-M	Backwashed Water Pump	2	SC	1.5		C	CW	380-3-50	C			TEFC		H	D			OD			
PU-08A/B-M	Centrifuge Feed Pump	2	SC	1.5		C	CW	380-3-50	C			TEFC		H	D			OD			
PU-09A/B-M	Coagulation Pump	2	SC	0.4		C	CW	380-3-50	C			TEFC		H	G			OD			
PU-10A/B-M	Lime Pump	2	SC	0.4		C	CW	380-3-50	C			TEFC		H	Q			OD			
PU-11A/B-M	Polymer-A Pump	2	SC	0.4		C	CW	380-3-50	C			TEFC		H	Q			OD			
PU-12A/B-M	Phosphate Pump	2	SC	0.4		C	CW	380-3-50	C			TEFC		H	Q			OD			
PU-13A/B-M	Urea Pump	2	SC	0.4		C	CW	380-3-50	C			TEFC		H	Q			OD			
PU-14A/B-M	Polymer-B Pump	2	SC	0.4		C	CW	380-3-50	C			TEFC		H	Q			OD			
PU-15A/B-M	NaOC Pump	2	SC	0.4		C	CW	380-3-50	C			TEFC		H	Q			OD			
PU-16A/B-M	Treated Water Pump	2	SC	2.2		C	CW	380-3-50	C			TEFC		H	Q			OD			
BL-01A/B-M	Blower	2	SC	37		C	CW	380-3-50	C			TEFC		H	V			OD			
MZ-01-A-M	Dehydrator (Main Motor)	1	SC	7.5		C	CW	380-3-50	C			TEFC		H	V			OD			
MZ-01-B-M	Dehydrator (Backdrive Motor)	1	SC	1.5		C	CW	380-3-50	C			TEFC		H	V			OD			
MX-01-M	Rapid Mixer	1	SC	0.4		C	CW	380-3-50	C			TEFC		V	Q			OD			
MX-02-M	Flocculator	1	SC	2.2		C	CW	380-3-50	C			TEFC		V	G			OD			
MX-03-M	Sedimentation Tank Rake	1	SC	0.4		C	CW	380-3-50	C			TEFC		V	G			OD			
MX-04-M	Clarifier Rake	1	SC	0.8		C	CW	380-3-50	C			TEFC		V	G			OD			
MX-05-M	Thickener Rake	1	SC	0.4		C	CW	380-3-50	C			TEFC		V	Q			OD			
MX-08A/B-M	Coagulation Tank Mixer	2	SC	0.2		C	CW	380-3-50	C			TEFC		V	G			OD			
MX-07A/B-M	Lime Tank Mixer	2	SC	0.2		C	CW	380-3-50	C			TEFC		V	Q			OD			
MX-08A/B-M	Polymer-A Tank Mixer	2	SC	0.1		C	CW	380-3-50	C			TEFC		V	G			OD			
MX-09A/B-M	Phosphate Tank Mixer	2	SC	0.1		C	CW	380-3-50	C			TEFC		V	G			OD			
MX-10A/B-M	Urea Tank Mixer	2	SC	0.4		C	CW	380-3-50	C			TEFC		V	G			OD			
MX-11A/B-M	Polymer-B Tank Mixer	2	SC	0.1		C	CW	380-3-50	C			TEFC		V	Q			OD			

Notes:

1. Type : SC = Squirrel Cage, W = Wound Rotor.
2. Speed : C = Constant, M = Multi, A = Adjustable, V = Varying.
3. Revolution Direction : Direction when viewed from coupling side.
CW = Clockwise, CCW = Counter-Clockwise.
4. Voltage : Rated Voltage
5. Time Rating : C = Continuous, ST = Short Time, P = Periodic.

6. Enclosure : TEFC = Totally-Enclosed Fan-Cooled.
DR = Drip-Proof.

7. Cable (or Wire) : T = Top, B = Bottom, S = Side, H = Hub for conduit tube or flexible tube.

8. Mounting : H = Horizontal, V = Vertical


9. Drive : D = Direct, B = Belt, C = Chain, G = Gear.

10. Location : ID = Indoor, OD = Outdoor.

Overall Schedule for Implementation of Demonstration Plant (Preliminary)

Dec. 11, 1999

Phase 1 Study



Demo-Plant in Mansoula Co., Resins & Chemicals: ESTIMATE SUMMARY & DEMARCATION

(Base Case)

1999.12.16

ITEM	IBL		OBL		Demarcation (Eq. ¥1000)	
	Yen Portion (¥1000)	LE Portion (LE)	Yen Portion (¥1000)	LE Portion (LE)	Japanese Side	Egyptian Side
1. Equipment & Materials						
(1) Machinery	50,290					
(2) Piping Materials	10,207					
(3) Instrument'n Eq. & Mtl's	16,950					
(4) Electrical Eq. & Mtl's	12,600					
(5) Testing Eq., Etc.	3,854					
1. Subtotal	93,901	0	0	0	93,901	0
2. Field Construction						
(1) Steel Tanks & Vessels		481,837				
(2) Acid-Proof Lining		0				
(3) Equipment Installation		60,500				
(4) Piping		128,980		17,600		600
(5) Foundations		75,000				0
(6) RC-made Reservoir/Structure		843,750				0
(7) Road/Pavement		30,000				0
(8) Building		361,760				0
(9) Platform, Piperack		30,000				0
(10) Painting		50,000				0
(11) Electrical Works		62,840		11,760		400
(12) Instrumentation		300,000				0
(13) Commissioning/Test		30,000				0
2. Subtotal	0	2,454,667	0	29,360	83,500	1,000
Direct Cost: 1 + 2 (Eq. ¥1000)		177,360		998		
3. Indirect Cost						
(1) Export Packing, Ocean Tra	13,500				13,500	0
(2) Import Duty, Inland Transportation*1		790,000		0		26,900
(3) Temporary Facilities*2		147,000			5,000	
(4) Subcontractor Expenses*3		613,667			20,900	
(5) Insurance, Social Tax*4		152,000		1,000	5,200	0
(6) Supervisor Expenses	10,000				10,000	
3. Subtotal	23,500	1,702,667	0	1,000	54,500	26,900
All Total: 1 + 2 + 3	117,401	4,157,334	0	30,360	231,901	27,900
All Total (Eq. ¥1000)	117,401	141,400	0	1,000		
IBL/OBL Total (Eq. ¥1000)		258,801		1,000		
Total Cost			259,801		231,901	27,900

*1 : (日本調達資材費+輸出梱包・海上輸送費) x25%

IBL=264,500千円x25%=66,125千円=1,945,000LE

OBL=9,500千円x25%=2,375千円=69,900LE

*2 : 現地工事費x6%=6,560,000LEx0.06=393,600LE

*3 : 現地工事費x25%=6,560,000LEx0.25=1,640,000LE

*4 : 1 + 2 (Supervisor Feeを除く) x2.7%

IBL=7,142千円(210,000LE)+177,000LE=387,000LE

OBL=257千円(7,600LE)+30,500LE=38,100LE

Costs are Demarcated to Egyptian Side.

Unit Cost for Estimation of W.W.T. Demonstration Plant (Reference)

Factory Name: Mansoura Co. for Resins and Chemicals.

Design Case: Basic Design

1. Major Equipment

<u>Equipment Name</u>	<u>Unit Cost [x10³Yen]</u>	<u>Note</u>
(1) Acid water pumps	600	Material: SCS
(2) Clarifier Rake	10,000	1 set
(3) Sedimentation Tank rake	8,000	1 set
(4) Thickener Rake	6,000	1 set
(5) Dehydrator	6,000	3 sets
(6) Motor Control Center	13,500	
(7) Center Control Panel	3,000	1 set

2. Field Work

<u>Work Item</u>	<u>unit</u>	<u>unit Cost[LE]</u>	<u>Note</u>
(1) Site Preparation	[m ²]	8	
(2) Civil (Earth Work)	[m ³]	34	
(3) RC Work	[m ³]	1,500	Foundation, Water Basin
(3) Storage Tank	[ton]	3,430	Equalization Tank, Chemical tank Neutralization Tanks
(4) Structural Steel	[ton]	2,000	Pipe rack, Operating Stage
(5) Equipment Installation	[ton]	400	Pumps, Clarifier rakes, Dehydrator
(6) Piping	[ton]	3,970	Except valves
	[in-m]	30	Except valves
(7) Painting	[m ²]	50	
(8) Local Building	[m ²]	2,600	W.W.T Control Room
(9) Electrical	[cable-m]	3	

Running Cost-Mansoura Co., Resins and chemicals

1999.11.23

T.Yasukawa

* Unit cost is not fixed yet

Items	Treating Capacity (m ³ /h)	Feeding Ratio (mg/L)	Consump. (kg/h)	Unit Cost (LE/kg)	Cost-1 (LE/h)	Cost-2 (LE/day)	Cost-3 (LE/year)	Unit Cost (LE/m ³)	Remarks
1 Chemical Cost									
1) Alum (Al ₂ (SO ₄) ₂ · 18H ₂ O)	30	30	0.9	0.3	0.27	6	2,138	0.009	
* 2) Lime (Ca(OH) ₂)	30	20	0.6	0.1	0.06	1	475	0.002	
3) Polymer-A (Anionic or Cationic)	30	0.3	0.01	27	0.24	6	1,925	0.008	
4) Polymer-B (Anionic or Cationic)	11 kg/h	1%	0.11	27	2.97	71	23,522	—	
5) CO(NH ₂) ₂	30	110	3.3	0.6	1.98	48	15,682	0.066	
* 6) H ₃ PO ₄	30	30	0.9	0.6	0.54	13	4,277	0.018	
7) NaOCl	30	4	0.9	0.385	0.35	8	2,744	0.012	
Sub-Total	—	—	—	—	6.41	154	50,763	0.214	
2 Filter Media									
* 1) Anthracite (3 Sets)	Loading 4.2 m ³	Loss 20 %/year	Loss/h 0.2	1	0.20	5	1,584	0.007	
* 2) Sand (3 Sets)	1.8 m ³	10 %/year	0.1	0.3	0.03	1	238	0.001	
* 3) Activated Carbon (1 Set)	5.0 m ³	14 days	7.4	14.7	108.78	2,611	861,538	3.626	
Sub-Total	—	—	—	—	109.01	2,616	863,359	3.634	
3 Power Consumption									
			kWh/d	LE/kWh					
			1,244	0.12	6.22	149.23	49,248	0.207	
			m ³ /day	m ³					
4 Industrial Water or Potable Water									
			5	0.528	0.11	2.64	871	0.004	
			Person/d	LE/P/year					
5 Operator	1 Person*3 Shift+1P		4	10,000	5.05	121.21	40,000	0.168	
6 Maintenance Fee	8,984,706								
(Plant Cost * 3 %/year)									
305,480,000/34=8,984,706 LE									
Total Operation Cost	—	—	—	—	160.83	3,859.95	1,273,782	5.36	

Power Consumption

Tag No.	kW	Operation	Consump.
PU-01	3.7	24	88.80
PU-02	2.2	24	52.80
PU-03	3.7	24	88.80
PU-04	5.5	0.5	2.75
PU-05	1.5	24	36.00
PU-06	2.2	24	52.80
PU-07	1.5	24	36.00
PU-08	1.5	8	12.00
PU-09	0.4	24	9.60
PU-10	0.4	24	9.60
PU-11	0.4	24	9.60
PU-12	0.4	24	9.60
PU-13	0.4	24	9.60
PU-14	0.4	24	9.60
PU-15	0.4	24	9.60
PU-16	2.2	24	52.80
B-01	37	24	888.00
MZ-01	9	8	72.00
MX-01	0.4	24	9.60
MX-02	2.2	24	52.80
MX-03	0.4	24	9.60
MX-04	0.75	24	18.00
MX-05	0.4	24	9.60
MX-06	0.2	0.2	0.04
MX-07	0.2	24	4.80
MX-08	0.1	0.2	0.02
MX-09	0.1	0.2	0.02
MX-10	0.4	0.2	0.08
MX-11	0.1	0.2	0.02
Total	—	—	1,554.53 kWh/d

Client: JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

Project Name: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL
IN THE ARAB REPUBLIC OF EGYPT

Factory Name: MANSOURA CO. FOR RESINS AND CHEMICALS

BASIC DESIGN

Document Title:

CALCULATION SHEET

FOR

W.W.T. RECOMMENDABLE PLANT

Issued Date

September 2000

Consultant:

JICA STUDY TEAM

CHIYODA DAMES AND MOORE CO.

CHIYODA CORPORATION

1. Object

This design calculation sheet is applied to the study of W.W.T. Recommendation Plant planning for 「Mansoura Co. for Resins and Chemicals」.

2. Wastewater to be treated

(1) Process Waste Water except Formalin Plant Regeneration Waste and Novolak Resin Solid Resin of Phenol Formaldehyde

The Formalin Plant regeneration Waste and Novolak Resin Solid Resin of Phenol Formaldehyde shall be treated by boiler or incinerator.

(2) Sanitary Waste Water

3. Design Conditions

(1) Waste management system in the Factory should be organized, and operated adequately under the responsible managers.

(2) Suitable routine works, periodical maintenances should be conducted in the whole company.

4. Contents of Wastewater Treating Facility

(1) Pre-treatment : Equalization Tank

(2) Primary Treatment : Chemical Clarifier

(3) Secondary Treatment : Activated Sludge Treatment including Sludge treatment

(4) Advanced Treatment : Sand Filter and Activated Carbon Filter

5. Design Basis

5.1 Quality and Quantity of Influent Wastewater

Shown on Table-1.

5.2 Quality and Quantity of Treated Water

The Law 48/82 Non potable Surface Water (Industrial) is to Basic Design.

Treated water qualities are shown on Table-1.

Table- 1 Design Basis of Wastewater Quality and Quantity

Items	Raw Water	Treated Water	Law48/82
Flow Rate [m ³ /h]	20 ~40	30	—
pH [-]	6 ~7	6 ~9	6 ~9
SS [mg/L]	100	< 1	< 50
BOD [mg/L]	1,300	< 20	< 60
COD [mg/L]	2,400	< 30	< 100
Oil&Grease [mg/L]	20	< 1	< 10
Phenol [mg/L]	460	< 0.005	< 0.005
TDS [mg/L]	700	< 750	< 2,000
Water Temp. [°C]	35 ~40	30 ~32	< 35

6. Unit Design

6.1 Wastewater Collection (Out of Battery)

The waste water of end of pipe is pumped to Equalization Tank.

6.1.1 Waste Water Pit (Z-01)

(1) Design Condition

- 1) Flow Rate(Q) : $700 \text{ m}^3/\text{d} = 29.2 \text{ m}^3/\text{h}$
Take : $30 \text{ m}^3/\text{h} = 0.50 \text{ m}^3/\text{min}$
- 2) Retention Time : 30 min.
- 3) Specification : Rectangular, RC(Semi-Underground), 1 set

(2) Sizing

- 1) Required Volume : 15 m^3
- 2) Effective Height : 1 m (take)
- 3) Required Area : $A_c = Q/Ah = 15 \text{ m}^2$
Take : $4,000^W \times 4,000^L \times 2,000^H \times 1 \text{ Set}$

6.1.2 Raw water Pump (PU-01A/B/C)

The Raw Water pumps (PU-01A/B/C) are normally operated with one operation/two standby basis.

If water level in Waste water pit (Z-01) increase to high-high level point (LC-01), the one of two standby pump is automatically started by the level switch, LC-01.

If water level in Waste water pit (Z-01) decrease to high level point (LC-01), the one of two running pumps is automatically stopped by the level switch, (LC-01).

- 1) Capacity Allowance : 5% Design Flow Rate : $31.5 \text{ m}^3/\text{h}$
- 2) Required Total Head : 20 m (take)
- 3) Efficiency of pump : 0.7
- 4) Motor Allowance : 0.9
- 5) Motor Power : 2.72 kW

Take : $31.5 \text{ m}^3/\text{h} \times 0.2 \text{ Mpa} \times 3.7 \text{ kW} \times 3 \text{ Sets}$

6.2 Equalization Tank

Waste water from end of pipe is stored in the Equalization Tank (TK-01) for equalization of waste water quantity and quality for further treatment.

6.2.1. Equalization Tank (T-01)

(1) Design Conditions

- 1) Quality of Wastewater: Shown on Table-2
- 2) Retention Time : 4 h
- 3) Specification : Vertical cylindrical, 1 set
- 4) Others : Air bubbling device

Table-2 Quantity and Quality of Wastewater

Items	Raw Water		Equalized W.
Flow Rate [m ³ /h]	20 ~40		30
pH [-]	6 ~7		6 ~7
SS [mg/L]	100		100
BOD [mg/L]	1,300		1,300
COD [mg/L]	2,400		2,400
Oil&Grease [mg/L]	20		20
Phenol [mg/L]	460		460
TDS [mg/L]	700		700
Water Temp. [°C]	35 ~40		35 ~40

(2) Sizing

- 1) Required Volume : 120 m³
- 2) Effective Height : 5 m (take)
- 3) Required Area : $Ac = Q/Ah = 24 \text{ m}^2$ Diameter = 5.53
 Take : $5.811^\phi \times 6.105^H$ (Chiyada Standard Tank)
- 4) Air Bubbling Device
 - a) Required Air (design base) : 3 Nm³/m²/h
 - b) Required Air Quantity : 72 Nm³/h = 1.2 Nm³/min (take)

6.2.2 Coagulation Tank Feed Pump (PU-02A/B)

Two pumps are provided as Coagulation Tank Feed Pumps (PU-2A/B).

One pump is normally in operation and the other pump is standby.

- 1) Capacity Allowance : 5% Design Flow Rate : 31.5 m³/h
- 2) Required Total Head : 12 m (take)
- 3) Efficiency of pump : 0.7
- 4) Motor Allowance : 0.9
- 5) Motor Power : 1.63 kW

Take : 31.5 m³/h x 0.2 Mpa x 2.2 kW x 2 Sets

6.3 Chemical Clarifier

(1) Purpose

The function of Chemical Clarifier is to reduce Suspended Solid (SS), free oil and color of the wastewater.

(2) Design Conditions

- 1) Wastewater : W.W. after equalized in T-01.
- 2) Capacity : 30 m³/h
- 3) Quality of In & outlet of Clarifier: Shown on Table-3.
- 4) Chemicals :
 - a) Coagulant= Al₂(SO₄)₃
 - b) pH Controller=Ca(OH)₂
 - c) Coagulant Aid=Polymer

Table-3 Quantity and Quality of Wastewater

Items	Equalized W.	Clarified W.
Flow Rate [m ³ /h]	30	30
pH [-]	6 ~ 7	7 ~ 8
SS [mg/L]	100	20
BOD [mg/L]	1,300	1,000
COD [mg/L]	2,400	2,200
Oil&Grease [mg/L]	20	5
Phenol [mg/L]	460	460
TDS [mg/L]	700	750
Water Temp. [°C]	35 ~ 40	35 ~ 40

(3) Sizing

1) Coagulation Tank (T-02)

- a) Rapid Mixing Time : 5 min (take)
- b) Required Volume : V= 2.5 m³
- c) Specification : Vertical Cylindrical, Carbon Steel with Epoxy Coating
- d) Number of Required : 1 set
- e) Demension : H= 1.6 m (take) Req'd Area= 1.56 m²
D= 1.41 m

Take : 1,430^φ × 2,000^H × 1 Set

2) Flocculation Tank (T-03)


- a) Slow Mixing Time : 30 min (take)
- b) Required Volume : V= 15 m³
- c) Specification : Vertical Cylindrical, Carbon Steel with Epoxy Coating
- d) Number of Required : 1 set
- Demension : H= 2.5 m (take) Req'd Area = 6 m²
D= 2.76 m

Take : 2,860^φ × 3,000^H × 1 Set

3) Sedimentation Tank

- a) Surface Load : Ls= 3 m³/m²/h (take)
- b) Required Area : As= 10 m²
- c) Specification : Vertical Cylindrical, Carbon Steel with Epoxy Coating
- d) Number of Required : 1 set

- e) Retention Time : $T_s = \boxed{1}$ h (take) = $\boxed{60}$ min
 f) Demension : $H = \boxed{3}$ m (take)
 $D = \boxed{3.6}$ m
 Take : $4,000^\phi \times 4,500^H \times 2$ Sets



4) Generated Sludge

- a) SS Removal : $\boxed{2.4}$ kg/h = $\boxed{57.6}$ kg/d
 b) Concentration of SS: 1 % (take)
 c) Sludge Draw-off : $Q = 240$ kg/h \div 0.24 m³/h
 d) Dewatered Sludge : $W = 16$ kg/h = 0.384 Ton/day

5) Coagulant $Al_2(SO_4)_3 \cdot 18H_2O$ Injection Unit

- a) Dosing Ratio : $\boxed{30}$ mg/L, Max. $\boxed{50}$ mg/L
 b) Concentration : $\boxed{20}$ wt % = $\boxed{222.4}$ g/L
 c) Specific Gravity : 1.112
 d) Injection Rate : $Q_{p0} = \boxed{4.0}$ L/h = $\boxed{0.07}$ L/min
 e) Tank Volume : $V_{p0} = \boxed{0.7}$ m³ (for 7days)
 f) Height : $H_{p0} = \boxed{1.0}$ m (take) $A_{p0} = \boxed{0.68}$ m²
 g) Diameter : $D_{p0} = \boxed{0.9}$ m

Take: $1,000^\phi \times 1,300^H \times 2$ Sets

6) pH Controller : $Ca(OH)_2$ Injection Unit

- a) Dosing Ratio : $\boxed{20}$ mg/L, Max. $\boxed{50}$ mg/L
 b) Concentration : $\boxed{10}$ wt % = $\boxed{100}$ g/L
 c) Specific Gravity : 1
 d) Injection Rate : $Q_{p0} = \boxed{6.0}$ L/h = $\boxed{0.10}$ L/min
 e) Tank Volume : $V_{p0} = \boxed{1.0}$ m³ (for 7days)
 f) Height : $H_{p0} = \boxed{1.2}$ m (take) $A_{p0} = \boxed{0.84}$ m²
 g) Diameter : $D_{p0} = \boxed{1.0}$ m

Take: $1,000^\phi \times 1,300^H \times 2$ Sets

7) Coagulant Aid: Polymer Injection Unit

- a) Dosing Ratio : $\boxed{0.3}$ mg/L, Max. $\boxed{0.5}$ mg/L
 b) Concentration : $\boxed{0.5}$ wt % = $\boxed{5}$ g/L
 c) Specific Gravity : 1
 d) Injection Rate : $Q_{p0} = \boxed{1.8}$ L/h = $\boxed{0.03}$ L/min
 e) Tank Volume : $V_{p0} = \boxed{0.3}$ m³ (for 7days)
 f) Height : $H_{p0} = \boxed{0.6}$ m (take) $A_{p0} = \boxed{0.50}$ m²
 g) Diameter : $D_{p0} = \boxed{0.8}$ m

Take: $800^\phi \times 1,000^H \times 2$ Sets

6.4 Biological Treating Unit (Activated Sludge Treatment)

(1) Purpose

To remove Organic Substances (BOD, COD, Phenol etc.) by aerobic micro bacteria.

(2) Design Conditions

- 1) Wastewater : Treated water from Chemical Clarifier
- 2) Treating Method : Activated Sludge Treatment
- 3) Capacity : $30 \text{ m}^3/\text{h}$
- 4) Water Quality : Shown on table-4

Table-4 Water Quality

Items	Clarified W.		Clarified W.
Flow Rate [m^3/h]	30		30
pH [-]	7 ~ 8		6 ~ 7
SS [mg/L]	20		20
BOD [mg/L]	1,000		50
COD [mg/L]	2,200		100
Oil&Grease [mg/L]	5		3
Phenol [mg/L]	460		0.5
TDS [mg/L]	750		750
Water Temp. [$^{\circ}\text{C}$]	35 ~ 40		32 ~ 35

- 5) Specification :
 - a) Aeration Basin : Rectangular/Above ground, RC, 1 set
 - b) Clarifier : Circular/Above ground, CS+Epoxy coating, 1 set

6) Chemicals

N and P are injected in case of lack of nutrient.

(3) Sizing

1) Aeration Basin

- a) BOD Loading : $0.5 \text{ kg-BOD}/\text{m}^3/\text{day}$ (take)
- b) Volume of Basin : $V_{as} = 1368 \text{ m}^3$
- c) Height of Basin : $H_{as} = 5 \text{ m}$ (take) $A_{as} = 273.6 \text{ m}^2$
 $W = 14 \text{ m}$ (take) $L = 19.54 \text{ m}$

Take : $14,000^W \times 20,000^L \times 5,800^H \times 1 \text{ Set}$

- d) BOD Removal : $R_{BOD} = 684 \text{ kg/day}$
- e) MLSS : $C_a = 2,000 \text{ mg/L}$

2) Clarifier

- a) Surface Loading : $L_{as} = 1 \text{ m}^3/\text{m}^2/\text{h}$ (take) = $24 \text{ m}^3/\text{m}^2/\text{day}$
- b) Surface Area : $A_{ss} = 30 \text{ m}^2$
- c) Height of Basin : $H_{ss} = 3 \text{ m}$ (take)
- d) Volume of Basin : $V_{ss} = 90 \text{ m}^3$
- e) Retention Time : $T_{ss} = 3 \text{ h}$
- f) Sludge Concentrati.: $C_R = 10,000 \text{ mg/L}$
- g) Diameter : $D_{ss} = 6.18 \text{ m}$

Take: $7,000^{\phi} \times 4,000^H \times 1 \text{ Set}$

3) Surplus Sludge

- a) BOD→SS Conversion Rate : 0.3 (take)
 b) Sludge from Act. Sludge T.: $W_{s1} = 8.55$ kg/h from BOD
 c) Sludge from Chemical Clar.: $W_{s2} = 2.40$ kg/h from SS
 d) Total Generated Sludge : $W_{TS} = 10.95$ kg/h = 262.8 kg/day
 f) Generated 85 % Water Cont. : $W_{85} = 73$ kg/h = 1,752 kg/day
 g) Centrifuge Feed Flow : $Q = 1.5$ m³/h

4) Air Requirement for Aeration

- a) Oxygen Demand : $W_{O_2} = a \cdot R_{BOD} + b \cdot S_a = 519.84$ kg/day
 $a = \text{BOD Factor} = 0.55$ kg-O₂/kg-O₂
 $b = \text{MLVSS Factor} = 0.07$
 $S_a = 0.75 \cdot \text{MLSS} \cdot \text{Vol. of Basin} / 1,000 = 2,052$
 $R_{BOD} = \text{BOD Removal} = 684$ kg/day kg

b) Required Air : $Q_{air} = (W_{O_2} \cdot 3.57 \text{ m}^3 / \text{kg-O}_2 \cdot 1.2) / (0.08 \cdot 24 \cdot 60)$
 $= 19.33$ Nm³/min

c) Blower capacity : $Q_{ta} = 24.638$ Nm³/min
 Take: 25 Nm³/min x 6 mH x 37 kW

5) Return Sludge Ratio : $R_s = C_a / (C_r - C_a)$
 $= 25 \%$

6) Nutrient as N : CO(NH₂)₂ Injection Unit

- a) Dosing Ratio : BOD : N = 100 : 5
 BOD : CO(NH₂)₂ = 100 : 11

b) Concentration : 25 wt %

c) Specific Gravity : 1.069

d) Injection Rate : $Q_{CO} = 12.3$ L/h

e) Tank Volume : $V_{CO} = 2.1$ m³ (7days)

f) Height : $H_{p0} = 1.8$ m (take) $A_{p0} = 1.15$ m²

g) Diameter : $D_{p0} = 1.2$ m

Take: 1,200^φ × 1,800^H × 2 Sets

7) Nutrient as P : H₃PO₄ Injection Unit

- a) Dosing Ratio : BOD : P = 100 : 1
 BOD : H₃PO₄ = 100 : 3

b) Concentration : 25 wt %

c) Specific Gravity : 1.189

d) Injection Rate : $Q_{ph} = 3.0$ L/h

e) Tank Volume : $V_{ph} = 0.5$ m³ (7days)

f) Height : $H_{p0} = 0.9$ m (take) $A_{p0} = 0.57$ m²

g) Diameter : $D_{p0} = 0.8$ m

Take: 800^φ × 1,000^H × 2 Sets

8) Polymer-B

- a) Dosing Ratio : 1 % as dry SS
- b) Concentration : 0.5 wt %
- c) Specific Gravity : 1
- d) Injection Rate : $Q_{ph} = 0.13$ L/h
- e) Tank Volume : $V_{ph} = 0.02$ m³ (7days)
- f) Height : $H_{po} = 0.5$ m (take) $A_{po} = 0.04$ m²
- g) Diameter : $D_{po} = 0.2$ m

Take: $800^\phi \times 1,000^H \times 1$ Set

9) Sludge Thickener

- a) Solids Loading $L_{ss} = 60$ kg/m²/d
- b) Total Solids $L_{to} = 262.8$ kg/d
- c) Required Area $A_{th} = 4.38$ m²
- d) Diameter $D_{po} = 2.36$ m

Take: $2,400^\phi \times 4,000^H \times 1$ Set

6.5 Sand Filter Unit

(1) Purpose

To remove overflow floc(SS) from Activated Sludge Treatment

(2) Design Conditions

- 1) Wastewater : Treated Water from Biological Treatment Unit
- 2) Capacity : 30 m³/h
- 3) Water Quality : Show on Table-5

Table-5 Water Quality

Items	Biological T.	Filtered W.
Flow Rate [m ³ /h]	30	30
pH [-]	7 ~ 8	6 ~ 7
SS [mg/L]	20	5
BOD [mg/L]	1,000	30
COD [mg/L]	2,200	80
Oil&Grease [mg/L]	5	2
Phenol [mg/L]	0.5	0.5
TDS [mg/L]	750	750
Water Temp. [°C]	35 ~ 40	32 ~ 35

- 4) Specification : Vertical Cylindrical, Carbon Steel with Epoxy Coating, Pressure Type
- 5) No. of Filter : 3 Sets (2 Operatio + 1 Stand-by)
- 6) Filter Media : Anthracite + Sand/Gravel
- 7) Backwashing : Water (Pump)

(3) Sizing

1) Filter

- a) Filter Velocity : $V_f = 180 \text{ m/day} = 7.5 \text{ m/h (take)}$
 b) Filter Area/Diameter $A_f = 2 \text{ m}^2$ $D_f = 1.6 \text{ m}$
 c) Height : $H_f =$
- | | |
|---------------------|------------|
| Upper of Trough | 0.5 m |
| Trough | 0.3 m |
| Trough-Anthracite | 0.7 m |
| Anthracite | 0.7 m |
| Sand+Gravel | 0.8 m |
| Support+Under | 0.7 m |
| Allowance | 0.3 m |
| Total Height | 4 m |

Take: $1,600^\phi \times 4,000^H \times 3 \text{ Sets}$

2) Filtered Water Pond & Waste Water Pond

- a) Volume of Pond : $V_{fb} = 60 \text{ min (take)}$ 30 m^3
 b) Depth of Pit : $H_{fb} = 2.5 \text{ m (take)}$ Surface Area 12 m^2
 $W = 3 \text{ m}$ $L = 4.00 \text{ m}$

Take: $3,000^W \times 4,000^L \times 3,000^H$

3) Backwashing Pump

- a) Backwash Velocity : $U_{bw} = 40 \text{ m/h (take)}$
 b) Backwash Flow rate : $Q_{bw} = 80 \text{ m}^3/\text{h}$
 c) Backwashing Time : $T_{bw} = 10 \text{ min (take)}$
 d) Backwashing Water : $V_{bw} = 13.33 \text{ m}^3/\text{h/Cycle}$
 e) Backwash Pump : $Q_p = 88 \text{ m}^3/\text{h}$ $H_p = 12 \text{ mH (take)}$
 $P = 4.10 \text{ kW}$ 5.5 kW

Take : $88 \text{ m}^3/\text{h} \times 0.12 \text{ Mpa} \times 5.5 \text{ kW} \times 2 \text{ Sets}$

6.5 Activated Carbon Filter Unit

(1) Purpose

To remove dissolved organic substances (BOD,COD,Phenol etc.) by adsorption.

(2) Design Conditions

- 1) Wastewater : Treated Water from Filter Unit
 2) Capacity : $30 \text{ m}^3/\text{h}$
 3) Water Quality : Show on Table-6

Table-6 Water Quality

Items	Filtered W.	Treated Water
Flow Rate [m^3/h]	30	30
pH [-]	6 ~ 7	6 ~ 9
SS [mg/L]	5	1
BOD [mg/L]	30	20
COD [mg/L]	80	30
Oil&Grease [mg/L]	2	1
Phenol [mg/L]	0.5	0.005
TDS [mg/L]	750	750
Water Temp. [$^\circ\text{C}$]	32 ~ 35	32 ~ 35

- 4) specification : Vertical Cylindrical, Carbon Steel with Epoxy Coating, Pressure Type
 5) No. of Filter : 2 Sets (1 Operatio + 1 Stand-by)
 6) Filter Media : Activated Carbon
 7) Backwashing : Water (Pump)

(3) Sizing

1) A/C Filter

a) Filter Velocity : $V_f = \frac{360}{24} \text{ m/day} = 15 \text{ m/h (take)}$

b) Filter Area/Diameter : $A_f = 2 \text{ m}^2$ $D_f = 1.6 \text{ m}$

c) Retention Time : $T_a = 10 \text{ min.}$

d) A/C Volume : $V_a = 5 \text{ m}^3$

Height	Hf=	Upper of Trough	0.4 m
<Linear part>		Trough-A/C	0.8 m
		Activated Carbon	2.5
		Support+Under	0.5 m
		Allowance	0.3 m
		Total Height	4.5 m

Take: $1,600^\phi \times 4,500^H \times 2 \text{ Sets}$

6.6 Sterilization

(1) Purpose

To sterilize treated water including sanitary wastewater

(2) Design Condition

a) Wastewater : Filtered water

b) Disinfectant : NaClO Conc 12 wt\% Sp. Gra 1.0155

c) Dosage : $4 \text{ mg/L (Max. 6mg/L)}$

d) Contact Time : 15 min

(3) Sizing

a) Injection Rate : $Q = 1 \text{ L/h}$

b) Req'd Drum Volume : $V = 0.2 \text{ m}^3 \text{ (for 7days)}$

c) Tank Dimension : Take: $800^\phi \times 1,000^H \times 1 \text{ Set}$

d) Sterilization Pond : 7.5 m^3

e) Pond Dimension : $H = 2 \text{ m (take)}$ $A = 3.75 \text{ m}^2$

$W = 3 \text{ m (take)}$ $LA = 1.25$

Take: $3,000^W \times 1,250^L \times 3,000^H$