

Caso 1 Base Case

Acid Wash Water for Solids Hydraulics	
Q(m ³ /h)	Hydraulics
150	170
H ₂ SO ₄ (kg/m ³)	2.5
FeSO ₄ (kg/m ³)	3.5

Waste Acid	
Q(m ³ /h)	
1.67	
H ₂ SO ₄ (kg/m ³)	120
FeSO ₄ (kg/m ³)	180

H ₂ SO ₄ loading (kg/h)	575
FeSO ₄ loading (kg/h)	825

Solids Production Unit
 1st stage gypsum
 [H₂SO₄ loading] * 1.755 - [2.0 kg/m³*Qm³/h]
 2nd stage Fe(OH)₃
 [FeSO₄ loading] * 0.704
 2nd stage gypsum
 [FeSO₄ loading] * 1.133
 2nd stage others
 [0.1 kg/m³ * Q m³/h]

Lime Requirement as CaO
 1st stage
 [H₂SO₄ loading] * 0.572
 2nd stage
 [FeSO₄ loading] * 0.369

Solids Production	
1st stage gypsum	706 kg/h
2nd stage Fe(OH) ₃	580 kg/h

2nd stage gypsum
935 kg/h

2nd stage others
15 kg/h

2nd stage total	1,530 kg/h
-----------------	------------


Lime Requirement as CaO	
1st stage	329 kg/h
2nd stage	305 kg/h

1st + 2nd total	2,236 kg/h
53,866 kg/D	


Lime Solution: 10% as Ca(OH) ₂ = 7.57% as CaO	
1st + 2nd total	633 kg/h
15,201 kg/D	

3,690 kg/1000m³-wastewater


	Molecular weight
H ₂ SO ₄	98.1
CaSO ₄ ·2H ₂ O	172.2
FeSO ₄	151.9
Fe ₂ (SO ₄) ₃	399.9
Fe(OH) ₃	106.9
CaO	56.1
Ca(OH) ₂	74.1



CHEMICAL REACTION and WATER BALANCE



Case 2 H₂SO₄ in Wastewater 1.2%



Acid Wash Water for Solids Hydraulics	
Q(m ³ /h)	150
H ₂ SO ₄ (kg/m ³)	12
Fe ₂ (SO ₄) ₃ (kg/m ³)	3.5

Waste Acid	
Q(m ³ /h)	1.67
H ₂ SO ₄ (kg/m ³)	120
Fe ₂ (SO ₄) ₃ (kg/m ³)	180

H ₂ SO ₄ loading (kg/h)	2000
Fe ₂ (SO ₄) ₃ loading (kg/h)	825

Solids Production Unit
 1st stage gypsum [H₂SO₄ loading] * 1.755 - [2.0 kg/m³ * Q m³/h]
 2nd stage Fe(OH)₃ [Fe₂(SO₄)₃ loading] * 0.704
 2nd stage gypsum [Fe₂(SO₄)₃ loading] * 1.133
 2nd stage others [0.1 kg/m³ * Q m³/h]

Lime Requirement as CaO
 1st stage [H₂SO₄ loading] * 0.572
 2nd stage [Fe₂(SO₄)₃ loading] * 0.369

Solids Production	
1st stage gypsum	3,207 kg/h
2nd stage Fe(OH) ₃	580 kg/h
2nd stage gypsum	935 kg/h
2nd stage others	15 kg/h
2nd stage total	1,530 kg/h


1st + 2nd total	4,737 kg/h
CaSO ₄ ·2H ₂ O	113,687 kg/D

Lime Solution: 10% as Ca(OH) ₂	
1st stage	1,144 kg/h

1st + 2nd total	1,448 kg/h
2nd stage	305 kg/h


Molecular weight	
H ₂ SO ₄	98.1
CaSO ₄ ·2H ₂ O	172.2
Fe ₂ (SO ₄) ₃	399.9
Fe(OH) ₃	106.9
CaO	56.1
Ca(OH) ₂	74.1

CHEMICAL REACTION and WATER BALANCE




8,436 kg/1000m³-wastewater

Case 3 Wash Water Only



CHEMICAL REACTION and WATER BALANCE



	Molecular weight
H ₂ SO ₄	98.1
CaSO ₄ ·2H ₂ O	172.2
FeSO ₄	151.9
Fe ₂ (SO ₄) ₃	399.9
Fe(OH) ₃	106.9
CaO	56.1
Ca(OH) ₂	74.1

1st + 2nd total	1,337 kg/h
CaSO ₄ ·2H ₂ O	32,095 kg/D

Lime Solution:	
10% as Ca(OH) ₂	
= 7.57% as CaO	

1st + 2nd total	408 kg/h
9790.12 kg/D	
2,402 kg/1000m ³ -wastewater	

Solids Production	
1st stage gypsum	350 kg/h
2nd stage Fe(OH) ₃	369 kg/h
2nd stage gypsum	595 kg/h
2nd stage others	15 kg/h
2nd stage total	979 kg/h

Lime Requirement as CaO	
1st stage	214 kg/h
2nd stage	194 kg/h

Client: JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
Project Name: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL
IN THE ARAB REPUBLIC OF EGYPT


Factory Name: EGYPTIAN IRON AND STEEL CO.

BASIC DESIGN
(ORIGINAL)

Document Title: CALCULATION SHEET
FOR
W.W.T. DEMONSTRATION PLANT


Issued Date September 2000

Consultant: JICA STUDY TEAM
CHIYODA DAMES AND MOORE CO.
CHIYODA CORPORATION



CHEMICAL REACTION and WATER BALANCE

Dec. 15, 1999
H. Toyohara



Molecular weight	
H ₂ SO ₄	98.1
CaSO ₄ · 2H ₂ O	172.2
FeSO ₄	151.9
Fe ₂ (SO ₄) ₃	399.9
Fe(OH) ₃	106.9
CaO	56.1
Ca(OH) ₂	74.1

1st + 2nd total
 2,236 kg/h
 53,666 kg/D

Lime Solution:
 10% as Ca(OH)₂
 = 7.57% as CaO

1st + 2nd total
 633 kg/h
 15201 kg/D

2nd stage total
 1,530 kg/h

Lime Requirement as CaO
 1st stage lime
 329 kg/h

2nd stage lime
 305 kg/h

Solids Production Unit
 1st stage gypsum
 $[\text{H}_2\text{SO}_4 \text{ loading}] * 1.755 - [2.0 \text{ kg/m}^3 * \text{Qm}^3/\text{h}]$
 2nd stage Fe(OH)₃
 $[\text{FeSO}_4 \text{ loading}] * 0.704$
 2nd stage gypsum
 $[\text{FeSO}_4 \text{ loading}] * 1.133$
 2nd stage others
 $[0.1 \text{ kg/m}^3 * \text{Q m}^3/\text{h}]$

Lime Requirement
 1st stage
 $[\text{H}_2\text{SO}_4 \text{ loading}] * 0.572$
 2nd stage
 $[\text{FeSO}_4 \text{ loading}] * 0.369$

Solids Production
 1st stage gypsum
 706 kg/h
 2nd stage Fe(OH)₃
 580 kg/h
 2nd stage gypsum
 935 kg/h
 2nd stage others
 15 kg/h

Sludge Production and Water Balance

For Solids calculation, 150 m³/h flow rate is applied.

1. Design Basis

Inlet wastewater			
Q	m ³ /h	150	
	m ³ /D	3600	
H ₂ SO ₄	%	0.25	estimated
FeSO ₄	%	0.35	

EISC said on Dec. 07	
H ₂ SO ₄	1.2 %
FeSO ₄	2.3 %
EISC said on Nov. 18	
H ₂ SO ₄	1.2 %
FeSO ₄	1.5 %
TIMS Analysis Nov. 17	
H ₂ SO ₄	0.24 %
FeSO ₄	0.2 %

Waste Acid		
Q	m ³ /d	40
H ₂ SO ₄	%	12
FeSO ₄	%	18

EISC said on Nov. 18, Dec. 07	
H ₂ SO ₄	10-12 %
FeSO ₄	16-18 %


MW	
H ₂ SO ₄	98.1
CaSO ₄ ·2H ₂ O	172.2
FeSO ₄	151.9
Fe ₂ (SO ₄) ₃	399.9
Fe(OH) ₃	106.9
CaO	56.1
Ca(OH) ₂	74.1

TIMS Analysis Nov. 17	
H ₂ SO ₄	17 %
FeSO ₄	16 %

WWT Inlet				
Q	m ³ /h	151.67		
H ₂ SO ₄	%	0.379	kg/m ³	3.791209
FeSO ₄	%	0.544	kg/m ³	5.43956

2. Sludge Production


1st Stage Gypsum Production



		(Wash)	(Acid)	
H ₂ SO ₄ to be treated	kg/h	575	375	200
	kg/D	13,800	9000	4800
CaSO ₄ ·2H ₂ O	kg/h	1,009	← Total Production (Solids + Dissolved)	
	kg/D	24,225		
Concentration in WW	kg/m ³	6.66		
Saturated concentration	kg/m ³	2.00	← To be discharged in wastewater	
Gypsum to be sedimented	kg/m ³	4.66		
	kg/h	706	← To be dehydrated in Centrifuge	
	kg/D	16,759		

2nd stage Sludge

FeSO₄



		(Wash)	(Acid)	
FeSO ₄ to be oxidized	kg/h	825	525	300

19,800 12600 7200

Fe to be treated	kg/h	303	
	kg/D	7,279	
Fe(OH) ₃ to be generated	kg/h	580	
	kg/D	13,929	
2nd stage gypsum			
Gypsum from FeSO ₄			
SO ₄ in FeSO ₄	kg/h	522	
CaSO ₄ ·2H ₂ O	kg/h	935	
Other Solids			
	kg/h	15.17	
	kg/D	364	
	kg/m ³	0.1	
1st Lime Injection			
H ₂ SO ₄ to be treated	kg/h	575	
Lime amount Ca(OH) ₂	kg/h	434.4	0.571787
Lime amount CaO	kg/h	328.8	0.571787
Lime Milk Conc.	%	10.0	7.568622
Lime Milk Flow Rate	m ³ /h	4.3	
2nd Lime Injection			
SO ₄ to be treated in 2nd stage	kg/h	522	0.369165
Required lime Ca(OH) ₂	kg/h	402	0.369165
Lime Amount CaO	kg/h	305	
Lime Milk Conc.	%	10.0	
Lime Milk Flow Rate	m ³ /h	4.0	
Total lime consumption			
CaO	kg/h	633.3	
	kg/D	15,200	
Ca(OH) ₂	kg/h	836.8	
	kg/D	20,083	
Lime Milk Flow rate Total	m ³ /h	8.4	

	kg/h	kg/D
1st stage Gypsum production	706	16,945

2nd stage Gypsum production	935.05	22,441	61.1
2nd stage Fe(OH) ₃	580.39	13,929	37.9
2nd stage others	15.17	364 @as 100 ppm	1.0
2nd stage total	1,531	36,735	100.0
TOTAL solids	2,236.67	53,680	

1st Dehydrator			
Solids to be treated	kg/h	706 for Balance Calc.	
Operation	h/D	12	
No. of Equipment in operation		1	
Concentration to be fed	%	5	
Capacity	m ³ /h	28.24 for Equipment Calc.	

2nd Dehydrator

Solids to be treated	kg/h	1,531
Operation	h/D	24
No. of Equipment in operation		1
Concentration to be fed	%	5
Capacity	m3/h	30.61

Water Balance (Case 3: 2 stage lime injection)

		Solids kg/m3	kg/h	Flow m3/h	H2SO4 kg/m3	FeSO4 kg/m3	
1	Washwater			170	2.5	3.5	
2	Waste Acid			1.67	120	180	
3	Wastewater			171.67	3.79	5.44	
	Backflow from WWT			65.32			
3	WWT In			171.67			
	Recycle from 1st Clarifier			6.06			
	Neutralization in			177.72			
	Lime in 1			4.34			
4	1st Settling Tank In			182.07			
	1st Settling Tank Overflow			161.89			
	1st Settling Tank Bottom	50	1,009	20.18			
	To Recycle	50	303	6.06			
	To 1st Centrifuge	50	706	14.12			30 % of gypsum generated from H2SO4 is recycled.
9	1st Centrifuge Sludge	600	706	1.18			24 hours operation Basis. 3 times flow rate for mech. Design
	1st Centrifuge Supernatant		(3.9)	12.94			
	Lime in 2			4.02			
	Recycle from 2nd Clarifier			15.31			
5	2nd Clarifier In			246.54			
6	2nd Clarifier Overflow			180.22			
	2nd Clarifier Bottom	30	1,990	66.33			
	To recycle	30	459	15.31			30 % of generated gypsum is recycled.
	To Thickener	30	1,531	51.02			
	Thickener Bottom/To Centrifuge	50	1,531	30.61			
	Thickener supernatant			20.41			
8	2nd Centrifuge sludge	200	1,531	7.65			
	2nd Centrifuge supernatant		(6.9)	22.96			
	Sand Filter In			180.22			
7	Sand Filter Out			171.20			
	Sand Filter Backwash			9.01			

Concrete Basins

		Z-01 Gypsum Pit	Z-02 Clarified Water Pi
Flow rate (Normal)	m ³ /h	14.12	161.89
HRT	h	4	0.5
Density	kg/m ³	1055	1055
Capacity	m ³	56.48498458	80.94468846
Diameter	m		
Length	m	5.0	5.0
Width	m	6.5	6.5
Height	m	2.2	3.1
Operating Level	m	1.7	2.5
Volume	m ³	72	101
Fluid Volume	m ³	56	81
Fluid Velocity	m/h	1.7	2.5
D/OL	—		
Number of Vessels	—	1	1
1m ³ 当りの重量(RC)	kg/m ³	2,200	2,200
1m ³ 当りの重量(Rubber)	kg/m ³	(1,000)	(1,000)
厚さ(RC)	mm	200	200
厚さ(Coat)	mm	4	4
安全係数	—	1.05	1.05
空時(1槽当り)	ton	38.7	48.4
運転時(1槽当り)	ton	98.3	133.8
厚さ	mm	—	—
面積	m ²	—	—
1槽当りの表面積			
・密閉式；屋根+側面+底			
・開放式；側面+底	m ²	83	104

Z-3 Treated Water Pit	Z-4 Wastewater Pit	Z-5 Sludge Pit
180.22	65.32	30.61
0.5	2	2
1055	1055	1055
90.10779396	130.6450272	61.22437

6.5	12.0	5.0
6.5	6.5	6.5
2.6	2.2	2.4
2.1	1.7	1.9
110	172	78
90	131	61
2.1	1.7	1.9
1	1	1

2,200	2,200	2,200
(1,000)	(1,000)	(1,000)
200	200	200
4	4	4
1.05	1.05	1.05
51.2	74.3	40.9
146.3	212.1	105.5

— — —

110	159	88
-----	-----	----

*****設計書*****														
● 顧客名 JICA / Egyptian Iron and Steel Co. ● 工事名 Industrial Pollution Contr. ● 設計日 1999/11/5 ● 設計者 K. Toyokura														
(注) 濃縮液 A (Basic Acid) 濃縮液 B (Basic Sherry) 濃縮液 C (Treated Basic Water) 濃縮液 D (Neutral Basic Water) 濃縮液 E (Neutral Basic Slurry) 濃縮液 F (Sulfide Slurry) 濃縮液 G (Sulfide Slurry) 濃縮液 H (Sulfide Slurry) 濃縮液 I (Sulfide Slurry) 濃縮液 J (Sulfide Slurry) 濃縮液 K (Sulfide Slurry)														
No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Tag No.	PU-01 A/B	PU-02 A/B	PU-03 A/B	PU-04 A/B	PU-05 A/B	PU-06 A/B	PU-07 A/B	PU-08 A/B	PU-09 A/B	PU-10 A/B	PU-11 A/B	PU-12 A/B	PU-13 A/B	PU-14 A/B
機器名	Wastewater Pump	No. 1 Sludge Pump	Gypsum Sludge Pump	Lime Pump	Coagulant Pump	Polymer A Pump	No. 2 Sludge Pump	No. 3 Sludge Pump	Filter Feed Pump	Backwash Pump	Wastewater return Pump	Treated Water Pump	Sludge Pump	Polymer B Pump
用途	RW Feed													
形式	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Diaphragm	Diaphragm	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal
設計条件	流体 *1)	WA	TWW	TWW	NahS	NahS	NahS	NahS	GS	GS	GS	GS	GS	NW
流量	m ³ /h	171.7	20.18	28.2	16.7	0.46	66.3	30.6	180.2	550.0	65.3	171.2	30.6	30.6
処理量	kg/h	171,666.7	21,186.5	29,634.6	17,656.4	462.9	69,642.7	32,142.8	180,215.6	550,000.0	65,322.5	171,204.8	30,612.2	30,612.2
濃度	%				22	22		50						
密度	kg/m ³	(1,000)	(1,050)	(1,050)	(1,055)	(1,000)	(1,050)	(1,050)	(1,000)	(1,000)	(1,000)	(1,000)	(1,000)	(1,000)
粘度	cP	(1.0)	(1.5)	(1.5)	(4.0)	—	(1.0)	—	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)
pH		(1)	(7)	(2)	(2)	—	(2)	—	(2)	(2)	(2)	(2)	(2)	(2)
運転温度	℃	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.
吸入圧力	m	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
吐出圧力	m	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	50.0	15.0	15.0
材質		SUS304	SUS304	SUS304	SUS304	SUS304	SUS304	CS	CS	CS	CS	CS	CS	SUS304
所要動力	KW	4.66	0.88	0.81	0.48	0.013	1.89	0.873	4.90	14.94	1.77	4.65	0.83	0.004
出力効率	%	50	50	50	50	50	50	50	50	50	50	50	50	50
所要軸動力	KW	9.3	1.74	1.6	1.0	0.03	3.8	1.75	9.8	49.8	3.5	15.5	1.7	0.01
吸込配管圧力損失	m													
吐出配管圧力損失	m													
合計配管圧力損失	m													
吸込実揚程	m													
吐出実揚程	m													
吐必要実揚程	m													
NPSH	m													
機器仕様														
台数	2	2	2	2	2	2	2	2	2	2	2	2	2	2
型式	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Diaphragm	Diaphragm	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Diaphragm
流量 (0x1.2)	m ³ /h	206	24	34	20	0.6	80	36.7	78	660	78	205	37	0.1
出力 (Hx1.5)	kw	15	15	15	15	15	15	15	15	15	15	15	15	15
流体	WA	TWW	TWW	TWW	NahS	NahS	NahS	NahS	GS	GS	GS	GS	NW	NW
使用温度	℃	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.
吐出濃度	%	0	5	5	0	0	0	0	0	0	0	0	0	0
密度	kg/m ³	(1,000)	(1,050)	(1,050)	(1,055)	(1,000)	(1,050)	(1,050)	(1,000)	(1,000)	(1,000)	(1,000)	(1,000)	(1,000)
粘度	cP	(1.0)	(1.5)	(1.5)	(4.0)	—	(1.0)	—	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)
pH		1	7	2	2	—	2	—	2	2	2	2	2	2
材質														
重量	kg													
必要軸動力	KW	(16.8)	(2.1)	(2.9)	(1.7)	(0.05)	(6.8)	(3.14)	(17.6)	(89.7)	(6.4)	(27.9)	(3.0)	(0.01)
必要吐出動力	KW	(22.0)	(3.0)	(3.7)	(2.2)	(0.1)	(11.0)	(5.5)	(22.0)	(110.0)	(11.0)	(33.0)	(5.5)	(0.1)
軸動力 (0.8仕様)	KW													
軸動力 (0.9仕様)	KW													
Pole		4	4	4	4	4	4	4	4	4	4	4	4	4
Volt.		415	415	415	415	415	415	415	415	415	415	415	415	415
Hz		50	50	50	50	50	50	50	50	50	50	50	50	50

*****設計書*****											
● 顧客名 JICA / Egyptian Iron and St											
● 7. 設計対象名 Industrial Pollution Contr											
● 設計日 1999/11/5											
● 設計者 K. Toyokura											
No.	1 Tag No.	16	17	18	19	20	21	22	22	合計	
1	PU-202A/B Lime Milk Feed Pump	PU-303A/B #1 NaHS Dosing Pump	PU-303A/B #2 NaHS Dosing Pump	PU-304A/B #1 H2SO4 Dosing Pump	PU-304A/B #2 H2SO4 Dosing Pump	PU-305A/B #2 H2SO4 Dosing Pump	PU-403A/B/C #3 Flocculant Dosing Pump			Lad	
2	消石灰送り機	硫酸鉄供給機	水酸化ナトリウム溶液供給機	硫酸供給機	硫酸供給機	硫酸供給機	高分子凝集剤溶液供給機				
3	MOHNO	Fe2(SO4)3	NaHS	NaHS+H2O	H2SO4	H2SO4+H2O	FLOC+H2O				
4	L.M.	48.6	0.08	4.63	0.0005	0.0443	0.4316				
5	処理量	51,273.0	462.9	4,628.6	0.89	44.30	431.60				
6	速度	10	50	10	98	2	0.1				
7	密度	(1,055)	(2,000)	(1,000)	(1,840)	(1,000)	(1,000)				
8	粘度	(4.0)	-	-	(18)	-	(1)				
9	pH	-	-	-	-	-	-				
10	運転温度	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.				
11	吸入圧力	0.0	0.0	0.0	0.0	0.0	0.0				
12	吐出圧力	30.0	10.0	10.0	10.0	10.0	10.0				
13	材質	CS+Rubber	SUS304	SUS304	SUS304	SUS304	SUS304				
14	所要水動力	4.18	0.004	0.013	0.126	2.4E-05	1.2E-03	49.8			
15	平均効率	50	50	50	50	50	50				
16	所要軸動力	8.4	0.01	0.03	0.25	0.0000	0.0024	125.8			
17	吸込配管圧力損失										
18	吐出配管圧力損失										
19	合計配管圧力損失										
20	吸込実揚程										
21	吐出実揚程										
22	H.必要実揚程										
23	NPSH										
24	台数	2	2	2	2	2	2	3			
25	型式	MOHNO Diaphragm	Diaphragm	Diaphragm	Diaphragm	Diaphragm	Diaphragm	Diaphragm			
26	流量 (Qx1.2)	58	0.1	0.6	5.6	0.001	0.053	0.518			
27	流量 (Hx1.5)	45	15	15	15	15	15	15			
28	流体	L.M.	Fe2(SO4)3	NaHS	NaHS+H2O	H2SO4	H2SO4+H2O	FLOC+H2O			
29	使用温度	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.	A.T.			
30	密度	(1,055)	(2,000)	(1,000)	(1,840)	(1,000)	(1,000)	(1,000)			
31	粘度	(4.0)	-	-	(18.0)	-	-	(1.0)			
32	pH	-	-	-	-	-	-	-			
33	材質	-	-	-	-	-	-	-			
34	質量	(15.0)	(0.01)	(0.05)	(0.45)	(0.0001)	(0.0043)	(0.0422)	(232.9)		
35	必要実軸動力	(19.0)	(0.1)	(0.1)	(1.1)	(0.1)	(0.1)	(0.1)	(304.4)		
36	必要実軸動力	-	-	-	-	-	-	-	-		
37	軸動力 (7-7仕様)	-	-	-	-	-	-	-	-		
38	軸動力 (7-7仕様)	-	-	-	-	-	-	-	-		
39	Pole	4	4	4	4	4	4	4			
40	Volt	415	415	415	415	415	415	415			
41	Hz	50	50	50	50	50	50	50			

****ポンプ設計書****																			
●顧客名		JICA / Egyptian Iron and St																	
●プロジェクト名		Industrial Pollution Control																	
●Job No.		1999/11/5																	
●設計日		N. Toyokawa																	
●設計者																			
No.																			
1 機器名		12	13	14	15														
2 用途		PU-01A/B	PU-02	PU-11A/B	PU-201A/B														
3 型式		Wastewater Pump	No. 1 Sludge Pump	Process Water Feed Pump	Lime Milk Transfer Pump														
4 仕様		RW Feed Centrifugal	Gypsum Withdraw Centrifugal	魔水供給 Centrifugal	消石灰送り Centrifugal														
5 設計条件		T.W.W.	S.S.	T.W.W.	L.M.														
Q: 処理量		39.5	1.9	80.6	48.6														
処理量		39,500.0	2,194.5	80,600.0	51,273.0														
濃度		(1.00)	(1.5)	(1.0)	(4.0)														
粘度		(10)	(7)	(7)	(7)														
密度		A.T.	A.T.	A.T.	A.T.														
PH		10.0	10.0	10.0	10.0														
運転温度		CS+Rubber	CS	CS	CS														
吸入圧力																			
吐出圧力																			
材質																			
6 機器設計		所要水動力	0.06	6.57	1.39														
ポンプ効率		50	50	50	50														
所要軸動力		2.1	0.1	13.1	2.8														
吸入配管圧力損失																			
吐出配管圧力損失																			
合計配管圧力損失																			
吸入流量																			
吐出流量																			
且必要流量																			
NPSH																			
7 機器仕様		回転数	2	2	2														
型式		Centrifugal	Centrifugal	Centrifugal	Centrifugal														
流量 (Q×1.2)		47	2.3	97	58														
ヘッド (H×1.5)		15	15	45	15														
流体		T.W.W.	S.S.	T.W.W.	L.M.														
使用温度		A.T.	A.T.	A.T.	A.T.														
密度		(1,000)	(1,155)	(1,000)	(1,055)														
粘度		(1.0)	(1.5)	(1.0)	(4.0)														
PH		10	7	7	7														
材質																			
質量																			
必要交軸動力		(3.9)	(0.2)	(23.6)	(5.0)														
必要交ポンプ動力		(5.5)	(0.4)	(30.0)	(7.5)														
軸動力 (ポンプ仕様)																			
軸動力 (ポンプ仕様)																			
Pole																			
Volt		415	415	415	415														
Hz		50	50	50	50														

Polymer B Injection

(3-5) Polymer Injection Unit for Centrifuge

Dry Sludge Amount: 1,531 kg/h

- 1) Dosage 0.5% as Dry SS= 7.65 kg/h
- 2) Concentration 2 wt % = 20 g/L
- 3) Specific gravity 1
- 4) Injection rate 382.6523 L/h = 6.38 L/min
- 5) Req'd Vol. 9.18 m³ (for 3days)
- 6) Drum Dimension: Hpo= 3.00 m (take) Apo= 3.06 m²
Dpo= 1.97 m
: Take: 2.5m¹⁰ x 3.5m¹¹

Polymer A Injection

(3-2) Polymer Injection Unit for 2ndary sedimentation

Flow Rate: 246.54 m³/h

- 1) Dosage 200 mg/L
- 2) Concentration 0.1 wt % = 1 g/L (D-09)
- 3) Specific gravity 1
- 4) Req'd Polymer 246.54 g/h = 246.54 L/h (PU-13)
- 5) Req'd Vol. 5.92 m³ (1day)
- 6) Demension Hpo= 2.00 m (take) Apo= 2.96 m²
Dpo= 1.94 m
: Take: 2.0m¹⁰ x 2.5m¹¹

Coagulant

(3-6) Coagulant Al₂(SO₄)₃ · 18H₂O Injection Unit

- 1) Dosing Rate: 30 mg/L, Max. 50 mg/L
- 2) Concentration: 20 wt % = 222.4 g/L
- 3) Specific Gravity: 1.112
- 4) Injection Rate: Q_{p0}= 33.3 L/h = 0.55 L/min (PU-10)
- 5) Drum Vol. : V_{p0}= 5.6 m³ (for 7days)
Height: 2.0 m (take) Apo= 2.79 m²
Diameter 1.9 m
: Take: 2.0m¹⁰ x 2.5m¹¹

BASIC DESIGN PACKAGE OF

WASTEWATER TREATMENT PLANT


FOR

EGYPTIAN IRON AND STEEL CO.

March 2000


CHIYODA DAMES AND MOORE CO.
CHIYODA CORPORATION

MODIFIED





SCALE

0 100m 200m



MODIFIED



Equipment No.	Service	Equipment No.	Service
T-01	Equalization Tank	PU-02A/B	Treated Water Pump
T-02	1st Neutralization Tank	PU-03A/B	Sludge Return Pump
T-03	2nd Neutralization Tank	PU-04A/B	Sludge Pump
T-04	Phosphatation Tank	PU-05A/B	Reflux Pump
T-05	Clarifier	PU-06A/B	Phosphor A Pump
T-06	Thickener	PU-07A/B	Phosphor B Pump
T-07	Bar Screen	PU-08A/B	Lime Pump
D-01A/B	Polymer A Tank	BL-01A/B	Blower
D-02A/B	Polymer B Tank	MZ-01A/B	Distillate
D-03	Lime Tank	MZ-02A/B	Sludge Hooper
Z-01	Acid Neutralization Tank	MZ-03	Counter
Z-02	Treated Water Pond	MZ-04	Skid Chamber
Z-03	Sludge Pond	MZ-05	Skid Chamber
Z-04	Waste Water Pond	MZ-06	Skid Chamber
Z-05	Waste Water Pond	MZ-07	Skid Chamber
PU-10A/B	Acid Neutralization Pump		
PU-01A/B	Waste Water Pump		

NO.	CHK	TECH	APPR	DATE	NO.	CHK	TECH	APPR	DATE

CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY
INDUSTRIAL DEVELOPMENT STUDY DIVISION

CONSULTANT: CHITODA, DAMES & MOORE CO.
CHITODA CORPORATION

PROJECT: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT

TITLE: FOR EGYPTIAN IRON AND STEEL CO. PLANT FOR WASTEWATER TREATMENT PLANT


ISSUED DATE: 1/1/80
SCALE: 1/100
DWG NO: DS-80-12-01
REV: 0

INSTRUMENT SYMBOLS AND LEGEND


1. INSTRUMENT LINE SYMBOLS




2. GENERAL INSTRUMENT SYMBOLS




3. CONTROL VALVE ACTUATOR SYMBOLS




4. SYMBOLS FOR SELF-ACTUATED REGULATOR




5. SYMBOLS FOR TEMPERATURE, FLOW AND LEVEL INSTRUMENTS




5-2. PRESSURE




5-3. FLOW




5-4. LEVEL



LEVEL INDICATOR (FLOW TYPE)




LEVEL INDICATOR (TAPE TYPE)



GAGE GLASS



5-5. OTHERS



FUNCTIONAL IDENTIFICATION LETTERS

LETTER	PROCESS VARIABLE / INSTRUMENT	FUNCTION / SUCCEEDING LETTER
A	ANALYSIS	ALARM
B	BURNER FLAME	
C	ELECTRICAL CONDUCTIVITY	CONTROL
D	DENSITY	
E	ELECTRIC VARIABLE	MEASURING ELEMENT
F	FLOW RATE	
G	DIFFERENTIAL GAUGING	LOCAL INDICATE
H	HAND	HAND OPERATE
I		INDICATE
J		COMPUTER CONTROL
K		LOCKING
L	LEVEL	
M	MEASURE OR IDENTIFY	
N	PRODUCT	
O	PRESSURE	SAMPLING POINT
P	CALORIE	INTEGRATE OR TOTALISE
R		RECORD
S	STIFFENING/COUPLING OR FLEXIBILITY	SWITCHING/SEQUENCE
T	TEMPERATURE	TRIP/SHUT
U	TEMPERATURE ON WALL TYPE VARIABLE	TRIP/SHUT AS
V	VELOCITY	VALVE/SHUTTER OR DAMPER
W	WEIGHT OR FORCE	WELL
X	OTHER VARIABLE	OTHER FUNCTION
Y		COMPARE OR RELAY
Z		SAFETY OR EMERGENCY

JICA	Check	Techn	Appr	Appr	Appr
Sign					
Date					
CHSL	Design	Check	Appr		
Sign				Design	Check
Date				Appr	Date

REVISION


CUSTOMER	JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION				
CONSULTANT	CHIYODA DAMES & MOORE CO. CHIYODA CORPORATION				
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT				
TITLE	FOR ENGINEERING FLOW DIAGRAM LEAD SHEET(2/2)				
ISSUED DATE		SCALE	None	REV.	0
DWG NO					

MODIFIED



INSTRUMENT SYMBOLS AND LEGEND

1. INSTRUMENT LINE SYMBOLS
 PHIDMATIC SIGNAL
 ELECTRIC SIGNAL




2. GENERAL INSTRUMENT SYMBOLS



3. CONTROL VALVE ACTUATOR SYMBOLS



5. SYMBOLS FOR TEMPERATURE, FLOW AND LEVEL INSTRUMENTS



FUNCTIONAL IDENTIFICATION LETTERS


LETTER	PROCESS VARIABLE / FUNCTION	SUCCESSING LETTER
A	ANALYSIS	ALARM
B	BURNER FLAME	CONTROL
C	ELECTRICAL CONDUCTIVITY	CONTROL
D	DENSITY	CONTROL
E	ELECTRIC VARIABLE	REGULATING ELEMENT
F	FLOW RATE	LOCAL INDICATE
G	DIAPHRAGM CHARGING	HAND OPERATE
H	IM/HD	IMPERATE
I	IM/HD	IMPERATE
J	IM/HD	IMPERATE
K	IM/HD	IMPERATE
L	LEVEL	COMPUTER CONTROL
M	MIXTURE OR HOMOGENITY	LOCKING
N	FREQUENCY	LOCKING
O	PRESSURE	LOCKING
P	CLORINE	LOCKING
Q	CLORINE	LOCKING
R	CLORINE	LOCKING
S	CLORINE	LOCKING
T	TEMPERATURE	LOCKING
U	TEMPERATURE	LOCKING
V	TEMPERATURE	LOCKING
W	TEMPERATURE	LOCKING
X	TEMPERATURE	LOCKING
Y	TEMPERATURE	LOCKING
Z	TEMPERATURE	LOCKING

JICA	Check	Tech	Appr	Rev	Description	Design	Check	Appr	Date
Sign									
Date									
CNSL									
Sign									
Date									

REVISION

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION
CONSULTANT	CHIYODA DAMES & MOORE CO. CHIYODA CORPORATION
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT
TITLE	FOR ENGINEERING FLOW DIAGRAM LEAD SHEET(2/2)
ISSUED DATE	
DWG NO	
SCALE	
REV.	
NAME	
NO	0


MODIFIED



JICA SIGN	CHK	TECH	APPR	DATE	DESIGN SIGN	CHK	APPR	DATE	REVISION	Cho	Appr	Dat
CLIENT										JAPAN INTERNATIONAL COOPERATION AGENCY		
CONSULTANT										INDUSTRIAL DEVELOPMENT STUDY DIVISION		
PROJECT										CHYODA DAMES & MOORE CO.		
TITLE										THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT		
ISSUED DATE										FOR EGYPTIAN IRON AND STEEL CO.		
DWG NO										PROCESS FLOW DIAGRAM OF WASTEWATER TREATMENT PLANT (without Spent Sulfuric Acid)		
SCALE										NONE		
REV.										EIS-BD-15-01		
										0		

Stream No.	Analytical Item	Unit	①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩	Law 48/82 Regulation
	Flow Rate (Max)	m ³ /h	80	10	90	113	115	24	4	24	16	5	5
	Flow Rate (Nor)	m ³ /h	35	5	40	63	65	24	4	24	15	5	5
	pH		0.5-2		0.5-2.0	4.0-5.0	8-8.5	8-8.5	8-8.5	8-8.5	8-8.5		6-9
	H ₂ SO ₄	mg/L	2,025	21,800	4,300	4,300	4,300	4,300	4,300	4,300	4,300		
	FeSO ₄	mg/L	2,025	21,800	4,300	4,300	4,300	4,300	4,300	4,300	4,300		
	CaSO ₄ ·2H ₂ O	mg/L	-	-	9,700	6,000	9,700	38,750	38,750	38,750	62,000		
	Ca(OH) ₂	mg/L	-	-	2,400	2,400	2,400	11,250	11,250	18,000	18,000		
	SS	mg/L	-	-	4,000	4,000	10,100	60,000	60,000	80,000	80,000		100,000
													30

MODIFIED



ITEM No.	DESCRIPTION	QUANTITY	UNIT	REMARKS
Z-101	Acid Washwater Tank	1	Unit	Existing
Z-102	Waste Sulfuric Acid Tank	1	Unit	Existing
PU-01A/B/C	Acid Washwater Pump	3	Unit	Existing
T-01	Equalization Tank	1	Unit	Existing
T-02	Waste Water Tank	1	Unit	Existing
PU-101A/B/C	Waste Water Pump	3	Unit	Existing
C-01	Air Compressor	1	Unit	Existing

NO.	DATE	BY	CHKD.	APP.	REVISION

CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY
 INDUSTRIAL DEVELOPMENT STUDY DIVISION

CONSULTANT: CHRYDIA DAMES & MOORE CO.
 CHRYDIA CORPORATION


PROJECT: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT

TITLE: FOR ENGINEERING FLOW DIAGRAM FOR WASTE WATER TREATMENT PLANT (I/A)

ISSUED DATE: DS-80-14-01

DWG NO: 0

I-02
MX-01




ITEM No	I-02	MX-01
SERVICE	1st Neutralization Tank	1st Neutralization Mixer
SIZE(m)	3872*4595*450*	7.5m*
DESIGN PRESS(㎏/㎠)	FULL WATER	FULL WATER
DESIGN TEMP (°C)	Amb.	Amb.
INSTALL TYPE	CS+R Liner/Vert.	CS+R Liner/Vert.

Rev	Check	Tech	Appr	Date	Rev	Check	Appr	Date

Date	Rev	Description	Design	Check	Appr	Date

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION
CONSULTANT	CHYODA DAIKES & MOORE CO. CHYODA CORPORATION
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT
TITLE	FOR EGYPTIAN IRON & STEEL CO. PACKAGING FLOW DIAGRAM FOR WASTE WATER TREATMENT PLANT(2/3)
ISSUED DATE	SCALE
DWG NO	REV.
015-18-11-02	0

MODIFIED



Rev	Date	By	Description	Check	Appr	Date

CLIENT
INDUSTRIAL DEVELOPMENT STUDY DIVISION

CONSULTANT
JAPAN INTERNATIONAL COOPERATION AGENCY
INDUSTRIAL DEVELOPMENT STUDY DIVISION

PROJECT
CHITODA DAME'S & MOORE CO
CHITODA CORPORATION


TITLE
THE STUDY ON INDUSTRIAL WASTE WATER
FOR THE HARBOR DEVELOPMENT OF EGYPT
ENHANCING IRON & STEEL CO.
WASTE WATER TREATMENT PLANT (3)

ISSUED DATE
SCALE

DATE NO
REV

ITEM No.	DESCRIPTION	UNIT	QTY	REMARKS
T-03	10000m ³ x 4500mm ² x 4500mm ² Floculation Tank	Full Water	1	CS+R Lining/Verti.
T-04	2680m ³ x 2500mm ² x 2300mm ² Floculation Tank	Full Water	2	CS+R Lining/Verti.
T-05	10000m ³ x 4500mm ² x 4500mm ² Clarifier	Full Water	1	CS+R Lining/Verti.
T-06	8500m ³ x 4500mm ² x 4500mm ² Thickener	Full Water	1	CS+E Cooling/Verti.
MX-02	5.5kW Floculator	Full Water	1	CS+R Lining/Verti.
MX-03	0.75kW Clarifier	Full Water	1	CS+R Lining/Center Drive
MX-04	0.75kW Thickener	Full Water	1	CS+R Lining/Center Drive
BL-01A/B	60m ² /max 50kg/11kW Blower	0.05	2	FC/FC/floor
PU-01A/B	30m ² /max 20kg/3.2kW Sludge Return Pump	0.2	2	SCS/Center/Verti.
PU-02A/B	20m ² /max 20kg/2.1kW Sludge Return Pump	0.2	2	SCS/Center/Verti.
PU-07A/B	3/4"-CH			
WI	2"-WI			
AP	2"-AP			
AI	1-1/2"-A			

MODIFIED



- FS-84/18-05 T-05
- FS-84/18-05 T-06
- FS-84/18-05 T-02
- FS-84/18-05 WI
- FS-84/18-05 AP
- FS-84/18-05 AI
- FS-84/18-05 MZ-01A/B
- FS-84/18-05 WI
- FS-84/18-05 AP
- FS-84/18-05 AI


ITEM No.	DESCRIPTION	SIZE (m)	DESIGN PRESSURE (kg/cm ²)	DESIGN TEMP (°C)	MATERIAL/TYPE
2-01	Waste Water PH Treated Water Pond	4500*5000*2500*1.5m	4500*5000*2500*1.5m	20m/7m/20m/12.2m	RC/Precast/In situ
2-02	Retention Pond	4500*5000*2500*1.5m	4500*5000*2500*1.5m	20m/7m/20m/12.2m	RC/Precast/In situ
2-03	Retention Pond	4500*5000*2500*1.5m	4500*5000*2500*1.5m	20m/7m/20m/12.2m	RC/Precast/In situ
PU-06A/B	Retention Pump	20m/7m/20m/12.2m	20m/7m/20m/12.2m	0.2	Amb. 5/2/Centrif. Horiz.
PU-02A/B/C	Treated Water Pump	45m/7m/50m/11.5m	45m/7m/50m/11.5m	0.5	Amb. 5/2/Centrif. Horiz.

NO.	CHK.	TECH.	APPR.	DATE	NO.	CHK.	TECH.	APPR.	DATE

DATE	NO.	CHK.	TECH.	APPR.	DATE	NO.	CHK.	TECH.	APPR.	DATE

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY
INDUSTRIAL DEVELOPMENT STUDY DIVISION	
CONSULTANT	CHRODA DAVIES & MOORE CO. CHRODA CORPORATION
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT
TITLE	FOR EGYPTIAN IRON & STEEL CO. (CAMECO) (FOR DIAGRAM FOR WASTE WATER TREATMENT PLANT (V/A))
ISSUED DATE	
SCALE	
DWG NO.	DS-18-18-01
REV.	
DWG	0

MODIFIED




ITEM No.	2-02	PU-02A/B	MZ-01A/B	MZ-02A/B
SERVICE	Sludge P/I	Thickened Sludge Pump	Dehydrator	Sludge Hooper
SIZE (m)	4500x5000x2200x1500	20m ³ /hr @ 2.5 bar	1.5m ³ /hr @ 5 bar x 2.5 bar	2500x1500x1000x2000
DESIGN TEMP (°C)	Amb.	U.G.	AMB.	AMB.
MATERIAL TYPE	Rc/Refractober	SSS/Carboni. Horiz.	SUS/Centrifuge	CS/Vertical

NO.	DATE	BY	CHKD.	REVISION

DATE	BY	CHKD.	REVISION
ES-86/16-04	WI	ES-86/16-06	2'-WI
ES-86/16-04	AP	ES-86/16-06	2'-AP
ES-86/16-04	AI	ES-86/16-06	1-1/2'-N

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION
CONSULTANT	CHIYODA DAMES & MOORE CO. CHIYODA CORPORATION
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER TREATMENT PLANT FOR THE MZ-02A/B FOR EGYPTIAN IRON & STEEL CO. WASTE WATER TREATMENT PLANT(S)/E
ISSUED DATE	ES-86-16-05
SCALE	
REV.	0

MODIFIED



ES-81 18-01	Lime Pipe	2'-CH
ES-82 18-01	T-03	
ES-83 18-01	Lime Pipe	3'-CH
ES-84 18-01	T-02	
ES-85 18-01	W1	2'-W1
ES-86 18-01	AP	2'-AP
ES-87 18-01	A1	1-1/2'-A1

JCA	Drawn	Checked	Appr.	Rev.	Description	Design	Drawn	Appr.	Date

CLIENT
JAPAN INTERNATIONAL COOPERATION AGENCY
INDUSTRIAL DEVELOPMENT SECTOR DIVISION

CONSULTANT
CHYODA DAIKES & MOORE CO.
CHYODA CORPORATION

PROJECT
THE REFINERY INDUSTRIAL WASTE WATER
POLYMERIZATION UNIT
THE ARAB REPUBLIC OF EGYPT

TITLE
FOR
EQUIPMENT WITH A STEEL CASE
EACH EQUIPMENT (1.0m DIA) FOR
WASTE WATER TREATMENT PLANT(6/4)

ISSUED DATE
ES-80-18-08

SCALE
REV. 0



ITEM No.	SERVICE	SIZE(m)	DESIGN PRESSURE	DESIGN TEMP. (C)	MATERIAL/TYPE
MZ-07	Belt Conveyor	700kg/h, 0.4kw			700kg/h, 0.4kw
MZ-06	Belt Conveyor	700kg/h, 0.4kw			700kg/h, 0.4kw
MZ-05	Bucket Elevator	700kg/h, 0.4kw			700kg/h, 0.4kw
MZ-04	Feeder	700kg/h, 0.4kw			700kg/h, 0.4kw
MZ-03	Crusher	700kg/h, 1.1kw			700kg/h, 1.1kw
MZ-02	Lime Mixer	1.5kW			1.5kW
MZ-01	Lime Pipe				

ITEM No.	SERVICE	SIZE(m)	DESIGN PRESSURE	DESIGN TEMP. (C)	MATERIAL/TYPE
PU-08A/B	Polymer A Mixer	0.4kW			0.4kW
PU-08B/B	Polymer B Mixer	0.4kW			0.4kW
PU-07A/B	Lime Pump	3/4" And 3/4" Dia 4kW			3/4" And 3/4" Dia 4kW
PU-07B/B	Lime Pump	3/4" And 3/4" Dia 4kW			3/4" And 3/4" Dia 4kW
PU-06A/B	Polymer A Pump	500 (And 3/4" Dia) 0.2kW			500 (And 3/4" Dia) 0.2kW
PU-06B/B	Polymer B Pump	500 (And 3/4" Dia) 0.2kW			500 (And 3/4" Dia) 0.2kW
PU-05A/B	Lime Pump	15m (And 3/4" Dia) 0.2kW			15m (And 3/4" Dia) 0.2kW
PU-05B/B	Lime Pump	15m (And 3/4" Dia) 0.2kW			15m (And 3/4" Dia) 0.2kW
MX-06A/B	Polymer A Mixer	0.4kW			0.4kW
MX-06B/B	Polymer B Mixer	0.4kW			0.4kW
MX-05A/B	Polymer A Mixer	0.4kW			0.4kW
MX-05B/B	Polymer B Mixer	0.4kW			0.4kW
MX-04A/B	Polymer A Mixer	0.4kW			0.4kW
MX-04B/B	Polymer B Mixer	0.4kW			0.4kW
MX-03A/B	Polymer A Mixer	0.4kW			0.4kW
MX-03B/B	Polymer B Mixer	0.4kW			0.4kW
MX-02A/B	Polymer A Mixer	0.4kW			0.4kW
MX-02B/B	Polymer B Mixer	0.4kW			0.4kW
MX-01A/B	Polymer A Mixer	0.4kW			0.4kW
MX-01B/B	Polymer B Mixer	0.4kW			0.4kW

ITEM No.	SERVICE	SIZE(m)	DESIGN PRESSURE	DESIGN TEMP. (C)	MATERIAL/TYPE
T-04	Tower Mill	1050m x 700m			1050m x 700m
T-03	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
T-02	Lime Tank	8100m x 1000m x 0.4m			8100m x 1000m x 0.4m
T-01	Lime Tank	8100m x 1000m x 0.4m			8100m x 1000m x 0.4m
D-02	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01A/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01B/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01C/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01D/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01E/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01F/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01G/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01H/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01I/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01J/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01K/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01L/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01M/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01N/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01O/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01P/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01Q/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01R/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01S/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01T/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01U/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01V/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01W/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01X/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01Y/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m
D-01Z/B	Lime Tank	1910m x 3000m x 10m			1910m x 3000m x 10m

MODIFIED

Equipment No.	Service	Equipment No.	Service
I-01	Equalization Tank	PU-02A/B	Treated Water Pump
I-02	1st Neutralization Tank	PU-03A/B	Sludge Return Pump
I-03	2nd Neutralization Tank	PU-04A/B	Sludge Pump
I-04	Phosphatation Tank	PU-05A/B	Standard Sludge Pump
I-05	Clarifier	PU-06A/B	Return Pump
I-06	Thickener	PU-07A/B	Proportion & Pumps
I-07	Layer Tank	PU-08A/B	Proportion & Pump
		PU-09A/B	Layer Pump
D-01A/B	Polymers A Tank	BL-01A/B	Blower
D-02A/B	Polymers B Tank	MZ-01A/B	Compressor
D-03	Layer Tank	MZ-02A/B	Sludge Hooper
Z-01	Treated Water Pond	MZ-03	Sludge Dewaterer
Z-02	Sludge Pit	MZ-04	Ball Grinder
Z-03	Sludge Water Pit	MZ-07	Ball Grinder



Rev.	Chg.	By	Date	Description
1				REVISION
2				
3				
4				
5				
6				
7				
8				
9				
10				

CLIENT
 JAPAN INTERNATIONAL COOPERATION AGENCY
 INDUSTRIAL DEVELOPMENT STUDY DIVISION

CONSULTANT
 CHYODA DAIKES & MOORE CO.
 CHYODA CORPORATION



PROJECT
 THE STUDY ON INDUSTRIAL WASTE WATER
 POLLUTION CONTROL IN
 THE ARAB REPUBLIC OF EGYPT

TITLE
 FOR
 EGYPTIAN IRON AND STEEL CO.
 PLOT PLAN FOR
 WASTEWATER TREATMENT PLANT

DESIGN DATE
 08-08-12-81


SCALE
 1/100

REV.
 0




MODIFIED

CONFIGURATION OF ELECTRICAL & INSTRUMENTATION SYSTEM FOR PLANT



MODIFIED

THIS DRAWING
 IS A MODIFICATION
 TO THE ORIGINAL
 DRAWING NO. ES-30-60-01




Client	JAPAN INTERNATIONAL COOPERATION AGENCY
Consultant	CHYUWA DAIKES AND MACHIE CO.
Project	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE HANOI REPUBLIC OF VIETNAM
Drawn	1/80
Checked	
Approved	
Scale	
Sheet No.	9
Total Sheets	9

DATE	DATE	DATE	DATE
DESIGNED	CHECKED	APPROVED	DATE
DATE	DATE	DATE	DATE
DATE	DATE	DATE	DATE
DATE	DATE	DATE	DATE

DATE	DATE	DATE	DATE
DATE	DATE	DATE	DATE
DATE	DATE	DATE	DATE
DATE	DATE	DATE	DATE
DATE	DATE	DATE	DATE

MODIFIED

SEE SHEET NO. ES-180-80-01
FOR 300V MOTOR





CLIENT	WYOMING INTERNATIONAL CORPORATION AGENT
CONSULTANT	OPTIMA DAMES AND MOORE CO.
PROJECT	THE START OF INDUSTRIAL WASTE WATER TREATMENT PLANT AT THE JARVIS REFINERY OF ICPPI
TITLE	FOR CONTROL BOX & 300V MOTOR CONTROL BOARD (2/2)
ISSUED DATE	ES-180-80-002
REV.	REV. 8

MODIFIED

NOTE: Vertical Cylindrical Tank
(Open Top Tank)
1) Type : Carbon Steel
2) Materials : Inside Resin Lining
3) Accessories: Stairway
Inside Ladder
Air Bubbling Tube

Loading Data :
Empty Weight : 24.8 ton
Full Water : 600 ton





No	Name	Size	No	Note
M-1	Manhole	500Φ	1	
N-6	Level Instrument	2"	1	
N-5	Over Flow	4"	1	
N-4	Drain	2"	1	
N-3	Bubbling Air Inlet	2"	1	
N-2	Waste Water Outlet	6"	1	
N-1	Waste Water Inlet	6"	1	

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY		
TITLE	FOR: EGYPTIAN IRON AND STEEL CO. EQUALIZATION TANK WASTEWATER TREATMENT PLANT		
DWG. NO	EIS - BD - 22 - SK01	REV.	0

MODIFIED

NOTE:
 1) Type : Vertical Cylindrical Tank
 (Open Top Tank)
 2) Materials : Carbon Steel
 Inside Resin Lining
 3) Accessories: Stairway
 Inside Ladder



Equipment No	Service	D	H ₁	H ₂	W ₁	W ₂
T-05	Clarifier	10,000	3,000	4,000	12.0	310
T-06	Thickener	8,500	3,000	4,000	9.7	230



W₁ : Empty Weight ton
 W₂ : Full Water ton

N-4						
N-3	Sludge Outlet		2B	1		
N-2	Water Outlet		6B	1		
N-1	Water Inlet		6B	1		
No	Name	Size	No	Note		
CLIENT : JAPAN INTERNATIONAL COOPERATION AGENCY						
FOR: EGYPTIAN IRON AND STEEL CO.						
TYTLE : CLARIFIER & THICKENER						
DWG. NO. : WASTEWATER TREATMENT PLANT						
EIS - BD - 22 - SK02						REV. 0

NOTE:
 1) Type : Vertical Cylindrical Tank
 (Open Top Tank)
 2) Materials : Carbon Steel
 Inside Epoxy Coating
 3) Accessories: Stairway

Equipment No	Service	D	H	W ₁	W ₂
T-02	Coagulant Tank	3,872	4,595	4.8	52
T-03	Flocculation Tank	3,872	4,595	4.8	52
T-03	Flocculation Tank	2,860	3,500	2.7	23

W₁ : Empty Weight ton
 W₂ : Full Water ton





N-3	Drain	2"	1	
N-2	Wastewater Outlet	8"	1	
N-1	Wastewater Inlet	8"	1	
No	Name	Size	No	Note
CLIENT : JAPAN INTERNATIONAL COOPERATION AGENCY				
FOR: EGYPTIAN IRON AND STEEL CO.				
TYTLE : 1ST , 2ND NEUTRALIZATION & FLOCCULATION TANK				
WASTEWATER TREATMENT PLANT				
DWG. NO	EIS - BD - 22 - SK03	REV.	0	

MODIFIED

Material : Reinforced Concrete
 Accessories : Operating Stage
 Stairway
 Air Distributing pipings
 (without Z-01)

Equipment No	Service	W	L	H	m ³
Z-01	Treated Water Pond	4,500	5,000	2,500	45
Z-02	Sludge Pit	4,500	5,000	2,500	45
Z-03	Wastewater Pit	4,500	5,000	2,500	45




N-2	Over Flow			1	
N-1	Waste Water Outlet			1	
No	Name		Size	No	Note
CLIENT JAPAN INTERNATIONAL COOPERATION AGENCY					
FOR: EGYPTIAN IRON AND STEEL CO.					
TYTLE Treated Water Pond, Sludge Pit & Waste Water Pit					
WASTEWATER TREATMENT PLANT					
DWG. NO	EIS - BD - 22 - SK04	REV.	0		

MODIFIED

NOTE:
 1) Type : Vertical Cylindrical Tank
 (Open Top Tank)
 2) Materials : Carbon Steel
 Inside Resin Coating.

Loading Data :
 : Empty Weight 1.5 ton
 : Full Water 9.5 ton




No	Name	Size	No	Note
M-1	Manhole	500Φ	1	
N-6	Level Instrument	2"	1	
N-5	Over Flow	2"	1	
N-4	Drain	2"	1	
N-3	Return Line	2"	1	
N-2	Lime Milk Outlet	2"	1	
N-1	Lime Milk Inlet	2"	1	

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY		
TITLE	FOR: EGYPTIAN IRON AND STEEL CO. LIME TANK WASTEWATER TREATMENT PLANT		
DWG. NO	EIS - BD - 22 - SK05	REV.	0


MODIFIED

0°
N-2,N-4



NOTE:
 1) Type : Vertical Cylindrical Tank
 (Open Top Tank)
 2) Materials : Carbon Steel
 Inside Resin Coating

Loading Data :
 : Empty Weight 0.5 ton
 : Full Water 9.0 ton




M-1	Manhole	450°	1
N-2	Water Inlet	2"	1
N-1	Lime Milk Outlet	2"	1
No	Name	Size	No
CLIENT JAPAN INTERNATIONAL COOPERATION AGENCY			
FOR: EGYPTIAN IRON AND STEEL CO.			
TYTLE TOWER MILL			
WASTEWATER TREATMENT PLANT			
DWG. NO	EIS - BD - 22 - SK06	REV.	0

NOTE:
 1) Type : Vertical Cylindrical Tank
 2) Materials : FRP
 3) Accessories: Level Gauge
 Man-hole

Equipment No	Service	D	H	W ₁	W ₂
D-01A/B	Polymer-A Tank	800	1,000	0.06	0.5
D-02A/B	Polymer-B Tank	800	1,000	0.06	0.5


W₁ : Empty Weight ton
 W₂ : Full Water ton



No	Name	Size	No	Note
M-1	Manhole	400Φ	1	
N-5	Vent	1"	1	
N-4	Drain	1"	1	
N-3	Level Gauge	3/4"	1	
N-2	Level Gauge	3/4"	1	
N-1	Water Inlet	1"	1	


CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY		
	FOR: EGYPTIAN IRON AND STEEL CO.		
TITLE	POLYMER-A AND B TANK WASTEWATER TREATMENT PLANT		
DWG. NO	EIS - BD - 22 - SK07	REV.	0

MODIFIED






Material : Reinforced Concrete
with Resin Lining
Accessories : Ladder

Note : Acid wastewater pump and level
switch are supplied by JICA.
The bottom of existing pipe tunnel
should be confirmed at detail design.



N-3	Waste Water Outlet	8"		
N-2	Leakage Water Inlet	4"	1	
N-1	Rinsing Water Inlet	8"	1	
No	Name	Size	No	Note
CLIENT: JAPAN INTERNATIONAL COOPERATION AGENCY				
FOR: EGYPTIAN IRON AND STEEL CO.				
TYTLE: RECEIVING PIT				
WASTEWATER TREATMENT PLANT				
DWG. NO.	EIS - BD - 22 - SK08	REV.	0	

MODIFIED





- PANEL SPECIFICATION
1. SELF STANDING TYPE FOR INDOOR
 2. STRUCTURE : 3.2MM STEEL
 3. COLOR : YELLOW GREEN
 4. CABLE ENTRY : BOTTOM

CONTROL PANEL OUTLINE FOR WASTEWATER TREATMENT PLANT
 (SCALE : NONE)
 (UNIT : MM)

JICA	Check	Tech.	Appr.	REVISION					
Sign	Date	Chk	Appr	Rev.	Descr	Desig	Chc	Appr	Date
CNSLT									
Sim									
Date	02/11/74								
CLIENT		JAPAN INTERNATIONAL COOPERATION AGENCY INDUSTRIAL DEVELOPMENT STUDY DIVISION							
CONSULTANT		CHIYODA DAMES & MOORE CO. CHIYODA CORPORATION							
PROJECT		THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT FOR EGYPTIAN IRON AND STEEL CO.							
TITLE		CONTROL PANEL OUTLINE FOR WASTEWATER TREATMENT PLANT							
ISSUED DATE		SCALE		REV.		NONE			
DWG NO		IS - BD - 70 - 1		REV.		0			

MODIFIED



Rev.	Chg.	By	Date	Rev.	Chg.	By	Date

CLIENT	JAPAN INTERNATIONAL COOPERATION AGENCY		
CONSULTANT	CHIYODA DAMES & MOORE CO. CHIYODA CORPORATION		
PROJECT	THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL IN THE ARAB REPUBLIC OF EGYPT		
TITLE	FOR WASTEWATER TREATMENT PLANT CONTROL ROOM		
ISSUED DWG	00-BD-56-01	SCALE	None
		REV	0

EQUIPMENT LIST for Egyptian Iron and Steel Co.

MODIFIED

DOC. NO. EIS-BD-L01

(1/4)

CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Industrial Waste Water Plant
 PLANT : W.W.T. Demonstration Plant
 WASTE W. : Rinsing Water + Leakage Water

REV	1	2	3	MADE	T. Yasukawa
BY				CKD	H. Takahashi
APVE				APVE	I. Nagahama
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
T-01	Equalization Tank	1	Vertical Cylindrical Type 8,719 ^φ × 10,635 ^H × 540 m ³	Carbon Steel/Resin Lining
T-02	1st Neutralization Tank	1	Vertical Cylindrical Type 3,872 ^φ × 4,595 ^H × 45 m ³	Carbon Steel/Resin Lining
T-03	2nd Neutralization Tank /Oxidation Tank	1	Vertical Cylindrical Type 3,872 ^φ × 4,595 ^H × 45 m ³	Carbon Steel/Resin Lining
T-04	Flocculation Tank	1	Vertical Cylindrical Type 2,860 ^φ × 3,500 ^H × 23 m ³	Carbon Steel/Resin Lining
T-05	Clarifier	1	Vertical Cylindrical Type 10,000 ^φ × 4,500 ^H	Carbon Steel/Resin Lining
T-06	Thickener	1	Vertical Cylindrical Type 8,500 ^φ × 4,500 ^H	Carbon Steel/Epoxy Coating
T-07	Tower Mill	1	Vertical Cylindrical Type 1,050 ^φ × 7,700 ^H	Carbon Steel
D-01A/B	Polymer-A Tank	2	Vertical Cylindrical Type 800 ^φ × 1,000 ^H × 0.4 m ³	FRP
D-02A/B	Polymer-B Tank	2	Vertical Cylindrical Type 800 ^φ × 1,000 ^H × 0.4 m ³	FRP
D-03	Lime Tank	1	Vertical Cylindrical Type 1,910 ^φ × 3,000 ^H × 8 m ³	FRP

Note:

EQUIPMENT LIST for Egyptian Iron and Steel Co.

MODIFIED

(2/4)

DOC. NO. EIS-BD-L01

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial Waste Water Plant

PLANT : W.W.T. Demonstration Plant

WASTE W. : Rinsing Water + Leakage Water

REV	1	2	3	MADE	T. Yasukawa
BY				CKD	H. Takahashi
APVE				APVE	I. Nagahama
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
Z-101	Acid Wastewater Pit	1	Rectangular, Underground	R.C with Resin lining
			5,000 ^W × 6,000 ^L × 6,000 ^H × 45 m ³	(out of Battery)
Z-01	Treated Water pond	1	Rectangular, Aboveground	Reinforced Concrete
			4,500 ^W × 5,000 ^L × 2,500 ^H × 45 m ³	
Z-02	Sludge Pit	1	Rectangular, Aboveground	R.C
			4,500 ^W × 5,000 ^L × 2,500 ^H × 45 m ³	
Z-03	Waste Water Pit	1	Rectangular, Aboveground	R.C
			4,500 ^W × 5,000 ^L × 2,500 ^H × 45 m ³	
PU-101	Acid Wastewater Pump	3	Horizontal Centrifugal Type	FC/Rubber Lining
A/B/C			45 m ³ /h × 30 m × 7.5 kW	
PU-01	Waste Water Pump	3	Horizontal Centrifugal Type	FC/Rubber Lining
A/B/C			45 m ³ /h × 15 m × 3.7 kW	
PU-02	Treated Water Pump	3	Horizontal Centrifugal Type	SCS
A/B/C			45 m ³ /h × 50 m × 11.5 kW	
PU-03A/B	Sludge Return Pump	2	Horizontal Centrifugal Type	SCS
			30 m ³ /h × 20 m × 3.7 kW	
PU-04A/B	Sludge Pump	2	Horizontal Centrifugal Type	
			20 m ³ /h × 20 m × 2.2 kW	
PU-05A/B	Thickened Sludge Pump	2	Horizontal Centrifugal Type	
			20 m ³ /h × 20 m × 2.2 kW	
PU-06A/B	Return Pump	2	Horizontal Centrifugal Type	
			20 m ³ /h × 20 m × 2.2 kW	

Note:

EQUIPMENT LIST for Egyptian Iron and Steel Co.

MODIFIED

DOC. NO. EIS-BD-L01

(3/4)

CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Industrial Waste Water Plant
 PLANT : W.W.T. Demonstration Plant
 WASTE W. : Rinsing Water + Leakage Water

REV	1	2	3	MADE	T. Yasukawa
BY				CKD	H. Takahashi
APVE				APVE	I. Nagahama
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
PU-07A/B	Polymer-A Pump	2	Reciprocating Type 3 L/h×0.3 MPa×0.4 kW	SCS/SCS
PU-08A/B	Polymer-B Pump	2	Reciprocating Type 500 L/h×0.3 MPa×0.75 kW	SCS/SCS
PU-09A/B	Lime Pump	2	Horizontal Centrifugal Type 15 m ³ /h×25 m×2.2 kW	SCS/SCS
BL-01A/B	Blower	2	Root Type 6 Nm ³ /min×5 m×11 kW	FC/FC
MX-01	1st Neutralization Mixer	1	Vertical Type 7.5 kW	Carbon Steel with Resin Lining
MX-02	Flocculator	1	Vertical Type 5.5 kW	Carbon Steel with Resin Lining
MX-03	Clarifier Rake	1	Center Drive Type 0.75 kW	Carbon Steel with Resin Lining
MX-04	Thickener Rake	1	Center Drive Type 0.75 kW	Carbon Steel with Resin Lining
MX-05A/B	Polymer-A Mixer	2	Vertical Type 0.4 kW	SUS
MX-06A/B	Polymer-B Mixer	2	Vertical Type 0.4 kW	SUS
MX-07	Tower Mill Screw	1	Vertical Type 15 kW	SUS
MX-08	Lime Mixer	1	Vertical Type 1.5 kW	SUS

Note:

EQUIPMENT LIST for Egyptian Iron and Steel Co.

MODIFIED

DOC. NO. EIS-BD-L01

(4/4)

CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Industrial Waste Water Plant
 PLANT : W.W.T. Demonstration Plant
 WASTE W. : Rinsing Water + Leakage Water

REV	1	2	3	MADE	T. Yasukawa
BY				CKD	H. Takahashi
APVE				APVE	I. Nagahama
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
MZ-01A/B	Dehydrator	2	Centrifuge Type	SUS
			15 m ³ /h × 45 kW + 7.5 kW	Sharpies PM-50000
MZ-02A/B	Sludge Hopper	2	Vertical Type	Carbon Steel
			2,500 ^W × 3,500 ^L × 3,000 ^H × 24 m ³	
MZ-03	Crusher	1	Ball Mill Type	Carbon Steel
			700 kg/h, 11 kW	
MZ-04	Feeder	1	Table Feeder Type	SUS
			700 kg/h, 0.4 kW	
MZ-05	Bucket Elevator	1	Vertical Type	Carbon Steel
			700 kg/h, 0.4 kW	
MZ-06	Belt Conveyer	1	700 kg/h, 0.4 kW	
MZ-07	Belt Conveyer	1	700 kg/h, 0.4 kW	

Note:

INSTRUMENT LIST for Egyptian Iron and Steel Co. MODIFIED

DOC. NO. EIS-BD-L2-(1/3)

(1/3)

CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Industrial W. W. Pollution Control
 PLANT : W.W.T. Demonstration Plant
 WASTE W. : Rinsing Water + Leakage Water

REV	1	2	3	MADE	T. Yasukawa
BY				CKD	H. Takahashi
APVE				APVE	I. Nagahama
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
AR-01	T-02 Inlet	1	pH 0~14 pH Analyzer	C.P.
AR-02	T-03 Outlet	1	pH 0~14 pH Analyzer	C.P.
FRCA-01	PU-01 Outlet Line	1	40 m ³ /h~100 m ³ /h Flow Recording Controller	
FI-01	T-01 Inlet	1	40 m ³ /h~100 m ³ /h Flow Meter	
FI-02	Blower Outlet	1	2~10 Nm ³ /min Flow Meter	
FI-03	PU-03A/B Outlet	1	10 m ³ /h~40 m ³ /h Magnetic Flow Meter	
FI-04	PU-04A/B Outlet	1	10 m ³ /h~40 m ³ /h Magnetic Flow Meter	
FI-05	PU-02A/B Outlet	1	40 m ³ /h~100 m ³ /h Flow Meter	
FI-06	PU-05A/B Outlet	1	10 m ³ /h~40 m ³ /h Magnetic Flow Meter	
FS-01	AP Line	1	Flow Integrator	
FIC-01	Return Line	1	20 m ³ /h~10 m ³ /h Flow Indicating Controller	
LS-01	Z-101 Acid Wastewater Pit	1	1,000 mm~1,500 mm Level Switch HH, H, L, LL	
LS-02	Z-03 Wastewater Pit	1	1,000 mm~2,000 mm Level Switch H, L	

Note: C.P. = Center Panel Mount
 L.P. = Local Panel Mount

INSTRUMENT LIST for Egyptian Iron and Steel Co. MODIFIED

DOC. NO. EIS-BD-L2-(2/3)

(2/3)

CLIENT : Japan International Cooperation Agency

PROJECT : The Study on Industrial W. W. Pollution Control

PLANT : W.W.T. Demonstration Plant

WASTE W. : Rinsing Water + Leakage Water

REV	1	2	3	MADE	T. Yasukawa
BY				CKD	H. Takahashi
APVE				APVE	I. Nagahama
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
LS-03	Z-01 Treated Water Pond	1	500 mm~2,000 mm Level Switch H,L	
LS-04	Z-02 Sludge Pit	1	500 mm~2,000 mm Level Switch H,L	
LIA	T-01 Equalization Tank	1	1,000 mm~9,000 mm Level Indicating Alarm	
LG-01A/B	D-01A/B Polimer A Tank	2	Tubular Level Gage	
LG-02A/B	D-02A/B Polimer B Tank	2	Tubular Level Gage	
LC-01	D-03 Lime Tank	2	Level Controller 1,000 mm~2,500 mm	
PI-01A/B/C	PU-101A/B/C Outlet	3	Diaphragm Pressure Indicator	
PI-02	WI Line	1	Buldon Tube Pressure Indicator	
PI-03	AP Line	1	Buldon Tube Pressure Indicator	
PI-04	Instrument Air Line	1	Buldon Tube Pressure Indicator	
PI-05A/B/C	PU-01A/B/C Outlet	3	Diaphragm Pressure Indicator	
PI-06A/B	BL-01A/B Outlet	2	Buldon Tube Pressure Indicator	
PI-07A/B	PU-03A/B Outlet	2	Diaphragm Pressure Indicator	

Note: C.P. = Center Panel Mount

L.P. = Local Panel Mount

PU-05A/B Outlet

INSTRUMENT LIST for Egyptian Iron and Steel Co. MODIFIED

DOC. NO. EIS-BD-L2-(3/3)
 CLIENT : Japan International Cooperation Agency
 PROJECT : The Study on Industrial W. W. Pollution Control
 PLANT : W.W.T. Demonstration Plant
 WASTE W. : Acid Wastewater

(3/3)

REV	1	2	3	MADE	T. Yasukawa
BY				CKD	H. Takahashi
APVE				APVE	I. Nagahama
DATE				DATE	

Equipment NO.	Service	No. Req'd	Type of Equipment	Remarks
PI-08A/B	PU-04A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-09A/B	PU-06A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-10A/B/C	PU-02A/B/C Outlet	3	Buldon Tube Pressure Indicattor	
PI-11A/B	PU-05A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-12A/B	MZ-01A/B Inlet	2	Diaphragm Pressure Indicattor	
PI-13A/B	PU-09A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-14A/B	PU-07A/B Outlet	2	Diaphragm Pressure Indicattor	
PI-13A/B	PU-08A/B Outlet	2	Diaphragm Pressure Indicattor	
TQA-01	MX-03 Clarifier Rake	1	Torque Alarm	
TQA-02	MX-04 Thickener Rake	1	Torque Alarm	

Note: C.P. = Center Panel Mount
 L.P. = Local Panel Mount

INDUCTION MOTOR LIST

MODIFIED

CLIENT :Japan International Cooperation Agency
 PROJECT :The Study on Industrial Waste Water Plant
 PLANT :Egyptian Iron and Steel Co.
 WASTE W. :Acid Wastewater

REV	1	2	3	MADE
BY				CKD
APVE				APVE
DATE				DATE

Motor No.	Service	No. Required	Type	Output		Speed Chst	Revolu tion r.p.m	V-φ-Hz	Time Rating	Starting		Insula tion	Encluse	Cable	Mounting	Drive	Bearing	Acc.	Location	Color Finish	Remarks
				Estimate	Final					Current	Torque										
PU-101-A-C-M	Acid wastewater Pump	3	SC	7.5		C	CW 4/1500	380-3-50	C			TEFC		H	D			OD			
PU-01A-C-M	Waste water Pump	3	SC	3.7		C	CW 4/1500	380-3-50	C			TEFC		H	D			OD			
PU-02A-C-M	Treated Water Pump	3	SC	11.5		C	CW 4/1500	380-3-50	C			TEFC		H	D			OD			
PU-03A/B-M	Sludge Return Pump	2	SC	3.7		C	CW 4/1500	380-3-50	C			TEFC		H	D			OD			
PU-04A/B-M	Sludge Pump	2	SC	2.2		C	CW 4/1500	380-3-50	C			TEFC		H	D			OD			
PU-05A/B-M	Thickened Sludge Pump	2	SC	2.2		C	CW 4/1500	380-3-50	C			TEFC		H	D			OD			
PU-06A/B-M	Return Pump	2	SC	2.2		C	CW 4/1500	380-3-50	C			TEFC		H	D			OD			
PU-07A/B-M	Polymer-A Pump	2	SC	0.4		C	CW 4/1500	380-3-50	C			TEFC		H	G			OD			
PU-08A/B-M	Polymer-B Pump	2	SC	0.75		C	CW 4/1500	380-3-50	C			TEFC		H	G			OD			
PU-09A/B-M	Lime Pump	2	SC	2.2		C	CW 4/1500	380-3-50	C			TEFC		H	D			OD			
MX-01-M	1st Neutralization Mixer	1	SC	7.5		C	CW 4/1500	380-3-50	C			TEFC		V	G			OD			
MX-02-M	Flocculator	1	SC	5.5		C	CW 4/1500	380-3-50	C			TEFC		V	G			OD			
MX-03-M	Clarifier Rake	1	SC	0.75		C	CW 4/1500	380-3-50	C			TEFC		V	G			OD			
MX-04-M	Thickener Rake	1	SC	0.75		C	CW 4/1500	380-3-50	C			TEFC		V	G			OD			
MX-05-M	Polymer A Mixer	2	SC	0.4		C	CW 4/1500	380-3-50	C			TEFC		V	G			OD			
MX-06-M	Polymer B Mixer	2	SC	0.4		C	CW 4/1500	380-3-50	C			TEFC		V	G			OD			
MX-07-M	Tower Mill Screw	1	SC	15		C	CW 4/1500	380-3-50	C			TEFC		V	G			OD			
MX-08-M	Lime Mixer	1	SC	1.5		C	CW 4/1500	380-3-50	C			TEFC		V	G			OD			
MZ-01A/B-M	Dehydrator (main)	2	SC	45		C	CW 4/1500	380-3-50	C			TEFC		H	G			ID			
MZ-01A/B-M	Dehydrator (Backdrive)	2	SC	7.5		C	CW 4/1500	380-3-50	C			TEFC		H	G			ID			
MZ-03-M	Crusher	1	SC	11		C	CW 4/1500	380-3-50	C			TEFC		H	G			OD			
MZ-04-M	Feeder	1	SC	0.4		C	CW 4/1500	380-3-50	C			TEFC		H	G			OD			
MZ-05-M	Bucket Elevator	1	SC	0.4		C	CW 4/1500	380-3-50	C			TEFC		H	B			OD			
MZ-06-M	No.1 Belt Conveyor	1	SC	0.4		C	CW 4/1500	380-3-50	C			TEFC		H	B			OD			
MZ-07-M	No.2 Belt Conveyor	1	SC	0.4		C	CW 4/1500	380-3-50	C			TEFC		H	B			OD			
BL-01A/B-M	Blower	2	SC	11		C	CW 4/1500	380-3-50	C			TEFC		H	B			ID			

Notes:
 1. Type : SC = Squirrel Cage, W = Wound Rotor.
 2. Speed : C = Constant, M = Multi, A = Adjustable, V = Varying.
 3. Revolution Direction : Direction when viewed from coupling side.
 CW = Clockwise, CCW = Counter-Clockwise.
 4. Voltage : Rated Voltage
 5. Time Rating : C = Continuous, ST = Short Time, P = Periodic.
 6. Enclosure : TEFC = Totally-Enclosed Fan-Cooled, DR = Drip-Proof.
 7. Cable(or Wire) : T = Top, B = Bottom, S = Side, H = Hub for conduit tube or flexible tube.
 8. Mounting : H = Horizontal, V = Vertical
 9. Drive : D = Direct, B = Belt, C = Chain, G = Gear.
 10. Location : ID = Indoor, OD = Outdoor.

Overall Schedule for Implementation of Demonstration Plant (Preliminary)

Dec. 11, 1999

Phase 1 Study




Table ESTIMATED CONSTRUCTION COST FOR EISCO).

2000/3/23

ITEM	Inside B/L		Outside B/L		Paid by (1000yen)	
	Japan(Myen)	Egypt (LE)	Japan(Myen)	Egypt (LE)	Japan	Egypt
1. Equipment, Instruments						
(1)Machinery	164,500					
(2)Pipings	8,830					
(3)Electrical	15,400					
(4)Instruments	17,540					
(5)Test Equipment	3,000					
1. Subtotal	209,270	0	0	0	209,270	0
2. Field Works						
(1)Tank Installation		1,075,868				
(2)Corrosion Proof		474,792				
(3)Instal. Machines		46,900				
(4)Piping		453,127		1,814,336		61,700
(5)Foundation		532,758				0
(6)RC Basins		300,590				0
(7)Paving, Road		42,888				0
(8)Structure		611,567				0
(9)pipe Rack, Stage		55,271				0
(10)Painting		165,600				0
(11)Electrical		132,000				0
(12)Instrumentation		150,000				0
(13)Test Operation		50,000				0
2. Subtotal	0	4,091,361	0	1,814,336	139,100	61,700
(1 + 2)Total	348,376	x1000yen	61,687	x1000yen		
3. Indirect Cost						
(1)Packing, Ocean Freight	19,500				19,500	0
(2)Tax., In Transportation*1		1,779,000				60,500
(3)Temporary Works*2		245,482		---	8,300	
(4)Construction Expense*3		1,022,840		---	34,800	
(5)Insurance, Tax *4		9,406		1,666	300	100
(6)Supervisor Field Expense	10,000				10,000	
3. Subtotal	29,500	3,056,728	0	1,666	72,900	60,600
(1 + 2 + 3) Total	238,770	7,148,089	0	1,816,002	421,270	122,300
Total (1000yen)	238,770	243,100	0	61,800		
[IBL/OBL] Total (1000yen)	481,870		61,800			
Grand Total		543,670			421,370	122,300

Note*1 : (Equipment/Instruments + packing/Ocean Freight) x 25%

Note*2 : Field Works Cost x 6%

Note*3 : Field Works Cost x 25%

Note*4 : [1+2 (except Supervisor Fee)] x 2.7%

Notes:(a) Piping Works except discharge pipeline is allocated in Inside B/L.

(b)The Cost is estimated as Japanese Contractor basis.

Unit Cost for Estimation of W.W.T. Demonstration Plant (Reference)

Factory Name: Egyptian Iron and Steel Co.
Design Case: Basic Design (Modified Case)

1. Major Equipment

<u>Equipment Name</u>	<u>Unit Cost [x10³Yen]</u>	<u>Note</u>
(1) Acid water pumps	2,300~3,600	Material: SCS
(2) Clarifier Rake	15,000	1 set
(3) Thickener Rake	12,000	1 set
(4) Dehydrator	25,000	2 sets
(5) Limestone grinding System	19,000	1 set
(6) Motor Control Center	12,000	
(7) Center Control Panel	3,000	1 set

2. Field Work

<u>Work Item</u>	<u>unit</u>	<u>unit Cost[LE]</u>	<u>Note</u>
(1) Site Preparation	[m ²]	8	
(2) Civil (Earth Work)	[m ³]	34	
(3) RC Work	[m ³]	1,500	Foundation, Water Basin
(3) Storage Tank	[ton]	3,430	Equalization Tank, Chemical tank Neutralization Tanks
(4) Structural Steel	[ton]	2,000	Pipe rack, Operating Stage
(5) Equipment Installation	[ton]	400	Pumps, Clarifier rakes, Dehydrator
(6) Piping	[ton]	3,970	Except valves
	[in-m]	30	Except valves
(7) Painting	[m ²]	50	
(8) Local Building	[m ²]	2,600	W.W.T Control Room
(9) Electrical	[cable-m]	3	

Running Cost-Egyptian Iron and Steel Co.

MODIFIED

Items	Treating Capacity (m ³ /h)	Feeding Ratio (mg/L)	Consump. (kg/h)	Unit Cost (LE/kg)	Cost-1 (LE/h)	Cost-2 (LE/day)	Cost-3 (LE/year)	Unit Cost (LE/m ³)	Remarks
1.1 Chemical Cost									
1) CaO	90	4,000	360	0.15	54.00	1,296	427,680	0.600	
2) Polymer-A (Anionic)	90	0.1	0.01	27	0.24	6	1,925	0.003	
3) Polymer-B (Anionic)	—	—	2.4	27	64.80	1,555	513,216	0.720	
Sub-Total	—	—	—	—	119.04	2,857	942,821	1.323	
1.2 Power Consumption				LE/kWh					
			kWh/d						
			2,761	0.12	13.80	331.28	109,323	0.153	
			m ³ /day						
1.3 Industrial Water or Potable Water									
			200	0.528	4.40	105.60	34,848	0.049	
1.4 Maintenance Fee									
(Plant Cost * 3 %/year)	15,144,000				57.36	1376.73	454,320	0.637	
514,900,000/34=15,144,000 LE									
Item 1 Total								2.16	
2. Operator including sludge handling	4 Persons*3 Shift+1S		16	10,000	20.20	484.85	160,000	0.22	
	(2 persons : operation								
	2 persons : sludge)								
Total Operation Cost	—	—	—	—	215	5,155	1,701,311	2.39	

Client: JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
Project Name: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL
IN THE ARAB REPUBLIC OF EGYPT

Factory Name: EGYPTIAN IRON AND STEEL CO.

BASIC DESIGN
(MODIFIED)

Document Title: STUDY REPORT
FOR
W.W.T. DEMONSTRATION PLANT

Issued Date September 2000

Consultant: JICA STUDY TEAM
CHIYODA DAMES AND MOORE CO.
CHIYODA CORPORATION

1. Purpose

This report states the studies and discussions concerning to the detail design for Wastewater Treating Plant for Egyptian Iron and Steel Co. (hereinafter EIS), that treats wastewater from the Pickling Plant in Cold Rolling Mill Factory.

The new wastewater treating plant is defined as Modified Wastewater Treating Plant (Modified Case) .

2. Basic Design (Modified Case)

2.1 Design Conditions

[1]

The Wastewater Treating Plant is designed to treat the rinsing water from the Pickling Plant except spent sulfuric acid after the existing Spent Sulfuric Acid Recovery Plant will be improved in the future.

[2]

In case that the Spent Sulfuric Acid Recovery Plant can not be operated, spent sulfuric acid should be neutralized and disposed independently.

[3]

The following water supply piping system to the Pickling Plant should be improved (Installation of new water supply pumps, replacement of piping) ;

(1) Process water is supplied as spray water of Rinsing Bath and side washing water of Pickling Bath.

(2) Potable water is supplied as make-up water to Rinsing Bath

2.2 Design Package

The following design drawings and documents were prepared:

- (1) Process Flow Diagram (PFD)
- (2) Engineering Flow Diagram (EFD)
- (3) Layout
- (4) Skeleton Drawings of Major Equipment
- (5) Single Line Diagram for Motor Control Board
- (6) Equipment List, Instrument List, Motor List
- (7) Construction Cost, Running Cost

3. Existing Wastewater Sewer System

The existing wastewater sewer system is shown on the attached drawings-1.

Almost all wastewater is recycled through the lagoon, and a part of wastewater is discharged to the Desert approx. 10km from the Factory.

4 . Design Conditions

4.1 Wastewater to be treated

The wastewaters to be treated are as follows;

- (1) Rinsing Water (including side washing water of Pickling Plant) – Continuously
- (2) Leakage Water in Wastewater Pipe Trench Continuously

4.2 Wastewater Flow Rate and Qualities

(1) Wastewater Flow Rate

The results of flow rate measurement are shown on Table-1.

Table-1 Wastewater Flow Rate

Wastewater	Ave. Flow Rate [m ³ /h]	Min-Max Flow [m ³ /h]	Note
Rinsing Water	16.9	9.8 – 21.5 peak Max. 32.0	Electro-magnetic Type---Continuous
Leakage Water	2.0	1.1 – 5.6 (11.2)*	Electro-magnetic Type—Spot (6 times)

- Note 1. Rinsing Water is always discharged except long stoppage of Pickling Plant.
2. Peak Max. Flow of Rinsing Water means the peak value recorded on the Flow Recorder Sheet.
 3. Leakage water decreases during stoppage of Pickling Plant operation, but flow rate will not reach to zero.
 4. * mark: The data is measured on 10th February at pre-survey.
 5. Pickling Plant stopped several times during our survey due to decreasing of steam pressure and mechanical troubles.

(2) Wastewater Qualities

The survey results are as follows;

1) Rinsing Water

Table-2 Rinsing Water Qualities

Item	Ave.	Min. – Max.	Note
H ₂ SO ₄ [mg/l]	3,300	1,000 – 7,600	
FeSO ₄ [mg/l]	4,100	500 – 10,700	
pH [-]	1.17	0.65 – 1.53	except pH4.6
Total Fe [mg/l]	681	169 – 1,350	
Fe ²⁺ [mg/l]	501	111 – 923	
Fe ³⁺ [mg/l]	180	38 – 595	
COD [mg/l]	134	62 – 227	
TDS [mg/l]	2,940	720 – 7,725	
Water Temp. [°C]	45.0	37.9 – 49.3	

Note 1. Number of samples=13

2. pH is recorded continuously.

2) Leakage Water

Table-3 Leakage Water Qualities

Item	Ave.	Min. – Max.	Note
H ₂ SO ₄ [mg/l]	43,600	22,700 – 66,100	
FeSO ₄ [mg/l]	31,700	8,700 – 61,200	
Total Fe [mg/l]	26,158	3,102 – 55,800	
Fe ²⁺ [mg/l]	22,203	2,078 – 45,833	
Fe ³⁺ [mg/l]	3,955	1,024 – 13,300	
pH [-]	2.20	1.00 – 3.75	
Water Temp. [°C]	27.9	23.8 – 32.2	

Note 1. Number of samples = 6

3) Calculated Wastewater Flow Rate and Qualities to be treated

The wastewater to be treated is mixed wastewater of rinsing water and leakage water. Therefore, wastewater flow rate and qualities are estimated based on calculation results.

Table-4 Calculated Flow Rate and Qualities to be treated

Item	Ave.	Min. – Max.	Note
Flow Rate [m ³ /h]	18.9	10.9 – 27.1	
H ₂ SO ₄ [mg/l]	7,565	3,296 – 13,790	
FeSO ₄ [mg/l]	7,021	1,368 – 16,044	
Water Temp. [°C]	43.2	36.2 – 47.2	

Note. Wastewater qualities are calculated at average flow rate, it means that maximum concentration must not occur at the maximum flow rate.

4.3 Design Wastewater Flow Rate and Qualities

4.3.1 Design Conditions at Present

(1) Wastewater Flow Rate

1) Rinsing water

[Average flow rate]

$$= \text{Average flow rate measured (16.9 [m}^3\text{/h])} \times (1 + \text{approx.20\%})$$

$$= 20 \text{ [m}^3\text{/h]}$$

[Maximum flow rate]

$$= 30 \text{ [m}^3\text{/h]}$$

Maximum flow rate measured at sampling period was 21.5 [m³/h], but it is decided considering 32 [m³/h] of maximum flow rate that had been recorded on the recorder chart.

2) Leakage Water

[Average flow rate]

$$= 5.0 \text{ [m}^3\text{/h]}$$

The average flow rate measured during survey was 2.0 [m³/h], but enough allowance is considered because of old wastewater piping adhered to scale.

[Maximum flow rate]

$$= 10 \text{ [m}^3\text{/h]}$$

The maximum flow rate measured during survey was 5.6 [m³/h], and 11.2[m³/h] had been recorded during pre-survey.

(2) Wastewater Qualities

- 1) The average wastewater qualities equal to the average values analyzed at the laboratory.

The average pollutant load:

It is defined as follows;

$$\text{Average pollutant load} = (\text{Average flow rate}) \times (\text{Wastewater qualities})$$

- 2) Concentration at the maximum flow rate:

It is assumed that the average pollutant load is always constant, only water increases at the maximum flow rate. Therefore, the concentration at the maximum flow rate is calculated as follows;

Concentration at the maximum flow rate:

$$= (\text{Average pollutant load}) / (\text{Maximum flow rate})$$

Table-5 Basic Wastewater Flow Rate and Qualities

Item		Rinsing Water	Leakage Water	Mixed Wastewater
Flow Rate [m ³ /h]	Ave.	20	5	25
	Max.	30	10	40
H ₂ SO ₄ Conc. [mg/l]	Ave.	3,300	43,600	11,360
	Flow Max.	2,200	21,800	7,100
H ₂ SO ₄ Load [kg/h]	Ave.	66	218	284
	Flow Max.	66	218	284
FeSO ₄ Conc. [mg/l]	Ave.	4,100	31,700	9,620
	Flow Max.	2,733	15,850	6,013
FeSO ₄ Load [kg/h]	Ave.	82	158.5	240.5
	Flow Max.	82	158.5	240.5

4.3.2 Design Base considering to Improvement of Water Supply Unit

- (1) Necessity of Consideration

We are informed by EIS that flow rate of Rinsing Water (they called as Acid Wash Water) is 150 [m³/h]. It has been cleared that 150 [m³/h] is the design base data by Soviet Manufacturer of Pickling Plant and nobody has confirmed to be correct or not.

- 1) Based on our survey results, wastewater flow rate from Pickling Plant was

measured to be around 20~30 [m³/h].

- 2) The estimated flow rate based on the pipe size, opening of valves and water pressure may be 60~70 [m³/h] (Refer to the attached table) .
- 3) Flow meter of ultra-sonic type could not be worked to the supply water pipeline to Rinsing Bath. One of the reasons is supposed that ultra-sonic transmittal / receiver ability is interfered by much scale on the interior surface of pipe. On the other hand, it was informed that EIS has his plan to install new water feeding pumps and to replace water supply pipes in order to increase supply water flow rate.

(2) Design Base of Wastewater Flow Rate and Qualities

1) [Wastewater flow rate]_{Design Base}

(a) Basic wastewater flow rate

Maximum flow rate based on Table-5

· Rinsing water: 30 [m³/h]

· Leakage water: 10 [m³/h]

Total 40 [m³/h]

(b) Design base of Maximum flow rate

Considering future improvement, the maximum flow rates were decided as follows;

i) Rinsing water :

Supply water flow rate will be two times of basic flow rate.

$$30 \text{ [m}^3\text{/h]} \times 2 = 60 \text{ [m}^3\text{/h]}$$

Leakage water :

The flow rate must not increase anymore.

$$10 \text{ [m}^3\text{/h]}$$

Wastewater to be treated (=Rinsing Water+Leakage Water) :

$$60 \text{ [m}^3\text{/h]} + 10 \text{ [m}^3\text{/h]} = 70 \text{ [m}^3\text{/h]}$$

ii) [Wastewater flow rate]_{Design Base} :

It is taken as approx. 30% design allowance (margin) .

$$70 \text{ [m}^3\text{/h]} \times (1+0.3) = 91 \rightarrow 90 \text{ [m}^3\text{/h]}$$

2) [H₂SO₄]_{Design Base}

(a) [H₂SO₄ load]_{Design Base}

i) At basic wastewater flow rate (40[m³/h])

284 [kg/h] (from Table-5)

It is taken approx. 1/3 (33.3%) as a design allowance (margin) .

$$284 \text{ [kg/h]} \times (1+0.33) = 377.7 \rightarrow 380 \text{ [kg/h]}$$

ii) At the maximum flow rate (90[m³/h]) ,

380 [kg/h] (as same as the above)

(b) [H₂SO₄ conc.]_{Design Base}

i) At basic wastewater flow rate (40[m³/h])
 $\{ 380 \text{ [kg/h]} / 40 \text{ [m}^3\text{/h]} \} \times 10^3 = 9,500 \text{ [mg/l]}$

ii) At the maximum flow rate (90[m³/h]) ,
 $\{ 380 \text{ [kg/h]} / 90 \text{ [m}^3\text{/h]} \} \times 10^3 = 4,220 \rightarrow 4,300 \text{ [mg/l]}$

3) [FeSO₄]_{Design Base}

(a) [FeSO₄ load]_{Design Base}

Based on Table-5, the ratio "a" of [FeSO₄] / [H₂SO₄] is as follows;

$$a = 240.5 / 284 = 0.85$$

The other hand, the ratios calculated based on the data given by EIS are;

· Dec.12 ~ 16, 1999 a=1.04

· Jan.17 ~ 30, 2000 a=2.13

Therefore, the ratio is assumed to be 1.0, that is, concentration of FeSO₄ is same as H₂SO₄.

i) At basic wastewater flow rate (40[m³/h]) :

$$380 \text{ [kg/h]}$$

ii) At the maximum flow rate :

$$380 \text{ [kg/h]} \text{ (same as the above)}$$

(b) [FeSO₄ conc.]_{Design Base}

i) At basic wastewater flow rate (40[m³/h]) :

$$= 380 \text{ [kg/h]} / 40 \text{ [m}^3\text{/h]} = 9,500 \text{ [mg/l]}$$

ii) At the maximum flow rate (90[m³/h]) :

$$= 380 \text{ [kg/h]} / 90 \text{ [m}^3\text{/h]} = 4,300 \text{ [mg/l]}$$

Table - 6 Design Base of Wastewater Flow Rate and Qualities

	Flow Rate Max.	Conc. Max	Note
Flow Rate [m ³ /h]	40	90	
H ₂ SO ₄ [mg/l]	9,500	4,300	
[kg/h]	380	380	
FeSO ₄ [mg/l]	9,500	4,300	
[kg/h]	380	380	
pH [-]	0.5 - 1.0	0.5 - 2.0	

4.4 Target of Treated Water

(1) Water quality of dispose water

Dispose water quality is applied to the most stringent Wastewater Discharge Regulation of Egyptian Standard , that is [Discharge into Underground Reservoir & Nile Branches / Canals] of Law 48/82.

(2) Consideration of TDS

Rinsing water contains high concentration of sulfuric acid, therefore TDS concentration of rinsing water is also too high (several 1,000mg/l). The treated

water (neutralized wastewater by lime) may contain approx. 2,000mg/l of gypsum in solution (saturate concentration).

TDS is specified as 800 mg/l at the Wastewater Discharge Regulation in Egypt.

In order to meet the regulation, the following two methods may be applied.

1) Dilution:

A large amount of low TDS water will be required.

2) Desalination

The expensive desalination plant such as RO (reverse osmosis), Ion Exchanger (resin, membrane) , Evaporator will be required. But, in this case, a little condensed waste may be generated.

In this basic design, neither dilution nor desalination is applied. Therefore, discharge wastewater quality meets to Law 48/82 except to TDS.

5. System Design

5.1 Wastewater Treating Plant

The Wastewater Treating Plant consists of the following units:

- (1) Wastewater Collecting Unit : Area "A"
- (2) Wastewater Treating Unit : Area "B"




Fig.-1 Flow Scheme of Wastewater

5.2 Collection and Supply of Wastewater

- (1) A new receiving pit will be provided besides the existing pipe trench outside of Cold Roll Mill Plant (Area "A") .
- (2) Two acid wastewater pumps controlled automatically by water level will be

provided at the above receiving pit.

5.3 Wastewater Treating System

(1) Wastewater quality to be treated

1) p H control

pH of wastewater from Pickling Plant is 0.5-2. Therefore, neutralization is required.

2) COD

COD of wastewater is higher than regulation value (COD=40[mg/l]). But almost COD components come from reducing Fe^{2+} , so that, COD value is easily reduced by air-oxidization.

3) Oil & Grease :

Oil and grease is contaminated, but not so high, so that it may be removed during neutralization coagulation process. Therefore, an oil separator is not required.

4) Heavy metals :

High concentration of soluble Fe is contained. It can be removed by neutralization at around pH 9. Any other heavy metals are not contained or a little negligibly.

(2) Design of Wastewater Treating System

The wastewater treatment plant consists of the following treating units:

(Refer to Section 7)




Fig-2 Flow Scheme of Wastewater Treatment System

5.4 Description of Treating Unit

(1) Equalization Tank

1) Purpose

- (a) Wastewater qualities of rinsing water and leakage water are very deferent.
- (b) Flow rate of wastewater and qualities are not always constant.
- (c) Pickling Plant may stop several times in a day.

To treat such wastewater stably, Equalization Tank is provided to equalize flow rate and qualities of wastewater. And, aeration devices are provided in the tank to promote equalization and air-oxidization.

2) Specification, design base

- (a) Shape: Open top tank of circular and vertical type, installed above ground.
- (b) Material: Carbon steel with resin lining on the inner surface.
Steel is easy to fabricate at shop and field, and inexpensive.
- (c) Volume: equal to 6 hours-retention time of maximum flow rate as general.
- (d) Attachment: Air bubbling devices (blower, air piping).

(2) 1st Neutralization Unit

1) Purpose

Described on the above, wastewater is neutralized at pH 3-4 by addition of CaO in the tank. In the tank, gypsum will generate under the following reaction:



2) Specification, Design base

2-1) 1st neutralization tank

- (a) Shape: Open top tank of circular and vertical type, installed above ground.
- (b) Material: Carbon steel with resin lining on the inner surface.
- (c) Volume: equal to 30 minutes-retention time of maximum flow rate considering reaction time.
- (d) Attachment: Vertical type of mixer
- (e) All gypsum slurry will be sent to 2nd neutralization tank not to draw-off gypsum.

2-2) Lime Injection Unit

Alkali chemical is applied to CaO stone used same as the existing plant.

CaO injection unit consists of the following equipment:

- (a) Crusher
- (b) Bucket elevator
- (c) Tower type of mill
- (d) Injection pumps
- (e) pH control system (Instrument, control valves)

3) Description

In order to neutralize wastewater of pH 0.5-2, a large amount of CaO is consumed

at pH 3-4 and gypsum (CaSO₄) slurry is produced.

Amount of gypsum slurry is not so much because H₂SO₄ concentration of wastewater is not so high. Therefore, gypsum is not recovered and gypsum slurry is sent to 2nd neutralization tank.



(3) 2nd Neutralization Unit

1) Purpose

In order to neutralize at pH 8.5-9 completely, more CaO is injected and mixed to gypsum slurry of pH 3-4. And air is injected from the bottom of tank to accelerate oxidization of slurry.

In this reaction, ferrous sulfate (FeSO₄) will be ferric sulfate (Fe₂(SO₄)₃), and ferric hydrate (Fe(OH)₃) by oxidization, then they will be settled at the sedimentation tank.

Reaction at 2nd neutralization is as follows:



The unit consists of the following equipment to complete the above reactions:

- (a) 2nd neutralization tank
- (b) Coagulation tank
- (c) Sedimentation tank
- (d) Chemical injection unit

2) Specification, Design base

- (a) Shape of tanks: Open top tank of circular and vertical type, installed above ground.
- (b) Material of tanks: Carbon steel with epoxy coating on the inner surface.
- (c) 2nd neutralization tank
 - Volume: equal to 30 minutes-retention time of maximum flow rate considering reaction time.
 - Attachment: Air bubbling devices (blower, aeration piping)
- (d) Coagulation tank
 - Volume: equal to 15 minutes-retention time of maximum flow rate considering reaction time.
 - Attachment: Vertical type of mixers
- (e) Sedimentation tank
 - Surface load: 36m³/m²/day=1.5m³/m²/hours based on the result of laboratory test

- Attachment: Center driven type of sludge collecting rake, supporting bridge
- (e) Chemical injection unit

The unit consists of chemical drums with mixers and chemical pumps.

Polymer will be injected at the inlet of coagulant tank as coagulant aid.

3) Description

In order to neutralize the residue of ferrous sulfate and sulfuric acid at pH 3-4, more CaO is added until pH 8.5-9 at 2nd neutralization, then air-oxidization is proceeded. As a result, ferric hydrate and hydrate of heavy metals (Zn, Pb, etc.) can be removed as settled sludge at the sedimentation tank.

(4) Sludge Treating Unit

(4-1) Sludge Thickener

1) Purpose

In order to dehydrate effectively, a thickener is provided to thicken sludge before feeding to a dehydrator.

A part of thickened sludge from the thickener bottom will be returned to the inlet of 1st neutralization tank as seeding sludge.

2) Specification, design base

- (a) Shape: Open top tank of circular and vertical type, installed above ground.
- (b) Material of tanks: Carbon steel with epoxy coating on the inner surface.
- (c) Surface load: $12\text{m}^3/\text{m}^2/\text{day}=0.5\text{m}^3/\text{m}^2/\text{hours}$ (standard)
- (d) Attachment: Center driven type of sludge collecting rake, supporting bridge

(4-2) Dehydrator (Centrifuge)

1) Purpose

In order to reduce sludge volume and to be able to treat as solid state, a dehydrator is provided to dehydrate sludge from the thickener.

2) Specification, design base

- (a) Shape: horizontal type of centrifuge, made of stainless steel
- (b) Operation: 12 hours/day x 2 sets or
24 hours/day x 1 set + 1 set spare
- (c) SS contents: Feed sludge approx. 5 % ($50\text{kg}/\text{m}^3$)
Sludge cake approx. 20 % ($200\text{kg}/\text{m}^3$)
- (d) Chemical feeding unit: chemical drums with mixers and pumps
- (e) Polymer (cation or anion) is used as coagulant.

3) Description

There are many type of dehydrating equipment such as a filter press (like as the existing unit), a vacuum filter (filter cloth) and a centrifuge.

In this basic design, a centrifuge is provided as following reasons;

- 1) Easy to operate and maintain
- 2) Compact.
- 3) Water content of dehydrated cake can be expected less than 80%.

Filtrate from centrifuge is returned to the inlet of 1st neutralization basin to treat again.

(5) Electrical Instrumental Design

1) Electrical Design

- (a) Primary power cables (380V-AC x 3 phase x 50 HZ) will be laid between the switch gear at the existing electric substation and a receiving/distributing board, transformer at the new electric substation in the W.W.T control room.
- (b) Secondary power cables (380-AC x 3 phase x 50 HZ) will be laid between MCC (Motor Control Center) at the new substation in the W.W.T. control room and each motors of equipment.
- (c) Lighting cables (220V-AC) will be laid between transformer, distribution board and each lighting implements.
- (d) Earthing work is required for steel equipment, piping and structure adequately.
- (f) EIS should be designed and constructed for primary power supplying work between the existing substation and the receiving board at the new substation in W.W.T control room.

2) Instrumental Design

- (a) The center instrument panel will be installed at W.W.T. control room. Indicators, recorders, alarms and sequence timers etc. will be mounted on the board, and W.W.T. control system can be designed so as to be operated automatically by the center control panel.
- (b) Control cables (220V-AC, 24V-DC) will be laid between transformer, center panel and each instruments at field
- (c) Electric implements and instruments are applied to tropical and dust proof type.
- (d) Control valves are operated pneumatically by compressed air.

6 . Consideration in design

6.1 Location of Plant

- (1) All equipment will be installed outdoor except dehydrator unit to protect noise.
- (2) The plant (including piping and cable) layout should be designed considering and operability maintenance of equipment, instruments, piping and cables.
- (3) All W.W.T area is classified as non-hazardous.

6.2 Other requirements

- (1) Operation day of W.W.T. is designed as 330 days a year.

- (2) A spare pump is provided for all pumps operated in normal.
- (3) Holding capacity of chemical tanks is designed as 1 week for normal condition.
- (4) The W.W.T. control room will have the following rooms:
 - 1) Center panel room (operator working room)
 - 2) Electric substation
 - 3) Mini. laboratory
 - 4) Toilet
 - 5) Locker room
 - 6) Warehouse
- (5) Mini-laboratory will provide the following lab-equipment:
 - 1) Jar tester (Coagulation / flocculation & sedimentation test)
 - 2) pH meter, Electric conductivity, Turbidity meter, Water content meter
 - 3) Simplified balance
 - 4) Glass ware for sampling and test

7. Discussions

7.1 Study of Gypsum (CaSO_4) Recovery

The Wastewater Treating Plant on the Basic Design (Original Case) has Gypsum Recovery Unit. In this modified case, H_2SO_4 concentration in wastewater is lower than the original case. It was studied by neutralization test in the laboratory that gypsum recovery is feasible or not in this case.

- (1) Product of gypsum will be decreased due to low H_2SO_4 concentration comparing to the original case.
- (2) Gypsum recovery plant is complicated and expensive, and running cost and manpower will increase.
- (3) Purity of gypsum may not be pure due to mixture of ferrous sulfate.
- (4) Settling velocity of sludge will decrease by removing gypsum, and sludge volume will be almost same as removing of gypsum or not.

As mention the above, gypsum recovery unit is not applied in this basic design (modified case).

7.2 Study of Two Step Separation

In general, settling velocity of high concentration sludge is small so that large surface area is required to separate sludge and water.

Two step separation method was studied (refer to Fig-3);

- (1) 1st stage separation


Gypsum sludge which produced at pH 3-4 by adding CaO is separated and removed at 1st sedimentation tank.

(2) 2nd stage separation

CaO is added to supernatant at pH 3-4 until it become around pH9. Then, sludge is separated and removed. But, sludge volume is not so decreased instead of gypsum sludge is removed at 1st stage separation (pH3-4). And settling velocity of sludge became smaller than 1st stage separation, therefore the surface area of settling basin can not be small and not efficiency.

As a result, two step separation can not be applied in this modified basic design.

[One Step Separation]



[Two Step Separation (Gypsum Recovery)]




Fig.-3 Block Flow Diagram of One/Two Step Separation

7.3 Oxidation by Aeration

Oxidation (aeration) test was tried using rinsing water of EIS at the laboratory. Air is blown into neutralized slurry at pH 8.5-9 (pH 9 is upper limit of disposal regulation).

Color of slurry gradually changed from dark green to brown (approx.20min.).

As a result, Fe^{2+} was completely removed, but at below pH 8.5 residual Fe^{2+} was detected in supernatant of sample.

7.4 Selection of Polymer

Settling velocity of slurry (flocs) after neutralization at pH 8.5-9 is very small in case of without any coagulant. Effect of polymer as coagulant was tested using Jar Tester at the laboratory. The results of test are as follows;

(1) Cation and anion polymer purchased in Cairo were used.

And it was found that coagulation/flocculation effect of each polymer is remarkable.

(2) Cation polymer is more effective than anion polymer.

(3) Suitable dosing rate of cation polymer is enough around 0.05mg/l based on Jar Test.

7.5 Filtration Effect

At the original basic design, Sand Filter (sand, anthracite as filter media) is planned to provide because of demonstration purpose.

As a result of neutralization test at the laboratory, total suspended solids (TSS) in supernatant at pH 8.5-9 may be less than 30mg/l of disposal regulation.

Therefore, actual wastewater treating plant is not necessary Filter Unit.

7.6 Disposal of Sludge Cake

(1) Sludge hopper

By calculation result, 4-ton/h sludge cake will be generated continuously at average flow rate. In original basic design, sludge cake was piled up outdoors near the plant. In this modified basic design, 2 sets of elevated sludge cake hopper ($24\text{m}^3 \times 2\text{sets}$) are provided to store and to be easy to load sludge cake on a damp truck.

(2) Sludge Cake Disposal

Sludge cake will be disposed to the Desert under management. Metal hydrates such as $\text{Fe}(\text{OH})_3$, $\text{Pb}(\text{OH})_2$, $\text{Zn}(\text{OH})_2$ are contained in sludge cake. That hydrate may not solve into water unless acid rain falls, then they become to metal oxides such as PbO_2 , ZnO , Fe_2O_3 at last. But, solution possibility of metal hydrate is not zero completely. Therefore the disposal place at Desert should be managed and metals in permeant water from sludge should be monitored until safety is confirmed.

7.7 Total Dissolved Solids (TDS)

(1) Regulation in Egypt

TDS limitation is specified at Wastewater Discharge Regulation in Egypt.

- The most stringent limitation 800 [mg/l]
- middle 1,200[mg/l]
- Others 2,000[mg/l]

High concentration of H_2SO_4 is contained in acid wastewater and a large amount of CaO is added to neutralize. At this reaction, gypsum ($CaSO_4$) will generate and settle. But, approx. 2,000mg/l of gypsum saturates in water and other substances may contain. Therefore, in order to be met the regulation, dilution by a large amount of fresh water or desalination process should be applied to remove TDS.

(2) Desalination Plant

There are a few kind of desalination process, such as Reverse Osmosis (RO), Ion exchange membrane, evaporator. etc. All desalination plants are very expensive in both construction cost and maintenance cost. And also a little condensed liquid may produce from all desalination plants.

As a result, in this modified basic design, TDS limitation in the regulation is neglected

(3) Other Industrial Wastewater

Acid or alkali wastewaters of high TDS are discharged from many factories. And, the Regeneration wastewater of ion exchanger resin is discharged from the factories that high-pressure steam is used. This wastewater is contained high concentration of neutralized salt or soluble substances if neutralized, therefore TDS concentration can not be met the regulation in Egypt.


8. Performance Guarantee

The basic design (Original, Modified) of Neutralization Plant of EIS is designed based on our survey data during limited short period and given data by EIS. This design procedure may be useful.

But, it is recommended to improve the existing Pickling Plant, Rinsing Plant and Utility system and its operation management. As a result, wastewater flow rate and qualities may change from our design basis. Therefore, if the new neutralization plant will be designed and constructed by yourself after some improvements, it is required to verify and settle the design conditions based on supplemental wastewater survey, then the detail design should be proceeded to be satisfied of the specified performance of plant.

This basic design (modified case) is only reference. Therefore, the Study Team can not guarantee the plant performance if any body will construct the new neutralization plant based on this basic design (modified case) package in the future.

COLD ROLL MILL FACTORY



- ◆ Flow Measuring Point; No. 1 or No. 2 or No. 3
- ◆ Sampling Point; No. 2 or No. 3

FLOW MEASUREMENT AND SAMPLING OF RINSING WASTEWATER

Client: JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
Project Name: THE STUDY ON INDUSTRIAL WASTE WATER POLLUTION CONTROL
IN THE ARAB REPUBLIC OF EGYPT

Factory Name: EGYPTIAN IRON AND STEEL CO.

BASIC DESIGN
(MODIFIED)

Document Title: CALCULATION SHEET
FOR
W.W.T. DEMONSTRATION PLANT

Issued Date September 2000

Consultant: JICA STUDY TEAM
CHIYODA DAMES AND MOORE CO.
CHIYODA CORPORATION

1. Object

This design calculation sheet is applied to the study of W.W.T. Recommendation Plant planning for [Egyptian Iron and Steel Co.] .

2. Wastewater to be treated

Rinsing Water and Leakage Water except Spent Sulfuric Acid.

3. Design Conditions

- (1) Waste management system in the Factory should be organized, and operated adequately under the responsible managers.
- (2) Suitable routine works, periodical maintenance should be conducted in the whole company.

4. Contents of Wastewater Treatment plant

- (1) Pre-treatment : Equalization Tank
- (2) Primary Treatment : Neutralization/Oxidization
- (3) Secondary Treatment : Sedimentation
- (4) Sludge Treatment : Centrifuge

5. Design Basis

5.1 Qualities and Quantities of Influent Wastewater

Shown on Table-1.

5.2 Qualities and Quantity of Treated Water

The Law 48/82 Non potable Surface Water (Industrial) is to basic design basis.

Treated water qualities are shown on Table-1.

Table-1 Design Basis of Wastewater Qualities and Quantities

Items	Rinsing Water	Leakage water	Acid Waste.	Treated Water	Law48/82
Flow (Max.) [m ³ /h]	80	10	90	90	—
Flow (Nor.) [m ³ /h]	35	5	40	40	—
p H [-]	0.5 ~2.0		0.5 ~2.0	8 ~9	6 ~9
H ₂ SO ₄ [mg/L]	2,025	21,800	4,300	—	—
FeSO ₄ [mg/L]	2,025	21,800	4,300	—	—
Oil & Grease [mg/L]				< 5	< 5
T D S [mg/L]					< 800
Water Temp. [°C]	37 ~49		< 35	< 35	< 35

Note: Rinsing water and leakage water qualities are based on flow maximum case.

6. Unit Design

6.1 Acid Wastewater Collection (Out of Battery)/Receiving Pit

The rinsing water and leakage water are stored in Receiving Pit and pumped to Equalization Tank.

(1) Design Condition

- 1) Retention time : $Tr = 0.5 \text{ h}$
- 2) Specification : Rectangular, Underground, Reinforced Concrete with resin Lining

(2) Sizing

- 1) Required Volume : $Vr = 45 \text{ m}^3$
- 2) Effective Height : $Hr = 1.5 \text{ m}$
- 3) Required Area : $Ar = 30 \text{ m}^2$
- 4) Dimension : Take $5,000^W \times 6,000^L \times 6,000^H$ (effective 1,500^H)

6.2 Equalization Tank

The acid wastewater from Acid Wastewater Pump is stored in the Equalization Tank for equalization of wastewater quantities and qualities for the further treatment.

(1) Design Conditions

- 1) Quality of Wastewater: Shown on Table-2
- 2) Retention Time : 6 h
- 3) Specification : Vertical cylindrical, 1 set
- 4) Others : Air bubbling device

(2) Sizing

- 1) Required Volume : 540 m^3
- 2) Effective Height : 9 m (take)
- 3) Required Area : $Ac = Q/Ah = 60 \text{ m}^2$ Diamete 8.74
Take : $8,719^\phi \times 10,635^H$ (Chiyada Standard Tank)
- 4) Air Bubbling Device
 - a) Required Air (design base): $3 \text{ Nm}^3/\text{m}^2/\text{h}$
 - b) Required Air Quantity: $180 \text{ Nm}^3/\text{h} = 3 \text{ Nm}^3/\text{min}$ (take)

6.3 1st Neutralization Tank

(1) Design Conditions

- 1) Retention Time : 0.5 h
- 2) Specification : Vertical cylindrical, 1 set
- 3) Others : Mixing device

(2) Sizing

- 1) Required Volume : 45 m^3
- 2) Effective Height : 4.5 m (take)
- 3) Required Area : $Ac = Q/Ah = 10 \text{ m}^2$ Diamete 3.57
Take : $3,872^\phi \times 4,595^H$ (Chiyada Standard Tank)

(3) Generated Gypsum


a) H₂SO₄ concentration : 4,300 mg/L

b) Lime concentration : 10 %

c) Solubility of Gypsum: 2,000 mg/L


d) Generated Gypsum : W= 679 kg/h

Actual generated Gypsum W' = 499 kg/h



98 : 74 = 172

e) Required Lime : W1= 292 kg/h ≐ 3,000 L/h as 10 % Ca(OH)₂



56 : 74

Required Lime Stone: Ws= 221 kg/h

6.4 2nd Neutralization Tank

(1) Design Conditions

- 1) Retention Time : 0.5 h
- 2) Specification : Vertical Cylindrical, 1 set
- 3) Others : Air mixing device

(2) Sizing

- 1) Required Volume : 45 m³
 - 2) Effective Height : 4.5 m (take)
 - 3) Required Area : Ac= Q/Ah= 10 m² Diamete 3.57
- Take : 3.872^φ × 4.595^H (Chiyada Standard Tank)

(3) Generated Sludge


1) FeSO₄ concentration: 4,300 mg/L

2) Lime concentration : 10 %


3) Generated Sludge : Wt= 1,210 kg/h as dry base

from Fe(OH)₃ W1= 272 kg/h=(22.5 %)

from CaSO₄·2H₂O : W2= 438 kg/h



152 : 74 = 172




107

from 1st Neutr. W3= 499 kg/h Total gypsum= 937 kg/h=(77.5 %)

4) Dewatered Sludge : Wg= 4 ton/h= 97 ton/day

Water content = 70 %

5) Required Lime (2nd) W1= 188 kg/h ≐ 1,900 L/h as 10 % Ca(OH)₂



56 : 74

Required Lime Stone: Ws= 143 kg/h Total Lime Stone= 364 kg/h as 100 %


6) Total Lime Feed: QT= 4,900 L/h

6.5 Flocculation Tank

- 1) Retention Time : 0.25 h (take)
- 2) Required Volume : $V = 23 \text{ m}^3$
- 3) Specification : Vertical Cylindrical, Carbon Steel with Epoxy Coating
- 4) Number of Required : 1 set
- 5) Dimension : $H = 3.5 \text{ m (take)}$ Req'd Area = 6 m^2
 $D = 2.86 \text{ m}$
Take : $2,860^d \times 3,500^H \times 1 \text{ set}$

6.6 Clarifier

- 1) Surface Load : $L_s = 1.5 \text{ m}^3/\text{m}^2/\text{h (take)}$
- 2) Required Area : $A_s = 63 \text{ m}^2$
- 3) Specification : Vertical Cylindrical, Carbon Steel with Epoxy Coating
- 4) Number of Required : 1 set
- 5) Retention Time : $T_s = 2 \text{ h (take)}$
- 6) Dimension : $H = 3 \text{ m (take)}$
 $D = 9.0 \text{ m}$
Take : $10,000^d \times 4,500^H \times 1 \text{ set}$



- 7) Sludge Draw off (5%) : $Q_s = 24 \text{ m}^3/\text{h}$
- 8) Sludge recycle : $Q_r = 4 \text{ m}^3/\text{h}$
 (Generated gypsum*30 % at 1st Neutr.)

6.7 Sludge Thickener

- 1) Surface Load : $V_{ss} = 0.5 \text{ m}^3/\text{m}^2/\text{h}$
- 2) Total Solids : $L_{to} = 1,210 \text{ kg/h}$
- 3) Sludge Concentration: $C_s = 8 \%$
- 4) Required Area : $A_{th} = 48 \text{ m}^2$
- 5) Diameter : $D_{PO} = 7.85 \text{ m}$
Take: $8,500^d \times 4,500^H \times 1 \text{ set}$
- 6) Centrifuge feed rate : $Q_c = 15 \text{ m}^3/\text{h}$

6.8 Polymer

(1) Polymer A for Coagulation

- 1) Dosing Ratio : 0.1 mg/L
- 2) Concentration : 0.5 wt %
- 3) Specific Gravity : 1
- 4) Injection Rate : $Q_{ph} = 1.8 \text{ L/h}$
- 5) Tank Volume : $V_{ph} = 0.3 \text{ m}^3 (7 \text{ days})$
- 6) Height : $H_{PO} = 0.6 \text{ m (take)}$ $A_{PO} = 0.50 \text{ m}^2$
- 7) Diameter : $D_{PO} = 0.8 \text{ m}$
Take: $800^d \times 1,000^H \times 1 \text{ Set}$

(2) Polymer-B for Dewatering

- 1) Dosing Ratio : 0.2 % as dry SS
- 2) Injection Rate : $W_p = 2.4 \text{ kg/h}$
- 3) Concentration : 0.5 wt %
- 4) Specific Gravity : $Q_{ph} = 484 \text{ L/h} \Rightarrow \text{Continuous Injection System}$

6.9 Air Blower

- 1) Feed ratio : $Q_f = 1 \text{ Nm}^3/\text{m}^3\text{-H}_2\text{O}$
- 2) Required Air : $Q_a = 90 \text{ Nm}^3/\text{h} = 1.5 \text{ Nm}^3/\text{min}$
- 3) Total Air : $Q_t = 270 \text{ Nm}^3/\text{h} = 4.5 \text{ Nm}^3/\text{min}$

6.10 Treated Water Pond

- 1) Retention time : $T_r = 0.5 \text{ h}$
- 2) Specification : Rectangular, Underground, Reinforced Concrete
- 3) Required Volume : $V_r = 45 \text{ m}^3$
- 4) Effective Height : $H_r = 2 \text{ m}$
- 5) Required Area : $A_r = 22.5 \text{ m}^2$
- 6) Dimension : Take $4,500^W \times 5,000^L \times 2,500^H$ (effective $2,000^H$)

6.11 Sludge Pit

- 1) Retention time : $T_r = 3 \text{ h}$
- 2) Specification : Rectangular, Underground, Reinforced Concrete
- 3) Required Volume : $V_r = 45 \text{ m}^3$
- 4) Effective Height : $H_r = 2 \text{ m}$
- 5) Required Area : $A_r = 23 \text{ m}^2$
- 6) Dimension : Take $4,500^W \times 5,000^L \times 2,500^H$ (effective $2,000^H$)

6.12 waste Water Pit

- 1) Retention time : $T_r = 2 \text{ h}$
- 2) Specification : Rectangular, Underground, Reinforced Concrete
- 3) Required Volume : $V_r = 40 \text{ m}^3$
- 4) Effective Height : $H_r = 2 \text{ m}$
- 5) Required Area : $A_r = 20 \text{ m}^2$
- 6) Dimension : Take $4,500^W \times 5,000^L \times 2,500^H$ (effective $2,000^H$)

6.13 Lime Feeder

Based on vendor specification