

## 第 6 章 送配電設備

## App. 6-4-1 PRICE LIST

No.	Article	Description	Unit	Unit Price (SB\$)
1	ACSR 42mm <sup>2</sup> "APPLE"		m	1.64
2	ACSR 66mm <sup>2</sup> "BANANA"		m	3.43
3	ACSR 10mm <sup>2</sup> "CHERRY"		m	5.90
4	AAC 77mm <sup>2</sup> "MARS"		m	2.45
5	AAC 124mm <sup>2</sup> "MOON"		m	5.28
6	ACSR/AC"QUINCE"		m	1.93
7	XLPE 4x25mm <sup>2</sup> cable		m	10.50
8	XLPE 4x50mm <sup>2</sup> cable	0.7kg/m	m	16.02
9	XLPE 4x95mm <sup>2</sup> cable	1.35kg/m	m	29.98
10	Dead-end hard. for BANANA		p.c.	44.98
11	Dead-end hard. for APPLE		p.c.	60.00
12	Dead-end hard. for CHERRY		p.c.	103.35
13	11kV Insulator 254mm		p.c.	29.00
14	11kV Insulator 16mm Ball		p.c.	36.20
15	11kV Pin Insulator "A"		p.c.	16.34
16	LV Pin Insulator "B"		p.c.	4.60
17	Steel Pole 3.6m Sec. 2	for 11kV line	p.c.	281.13
18	Steel Pole 3.6m Sec. 3	for 11kV line	p.c.	228.89
19	Steel Pole 3.6m Sec. 4	for 11kV line	p.c.	267.85
20	Steel Pole 3.6m Sec. 5	for 11kV line	p.c.	363.52
21	Steel Pole	100 x 9 for LV line	p.c.	1,295.27
22	Crossarm 101 x 50mm x 10kg/m		p.c.	109.07
23	Steel crossarm bracket	No. 2 sect	p.c.	207.60
24	Steel crossarm bracket	3.6m	p.c.	203.75
25	Steel crossarm bracket	3.6m	p.c.	255.36
26	Tr 1000kVA	S/N 36964	each	31,504.10
27	Tr 750kVA	S/N 37137	each	24,245.80
28	Tr 500kVA	S/N 43641	each	30,949.40
29	Tr 1000kVA	S/N 36970	each	42,688.60
30	Tr 300kVA	ABB	each	35,156.60
31	Tr 200kVA	ABB	each	20,413.00
32	Tr 300kVA 11kV/415V	3P S/N 50232	each	20,080.00
33	Tr 300kVA 11kV/415V	with D/S S/N 15368	each	34,667.40
34	Tr 300kVA 11kV/415V		each	47,100.00
35	Tr 500kVA		each	79,063.09
36	Tr 200kVA 11kV/415V 3P		each	28,592.80
37	Tr 500kVA 33/11kV	Outdoor, Ground mopunting	each	830,610.60
38	Tr 50kVA 11kV/415V Dy11	BBC 3P Pole mounting	each	10,252.34
39	Tr 100kVA 11kV/415V Dy11	BBC 3P Pole mounting	each	18,439.32
40	Tr 200kVA 11kV/415V Dy11	BBC 3P Pole mounting	each	27,286.00

## App. 6-4-1 PRICE LIST

No.	Article	Description	Unit	Unit Price (SB\$)
41	Tr 300kVA 11kV/415V Dy11	BBC 3P Ground mounting	each	34,692.59
42	Tr 500kVA 11kV/415V Dy11	BBC 3P Pad mounting	each	83,482.98
43	Ring main unit SDAF3		p.c.	32,557.53
44	Switch SDAF		p.c.	12,516.00
45	Tr 500kVA w/main ring unit	S/N 5286	p.c.	47,269.03
46	Double oil switch SD2		p.c.	10,749.08
47	Tr 500kVA w/main ring unit	S/N 51514	p.c.	42,473.80
48	Tr 10kVA		p.c.	2,870.30
49	Tr 15kVA 11kV 3P	S/N 309224-309227	p.c.	4,442.00
50	Auto ring main unit SDAF3	3P cable 185mm2 ABB	p.c.	19,516.50
51	Triple oil switch SD3	3P cable 185mm2 ABB	p.c.	22,994.00
52	Tr 50VA 11kV/415V	Outdoor, Pole mounting	p.c.	12,958.55
53	Lightning arrester	12kV 10kA XBE 242	p.c.	542.96
54	Lightning arrester	30kV XBE 30A3	p.c.	814.67
55	Air break SW 11kV 600A	3 insulator/P D169H/1C	p.c.	5,844.60
56	Air break SW 11kV 600A	2 insulator/P D459H/1C	p.c.	6,427.00
57	LV 400A fuse SW		p.c.	372.58
58	D/D fuse SW 3P 11kV	D246/11	p.c.	950.00
59	D/D fuse SW 1P 11kV 100A	S/N 7242181	p.c.	282.40
60	Street column		set	1,770.20
61	33kV XLPE Al Cable	25mm2	m	90.63
62	33kV XLPE Al Cable	240mm2	m	192.28
63	33kV XLPE Cu Cable	150mm2	m	229.09
64	Joint kits	for 25mm2 Al XLPE	each	4,062.50
65	Joint kits	for 240mm2 Al XLPE	each	4,822.00
66	Joint kits	for 150mm2 Al XLPE	each	4,772.00
67	Termination kits	for 25mm2 Al XLPE	each	2,281.25
68	Termination kits	for 240mm2 Al XLPE	each	2,572.00
69	Termination kits	for 150mm2 Al XLPE	each	2,315.00
70	Cover tile	for underground cable	km	18,750.00
71	Warning tape		km	1,093.75

Appendix 6-6-1 Monthly Maximum Mean Temperature

SOLOMON ISLANDS METEOROLOGICAL SERVICE  
CLIMATOLOGICAL DATA

STATION : HONIARA

ISLAND: GUADALCANAL

YEAR : 1951 - 1997

LATITUDE: 09 25 'S

LONGITUDE: 160 03 'E

ELEVATION : 7.9 M

YEARS	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
1951	31.5	30.5	29.8	30.4	30.6	31.1	30.2	30.4	30.4	31.0	31.2	31.3
1952	30.7	30.9	30.5	29.8	30.9	30.2	29.8	30.6	30.2			
1953	31.1	30.6	29.8	29.6	29.6	30.2	29.3	29.1	30.0	30.5	30.7	30.7
1954	30.5	30.0	30.5	30.9	30.8	30.9	30.6	30.8	31.4	30.9	30.6	30.4
1955	31.1	30.9	29.7	31.0	31.2	30.7	30.2	30.9	30.8	31.2	30.5	29.5
1956	30.8	30.0	29.9	31.0	31.6	31.0	30.9	31.3	31.8	31.5	31.0	30.6
1957	30.5	29.8	29.7	30.5	30.0	30.0	30.2	30.6	30.1	30.3	30.8	30.8
1958	31.2	31.1	31.1	30.1	30.5	29.9	30.2	31.0	31.1	31.1	30.9	29.9
1959	30.4	30.4	30.2	30.4	30.4	30.0	30.1	29.9	29.7	30.5	30.8	30.5
1960	30.8	30.0	29.9	30.1	31.1	30.5	30.0	30.8	30.9	30.6	31.5	31.1
1961	30.7	31.1	30.6	31.1	31.1	30.9	29.7	30.6	30.4	30.6	30.6	31.2
1962	31.1	30.4	30.9	30.3	30.4	30.1	30.6	30.5	30.9	31.5	30.5	30.1
1963	30.9	30.7	30.2	30.5	30.8	30.9	29.8	30.3	30.2	29.6	30.1	30.4
1964	30.6	30.8	30.7	30.7	30.8	30.3	30.5	30.6	31.4	31.1	30.7	30.5
1965	30.3	30.6	29.7	30.3	30.0	29.1	28.4	29.1	30.1	30.4	30.2	30.5
1966	31.1	31.0	30.4	30.8	30.5	30.7	30.6	31.0	30.9	31.1	30.5	30.4
1967	29.9	29.8	29.9	30.3	30.6	30.8	30.4	30.1	30.6	29.9	30.1	31.1
1968	30.6	30.1	30.6	30.3	31.1	30.7	29.7	30.2	30.4	30.6	30.7	30.3
1969	30.8	30.5	30.8	31.1	31.4	30.7	30.2	30.1	30.8	31.1	31.2	30.3
1970	31.3	30.5	30.6	30.2	30.6	30.2	30.2	30.8	30.6	30.2	30.6	30.5
1971	30.2	30.6	29.3	30.3	30.6	30.4	30.2	30.7	30.7	30.7	30.9	30.3
1972	29.6	30.9	30.1	30.3	30.1	29.6	29.7	29.4	30.0	30.4	31.4	30.6
1973	31.4	30.4	30.5	30.6	30.3	30.8	30.1	30.6	30.9	30.4	30.6	30.3
1974	30.1	29.8	30.1	30.6	30.7	30.6	30.9	30.9	30.8			
1987			31.2	31.0	30.8	31.4	30.7	30.9	31.4	31.3	31.6	31.0
1988	30.7	30.8	32.0	31.2	31.9	31.0	30.6	30.8	30.8	30.8	30.6	29.8
1989	30.4	29.7	30.5	30.5	30.4	31.0	31.3	31.8	31.6	32.1	32.9	31.2
1990	31.5	31.8	31.3	31.4	31.6	31.2	30.8	31.6	31.2	32.3	31.9	31.4
1991	31.4	31.1	31.5	31.9	31.3	31.1	30.4	30.6	30.3	30.9	31.1	32.3
1992	31.7	30.5	31.1	31.1	31.0	30.8	30.2	30.9	31.0	30.9	30.6	31.4
1993	31.6	31.1	31.4	31.3	30.5	30.5	29.9	29.7	30.1	30.7	31.9	31.6
1994	31.4	31.0	31.4	31.3	30.9	30.3	30.0	30.4	30.7	31.3	31.9	31.5
1995	32.0	31.5	30.4	31.6	31.4	31.7	32.2	32.0	31.9	31.6	32.6	31.4
1996	31.1	31.7	31.2	31.9	31.2	31.1	31.4	31.5	31.7	31.6	31.7	31.2
1997	31.4	30.8	30.7	31.0	31.3	30.7	32.1	30.5	30.1	29.9	31.4	32.1
Aver	30.8	30.6	30.5	30.7	30.8	30.6	30.3	30.6	30.7	30.9	31.0	30.8
Lowest	29.6	29.7	29.3	29.6	29.6	29.1	28.4	29.1	29.7	29.6	30.1	29.5
Highest	32.0	31.8	32.0	31.9	31.9	31.7	32.2	32.0	31.9	32.3	32.9	32.3
Entries	34	34	35	35	35	35	35	35	35	33	33	33

SOLOMON ISLANDS METEOROLOGICAL SERVICE  
CLIMATOLOGICAL DATA

STATION : HONIARA

ISLAND: GUADALCANAL

YEAR : 1951 - 1997

LATITUDE: 09 25 'S

LONGITUDE: 160 03 'E

ELEVATION : 7.9 M

YEARS	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
1951	27.1	26.6	26.2	26.6	26.4	26.6	25.9	26.2	26.4	26.7	27.1	27.1
1952	27.2	27.3	26.9	26.4	26.9	26.5	26.1	26.5	26.4			
1953	27.1	26.7	26.3	26.0	25.8	26.3	25.7	25.7	26.1	26.5	26.8	26.7
1954	26.8	26.4	26.7	26.8	26.8	26.5	26.4	26.3	26.7	26.6	26.5	26.7
1955	27.0	26.9	26.2	26.7	26.7	26.4	26.2	26.3	26.1	26.7	26.4	25.9
1956	26.4	26.4	26.1	26.6	27.1	26.7	26.6	26.8	27.1	27.2	26.9	27.0
1957	26.8	26.3	26.3	26.8	26.5	26.0	26.1	26.5	26.5	26.6	26.7	27.0
1958	27.1	27.3	27.2	26.9	26.8	26.2	26.1	26.5	27.0	27.0	26.8	26.5
1959	26.9	26.7	26.8	26.8	26.8	26.5	26.2	25.9	25.8	26.6	26.8	26.9
1960	26.8	26.4	26.3	26.5	27.1	26.6	26.0	26.4	26.7	26.5	27.3	27.1
1961	27.2	27.2	26.9	27.0	27.0	26.7	26.0	26.4	26.4	26.4	26.5	27.0
1962	27.2	26.8	26.9	26.6	26.6	26.1	26.5	26.3	26.7	27.0	26.6	26.6
1963	26.9	26.7	26.6	26.7	26.7	26.8	26.1	26.5	26.3	26.1	26.2	26.6
1964	26.9	27.1	27.0	26.9	26.8	26.3	26.2	26.3	26.9	26.8	26.6	26.5
1965	26.6	26.7	26.3	26.4	26.2	25.6	25.2	25.3	26.2	26.2	26.2	26.8
1966	26.8	27.1	26.7	26.7	26.6	26.5	26.3	26.6	26.6	26.9	26.5	26.6
1967	26.5	26.4	26.4	26.5	26.7	26.7	26.2	26.2	26.5	26.2	26.2	27.0
1968	26.8	26.5	26.7	26.3	26.8	26.6	26.0	26.1	26.3	26.6	26.8	26.8
1969	26.8	26.9	27.1	27.4	27.4	26.8	26.3	26.2	26.7	27.0	27.2	26.8
1970	27.4	26.9	27.2	26.6	26.9	26.5	26.4	26.6	26.5	26.5	26.7	26.8
1971	26.6	26.7	26.0	26.5	26.6	26.3	26.0	26.3	26.6	26.5	26.8	26.5
1972	26.2	26.9	26.5	26.6	26.7	26.1	25.8	25.3	26.0	26.4	27.3	27.2
1973	27.5	27.0	27.2	27.0	26.6	27.0	26.2	26.5	26.9	26.6	26.9	26.8
1974	26.4	26.2	26.5	26.7	26.6	26.7	26.7	26.6	26.6			
1987			27.5	27.2	27.1	26.9	26.6	26.3	27.3	27.5	27.8	27.5
1988	27.4	27.5	28.1	27.4	27.9	27.2	26.8	26.9	27.0	27.0	27.0	26.6
1989	27.0	26.5	26.9	27.0	26.8	26.9	27.1	27.3	27.4	27.8	28.5	27.7
1990	27.9	27.7	27.8	27.6	27.8	27.3	27.0	27.3	27.2	28.0	27.9	27.7
1991	27.9	27.6	27.6	27.9	27.6	27.5	26.8	27.0	26.7	27.1	27.0	27.9
1992	27.7	27.1	27.3	27.2	27.3	27.2	26.7	27.0	26.9	27.0	26.9	27.6
1993	27.5	27.4	27.4	27.6	27.1	27.0	26.3	25.8	26.3	26.7	27.6	27.8
1994	27.7	27.4	27.6	27.5	27.3	26.6	26.4	26.8	26.6	27.1	27.4	27.5
1995	28.2	27.9	27.2	27.8	27.6	27.5	27.6	27.7	27.5	27.6	28.2	27.6
1996	27.5	27.8	27.5	27.8	27.4	27.2	27.4	27.3	27.6	27.5	27.5	27.6
1997	27.6	27.4	27.3	27.3	27.2	26.5	27.6	26.4	26.1	25.8	27.1	28.1
Aver	27.1	27.0	26.9	26.9	26.9	26.6	26.4	26.5	26.6	26.8	27.0	27.0
Lowest	26.2	26.2	26.0	26.0	25.8	25.6	25.2	25.3	25.8	25.8	26.2	25.9
Highest	28.2	27.9	28.1	27.9	27.9	27.5	27.6	27.7	27.6	28.0	28.5	28.1
Entries	34	34	35	35	35	35	35	35	35	33	33	33

SOLOMON ISLANDS METEOROLOGICAL SERVICE  
CLIMATOLOGICAL DATA

STATION : HONIARA

ISLAND: GUADALCANAL

YEAR : 1951 - 1997

Vavaya Ridge

LATITUDE: 09 25 'S

LONGITUDE: 160 03 'E

ELEVATION : 7.9 M

YEARS	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
1951	22.6	22.7	22.7	22.8	22.3	22.1	21.6	22.0	22.4	22.4	22.9	22.9
1952	23.6	23.6	23.3	23.0	22.9	22.8	22.4	22.3	22.5			
1953	23.1	22.9	22.9	22.5	22.1	22.4	22.1	22.2	22.2	22.5	22.8	22.6
1954	23.1	22.8	22.9	22.7	22.8	22.0	22.2	21.8	22.1	22.4	22.5	22.9
1955	22.9	22.9	22.7	22.4	22.2	22.1	22.1	21.6	21.4	22.1	22.3	22.4
1956	22.0	22.7	22.3	22.2	22.6	22.4	22.2	22.4	22.5	22.9	22.9	23.3
1957	23.1	22.8	22.9	23.1	22.9	22.0	22.1	22.4	22.9	22.8	22.6	23.2
1958	23.0	23.6	23.3	23.6	23.1	22.5	22.1	21.9	22.9	23.0	22.6	23.2
1959	23.4	23.1	23.4	23.2	23.2	22.9	22.3	21.9	21.9	22.7	22.7	23.3
1960	22.9	22.8	22.6	22.9	23.1	22.6	22.0	22.0	22.4	22.5	23.1	23.2
1961	23.6	23.3	23.2	23.0	22.8	22.4	22.3	22.3	22.3	22.3	22.4	22.8
1962	23.3	23.1	22.8	22.8	22.7	22.2	22.3	22.1	22.4	22.5	22.6	23.1
1963	22.9	22.7	23.0	22.9	22.6	22.8	22.3	22.7	22.5	22.6	22.4	22.9
1964	23.2	23.5	23.3	23.1	22.8	22.4	22.0	22.0	22.3	22.6	22.5	22.4
1965	22.9	22.9	23.0	22.6	22.5	22.1	21.9	21.5	22.3	22.0	22.1	23.1
1966	22.5	23.2	23.0	22.6	22.7	22.2	22.0	22.2	22.4	22.7	22.4	22.8
1967	23.0	23.0	22.8	22.8	22.8	22.5	22.1	22.2	22.4	22.4	22.3	23.0
1968	23.1	22.9	22.8	22.3	22.6	22.4	22.2	22.0	22.2	22.7	23.0	23.3
1969	22.7	23.3	23.4	23.8	23.4	22.9	22.5	22.3	22.5	22.8	23.2	23.4
1970	23.4	23.4	23.8	23.0	23.2	22.8	22.5	22.4	22.3	22.9	22.8	23.0
1971	23.0	22.7	22.7	22.8	22.7	22.3	21.9	22.0	22.4	22.2	22.6	22.7
1972	22.7	22.8	22.9	23.0	23.2	22.5	22.0	21.2	22.0	22.3	23.2	23.7
1973	23.5	23.6	23.9	23.5	22.8	23.2	22.4	22.3	22.9	22.8	23.2	23.3
1974	22.8	22.7	22.9	22.7	22.6	22.8	22.5	22.3	22.4			
1987			23.8	23.3	23.5	22.5	22.5	21.8	23.1	23.7	24.1	24.0
1988	24.0	24.1	24.2	23.6	23.9	23.4	23.0	23.1	23.2	23.2	23.5	23.4
1989	23.5	23.2	23.2	23.4	23.1	22.9	22.9	22.8	23.1	23.5	24.1	24.2
1990	24.2	23.6	24.2	23.8	23.9	23.4	23.1	23.1	23.3	23.8	23.8	24.0
1991	24.3	24.1	23.8	24.0	23.8	23.9	23.2	23.4	23.1	23.3	22.9	23.5
1992	23.7	23.7	23.6	23.4	23.6	23.6	23.1	23.1	22.7	23.2	23.3	23.7
1993	23.4	23.7	23.3	23.8	23.8	23.6	22.7	21.9	22.5	22.6	23.3	24.0
1994	24.0	23.9	23.9	23.8	23.7	22.9	22.8	23.2	22.5	22.9	22.9	23.4
1995	24.3	24.3	24.0	24.0	23.9	23.3	23.1	23.5	23.2	23.6	23.8	23.7
1996	23.9	24.0	23.8	23.8	23.5	23.4	23.4	23.1	23.4	23.3	23.3	23.9
1997	23.8	24.0	23.9	23.5	23.1	22.2	23.1	22.3	22.1	21.7	22.8	24.1
Aver	23.3	23.3	23.3	23.1	23.0	22.7	22.4	22.3	22.5	22.7	22.9	23.3
Lowest	22.0	22.7	22.3	22.2	22.1	22.0	21.6	21.2	21.4	21.7	22.1	22.4
Highest	24.3	24.3	24.2	24.0	23.9	23.9	23.4	23.5	23.4	23.8	24.1	24.2
Entries	34	34	35	35	35	35	35	35	35	33	33	33

# Appendix 6-6-4 Monthly Maximum Wind Gust (Knots)

Station: Honiara

Island: Guadalcanal

Year: 1954 - 1997

Latitude: 09 25'S

Longitude: 159 58'E

Elevation: 55.0 M


Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1954	W/10	S/10	NW/19	S/15	E/24	E/18	E/14	NE/25	NE/18	ENE/20	NE/15	E/10
1955	SW/18	NE/20	NE/15	E/15	E/15	E/12	SE/25	E/15	NE/15	E/35	N/20	NE/20
1956	S/10	NW/15	NW/15	E/15	S/10	E/15	E/15	E/20	NE/18	NE/15	NE/21	N/21
1957	SE/20	SSE/32	NW/27	S/23	SW/23	E/39	E/26	E/36	SE/26	NE/26	SSE/26	NE/23
1958	SE/30	NW/29	NW/32	NW/26	SE/24	NW/48	SE/25	SE/28	NE/28	NE/28	ENE/32	NE/25
1959	NW/35	N/33	NW/26	NE/28	NE/24	NE/27	SE/27	E/30	SE/34	SSW/23	SSW/30	NW/47
1960	SW/23	NW/22	NNE/39	NNE/23	SE/24	ESE/29	NNE/28	SSE/28	E/34	SE/28	NNE/27	NW/26
1961	NW/26	NW/29	SW/26	SE/32	ESE/37	ESE/30	SSE/31	SE/25	ENE/28	S/25	NE/37	NW/30
1962	SSW/26	SSW/37	NE/25	ESE/30	NW/30	SSE/35	ENE/31	E/37	SSE/35	ENE/28	SSW/33	NW/25
1963	NW/25	SW/28	NW/25	NE/35	SE/27	SSE/30	SE/34	SE/15	SE/27	N/30	NW/32	N/13
1964	NE/26	NW/24	NW/17	SSE/34	ENE/32	N/26	SE/30	SSE/28	SE/31	SSE/35	W/30	N/24
1965	ENE/30	NW/27	NW/34	N/27	N/26	S/23	SSE/26	SE/25	ESE/35	SE/29	SE/23	ENE/24
1966	SW/27	NE/30	NW/32	SW/28	ESE/29	SE/34	ESE/30	SE/34	SE/31	NE/34	NNE/36	NE/26
1967	N/43	NW/29	NW/67	NW/34	SSE/32	SSE/30	SE/30	SE/29	E/26	SSE/37	SSE/29	SW/25
1968	SSW/26	NW/41	NW/30	SSE/27	SSE/26	N/36	SE/30	SSE/31	SE/36	SE/34	ENE/16	SE/30
1969	NW/55	NW/31	S/27	NW/39	SE/36	SE/29	ESE/27	ENE/42	NNE/36	ESE/32	SSE/28	SSE/23
1970	SW/32	NW/35	NW/20	SSE/41	SSW/25	NNE/30	SSE/39	SSE/28	SSE/24	SSE/20	NE/28	W/36
1971	NW/39	SW/34	N/29	NW/27	NE/30	NE/30	N/31	ESE/41	ESE/31	SE/32	NW/28	NW/46
1972	NW/69	NW/33	NW/34	W/36	NW/40	SSE/50	E/27	S/19	SSE/28	S/30	NE/26	SSW/29
1973	SE/26	SW/28	NW/28	SE/27	N/32	ESE/29	NE/29	NE/40	NE/35	SE/37	NW/31	SE/24
1974	NW/35	NW/34	S/34	SSE/30	NNE/28	E/28	E/28	ESE/40	ENE/34			
1987			SSW/10	SSW/14	E/14	NE/14	E/18	ENE/24	NE/18	NE/15	NE/14	NE/08
1988	SW/12	NW/15	NW/14	E/14	E/15	ENE/20	ENE/22	E/20	E/18	NE/12	NW/08	NW/10
1989	SW/18	NW/10	NW/14	W/12	E/10	E/16	SSW/10	NE/16	ENE/15	ENE/17	ENE/17	ENE/20
1990	W/20	W/12	SW/17	S/20	E/14	SSE/10	NE/12	NNE/12	NE/12	NE/14	SW/12	N/16
1991	W/10	SSW/14	NE/18	NNE/13	NE/11	SE/15	S/18	ENE/11	NE/14	NE/10	SW/15	S/10
1992	NNE/13	W/13	W/11	W/11	ENE/13	NE/14	NE/15	ENE/15	ENE/17	ENE/15	ENE/15	ENE/12
1993	NE/15	SW/15	NW/14	E/14	E/12	E/14	NE/12	NE/18	E/16	ENE/17	E/14	NE/14
1994	SW/14	N/14	E/10	E/13	S/14	ENE/14	NE/11	NE/14	E/16	NE/18	NE/12	SSW/12
1995	NE/12	S/10	NW/10	NE/12	ENE/12	ENE/14	ENE/17	ENE/14	E/15	NE/15	ENE/18	SW/13
1996	S/10	E/12	E/13	NE/11	NE/12	SE/14	E/12	NE/17	S/14	ENE/15	NE/12	ENE/14
1997	W/15	NW/12	W/13	ENE/16	W/12	E/12	E/15	ENE/15	ENE/13	S/12	ENE/13	ENE/13

## Note:

Data from 1987 onwards only represents the highest wind speed picked from the 3 hourly observations and are not actual maximum wind gusts.

No data is available from Oct 1974 to Feb 1987

# Appendix 6-6-5 Geographical Distribution of Earthquakes in Solomon Islands





App. 6-6-6 EARTHQUAKES GREATER THAN MAGNITUDE 5.6  
IN THE SOLOMON ISLANDS FROM 1960 TO 1980

(1(3)3)

Year	Month	Depth	MB	MS	Year	Month	Depth	MB	MS
<b><i>Santa Cruz Islands</i></b>					1977	Aug	36	5.2	5.7
1960	Oct	40	6.0		1978	Aug	88	5.7	
1961	Jan	140	6.8		1979	May	33	5.5	5.9
	Jan	25	7.0			May	68	5.6	
1962	Apr	36	5.5		1980	Apr	33	6.0	6.1
	May	135	6.5 - 6.8			Jul	33	5.9	7.5
	Jul	114	6.6 - 6.8			Jul	33	5.6	
1963	Sep	43	6.3			Jul	37	5.3	5.9
	Sep	17	6.1			Jul	33	5.4	5.9
1965	Feb	86	5.7			Jul	33	5.2	6.7
	Aug	51	5.8			Jul	33	5.6	
	Dec	52	5.8			Jul	33	5.8	7.9
1966	Jun	228	6.1			Jul	33	5.7	
	Jun	60	5.5			Jul	33	5.6	
	Dec	56		7.7		Jul	79	5.7	
1967	Jan	154	5.5			Jul	80	5.9	
	Jan	133	6.0			Aug	33	5.7	6.3
	Mar	34	5.9			Aug	42	4.6	5.1
	Mar	24	5.9			Sep	62	5.5	
	Mar	49	6.0			Oct	33	5.3	6.2
	Nov	48	5.6			Nov	33	5.5	4.6
	Dec	33	5.5		<b><i>San Cristobal</i></b>				
1968	May	41	5.5		1960	Oct	93	6.2 - 7.0	
	Jun	33	5.5	6.1	1961	Mar	99	6.2	
	Oct	60	5.9		1963	May	33	5.8 - 6.0	
1969	Jan	32	6.2	6.8	1964	Oct	68	6.0	
	Jan	4	5.6	5.8	1965	Oct	65	5.5	
	Jul	34	5.5		1966	Jun	37	5.5	
1970	Jan	50	5.7	6.4	1966	Jul	33	5.5	
	Jan	50	5.5	5.5		Aug	70	5.7	
	May	50	5.9	6.1	1967	Jan	21	5.7	
1971	Nov	115	6.4		1970	Aug	33	5.7	5.8
	Nov	110	5.8			Dec	33	5.5	6.1
1972	Feb	102	6.2			Dec	36	5.3	6.5
	Sep	62	6.0			Dec	33	5.8	7.0
1973	Jan	97	5.8			Dec	72	6.1	
	Jun	146	5.5		1971	Feb	90	5.9	
	Dec	15	5.5	5.4		Mar	42	5.8	6.4
1975	Feb	33	5.4	5.5		May	45	4.6	5.7
	Sep	132	5.6		1972	Aug	34	5.2	6.0
	Sep	106	5.6			Aug	36	5.5	6.1
	Oct	54	6.6	7.0		Aug	33	5.2	6.1
	Nov	77	5.7			Aug	33	5.4	6.1
	Nov	60	5.9			Aug	56	5.9	
	Dec	33	6.0	5.8		Sep	56	5.5	
	Dec	88	5.5		1973	Jan	32	5.6	5.8
1976	Feb	39	5.4	5.6		Jan	32	5.0	5.9
	Mar	47	6.1	5.9		Jun	70	6.3	
	Mar	72	5.6		1975	Jul	79	5.9	
	Mar	59	5.8			Dec	33	5.6	5.7
	Apr	84	5.8		1976	Jun	61	6.2	6.6
1977	Jan	42	5.5	5.6		Jun	54	5.5	5.3
	Jan	25	5.7	5.2		Aug	43	5.5	5.2
	May	138	5.6			Sep	83	5.6	

Year	Month	Depth	MB	MS	Year	Month	Depth	MB	MS
1976	Oct	106	6.0		1977	Jun	11	b	5.7
1977	Aug	32	5.8	5.5		Jul	16	5.8	
	Sep	61	5.5		1978	Jan	73	5.5	
	Nov	70	5.6			Apr	46	6.2	5.9
	Nov	92	5.9		<b>Russell Islands</b>				
1978	Nov	33	5.8	6.9	1963	Jun	33	5.6	
	Nov	33	6.0		1964	Jun	17	5.6	
	Nov	33	5.6		1965	May	50	5.6	
	Nov	33	5.5	5.7	1974	Aug	59	5.5	
	Nov	33	6.3	7.1	1979	Nov	30	6.0	6.1
	Nov	33	5.7	6.1	<b>New Georgia Islands</b>				
	Nov	33	5.3	5.8	1963	Jul	33	5.8	
	Nov	33	5.6	5.4		Aug	33	6.1	
	Nov	33	5.9	5.9	1964	Jan	33	5.5	
	Dec	93	6.0			Jan	32	5.7	
	Dec	30	5.6	6.3		Dec	42	5.6	
1979	Oct	33	5.4	5.9	1965	Oct	20	5.6	
	Oct	22	6.1	7.1	1968	Jan	33	6.0	
	Oct	33	5.6			Jun	33	5.4	5.7
	Oct	33	5.7		1969	May	16	5.6	5.2
	Oct	33	5.8			Sep	15	5.8	6.1
	Oct	33	5.5			Sep	10	5.8	5.7
	Oct	33	5.5			Sep	33	5.6	
1980	Feb	68	5.9		1970	Apr	5	5.6	
<b>Guadalcanal</b>					1971	Sep	33	5.5	
1961	Jan	50	6.5 - 6.8		1974	Mar	50	5.8	
1963	Feb	30	6.5		1975	Apr	41	5.6	
1964	Jul	21	5.6			Nov	33	5.7	6.1
1965	Jul	41	6.0		1976	Nov	33	6.1	6.5
	Nov	41	6.0		1977	Mar	33	5.3	5.8
1966	Jun	34	6.0			Apr	33	5.7	
	Jun	23	7.2		1978	Sep	33	6.0	6.2
	Jun	19	5.6			Sep	16	5.5	
	Jun	41	5.7		1979	Feb	33	5.5	4.8
	Jun	15	5.6		1980	Feb	40	5.8	5.6
	Oct	36	5.6		<b>Mono and Shortland Islands</b>				
1968	Aug	538	6.2		1961	Feb	5	6.8	
1972	Jun	40	5.5		1966	May	37	5.5	
1973	Feb	62	5.9		1967	Apr	37	5.5	
1975	Oct	56	5.8			Apr	29	5.8	
1977	Apr	33	5.4	6.7		Sep	94	5.7	
	Apr	19	6.3	7.5	1968	Nov	169	5.7	
	Apr	33	6.8	7.5	1971	Sep	46	5.7	
	Apr	33	5.7		1973	Aug	62	5.8	
	Apr	33	6.1		1974	Jan	34	6.0	7.0
	Apr	33	5.5			Feb	40	6.2	7.1
	Apr	32	5.5			Feb	33	5.4	5.6
	Apr	32	5.5			Feb	33	5.3	5.8
	Apr	33	6.6	7.5		Feb	48	5.6	5.2
	Apr	33	5.8			Feb	33	5.2	5.5
	Apr	33	5.6	6.0		Feb	43	5.4	5.6
	Apr	33	5.6	5.6		Mar	47	5.4	5.7
	Apr	51	5.6	6.0		Mar	50	5.8	6.5
	May	19	5.5			Mar	33	5.7	6.6
	May	33	5.4	5.7		May	33	5.6	5.4

Year	Month	Depth	MB	MS	Year	Month	Depth	MB	MS
1974	Jun	70	5.5		<b>Malaita</b>				
1975	May	81	5.6		1963	Dec	69	5.5	
	Jul	49	6.6	7.9	1973	Jul	69	5.5	
	Jul	44	6.1	7.7		Jul	30	5.4	6.0
	Jul	47	5.7	6.8	1974	Jan	53	5.6	
	Jul	95	6.1		1979	Jan	93	5.7	
	Jul	33	5.5		<b>Santa Isabel</b>				
	Jul	36	5.7	6.1	1968	Jun	35	5.6	5.2
	Jul	70	5.5		1969	Jan	47	6.4	7.1
	Jul	42	5.6	5.7		Apr	77	5.7	
	Aug	73	5.6			Jun	62	6.0	
	Sep	54	5.6		1970	Jun	69	6.1	
	Sep	86	5.7			Aug	67	5.9	
	Dec	67	5.8		<b>Choiseul</b>				
1976	Mar	45	5.8	5.2	1968	Jul	134	5.6	
	Apr	33	5.1	5.5	1978	Sep	33	5.5	5.3
	Oct	56	5.5						
1977	Mar	31	5.5	5.8					
	Jul	33	6.4	7.2					
	Aug	58	5.9						
	Nov	75	5.7						

Note:

MB = Richter magnitude derived from body waves

MS = Richter magnitude derived from vertical ground


From;

Report No. 81/14, Honiara 1981

"The Regional distribution of Earthquakes greater than Magnitude 5.5 in the Solomon Islands from 1960 to 1980"

Geological Survey Division, Ministry of Lands, Energy & Natural Resources  
Solomon Islands Government

## 第 7 章 太陽光発電



# CATCHMENT AREAS

1:250,000 British Solomon Islands Protectorate


GUADALCANAL and THE FLORIDA ISLANDS

Map 2b

MAJOR ISLANDS WATERBED CATCHMENT AREA BOUNDARIES


Key No.	Name (where known)	Area (km <sup>2</sup> )	Key No.	Name (where known)	Area (km <sup>2</sup> )
1	Guadalcanal Catchment Area	2	111	Guadalcanal Catchment Area (small)	42
2	Vunaha	3	112	Chail	56
3	Kapiga, Kamabuku, Hapilapaga	5	113	Avail	6
4	Tanarua	22	114	Kaungu	2
5	Saua	28	115	Maitovu	26
6	Vuho	9	116	Maitu, Kama	10
7	Anuho	3	117	Komabu	9
8	Kama, Kama	118	118	Chauva	81
9	Fanua	4	119	Tangara	3
10	Maitu	9	120	Sandfly	1
11	Chumba	12	121	Gheva	4
12	Tamba	18	122	Komabu	5
13	Unuani	89	123	Kengere	2
14	Mae	51	124	Kengere	2
15	Mitanga	73	125	Mitanga	1
16	Kat	12	126	Kat	1
17	Kat	48	127	Kat	1
18	Kat	23	128	Kat	1
19	Taua (Haitu)	11	129	Haitu, Kachimu	90
20	Maitu	83	130	Vunaha, Kama	3
21	Rae	7	131	Suara	3
22	Maitu	2	132	Candara	4
23	Lumaga	286	133	Lumaga, Chivau	7
24	Tanarua	129	134	Maitu	12
25	Ma	7	135	Maitu	31
26	Maitu	221	136	Rae	3
27	Maia Creek	33	137	Kama	6
28	Maitu, Maitu	189	138	Kama	3
29	Saua	17	139	Maitu	11
30	Chauva	20	140	Kuraga	14
31	Maitu	210	141	Ka Chail	4
32	Ma	5	142	Anuho	4
33	Kamabuku	9	143	Ka Chail	4
34	Maitu	221	144	Tanarua	6
35	Maitu	388	145	Ma	8
36	Maitu	303	146	Kama	8
37	Maia	105	147	Tanarua	8
38	Maitu	148	148	Candara	8
39	Komabu	94	149	Small offshore islands	182
40	Maia	5			
41	Maia, Sua	112			
42	Maitu, Vail	87			
43	Tanarua	109			
44	Saua	174			
45	Maia	16			
46	Maia	11			
47	Maia	18			
48	Saua	10			
49	Kamabuku	25			
50	Maitu	82			
51	Maitu	12			
52	Maia	2			
53	Maia	2			
54	Maia	2			
55	Maia	2			
56	Maia	2			
57	Maia	2			
58	Maia	2			
59	Maia	2			
60	Maia	2			
61	Maia	2			
62	Maia	2			
63	Maia	2			
64	Maia	2			
65	Maia	2			
66	Maia	2			
67	Maia	2			
68	Maia	2			
69	Maia	2			
70	Maia	2			
71	Maia	2			
72	Maia	2			
73	Maia	2			
74	Maia	2			
75	Maia	2			
76	Maia	2			
77	Maia	2			
78	Maia	2			
79	Maia	2			
80	Maia	2			
81	Maia	2			
82	Maia	2			
83	Maia	2			
84	Maia	2			
85	Maia	2			
86	Maia	2			
87	Maia	2			
88	Maia	2			
89	Maia	2			
90	Maia	2			
91	Maia	2			
92	Maia	2			
93	Maia	2			
94	Maia	2			
95	Maia	2			
96	Maia	2			
97	Maia	2			
98	Maia	2			
99	Maia	2			
100	Maia	2			
101	Maia	2			
102	Maia	2			
103	Maia	2			
104	Maia	2			
105	Maia	2			
106	Maia	2			
107	Maia	2			
108	Maia	2			
109	Maia	2			
110	Maia	2			
111	Maia	2			
112	Maia	2			
113	Maia	2			
114	Maia	2			
115	Maia	2			
116	Maia	2			
117	Maia	2			
118	Maia	2			
119	Maia	2			
120	Maia	2			
121	Maia	2			
122	Maia	2			
123	Maia	2			
124	Maia	2			
125	Maia	2			
126	Maia	2			
127	Maia	2			
128	Maia	2			
129	Maia	2			
130	Maia	2			
131	Maia	2			
132	Maia	2			
133	Maia	2			
134	Maia	2			
135	Maia	2			
136	Maia	2			
137	Maia	2			
138	Maia	2			
139	Maia	2			
140	Maia	2			
141	Maia	2			
142	Maia	2			
143	Maia	2			
144	Maia	2			
145	Maia	2			
146	Maia	2			
147	Maia	2			
148	Maia	2			
149	Maia	2			
150	Maia	2			
151	Maia	2			
152	Maia	2			
153	Maia	2			
154	Maia	2			
155	Maia	2			
156	Maia	2			
157	Maia	2			
158	Maia	2			
159	Maia	2			
160	Maia	2			
161	Maia	2			
162	Maia	2			
163	Maia	2			
164	Maia	2			
165	Maia	2			
166	Maia	2			
167	Maia	2			
168	Maia	2			
169	Maia	2			
170	Maia	2			
171	Maia	2			
172	Maia	2			
173	Maia	2			
174	Maia	2			
175	Maia	2			
176	Maia	2			
177	Maia	2			
178	Maia	2			
179	Maia	2			
180	Maia	2			
181	Maia	2			
182	Maia	2			
183	Maia	2			
184	Maia	2			
185	Maia	2			
186	Maia	2			
187	Maia	2			
188	Maia	2			
189	Maia	2			
190	Maia	2			
191	Maia	2			
192	Maia	2			
193	Maia	2			
194	Maia	2			
195	Maia	2			
196	Maia	2			
197	Maia	2			
198	Maia	2			
199	Maia	2			
200	Maia	2			
201	Maia	2			
202	Maia	2			
203	Maia	2			
204	Maia	2			
205	Maia	2			
206	Maia	2			
207	Maia	2			
208	Maia	2			
209	Maia	2			
210	Maia	2			
211	Maia	2			
212	Maia	2			
213	Maia	2			
214	Maia	2			
215	Maia	2			
216	Maia	2			
217	Maia	2			
218	Maia	2			
219	Maia	2			
220	Maia	2			
221	Maia	2			
222	Maia	2			
223	Maia	2			
224	Maia	2			
225	Maia	2			
226	Maia	2			
227	Maia	2			
228	Maia	2			
229	Maia	2			
230	Maia	2			
231	Maia	2			
232	Maia	2			
233	Maia	2			
234	Maia	2			
235	Maia	2			
236	Maia	2			
237	Maia	2			
238	Maia	2			
239	Maia	2			
240	Maia	2			
241	Maia	2			
242	Maia	2			
243	Maia	2			
244	Maia	2			
245	Maia	2			
246	Maia	2			
247	Maia	2			
248	Maia	2			
249	Maia	2			
250	Maia	2			
251	Maia	2			
252	Maia	2			
253	Maia	2			
254	Maia	2			
255	Maia	2			
256	Maia	2			
257	Maia	2			
258	Maia	2			
259	Maia	2			
260	Maia	2			
261	Maia	2			
262	Maia	2			
263	Maia	2			
264	Maia	2			
265	Maia	2			
266	Maia	2			
267	Maia	2			
268	Maia	2			
269	Maia	2			
270	Maia	2			
271	Maia	2			
272	Maia	2			
273	Maia	2			
274	Maia	2			
275	Maia	2			
276	Maia	2			
277	Maia	2			
278	Maia	2			
279	Maia	2			
280	Maia	2			
281	Maia	2			
282	Maia	2			
283	Maia	2			
284	Maia	2			
285	Maia	2			
286	Maia	2			
287	Maia	2			
288	Maia	2			
289	Maia	2			
290	Maia	2			
291	Maia	2			
292	Maia	2			
293	Maia	2			
294	Maia	2			
295	Maia	2			
296	Maia	2			

A7-2



Appendix 7-5-1 Location of the Investigated Village(2/7)


### Map 4b












Key No	Name (where known)	Area (km <sup>2</sup> )	Key No	Name (where known)	Area (km <sup>2</sup> )	Key No	Name (where known)	Area (km <sup>2</sup> )
San Cristobal Catchment Areas			San Cristobal Catchment Areas (cont'd)			San Cristobal Catchment Areas (cont'd)		
1	Su'u	2	123		2	245		1
2	Gonururua	1	124		3	246		10
3	Haurua	8	125		4	247		1
4	Haurua	2	126		5	248		1.5
5	Tavata	6	127		6	249		1.8
6	Ribo	5	128		7	250		0.5
7	Ribo	2	129		8	251		3.4
8		2	130		9	252		1.5
9	Su'u	1	131		10	253		0.5
10	Wanarua	1	132		11	254		1
11	Wanarua	0.5	133		12	255		0.5
12	Wanarua	0.5	134		13	256		1.5
13	Wanarua	0.5	135		14	257		0.5
14	Wanarua	0.5	136		15	258		0.5
15	Wanarua	0.5	137		16	259	Aporo	0.5
16	Aute	0.5	138	Paghet	6	260		16
17	Rana	0.75	139		70	261		0.5
18	Wanarua	0.5	140		1	262		0.5
19	Wanarua	40	141		2	263		2
20	Rau	2	142		1	264		1
21	Wanarua	2	143		1	265		1
22	Manarua	2	144		8	266		2
23	Wanarua	2	145		1	267	Hunua	0.5
24	Wanarua	16	146		0.5	268		0.5
26	Manarua	1	147		1	269	Makia	0.5
27	Wanarua	1	148		1	270		0.5
28	Wanarua	1	149		2.5	271	Wanarua	0.5
29	Wanarua	0.8	150		4	272		0.5
29	Wanarua	3	151		0.5	273		0.5
30	Wanarua	3	152		1.5	274		1
31	Wanarua	24	153		2	275		0.5
32	Wanarua	38	154		0.5	276		0.5
33	Wanarua	158	155		0.5	277		0.5
34	Wanarua	85	156		0.5	278		0.5
35	Wanarua	8	157		1.5	279		0.5
36	Wanarua	2	158		2	280		2
37	Wanarua	5	159		2	281		0.5
38	Wanarua	2	160		2	282		1
39	Wanarua	5	161		1	283		0.5
40	Wanarua	1	162		0.5	284		0.5
41	Wanarua	2	163		1	285	Boro	0.5
42	Wanarua	17	164		0.5	286		0.5
43	Taru	89	165		1	287		13
44	Pura	21	166		1.5	288		1
45	Wanarua	1	167		0.5	289	Wanarua	0.5
46	Wanarua	1	168		1	290		0.5
47	Wanarua	1.5	169		0.5	291		0.5
48	Wanarua	4	170		0.5	292		16
49	Wanarua	1	171		0.5	293	Wanarua	1
50	Wanarua	4	172		0.25	294		1.5
51	Wanarua	1	173		1.5	295		0.5
52	Wanarua	4	174		2	296		1
53	Wanarua	64	175		1	297		1
54	Wanarua	223	176		1	298	Bawitwa	25
55	Wanarua	1	177		2	299		2
56	Wanarua	2	178		1	300	Tawata's	1
57	Wanarua	1	179	Wanarua	2	301		1
58	Wanarua	6	180		6	302		5
59	Wanarua	50	181	Baphara	1.5	303		1
60	Schano	2	182	Wanarua	4	304		1
61	Agua	2	183	Maruwa	0.5	305		3
62	Wanarua	8	184		2	306		6
63	Wanarua	8	185		1	307	Mattawa	1
64	Makua	57	186	Wau	9	308		2
65	Hao	120	187		20	309		5
66	Wanarua	1	188	Baphara	19	310		20
67	Mogho	1	189		31	311	Hadi	6
68	Wanarua	1	190	Mananghaji	36	312	Wanarua	3
69	Ngirigoro	3	191		1	313		10
70	Ghishoro	3	192		314	314	Eleria	41
71	Hore	2	193		0.5	315		3
72	Wanarua	8	194		0.5	316		10
73	Puepa	20	195		1	317	Aporo	0.5
74	Wanarua	2	196		0.5	318	Small offshore islands	0.5
75	Wanarua	2	197	Wanarua	33	319		0.5
76	Wanarua	2	198		8	320		1
77	Wanarua	0.5	200	Wanarua	12			
78	Wanarua	0.5	201		0.75			
80	Hunahua	4	202		28	318	Ugi Island Catchment Areas	4
81	Rano	246	203		2	319		1
82	B'arora	5	204		1	320		1
83	Witua	21	205		2	321		3.5
84	Wanarua	2	206		2	322	Ranangali	1.5
85	Wanarua	233	207		0.5	323	Wanarua	2.5
86	Wanarua	1	208		1.5	324	Wanarua	2.5
87	Hunahua	8	209		2.5	325	Wanarua	2.5
88	Wanarua	1	210		2	326	Wanarua	1.5
89	Wanarua	0.5	211		2	327		1.5
90	Wanarua	0.5	212		1.5	328		1.5
91	Wanarua	0.5	213		1	329		1.5
92	Wanarua	0.5	214		1	330		1.5
93	Wanarua	1	215	Magharita, Mogho	0.5	331	Uthua, 'Eia'sia	1.5
94	Hani	10	216		45	332	Wanarua	1
95	Wanarua	2	217		1	333	Wanarua	1
96	Wanarua	0.5	218	Wanarua	16	334	Hano	3
97	Wanarua	1.5	219	Reia	33	335	Wanarua	1.5
98	Wanarua	1	220		3	336	Wanarua	1
100	Tora	7	221		31	337	Pura	1
101	Hagheha	11	222	Aporo	21	338		2
102	Hagheha	1.5	223		2	339		0.5
103	Tanaga	6	224		0.5	340		1
104	Ranaga	0.5	225		0.25			42
105	Wanarua	0.5	226		0.5			
106	Wanarua	0.5	227		3			
107	Wanarua	16	228		8			
108	Wanarua	2	229		2	341		2
109	Nakuru	8	230		1.5	342		2
110	Wanarua	2	231		0.5	343	Lake Wapilapi	1.5
111	Wanarua	6	232		1	344	Lake Wapilapi	1.5
112	Wanarua	1.5	233		1.5	345	Lake Wapilapi	3
113	Wau	117	234	Hatu	1			11
114	Wanarua	0.5	235		0.5			
115	Wanarua	0.5	236		1			
116	Wanarua	2	237		0.5			
117	Wanarua	2	238		1			
118	Wanarua	2	239		1	346		3
119	Wanarua	2	240		1			
120	Nakuru (Hagheha)	8	241		1			
121	Wanarua	20	242		1	347	Three Sisters	3
122	Hagheha	103	243		1	348		3
123	Nakuru	20	244		1	349		6
124	Nakuru	20	244		1	349		6
Grand total = 3080 km <sup>2</sup>								

### Malo (2<sup>nd</sup> Investigation)



### Appendix 7-5-1 Location of the Investigated Village(7/7)

JAPAN INTERNATIONAL COOPERATION AGENCY	MASTER PLAN STUDY OF POWER DEVELOPMENT IN SOLOMON ISLANDS	TITLE
TOKYO ELECTRIC POWER SERVICES CO., LTD. IC NET CO., LTD		

### Appendix 7-5-2(1) Result of the Second Site Survey ( 1/3)

Village name			Sipokana	Loemuni	Sageragi	Ngorangora	Arohane	Goveo
Date and weather			10/27, Clear	10/27, Clear	11/1, Clear	11/9, Clear	11/9, Clear	11/13, Clear
Area	Province/Ward Name		Choiseul/Bataba	Choiseul/Bataba	Western/Gizo	Makira/Bauro Central	Makira/Bauro Central	Santa Isabel/Kokota
	Island name		Choiseul	Choiseul	Gizo	Makira	Makira	Isabel
	Houses are scattered or concentrated		Scattered	concentrated	concentrated	concentrated	concentrated	concentrated
Average number of rooms			3(bed room 2, sitting room 1)	4(bed room 3, sitting room 1)	3(bed room 2, sitting room 1)	4(bed room 3, sitting room 1)	4(bed room 3, sitting room 1)	4(bed room 3, sitting room 1)
means of communication			nothing (at Leomuni village)	a wireless radio with Solar	telephone with solar or wireless radio with solar	nothing(at Kirakira)	nothing(at Kirakira)	nothing(at Buala)
Are there any electrification plan			nothing	nothing	nothing	nothing	nothing	nothing
Nearest accommodation			Sipozae Guesthouse	Sipozae Guesthouse	Gizo	Kirakira	Kirakira	Buala
Number of households			26	36	39	39	40	52
Population			110	336	350	500	280	358
Nearest air field name			Taro	Taro	Gizo	Kirakira	Kirakira	Fera
Number of flight a week			3	3	3/day	4	4	3
Transportation to the village	by Out of Boat Motor,OBM	from where?	Taro	Taro	Gizo	-----	-----	Buala
		How long does it take	20-45 minutes by OBM 2 hours by Conoe	30-60 minutes by OBM	5 minutes by 40 HP OBM 45 minutes by 9.9 HP OBM	-----	-----	1 hour by 25 HP OBM 2 hours by 9.9 HP OBM
	by truck	from where?	---	---	Gizo	Kirakira air field	7 km from Kirakira	---
		How long does it take	---	---	60 minutes	5 minutes by car	20 minutes by truck	---
What's been used for lighting			kerosene lamp	kerosene lamp	kerosene lamp	kerosene lamp	kerosene lamp	kerosene lamp
Are there any shops for a living			3 private shops	2 private shops	4 private shops	3 private shops	2 private shops	3 private shops
Whether labor is available for a SHS construction			available	available	available	available	available	available
Labor cost (SB\$/day · man) Regular working hour: 8 - 12, 13 - 16, Overtime work pay: weekday (1.5 times), Saturday (2 times), Sunday (3 times)			free for community work, 15 SB\$/day for other purpose	free for community work, 15-20 SB\$/day for other purpose	free for community work, 10-20 SB\$/day for other purpose	free for community work, 10-20 SB\$/day for other purpose	free for community work, 10 SB\$/day for other purpose	free for community work, 30 SB\$/day for other purpose
Transportation costs of ship and car		Ship	from Taro 60-90 SB\$ /day/round-trip (OBM:10-15/day, Driver:20-30/day, Fuel:30-45/round-trip)	from Taro 55-60 SB\$ /day/round-trip (OBM with driver: 25-30/day, fuel:30/round-trip)	from Gizo 75-85 SB\$ /day/round-trip (OBM(9.9HP) with driver:25/day, fuel:50-60/round-trip)	----	----	from Buala: 112 (SB\$/day/round-trip) by boat (15 HP, 21 feet long, fuel:20 liter) canoe rate:1\$/(1 foot long)/day, screw rate:1\$/HP/day driver:20/day, fuel:2.8/liter
		Car	---	---	from Gizo 70SB\$ /day/round-trip (driver:10/day, pickup truck:60/round-trip)	truck:Hilux(1.5t) Provincial Government owns...53 SB\$/h (including driver and fuel)	truck:Hilux(1.5t) Provincial Government owns...53 SB\$/h (including driver and fuel)	---
Are there any public facilities		School	nothing	primary school	nothing	primary school, kindergarten	primary school	primary school
		Clinic	nothing	health aid post	health aid post	nothing	nothing	health aid post
		Church	a church evening service: every day 6:30-8:30pm	a church evening service :Mon to Fri and Sun, 6-7pm	2 churches evening service: Mon to Sun, 7:30-9pm	2 churches evening service: Mon to Sun, 6:30-7:30pm	evening service: Mon to Sun, 6-8pm	a church evening service: Mon to Sat: 5-5:30pm (Sun: 5-6pm)
		others	meeting house	meeting house	meeting house	nothing	nothing	nothing

### Appendix 7-5-2(1) Result of the Second Site Survey ( 2/3)

Village name			Sipokana	Loemuni	Sageragi	Ngorangora	Arohane	Goveo
Average income in a household	Monthly income (SB\$/month)		unsure	50	150	200	160	100
	Source of income	Percentage of agriculture income in total income (%)	90%	100%	80%	100%	100%	90%
		Kind of farm produce to sell	copra (mainly), vegetables(taro, sweet potato), fruits(banana)	copra, vegetables(bean, pepper, sweet potato, corn)	copra, vegetables	copra, cocoa, pork, chicken, vegetables(sweet potato, peanut, cabbage), fruits(banana, pineapple)	copra, cocoa, vegetables (sweet potato, cabbage, tomato, bean, cucumber), banana	copra, vegetables(yam, cassava, sweet potato), fruits(banana, papaya)
		Percentage of fishery income in total income (%)	10%	0%	20%	0%	0%	10%
		Kind of fish to sell	reef fish, marine products(dried sea cucumber, trochus for shellwork)	home consumption only	reef fish, tuna, king fish	----	----	reef fish, marine products(dried sea cucumber, trochus for shellwork)
Kind of electrical appliances	Private house	Flashlight	1.5*(3-4)=4.5-6 V	1.5*3=4.5 V	1.5*(3-4)=4.5-6 V	1.5*(2-4)=3-6 V	1.5*(2-6)=3-9 V	1.5*(4-8)=6-12 V
		Radio	1.5*(6-8)=9-12 V	1.5*6=9 V	1.5*(6-8)=9-12 V	1.5*(6-8)=9-12 V	1.5*(6-12)=9-18 V	1.5*(6-8)=9-12 V
		Radio-cassette						
		others	nothing	nothing	nothing	nothing	nothing	nothing
	School	Flashlight	-----	nothing	-----	1.5*(2-4)=3-6 V	nothing	nothing
		Radio	-----	nothing	-----	1.5*(6-8)=9-12 V	nothing	nothing
		Radio-cassette	-----	nothing	-----		nothing	nothing
		others	-----	nothing	-----	nothing	nothing	nothing
	Church	Flashlight	nothing	nothing	nothing	nothing	nothing	nothing
		Radio	nothing	nothing	nothing	nothing	nothing	nothing
		Radio-cassette	nothing	nothing	nothing	nothing	nothing	nothing
		others	nothing	nothing	keyboard	nothing	nothing	nothing
	Clinic	Flashlight	-----	nothing	nothing	-----	----	nothing
		Radio	-----	nothing	nothing	-----	----	nothing
		Radio-cassette	-----	nothing	nothing	-----	----	nothing
		others	-----	nothing	nothing	-----	----	nothing
	Community hall	Flashlight	nothing	nothing	nothing	-----	nothing	nothing
		Radio	nothing	nothing	nothing	-----	nothing	nothing
		Radio-cassette	nothing	nothing	nothing	-----	nothing	nothing
		others	nothing	nothing	nothing	-----	nothing	nothing

### Appendix 7-5-2(1) Result of the Second Site Survey ( 3/3)

Village name			Sipokana	Loemuni	Sageragi	Ngorangora	Arohane	Goveo
Kerosene situations	Price (SB\$/liter)		2.5	2.5	2.5	2.7	3.0	3.0
	How to buy/means of purchase		shop in village	shop in village	shop in village	at Kirakira	shop in village	shop in village
	Private house raising babies	Using time (hour/day)	12 (6pm-6am)	12 (6pm-6am)	12 (6pm-6am)	12 (6pm-6am)	12 (6pm-6am)	12 (6pm-6am)
		Monthly consumption (liter/m.)	8	unsure	10	9	2	11
		Monthly expenses (SB\$/m.)	20	unsure	25	24	6	33
	Private house no babies	Using time (hour/day)	3.5 (6:30-10pm)	3.5 (6:30-10pm)	3 (6:30-9:30pm)	3 (6-9pm)	2 (6-8pm)	4 (6-10pm)
		Monthly consumption (liter/m.)	2	unsure	3.3	4.5	2	10
		Monthly expenses (SB\$/m.)	5	unsure	8	12	6	30
	School	Using time (hour/day)	-----	no need for a day school	-----	8-9pm for entrance exam. (standard class 5,6)	no need for a day school	7-8pm for entrance exam.
		Monthly consumption (liter/m.)	-----		-----	unsure		18
		Monthly expenses (SB\$/m.)	-----		-----	unsure		54
		Who pay	-----		-----	----		-----
	Church	Using time (hour/day)	pressure type lamp, tilley lamp 2 (6:30-8:30pm)	4 hurricane lamps 1 (6-7pm)	a hurricane and a tilley lamp 1.5 (7:30-9pm)	three hurricane lamps 1 (6:30-7:30pm)	a hurricane lamp 2 (6-8pm), 5 (6-11pm, Sat.)	a tilley lamp 1h (every Sunday)
		Monthly consumption (liter/m.)	10	unsure	16	4	12	4
		Monthly expenses (SB\$/m.)	25	unsure	40	11	36	12
		Who pay	Church Committee	Church Committee	Church Committee	Church Committee	Church Committee	Church Committee
	Clinic	Using time (hour/day)	-----	as the need arises	as the need arises	as the need arises	----	24 hour for medical ice box
		Monthly consumption (liter/m.)	-----	unsure	unsure	unsure	----	60 SB\$ for a kerosene medical ice box
		Monthly expenses (SB\$/m.)	-----	unsure	unsure	unsure	----	180
		Who pay	-----	patients	patients	patients	----	province
Dry cell situations	Price (SB\$/one)		3	2.5	2.5	2.2	2	2.3
	Private house	Monthly consumption (pieces/m.)	unsure F/L: 3/month R/C: 8/3days	unsure	unsure	unsure	unsure	F/L: 3/5 days R/C: 8/3 days
		Monthly expenses (SB\$/m.)	unsure	unsure	unsure	unsure	unsure	unsure
	School	Monthly consumption (pieces/m.)	-----	-----	-----	----	----	----
		Monthly expenses (SB\$/m.)	-----	-----	-----	----	----	----
		Who pay	-----	-----	-----	----	----	----
	Church	Monthly consumption (pieces/m.)	-----	-----	unsure	----	----	----
		Monthly expenses (SB\$/m.)	-----	-----	unsure	----	----	----
		Who pay	-----	-----	----	----	----	----
	Clinic	Monthly consumption (pieces/m.)	-----	-----	-----	----	----	----
		Monthly expenses (SB\$/m.)	-----	-----	-----	----	----	----
		Who pay	-----	-----	-----	----	----	----
What kinds of electrical appliances will be required first after electrification			1st: lights (sitting room), 2nd: outlet	1st: lights (sitting room), 2nd: outlet	1st: lights 2nd: outlet	1st: lights (sitting room), 2nd: outlet	1st: lights (center of house), 2nd: outlet	1st: lights (center of house), 2nd: outlet

Appendix 7-5-2(2) Result of the Second Site Survey ( 1/3)

Village name			Hovikoilo	Malo	Vunuha	Bubuitolo	Nusa Roviana	Mandou
Date and weather			11/13, Clear/Rain	11/18, Rain	11/23, Clear	11/25, Clear	11/29, Clear/Rain	11/30, Clear/Rain
Area	Province/Ward Name		Santa Isabel/Hovikoilo	Temotu/Neo	Central/South West Gela	Malaita/Fauabu	Western/Nusa Roviana	Western/Parara
	Island name		Isabel	Trevanion	Frolida	Malaita	Nusa roviaana	Parara
	Houses are scattered or concentrated		concentrated	scattered	concentrated	concentrated	scattered	concentrated
Average number of rooms			3(bed room 2, sitting room 1)	3(bed room 2, sitting room 1)	4(bed room 3, sitting room 1)	3(bed room 2, sitting room 1)	3(bed room 2, sitting room 1)	3(bed room 2, sitting room 1)
means of communication			nothing(at Buala)	nothing(at Lata)	nothing(at Tulagi by canoe)	nothing(at Auki)	Radio with Solar (PV:40W, B:120Ah, C/C:12V,4A)	Radio with dry cell
Are there any electrification plan			nothing	nothing	nothing	nothing	nothing	nothing
Nearest accommodation			Buala	Lata	guest house(under construction:no electricity)	Auki	Munda	Munda
Number of households			120	125	86	45	83	200
Population			700	630	500	400	500	1,000
Nearest air field name			Fera	Lata	----	Auki	Munda	Munda, Noro, Gizo, Lola
Number of flight a week			3	2	----	14	14	14
Transportation to the village	by Out of Boat Motor,OBM	from where?	Buala	Lata	Honiara	---	Munda	Noro
		How long does it take	45 minutes by 9.9 HP OBM 2 hours on foot	5 minutes by 25 HP OBM	1.5 hours by 70 HP OBM	---	15 minutes by 9.9 HP OBM, 10 minutes by 25 HP OBM	1 hour by boat
	by truck	from where?	---	---	---	Auki	---	---
		How long does it take	---	---	---	1 hour by truck	---	---
What's been used for lighting			kerosene lamp	kerosene lamp	kerosene lamp	kerosene lamp	kerosene lamp	kerosene lamp
Are there any shops for a living			6 private shops	6 private shops	2 private shops	2 private shops	4 private shops	6 private shops, 1 community shop
Whether labor is available for a SHS construction			available	available	available	available	available	available
Labor cost (SB\$/day · man) Regular working hour: 8 - 12, 13 - 16, Overtime work pay: weekday (1.5 times), Saturday (2 times), Sunday (3 times)			free for community work, 10 SB\$/day for other purpose	free for community work, 50 SB\$/day for other purpose	free for community work, 20 SB\$/day for other purpose	free for community work, 10 SB\$/day for other purpose	free for community work, 10 SB\$/day for other purpose	free for community work, 10 SB\$/day for other purpose
Transportation costs of ship and car		Ship	from Buala: 58 (SB\$/day/round-trip) by boat (9.9/15/25 HP, fuel:10 liter) (OBM with driver:30/day, fuel:2.8/liter)	from Lata: 30 (SB\$/round-trip) by boat (including driver and fuel)	from Honiara: 300 (SB\$/round-trip) by boat (including driver and fuel) from Tulagi: 150 (SB\$/round-trip) by boat (including driver and fuel)	---	from Munda : 95 SB\$/round- trip, OBM: 50 SB\$/day (including driver), fuel: 15 liter (2.8-3.2 SB\$/l)	from Noro : 95 SB\$/round- trip, OBM: 50 SB\$/day (including driver, doesn't depend on HP), fuel: 15 liter (3 SB\$/l)
		Car	---	---	---	from Auki, 200 SB\$/one-way/3t truckr (including driver and fuel)	---	---
Are three any public facilities		School	kindergarten	primary school	kindergarten	nothing	primary school	primary school
		Clinic	nothing, (at Guguha 2 km way from the village)	health aid post	nothing, (at Koilovala 3.2 km way from the village)	nothing, (at Gwaunoa 9 km way)	health aid post	village health to worker
		Church	a church evening service: Mon to Sun: 6-7pm (Holy Communion, twice a month: 6-8pm)	three church evening service: Mon to Sun: 6-8pm	a church evening service: Mon to Sun: 6-7:30pm	a church evening service: Mon to Sun: 6-7pm	three church evening service: Sun: 5-10pm	a church evening service: 8-11pm (Mon, Wed, Fri, and Sun)
		others	meeting house	nothing	nothing	nothing	meeting house, dining house	---

Appendix 7-5-2(2) Result of the Second Site Survey ( 2/3)

Village name			Hovikoilo	Malo	Vunuha	Bubuitolo	Nusa Roviana	Mandou
Average income in a household	Monthly income (SB\$/month)		230	200	800	100	500	500
	Source of income	Percentage of agriculture income in total income (%)	100%	90%	30%	100%	50%	70%
		Kind of farm produce to sell	copra, vegetables(tomato, cassava, sweet potato, taro, cucumber), banana *note:15-20 SB\$/(a 25kg basket of sweet potato)	copra, cocoa, vegetables(beans, tomato, cabbage)	200-300 SB\$/family by selling farm productsat at Honiara or Tulagi which are copra, coconut, vegetables(beans, tomato, cabbage, corn), and banana	copra, coconut, vegetables(beans, cabbage) (copra: 2 SB\$/10 pieces, coconut: 1 SB\$/piece)	women's share: 50 SB\$/5days/week by selling farm products,	copra(mainly), vegetable, fruits
		Percentage of fishery income in total income (%)	0%	10%	70%	0%	50%	30%
		Kind of fish to sell	----	reef fish	fish: 1,000 SB\$/week/(6-8 people) at Honiara, marine products(sea cucumber, trochus)	---	men's share: 50 SB\$/5days/week by selling marine products (trochus, dried sea cucumber, shark fin)	reef fish
Kind of electrical appliances	Private house	Flashlight	1.5*(2-4)=3-6 V	1.5*(2-4)=3-6 V	1.5*(2-3)=3-4.5 V	1.5*3 =4.5 V	three familes own a small generator, (two of three are: 0.7 kW, 240V (YAMAHA EF1000) and 4.3 kW, 240V (Fuji Heavy Industry RGB5000)	1.5*3=4.5 V
		Radio	1.5*(4-6)=6-9 V	1.5*(6-8)=9-12 V	1.5*(6-8)=9-12 V	1.5*(6-8)=9-12 V		1.5*(6-8)=9-12 V
		Radio-cassette						
		others	nothing	nothing	nothing	nothing		nothing
	School	Flashlight	-----	nothing	-----	---	nothing	nothing
		Radio	-----	nothing	-----	---	nothing	nothing
		Radio-cassette	-----	nothing	-----	---	nothing	nothing
		others	-----	nothing	-----	---	nothing	nothing
	Church	Flashlight	nothing	two churces own generator: 2 kVA, Honda EG2200 one of three owns fluorescent light: 40W*2, 20W*1	fluorescent light: 40W*9 (being supplied from private generator of 4.3kW, 240V Fuji Heavy Industry as a donation)	nothing	ceiling fan: 100W*3 fluorescent light: 40W*5 light bulb: 40W*4	nothing
		Radio	nothing			nothing		nothing
		Radio-cassette	nothing			nothing		nothing
		others	nothing			nothing		nothing
	Clinic	Flashlight	-----	nothing	-----	-----	nothing	nothing
		Radio	-----	nothing	-----	-----	nothing	nothing
		Radio-cassette	-----	nothing	-----	-----	nothing	nothing
		others	-----	nothing	-----	-----	nothing	nothing
	Community hall	Flashlight	nothing	nothing	-----	-----	fluorescent light:40W*2(each of meeting housel and dining house), (generator supply church, meeting house, and dining house:Rating, 1.7kW, 240V, Fuji heavy Industry, Robin)	---
		Radio	nothing	nothing	-----	-----		---
		Radio-cassette	nothing	nothing	-----	-----		---
		others	nothing	nothing	-----	-----		---



Appendix 7-5-2(2) Result of the Second Site Survey ( 3/3)

Village name			Hovikoilo	Malo	Vunuha	Bubuitolo	Nusa Roviana	Mandou
Kerosene situations	Price (SB\$/liter)		3.0	3.0	2.0	2.9	2.9	2.5
	How to buy/means of purchase		shop in village	Lata	shop in village	shop in village	shop in village	shop in village
	Private house raising babies	Using time (hour/day)	12 (6pm-6am)	12 (6pm-6am)	12 (6pm-6am)	12 (6pm-6am)	12 (6pm-6am)	11 (6pm-5am)
		Monthly consumption (liter/m.)	2	5	10-20	11	15	15
		Monthly expenses (SB\$/m.)	6	15	20-40	30	43	38
	Private house no babies	Using time (hour/day)	4 (6-10pm)	4 (6-10pm)	4 (6-10pm)	4 (6-10pm)	3 (7-10pm)	4 (6-10pm)
		Monthly consumption (liter/m.)	2	5	10	5	8	15
		Monthly expenses (SB\$/m.)	6	15	20	15	21	38
	School	Using time (hour/day)	-----	no need for a day school	-----	---	basically no need for a day school, but one study room and one staff room are sometimes needed	no need for a day school
		Monthly consumption (liter/m.)	-----		-----	---		
		Monthly expenses (SB\$/m.)	-----		-----	---		
		Who pay	-----		-----	---		
	Church	Using time (hour/day)	one or two tilley lamp 1 (6-7pm), 1 lamp 2 (twice a month), 2 lamps	two or three tilley lamps 2 (6-8pm)	two tilley lamps 1.5 (6-7:30pm)	one tilley lamp 1 (6-7pm)	electrified	one tilley(Mon,Wed,Fri), 3 tilley(Sun) 3(8-11pm)
		Monthly consumption (liter/m.)	unsure	3.5	28	1*350ml/1hour		24
		Monthly expenses (SB\$/m.)	unsure	11	56	30		60
		Who pay	Church Committee	Church Committee	Church Committee	Church Committee	Church Committee	Community store
	Clinic	Using time (hour/day)	----	as the need arises	----	---	as the need arises	nothing
		Monthly consumption (liter/m.)	----	unsure	----	---	unsure	nothing
		Monthly expenses (SB\$/m.)	----	unsure	----	---	unsure	nothing
		Who pay	----	patients	----	---	village head	nothing
Dry cell situations	Price (SB\$/one)		2.4	----	2.4	2.5	1.8	2.4
	Private house	Monthly consumption (pieces/m.)	F/L: 3 days R: 30 days	----	----	(long life battery) R/C: 6/12 hours 2 times/month	F/L: once/7 days R/C: once/3 days	unsure
		Monthly expenses (SB\$/m.)	unsure	----	----	unsure	unsure	unsure
	School	Monthly consumption (pieces/m.)	----	----	----	----	----	----
		Monthly expenses (SB\$/m.)	----	----	----	----	----	----
		Who pay	----	----	----	----	----	----
	Church	Monthly consumption (pieces/m.)	----	----	----	----	----	----
		Monthly expenses (SB\$/m.)	----	----	----	----	----	----
		Who pay	----	----	----	----	----	----
	Clinic	Monthly consumption (pieces/m.)	----	----	----	---	----	---
		Monthly expenses (SB\$/m.)	----	----	----	---	----	---
		Who pay	----	----	----	---	----	---
What kinds of electrical appliances will be required first after electrification			1st: lights (cooking house), 2nd: outlet	1st: lights (center of house), 2nd: outlet	1st: lights (center of house), 3nd: outlet	1st:lights, 2nd:R/C	1st:lights, 2nd:outlet	1st:lights, 2nd:TV

Appendix 7-7-1 Sunshine Duration & Solar Irradiation at Vavaya Ridge Upper Air  
Observatory in Guadalcanal Island (1/4)

date	Sunshine duration (h/day)	Irradiation energy		Conversion coefficient (kW/m <sup>2</sup> )
		(MJ/m <sup>2</sup> /day)	(kWh/m <sup>2</sup> /day)	
1999/12/1	2.7	14.75	4.10	1.52
1999/12/2	4.5	13.65	3.79	0.84
1999/12/3	9.5	22.78	6.33	0.67
1999/12/4	6.3	19.64	5.46	0.87
1999/12/5	6.3	15.88	4.41	0.70
1999/12/6	5.5	16.45	4.57	0.83
1999/12/7	9.0	18.82	5.23	0.58
1999/12/8	9.2	18.00	5.00	0.54
1999/12/9	-	-	-	-
1999/12/10	-	-	-	-
1999/12/11	-	-	-	-
1999/12/12	-	-	-	-
1999/12/13	6.2	13.98	3.88	0.63
1999/12/14	6.0	20.88	5.80	0.97
1999/12/15	-	-	-	-
1999/12/16	-	-	-	-
1999/12/17	1.0	7.16	1.99	1.99
1999/12/18	4.8	17.32	4.81	1.00
1999/12/19	-	-	-	-
1999/12/20	7.3	14.98	4.16	0.57
1999/12/21	5.8	13.99	3.89	0.67
1999/12/22	7.4	16.79	4.66	0.63
1999/12/23	6.1	15.32	4.26	0.70
1999/12/24	6.9	16.74	4.65	0.67
1999/12/25	6.1	16.46	4.57	0.75
1999/12/26	6.0	17.05	4.74	0.79
1999/12/27	9.3	19.46	5.41	0.58
1999/12/28	7.3	18.01	5.00	0.69
1999/12/29	6.9	19.99	5.55	0.80
1999/12/30	9.1	20.72	5.76	0.63
1999/12/31	7.9	22.18	6.16	0.78
Average	6.55	17.13	4.76	0.727

Note - : no data

Source :Data from Vavaya ridge Upper Air Observatory

Appendix 7-7-1 Sunshine Duration & Solar Irradiation at Vavaya Ridge Upper Air  
Observatory in Guadalcanal Island (2/4)

date	Sunshine duration (h/day)	Irradiation energy		Conversion coefficient (kW/m <sup>2</sup> )
		(MJ/m <sup>2</sup> /day)	(kWh/m <sup>2</sup> /day)	
2000/1/1	-	-	-	-
2000/1/2	1.3	10.64	2.96	2.27
2000/1/3	3.3	15.27	4.24	1.29
2000/1/4	0.2	8.12	2.26	11.28
2000/1/5	7.2	18.38	5.11	0.71
2000/1/6	3.9	14.63	4.06	1.04
2000/1/7	6.1	18.04	5.01	0.82
2000/1/8	5.6	15.63	4.34	0.78
2000/1/9	3.6	10.94	3.04	0.84
2000/1/10	4.0	13.07	3.63	0.91
2000/1/11	0.0	5.00	1.39	-
2000/1/12	6.3	16.32	4.53	0.72
2000/1/13	1.1	7.36	2.04	1.86
2000/1/14	4.0	13.12	3.64	0.91
2000/1/15	4.8	17.23	4.79	1.00
2000/1/16	6.7	20.33	5.65	0.84
2000/1/17	7.5	17.83	4.95	0.66
2000/1/18	3.7	16.01	4.45	1.20
2000/1/19	1.2	10.10	2.81	2.34
2000/1/20	7.6	18.95	5.26	0.69
2000/1/21	9.1	17.59	4.89	0.54
2000/1/22	5.5	18.04	5.01	0.91
2000/1/23	1.8	12.32	3.42	1.90
2000/1/24	-	-	-	-
2000/1/25	6.7	16.32	4.53	0.68
2000/1/26	4.7	15.93	4.43	0.94
2000/1/27	6.3	18.30	5.08	0.81
2000/1/28	1.8	12.67	3.52	1.96
2000/1/29	7.2	14.50	4.03	0.56
2000/1/30	7.0	18.94	5.26	0.75
2000/1/31	6.3	17.50	4.86	0.77
Average	4.64	14.80	4.11	0.886

Note - : no data

Source :Data from Vavaya ridge Upper Air Observatory

Appendix 7-7-1 Sunshine Duration & Solar Irradiation at Vavaya Ridge Upper Air  
Observatory in Guadalcanal Island (3/4)

date	Sunshine duration (h/day)	Irradiation energy		Conversion coefficient (kW/m <sup>2</sup> )
		(MJ/m <sup>2</sup> /day)	(kWh/m <sup>2</sup> /day)	
2000/2/1	4.4	16.00	4.44	1.01
2000/2/2	2.3	11.00	3.06	1.33
2000/2/3	3.4	12.63	3.51	1.03
2000/2/4	7.6	19.00	5.28	0.69
2000/2/5	7.3	18.14	5.04	0.69
2000/2/6	5.6	16.18	4.49	0.80
2000/2/7	6.0	15.87	4.41	0.73
2000/2/8	4.2	15.20	4.22	1.01
2000/2/9	9.5	20.07	5.58	0.59
2000/2/10	8.1	20.31	5.64	0.70
2000/2/11	10.0	21.40	5.94	0.59
2000/2/12	9.5	20.02	5.56	0.59
2000/2/13	9.0	19.33	5.37	0.60
2000/2/14	9.8	19.52	5.42	0.55
2000/2/15	8.7	19.87	5.52	0.63
2000/2/16	9.7	20.87	5.80	0.60
2000/2/17	2.8	10.98	3.05	1.09
2000/2/18	3.4	12.67	3.52	1.03
2000/2/19	4.2	13.45	3.74	0.89
2000/2/20	-	-	-	-
2000/2/21	0.9	6.73	1.87	2.08
2000/2/22	5.1	17.26	4.79	0.94
2000/2/23	6.4	17.07	4.74	0.74
2000/2/24	9.7	19.77	5.49	0.57
2000/2/25	2.9	12.77	3.55	1.22
2000/2/26	5.3	12.92	3.59	0.68
2000/2/27	5.8	18.98	5.27	0.91
2000/2/28	3.8	13.65	3.79	1.00
2000/2/29	7.5	17.80	4.94	0.66
Average	6.18	16.97	4.56	0.738

Note - : no data

Source :Data from Vavaya ridge Upper Air Observatory

Appendix 7-7-1 Sunshine Duration & Solar Irradiation at Vavaya Ridge Upper Air  
Observatory in Guadalcanal Island (4/4)

date	Sunshine duration (h/day)	Irradiation energy		Conversion coefficient (kW/m <sup>2</sup> )
		(MJ/m <sup>2</sup> /day)	(kWh/m <sup>2</sup> /day)	
2000/3/1	4.4	16.00	4.44	1.01
2000/3/2	2.3	11.00	3.06	1.33
2000/3/3	3.4	12.63	3.51	1.03
2000/3/4	7.6	19.00	5.28	0.69
2000/3/5	7.3	18.14	5.04	0.69
2000/3/6	5.6	16.18	4.49	0.80
2000/3/7	6.0	15.87	4.41	0.73
2000/3/8	4.2	15.20	4.22	1.01
2000/3/9	9.5	20.07	5.58	0.59
2000/3/10	8.1	20.31	5.64	0.70
2000/3/11	10.0	21.40	5.94	0.59
2000/3/12	9.5	20.02	5.56	0.59
2000/3/13	9.0	19.33	5.37	0.60
2000/3/14	9.8	19.52	5.42	0.55
2000/3/15	8.7	19.87	5.52	0.63
2000/3/16	9.7	20.87	5.80	0.60
2000/3/17	2.8	10.98	3.05	1.09
2000/3/18	3.4	12.67	3.52	1.04
2000/3/19	4.2	13.45	3.74	0.89
2000/3/20	0.0	11.23	3.12	-
2000/3/21	0.9	6.73	1.87	2.08
2000/3/22	5.1	17.26	4.79	0.94
2000/3/23	6.4	17.07	4.74	0.74
2000/3/24	9.7	19.77	5.49	0.57
2000/3/25	2.9	12.77	3.55	1.22
2000/3/26	5.3	12.92	3.59	0.68
2000/3/27	5.8	18.98	5.27	0.91
2000/3/28	3.8	13.65	3.79	1.00
2000/3/29	7.5	17.80	4.94	0.66
2000/3/30	-	-	-	-
2000/3/31	-	-	-	-
Average	5.96	16.23	4.51	0.756

Note - : no data

Source :Data from Vavaya ridge Upper Air Observatory

### Appendix 7-8-1 Calculation of PV and battery capacity in Honiara (1/3)

(for a private house)

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion factor for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree	degree	Wh/day	hour/day	kW/m <sup>2</sup>	MJ/m <sup>2</sup> /day	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp
Jan.	-20.79	-9.4	56.0	6.0	0.7	15.1	15.33	33.0	15.12	33.4	14.80	34.2	14.36	35.2	14.10	35.8	13.82	36.6	13.17	38.4
Feb.	-12.96	-9.4	56.0	6.0	0.7	15.1	15.14	33.4	15.12	33.4	14.98	33.7	14.73	34.3	14.56	34.7	14.36	35.2	13.89	36.4
Mar.	-1.99	-9.4	56.0	6.3	0.7	15.9	15.64	32.3	15.88	31.8	16.00	31.6	15.99	31.6	15.95	31.7	15.87	31.8	15.62	32.3
Apr.	9.61	-9.4	56.0	6.6	0.7	16.6	16.07	31.4	16.63	30.4	17.07	29.6	17.37	29.1	17.48	28.9	17.55	28.8	17.59	28.7
May	18.73	-9.4	56.0	6.7	0.7	16.9	16.03	31.5	16.88	29.9	17.61	28.7	18.19	27.8	18.44	27.4	18.64	27.1	18.95	26.7
June	23.04	-9.4	56.0	6.9	0.7	17.4	16.36	30.9	17.39	29.1	18.29	27.6	19.04	26.5	19.37	26.1	19.66	25.7	20.12	25.1
July	21.23	-9.4	56.0	6.2	0.7	15.6	14.76	34.2	15.62	32.3	16.37	30.9	16.99	29.7	17.26	29.3	17.49	28.9	17.85	28.3
Aug.	13.80	-9.4	56.0	6.7	0.7	16.9	16.19	31.2	16.88	29.9	17.45	29.0	17.88	28.3	18.05	28.0	18.18	27.8	18.34	27.6
Sept.	3.06	-9.4	56.0	6.6	0.7	16.6	16.25	31.1	16.63	30.4	16.89	29.9	17.02	29.7	17.03	29.7	17.02	29.7	16.89	29.9
Oct.	-8.55	-9.4	56.0	7.2	0.7	18.1	18.05	28.0	18.14	27.9	18.10	27.9	17.92	28.2	17.77	28.4	17.60	28.7	17.14	29.5
Nov.	-18.24	-9.4	56.0	7.6	0.7	19.2	19.34	26.1	19.15	26.4	18.82	26.9	18.34	27.5	18.05	28.0	17.73	28.5	16.98	29.8
Dec.	-22.97	-9.4	56.0	6.6	0.7	16.6	16.92	29.9	16.63	30.4	16.22	31.2	15.68	32.2	15.37	32.9	15.03	33.6	14.26	35.4
Total						200.1	196.07		200.09		202.58		203.53		203.42		202.93		200.79	
Average				6.6		16.7	16.34	31.1	16.67	30.4	16.88	30.1	16.96	30.0	16.95	30.1	16.91	30.2	16.73	30.7
Maximum				7.6		19.2	19.34	34.2	19.15	33.4	18.82	34.2	19.04	35.2	19.37	35.8	19.66	36.6	20.12	38.4
Minimum				6.0		15.1	14.76	26.1	15.12	26.4	14.80	26.9	14.36	26.5	14.10	26.1	13.82	25.7	13.17	25.1

#### (Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, $\gamma = 1 - 0.0042 \times (65 - 25)$ , supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	$K0 = As \times K1 \times K2 \times K3 \times K4 \times K5 \times K6 \times K7 \times K8 \times K9 \times K10$

#### Applicable appliances and their energy consumption

Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	1	4	44.0
	FL 9W	9			0.0
	FL 7W	7			0.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	2	12.0
Total (Wh/day)		---	---	---	56.0

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

#### Battery Capacity (Ah)

Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
56.0	0.5	5.0	0.9	1.0	52

### Appendix 7-8-1 Calculation of PV and battery capacity in Honiara (2/3)

(for a private house)

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree	degree	Wh/day	hour/day	kW/m <sup>2</sup>	MJ/m <sup>2</sup> /day	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp
Jan.	-20.79	-9.40	85.5	6.0	0.7	15.1	15.33	50.3	15.12	51.0	14.80	52.1	14.36	53.7	14.10	54.7	13.82	55.8	13.17	58.6
Feb.	-12.96	-9.40	85.5	6.0	0.7	15.1	15.14	50.9	15.12	51.0	14.98	51.5	14.73	52.4	14.56	53.0	14.36	53.7	13.89	55.6
Mar.	-1.99	-9.40	85.5	6.3	0.7	15.9	15.64	49.3	15.88	48.6	16.00	48.2	15.99	48.2	15.95	48.4	15.87	48.6	15.62	49.4
Apr.	9.61	-9.40	85.5	6.6	0.7	16.6	16.07	48.0	16.63	46.4	17.07	45.2	17.37	44.4	17.48	44.1	17.55	44.0	17.59	43.9
May	18.73	-9.40	85.5	6.7	0.7	16.9	16.03	48.1	16.88	45.7	17.61	43.8	18.19	42.4	18.44	41.8	18.64	41.4	18.95	40.7
June	23.04	-9.40	85.5	6.9	0.7	17.4	16.36	47.2	17.39	44.4	18.29	42.2	19.04	40.5	19.37	39.8	19.66	39.3	20.12	38.3
July	21.23	-9.40	85.5	6.2	0.7	15.6	14.76	52.3	15.62	49.4	16.37	47.1	16.99	45.4	17.26	44.7	17.49	44.1	17.85	43.2
Aug.	13.80	-9.40	85.5	6.7	0.7	16.9	16.19	47.7	16.88	45.7	17.45	44.2	17.88	43.1	18.05	42.7	18.18	42.4	18.34	42.1
Sept.	3.06	-9.40	85.5	6.6	0.7	16.6	16.25	47.5	16.63	46.4	16.89	45.7	17.02	45.3	17.03	45.3	17.02	45.3	16.89	45.7
Oct.	-8.55	-9.40	85.5	7.2	0.7	18.1	18.05	42.7	18.14	42.5	18.10	42.6	17.92	43.1	17.77	43.4	17.60	43.8	17.14	45.0
Nov.	-18.24	-9.40	85.5	7.6	0.7	19.2	19.34	39.9	19.15	40.3	18.82	41.0	18.34	42.1	18.05	42.7	17.73	43.5	16.98	45.4
Dec.	-22.97	-9.40	85.5	6.6	0.7	16.6	16.92	45.6	16.63	46.4	16.22	47.6	15.68	49.2	15.37	50.2	15.03	51.3	14.26	54.1
Total						200.1	196.07		200.09		202.58		203.53		203.42		202.93		200.79	
Average				6.6		16.7	16.34	47.5	16.67	46.5	16.88	45.9	16.96	45.8	16.95	45.9	16.91	46.1	16.73	46.8
Maximum				7.6		19.2	19.34	52.3	19.15	51.0	18.82	52.1	19.04	53.7	19.37	54.7	19.66	55.8	20.12	58.6
Minimum				6.0		15.1	14.76	39.9	15.12	40.3	14.80	41.0	14.36	40.5	14.10	39.8	13.82	39.3	13.17	38.3

#### (Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '=1-0.0042*(65-25), supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10

#### Applicable appliances and their energy consumption

Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11			0.0
	FL 9W	9			0.0
	FL 7W	7	3	3.5	73.5
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	2	12.0
Total (Wh/day)		---	---	---	85.5

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

#### Battery Capacity (Ah)

Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
85.5	0.5	5.0	0.9	1.0	79

**Appendix 7-8-1 Calculation of PV and battery capacity in Honiara (3/3)**

**(for a public facility)**

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20		
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane
	degree	degree	Wh/day	hour	kW/m <sup>2</sup>	MJ/m <sup>2</sup> /day	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day
Jan.	-20.79	-9.40	116.0	6.0	0.7	15.1	15.33	68.3	15.12	69.2	14.80	70.7	14.36	72.9	14.10	74.2	13.82	75.8	13.17	79.5	
Feb.	-12.96	-9.40	116.0	6.0	0.7	15.1	15.14	69.1	15.12	69.2	14.98	69.9	14.73	71.1	14.56	71.9	14.36	72.9	13.89	75.4	
Mar.	-1.99	-9.40	116.0	6.3	0.7	15.9	15.64	66.9	15.88	65.9	16.00	65.4	15.99	65.4	15.95	65.6	15.87	66.0	15.62	67.0	
Apr.	9.61	-9.40	116.0	6.6	0.7	16.6	16.07	65.1	16.63	62.9	17.07	61.3	17.37	60.2	17.48	59.9	17.55	59.6	17.59	59.5	
May	18.73	-9.40	116.0	6.7	0.7	16.9	16.03	65.3	16.88	62.0	17.61	59.5	18.19	57.5	18.44	56.8	18.64	56.1	18.95	55.2	
June	23.04	-9.40	116.0	6.9	0.7	17.4	16.36	64.0	17.39	60.2	18.29	57.2	19.04	55.0	19.37	54.0	19.66	53.3	20.12	52.0	
July	21.23	-9.40	116.0	6.2	0.7	15.6	14.76	70.9	15.62	67.0	16.37	63.9	16.99	61.6	17.26	60.7	17.49	59.9	17.85	58.7	
Aug.	13.80	-9.40	116.0	6.7	0.7	16.9	16.19	64.7	16.88	62.0	17.45	60.0	17.88	58.5	18.05	58.0	18.18	57.6	18.34	57.1	
Sept.	3.06	-9.40	116.0	6.6	0.7	16.6	16.25	64.4	16.63	62.9	16.89	62.0	17.02	61.5	17.03	61.5	17.02	61.5	16.89	62.0	
Oct.	-8.55	-9.40	116.0	7.2	0.7	18.1	18.05	58.0	18.14	57.7	18.10	57.8	17.92	58.4	17.77	58.9	17.60	59.5	17.14	61.1	
Nov.	-18.24	-9.40	116.0	7.6	0.7	19.2	19.34	54.1	19.15	54.7	18.82	55.6	18.34	57.1	18.05	58.0	17.73	59.0	16.98	61.7	
Dec.	-22.97	-9.40	116.0	6.6	0.7	16.6	16.92	61.9	16.63	62.9	16.22	64.5	15.68	66.7	15.37	68.1	15.03	69.7	14.26	73.4	
Total						200.1	196.07		200.09		202.58		203.53		203.42		202.93		200.79		
Average				6.6		16.7	16.34	64.4	16.67	63.1	16.88	62.3	16.96	62.2	16.95	62.3	16.91	62.6	16.73	63.5	
Maximum				7.6		19.2	19.34	70.9	19.15	69.2	18.82	70.7	19.04	72.9	19.37	74.2	19.66	75.8	20.12	79.5	
Minimum				6.0		15.1	14.76	54.1	15.12	54.7	14.80	55.6	14.36	55.0	14.10	54.0	13.82	53.3	13.17	52.0	

**(Coefficient for PV panel)**

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '= $1-0.0042*(65-25)$ ), supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	$K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10$

**Applicable appliances and their energy consumption**

Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	4	2.5	110.0
	FL 9W	9			0.0
	FL 7W	7			0.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	1	6.0
Total (Wh/day)		---	---	---	116.0

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

**Battery Capacity (Ah)**

Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
116.0	0.5	5.0	0.9	1.0	107



Appendix 7-8-2 Calculation of PV and battery capacity in Munda (1/3)  
(for a private house)

Month	solar declination, monthly average (year '99)	latitude		Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree	degree	Wh/day	hour/day	kW/m <sup>2</sup>	MJ/m <sup>2</sup> /day	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp
Jan.	-20.79	-8.3	48.2	5.9	0.7	14.9	15.10	28.8	14.87	29.3	14.52	29.9	14.07	30.9	13.80	31.5	13.51	32.2	12.84	33.9
Feb.	-12.96	-8.3	48.2	5.0	0.7	12.6	12.64	34.4	12.60	34.5	12.46	34.9	12.23	35.6	12.08	36.0	11.90	36.5	11.49	37.9
Mar.	-1.99	-8.3	48.2	5.8	0.7	14.6	14.42	30.2	14.62	29.8	14.70	29.6	14.67	29.6	14.62	29.8	14.54	29.9	14.29	30.4
Apr.	9.61	-8.3	48.2	5.6	0.7	14.1	13.66	31.8	14.11	30.8	14.46	30.1	14.69	29.6	14.76	29.5	14.81	29.4	14.82	29.3
May	18.73	-8.3	48.2	5.5	0.7	13.9	13.19	33.0	13.86	31.4	14.42	30.2	14.88	29.2	15.06	28.9	15.22	28.6	15.44	28.2
June	23.04	-8.3	48.2	5.3	0.7	13.4	12.60	34.5	13.36	32.6	14.01	31.0	14.57	29.9	14.80	29.4	15.01	29.0	15.33	28.4
July	21.23	-8.3	48.2	4.6	0.7	11.6	10.98	39.6	11.59	37.5	12.12	35.9	12.56	34.6	12.74	34.1	12.90	33.7	13.14	33.1
Aug.	13.80	-8.3	48.2	5.4	0.7	13.6	13.07	33.3	13.61	32.0	14.04	31.0	14.36	30.3	14.48	30.0	14.57	29.8	14.68	29.6
Sept.	3.06	-8.3	48.2	5.5	0.7	13.9	13.56	32.1	13.86	31.4	14.05	31.0	14.13	30.8	14.13	30.8	14.11	30.8	13.98	31.1
Oct.	-8.55	-8.3	48.2	5.9	0.7	14.9	14.82	29.4	14.87	29.3	14.81	29.4	14.63	29.7	14.50	30.0	14.34	30.3	13.95	31.2
Nov.	-18.24	-8.3	48.2	6.5	0.7	16.4	16.57	26.3	16.38	26.6	16.07	27.1	15.63	27.8	15.37	28.3	15.08	28.8	14.41	30.2
Dec.	-22.97	-8.3	48.2	6.2	0.7	15.6	15.92	27.3	15.62	27.8	15.21	28.6	14.68	29.6	14.37	30.3	14.03	31.0	13.28	32.7
Total						169.3	166.53		169.34		170.87		171.10		170.72		170.02		167.65	
Average				5.6		14.1	13.88	31.7	14.11	31.1	14.24	30.7	14.26	30.6	14.23	30.7	14.17	30.8	13.97	31.3
Maximum				6.5		16.4	16.57	39.6	16.38	37.5	16.07	35.9	15.63	35.6	15.37	36.0	15.22	36.5	15.44	37.9
Minimum				4.6		11.6	10.98	26.3	11.59	26.6	12.12	27.1	12.23	27.8	12.08	28.3	11.90	28.6	11.49	28.2

(Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '=1-0.0042*(65-25), supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	1	4	44.0
	FL 9W	9			0.0
	FL 7W	7			0.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	0.7	4.2
Total (Wh/day)		---	---	---	48.2

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
48.2	0.5	5.0	0.9	1.0	45

Appendix 7-8-2 Calculation of PV and battery capacity in Munda (2/3) (for a private house)

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree	degree	Wh/day	hour/day	kW/m <sup>2</sup>	MJ/m <sup>2</sup> /day	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp
Jan.	-20.79	-8.30	73.4	5.9	0.7	14.9	15.10	43.9	14.87	44.5	14.52	45.6	14.07	47.1	13.80	48.0	13.51	49.0	12.84	51.6
Feb.	-12.96	-8.30	73.4	5.0	0.7	12.6	12.64	52.4	12.60	52.6	12.46	53.1	12.23	54.2	12.08	54.8	11.90	55.6	11.49	57.7
Mar.	-1.99	-8.30	73.4	5.8	0.7	14.6	14.42	45.9	14.62	45.3	14.70	45.1	14.67	45.1	14.62	45.3	14.54	45.6	14.29	46.4
Apr.	9.61	-8.30	73.4	5.6	0.7	14.1	13.66	48.5	14.11	46.9	14.46	45.8	14.69	45.1	14.76	44.9	14.81	44.7	14.82	44.7
May	18.73	-8.30	73.4	5.5	0.7	13.9	13.19	50.2	13.86	47.8	14.42	45.9	14.88	44.5	15.06	44.0	15.22	43.5	15.44	42.9
June	23.04	-8.30	73.4	5.3	0.7	13.4	12.60	52.6	13.36	49.6	14.01	47.3	14.57	45.5	14.80	44.8	15.01	44.1	15.33	43.2
July	21.23	-8.30	73.4	4.6	0.7	11.6	10.98	60.3	11.59	57.1	12.12	54.6	12.56	52.7	12.74	52.0	12.90	51.4	13.14	50.4
Aug.	13.80	-8.30	73.4	5.4	0.7	13.6	13.07	50.7	13.61	48.7	14.04	47.2	14.36	46.1	14.48	45.7	14.57	45.4	14.68	45.1
Sept.	3.06	-8.30	73.4	5.5	0.7	13.9	13.56	48.8	13.86	47.8	14.05	47.1	14.13	46.9	14.13	46.9	14.11	46.9	13.98	47.4
Oct.	-8.55	-8.30	73.4	5.9	0.7	14.9	14.82	44.7	14.87	44.5	14.81	44.7	14.63	45.3	14.50	45.7	14.34	46.2	13.95	47.5
Nov.	-18.24	-8.30	73.4	6.5	0.7	16.4	16.57	40.0	16.38	40.4	16.07	41.2	15.63	42.4	15.37	43.1	15.08	43.9	14.41	46.0
Dec.	-22.97	-8.30	73.4	6.2	0.7	15.6	15.92	41.6	15.62	42.4	15.21	43.6	14.68	45.1	14.37	46.1	14.03	47.2	13.28	49.9
Total						169.3	166.53		169.34		170.87		171.10		170.72		170.02		167.65	
Average				5.6		14.1	13.88	48.3	14.11	47.3	14.24	46.8	14.26	46.7	14.23	46.8	14.17	47.0	13.97	47.7
Maximum				6.5		16.4	16.57	60.3	16.38	57.1	16.07	54.6	15.63	54.2	15.37	54.8	15.22	55.6	15.44	57.7
Minimum				4.6		11.6	10.98	40.0	11.59	40.4	12.12	41.2	12.23	42.4	12.08	43.1	11.90	43.5	11.49	42.9

(Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '=1-0.0042*(65-25)、 supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	1	4	44.0
	FL 9W	9	1	1.5	13.5
	FL 7W	7	1	1.5	10.5
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	0.9	5.4
Total (Wh/day)		---	---	---	73.4

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
73.4	0.5	5.0	0.9	1.0	68

Appendix 7-8-2 Calculation of PV and battery capacity in Munda (3/3)																			(for a public facility)		
Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20		
	Solar irradiation on tilt plane						PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree						degree	Wh/day	hour/day	kW/m²	MJ/m²/day	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp
Jan.	-20.79	-8.30	100.4	5.9	0.7	14.9	15.10	60.0	14.87	60.9	14.52	62.4	14.07	64.4	13.80	65.6	13.51	67.1	12.84	70.5	
Feb.	-12.96	-8.30	100.4	5.0	0.7	12.6	12.64	71.7	12.60	71.9	12.46	72.7	12.23	74.1	12.08	75.0	11.90	76.1	11.49	78.8	
Mar.	-1.99	-8.30	100.4	5.8	0.7	14.6	14.42	62.8	14.62	62.0	14.70	61.6	14.67	61.7	14.62	62.0	14.54	62.3	14.29	63.4	
Apr.	9.61	-8.30	100.4	5.6	0.7	14.1	13.66	66.3	14.11	64.2	14.46	62.7	14.69	61.7	14.76	61.3	14.81	61.2	14.82	61.1	
May	18.73	-8.30	100.4	5.5	0.7	13.9	13.19	68.7	13.86	65.4	14.42	62.8	14.88	60.9	15.06	60.1	15.22	59.5	15.44	58.7	
June	23.04	-8.30	100.4	5.3	0.7	13.4	12.60	71.9	13.36	67.8	14.01	64.6	14.57	62.2	14.80	61.2	15.01	60.4	15.33	59.1	
July	21.23	-8.30	100.4	4.6	0.7	11.6	10.98	82.5	11.59	78.1	12.12	74.7	12.56	72.1	12.74	71.1	12.90	70.2	13.14	68.9	
Aug.	13.80	-8.30	100.4	5.4	0.7	13.6	13.07	69.3	13.61	66.6	14.04	64.5	14.36	63.1	14.48	62.5	14.57	62.1	14.68	61.7	
Sept.	3.06	-8.30	100.4	5.5	0.7	13.9	13.56	66.8	13.86	65.4	14.05	64.5	14.13	64.1	14.13	64.1	14.11	64.2	13.98	64.8	
Oct.	-8.55	-8.30	100.4	5.9	0.7	14.9	14.82	61.1	14.87	60.9	14.81	61.2	14.63	61.9	14.50	62.5	14.34	63.1	13.95	64.9	
Nov.	-18.24	-8.30	100.4	6.5	0.7	16.4	16.57	54.7	16.38	55.3	16.07	56.4	15.63	57.9	15.37	58.9	15.08	60.1	14.41	62.9	
Dec.	-22.97	-8.30	100.4	6.2	0.7	15.6	15.92	56.9	15.62	58.0	15.21	59.6	14.68	61.7	14.37	63.0	14.03	64.5	13.28	68.2	
Total						169.3	166.53		169.34		170.87		171.10		170.72		170.02		167.65		
Average				5.6		14.1	13.88	66.1	14.11	64.7	14.24	64.0	14.26	63.8	14.23	64.0	14.17	64.2	13.97	65.3	
Maximum				6.5		16.4	16.57	82.5	16.38	78.1	16.07	74.7	15.63	74.1	15.37	75.0	15.22	76.1	15.44	78.8	
Minimum				4.6		11.6	10.98	54.7	11.59	55.3	12.12	56.4	12.23	57.9	12.08	58.9	11.90	59.5	11.49	58.7	

(Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '=1-0.0042*(65-25)、 supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	4	2.25	99.0
	FL 9W	9			0.0
	FL 7W	7			0.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	0.23	1.4
Total (Wh/day)		---	---	---	100.4

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
100.4	0.5	5.0	0.9	1.0	93

Appendix 7-8-3 Calculation of PV and battery capacity in Taro (1/3)  
(for a private house)

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree	degree	Wh/day	hour/day	kW/m <sup>2</sup>	MJ/m <sup>2</sup> /day	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp
Jan.	-20.79	-6.4	42.6	5.9	0.7	14.9	15.14	25.4	14.87	25.9	14.48	26.5	13.98	27.5	13.69	28.1	13.37	28.7	12.67	30.3
Feb.	-12.96	-6.4	42.6	5.6	0.7	14.1	14.20	27.1	14.11	27.2	13.92	27.6	13.62	28.2	13.43	28.6	13.21	29.1	12.71	30.3
Mar.	-1.99	-6.4	42.6	5.7	0.7	14.4	14.21	27.0	14.36	26.8	14.41	26.7	14.34	26.8	14.26	27.0	14.16	27.1	13.88	27.7
Apr.	9.61	-6.4	42.6	5.9	0.7	14.9	14.44	26.6	14.87	25.9	15.18	25.3	15.38	25.0	15.44	24.9	15.47	24.9	15.43	24.9
May	18.73	-6.4	42.6	5.0	0.7	12.6	12.04	31.9	12.60	30.5	13.07	29.4	13.43	28.6	13.58	28.3	13.70	28.1	13.86	27.7
June	23.04	-6.4	42.6	4.9	0.7	12.3	11.69	32.9	12.35	31.1	12.91	29.8	13.37	28.8	13.56	28.3	13.73	28.0	13.99	27.5
July	21.23	-6.4	42.6	3.9	0.7	9.8	9.34	41.1	9.83	39.1	10.24	37.5	10.57	36.4	10.71	35.9	10.82	35.5	10.99	35.0
Aug.	13.80	-6.4	42.6	4.5	0.7	11.3	10.93	35.2	11.34	33.9	11.66	33.0	11.89	32.3	11.97	32.1	12.03	31.9	12.08	31.8
Sept.	3.06	-6.4	42.6	5.3	0.7	13.4	13.11	29.3	13.36	28.8	13.50	28.5	13.54	28.4	13.52	28.4	13.48	28.5	13.31	28.9
Oct.	-8.55	-6.4	42.6	5.5	0.7	13.9	13.85	27.7	13.86	27.7	13.76	27.9	13.56	28.4	13.42	28.6	13.25	29.0	12.85	29.9
Nov.	-18.24	-6.4	42.6	6.4	0.7	16.1	16.36	23.5	16.13	23.8	15.77	24.4	15.30	25.1	15.01	25.6	14.70	26.1	14.00	27.5
Dec.	-22.97	-6.4	42.6	5.9	0.7	14.9	15.20	25.3	14.87	25.9	14.43	26.6	13.87	27.7	13.56	28.4	13.22	29.1	12.46	30.9
Total						162.5	160.52		162.54		163.32		162.85		162.16		161.15		158.22	
Average				5.4		13.5	13.38	29.4	13.55	28.9	13.61	28.6	13.57	28.6	13.51	28.7	13.43	28.8	13.19	29.4
Maximum				6.4		16.1	16.36	41.1	16.13	39.1	15.77	37.5	15.38	36.4	15.44	35.9	15.47	35.5	15.43	35.0
Minimum				3.9		9.8	9.34	23.5	9.83	23.8	10.24	24.4	10.57	25.0	10.71	24.9	10.82	24.9	10.99	24.9

(Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '=1-0.0042*(65-25)、 supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11			0.0
	FL 9W	9	1	4	36.0
	FL 7W	7			0.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	1.1	6.6
Total (Wh/day)		---	---	---	42.6

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
42.6	0.5	5.0	0.9	1.0	39

Appendix 7-8-3 Calculation of PV and battery capacity in Taro (2/3) (for a private house)

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree	degree	Wh/day	hour/day	kW/m²	MJ/m²/day	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp
Jan.	-20.79	-6.40	65.1	5.9	0.7	14.9	15.14	38.8	14.87	39.5	14.48	40.6	13.98	42.0	13.69	42.9	13.37	43.9	12.67	46.4
Feb.	-12.96	-6.40	65.1	5.6	0.7	14.1	14.20	41.4	14.11	41.6	13.92	42.2	13.62	43.1	13.43	43.8	13.21	44.5	12.71	46.2
Mar.	-1.99	-6.40	65.1	5.7	0.7	14.4	14.21	41.3	14.36	40.9	14.41	40.8	14.34	41.0	14.26	41.2	14.16	41.5	13.88	42.3
Apr.	9.61	-6.40	65.1	5.9	0.7	14.9	14.44	40.7	14.87	39.5	15.18	38.7	15.38	38.2	15.44	38.0	15.47	38.0	15.43	38.1
May	18.73	-6.40	65.1	5.0	0.7	12.6	12.04	48.8	12.60	46.6	13.07	45.0	13.43	43.7	13.58	43.3	13.70	42.9	13.86	42.4
June	23.04	-6.40	65.1	4.9	0.7	12.3	11.69	50.2	12.35	47.6	12.91	45.5	13.37	43.9	13.56	43.3	13.73	42.8	13.99	42.0
July	21.23	-6.40	65.1	3.9	0.7	9.8	9.34	62.9	9.83	59.8	10.24	57.4	10.57	55.6	10.71	54.9	10.82	54.3	10.99	53.4
Aug.	13.80	-6.40	65.1	4.5	0.7	11.3	10.93	53.7	11.34	51.8	11.66	50.4	11.89	49.4	11.97	49.1	12.03	48.8	12.08	48.6
Sept.	3.06	-6.40	65.1	5.3	0.7	13.4	13.11	44.8	13.36	44.0	13.50	43.5	13.54	43.4	13.52	43.4	13.48	43.6	13.31	44.1
Oct.	-8.55	-6.40	65.1	5.5	0.7	13.9	13.85	42.4	13.86	42.4	13.76	42.7	13.56	43.3	13.42	43.8	13.25	44.3	12.85	45.7
Nov.	-18.24	-6.40	65.1	6.4	0.7	16.1	16.36	35.9	16.13	36.4	15.77	37.2	15.30	38.4	15.01	39.1	14.70	40.0	14.00	42.0
Dec.	-22.97	-6.40	65.1	5.9	0.7	14.9	15.20	38.7	14.87	39.5	14.43	40.7	13.87	42.3	13.56	43.3	13.22	44.4	12.46	47.2
Total						162.5	160.52		162.54		163.32		162.85		162.16		161.15		158.22	
Average				5.4		13.5	13.38	45.0	13.55	44.1	13.61	43.7	13.57	43.7	13.51	43.8	13.43	44.1	13.19	44.9
Maximum				6.4		16.1	16.36	62.9	16.13	59.8	15.77	57.4	15.38	55.6	15.44	54.9	15.47	54.3	15.43	53.4
Minimum				3.9		9.8	9.34	35.9	9.83	36.4	10.24	37.2	10.57	38.2	10.71	38.0	10.82	38.0	10.99	38.1

(Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '=1-0.0042*(65-25)、 supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11			0.0
	FL 9W	9			0.0
	FL 7W	7	3	3.1	65.1
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	0	0.0
Total (Wh/day)		---	---	---	65.1

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
65.1	0.5	5.0	0.9	1.0	60



Appendix 7-8-3 Calculation of PV and battery capacity in Taro (3/3) (for a public facility)

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree	degree	Wh/day	hour/day	kW/m <sup>2</sup>	MJ/m <sup>2</sup> /day	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp
Jan.	-20.79	-6.40	89.0	5.9	0.7	14.9	15.14	53.0	14.87	54.0	14.48	55.5	13.98	57.5	13.69	58.7	13.37	60.1	12.67	63.4
Feb.	-12.96	-6.40	89.0	5.6	0.7	14.1	14.20	56.6	14.11	56.9	13.92	57.7	13.62	59.0	13.43	59.8	13.21	60.8	12.71	63.2
Mar.	-1.99	-6.40	89.0	5.7	0.7	14.4	14.21	56.5	14.36	55.9	14.41	55.8	14.34	56.0	14.26	56.3	14.16	56.7	13.88	57.9
Apr.	9.61	-6.40	89.0	5.9	0.7	14.9	14.44	55.6	14.87	54.0	15.18	52.9	15.38	52.2	15.44	52.0	15.47	51.9	15.43	52.1
May	18.73	-6.40	89.0	5.0	0.7	12.6	12.04	66.7	12.60	63.8	13.07	61.5	13.43	59.8	13.58	59.1	13.70	58.6	13.86	58.0
June	23.04	-6.40	89.0	4.9	0.7	12.3	11.69	68.7	12.35	65.1	12.91	62.2	13.37	60.1	13.56	59.2	13.73	58.5	13.99	57.4
July	21.23	-6.40	89.0	3.9	0.7	9.8	9.34	86.0	9.83	81.7	10.24	78.5	10.57	76.0	10.71	75.0	10.82	74.2	10.99	73.1
Aug.	13.80	-6.40	89.0	4.5	0.7	11.3	10.93	73.5	11.34	70.8	11.66	68.9	11.89	67.5	11.97	67.1	12.03	66.8	12.08	66.5
Sept.	3.06	-6.40	89.0	5.3	0.7	13.4	13.11	61.3	13.36	60.1	13.50	59.5	13.54	59.3	13.52	59.4	13.48	59.6	13.31	60.3
Oct.	-8.55	-6.40	89.0	5.5	0.7	13.9	13.85	58.0	13.86	58.0	13.76	58.4	13.56	59.2	13.42	59.9	13.25	60.6	12.85	62.5
Nov.	-18.24	-6.40	89.0	6.4	0.7	16.1	16.36	49.1	16.13	49.8	15.77	50.9	15.30	52.5	15.01	53.5	14.70	54.6	14.00	57.4
Dec.	-22.97	-6.40	89.0	5.9	0.7	14.9	15.20	52.9	14.87	54.0	14.43	55.7	13.87	57.9	13.56	59.2	13.22	60.8	12.46	64.5
Total						162.5	160.52		162.54		163.32		162.85		162.16		161.15		158.22	
Average				5.4		13.5	13.38	61.5	13.55	60.4	13.61	59.8	13.57	59.8	13.51	59.9	13.43	60.3	13.19	61.4
Maximum				6.4		16.1	16.36	86.0	16.13	81.7	15.77	78.5	15.38	76.0	15.44	75.0	15.47	74.2	15.43	73.1
Minimum				3.9		9.8	9.34	49.1	9.83	49.8	10.24	50.9	10.57	52.2	10.71	52.0	10.82	51.9	10.99	52.1

(Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '=1-0.0042*(65-25), supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	4	2	88.0
	FL 9W	9			0.0
	FL 7W	7			0.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	0.17	1.0
Total (Wh/day)		---	---	---	89.0

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
89.0	0.5	5.0	0.9	1.0	82

Appendix 7-8-4 Calculation of PV and battery capacity in Lata (1/3) (for a private house)

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion facto r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
	degree	degree	Wh/day	hour/day	kW/m²	MJ/m²/day	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp	MJ/m²/day	Wp
Jan.	-20.79	-10.7	51.8	5.6	0.7	14.1	14.28	32.7	14.11	33.1	13.84	33.8	13.46	34.7	13.23	35.3	12.98	36.0	12.40	37.7
Feb.	-12.96	-10.7	51.8	5.4	0.7	13.6	13.60	34.4	13.61	34.3	13.51	34.6	13.31	35.1	13.17	35.5	13.01	35.9	12.60	37.1
Mar.	-1.99	-10.7	51.8	5.1	0.7	12.9	12.63	37.0	12.85	36.4	12.97	36.0	13.00	36.0	12.97	36.0	12.92	36.2	12.75	36.7
Apr.	9.61	-10.7	51.8	5.8	0.7	14.6	14.09	33.2	14.62	32.0	15.03	31.1	15.33	30.5	15.44	30.3	15.52	30.1	15.58	30.0
May	18.73	-10.7	51.8	5.0	0.7	12.6	11.93	39.2	12.60	37.1	13.17	35.5	13.64	34.3	13.84	33.8	14.01	33.4	14.27	32.8
June	23.04	-10.7	51.8	5.3	0.7	13.4	12.53	37.3	13.36	35.0	14.08	33.2	14.70	31.8	14.97	31.2	15.21	30.7	15.60	30.0
July	21.23	-10.7	51.8	5.4	0.7	13.6	12.82	36.5	13.61	34.3	14.30	32.7	14.87	31.4	15.12	30.9	15.34	30.5	15.69	29.8
Aug.	13.80	-10.7	51.8	5.3	0.7	13.4	12.77	36.6	13.36	35.0	13.84	33.8	14.21	32.9	14.36	32.6	14.48	32.3	14.63	31.9
Sept.	3.06	-10.7	51.8	5.3	0.7	13.4	13.02	35.9	13.36	35.0	13.59	34.4	13.72	34.1	13.75	34.0	13.75	34.0	13.67	34.2
Oct.	-8.55	-10.7	51.8	6.0	0.7	15.1	15.01	31.1	15.12	30.9	15.11	30.9	14.99	31.2	14.88	31.4	14.75	31.7	14.40	32.5
Nov.	-18.24	-10.7	51.8	6.4	0.7	16.1	16.25	28.8	16.13	29.0	15.88	29.4	15.51	30.1	15.28	30.6	15.03	31.1	14.43	32.4
Dec.	-22.97	-10.7	51.8	5.7	0.7	14.4	14.58	32.1	14.36	32.5	14.04	33.3	13.60	34.4	13.35	35.0	13.07	35.8	12.43	37.6
Total						167.1	163.52		167.08		169.36		170.36		170.37		170.05		168.46	
Average				5.5		320.04	13.63	34.6	13.92	33.7	14.11	33.2	14.20	33.0	14.20	33.0	14.17	33.1	14.04	33.5
Maximum				6.4		16.1	16.25	39.2	16.13	37.1	15.88	36.0	15.51	36.0	15.44	36.0	15.52	36.2	15.69	37.7
Minimum				5.0		12.6	11.93	28.8	12.60	29.0	12.97	29.4	13.00	30.1	12.97	30.3	12.92	30.1	12.40	29.8

(Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, '=1-0.0042*(65-25), supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	K0=As*K1*K2*K3*K4*K5*K6*K7*K8*K9*K10

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	1	4	44.0
	FL 9W	9			0.0
	FL 7W	7			0.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	1.3	7.8
Total (Wh/day)		---	---	---	51.8

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
51.8	0.5	5.0	0.9	1.0	48

**Appendix 7-8-4 Calculation of PV and battery capacity in Lata (2/3)**

**(for a private house)**

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion factor for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
							MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp
Jan.	-20.79	-10.70	79.0	5.6	0.7	14.1	14.28	49.9	14.11	50.5	13.84	51.5	13.46	53.0	13.23	53.9	12.98	54.9	12.40	57.5
Feb.	-12.96	-10.70	79.0	5.4	0.7	13.6	13.60	52.4	13.61	52.4	13.51	52.8	13.31	53.6	13.17	54.1	13.01	54.8	12.60	56.6
Mar.	-1.99	-10.70	79.0	5.1	0.7	12.9	12.63	56.4	12.85	55.5	12.97	55.0	13.00	54.9	12.97	55.0	12.92	55.2	12.75	55.9
Apr.	9.61	-10.70	79.0	5.8	0.7	14.6	14.09	50.6	14.62	48.8	15.03	47.4	15.33	46.5	15.44	46.2	15.52	45.9	15.58	45.8
May	18.73	-10.70	79.0	5.0	0.7	12.6	11.93	59.8	12.60	56.6	13.17	54.1	13.64	52.3	13.84	51.5	14.01	50.9	14.27	50.0
June	23.04	-10.70	79.0	5.3	0.7	13.4	12.53	56.9	13.36	53.4	14.08	50.6	14.70	48.5	14.97	47.6	15.21	46.9	15.60	45.7
July	21.23	-10.70	79.0	5.4	0.7	13.6	12.82	55.6	13.61	52.4	14.30	49.9	14.87	47.9	15.12	47.2	15.34	46.5	15.69	45.5
Aug.	13.80	-10.70	79.0	5.3	0.7	13.4	12.77	55.8	13.36	53.4	13.84	51.5	14.21	50.2	14.36	49.7	14.48	49.3	14.63	48.7
Sept.	3.06	-10.70	79.0	5.3	0.7	13.4	13.02	54.8	13.36	53.4	13.59	52.5	13.72	52.0	13.75	51.9	13.75	51.9	13.67	52.2
Oct.	-8.55	-10.70	79.0	6.0	0.7	15.1	15.01	47.5	15.12	47.2	15.11	47.2	14.99	47.6	14.88	47.9	14.75	48.3	14.40	49.5
Nov.	-18.24	-10.70	79.0	6.4	0.7	16.1	16.25	43.9	16.13	44.2	15.88	44.9	15.51	46.0	15.28	46.7	15.03	47.5	14.43	49.4
Dec.	-22.97	-10.70	79.0	5.7	0.7	14.4	14.58	48.9	14.36	49.6	14.04	50.8	13.60	52.4	13.35	53.4	13.07	54.6	12.43	57.4
Total						167.1	163.52		167.08		169.36		170.36		170.37		170.05		168.46	
Average				5.5		13.9	13.63	52.7	13.92	51.4	14.11	50.7	14.20	50.4	14.20	50.4	14.17	50.6	14.04	51.2
Maximum				6.4		16.1	16.25	59.8	16.13	56.6	15.88	55.0	15.51	54.9	15.44	55.0	15.52	55.2	15.69	57.5
Minimum				5.0		12.6	11.93	43.9	12.60	44.2	12.97	44.9	13.00	46.0	12.97	46.2	12.92	45.9	12.40	45.5

A7-28

**(Coefficient for PV panel)**

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, $\gamma = 1 - 0.0042 \times (65 - 25)$ , supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	$K0 = As \times K1 \times K2 \times K3 \times K4 \times K5 \times K6 \times K7 \times K8 \times K9 \times K10$

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	1	4	44.0
	FL 9W	9	1	2	18.0
	FL 7W	7	1	1	7.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	1.67	10.0
Total (Wh/day)		---	---	---	79.0

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
79.0	0.5	5.0	0.9	1.0	73



### Appendix 7-8-4 Calculation of PV and battery capacity in Lata (3/3)

(for a public facility)

Month	solar declination, monthly average (year '99)	latitude	Power demand	Average sunshine hours	Conversion factor r for equivalent sunshine hour	Solar irradiation on horizontal plane	tilt angle, -5		tilt angle, 0		tilt angle, 5		tilt angle, 10		tilt angle, 12.5		tilt angle, 15		tilt angle, 20	
							Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand	Solar irradiation on tilt plane	PV capacity to meet demand
							MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp	MJ/m <sup>2</sup> /day	Wp
Jan.	-20.79	-10.70	107.8	5.6	0.7	14.1	14.28	68.1	14.11	68.9	13.84	70.3	13.46	72.2	13.23	73.5	12.98	74.9	12.40	78.4
Feb.	-12.96	-10.70	107.8	5.4	0.7	13.6	13.60	71.5	13.61	71.5	13.51	72.0	13.31	73.1	13.17	73.8	13.01	74.8	12.60	77.2
Mar.	-1.99	-10.70	107.8	5.1	0.7	12.9	12.63	77.0	12.85	75.7	12.97	74.9	13.00	74.8	12.97	75.0	12.92	75.2	12.75	76.3
Apr.	9.61	-10.70	107.8	5.8	0.7	14.6	14.09	69.0	14.62	66.5	15.03	64.7	15.33	63.4	15.44	63.0	15.52	62.7	15.58	62.4
May	18.73	-10.70	107.8	5.0	0.7	12.6	11.93	81.5	12.60	77.2	13.17	73.8	13.64	71.3	13.84	70.3	14.01	69.4	14.27	68.1
June	23.04	-10.70	107.8	5.3	0.7	13.4	12.53	77.6	13.36	72.8	14.08	69.0	14.70	66.1	14.97	65.0	15.21	63.9	15.60	62.3
July	21.23	-10.70	107.8	5.4	0.7	13.6	12.82	75.9	13.61	71.5	14.30	68.0	14.87	65.4	15.12	64.3	15.34	63.4	15.69	62.0
Aug.	13.80	-10.70	107.8	5.3	0.7	13.4	12.77	76.1	13.36	72.8	13.84	70.3	14.21	68.4	14.36	67.7	14.48	67.2	14.63	66.5
Sept.	3.06	-10.70	107.8	5.3	0.7	13.4	13.02	74.7	13.36	72.8	13.59	71.6	13.72	70.9	13.75	70.7	13.75	70.7	13.67	71.1
Oct.	-8.55	-10.70	107.8	6.0	0.7	15.1	15.01	64.8	15.12	64.3	15.11	64.3	14.99	64.9	14.88	65.3	14.75	65.9	14.40	67.5
Nov.	-18.24	-10.70	107.8	6.4	0.7	16.1	16.25	59.8	16.13	60.3	15.88	61.2	15.51	62.7	15.28	63.6	15.03	64.7	14.43	67.4
Dec.	-22.97	-10.70	107.8	5.7	0.7	14.4	14.58	66.7	14.36	67.7	14.04	69.3	13.60	71.5	13.35	72.9	13.07	74.4	12.43	78.2
Total						167.1	163.52		167.08		169.36		170.36		170.37		170.05		168.46	
Average				5.5		13.9	13.63	71.9	13.92	70.2	14.11	69.1	14.20	68.7	14.20	68.8	14.17	68.9	14.04	69.8
Maximum				6.4		16.1	16.25	81.5	16.13	77.2	15.88	74.9	15.51	74.8	15.44	75.0	15.52	75.2	15.69	78.4
Minimum				5.0		12.6	11.93	59.8	12.60	60.3	12.97	61.2	13.00	62.7	12.97	63.0	12.92	62.7	12.40	62.0

A7-29

#### (Coefficient for PV panel)

As	1.00	Design flexibility
K1	0.83	Coefficient of temperature, $t = 1 - 0.0042 \times (65 - 25)$ , supposing that operation temperature of cells is 65 degrees.
K2	0.99	Coefficient of the panel surface dirt
K3	0.80	Efficiency of charge and discharge
K4	0.91	Coefficient of the DC circuit loss 5%, C/C loss 4%
K5	1.00	If inverter installed, efficiency of the inverter would be considered
K6	0.80	Coefficient of difference between maximum power point and actual operation point
K7	0.95	Coefficient of the dispersion of the solar radiation quantity
K8	0.95	Coefficient of the condition around PV panel
K9	0.97	Coefficient due to the difference from designed tilt angle and orientation for PV panel
K10	0.95	Coefficient due to lost performance with age
K0	0.399	$K0 = As \times K1 \times K2 \times K3 \times K4 \times K5 \times K6 \times K7 \times K8 \times K9 \times K10$

Applicable appliances and their energy consumption					
Appliances		Power Consumption (W)	The number	Lighting Hour (h/day)	Energy Consumption (Wh/day)
Fluorescent lamp *	FL 11W	11	4	2.34	103.0
	FL 9W	9			0.0
	FL 7W	7			0.0
TV(B&W14)	12V 12W	12			0.0
Radio Cassette	12V 6W	6	1	0.8	4.8
Total (Wh/day)		---	---	---	107.8

\*Note: If inverter is installed, efficiency of inverter should be included in power consumption.

Battery Capacity (Ah)					
Energy Consumption (Wh/day)	depth of discharge	Consecutive non-sunshine day	Maintenance factor	Efficient of inverter	Capacity
107.8	0.5	5.0	0.9	1.0	100

**Appendix 7-8-5 Calculation of available demand on PV panel, available consecutive non-sunshine day & its recovery day on battery in Honiara**

Month	Solar irradiation on PV (tilt angle 12.5 deg)	Available demand(Wh/day) & Charging current(Ah/day)						Available consecutive non-sunshine day & Recovery day					
		36 Wp system		55 Wp system		75 Wp system		56.5 Ah Battery (36Wp system)	80 Ah Battery (55Wp system)	108 Ah Battery (75Wp system)			
	MJ/m <sup>2</sup> /day	Wh/day	Ah/day	Wh/day	Ah/day	Wh/day	Ah/day	non-sunshine	recovery	non-sunshine	recovery	non-sunshine	recovery
Jan.	14.10	56.3	5.49	86.0	8.40	117.2	11.45	6.0	5.1	5.6	4.8	5.5	4.7
Feb.	14.56	58.1	5.67	88.7	8.67	121.0	11.82	5.8	5.0	5.4	4.6	5.4	4.6
Mar.	15.95	63.6	6.21	97.2	9.49	132.5	12.94	5.3	4.5	4.9	4.2	4.9	4.2
Apr.	17.48	69.7	6.81	106.5	10.40	145.3	14.19	4.9	4.1	4.5	3.8	4.5	3.8
May	18.44	73.6	7.18	112.4	10.98	153.2	14.97	4.6	3.9	4.3	3.6	4.2	3.6
June	19.37	77.3	7.55	118.0	11.53	161.0	15.72	4.4	3.7	4.1	3.5	4.0	3.4
July	17.26	68.8	6.72	105.2	10.27	143.4	14.01	4.9	4.2	4.6	3.9	4.5	3.9
Aug.	18.05	72.0	7.03	110.0	10.75	150.0	14.65	4.7	4.0	4.4	3.7	4.3	3.7
Sept.	17.03	68.0	6.64	103.8	10.14	141.6	13.83	5.0	4.3	4.6	3.9	4.6	3.9
Oct.	17.77	70.9	6.92	108.3	10.58	147.7	14.43	4.8	4.1	4.4	3.8	4.4	3.7
Nov.	18.05	72.0	7.03	110.0	10.75	150.1	14.66	4.7	4.0	4.4	3.7	4.3	3.7
Dec.	15.37	61.3	5.99	93.7	9.15	127.7	12.48	5.5	4.7	5.1	4.4	5.1	4.3
Average	16.95	67.6	6.61	103.3	10.09	140.9	13.76	5.1	4.3	4.7	4.0	4.6	4.0
Maximum	19.37	77.3	7.55	118.0	11.53	161.0	15.72	6.0	5.1	5.6	4.8	5.5	4.7
Minimum	14.10	56.3	5.49	86.0	8.40	117.2	11.45	4.4	3.7	4.1	3.5	4.0	3.4

**Appendix7-8-6 Calculation of available demand on PV panel, available consecutive non-sunshine day & its recovery day on battery in Munda**


Month	Solar irradiation on PV (tilt angle 12.5 deg)	Available demand(Wh/day) & Charging current(Ah/day)						Available consecutive non-sunshine day & Recovery day					
		36 Wp system		55 Wp system		75 Wp system		56.5	Ah Battery (36Wp system)	80	Ah Battery (55Wp system)	108	Ah Battery (75Wp system)
	MJ/m <sup>2</sup> /day	Wh/day	Ah/day	Wh/day	Ah/day	Wh/day	Ah/day	non-sushine	recovery	non-sushine	recovery	non-sushine	recovery
Jan.	13.80	55.1	5.38	84.1	8.22	114.7	11.20	6.2	5.3	5.7	4.9	5.6	4.8
Feb.	12.08	48.2	4.71	73.6	7.19	100.4	9.81	7.0	6.0	6.5	5.6	6.5	5.5
Mar.	14.62	58.3	5.70	89.1	8.70	121.5	11.87	5.8	5.0	5.4	4.6	5.3	4.6
Apr.	14.76	58.9	5.75	90.0	8.79	122.7	11.99	5.8	4.9	5.3	4.6	5.3	4.5
May	15.06	60.1	5.87	91.8	8.97	125.2	12.23	5.6	4.8	5.2	4.5	5.2	4.4
June	14.80	59.0	5.77	90.2	8.81	123.0	12.01	5.7	4.9	5.3	4.5	5.3	4.5
July	12.74	50.8	4.96	77.6	7.58	105.9	10.34	6.7	5.7	6.2	5.3	6.1	5.2
Aug.	14.48	57.8	5.64	88.3	8.62	120.4	11.76	5.9	5.0	5.4	4.6	5.4	4.6
Sept.	14.13	56.4	5.51	86.1	8.41	117.5	11.47	6.0	5.1	5.6	4.8	5.5	4.7
Oct.	14.50	57.9	5.65	88.4	8.63	120.5	11.77	5.9	5.0	5.4	4.6	5.4	4.6
Nov.	15.37	61.3	5.99	93.7	9.15	127.8	12.48	5.5	4.7	5.1	4.4	5.1	4.3
Dec.	14.37	57.3	5.60	87.6	8.55	119.4	11.66	5.9	5.0	5.5	4.7	5.4	4.6
Average	14.23	56.8	5.54	86.7	8.47	118.2	11.55	6.0	5.1	5.6	4.7	5.5	4.7
Maximum	15.37	61.3	5.99	93.7	9.15	127.8	12.48	7.0	6.0	6.5	5.6	6.5	5.5
Minimum	12.08	48.2	4.71	73.6	7.19	100.4	9.81	5.5	4.7	5.1	4.4	5.1	4.3

**Appendix 7-8-7 Calculation of available demand on PV panel, available consecutive non-sunshine day & its recovery day on battery in Taro**


Month	Solar irradiation on PV (tilt angle 12.5 deg)	Available demand(Wh/day) & Charging current(Ah/day)						Available consecutive non-sunshine day & Recovery day					
		36 Wp system		55 Wp system		75 Wp system		56.5 Ah Battery (36Wp system)		80 Ah Battery (55Wp system)		108 Ah Battery (75Wp system)	
	MJ/m <sup>2</sup> /day	Wh/day	Ah/day	Wh/day	Ah/day	Wh/day	Ah/day	non-sunshine	recovery	non-sunshine	recovery	non-sunshine	recovery
Jan.	13.69	54.6	5.33	83.4	8.15	113.8	11.11	6.2	5.3	5.8	4.9	5.7	4.9
Feb.	13.43	53.6	5.23	81.8	7.99	111.6	10.90	6.3	5.4	5.9	5.0	5.8	5.0
Mar.	14.26	56.9	5.56	86.9	8.49	118.5	11.58	6.0	5.1	5.5	4.7	5.5	4.7
Apr.	15.44	61.6	6.02	94.1	9.19	128.3	12.53	5.5	4.7	5.1	4.4	5.0	4.3
May	13.58	54.2	5.29	82.8	8.08	112.9	11.02	6.3	5.3	5.8	4.9	5.7	4.9
June	13.56	54.1	5.29	82.7	8.07	112.7	11.01	6.3	5.3	5.8	5.0	5.7	4.9
July	10.71	42.7	4.17	65.3	6.37	89.0	8.69	7.9	6.8	7.4	6.3	7.3	6.2
Aug.	11.97	47.8	4.67	73.0	7.13	99.5	9.72	7.1	6.1	6.6	5.6	6.5	5.6
Sept.	13.52	53.9	5.27	82.4	8.05	112.4	10.98	6.3	5.4	5.8	5.0	5.8	4.9
Oct.	13.42	53.5	5.23	81.8	7.99	111.5	10.89	6.3	5.4	5.9	5.0	5.8	5.0
Nov.	15.01	59.9	5.85	91.5	8.94	124.8	12.19	5.7	4.8	5.2	4.5	5.2	4.4
Dec.	13.56	54.1	5.28	82.6	8.07	112.7	11.01	6.3	5.3	5.8	5.0	5.8	4.9
Average	13.51	53.9	5.27	82.4	8.04	112.3	10.97	6.3	5.4	5.9	5.0	5.8	5.0
Maximum	15.44	61.6	6.02	94.1	9.19	128.3	12.53	7.9	6.8	7.4	6.3	7.3	6.2
Minimum	10.71	42.7	4.17	65.3	6.37	89.0	8.69	5.5	4.7	5.1	4.4	5.0	4.3

**Appendix 7-8-8 Calculation of available demand on PV panel, available consecutive non-sunshine day & its recovery day on battery in Lata**


Month	Solar irradiation on PV (tilt angle 12.5 deg)	Available demand(Wh/day) & Charging current(Ah/day)						Available consecutive non-sunshine day & Recovery day					
		36 Wp system		55 Wp system		75 Wp system		56.5 Ah Battery (36Wp system)		80 Ah Battery (55Wp system)		108 Ah Battery (75Wp system)	
	MJ/m <sup>2</sup> /day	Wh/day	Ah/day	Wh/day	Ah/day	Wh/day	Ah/day	non-sushine	recovery	non-sushine	recovery	non-sushine	recovery
Jan.	13.23	52.8	5.16	80.7	7.88	110.0	10.74	6.4	5.5	6.0	5.1	5.9	5.0
Feb.	13.17	52.5	5.13	80.3	7.84	109.5	10.69	6.5	5.5	6.0	5.1	5.9	5.1
Mar.	12.97	51.8	5.06	79.1	7.72	107.8	10.53	6.5	5.6	6.1	5.2	6.0	5.1
Apr.	15.44	61.6	6.02	94.1	9.19	128.3	12.53	5.5	4.7	5.1	4.4	5.0	4.3
May	13.84	55.2	5.39	84.4	8.24	115.0	11.23	6.1	5.2	5.7	4.9	5.6	4.8
June	14.97	59.7	5.83	91.2	8.91	124.4	12.15	5.7	4.8	5.3	4.5	5.2	4.4
July	15.12	60.3	5.89	92.2	9.00	125.7	12.27	5.6	4.8	5.2	4.4	5.2	4.4
Aug.	14.36	57.3	5.59	87.5	8.55	119.3	11.65	5.9	5.0	5.5	4.7	5.4	4.6
Sept.	13.75	54.8	5.36	83.8	8.18	114.3	11.16	6.2	5.3	5.7	4.9	5.7	4.8
Oct.	14.88	59.4	5.80	90.7	8.86	123.7	12.08	5.7	4.9	5.3	4.5	5.2	4.5
Nov.	15.28	61.0	5.96	93.2	9.10	127.0	12.41	5.6	4.7	5.2	4.4	5.1	4.4
Dec.	13.35	53.2	5.20	81.4	7.95	110.9	10.84	6.4	5.4	5.9	5.0	5.8	5.0
Average	14.20	56.6	5.53	86.5	8.45	118.0	11.52	6.0	5.1	5.6	4.8	5.5	4.7
Maximum	15.44	61.6	6.02	94.1	9.19	128.3	12.53	6.5	5.6	6.1	5.2	6.0	5.1
Minimum	12.97	51.8	5.06	79.1	7.72	107.8	10.53	5.5	4.7	5.1	4.4	5.0	4.3



Appendix. 7-8-9 Available demand on PV, available non-sunshine day and recovery day on battery in Honiara (1/3)




Appendix. 7-8-9 Available demand on PV, available non-sunshine day and recovery day on battery in Honiara (2/3)




(75W system)

Appendix 7-8-9 Available demand on PV, available non-sunshine day and recovery day on battery in Honiara (3/3)






Appendix 7-8-10 Available demand on PV, available non-sunshine day and recovery day on battery in Munda (1/3)




(55W system)


Appendix 7-8-10 Available demand on PV, available non-sunshine day and recovery day on battery in Munda (2/3)




Appendix 7-8-10 Available demand on PV, available non-sunshine day and recovery day on battery in munda (3/3)




Appendix 7-8-11 Available demand on PV, available non-sunshine day and recovery day on battery in Taro (1/3)




Appendix 7-8-11 Available demand on PV, available non-sunshine day and recovery day on battery in Taro (2/3)



Appendix 7-8-11 Available demand on PV, available non-sunshine day and recovery day on battery in Taro (3/3)




Appendix 7-8-12 Available demand on PV, available non-sunshine day and recovery day on battery in Lata (1/3)



Appendix 7-8-12 Available demand on PV, available non-sunshine day and recovery day on battery in Lata (2/3)





Appendix 7-8-12 Available demand on PV, available non-sunshine day and recovery day on battery in Lata (3/3)

**Appendix 7-10-1(1) Expenses for the SHS (36Wp: with tax and others)**

Item	Description	Price (US\$)	Life span
PV panel	36Wp Siemens SP36 (Mono,17V,2.1A)	368	20
Battery*	12V,56.5Ah(100h):Federal 8G22NF (Sealed Gel Type, deep cycle)	248	7
Charge controller	SunLight-10(PV:10A,Load:10A) Semiconductor type, Protect O/C, O/DC	144	10
Fitting & Accessories	power point, switches, wire cables and others	122	
Wooden box	Container for Battery	19	
Installation fittings	Pole & others	204	
Transport costs	Average in whole country	20	
Construction costs		70	
Total		1,195	With tax, duty and benefit for agency

Note: import duty = CIF\*1.3\*0.05, duty surcharge = import duty\*0.05, goods tax = CIF\*1.3\*0.15, benefit for agency = CIF\*0.15

\*Battery cost includes disposal cost (US\$4/unit)

**Appendix 7-10-1(2) Expenses for the SHS (36Wp: without tax and duty)**

Item	Description	Price (US\$)	Life span
PV panel	36Wp Siemens SP36 (Mono,17V,2.1A)	300	20
Battery	12V,56.5Ah(100h):Federal 8G22NF (Sealed Gel Type, deep cycle)	202	7
Charge controller	SunLight-10(PV:10A,Load:10A) Semiconductor type, Protect O/C, O/DC	117	10
Fitting & Accessories	power point, switches, wire cables and others	100	
Wooden box	Container for Battery	19	
Installation fittings	Pole & others	168	
Transport costs	Average in whole country	20	
Construction costs		70	
Total		996	Without tax and duty

Note: benefit for agency = CIF\*0.15

\*Battery cost includes disposal cost (US\$4/unit)

**Appendix 7-10-2(1) Expenses for the SHS (55Wp: with tax and others)**

Item	Description	Price (US\$)	Life span
PV panel	55Wp Siemens SM55 (Mono,17.4V,3.15A)	486	20
Battery*	12V,56.5Ah(100h):Federal 8G24 (Sealed Gel Type, deep cycle)	290	7
Charge controller	SunLight-10(PV:10A,Load:10A) Semiconductor type, Protect O/C, O/DC	144	10
Fitting & Accessories	power point, switches, wire cables and others	165	
Wooden box	Container for Battery	19	
Installation fittings	Pole & others	204	
Transport costs	Average in whole country	20	
Construction costs		70	
Total		1,398	With tax, duty and benefit for agency

Note: import duty = CIF\*1.3\*0.05, duty surcharge = import duty\*0.05, goods tax = CIF\*1.3\*0.15, benefit for agency = CIF\*0.15

\*Battry cost includes disposal cost (US\$4/unit)

**Appendix 7-10-2(2) Expenses for the SHS (55Wp: without tax and duty)**

Item	Description	Price (US\$)	Life span
PV panel	55Wp Siemens SM55 (Mono,17.4V,3.15A)	395	20
Battery*	12V,80Ah(100h):Federal 8G24 (Sealed Gel Type, deep cycle)	237	7
Charge controller	SunLight-10(PV:10A,Load:10A) Semiconductor type, Protect O/C, O/DC	117	10
Fitting & Accessories	power point, switches, wire cables and others	134	
Wooden box	Container for Battery	19	
Installation fittings	Pole & others	168	
Transport costs	Average in whole country	20	
Construction costs		70	
Total		1,160	Without tax and duty

Note: benefit for agency = CIF\*0.15

\*Battry cost includes disposal cost (US\$4/unit)

**Appendix 7-10-3(1) Expenses for the SHS (75Wp: with tax and others)**

Item	Description	Price (US\$)	Life span
PV panel	75Wp Siemens SP75 (Mono,17V,4.4A)	627	20
Battery*	12V,108Ah(100h):Federal 8G310T (Sealed Gel Type, deep cycle)	364	7
Charge controller	SunLight-10(PV:10A,Load:10A) Semiconductor type, Protect O/C, O/DC	144	10
Fitting & Accessories	power point, switches, wire cables and others	204	
Wooden box	Container for Battery	19	
Installation fittings	Pole & others	192	
Transport costs	Average in whole country	20	
Construction costs		70	
Total		1,640	With tax, duty and benefit for agency

Note: import duty = CIF\*1.3\*0.05, duty surcharge = import duty\*0.05, goods tax = CIF\*1.3\*0.15, benefit for agency = CIF\*0.15

\*Battry cost includes disposal cost (US\$4/unit)

**Appendix 7-10-3(2) Expenses for the SHS (75Wp: without tax and duty)**

Item	Description	Price (US\$)	Life span
PV panel	75Wp Siemens SP75 (Mono,17V,4.4A)	510	20
Battery*	12V,108Ah(100h):Federal 8G310T (Sealed Gel Type, deep cycle)	297	7
Charge controller	SunLight-10(PV:10A,Load:10A) Semiconductor type, Protect O/C, O/DC	117	10
Fitting & Accessories	power point, switches, wire cables and others	100	
Wooden box	Container for Battery	19	
Installation fittings	Pole & others	168	
Transport costs	Average in whole country	20	
Construction costs		70	
Total		1,301	Without tax and duty

Note: benefit for agency = CIF\*0.15

\*Battry cost includes disposal cost (US\$4/unit)

**Appendix 7-11-1(1) Calculation of annual expenses for the SHS (36Wp: with tax and others)**

(UNIT:US\$)

Payment term (year)	20	15	10	7	5	3	0	20	15	10	7	5	3	0
Discount rate ( = r )	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%
Interest charged ( = i )	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%		0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	
Capital Recovery Factor CRF = $i / (1 - (1 + i)^{-n})$	0.074	0.090	0.123	0.167	0.225	0.360		0.050	0.067	0.100	0.143	0.200	0.333	
Initial cost ( A )	1195	1195	1195	1195	1195	1195	1195	1195	1195	1195	1195	1195	1195	1195
Down payment ( B )	30	30	30	30	30	30		30	30	30	30	30	30	
Present value of replaced battery (two unit) ( C )*	332	332	332	332	332	332	332	332	332	332	332	332	332	332
Present value of replaced charge controller ( D )*	97	97	97	97	97	97	97	97	97	97	97	97	97	97
Present value of O&M cost ( E ) *	163	163	163	163	163	163	163	163	163	163	163	163	163	163
Total Present value (F)= (A)-(B)+(C)+(D)+(E)	1757	1757	1757	1757	1757	1757	1787	1757	1757	1757	1757	1757	1757	1787
Total annual expenses (G)=(F)*CRF	129	158	217	293	395	633		88	117	176	251	351	586	
Total monthly expenses (US\$) (G)/12	10.8	13.2	18.0	24.4	32.9	52.7		7.3	9.8	14.6	20.9	29.3	48.8	
Total monthly expenses (SB\$)	53.9	65.8	90.2	121.9	164.4	263.7		36.6	48.8	73.2	104.6	146.4	244.0	

Note: excluding fluorescent light

**Appendix 7-11-1(2) Calculation of annual expenses for the SHS (36Wp: without tax and duty)**

(UNIT:US\$)

Payment term (year)	20	15	10	7	5	3	0	20	15	10	7	5	3	0
Discount rate ( = r )	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%
Interest charged ( = i )	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%		0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	
Capital Recovery Factor CRF = $i / (1 - (1 + i)^{-n})$	0.074	0.090	0.123	0.167	0.225	0.360		0.050	0.067	0.100	0.143	0.200	0.333	
Initial cost ( A )	996	996	996	996	996	996	996	996	996	996	996	996	996	996
Down payment ( B )	30	30	30	30	30	30		30	30	30	30	30	30	
Present value of replaced battery (two unit) ( C )*	270	270	270	270	270	270	270	270	270	270	270	270	270	270
Present value of replaced charge controller ( D )*	79	79	79	79	79	79	79	79	79	79	79	79	79	79
Present value of O&M cost ( E ) *	163	163	163	163	163	163	163	163	163	163	163	163	163	163
Total Present value (F)= (A)-(B)+(C)+(D)+(E)	1478	1478	1478	1478	1478	1478	1508	1478	1478	1478	1478	1478	1478	1508
Total annual expenses (G)=(F)*CRF	109	133	182	246	332	533		74	99	148	211	296	493	
Total monthly expenses (US\$) (G)/12	9.1	11.1	15.2	20.5	27.7	44.4		6.2	8.2	12.3	17.6	24.6	41.0	
Total monthly expenses (SB\$)	45.3	55.4	75.9	102.6	138.3	221.9		30.8	41.0	61.6	88.0	123.1	205.2	

Note: excluding fluorescent light

$$(C) = \text{battery}/(1+r)^7 + \text{battery}/(1+r)^{14}$$

$$(D) = \text{charge controller}/(1+r)^{10}$$

$$(E) = \sum_{n=1}^{20} \frac{O \& M}{(1+r)^n}, \quad O\&M \text{ cost} = \text{US\$}12.0/\text{year}$$

**Appendix 7-11-2(1) Calculation of annual expenses for the SHS (55Wp: with tax and others)**

(UNIT:US\$)

Payment term (year)	20	15	10	7	5	3	0	20	15	10	7	5	3	0
Discount rate ( = r )	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%
Interest charged ( = i )	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%		0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	
Capital Recovery Factor CRF = $i / (1 - (1 + i)^{-n})$	0.074	0.090	0.123	0.167	0.225	0.360		0.050	0.067	0.100	0.143	0.200	0.333	
Initial cost ( A )	1398	1398	1398	1398	1398	1398	1398	1398	1398	1398	1398	1398	1398	1398
Down payment ( B )	30	30	30	30	30	30		30	30	30	30	30	30	
Present value of replaced battery (two unit) ( C )*	388	388	388	388	388	388	388	388	388	388	388	388	388	388
Present value of replaced charge controller ( D )*	97	97	97	97	97	97	97	97	97	97	97	97	97	97
Present value of O&M cost ( E ) *	163	163	163	163	163	163	163	163	163	163	163	163	163	163
Total Present value (F)= (A)-(B)+(C)+(D)+(E)	2016	2016	2016	2016	2016	2016	2046	2016	2016	2016	2016	2016	2016	2046
Total annual expenses (G)=(F)*CRF	148	181	249	336	453	726		101	134	202	288	403	672	
Total monthly expenses (US\$) (G)/12	12.4	15.1	20.7	28.0	37.7	60.5		8.4	11.2	16.8	24.0	33.6	56.0	
Total monthly expenses (SB\$)	61.8	75.5	103.5	139.9	188.7	302.6		42.0	56.0	84.0	120.0	168.0	280.0	

Note: excluding fluorescent light

**Appendix 7-11-2(2) Calculation of annual expenses for the SHS (55Wp: without tax and duty)**

(UNIT:US\$)

Payment term (year)	20	15	10	7	5	3	0	20	15	10	7	5	3	0
Discount rate ( = r )	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%
Interest charged ( = i )	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%		0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	
Capital Recovery Factor CRF = $i / (1 - (1 + i)^{-n})$	0.074	0.090	0.123	0.167	0.225	0.360		0.050	0.067	0.100	0.143	0.200	0.333	
Initial cost ( A )	1160	1160	1160	1160	1160	1160	1160	1160	1160	1160	1160	1160	1160	1160
Down payment ( B )	30	30	30	30	30	30		30	30	30	30	30	30	
Present value of replaced battery (two unit) ( C )*	317	317	317	317	317	317	317	317	317	317	317	317	317	317
Present value of replaced charge controller ( D )*	79	79	79	79	79	79	79	79	79	79	79	79	79	79
Present value of O&M cost ( E ) *	163	163	163	163	163	163	163	163	163	163	163	163	163	163
Total Present value (F)= (A)-(B)+(C)+(D)+(E)	1689	1689	1689	1689	1689	1689	1719	1689	1689	1689	1689	1689	1689	1719
Total annual expenses (G)=(F)*CRF	124	152	208	281	379	608		84	113	169	241	338	563	
Total monthly expenses (US\$) (G)/12	10.4	12.7	17.3	23.4	31.6	50.7		7.0	9.4	14.1	20.1	28.1	46.9	
Total monthly expenses (SB\$)	51.8	63.3	86.7	117.2	158.0	253.5		35.2	46.9	70.4	100.5	140.7	234.5	

Note: excluding fluorescent light

(C) = battery/(1+r)^7+battery/(1+r)^14

(D) = charge controller/(1+r)^10

$$(E) = \sum_{n=1}^{20} \frac{O \& M}{(1+r)^n}, \text{ O\&M cost = US\$12.0/year}$$

**Appendix 7-11-3(1) Calculation of annual expenses for the SHS (75Wp: with tax and others)**

(UNIT:US\$)

Payment term (year)	20	15	10	7	5	3	0	20	15	10	7	5	3	0
Discount rate (= r)	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%
Interest charged (= i)	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%		0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	
Capital Recovery Factor CRF = $i / (1 - (1 + i)^{-n})$	0.074	0.090	0.123	0.167	0.225	0.360		0.050	0.067	0.100	0.143	0.200	0.333	
Initial cost (A)	1640	1640	1640	1640	1640	1640	1640	1640	1640	1640	1640	1640	1640	1640
Down payment (B)	30	30	30	30	30	30		30	30	30	30	30	30	
Present value of replaced battery (two unit) (C)*	487	487	487	487	487	487	487	487	487	487	487	487	487	487
Present value of replaced charge controller (D)*	97	97	97	97	97	97	97	97	97	97	97	97	97	97
Present value of O&M cost (E) *	163	163	163	163	163	163	163	163	163	163	163	163	163	163
Total Present value (F)= (A)-(B)+(C)+(D)+(E)	2357	2357	2357	2357	2357	2357	2387	2357	2357	2357	2357	2357	2357	2387
Total annual expenses (G)=(F)*CRF	173	212	291	393	529	849		118	157	236	337	471	786	
Total monthly expenses (US\$) (G)/12	14.5	17.7	24.2	32.7	44.1	70.8		9.8	13.1	19.6	28.1	39.3	65.5	
Total monthly expenses (SB\$)	72.3	88.3	121.1	163.6	220.6	353.8		49.1	65.5	98.2	140.3	196.4	327.3	

Note: excluding fluorescent light

**Appendix 7-11-3(2) Calculation of annual expenses for the SHS (75Wp: without tax and duty)**

(UNIT:US\$)

Payment term (year)	20	15	10	7	5	3	0	20	15	10	7	5	3	0
Discount rate (= r)	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%
Interest charged (= i)	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%		0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	
Capital Recovery Factor CRF = $i / (1 - (1 + i)^{-n})$	0.074	0.090	0.123	0.167	0.225	0.360		0.050	0.067	0.100	0.143	0.200	0.333	
Initial cost (A)	1301	1301	1301	1301	1301	1301	1301	1301	1301	1301	1301	1301	1301	1301
Down payment (B)	30	30	30	30	30	30		30	30	30	30	30	30	
Present value of replaced battery (two unit) (C)*	397	397	397	397	397	397	397	397	397	397	397	397	397	397
Present value of replaced charge controller (D)*	79	79	79	79	79	79	79	79	79	79	79	79	79	79
Present value of O&M cost (E) *	163	163	163	163	163	163	163	163	163	163	163	163	163	163
Total Present value (F)= (A)-(B)+(C)+(D)+(E)	1910	1910	1910	1910	1910	1910	1940	1910	1910	1910	1910	1910	1910	1940
Total annual expenses (G)=(F)*CRF	141	172	235	318	429	688		95	127	191	273	382	637	
Total monthly expenses (US\$) (G)/12	11.7	14.3	19.6	26.5	35.7	57.4		8.0	10.6	15.9	22.7	31.8	53.1	
Total monthly expenses (SB\$)	58.6	71.6	98.1	132.6	178.7	286.8		39.8	53.1	79.6	113.7	159.2	265.3	

Note: excluding fluorescent light

$$(C) = \text{battery} / (1+r)^7 + \text{battery} / (1+r)^{14}$$


$$(D) = \text{charge controller} / (1+r)^{10}$$


$$(E) = \sum_{n=1}^{20} \frac{O \& M}{(1+r)^n}, \quad O\&M \text{ cost} = \text{US\$12.0/year}$$

## 第 1 0 章 電力供給計画




A10-1







A10-3




Appendix 10-3-3 Area served by the future powerstation (Buala)



*Area served by the independent isolated power source*




Appendix 10-3-5 Area served by the future powerstation (Lata)




Appendix 10-3-11 Power demand and power supply development (Honira - Lungga ) Plan-1

Name of new power	Plan 1	Lungga DPS (kW)	Honiara DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	10,100	4,000	0	14,100	0	0	10,450	14,050
Lungga diesel NO.9 commission	1999	10,100	4,000	0	14,100	3,900	0	10,604	14,204
Lungga diesel NO.10 install, Lungga diesel No.4 & 5 and Honiara diesel No.5 & 6 retired	2000	12,000	3,000	0	15,000	4,200	0	11,144	18,644
	2001	16,200	3,000	0	19,200	0	0	11,711	19,811
	2002	16,200	3,000	0	19,200	0	0	12,477	20,577
Lungga hydro No.1 and No.2 develop	2003	16,200	3,000	10,000	19,200	0	10,000	13,298	21,398
Lungga diesel No.7 retired	2004	13,900	3,000	10,000	26,900	0	0	14,168	22,268
	2005	13,900	3,000	10,000	26,900	0	0	14,953	23,053
	2006	13,900	3,000	10,000	26,900	0	0	15,785	23,885
Lungga diesel NO.11 install	2007	13,900	3,000	10,000	26,900	5,000	0	16,667	24,767
Lungga diesel No.8 retired	2008	15,300	3,000	10,000	28,300	0	0	17,602	26,802
	2009	15,300	3,000	10,000	28,300	0	0	18,727	27,927
Maotapuku I and II develop	2010	15,300	3,000	10,000	28,300	0	3,000	19,632	28,832
Lungga diesel NO.12 install	2011	15,300	3,000	13,000	31,300	5,000	0	20,525	29,725
	2012	20,300	3,000	13,000	36,300	0	0	21,495	30,695
	2013	20,300	3,000	13,000	36,300	0	0	22,511	31,711
	2014	20,300	3,000	13,000	36,300	0	0	23,237	32,437
	2015	20,300	3,000	13,000	36,300	0	0	24,221	33,421
Lungga diesel NO.13 install	2016	20,300	3,000	13,000	36,300	2,000	0	25,247	34,447
	2017	22,300	3,000	13,000	38,300	0	0	26,317	35,517
	2018	22,300	3,000	13,000	38,300	0	0	27,434	36,634



# Appendix 10-3-12 Power demand and power supply development (Honira - Lungga ) Plan-2


Name of new power	Plan 2	Lungga DPS (kW)	Honiara DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	10,100	4,000	0	14,100	0	0	10,450	14,050
Lungga diesel NO.9 commission	1999	10,100	4,000	0	14,100	3,900	0	10,604	14,204
Lungga diesel NO.10 install, Lungga diesel No.4 & 5 and Honiara diesel No.5 & 6 retired	2000	12,000	3,000	0	15,000	4,200	0	11,144	18,644
	2001	16,200	3,000	0	19,200	0	0	11,711	19,811
	2002	16,200	3,000	0	19,200	0	0	12,477	20,577
Lungga hydro No.1 develop	2003	16,200	3,000	5,000	19,200	0	5,000	13,298	21,398
Lungga hydro No.2 develop, Lungga diesel No.7 retired	2004	13,900	3,000	5,000	21,900	0	5,000	14,168	22,268
	2005	13,900	3,000	10,000	26,900	0	0	14,953	23,053
	2006	13,900	3,000	10,000	26,900	0	0	15,785	23,885
Lungga diesel NO.11	2007	13,900	3,000	10,000	26,900	5,000	0	16,667	24,767
Lungga diesel No.8 retired	2008	15,300	3,000	10,000	28,300	0	0	17,602	26,802
	2009	15,300	3,000	10,000	28,300	0	0	18,727	27,927
Maotapuku I and II develop	2010	15,300	3,000	13,000	31,300	0	3,000	19,632	28,832
	2011	15,300	3,000	13,000	31,300	0	0	20,525	29,725
Lungga diesel NO.12	2012	15,300	3,000	13,000	31,300	5,000	0	21,495	30,695
	2013	20,300	3,000	13,000	36,300	0	0	22,511	31,711
	2014	20,300	3,000	13,000	36,300	0	0	23,237	32,437
	2015	20,300	3,000	13,000	36,300	0	0	24,221	33,421
	2016	20,300	3,000	13,000	36,300	0	0	25,247	34,447
Lungga diesel NO.13	2017	20,300	3,000	13,000	36,300	2,000	0	26,317	35,517
	2018	22,300	3,000	13,000	38,300	0	0	27,434	36,634






# Appendix 10-3-13 Power demand and power supply development (Honira - Lungga ) Plan-3

Name of new power	Plan 3	Lungga DPS (kW)	Honiara DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	10,100	4,000	0	14,100	0	0	10,450	14,050
Lungga diesel NO.9 commission	1999	10,100	4,000	0	14,100	3,900	0	10,604	14,204
Lungga diesel NO.10 install, Lungga diesel No.4 & 5 and Honiara diesel No.5 & 6 retired	2000	12,000	3,000	0	15,000	4,200	0	11,144	18,644
	2001	16,200	3,000	0	19,200	0	0	11,711	19,811
	2002	16,200	3,000	0	19,200	0	0	12,477	20,577
Lungga diesel No.11 install	2003	16,200	3,000	0	19,200	5,000	0	13,298	21,398
Lungga diesel No.12 install, Lungga diesel No.7 retired	2004	18,900	3,000	0	21,900	5,000	0	14,168	22,268
	2005	23,900	3,000	0	26,900	0	0	14,953	23,053
	2006	23,900	3,000	0	26,900	0	0	15,785	23,885
Lungga diesel NO.13 install	2007	23,900	3,000	0	26,900	5,000	0	16,667	24,767
Lungga diesel No.8 retired	2008	25,300	3,000	0	28,300	0	0	17,602	26,802
	2009	25,300	3,000	0	28,300	0	0	18,727	27,927
Maotapuku I and II develop	2010	25,300	3,000	0	28,300	0	3,000	19,632	28,832
	2011	25,300	3,000	3,000	31,300	0	0	20,525	29,725
Lungga diesel NO.14 install	2012	25,300	3,000	3,000	31,300	5,000	0	21,495	30,695
	2013	30,300	3,000	3,000	36,300	0	0	22,511	31,711
	2014	30,300	3,000	3,000	36,300	0	0	23,237	32,437
	2015	30,300	3,000	3,000	36,300	0	0	24,221	33,421
Lungga diesel NO.15 install	2016	30,300	3,000	3,000	36,300	2,000	0	25,247	34,447
	2017	32,300	3,000	3,000	38,300	0	0	26,317	35,517
	2018	32,300	3,000	3,000	38,300	0	0	27,434	36,634




Appendix 10-3-14 Power demand and power supply development (Honira - Lungga ) Plan-4

Name of new power	Plan 4	Lungga DPS (kW)	Honiara DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	10,100	4,000	0	14,100	0	0	10,450	14,050
Lungga diesel N0.9 commission	1999	10,100	4,000	0	14,100	3,900	0	10,604	14,204
Lungga diesel N0.10 install, Lungga diesel No.4 & 5 and Honiara diesel No.5 & 6 retired	2000	12,000	3,000	0	15,000	4,200	0	11,144	18,644
	2001	16,200	3,000	0	19,200	0	0	11,711	19,811
	2002	16,200	3,000	0	19,200	0	0	12,477	20,577
Lungga diesel No.11 install	2003	16,200	3,000	0	19,200	5,000	0	13,298	21,398
Lungga diesel No.12 install, Lungga diesel No.7 retired	2004	18,900	3,000	0	21,900	5,000	0	14,168	22,268
	2005	23,900	3,000	0	26,900	0	0	14,953	23,053
	2006	23,900	3,000	0	26,900	0	0	15,785	23,885
Lungga diesel N0.13 install	2007	23,900	3,000	0	26,900	5,000	0	16,667	24,767
Lungga diesel No.8 retired	2008	25,300	3,000	0	28,300	0	0	17,602	26,802
Lungga diesel No.14 install	2009	25,300	3,000	0	28,300	5,000	0	18,727	27,927
	2010	30,300	3,000	0	33,300	0	0	19,632	28,832
	2011	30,300	3,000	0	33,300	0	0	20,525	29,725
	2012	30,300	3,000	0	33,300	0	0	21,495	30,695
	2013	30,300	3,000	0	33,300	0	0	22,511	31,711
	2014	30,300	3,000	0	33,300	0	0	23,237	32,437
Lungga diesel N0.15	2015	30,300	3,000	0	33,300	5,000	0	24,221	33,421
	2016	35,300	3,000	0	38,300	0	0	25,247	34,447
	2017	35,300	3,000	0	38,300	0	0	26,317	35,517
	2018	35,300	3,000	0	38,300	0	0	27,434	36,634




Appendix 10-3-21 Power demand and power supply development (Auki-Malu'u - Bina ) Plan-1

Name of new power	Plan 1	Auki DPS + Bina DPS (kW)	Malu'u HPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	624	30	0	654	0	0	470	678
	1999	624	30	0	654	0	0	487	695
Auki diesel 2 units (200kW*2) replacement and Malu'u diesel 1 unit (83kW) install	2000	624	30	0	654	483	0	481	689
Bina diesel No.1 unit (1500kW) install and existing 1 diesel retired	2001	608	113	0	721	1,500	0	478	686
Bina diesel No.2 unit install	2002	1,900	113	0	2,013	1,500	0	2,387	2,595
Bina diesel No.3 unit install and Rori hydro develop	2003	3,400	113	0	3,513	1,500	300	2,164	3,664
	2004	4,900	113	300	5,313	0	0	3,538	5,038
	2005	4,900	113	300	5,313	0	0	3,578	5,078
	2006	4,900	113	300	5,313	0	0	3,622	5,122
	2007	4,900	113	300	5,313	0	0	3,668	5,168
	2008	4,900	113	300	5,313	0	0	3,717	5,217
Manakwai Hydro develop	2009	4,900	113	300	5,313	0	400	3,765	5,265
	2010	4,900	113	700	5,713	0	0	3,816	5,316
	2011	4,900	113	700	5,713	0	0	3,871	5,371
	2012	4,900	113	700	5,713	0	0	3,929	5,429
	2013	4,900	113	700	5,713	0	0	3,990	5,490
Silolo Hydro develop	2014	4,900	113	700	5,713	0	2,100	4,051	5,551
	2015	4,900	113	2,800	7,813	0	0	5,715	7,215
	2016	4,900	113	2,800	7,813	0	0	5,788	7,288
	2017	4,900	113	2,800	7,813	0	0	5,866	7,366
	2018	4,900	113	2,800	7,813	0	0	5,948	7,448




Appendix 10-3-22 Power demand and power supply development (Auki-Malu'u - Bina ) Plan-2

Name of new power	Plan 2	Auki DPS + Bina DPS (kW)	Malu'u HPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	624	30	0	654	0	0	470	678
	1999	624	30	0	654	0	0	487	695
Auki diesel 2 units (200kW*2) replacement and Malu'u diesel 1 unit (83kW) install	2000	624	30	0	654	483	0	481	689
Bina diesel No.1 unit (1500kW) install and existing 1 diesel retired	2001	608	113	0	721	1,500	0	478	686
Bina diesel No.2 unit installation	2002	1,900	113	0	2,013	1,500	0	2,387	2,595
Bina diesel No.3 unit install and Manakwai hydro develop	2003	3,400	113	0	3,513	1,500	400	2,164	3,664
	2004	4,900	113	400	5,413	0	0	3,538	5,038
	2005	4,900	113	400	5,413	0	0	3,578	5,078
	2006	4,900	113	400	5,413	0	0	3,622	5,122
	2007	4,900	113	400	5,413	0	0	3,668	5,168
	2008	4,900	113	400	5,413	0	0	3,717	5,217
	2009	4,900	113	400	5,413	0	0	3,765	5,265
	2010	4,900	113	400	5,413	0	0	3,816	5,316
Ruala'e Hydro develop	2011	4,900	113	400	5,413	0	200	3,871	5,371
	2012	4,900	113	600	5,613	0	0	3,929	5,429
	2013	4,900	113	600	5,613	0	0	3,990	5,490
Silolo Hydro develop	2014	4,900	113	600	5,613	0	2,100	4,051	5,551
	2015	4,900	113	2,700	7,713	0	0	5,715	7,215
	2016	4,900	113	2,700	7,713	0	0	5,788	7,288
	2017	4,900	113	2,700	7,713	0	0	5,866	7,366
	2018	4,900	113	2,700	7,713	0	0	5,948	7,448




Appendix 10-3-23 Power demand and power supply development (Auki-Malu'u - Bina ) Plan-3

Name of new power	Plan 3	Auki DPS + Bina DPS (kW)	Malu'u HPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	624	30	0	654	0	0	470	678
	1999	624	30	0	654	0	0	487	695
Auki diesel 2 units (200kW*2) replacement and Malu'u diesel 1 unit (83kW) install	2000	624	30	0	654	483	0	481	689
Bina diesel No.1 unit (1500kW) install and existing 1 diesel retired	2001	608	113	0	721	1,500	0	478	686
Bina diesel No.2 unit install	2002	1,900	113	0	2,013	1,500	0	2,387	2,595
Bina diesel No.3 unit install and Rori hydro develop	2003	3,400	113	0	3,513	1,500	300	2,164	3,664
	2004	4,900	113	300	5,313	0	0	3,538	5,038
	2005	4,900	113	300	5,313	0	0	3,578	5,078
	2006	4,900	113	300	5,313	0	0	3,622	5,122
	2007	4,900	113	300	5,313	0	0	3,668	5,168
	2008	4,900	113	300	5,313	0	0	3,717	5,217
Ruala'e Hydro develop	2009	4,900	113	300	5,313	0	200	3,765	5,265
	2010	4,900	113	500	5,513	0	0	3,816	5,316
	2011	4,900	113	500	5,513	0	0	3,871	5,371
	2012	4,900	113	500	5,513	0	0	3,929	5,429
Silolo Hydro develop	2013	4,900	113	500	5,513	0	2,100	3,990	5,490
	2014	4,900	113	2,600	7,613	0	0	4,051	5,551
	2015	4,900	113	2,600	7,613	0	0	5,715	7,215
	2016	4,900	113	2,600	7,613	0	0	5,788	7,288
	2017	4,900	113	2,600	7,613	0	0	5,866	7,366
	2018	4,900	113	2,600	7,613	0	0	5,948	7,448




Appendix 10-3-24 Power demand and power supply development (Auki-Malu'u - Bina ) Plan-4

Name of new power	Plan 4	Auki DPS + Bina DPS (kW)	Malu'u HPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	624	30	0	654	0	0	470	678
	1999	624	30	0	654	0	0	487	695
Auki diesel 2 units (200kW*2) replacement and Malu'u diesel 1 unit (83kW) install	2000	624	30	0	654	483	0	481	689
Bina diesel No.1 unit (1500kW) install and existing 1 diesel retired	2001	608	113	0	721	1,500	0	478	686
Bina diesel No.2 unit install	2002	1,900	113	0	2,013	1,500	0	2,387	2,595
Bina diesel No.3 unit install and Ruuala'e hydro develop	2003	3,400	113	0	3,513	1,500	200	2,164	3,664
	2004	4,900	113	200	5,213	0	0	3,538	5,038
	2005	4,900	113	200	5,213	0	0	3,578	5,078
	2006	4,900	113	200	5,213	0	0	3,622	5,122
Manakwai hydro develop	2007	4,900	113	200	5,213	0	400	3,668	5,168
	2008	4,900	113	600	5,613	0	0	3,717	5,217
	2009	4,900	113	600	5,613	0	0	3,765	5,265
	2010	4,900	113	600	5,613	0	0	3,816	5,316
	2011	4,900	113	600	5,613	0	0	3,871	5,371
	2012	4,900	113	600	5,613	0	0	3,929	5,429
	2013	4,900	113	600	5,613	0	0	3,990	5,490
Silolo Hydro develop	2014	4,900	113	600	5,613	0	2,100	4,051	5,551
	2015	4,900	113	2,700	7,713	0	0	5,715	7,215
	2016	4,900	113	2,700	7,713	0	0	5,788	7,288
	2017	4,900	113	2,700	7,713	0	0	5,866	7,366
	2018	4,900	113	2,700	7,713	0	0	5,948	7,448




Appendix 10-3-25 Power demand and power supply development (Auki-Malu'u - Bina ) Plan-5

Name of new power	Plan 5	Auki DPS + Bina DPS (kW)	Malu'u HPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	624	30	0	654	0	0	470	678
	1999	624	30	0	654	0	0	487	695
Auki diesel 2 units (200kW*2) replacement and Malu'u diesel 1 unit (83kW) install	2000	624	30	0	654	483	0	481	689
Bina diesel No.1 unit (1500kW) install and existing 1 diesel retired	2001	608	113	0	721	1,500	0	478	686
Bina diesel No.2 unit install	2002	1,900	113	0	2,013	1,500	0	2,387	2,595
Bina diesel No.3 unit install and Manakwai hydro develop	2003	3,400	113	0	3,513	1,500	400	2,164	3,664
	2004	4,900	113	400	5,413	0	0	3,538	5,038
	2005	4,900	113	400	5,413	0	0	3,578	5,078
	2006	4,900	113	400	5,413	0	0	3,622	5,122
	2007	4,900	113	400	5,413	0	0	3,668	5,168
	2008	4,900	113	400	5,413	0	0	3,717	5,217
	2009	4,900	113	400	5,413	0	0	3,765	5,265
	2010	4,900	113	400	5,413	0	0	3,816	5,316
Rori hydro develop	2011	4,900	113	400	5,413	0	300	3,871	5,371
	2012	4,900	113	700	5,713	0	0	3,929	5,429
	2013	4,900	113	700	5,713	0	0	3,990	5,490
Silolo Hydro develop	2014	4,900	113	700	5,713	0	2,100	4,051	5,551
	2015	4,900	113	2,800	7,813	0	0	5,715	7,215
	2016	4,900	113	2,800	7,813	0	0	5,788	7,288
	2017	4,900	113	2,800	7,813	0	0	5,866	7,366
	2018	4,900	113	2,800	7,813	0	0	5,948	7,448



Appendix 10-3-26 Power demand and power supply development (Auki-Malu'u - Bina ) Plan-6


Name of new power	Plan 6	Auki DPS + Bina DPS (kW)	Malu'u HPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year								
	1998	624	30	0	654	0	0	470	678
	1999	624	30	0	654	0	0	487	695
Auki diesel 2 units (200kW*2) replacement and Malu'u diesel 1 unit (83kW) install	2000	624	30	0	654	483	0	481	689
Bina diesel No.1 unit (1500kW) install and existing 1 diesel retired	2001	608	113	0	721	1,500	0	478	686
Bina diesel No.2 unit install	2002	1,900	113	0	2,013	1,500	0	2,387	2,595
Bina diesel No.3 unit install and Ruuala'e hydro develop	2003	3,400	113	0	3,513	1,500	200	2,164	3,664
	2004	4,900	113	200	5,213	0	0	3,538	5,038
	2005	4,900	113	200	5,213	0	0	3,578	5,078
	2006	4,900	113	200	5,213	0	0	3,622	5,122
Rori hydro develop	2007	4,900	113	200	5,213	0	300	3,668	5,168
	2008	4,900	113	500	5,513	0	0	3,717	5,217
	2009	4,900	113	500	5,513	0	0	3,765	5,265
	2010	4,900	113	500	5,513	0	0	3,816	5,316
	2011	4,900	113	500	5,513	0	0	3,871	5,371
	2012	4,900	113	500	5,513	0	0	3,929	5,429
Silolo Hydro develop	2013	4,900	113	500	5,513	0	2,100	3,990	5,490
	2014	4,900	113	2,600	7,613	0	0	4,051	5,551
	2015	4,900	113	2,600	7,613	0	0	5,715	7,215
	2016	4,900	113	2,600	7,613	0	0	5,788	7,288
	2017	4,900	113	2,600	7,613	0	0	5,866	7,366
	2018	4,900	113	2,600	7,613	0	0	5,948	7,448






Appendix 10-3-31 Power demand and power supply development (Buala ) Plan-1

Name of new power	Plan 1 Year	Buala HPS (kW)	Buala DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	150	62	0	212	0	0	70	132
	1999	150	62	0	212	0	0	81	143
	2000	150	62	0	212	0	0	89	151
	2001	150	62	0	212	0	0	98	160
	2002	150	62	0	212	0	0	108	170
	2003	150	62	0	212	0	0	119	181
	2004	150	62	0	212	0	0	129	191
New diesel No.2 install	2005	150	62	0	212	160	0	139	201
	2006	150	222	0	372	0	0	151	311
	2007	150	222	0	372	0	0	164	324
	2008	150	222	0	372	0	0	177	337
Kubolata hydro develop	2009	150	222	0	372	0	80	202	362
	2010	150	222	80	452	0	0	216	376
	2011	150	222	80	452	0	0	231	391
New diesel No.3 install	2012	150	222	80	452	160	0	247	407
Exist. old diesel retired	2013	150	320	80	550	0	0	265	425
	2014	150	320	80	550	0	0	281	441
	2015	150	320	80	550	0	0	298	458
	2016	150	320	80	550	0	0	316	476
	2017	150	320	80	550	0	0	336	496
	2018	150	320	80	550	0	0	357	517




Appendix 10-3-32 Power demand and power supply development (Buala ) Plan-2

Name of new power	Plan 2 Year	Buala HPS (kW)	Buala DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	150	62	0	212	0	0	70	132
	1999	150	62	0	212	0	0	81	143
	2000	150	62	0	212	0	0	89	151
New diesel No.2 install	2001	150	62	0	212	110	0	98	160
	2002	150	172	0	322	0	0	108	218
	2003	150	172	0	322	0	0	119	229
	2004	150	172	0	322	0	0	129	239
	2005	150	172	0	322	0	0	139	249
	2006	150	172	0	322	0	0	151	261
	2007	150	172	0	322	0	0	164	274
	2008	150	172	0	322	0	0	177	287
New diesel No.3 install	2009	150	172	0	322	110	0	202	312
	2010	150	282	0	432	0	0	216	326
	2011	150	282	0	432	0	0	231	341
New diesel No.4 install	2012	150	282	0	432	110	0	247	357
Exist. old diesel retired	2013	150	330	0	480	0	0	265	375
	2014	150	330	0	480	0	0	281	391
	2015	150	330	0	480	0	0	298	408
	2016	150	330	0	480	0	0	316	426
	2017	150	330	0	480	0	0	336	446
	2018	150	330	0	480	0	0	357	467




Appendix 10-3-41 Power demand and power supply development (Kirakira ) Plan-1

Name of new power	Plan 1 Year	Kirakira DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	110	0	110	0	0	55	115
	1999	110	0	110	0	0	69	129
	2000	110	0	110	0	0	76	136
New diesel No.4 install	2001	110	0	110	200	0	84	144
	2002	310	0	310	0	0	92	292
	2003	310	0	310	0	0	101	301
Huro hydro develop	2004	310	0	310	0	120	110	310
	2005	310	120	430	0	0	120	320
	2006	310	120	430	0	0	131	331
	2007	310	120	430	0	0	143	343
	2008	310	120	430	0	0	155	355
	2009	310	120	430	0	0	179	379
	2010	310	120	430	0	0	193	393
Waimapur hydro develop	2011	310	120	430	0	20	207	407
New diesel No.5 install, existing diesel No.1 retired	2012	250	140	390	300	0	223	423
Existing diesel No.2 retired	2013	500	140	640	0	0	240	540
	2014	500	140	640	0	0	256	556
	2015	500	140	640	0	0	274	574
	2016	500	140	640	0	0	292	592
	2017	500	140	640	0	0	312	612
	2018	500	140	640	0	0	334	634




Appendix 10-3-42 Power demand and power supply development (Kirakira ) Plan-2

Name of new power	Plan 2 Year	Kirakira DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	110	0	110	0	0	55	115
	1999	110	0	110	0	0	69	129
	2000	110	0	110	0	0	76	136
New diesel No.4 install	2001	110	0	110	200	0	84	144
	2002	310	0	310	0	0	92	292
	2003	310	0	310	0	0	101	301
Huro hydro develop	2004	310	0	310	0	120	110	310
	2005	310	120	430	0	0	120	320
	2006	310	120	430	0	0	131	331
	2007	310	120	430	0	0	143	343
	2008	310	120	430	0	0	155	355
	2009	310	120	430	0	0	179	379
	2010	310	120	430	0	0	193	393
New diesel No.5 install	2011	310	120	430	240	0	207	407
Existing diesel No.1 retired	2012	490	120	610	0	0	223	423
Existing diesel No.2 retired	2013	440	120	560	0	0	240	440
	2014	440	120	560	0	0	256	456
	2015	440	120	560	0	0	274	474
	2016	440	120	560	0	0	292	492
	2017	440	120	560	0	0	312	512
	2018	440	120	560	0	0	334	534




Appendix 10-3-43 Power demand and power supply development (Kirakira ) Plan-3

Name of new power	Plan 3	Kirakira DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year							
	1998	110	0	110	0	0	55	115
	1999	110	0	110	0	0	69	129
	2000	110	0	110	0	0	76	136
New diesel No.4 install	2001	110	0	110	200	0	84	144
	2002	310	0	310	0	0	92	292
	2003	310	0	310	0	0	101	301
New diesel No.5	2004	310	0	310	170	0	110	310
	2005	480	0	480	0	0	120	320
	2006	480	0	480	0	0	131	331
	2007	480	0	480	0	0	143	343
	2008	480	0	480	0	0	155	355
	2009	480	0	480	0	0	179	379
	2010	480	0	480	0	0	193	393
New diesel No.6 install	2011	480	0	480	170	0	207	407
Existing diesel No.1 retired	2012	590	0	590	0	0	223	423
Existing diesel No.2 retired	2013	540	0	540	0	0	240	440
	2014	540	0	540	0	0	256	456
	2015	540	0	540	0	0	274	474
	2016	540	0	540	0	0	292	492
	2017	540	0	540	0	0	312	512
	2018	540	0	540	0	0	334	534




Appendix 10-3-51 Power demand and power supply development (Lata) Plan-1

Name of new power	Plan 1 Year	Lata DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	160	0	160	0	0	65	125
	1999	160	0	160	0	0	66	126
	2000	160	0	160	0	0	70	130
	2001	160	0	160	0	0	75	135
	2002	160	0	160	0	0	80	140
	2003	160	0	160	0	0	86	146
	2004	160	0	160	0	0	91	151
New diesel No.4	2005	160	0	160	200	0	96	156
	2006	360	0	360	0	0	102	302
	2007	360	0	360	0	0	108	308
	2008	360	0	360	0	0	115	315
	2009	360	0	360	0	0	121	321
	2010	360	0	360	0	0	128	328
	2011	360	0	360	0	0	134	334
Luembalele hydro develop	2012	360	0	360	0	50	141	341
New diesel No.5 (150kW) install and existing diesel No.1 retired	2013	300	50	350	150	0	149	349
Existing diesel No.2 retired	2014	410	50	460	0	0	156	356
Existing diesel No.3 retired	2015	350	50	400	0	0	163	363
	2016	350	50	400	0	0	170	370
	2017	350	50	400	0	0	178	378
	2018	350	50	400	0	0	186	386



Appendix 10-3-52 Power demand and power supply development (Lata) Plan-2


Name of new power	Plan 2	Lata DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year							
	1998	160	0	160	0	0	65	125
	1999	160	0	160	0	0	66	126
	2000	160	0	160	0	0	70	130
	2001	160	0	160	0	0	75	135
	2002	160	0	160	0	0	80	140
	2003	160	0	160	0	0	86	146
	2004	160	0	160	0	0	91	151
New diesel No.4	2005	160	0	160	200	0	96	156
	2006	360	0	360	0	0	102	302
	2007	360	0	360	0	0	108	308
	2008	360	0	360	0	0	115	315
	2009	360	0	360	0	0	121	321
	2010	360	0	360	0	0	128	328
	2011	360	0	360	0	0	134	334
New diesel No.5 develop	2012	360	0	360	200	0	141	341
Existing diesel No.1 retired	2013	500	0	500	0	0	149	349
Existing diesel No.2 retired	2014	460	0	460	0	0	156	356
Existing diesel No.3 retired	2015	400	0	400	0	0	163	363
	2016	400	0	400	0	0	170	370
	2017	400	0	400	0	0	178	378
	2018	400	0	400	0	0	186	386



A10-23

Appendix 10-3-61 Power demand and power supply development (Choiseul) Plan-1


Name of new power	Plan 1	Taro DPS (kW)	Choiseul Is PS (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year							
	1998	0	0	0	0	0	14	14
	1999	0	0	0	0	0	19	19
Diesel developed in Taro Is.	2000	0	0	0	40	0	21	41
	2001	40	0	40	0	0	23	43
	2002	40	0	40	0	0	25	45
Sorave hydro develop	2003	40	0	40	0	70	28	48
	2004	40	70	110	0	0	30	50
	2005	40	70	110	0	0	32	52
	2006	40	70	110	0	0	35	55
	2007	40	70	110	0	0	38	58
	2008	40	70	110	0	0	41	61
	2009	40	70	110	0	0	57	77
	2010	40	70	110	0	0	60	80
	2011	40	70	110	0	0	63	83
	2012	40	70	110	0	0	66	86
	2013	40	70	110	0	0	70	90
	2014	40	70	110	0	0	73	93
	2015	40	70	110	0	0	76	96
	2016	40	70	110	0	0	79	99
	2017	40	70	110	0	0	82	102
	2018	40	70	110	0	0	86	106






Appendix 10-3-62 Power demand and power supply development (Choiseul) Plan-2

Name of new power	Plan 2	Taro DPS (kW)	Choiseul Is PS (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year							
	1998	0	0	0	0	0	14	14
	1999	0	0	0	0	0	19	19
Diesel developed in Taro Is.	2000	0	0	0	40	0	21	41
	2001	40	0	40	0	0	23	43
	2002	40	0	40	0	0	25	45
Diesel develop in Main Is.	2003	40	0	40	120	0	28	48
	2004	160	0	160	0	0	30	90
	2005	160	0	160	0	0	32	92
	2006	160	0	160	0	0	35	95
	2007	160	0	160	0	0	38	98
	2008	160	0	160	0	0	41	101
	2009	160	0	160	0	0	57	117
	2010	160	0	160	0	0	60	120
	2011	160	0	160	0	0	63	123
	2012	160	0	160	0	0	66	126
	2013	160	0	160	0	0	70	130
	2014	160	0	160	0	0	73	133
	2015	160	0	160	0	0	76	136
	2016	160	0	160	0	0	79	139
	2017	160	0	160	0	0	82	142
	2018	160	0	160	0	0	86	146




Appendix 10-3-71 Power demand and power supply development (Gizo) Plan-1

Name of new power	Plan 1 Year	Gizo DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	510	0	510	0	0	270	440
	1999	510	0	510	0	0	485	655
Gizo diesel 2 units (200kW*2) replacement	2000	510	0	510	400	0	512	682
	2001	570	0	570	0	0	541	741
New diesel No.4 & 5 (600kW*2) install	2002	570	0	570	1,200	0	571	771
Existing diesel No.3 retired	2003	1,600	0	1,600	0	0	603	1,203
	2004	1,600	0	1,600	0	0	632	1,232
	2005	1,600	0	1,600	0	0	662	1,262
	2006	1,600	0	1,600	0	0	694	1,294
	2007	1,600	0	1,600	0	0	727	1,327
	2008	1,600	0	1,600	0	0	763	1,363
	2009	1,600	0	1,600	0	0	793	1,393
	2010	1,600	0	1,600	0	0	824	1,424
	2011	1,600	0	1,600	0	0	856	1,456
	2012	1,600	0	1,600	0	0	891	1,491
	2013	1,600	0	1,600	0	0	926	1,526
	2014	1,600	0	1,600	0	0	955	1,555
New diesel No.6 (600kW) install	2015	1,600	0	1,600	600	0	984	1,584
	2016	2,200	0	2,200	0	0	1,015	1,615
	2017	2,200	0	2,200	0	0	1,046	1,646
	2018	2,200	0	2,200	0	0	1,079	1,679




Appendix 10-3-72 Power demand and power supply development (Gizo) Plan-2

Name of new power	Plan 2 Year	Gizo DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	510	0	510	0	0	270	440
	1999	510	0	510	0	0	485	655
Gizo diesel 2 units (200kW*2) replacement	2000	510	0	510	400	0	512	682
	2001	570	0	570	0	0	541	741
New diesel No.4 & 5 (300kW*2) install	2002	570	0	570	600	0	571	771
Existing diesel No.3 retired	2003	1,000	0	1,000	0	0	603	903
	2004	1,000	0	1,000	0	0	632	932
	2005	1,000	0	1,000	0	0	662	962
New diesel No.6 (300kW) install	2006	1,000	0	1,000	300	0	694	994
	2007	1,300	0	1,300	0	0	727	1,027
	2008	1,300	0	1,300	0	0	763	1,063
	2009	1,300	0	1,300	0	0	793	1,093
	2010	1,300	0	1,300	0	0	824	1,124
	2011	1,300	0	1,300	0	0	856	1,156
	2012	1,300	0	1,300	0	0	891	1,191
	2013	1,300	0	1,300	0	0	926	1,226
	2014	1,300	0	1,300	0	0	955	1,255
New diesel No.7 (300kW) install	2015	1,300	0	1,300	300	0	984	1,284
	2016	1,600	0	1,600	0	0	1,015	1,315
	2017	1,600	0	1,600	0	0	1,046	1,346
	2018	1,600	0	1,600	0	0	1,079	1,379




Appendix 10-3-73 Power demand and power supply development (Gizo) Plan-3

Name of new power	Plan 3 Year	Gizo DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	510	0	510	0	0	270	440
	1999	510	0	510	0	0	485	655
Gizo diesel 2 units (200kW*2) replacement	2000	510	0	510	400	0	512	682
New diesel No.4 (400kW) install	2001	570	0	570	400	0	541	741
	2002	970	0	970	0	0	571	971
New diesel No.5 (400kW) install and existing diesel No.3 retired	2003	800	0	800	400	0	603	1,003
	2004	1,200	0	1,200	0	0	632	1,032
	2005	1,200	0	1,200	0	0	662	1,062
	2006	1,200	0	1,200	0	0	694	1,094
	2007	1,200	0	1,200	0	0	727	1,127
	2008	1,200	0	1,200	0	0	763	1,163
New diesel No.6 (400kW) install	2009	1,200	0	1,200	400	0	793	1,193
	2010	1,600	0	1,600	0	0	824	1,224
	2011	1,600	0	1,600	0	0	856	1,256
	2012	1,600	0	1,600	0	0	891	1,291
	2013	1,600	0	1,600	0	0	926	1,326
	2014	1,600	0	1,600	0	0	955	1,355
	2015	1,600	0	1,600	0	0	984	1,384
	2016	1,600	0	1,600	0	0	1,015	1,415
	2017	1,600	0	1,600	0	0	1,046	1,446
	2018	1,600	0	1,600	0	0	1,079	1,479




Appendix 10-3-74 Power demand and power supply development (Noro-Munda) Plan-1

Name of new power	Plan 1	Noro DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year							
	1998	2,700	0	2,700	0	0	1,790	2,690
	1999	2,700	0	2,700	0	0	1,930	2,830
	2000	2,700	0	2,700	0	0	2,150	3,050
Diesel extension No.4 & 5 (2000kW*2)	2001	2,700	0	2,700	4,000	0	2,397	3,297
	2002	6,700	0	6,700	0	0	2,673	4,673
	2003	6,700	0	6,700	0	0	2,983	4,983
	2004	6,700	0	6,700	0	0	3,297	5,297
Diesel extension No.6 (4200kW*1)	2005	6,700	0	6,700	4,200	0	3,647	5,647
Existing diesel No.1 retired	2006	10,000	0	10,000	0	0	4,036	8,236
New diesel No. 7 (4200kW) install and existing diesel No.2 retired	2007	9,100	0	9,100	4,200	0	4,469	8,669
Existing diesel No.3 retired	2008	12,400	0	12,400	0	0	4,951	9,151
	2009	12,400	0	12,400	0	0	5,401	9,601
	2010	12,400	0	12,400	0	0	5,893	10,093
	2011	12,400	0	12,400	0	0	6,433	10,633
	2012	12,400	0	12,400	0	0	7,024	11,224
Diesel extension No.8 (4200kW*1)	2013	12,400	0	12,400	4,200	0	7,673	11,873
	2014	16,600	0	16,600	0	0	8,289	12,489
	2015	16,600	0	16,600	0	0	8,957	13,157
	2016	16,600	0	16,600	0	0	9,683	13,883
	2017	16,600	0	16,600	0	0	10,470	14,670
	2018	16,600	0	16,600	0	0	11,326	15,526



Appendix 10-3-75 Power demand and power supply development (Noro-Munda) Plan-2


Name of new power	Plan 2 Year	Noro DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	2,700	0	2,700	0	0	1,790	2,690
	1999	2,700	0	2,700	0	0	1,930	2,830
	2000	2,700	0	2,700	0	0	2,150	3,050
Diesel extension No.4 & 5 (2000kW*2)	2001	2,700	0	2,700	4,000	0	2,397	3,297
	2002	6,700	0	6,700	0	0	2,673	4,673
	2003	6,700	0	6,700	0	0	2,983	4,983
	2004	6,700	0	6,700	0	0	3,297	5,297
Diesel extension No.6 & No.7 (2000kW*2)	2005	6,700	0	6,700	4,000	0	3,647	5,647
Existing diesel No.1 retired	2006	9,800	0	9,800	0	0	4,036	6,036
Existing diesel No.2 retired	2007	8,900	0	8,900	0	0	4,469	6,469
Existing diesel No.3 retired	2008	8,000	0	8,000	0	0	4,951	6,951
	2009	8,000	0	8,000	0	0	5,401	7,401
New diesel No. 8 & No.9 (2000kW*2) install	2010	8,000	0	8,000	4,000	0	5,893	7,893
	2011	12,000	0	12,000	0	0	6,433	8,433
	2012	12,000	0	12,000	0	0	7,024	9,024
	2013	12,000	0	12,000	0	0	7,673	9,673
	2014	12,000	0	12,000	0	0	8,289	10,289
	2015	12,000	0	12,000	0	0	8,957	10,957
Diesel extension No.10 (2000kW*1)	2016	12,000	0	12,000	2,000	0	9,683	11,683
	2017	14,000	0	14,000	0	0	10,470	12,470
	2018	14,000	0	14,000	0	0	11,326	13,326



Appendix 10-3-81 Power demand and power supply development (Tulagi) Plan-1


Name of new power	Plan 1	Tulagi DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	Year							
	1998	244	0	244	0	0	65	209
	1999	244	0	244	0	0	66	221
	2000	244	0	244	0	0	70	225
	2001	244	0	244	0	0	75	228
	2002	244	0	244	0	0	80	231
	2003	244	0	244	0	0	86	235
	2004	244	0	244	0	0	91	239
New diesel No.3	2005	244	0	244	83	0	96	242
	2006	327	0	327	0	0	102	246
	2007	327	0	327	0	0	108	251
	2008	327	0	327	0	0	115	255
	2009	327	0	327	0	0	121	259
	2010	327	0	327	0	0	128	263
	2011	327	0	327	0	0	134	268
	2012	327	0	327	0	0	141	273
	2013	327	0	327	0	0	149	278
	2014	327	0	327	0	0	156	282
	2015	327	0	327	0	0	163	287
	2016	327	0	327	0	0	170	292
	2017	327	0	327	0	0	178	297
	2018	327	0	327	0	0	186	303

A10-31



Appendix 10-3-82 Power demand and power supply development (Tulagi) Plan-2


Name of new power	Plan 2 Year	Tulagi DPS (kW)	Hydro power (kW)	Total power (kW)	New developed diesel power (kW)	New developed hydro power (kW)	Peak Load (kW)	Necessary power (kW)
	1998	244	0	244	0	0	65	209
	1999	244	0	244	0	0	66	221
	2000	244	0	244	0	0	70	225
	2001	244	0	244	0	0	75	228
	2002	244	0	244	0	0	80	231
	2003	244	0	244	0	0	86	235
	2004	244	0	244	0	0	91	239
New diesel No.3	2005	244	0	244	60	0	96	242
	2006	304	0	304	0	0	102	246
	2007	304	0	304	0	0	108	251
	2008	304	0	304	0	0	115	255
	2009	304	0	304	0	0	121	259
	2010	304	0	304	0	0	128	263
	2011	304	0	304	0	0	134	268
	2012	304	0	304	0	0	141	273
	2013	304	0	304	0	0	149	278
	2014	304	0	304	0	0	156	282
	2015	304	0	304	0	0	163	287
	2016	304	0	304	0	0	170	292
	2017	304	0	304	0	0	178	297
	2018	304	0	304	0	0	186	303






## Appendix 10-3-91 Power demand and power supply development (Rennell and Bellona) Plan-1

Name of new power	Plan 1	Rennell Solar PS (kW)	Rennell Wind PS (kW)	Total power (kW)	New developed Solar power (kW)	New developed wind power (kW)	Peak Load (kW)	Necessary power (kW) by Solar
	Year							
	1998	0	0	0	0	0	6	39
	1999	0	0	0	0	0	6	42
	2000	0	0	0	0	0	7	46
	2001	0	0	0	0	0	7	51
Solar generation (30kW*2) developed	2002	0	0	0	60	0	8	55
	2003	60	0	60	0	0	9	61
	2004	60	0	60	0	0	9	65
Wind power (20kW*1) develop	2005	60	0	60	0	20	10	70
	2006	60	20	60	0	0	10	76
	2007	60	20	60	0	0	11	81
Solar generation (30kW*1) extend	2008	60	20	60	30	0	12	87
	2009	90	20	90	0	0	12	92
	2010	90	20	90	0	0	13	97
Wind power (20kW*1) extend	2011	90	20	90	0	20	13	102
	2012	90	40	90	0	0	14	108
	2013	90	40	90	0	0	15	113
Solar generation (30kW*1) extend	2014	90	40	90	30	0	15	117
	2015	120	40	120	0	0	16	121
	2016	120	40	120	0	0	16	125
	2017	120	40	120	0	0	16	129
	2018	120	40	120	0	0	17	133



## Appendix 10-3-92 Power demand and power supply development (Rennell and Bellona) Plan-2

Name of new power	Plan 2	Rennell Solar PS (kW)	Rennell Wind PS (kW)	Total power (kW)	New developed Solar power (kW)	New developed wind power (kW)	Peak Load (kW)	Necessary power (kW) by Solar
	Year							
	1998	0	0	0	0	0	6	39
	1999	0	0	0	0	0	6	42
	2000	0	0	0	0	0	7	46
	2001	0	0	0	0	0	7	51
Solar generation (20kW*3) developed	2002	0	0	0	60	0	8	55
	2003	60	0	60	0	0	9	61
	2004	60	0	60	0	0	9	65
Wind power (20kW*1) develop	2005	60	0	60	0	20	10	70
	2006	60	20	60	0	0	10	76
	2007	60	20	60	0	0	11	81
Solar generation (15kW*2) extend	2008	60	20	60	30	0	12	87
	2009	90	20	90	0	0	12	92
	2010	90	20	90	0	0	13	97
Wind power (20kW*1) extend	2011	90	20	90	0	20	13	102
	2012	90	40	90	0	0	14	108
	2013	90	40	90	0	0	15	113
Solar generation (15kW*2) extend	2014	90	40	90	30	0	15	117
	2015	120	40	120	0	0	16	121
	2016	120	40	120	0	0	16	125
	2017	120	40	120	0	0	16	129
	2018	120	40	120	0	0	17	133



## 第 1 2 章 經濟・財務分析

**Appendix 12-1-1 LRAIC and LRMC for the Master Plan**

Year	Peak Demand	Incremental Demand	Retire	New Capacity	H-3	A-3	B-1	K-2	L-2	C-1	G-2	N-2	T-2	Total
	(kW)	(kW)	(kW)	(kW)	(US\$)	(US\$)	(US\$)	(US\$)	(US\$)	(US\$)	(US\$)	(US\$)	(US\$)	(US\$)
1998	12,983	0	0	0	0	0	0	0	0	0	0	0	0	0
1999	13,573	591	3000	3,900	0	0	0	0	0	0	0	0	0	0
2000	14,400	827	0	4,723	6,442,800	149,400	0	0	0	206,960	800,000	0	0	7,599,160
2001	15,277	877	416	5,700	0	7,277,254	0	413,000	0	0	0	7,200,000	0	14,890,254
2002	16,207	930	208	2,100	0	3,916,738	0	1,144,017	0	1,798,469	1,200,000	0	0	8,059,224
2003	17,194	987	510	6,870	7,670,000	2,700,000	0	304,106	0	0	0	0	0	10,674,106
2004	18,065	871	2300	5,120	7,670,000	0	0	0	0	0	0	0	0	7,670,000
2005	19,165	1,100	0	4,420	0	0	368,000	0	461,400	0	0	7,200,000	300,000	8,329,400
2006	20,332	1,167	900	300	9,037,292	0	0	0	0	0	600,000	0	0	9,637,292
2007	21,569	1,238	900	5,000	20,221,795	0	0	0	0	0	0	0	0	20,221,795
2008	22,882	1,313	4500	0	21,589,087	665,624	1,595,307	0	0	0	0	0	0	23,850,019
2009	23,811	929	0	80	7,029,005	176,938	0	0	0	0	0	0	0	7,205,943
2010	25,016	1,205	0	7,200	0	4,921,343	0	0	0	0	0	7,200,000	0	12,121,343
2011	26,282	1,266	0	240	0	6,835,198	0	495,600	0	0	0	0	0	7,330,798
2012	27,612	1,330	60	5,360	7,670,000	11,756,541	368,000	0	461,400	0	0	0	0	20,255,941
2013	29,009	1,397	172	0	0	3,827,711	0	0	0	0	0	0	0	3,827,711
2014	29,896	887	40	2,100	0	0	0	0	0	0	0	0	0	0
2015	31,103	1,207	60	300	0	0	0	0	0	0	600,000	0	0	600,000
2016	32,358	1,256	0	4,000	3,068,000	0	0	0	0	0	0	3,600,000	0	6,668,000
2017	33,665	1,306	0	0	0	0	0	0	0	0	0	0	0	0
2018	35,024	1,359	0	0	0	0	0	0	0	0	0	0	0	0
Total =		22,041	13,066	57,413	90,397,980	42,226,747	2,331,307	2,356,723	922,800	2,005,429	3,200,000	25,200,000	300,000	168,940,986
NPV =		9,338		30,903	43,490,075	19,150,571	999,028	1,442,537	394,733	1,388,299	1,902,064	12,663,739	162,081	81,593,128
Discount Rate		8.00% ( = r )												
		AIC (capacity)		US\$/kW	2,640	=	/							
		AIC (demand)		US\$/kW	8,738	=	/							
Power balance	Hydro		kW		5,870	10.18% ( = h )								
	Thermal		kW		51,787	89.82% ( = t )								
Energy value (kWh value)														
Power value														
Weighted average life time			year		23.05	n = 50*h+20*t				Fuel Cost	0.0841	US\$/kWh		
CRF					0.0963	CRF = r/(1-(1+r)^(-n))				Energy loss	5.00%			
Annualized Power value			US\$/kW/year		254.37	= *CRF				Variable O&M	3.24%			
Average Plant factor			%		34.3%					Energy value	0.0914	US\$/kWh ( = e )		
Average total loss			%		9.9%									
Fixed O&M cost			%		3.24%									
Power value per kWh			US\$/kWh		0.0970	= /(8760* )(1- )*(1+ )								
Energy value (weighted)			US\$/kWh		0.0821	= e * t								
		LRAIC =		US\$/kWh	0.1791	= +								
				SB\$/kWh	0.8956									
		LRMC =		US\$/kWh	0.1922	= *CRF/8760/(1- )*(1+ )+								
				SB\$/kWh	0.9609									

**Appendix 12-1-2    Honiara-Lungga grid    Plan 1-4**

Year	Peak Demand (kW)	Incremental Demand (kW)	Retire (kW)	Plan-1		Plan-2		Plan-3		Plan-4	
				New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	10,450	0		0	0	0	0	0	0	0	0
1999	10,604	154	3,000	3,900	0	3,900	0	3,900	0	3,900	0
2000	11,144	540		4,200	6,442,800	4,200	6,442,800	4,200	6,442,800	4,200	6,442,800
2001	11,711	567		0	41,270,946	0	20,635,473	0	0	0	0
2002	12,477	766		0	41,270,946	0	20,635,473	0	0	0	0
2003	13,298	821		10,000	0	5,000	41,270,946	5,000	7,670,000	5,000	7,670,000
2004	14,168	870	2,300	0	0	5,000	0	5,000	7,670,000	5,000	7,670,000
2005	14,953	785		0	0	0	0	0	0	0	0
2006	15,785	832		0	9,037,292	0	9,037,292	0	9,037,292	0	0
2007	16,667	882		5,000	20,221,795	5,000	20,221,795	5,000	20,221,795	5,000	7,670,000
2008	17,602	935	3,600	0	21,589,087	0	21,589,087	0	21,589,087	5,000	7,670,000
2009	18,727	1,125		0	7,029,005	0	7,029,005	0	7,029,005	0	0
2010	19,632	905		3,000	0	3,000	0	3,000	0	0	0
2011	20,525	893		5,000	7,670,000	0	0	0	0	0	0
2012	21,495	970		0	0	5,000	7,670,000	5,000	7,670,000	0	0
2013	22,511	1,016		0	0	0	0	0	0	5,000	7,670,000
2014	23,237	726		0	0	0	0	0	0	0	0
2015	24,221	984		0	0	0	0	0	0	0	0
2016	25,247	1,026		2,000	3,068,000	0	0	2,000	3,068,000	0	0
2017	26,317	1,070		0	0	2,000	3,068,000	0	0	0	0
2018	27,434	1,117		0	0	0	0	0	0	0	0
Total =		16,984	8,900	33,100	157,599,873	33,100	157,599,873	33,100	90,397,980	33,100	44,792,800
NPV =		6,991		18,564	92,798,426	18,170	89,348,186	18,205	43,490,075	18,666	23,504,300
Discount Rate		8.00%									
				AIC (capacity) US\$/kW	4,999	4,917		2,389		1,259	
				AIC (demand) US\$/kW	13,274	12,780		6,221		3,362	
				*AIC = Average Incremental Cost							
Power balance in 2018	Hydro	kW		13,000	39.27%	13,000	39.27%	3,000	9.06%	0	0.00%
	Thermal	kW		20,100	60.73%	20,100	60.73%	30,100	90.94%	33,100	100.00%
Power value											Energy value (kWh value)
Weighted average life time				year	31.78	31.78		22.72		20.00	
CRF					0.0876	0.0876		0.0969		0.1019	Fuel Cost 0.0841 US\$/kWh
Annualized Power value				US\$/kW/year	437.84	430.69		231.39		128.25	Loss factor 5.00%
Average Plant factor				%	34.3%	34.3%		34.3%		34.3%	Variable O&M 3.45%
Average total loss				%	9.9%	9.9%		9.9%		9.9%	Energy value 0.0916 US\$/kWh
Fixed O&M cost				%	3.72%	3.72%		3.45%		3.40%	
Power value per kWh				US\$/kWh	0.1677	0.1650		0.0884		0.0490	
Energy value (weight average)				US\$/kWh	0.0556	0.0556		0.0833		0.0916	
LRAIC =				US\$/kWh	0.2234	0.2206		0.1717		0.1406	
				SB\$/kWh	1.1168	1.1031		0.8585		0.7029	
LRMC =				US\$/kWh	0.2083	0.2027		0.1622		0.1364	
				SB\$/kWh	1.0417	1.0133		0.8112		0.6822	

**Appendix 12-1-3 Auki-Malu'u grid Plan 1-6**

Year	Peak Demand (kW)	Incremental (kW)	Retire (kW)	Plan-1		Plan-2		Plan-3		Plan-4		Plan-5		Plan-6		
				New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	
1998	470	0		0	0	0	0	0	0	0	0	0	0	0	0	
1999	487	17		0	0	0	0	0	0	0	0	0	0	0	0	
2000	481	-6		83	149,400	83	149,400	83	149,400	83	149,400	83	149,400	83	149,400	
2001	478	-3	416	1,500	7,277,254	1,500	3,592,669	1,500	7,277,254	1,500	3,365,624	1,500	3,592,669	1,500	3,365,624	
2002	2,387	1,909	208	1,500	3,916,738	1,500	2,937,292	1,500	3,916,738	1,500	2,876,938	1,500	2,937,292	1,500	2,876,938	
2003	2,164	-223		1,800	2,700,000	1,900	2,700,000	1,800	2,700,000	1,700	2,700,000	1,900	2,700,000	1,700	2,700,000	
2004	3,538	1,374		0	0	0	0	0	0	0	0	0	0	0	0	
2005	3,578	40		0	0	0	0	0	0	0	892,669	0	0	0	0	
2006	3,622	44		0	0	0	0	0	0	0	237,292	0	0	0	0	
2007	3,668	46		0	892,669	0	0	0	0	400	0	0	0	0	0	
2008	3,717	49		0	237,292	0	0	0	665,624	0	0	0	4,577,254	0	4,577,254	
2009	3,765	48		400	0	0	665,624	0	176,938	0	0	0	1,216,738	0	1,216,738	
2010	3,816	51		0	4,921,343	0	5,098,281	200	4,921,343	0	4,921,343	300	4,921,343	300	4,921,343	
2011	3,871	55		0	6,835,198	200	6,835,198	0	6,835,198	0	6,835,198	0	6,835,198	0	6,835,198	
2012	3,929	58		0	11,756,541	0	11,756,541	0	11,756,541	0	11,756,541	0	11,756,541	0	11,756,541	
2013	3,990	61		0	3,827,711	0	3,827,711	0	3,827,711	0	3,827,711	0	3,827,711	0	3,827,711	
2014	4,051	61		2,100	0	2,100	0	2,100	0	2,100	0	2,100	0	2,100	0	
2015	5,715	1,664		0	0	0	0	0	0	0	0	0	0	0	0	
2016	5,788	73		0	0	0	0	0	0	0	0	0	0	0	0	
2017	5,866	78		0	0	0	0	0	0	0	0	0	0	0	0	
2018	5,948	82		0	0	0	0	0	0	0	0	0	0	0	0	
Total =		5,478	624	7,383	42,514,145	7,283	37,562,716	7,183	42,226,747	7,283	37,562,716	7,383	42,514,145	7,183	42,226,747	
NPV =		2,629		4,050	19,310,081	4,022	15,749,346	3,965	19,150,571	4,013	15,812,983	4,065	17,866,246	3,938	17,658,286	
Discount Rate		8.00%														
				AIC (capacity) US\$/kW	4,768	3,916	4,830	3,940	4,396	4,484						
				AIC (demand) US\$/kW	7,344	5,990	7,283	6,014	6,795	6,716						
Power balance				Hydro kW	2,800	37.92%	2,700	37.07%	2,600	36.20%	2,700	37.07%	2,800	37.92%	2,600	36.20%
				Thermal kW	4,583	62.08%	4,583	62.93%	4,583	63.80%	4,583	62.93%	4,583	62.08%	4,583	63.80%
Power value																
Weighted average life time				year	31.38	31.12	30.86	31.12	31.38	30.86						
CRF					0.0879	0.0880	0.0882	0.0880	0.0879	0.0882						
Annualized Power value				US\$/kW/year	418.87	344.66	426.05	346.82	386.17	395.47						
Average Plant factor				%	34.3%	34.3%	34.3%	34.3%	34.3%	34.3%						
Average total loss				%	9.9%	9.9%	9.9%	9.9%	9.9%	9.9%						
Fixed O&M cost				%	3.00%	3.00%	3.00%	3.00%	3.00%	3.00%						
Power value per kWh				US\$/kWh	0.1593	0.1311	0.1621	0.1319	0.1469	0.1504						
Energy value (weighted)				US\$/kWh	0.0566	0.0574	0.0582	0.0574	0.0566	0.0582						
LRAIC =				US\$/kWh	0.2160	0.1885	0.2203	0.1893	0.2035	0.2086						
				SBS/kWh	1.0798	0.9425	1.1013	0.9466	1.0176	1.0432						
LRMC =				US\$/kWh	0.1408	0.1262	0.1420	0.1264	0.1345	0.1355						
				SBS/kWh	0.7039	0.6308	0.7100	0.6322	0.6724	0.6773						

A12-3

## Appendix 12-1-4 Buala Plan 1-2

Year	Peak Demand (kW)	Incremental (kW)	Retire (kW)	Plan-1		Plan-2	
				New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	70	0		0	0	0	0
1999	81	11		0	0	0	0
2000	89	8		0	0	0	0
2001	98	9		0	0	110	253,000
2002	108	10		0	0	0	0
2003	119	11		0	0	0	0
2004	129	10		0	0	0	0
2005	139	10		160	368,000	0	0
2006	151	12		0	0	0	0
2007	164	13		0	0	0	0
2008	177	13		0	1,595,307	0	0
2009	202	25		80	0	110	253,000
2010	216	14		0	0	0	0
2011	231	15		0	0	0	0
2012	247	16		160	368,000	110	253,000
2013	265	18	62	0	0	0	0
2014	281	16		0	0	0	0
2015	298	17		0	0	0	0
2016	316	18		0	0	0	0
2017	336	20		0	0	0	0
2018	357	21		0	0	0	0
Total =		287	62	400	2,331,307	330	759,000
NPV =		117		169	999,028	159	366,188
Discount Rate		8.00%					
		AIC (capacity)	US\$/kW	5,924		2,300	
		AIC (demand)	US\$/kW	8,563		3,139	
Power balance		Hydro	kW	80	20.00%	0	0.00%
		Thermal	kW	320	80.00%	330	100.00%
Power value				Energy value (kWh value)			
Weighted average life time		year	26.00	20.00			
CRF			0.0925	0.1019		Fuel Cost 0.0841 US\$/kWh	
Annualized Power value		US\$/kW/year	547.98	234.26		Energy loss 5.0%	
Average Plant factor		%	34.3%	34.3%		Variable O&M 3.0%	
Average total loss		%	9.9%	9.9%		Energy value 0.0912 US\$/kWh	
Fixed O&M cost		%	3.00%	3.00%			
Power value per kWh		US\$/kWh	0.2085	0.0891			
Energy value (weighted)		US\$/kWh	0.0730	0.0912			
LRAIC =		US\$/kWh	0.2814	0.1803			
		SB\$/kWh	1.4071	0.9016			
LRMC =		US\$/kWh	0.1763	0.1329			
		SB\$/kWh	0.8815	0.6646			

## Appendix 12-1-5 Kirakira Plan 1-3

Year	Peak Demand (kW)	Incremental (kW)	Plan-1			Plan-2		Plan-3	
			Retire (kW)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	55	0		0	0	0	0	0	0
1999	69	14		0	0	0	0	0	0
2000	76	7		0	0	0	0	0	0
2001	84	8		200	413,000	200	413,000	200	413,000
2002	92	8		0	1,144,017	0	1,144,017	0	0
2003	101	9		0	304,106	0	304,106	0	0
2004	110	9		120	0	120	0	170	351,050
2005	120	10		0	0	0	0	0	0
2006	131	11		0	0	0	0	0	0
2007	143	12		0	882,304	0	0	0	0
2008	155	12		20	0	0	0	0	0
2009	179	24		0	0	0	0	0	0
2010	193	14		0	0	0	0	0	0
2011	207	14		0	0	240	495,600	170	351,050
2012	223	16	60	300	619,500	0	0	0	0
2013	240	17	50	0	0	0	0	0	0
2014	256	16		0	0	0	0	0	0
2015	274	18		0	0	0	0	0	0
2016	292	18		0	0	0	0	0	0
2017	312	20		0	0	0	0	0	0
2018	334	22		0	0	0	0	0	0
Total =		279	110	640	3,362,927	560	2,356,723	540	1,115,100
NPV =		113		320	1,877,774	299	1,442,537	304	627,920
Discount Rate		8.00%							
AIC (capacity)			US\$/kW	5,865		4,829		2,065	
AIC (demand)			US\$/kW	16,687		12,819		5,580	
Power balance									
Hydro			kW	140	21.88%	120	21.43%	0	0.00%
Thermal			kW	500	78.13%	440	78.57%	540	100.00%
Power value									Energy value (kWh value)
Weighted average life time			year	26.56		26.43		20.00	
CRF				0.0919		0.0920		0.1019	
Annualized Power value			US\$/kW/year	538.97		444.44		210.32	
Average Plant factor			%	34.3%		34.3%		34.3%	
Average total loss			%	9.9%		9.9%		9.9%	
Fixed O&M cost			%	3.00%		3.00%		3.00%	
Power value per kWh			US\$/kWh	0.2050		0.1691		0.0800	
Energy value (weighted)			US\$/kWh	0.0713		0.0717		0.0912	
LRAIC =			US\$/kWh	0.2763		0.2407		0.1712	
			SB\$/kWh	1.3814		1.2037		0.8561	
LRMC =			US\$/kWh	0.2713		0.2256		0.1653	
			SB\$/kWh	1.3564		1.1278		0.8267	

Fuel Cost	0.0841 US\$/kWh
Energy loss	5.0%
Variable O&M	3.0%
Energy value	0.0912 US\$/kWh



## Appendix 12-1-6 Lata Plan 1-2

Year	Peak Demand (kW)	Incremental (kW)	Retire (kW)	Plan-1		Plan-2	
				New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	65	0		0	0	0	0
1999	66	1		0	0	0	0
2000	70	4		0	0	0	0
2001	75	5		0	0	0	0
2002	80	5		0	0	0	0
2003	86	6		0	0	0	0
2004	91	5		0	0	0	0
2005	96	5		200	461,400	200	461,400
2006	102	6		0	0	0	0
2007	108	6		0	0	0	0
2008	115	7		0	0	0	0
2009	121	6		0	0	0	0
2010	128	7		0	0	0	0
2011	134	6		0	3,982,946	0	0
2012	141	7		50	0	200	461,400
2013	149	8	60	150	346,050	0	0
2014	156	7	40	0	0	0	0
2015	163	7	60	0	0	0	0
2016	170	7		0	0	0	0
2017	178	8		0	0	0	0
2018	186	8		0	0	0	0
Total =		121	160	400	4,790,396	400	922,800
NPV =		49		168	1,706,327	171	394,733
Discount Rate		8.00%					
		AIC (capacity)	US\$/kW	10,181		2,307	
		AIC (demand)	US\$/kW	34,537		7,990	
Power balance		Hydro	kW	50	12.50%	0	0.00%
		Thermal	kW	350	87.50%	400	100.00%
Power value				Energy value (kWh value)			
Weighted average life time		year	23.75		20.00		
CRF			0.0953		0.1019		
Annualized Power value		US\$/kW/year	970.50		234.97		
Average Plant factor		%	34.3%		34.3%		
Average total loss		%	9.9%		9.9%		
Fixed O&M cost		%	3.00%		3.00%		
Power value per kWh		US\$/kWh	0.3692		0.0894		
Energy value (weighted)		US\$/kWh	0.0798		0.0912		
LRAIC =		US\$/kWh	0.4490		0.1806		
		SB\$/kWh	2.2449		0.9030		
LRMC =		US\$/kWh	0.5092		0.1974		
		SB\$/kWh	2.5462		0.9868		
						Fuel Cost	0.0841 US\$/kWh
						Energy loss	5.0%
						Variable O&M	3.0%
						Energy value	0.0912 US\$/kWh

**Appendix 12-1-7    Taro-Choiseul    Plan 1-2**

Year	Peak Demand (kW)	Incremental (kW)	Plan-1		Plan-2	
			New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	14	0	0	0	0	0
1999	19	5	0	0	0	0
2000	21	2	40	206,960	40	206,960
2001	23	2	0	0	0	0
2002	25	2	0	1,798,469	0	0
2003	28	3	70	0	120	620,880
2004	30	2	0	0	0	0
2005	32	2	0	0	0	0
2006	35	3	0	0	0	0
2007	38	3	0	0	0	0
2008	41	3	0	0	0	0
2009	57	16	0	0	0	0
2010	60	3	0	0	0	0
2011	63	3	0	0	0	0
2012	66	3	0	0	0	0
2013	70	4	0	0	0	0
2014	73	3	0	0	0	0
2015	76	3	0	0	0	0
2016	79	3	0	0	0	0
2017	82	3	0	0	0	0
2018	86	4	0	0	0	0
Total =		72	110	2,005,429	160	827,840
NPV =		31	76	1,388,299	107	555,551
Discount Rate		8.00%				
			AIC (capacity)	US\$/kW	18,300	5,174
			AIC (demand)	US\$/kW	44,345	17,745
Power balance			Hydro	kW	70	63.64%
			Thermal	kW	40	36.36%
Power value						Energy value (kWh value)
Weighted average life time			year	39.09	20.00	
CRF				0.0842	0.1019	Fuel Cost 0.0841 US\$/kWh
Annualized Power value			US\$/kW/year	1,539.99	526.98	Energy loss 5.0%
Average Plant factor			%	34.3%	34.3%	Variable O&M 3.0%
Average total loss			%	9.9%	9.9%	Energy value 0.0912 US\$/kWh
Fixed O&M cost			%	3.00%	3.00%	
Power value per kWh			US\$/kWh	0.5858	0.2005	
Energy value (weighted)			US\$/kWh	0.0332	0.0912	
LRAIC =			US\$/kWh	0.6190	0.2917	
			SB\$/kWh	3.0949	1.4584	
LRMC =			US\$/kWh	0.5199	0.3270	
			SB\$/kWh	2.5997	1.6348	

## Appendix 12-1-8 Gizo Plan 1-3

Year	Peak Demand (kW)	Incremental (kW)	Retire (kW)	Plan-1		Plan-2		Plan-3	
				New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	270	0		0	0	0	0	0	0
1999	485	215		0	0	0	0	0	0
2000	512	27		400	800,000	400	800,000	400	800,000
2001	541	29		0	0	0	0	400	800,000
2002	571	30		1,200	2,400,000	600	1,200,000	0	0
2003	603	32	510	0	0	0	0	400	800,000
2004	632	29		0	0	0	0	0	0
2005	662	30		0	0	0	0	0	0
2006	694	32		0	0	300	600,000	0	0
2007	727	33		0	0	0	0	0	0
2008	763	36		0	0	0	0	0	0
2009	793	30		0	0	0	0	400	800,000
2010	824	31		0	0	0	0	0	0
2011	856	32		0	0	0	0	0	0
2012	891	35		0	0	0	0	0	0
2013	926	35		0	0	0	0	0	0
2014	955	29		0	0	0	0	0	0
2015	984	29		600	1,200,000	300	600,000	0	0
2016	1,015	31		0	0	0	0	0	0
2017	1,046	31		0	0	0	0	0	0
2018	1,079	33		0	0	0	0	0	0
Total =		809	510	2,200	4,400,000	1,600	3,200,000	1,600	3,200,000
NPV =		438		1,284	2,568,764	951	1,902,064	1,022	2,044,916
Discount Rate		8.00%							
		AIC (capacity)	US\$/kW	2,000		2,000		2,000	
		AIC (demand)	US\$/kW	5,859		4,338		4,664	
Power balance		Hydro	kW	0	0.00%	0	0.00%	0	0.00%
		Thermal	kW	2,200	100.00%	1,600	100.00%	1,600	100.00%
Power value				Energy value (kWh value)					
Weighted average life time		year	20.00		20.00		20.00		
CRF			0.1019		0.1019		0.1019		
Annualized Power value		US\$/kW/year	203.70		203.70		203.70		
Average Plant factor		%	34.3%		34.3%		34.3%		
Average total loss		%	9.9%		9.9%		9.9%		
Fixed O&M cost		%	3.00%		3.00%		3.00%		
Power value per kWh		US\$/kWh	0.0775		0.0775		0.0775		
Energy value (weighted)		US\$/kWh	0.0912		0.0912		0.0912		
LRAIC =		US\$/kWh	0.1687		0.1687		0.1687		
		SB\$/kWh	0.8435		0.8435		0.8435		
LRMC =		US\$/kWh	0.1690		0.1488		0.1532		
		SB\$/kWh	0.8452		0.7442		0.7659		

Fuel Cost 0.0841 US\$/kWh  
Energy loss 5.0%  
Variable O&M 3.0%  
Energy value 0.0912 US\$/kWh

**Appendix 12-1-9    Noro-Munda    Plan 1-2**

Year	Peak Demand (kW)	Incremental (kW)	Retire (kW)	Plan-1		Plan-2	
				New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	1,790	0		0	0	0	0
1999	1,930	140		0	0	0	0
2000	2,150	220		0	0	0	0
2001	2,397	247		4,000	7,200,000	4,000	7,200,000
2002	2,673	276		0	0	0	0
2003	2,983	310		0	0	0	0
2004	3,297	314		0	0	0	0
2005	3,647	350		4,200	7,560,000	4,000	7,200,000
2006	4,036	389	900	0	0	0	0
2007	4,469	433	900	4,200	7,560,000	0	0
2008	4,951	482	900	0	0	0	0
2009	5,401	450		0	0	0	0
2010	5,893	492		0	0	4,000	7,200,000
2011	6,433	540		0	0	0	0
2012	7,024	591		0	0	0	0
2013	7,673	649		4,200	7,560,000	0	0
2014	8,289	616		0	0	0	0
2015	8,957	668		0	0	0	0
2016	9,683	726		0	0	2,000	3,600,000
2017	10,470	787		0	0	0	0
2018	11,326	856		0	0	0	0
Total =		9,536	2,700	16,600	29,880,000	14,000	25,200,000
NPV =		3,594		8,381	15,085,082	7,035	12,663,739
Discount Rate		8.00%					
		AIC (capacity)	US\$/kW	1,800		1,800	
		AIC (demand)	US\$/kW	4,198		3,524	
Power balance		Hydro	kW	0	0.00%	0	0.00%
		Thermal	kW	16,600	100.00%	14,000	100.00%
Power value				Energy value (kWh value)			
Weighted average life time		year	20.00		20.00		
CRF			0.1019		0.1019	Fuel Cost	0.0841 US\$/kWh
Annualized Power value		US\$/kW/year	183.33		183.33	Energy loss	5.0%
Average Plant factor		%	34.3%		34.3%	Variable O&M	3.0%
Average total loss		%	9.9%		9.9%	Energy value	0.0912 US\$/kWh
Fixed O&M cost		%	3.00%		3.00%		
Power value per kWh		US\$/kWh	0.0697		0.0697		
Energy value (weighted)		US\$/kWh	0.0912		0.0912		
LRAIC =		US\$/kWh	0.1610		0.1610		
		SB\$/kWh	0.8048		0.8048		
LRMC =		US\$/kWh	0.1470		0.1380		
		SB\$/kWh	0.7349		0.6902		

## Appendix 12-1-10 Tulagi Plan 1-2

Year	Peak Demand (kW)	Incremental (kW)	Plan-1		Plan-2	
			New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	49	0	0	0	0	0
1999	61	12	0	0	0	0
2000	65	4	0	0	0	0
2001	68	3	0	0	0	0
2002	71	3	0	0	0	0
2003	75	4	0	0	0	0
2004	79	4	0	0	0	0
2005	82	3	83	415,000	60	300,000
2006	86	4	0	0	0	0
2007	91	5	0	0	0	0
2008	95	4	0	0	0	0
2009	99	4	0	0	0	0
2010	103	4	0	0	0	0
2011	108	5	0	0	0	0
2012	113	5	0	0	0	0
2013	118	5	0	0	0	0
2014	122	4	0	0	0	0
2015	127	5	0	0	0	0
2016	132	5	0	0	0	0
2017	137	5	0	0	0	0
2018	143	6	0	0	0	0
Total =		94	83	415,000	60	300,000
NPV =		44	45	224,212	32	162,081
Discount Rate		8.00%				
AIC (capacity)			5,000		5,000	
AIC (demand)			5,122		3,703	
Power balance						
Hydro			0	0.00%	0	0.00%
Thermal			327	100.00%	304	100.00%
Power value					Energy value (kWh value)	
Weighted average life time			20.00		20.00	
CRF			0.1019		0.1019	
Annualized Power value			509.26		509.26	
Average Plant factor			34.3%		34.3%	
Average total loss			9.9%		9.9%	
Fixed O&M cost			3.00%		3.00%	
Power value per kWh			0.1937		0.1937	
Energy value (weighted)			0.0912		0.0912	
LRAIC =			US\$/kWh	0.2849	0.2849	
			SB\$/kWh	1.4247	1.4247	
LRMC =			US\$/kWh	0.1593	0.1404	
			SB\$/kWh	0.7963	0.7020	
Fuel Cost					0.0841	US\$/kWh
Energy loss					5.0%	
Variable O&M					3.0%	
Energy value					0.0912	US\$/kWh

Appendix 12-1-11 Rennell Plan 1-2

Year	Peak Demand (kW)	Incremental (kW)	Plan-1		Plan-2	
			New (kW)	Total Cost (US\$)	New (kW)	Total Cost (US\$)
1998	6	0	0	0	0	0
1999	6	0	0	0	0	0
2000	7	1	0	0	0	0
2001	7	0	0	0	0	0
2002	8	1	60	1,500,000	60	1,500,000
2003	9	1	0	0	0	0
2004	9	0	0	0	0	0
2005	10	1	20	500,000	20	500,000
2006	10	0	0	0	0	0
2007	11	1	0	0	0	0
2008	12	1	30	750,000	30	750,000
2009	12	0	0	0	0	0
2010	13	1	0	0	0	0
2011	13	0	20	500,000	20	500,000
2012	14	1	0	0	0	0
2013	15	1	0	0	0	0
2014	15	0	30	750,000	30	750,000
2015	16	1	0	0	0	0
2016	16	0	0	0	0	0
2017	16	0	0	0	0	0
2018	17	1	0	0	0	0
Total =		11	160	4,000,000	160	4,000,000
NPV =		5	79	1,985,604	79	1,985,604
Discount Rate		8.00%				
			AIC (capacity)	US\$/kW	25,000	25,000
			AIC (demand)	US\$/kW	400,270	400,270
Power balance			Hydro	kW	0	0
			Thermal	kW	0	0
Power value						
Weighted average life time			year	20.00	20.00	
CRF				0.1019	0.1019	
Annualized Power value			US\$/kW/year	2,546.31	2,546.31	
Average Plant factor			%	6.6%	6.6%	
Average total loss			%	0.0%	0.0%	
Fixed O&M cost			%	0.00%	3.72%	
Power value per kWh			US\$/kWh	4.4060	4.5700	
Energy value (weighted)			US\$/kWh	0.0000	0.0000	
LRAIC =			US\$/kWh	4.4060	4.5700	
			SB\$/kWh	22.0300	22.8500	
LRMC =			US\$/kWh	4.6539	4.8272	
			SB\$/kWh	23.2696	24.1358	

## Appendix 12-2-7 (1) Calculation of IRR

### Maotapku-1

Maotapku-1						Alternative Diesel						
FIRR =		5.244%				EIRR =		3.280%		kW coat	1,534	US\$kW
										Plant Factor	38.1%	
										Power value	4,580	US\$kW
US\$						US\$						
Year	Cost	O&M	Sold Energy MWh	Benefit	NET	Year	Cost	O&M	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET
1	4,476,600	0		0	-4,476,600	1	4,330,837	0		0	0	-4,330,837
2	6,217,500	0		0	-6,217,500	2	6,015,052	0		0	0	-6,015,052
3	10,694,100	0		0	-10,694,100	3	10,345,889	0		0	0	-10,345,889
4	3,481,800	0		0	-3,481,800	4	3,368,429	0		7,328,669	0	3,960,240
5		141,000	7,423	1,696,800	1,555,800	5		136,409	7,423	0	647,611	511,202
6		141,000	7,423	1,696,800	1,555,800	6		136,409	7,423	0	647,611	511,202
7		141,000	7,423	1,696,800	1,555,800	7		136,409	7,423	0	647,611	511,202
8		141,000	7,423	1,696,800	1,555,800	8		136,409	7,423	0	647,611	511,202
9		141,000	7,423	1,696,800	1,555,800	9		136,409	7,423	0	647,611	511,202
10		141,000	7,423	1,696,800	1,555,800	10		136,409	7,423	0	647,611	511,202
11		141,000	7,423	1,696,800	1,555,800	11		136,409	7,423	0	647,611	511,202
12		141,000	7,423	1,696,800	1,555,800	12		136,409	7,423	0	647,611	511,202
13		141,000	7,423	1,696,800	1,555,800	13		136,409	7,423	0	647,611	511,202
14		141,000	7,423	1,696,800	1,555,800	14		136,409	7,423	0	647,611	511,202
15		141,000	7,423	1,696,800	1,555,800	15		136,409	7,423	0	647,611	511,202
16		141,000	7,423	1,696,800	1,555,800	16		136,409	7,423	0	647,611	511,202
17		141,000	7,423	1,696,800	1,555,800	17		136,409	7,423	0	647,611	511,202
18		141,000	7,423	1,696,800	1,555,800	18		136,409	7,423	0	647,611	511,202
19		141,000	7,423	1,696,800	1,555,800	19		136,409	7,423	0	647,611	511,202
20		141,000	7,423	1,696,800	1,555,800	20		136,409	7,423	0	647,611	511,202
21		141,000	7,423	1,696,800	1,555,800	21		136,409	7,423	0	647,611	511,202
22		141,000	7,423	1,696,800	1,555,800	22		136,409	7,423	0	647,611	511,202
23		141,000	7,423	1,696,800	1,555,800	23		136,409	7,423	0	647,611	511,202
24		141,000	7,423	1,696,800	1,555,800	24		136,409	7,423	7,328,669	647,611	7,839,871
25		141,000	7,423	1,696,800	1,555,800	25		136,409	7,423	0	647,611	511,202
26		141,000	7,423	1,696,800	1,555,800	26		136,409	7,423	0	647,611	511,202
27		141,000	7,423	1,696,800	1,555,800	27		136,409	7,423	0	647,611	511,202
28		141,000	7,423	1,696,800	1,555,800	28		136,409	7,423	0	647,611	511,202
29		141,000	7,423	1,696,800	1,555,800	29		136,409	7,423	0	647,611	511,202
30		141,000	7,423	1,696,800	1,555,800	30		136,409	7,423	0	647,611	511,202
31		141,000	7,423	1,696,800	1,555,800	31		136,409	7,423	0	647,611	511,202
32		141,000	7,423	1,696,800	1,555,800	32		136,409	7,423	0	647,611	511,202
33		141,000	7,423	1,696,800	1,555,800	33		136,409	7,423	0	647,611	511,202
34		141,000	7,423	1,696,800	1,555,800	34		136,409	7,423	0	647,611	511,202
35		141,000	7,423	1,696,800	1,555,800	35		136,409	7,423	0	647,611	511,202
36		141,000	7,423	1,696,800	1,555,800	36		136,409	7,423	0	647,611	511,202
37		141,000	7,423	1,696,800	1,555,800	37		136,409	7,423	0	647,611	511,202
38		141,000	7,423	1,696,800	1,555,800	38		136,409	7,423	0	647,611	511,202
39		141,000	7,423	1,696,800	1,555,800	39		136,409	7,423	0	647,611	511,202
40		141,000	7,423	1,696,800	1,555,800	40		136,409	7,423	0	647,611	511,202
41		141,000	7,423	1,696,800	1,555,800	41		136,409	7,423	0	647,611	511,202
42		141,000	7,423	1,696,800	1,555,800	42		136,409	7,423	0	647,611	511,202
43		141,000	7,423	1,696,800	1,555,800	43		136,409	7,423	0	647,611	511,202
44		141,000	7,423	1,696,800	1,555,800	44		136,409	7,423	7,328,669	647,611	7,839,871
45		141,000	7,423	1,696,800	1,555,800	45		136,409	7,423	0	647,611	511,202
46		141,000	7,423	1,696,800	1,555,800	46		136,409	7,423	0	647,611	511,202
47		141,000	7,423	1,696,800	1,555,800	47		136,409	7,423	0	647,611	511,202
48		141,000	7,423	1,696,800	1,555,800	48		136,409	7,423	0	647,611	511,202
49		141,000	7,423	1,696,800	1,555,800	49		136,409	7,423	0	647,611	511,202
50		141,000	7,423	1,696,800	1,555,800	50		136,409	7,423	0	647,611	511,202

## Appendix 12-2-7 (2) Calculation of IRR

### Maotapku-2

Maotapku-2						Alternative Diesel								
												kW coat	1,534	US\$kW
												Plant Factor	38.1%	
												Power value	4,580	US\$kW
FIRR = 3.400%						EIRR = 1.416%								
US\$						US\$								
Year	Cost	O&M	Sold Energy MWh	Benefit	NET	Year	Cost	O&M	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET		
1	4,864,860	0		0	-4,864,860	1	4,706,455	0		0	0	-4,706,455		
2	6,756,750	0		0	-6,756,750	2	6,536,743	0		0	0	-6,536,743		
3	11,621,610	0		0	-11,621,610	3	11,243,198	0		0	0	-11,243,198		
4	3,783,780	0		0	-3,783,780	4	3,660,576	0		6,412,586	0	2,752,009		
5		203,000	6,268	1,432,906	1,229,906	5		196,390	6,268	0	546,892	350,502		
6		203,000	6,268	1,432,906	1,229,906	6		196,390	6,268	0	546,892	350,502		
7		203,000	6,268	1,432,906	1,229,906	7		196,390	6,268	0	546,892	350,502		
8		203,000	6,268	1,432,906	1,229,906	8		196,390	6,268	0	546,892	350,502		
9		203,000	6,268	1,432,906	1,229,906	9		196,390	6,268	0	546,892	350,502		
10		203,000	6,268	1,432,906	1,229,906	10		196,390	6,268	0	546,892	350,502		
11		203,000	6,268	1,432,906	1,229,906	11		196,390	6,268	0	546,892	350,502		
12		203,000	6,268	1,432,906	1,229,906	12		196,390	6,268	0	546,892	350,502		
13		203,000	6,268	1,432,906	1,229,906	13		196,390	6,268	0	546,892	350,502		
14		203,000	6,268	1,432,906	1,229,906	14		196,390	6,268	0	546,892	350,502		
15		203,000	6,268	1,432,906	1,229,906	15		196,390	6,268	0	546,892	350,502		
16		203,000	6,268	1,432,906	1,229,906	16		196,390	6,268	0	546,892	350,502		
17		203,000	6,268	1,432,906	1,229,906	17		196,390	6,268	0	546,892	350,502		
18		203,000	6,268	1,432,906	1,229,906	18		196,390	6,268	0	546,892	350,502		
19		203,000	6,268	1,432,906	1,229,906	19		196,390	6,268	0	546,892	350,502		
20		203,000	6,268	1,432,906	1,229,906	20		196,390	6,268	0	546,892	350,502		
21		203,000	6,268	1,432,906	1,229,906	21		196,390	6,268	0	546,892	350,502		
22		203,000	6,268	1,432,906	1,229,906	22		196,390	6,268	0	546,892	350,502		
23		203,000	6,268	1,432,906	1,229,906	23		196,390	6,268	0	546,892	350,502		
24		203,000	6,268	1,432,906	1,229,906	24		196,390	6,268	6,412,586	546,892	6,763,087		
25		203,000	6,268	1,432,906	1,229,906	25		196,390	6,268	0	546,892	350,502		
26		203,000	6,268	1,432,906	1,229,906	26		196,390	6,268	0	546,892	350,502		
27		203,000	6,268	1,432,906	1,229,906	27		196,390	6,268	0	546,892	350,502		
28		203,000	6,268	1,432,906	1,229,906	28		196,390	6,268	0	546,892	350,502		
29		203,000	6,268	1,432,906	1,229,906	29		196,390	6,268	0	546,892	350,502		
30		203,000	6,268	1,432,906	1,229,906	30		196,390	6,268	0	546,892	350,502		
31		203,000	6,268	1,432,906	1,229,906	31		196,390	6,268	0	546,892	350,502		
32		203,000	6,268	1,432,906	1,229,906	32		196,390	6,268	0	546,892	350,502		
33		203,000	6,268	1,432,906	1,229,906	33		196,390	6,268	0	546,892	350,502		
34		203,000	6,268	1,432,906	1,229,906	34		196,390	6,268	0	546,892	350,502		
35		203,000	6,268	1,432,906	1,229,906	35		196,390	6,268	0	546,892	350,502		
36		203,000	6,268	1,432,906	1,229,906	36		196,390	6,268	0	546,892	350,502		
37		203,000	6,268	1,432,906	1,229,906	37		196,390	6,268	0	546,892	350,502		
38		203,000	6,268	1,432,906	1,229,906	38		196,390	6,268	0	546,892	350,502		
39		203,000	6,268	1,432,906	1,229,906	39		196,390	6,268	0	546,892	350,502		
40		203,000	6,268	1,432,906	1,229,906	40		196,390	6,268	0	546,892	350,502		
41		203,000	6,268	1,432,906	1,229,906	41		196,390	6,268	0	546,892	350,502		
42		203,000	6,268	1,432,906	1,229,906	42		196,390	6,268	0	546,892	350,502		
43		203,000	6,268	1,432,906	1,229,906	43		196,390	6,268	0	546,892	350,502		
44		203,000	6,268	1,432,906	1,229,906	44		196,390	6,268	6,412,586	546,892	6,763,087		
45		203,000	6,268	1,432,906	1,229,906	45		196,390	6,268	0	546,892	350,502		
46		203,000	6,268	1,432,906	1,229,906	46		196,390	6,268	0	546,892	350,502		
47		203,000	6,268	1,432,906	1,229,906	47		196,390	6,268	0	546,892	350,502		
48		203,000	6,268	1,432,906	1,229,906	48		196,390	6,268	0	546,892	350,502		
49		203,000	6,268	1,432,906	1,229,906	49		196,390	6,268	0	546,892	350,502		
50		203,000	6,268	1,432,906	1,229,906	50		196,390	6,268	0	546,892	350,502		



### Appendix 12-2-7 (3) Calculation of IRR

Sasa

FIRR = 5.880%

US\$

Year	Cost	O&M	Sold Energy MWh	Benefit	NET
1	4,906,690	0	0	0	-4,906,690
2	1,304,310	0	0	0	-1,304,310
3	0	62,000	2,269	470,472	408,472
4	0	62,000	2,269	470,472	408,472
5		62,000	2,269	470,472	408,472
6		62,000	2,269	470,472	408,472
7		62,000	2,269	470,472	408,472
8		62,000	2,269	470,472	408,472
9		62,000	2,269	470,472	408,472
10		62,000	2,269	470,472	408,472
11		62,000	2,269	470,472	408,472
12		62,000	2,269	470,472	408,472
13		62,000	2,269	470,472	408,472
14		62,000	2,269	470,472	408,472
15		62,000	2,269	470,472	408,472
16		62,000	2,269	470,472	408,472
17		62,000	2,269	470,472	408,472
18		62,000	2,269	470,472	408,472
19		62,000	2,269	470,472	408,472
20		62,000	2,269	470,472	408,472
21		62,000	2,269	470,472	408,472
22		62,000	2,269	470,472	408,472
23		62,000	2,269	470,472	408,472
24		62,000	2,269	470,472	408,472
25		62,000	2,269	470,472	408,472
26		62,000	2,269	470,472	408,472
27		62,000	2,269	470,472	408,472
28		62,000	2,269	470,472	408,472
29		62,000	2,269	470,472	408,472
30		62,000	2,269	470,472	408,472
31		62,000	2,269	470,472	408,472
32		62,000	2,269	470,472	408,472
33		62,000	2,269	470,472	408,472
34		62,000	2,269	470,472	408,472
35		62,000	2,269	470,472	408,472
36		62,000	2,269	470,472	408,472
37		62,000	2,269	470,472	408,472
38		62,000	2,269	470,472	408,472
39		62,000	2,269	470,472	408,472
40		62,000	2,269	470,472	408,472
41		62,000	2,269	470,472	408,472
42		62,000	2,269	470,472	408,472
43		62,000	2,269	470,472	408,472
44		62,000	2,269	470,472	408,472
45		62,000	2,269	470,472	408,472
46		62,000	2,269	470,472	408,472
47		62,000	2,269	470,472	408,472
48		62,000	2,269	470,472	408,472
49		62,000	2,269	470,472	408,472
50		62,000	2,269	470,472	408,472

Alternative Diesel

kW coat

1,534

US\$/kW

Plant Factor

38.1%

Power value

4,580

US\$/kW

EIRR = 2.726%

US\$

Year	Cost	O&M Cost	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET
1	4,746,923	0	0	0	0	-4,746,923
2	1,261,840	0	0	1,282,517	0	20,677
3	0	59,981	2,269	0	197,968	137,987
4	0	59,981	2,269	0	197,968	137,987
5		59,981	2,269	0	197,968	137,987
6		59,981	2,269	0	197,968	137,987
7		59,981	2,269	0	197,968	137,987
8		59,981	2,269	0	197,968	137,987
9		59,981	2,269	0	197,968	137,987
10		59,981	2,269	0	197,968	137,987
11		59,981	2,269	0	197,968	137,987
12		59,981	2,269	0	197,968	137,987
13		59,981	2,269	0	197,968	137,987
14		59,981	2,269	0	197,968	137,987
15		59,981	2,269	0	197,968	137,987
16		59,981	2,269	0	197,968	137,987
17		59,981	2,269	0	197,968	137,987
18		59,981	2,269	0	197,968	137,987
19		59,981	2,269	0	197,968	137,987
20		59,981	2,269	0	197,968	137,987
21		59,981	2,269	0	197,968	137,987
22		59,981	2,269	1,282,517	197,968	1,420,504
23		59,981	2,269	0	197,968	137,987
24		59,981	2,269	0	197,968	137,987
25		59,981	2,269	0	197,968	137,987
26		59,981	2,269	0	197,968	137,987
27		59,981	2,269	0	197,968	137,987
28		59,981	2,269	0	197,968	137,987
29		59,981	2,269	0	197,968	137,987
30		59,981	2,269	0	197,968	137,987
31		59,981	2,269	0	197,968	137,987
32		59,981	2,269	0	197,968	137,987
33		59,981	2,269	0	197,968	137,987
34		59,981	2,269	0	197,968	137,987
35		59,981	2,269	0	197,968	137,987
36		59,981	2,269	0	197,968	137,987
37		59,981	2,269	0	197,968	137,987
38		59,981	2,269	0	197,968	137,987
39		59,981	2,269	0	197,968	137,987
40		59,981	2,269	0	197,968	137,987
41		59,981	2,269	0	197,968	137,987
42		59,981	2,269	1,282,517	197,968	1,420,504
43		59,981	2,269	0	197,968	137,987
44		59,981	2,269	0	197,968	137,987
45		59,981	2,269	0	197,968	137,987
46		59,981	2,269	0	197,968	137,987
47		59,981	2,269	0	197,968	137,987
48		59,981	2,269	0	197,968	137,987
49		59,981	2,269	0	197,968	137,987
50		59,981	2,269	0	197,968	137,987

## Appendix 12-2-7 (4) Calculation of IRR

Silolo

Alternative Diesel

kW coat 1,800 US\$kW

Plant Factor 20.0%

Power value 10,239 US\$kW

FIRR = 6.432%

EIRR = 10.365%

US\$					
Year	Cost	O&M	Sold Energy MWh	Benefit	NET
1	5,086,980	0	0	0	-5,086,980
2	7,065,250	0	0	0	-7,065,250
3	12,152,230	0	0	0	-12,152,230
4	3,956,540	0	0	0	-3,956,540
5		156,000	9,939	2,271,997	2,115,997
6		156,000	9,939	2,271,997	2,115,997
7		156,000	9,939	2,271,997	2,115,997
8		156,000	9,939	2,271,997	2,115,997
9		156,000	9,939	2,271,997	2,115,997
10		156,000	9,939	2,271,997	2,115,997
11		156,000	9,939	2,271,997	2,115,997
12		156,000	9,939	2,271,997	2,115,997
13		156,000	9,939	2,271,997	2,115,997
14		156,000	9,939	2,271,997	2,115,997
15		156,000	9,939	2,271,997	2,115,997
16		156,000	9,939	2,271,997	2,115,997
17		156,000	9,939	2,271,997	2,115,997
18		156,000	9,939	2,271,997	2,115,997
19		156,000	9,939	2,271,997	2,115,997
20		156,000	9,939	2,271,997	2,115,997
21		156,000	9,939	2,271,997	2,115,997
22		156,000	9,939	2,271,997	2,115,997
23		156,000	9,939	2,271,997	2,115,997
24		156,000	9,939	2,271,997	2,115,997
25		156,000	9,939	2,271,997	2,115,997
26		156,000	9,939	2,271,997	2,115,997
27		156,000	9,939	2,271,997	2,115,997
28		156,000	9,939	2,271,997	2,115,997
29		156,000	9,939	2,271,997	2,115,997
30		156,000	9,939	2,271,997	2,115,997
31		156,000	9,939	2,271,997	2,115,997
32		156,000	9,939	2,271,997	2,115,997
33		156,000	9,939	2,271,997	2,115,997
34		156,000	9,939	2,271,997	2,115,997
35		156,000	9,939	2,271,997	2,115,997
36		156,000	9,939	2,271,997	2,115,997
37		156,000	9,939	2,271,997	2,115,997
38		156,000	9,939	2,271,997	2,115,997
39		156,000	9,939	2,271,997	2,115,997
40		156,000	9,939	2,271,997	2,115,997
41		156,000	9,939	2,271,997	2,115,997
42		156,000	9,939	2,271,997	2,115,997
43		156,000	9,939	2,271,997	2,115,997
44		156,000	9,939	2,271,997	2,115,997
45		156,000	9,939	2,271,997	2,115,997
46		156,000	9,939	2,271,997	2,115,997
47		156,000	9,939	2,271,997	2,115,997
48		156,000	9,939	2,271,997	2,115,997
49		156,000	9,939	2,271,997	2,115,997
50		156,000	9,939	2,271,997	2,115,997

US\$						
Year	Cost	O&M Cost	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET
1	4,921,343	0	0	0	0	-4,921,343
2	6,835,198	0	0	0	0	-6,835,198
3	11,756,541	0	0	0	0	-11,756,541
4	3,827,711	0	0	21,501,391	0	17,673,680
5		150,920	9,939	0	867,144	716,224
6		150,920	9,939	0	867,144	716,224
7		150,920	9,939	0	867,144	716,224
8		150,920	9,939	0	867,144	716,224
9		150,920	9,939	0	867,144	716,224
10		150,920	9,939	0	867,144	716,224
11		150,920	9,939	0	867,144	716,224
12		150,920	9,939	0	867,144	716,224
13		150,920	9,939	0	867,144	716,224
14		150,920	9,939	0	867,144	716,224
15		150,920	9,939	0	867,144	716,224
16		150,920	9,939	0	867,144	716,224
17		150,920	9,939	0	867,144	716,224
18		150,920	9,939	0	867,144	716,224
19		150,920	9,939	0	867,144	716,224
20		150,920	9,939	0	867,144	716,224
21		150,920	9,939	0	867,144	716,224
22		150,920	9,939	0	867,144	716,224
23		150,920	9,939	0	867,144	716,224
24		150,920	9,939	21,501,391	867,144	22,217,615
25		150,920	9,939	0	867,144	716,224
26		150,920	9,939	0	867,144	716,224
27		150,920	9,939	0	867,144	716,224
28		150,920	9,939	0	867,144	716,224
29		150,920	9,939	0	867,144	716,224
30		150,920	9,939	0	867,144	716,224
31		150,920	9,939	0	867,144	716,224
32		150,920	9,939	0	867,144	716,224
33		150,920	9,939	0	867,144	716,224
34		150,920	9,939	0	867,144	716,224
35		150,920	9,939	0	867,144	716,224
36		150,920	9,939	0	867,144	716,224
37		150,920	9,939	0	867,144	716,224
38		150,920	9,939	0	867,144	716,224
39		150,920	9,939	0	867,144	716,224
40		150,920	9,939	0	867,144	716,224
41		150,920	9,939	0	867,144	716,224
42		150,920	9,939	0	867,144	716,224
43		150,920	9,939	0	867,144	716,224
44		150,920	9,939	21,501,391	867,144	22,217,615
45		150,920	9,939	0	867,144	716,224
46		150,920	9,939	0	867,144	716,224
47		150,920	9,939	0	867,144	716,224
48		150,920	9,939	0	867,144	716,224
49		150,920	9,939	0	867,144	716,224
50		150,920	9,939	0	867,144	716,224

0

## Appendix 12-2-7 (5) Calculation of IRR

Rori

FIRR = 6.429%

US\$

Year	Cost	O&M	Sold Energy MWh	Benefit	NET
1	4,731,310	0	0	0	-4,731,310
2	1,257,690	0	0	0	-1,257,690
3	0	70,000	2,392	495,998	425,998
4	0	70,000	2,392	495,998	425,998
5		70,000	2,392	495,998	425,998
6		70,000	2,392	495,998	425,998
7		70,000	2,392	495,998	425,998
8		70,000	2,392	495,998	425,998
9		70,000	2,392	495,998	425,998
10		70,000	2,392	495,998	425,998
11		70,000	2,392	495,998	425,998
12		70,000	2,392	495,998	425,998
13		70,000	2,392	495,998	425,998
14		70,000	2,392	495,998	425,998
15		70,000	2,392	495,998	425,998
16		70,000	2,392	495,998	425,998
17		70,000	2,392	495,998	425,998
18		70,000	2,392	495,998	425,998
19		70,000	2,392	495,998	425,998
20		70,000	2,392	495,998	425,998
21		70,000	2,392	495,998	425,998
22		70,000	2,392	495,998	425,998
23		70,000	2,392	495,998	425,998
24		70,000	2,392	495,998	425,998
25		70,000	2,392	495,998	425,998
26		70,000	2,392	495,998	425,998
27		70,000	2,392	495,998	425,998
28		70,000	2,392	495,998	425,998
29		70,000	2,392	495,998	425,998
30		70,000	2,392	495,998	425,998
31		70,000	2,392	495,998	425,998
32		70,000	2,392	495,998	425,998
33		70,000	2,392	495,998	425,998
34		70,000	2,392	495,998	425,998
35		70,000	2,392	495,998	425,998
36		70,000	2,392	495,998	425,998
37		70,000	2,392	495,998	425,998
38		70,000	2,392	495,998	425,998
39		70,000	2,392	495,998	425,998
40		70,000	2,392	495,998	425,998
41		70,000	2,392	495,998	425,998
42		70,000	2,392	495,998	425,998
43		70,000	2,392	495,998	425,998
44		70,000	2,392	495,998	425,998
45		70,000	2,392	495,998	425,998
46		70,000	2,392	495,998	425,998
47		70,000	2,392	495,998	425,998
48		70,000	2,392	495,998	425,998
49		70,000	2,392	495,998	425,998
50		70,000	2,392	495,998	425,998

Alternative Diesel

kW coat

1,800

US\$/kW

Plant Factor

20.0%

Power value

10,239

US\$/kW

EIRR = 6.794%

US\$

Year	Cost	O&M Cost	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET
1	4,577,254	0	0	0	0	-4,577,254
2	1,216,738	0	0	3,071,627	0	1,854,889
3	0	67,721	2,392	0	208,710	140,989
4	0	67,721	2,392	0	208,710	140,989
5		67,721	2,392	0	208,710	140,989
6		67,721	2,392	0	208,710	140,989
7		67,721	2,392	0	208,710	140,989
8		67,721	2,392	0	208,710	140,989
9		67,721	2,392	0	208,710	140,989
10		67,721	2,392	0	208,710	140,989
11		67,721	2,392	0	208,710	140,989
12		67,721	2,392	0	208,710	140,989
13		67,721	2,392	0	208,710	140,989
14		67,721	2,392	0	208,710	140,989
15		67,721	2,392	0	208,710	140,989
16		67,721	2,392	0	208,710	140,989
17		67,721	2,392	0	208,710	140,989
18		67,721	2,392	0	208,710	140,989
19		67,721	2,392	0	208,710	140,989
20		67,721	2,392	0	208,710	140,989
21		67,721	2,392	0	208,710	140,989
22		67,721	2,392	3,071,627	208,710	3,212,616
23		67,721	2,392	0	208,710	140,989
24		67,721	2,392	0	208,710	140,989
25		67,721	2,392	0	208,710	140,989
26		67,721	2,392	0	208,710	140,989
27		67,721	2,392	0	208,710	140,989
28		67,721	2,392	0	208,710	140,989
29		67,721	2,392	0	208,710	140,989
30		67,721	2,392	0	208,710	140,989
31		67,721	2,392	0	208,710	140,989
32		67,721	2,392	0	208,710	140,989
33		67,721	2,392	0	208,710	140,989
34		67,721	2,392	0	208,710	140,989
35		67,721	2,392	0	208,710	140,989
36		67,721	2,392	0	208,710	140,989
37		67,721	2,392	0	208,710	140,989
38		67,721	2,392	0	208,710	140,989
39		67,721	2,392	0	208,710	140,989
40		67,721	2,392	0	208,710	140,989
41		67,721	2,392	0	208,710	140,989
42		67,721	2,392	3,071,627	208,710	3,212,616
43		67,721	2,392	0	208,710	140,989
44		67,721	2,392	0	208,710	140,989
45		67,721	2,392	0	208,710	140,989
46		67,721	2,392	0	208,710	140,989
47		67,721	2,392	0	208,710	140,989
48		67,721	2,392	0	208,710	140,989
49		67,721	2,392	0	208,710	140,989
50		67,721	2,392	0	208,710	140,989

## Appendix 12-2-7 (6) Calculation of IRR

Kware'a

FIRR = 0.313%

US\$					
Year	Cost	O&M	Sold Energy MWh	Benefit	NET
1	3,273,300	0	0	0	-3,273,300
2	4,546,250	0	0	0	-4,546,250
3	7,819,550	0	0	0	-7,819,550
4	2,545,900	0	0	0	-2,545,900
5		123,000	2,406	550,085	427,085
6		123,000	2,406	550,085	427,085
7		123,000	2,406	550,085	427,085
8		123,000	2,406	550,085	427,085
9		123,000	2,406	550,085	427,085
10		123,000	2,406	550,085	427,085
11		123,000	2,406	550,085	427,085
12		123,000	2,406	550,085	427,085
13		123,000	2,406	550,085	427,085
14		123,000	2,406	550,085	427,085
15		123,000	2,406	550,085	427,085
16		123,000	2,406	550,085	427,085
17		123,000	2,406	550,085	427,085
18		123,000	2,406	550,085	427,085
19		123,000	2,406	550,085	427,085
20		123,000	2,406	550,085	427,085
21		123,000	2,406	550,085	427,085
22		123,000	2,406	550,085	427,085
23		123,000	2,406	550,085	427,085
24		123,000	2,406	550,085	427,085
25		123,000	2,406	550,085	427,085
26		123,000	2,406	550,085	427,085
27		123,000	2,406	550,085	427,085
28		123,000	2,406	550,085	427,085
29		123,000	2,406	550,085	427,085
30		123,000	2,406	550,085	427,085
31		123,000	2,406	550,085	427,085
32		123,000	2,406	550,085	427,085
33		123,000	2,406	550,085	427,085
34		123,000	2,406	550,085	427,085
35		123,000	2,406	550,085	427,085
36		123,000	2,406	550,085	427,085
37		123,000	2,406	550,085	427,085
38		123,000	2,406	550,085	427,085
39		123,000	2,406	550,085	427,085
40		123,000	2,406	550,085	427,085
41		123,000	2,406	550,085	427,085
42		123,000	2,406	550,085	427,085
43		123,000	2,406	550,085	427,085
44		123,000	2,406	550,085	427,085
45		123,000	2,406	550,085	427,085
46		123,000	2,406	550,085	427,085
47		123,000	2,406	550,085	427,085
48		123,000	2,406	550,085	427,085
49		123,000	2,406	550,085	427,085
50		123,000	2,406	550,085	427,085

Alternative Diesel

kW coat 1,800 US\$kW  
Plant Factor 20.0%  
Power value 10,239 US\$kW

EIRR = 1.227%

US\$						
Year	Cost	O&M Cost	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET
1	3,166,718	0	0	0	0	-3,166,718
2	4,398,219	0	0	0	0	-4,398,219
3	7,564,937	0	0	0	0	-7,564,937
4	2,463,003	0	0	6,143,255	0	3,680,252
5		118,995	2,406	0	209,949	90,954
6		118,995	2,406	0	209,949	90,954
7		118,995	2,406	0	209,949	90,954
8		118,995	2,406	0	209,949	90,954
9		118,995	2,406	0	209,949	90,954
10		118,995	2,406	0	209,949	90,954
11		118,995	2,406	0	209,949	90,954
12		118,995	2,406	0	209,949	90,954
13		118,995	2,406	0	209,949	90,954
14		118,995	2,406	0	209,949	90,954
15		118,995	2,406	0	209,949	90,954
16		118,995	2,406	0	209,949	90,954
17		118,995	2,406	0	209,949	90,954
18		118,995	2,406	0	209,949	90,954
19		118,995	2,406	0	209,949	90,954
20		118,995	2,406	0	209,949	90,954
21		118,995	2,406	0	209,949	90,954
22		118,995	2,406	0	209,949	90,954
23		118,995	2,406	0	209,949	90,954
24		118,995	2,406	6,143,255	209,949	6,234,209
25		118,995	2,406	0	209,949	90,954
26		118,995	2,406	0	209,949	90,954
27		118,995	2,406	0	209,949	90,954
28		118,995	2,406	0	209,949	90,954
29		118,995	2,406	0	209,949	90,954
30		118,995	2,406	0	209,949	90,954
31		118,995	2,406	0	209,949	90,954
32		118,995	2,406	0	209,949	90,954
33		118,995	2,406	0	209,949	90,954
34		118,995	2,406	0	209,949	90,954
35		118,995	2,406	0	209,949	90,954
36		118,995	2,406	0	209,949	90,954
37		118,995	2,406	0	209,949	90,954
38		118,995	2,406	0	209,949	90,954
39		118,995	2,406	0	209,949	90,954
40		118,995	2,406	0	209,949	90,954
41		118,995	2,406	0	209,949	90,954
42		118,995	2,406	0	209,949	90,954
43		118,995	2,406	0	209,949	90,954
44		118,995	2,406	6,143,255	209,949	6,234,209
45		118,995	2,406	0	209,949	90,954
46		118,995	2,406	0	209,949	90,954
47		118,995	2,406	0	209,949	90,954
48		118,995	2,406	0	209,949	90,954
49		118,995	2,406	0	209,949	90,954
50		118,995	2,406	0	209,949	90,954

## Appendix 12-2-7 (7) Calculation of IRR

### Kubolata

FIRR = 4.379%

US\$					
Year	Cost	O&M	Sold Energy MWh	Benefit	NET
1	1,649,000	0	0	0	-1,649,000
2	0	23,000	533	105,285	82,285
3	0	23,000	533	105,285	82,285
4	0	23,000	533	105,285	82,285
5		23,000	533	105,285	82,285
6		23,000	533	105,285	82,285
7		23,000	533	105,285	82,285
8		23,000	533	105,285	82,285
9		23,000	533	105,285	82,285
10		23,000	533	105,285	82,285
11		23,000	533	105,285	82,285
12		23,000	533	105,285	82,285
13		23,000	533	105,285	82,285
14		23,000	533	105,285	82,285
15		23,000	533	105,285	82,285
16		23,000	533	105,285	82,285
17		23,000	533	105,285	82,285
18		23,000	533	105,285	82,285
19		23,000	533	105,285	82,285
20		23,000	533	105,285	82,285
21		23,000	533	105,285	82,285
22		23,000	533	105,285	82,285
23		23,000	533	105,285	82,285
24		23,000	533	105,285	82,285
25		23,000	533	105,285	82,285
26		23,000	533	105,285	82,285
27		23,000	533	105,285	82,285
28		23,000	533	105,285	82,285
29		23,000	533	105,285	82,285
30		23,000	533	105,285	82,285
31		23,000	533	105,285	82,285
32		23,000	533	105,285	82,285
33		23,000	533	105,285	82,285
34		23,000	533	105,285	82,285
35		23,000	533	105,285	82,285
36		23,000	533	105,285	82,285
37		23,000	533	105,285	82,285
38		23,000	533	105,285	82,285
39		23,000	533	105,285	82,285
40		23,000	533	105,285	82,285
41		23,000	533	105,285	82,285
42		23,000	533	105,285	82,285
43		23,000	533	105,285	82,285
44		23,000	533	105,285	82,285
45		23,000	533	105,285	82,285
46		23,000	533	105,285	82,285
47		23,000	533	105,285	82,285
48		23,000	533	105,285	82,285
49		23,000	533	105,285	82,285
50		23,000	533	105,285	82,285

### Alternative Diesel

kW coat 2,300 US\$kW  
Plant Factor 20.0%  
Power value 13,083 US\$kW

EIRR = 8.224%

US\$						
Year	Cost	O&M	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET
1	1,595,307	0	0	1,046,629	0	-548,678
2	0	22,251	533	0	46,518	24,267
3	0	22,251	533	0	46,518	24,267
4	0	22,251	533	0	46,518	24,267
5		22,251	533	0	46,518	24,267
6		22,251	533	0	46,518	24,267
7		22,251	533	0	46,518	24,267
8		22,251	533	0	46,518	24,267
9		22,251	533	0	46,518	24,267
10		22,251	533	0	46,518	24,267
11		22,251	533	0	46,518	24,267
12		22,251	533	0	46,518	24,267
13		22,251	533	0	46,518	24,267
14		22,251	533	0	46,518	24,267
15		22,251	533	0	46,518	24,267
16		22,251	533	0	46,518	24,267
17		22,251	533	0	46,518	24,267
18		22,251	533	0	46,518	24,267
19		22,251	533	0	46,518	24,267
20		22,251	533	0	46,518	24,267
21		22,251	533	1,046,629	46,518	1,070,895
22		22,251	533	0	46,518	24,267
23		22,251	533	0	46,518	24,267
24		22,251	533	0	46,518	24,267
25		22,251	533	0	46,518	24,267
26		22,251	533	0	46,518	24,267
27		22,251	533	0	46,518	24,267
28		22,251	533	0	46,518	24,267
29		22,251	533	0	46,518	24,267
30		22,251	533	0	46,518	24,267
31		22,251	533	0	46,518	24,267
32		22,251	533	0	46,518	24,267
33		22,251	533	0	46,518	24,267
34		22,251	533	0	46,518	24,267
35		22,251	533	0	46,518	24,267
36		22,251	533	0	46,518	24,267
37		22,251	533	0	46,518	24,267
38		22,251	533	0	46,518	24,267
39		22,251	533	0	46,518	24,267
40		22,251	533	0	46,518	24,267
41		22,251	533	1,046,629	46,518	1,070,895
42		22,251	533	0	46,518	24,267
43		22,251	533	0	46,518	24,267
44		22,251	533	0	46,518	24,267
45		22,251	533	0	46,518	24,267
46		22,251	533	0	46,518	24,267
47		22,251	533	0	46,518	24,267
48		22,251	533	0	46,518	24,267
49		22,251	533	0	46,518	24,267
50		22,251	533	0	46,518	24,267

## Appendix 12-2-7 (8) Calculation of IRR

### Waimapuru

Waimapuru						Alternative Diesel									
						FIRR = -1.143%		US\$		EIRR = -2.252%		kW coat Plant Factor Power value		2,065	US\$kW
														20.0%	
														11,746	US\$kW
						US\$									
Year	Cost	O&M	Sold Energy MWh	Benefit	NET	Year	Cost	O&M	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET			
1	912,000	0	0	0	-912,000	1	882,304	0	0	234,923	0	-647,382			
2	0	18,000	161	31,781	13,781	2	0	17,414	161	0	14,042	-3,372			
3	0	18,000	161	31,781	13,781	3	0	17,414	161	0	14,042	-3,372			
4	0	18,000	161	31,781	13,781	4	0	17,414	161	0	14,042	-3,372			
5		18,000	161	31,781	13,781	5		17,414	161	0	14,042	-3,372			
6		18,000	161	31,781	13,781	6		17,414	161	0	14,042	-3,372			
7		18,000	161	31,781	13,781	7		17,414	161	0	14,042	-3,372			
8		18,000	161	31,781	13,781	8		17,414	161	0	14,042	-3,372			
9		18,000	161	31,781	13,781	9		17,414	161	0	14,042	-3,372			
10		18,000	161	31,781	13,781	10		17,414	161	0	14,042	-3,372			
11		18,000	161	31,781	13,781	11		17,414	161	0	14,042	-3,372			
12		18,000	161	31,781	13,781	12		17,414	161	0	14,042	-3,372			
13		18,000	161	31,781	13,781	13		17,414	161	0	14,042	-3,372			
14		18,000	161	31,781	13,781	14		17,414	161	0	14,042	-3,372			
15		18,000	161	31,781	13,781	15		17,414	161	0	14,042	-3,372			
16		18,000	161	31,781	13,781	16		17,414	161	0	14,042	-3,372			
17		18,000	161	31,781	13,781	17		17,414	161	0	14,042	-3,372			
18		18,000	161	31,781	13,781	18		17,414	161	0	14,042	-3,372			
19		18,000	161	31,781	13,781	19		17,414	161	0	14,042	-3,372			
20		18,000	161	31,781	13,781	20		17,414	161	0	14,042	-3,372			
21		18,000	161	31,781	13,781	21		17,414	161	234,923	14,042	231,550			
22		18,000	161	31,781	13,781	22		17,414	161	0	14,042	-3,372			
23		18,000	161	31,781	13,781	23		17,414	161	0	14,042	-3,372			
24		18,000	161	31,781	13,781	24		17,414	161	0	14,042	-3,372			
25		18,000	161	31,781	13,781	25		17,414	161	0	14,042	-3,372			
26		18,000	161	31,781	13,781	26		17,414	161	0	14,042	-3,372			
27		18,000	161	31,781	13,781	27		17,414	161	0	14,042	-3,372			
28		18,000	161	31,781	13,781	28		17,414	161	0	14,042	-3,372			
29		18,000	161	31,781	13,781	29		17,414	161	0	14,042	-3,372			
30		18,000	161	31,781	13,781	30		17,414	161	0	14,042	-3,372			
31		18,000	161	31,781	13,781	31		17,414	161	0	14,042	-3,372			
32		18,000	161	31,781	13,781	32		17,414	161	0	14,042	-3,372			
33		18,000	161	31,781	13,781	33		17,414	161	0	14,042	-3,372			
34		18,000	161	31,781	13,781	34		17,414	161	0	14,042	-3,372			
35		18,000	161	31,781	13,781	35		17,414	161	0	14,042	-3,372			
36		18,000	161	31,781	13,781	36		17,414	161	0	14,042	-3,372			
37		18,000	161	31,781	13,781	37		17,414	161	0	14,042	-3,372			
38		18,000	161	31,781	13,781	38		17,414	161	0	14,042	-3,372			
39		18,000	161	31,781	13,781	39		17,414	161	0	14,042	-3,372			
40		18,000	161	31,781	13,781	40		17,414	161	0	14,042	-3,372			
41		18,000	161	31,781	13,781	41		17,414	161	234,923	14,042	231,550			
42		18,000	161	31,781	13,781	42		17,414	161	0	14,042	-3,372			
43		18,000	161	31,781	13,781	43		17,414	161	0	14,042	-3,372			
44		18,000	161	31,781	13,781	44		17,414	161	0	14,042	-3,372			
45		18,000	161	31,781	13,781	45		17,414	161	0	14,042	-3,372			
46		18,000	161	31,781	13,781	46		17,414	161	0	14,042	-3,372			
47		18,000	161	31,781	13,781	47		17,414	161	0	14,042	-3,372			
48		18,000	161	31,781	13,781	48		17,414	161	0	14,042	-3,372			
49		18,000	161	31,781	13,781	49		17,414	161	0	14,042	-3,372			
50		18,000	161	31,781	13,781	50		17,414	161	0	14,042	-3,372			

## Appendix 12-2-7 (9) Calculation of IRR

Sorave

FIRR = 3.836%

US\$

Year	Cost	O&M	Sold Energy MWh	Benefit	NET
1	1,859,000	0	0	0	-1,859,000
2	0	26,000	561	110,708	84,708
3	0	26,000	561	110,708	84,708
4	0	26,000	561	110,708	84,708
5		26,000	561	110,708	84,708
6		26,000	561	110,708	84,708
7		26,000	561	110,708	84,708
8		26,000	561	110,708	84,708
9		26,000	561	110,708	84,708
10		26,000	561	110,708	84,708
11		26,000	561	110,708	84,708
12		26,000	561	110,708	84,708
13		26,000	561	110,708	84,708
14		26,000	561	110,708	84,708
15		26,000	561	110,708	84,708
16		26,000	561	110,708	84,708
17		26,000	561	110,708	84,708
18		26,000	561	110,708	84,708
19		26,000	561	110,708	84,708
20		26,000	561	110,708	84,708
21		26,000	561	110,708	84,708
22		26,000	561	110,708	84,708
23		26,000	561	110,708	84,708
24		26,000	561	110,708	84,708
25		26,000	561	110,708	84,708
26		26,000	561	110,708	84,708
27		26,000	561	110,708	84,708
28		26,000	561	110,708	84,708
29		26,000	561	110,708	84,708
30		26,000	561	110,708	84,708
31		26,000	561	110,708	84,708
32		26,000	561	110,708	84,708
33		26,000	561	110,708	84,708
34		26,000	561	110,708	84,708
35		26,000	561	110,708	84,708
36		26,000	561	110,708	84,708
37		26,000	561	110,708	84,708
38		26,000	561	110,708	84,708
39		26,000	561	110,708	84,708
40		26,000	561	110,708	84,708
41		26,000	561	110,708	84,708
42		26,000	561	110,708	84,708
43		26,000	561	110,708	84,708
44		26,000	561	110,708	84,708
45		26,000	561	110,708	84,708
46		26,000	561	110,708	84,708
47		26,000	561	110,708	84,708
48		26,000	561	110,708	84,708
49		26,000	561	110,708	84,708
50		26,000	561	110,708	84,708

Alternative Diesel

kW coat 5,174 US\$kW

Plant Factor 20.0%

Power value 15,449 US\$kW

EIRR = 6.694%

US\$

Year	Cost	O&M Cost	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET
1	1,798,469	0	0	1,081,445	0	-717,025
2	0	25,153	561	0	48,914	23,760
3	0	25,153	561	0	48,914	23,760
4	0	25,153	561	0	48,914	23,760
5		25,153	561	0	48,914	23,760
6		25,153	561	0	48,914	23,760
7		25,153	561	0	48,914	23,760
8		25,153	561	0	48,914	23,760
9		25,153	561	0	48,914	23,760
10		25,153	561	0	48,914	23,760
11		25,153	561	0	48,914	23,760
12		25,153	561	0	48,914	23,760
13		25,153	561	0	48,914	23,760
14		25,153	561	0	48,914	23,760
15		25,153	561	0	48,914	23,760
16		25,153	561	0	48,914	23,760
17		25,153	561	0	48,914	23,760
18		25,153	561	0	48,914	23,760
19		25,153	561	0	48,914	23,760
20		25,153	561	0	48,914	23,760
21		25,153	561	1,081,445	48,914	1,105,205
22		25,153	561	0	48,914	23,760
23		25,153	561	0	48,914	23,760
24		25,153	561	0	48,914	23,760
25		25,153	561	0	48,914	23,760
26		25,153	561	0	48,914	23,760
27		25,153	561	0	48,914	23,760
28		25,153	561	0	48,914	23,760
29		25,153	561	0	48,914	23,760
30		25,153	561	0	48,914	23,760
31		25,153	561	0	48,914	23,760
32		25,153	561	0	48,914	23,760
33		25,153	561	0	48,914	23,760
34		25,153	561	0	48,914	23,760
35		25,153	561	0	48,914	23,760
36		25,153	561	0	48,914	23,760
37		25,153	561	0	48,914	23,760
38		25,153	561	0	48,914	23,760
39		25,153	561	0	48,914	23,760
40		25,153	561	0	48,914	23,760
41		25,153	561	1,081,445	48,914	1,105,205
42		25,153	561	0	48,914	23,760
43		25,153	561	0	48,914	23,760
44		25,153	561	0	48,914	23,760
45		25,153	561	0	48,914	23,760
46		25,153	561	0	48,914	23,760
47		25,153	561	0	48,914	23,760
48		25,153	561	0	48,914	23,760
49		25,153	561	0	48,914	23,760
50		25,153	561	0	48,914	23,760

## Appendix 12-2-7 (10) Calculation of IRR

### Luembalele

Luembalele						Alternative Diesel						
						kW coat		2,307	US\$kW			
						Plant Factor		20.0%				
						Power value		13,123	US\$kW			
FIRR =		-3.568%				EIRR =		-4.610%				
US\$						US\$						
Year	Cost	O&M	Sold Energy MWh	Benefit	NET	Year	Cost	O&M	Sold Energy MWh	Benefit Construction	Benefit Fuel	NET
1	4,117,000	0	0	0	-4,117,000	1	3,982,946	0	0	656,134	0	-3,326,813
2	0	51,000	409	80,787	29,787	2	0	49,339	409	0	35,694	-13,646
3	0	51,000	409	80,787	29,787	3	0	49,339	409	0	35,694	-13,646
4	0	51,000	409	80,787	29,787	4	0	49,339	409	0	35,694	-13,646
5		51,000	409	80,787	29,787	5		49,339	409	0	35,694	-13,646
6		51,000	409	80,787	29,787	6		49,339	409	0	35,694	-13,646
7		51,000	409	80,787	29,787	7		49,339	409	0	35,694	-13,646
8		51,000	409	80,787	29,787	8		49,339	409	0	35,694	-13,646
9		51,000	409	80,787	29,787	9		49,339	409	0	35,694	-13,646
10		51,000	409	80,787	29,787	10		49,339	409	0	35,694	-13,646
11		51,000	409	80,787	29,787	11		49,339	409	0	35,694	-13,646
12		51,000	409	80,787	29,787	12		49,339	409	0	35,694	-13,646
13		51,000	409	80,787	29,787	13		49,339	409	0	35,694	-13,646
14		51,000	409	80,787	29,787	14		49,339	409	0	35,694	-13,646
15		51,000	409	80,787	29,787	15		49,339	409	0	35,694	-13,646
16		51,000	409	80,787	29,787	16		49,339	409	0	35,694	-13,646
17		51,000	409	80,787	29,787	17		49,339	409	0	35,694	-13,646
18		51,000	409	80,787	29,787	18		49,339	409	0	35,694	-13,646
19		51,000	409	80,787	29,787	19		49,339	409	0	35,694	-13,646
20		51,000	409	80,787	29,787	20		49,339	409	0	35,694	-13,646
21		51,000	409	80,787	29,787	21		49,339	409	656,134	35,694	642,488
22		51,000	409	80,787	29,787	22		49,339	409	0	35,694	-13,646
23		51,000	409	80,787	29,787	23		49,339	409	0	35,694	-13,646
24		51,000	409	80,787	29,787	24		49,339	409	0	35,694	-13,646
25		51,000	409	80,787	29,787	25		49,339	409	0	35,694	-13,646
26		51,000	409	80,787	29,787	26		49,339	409	0	35,694	-13,646
27		51,000	409	80,787	29,787	27		49,339	409	0	35,694	-13,646
28		51,000	409	80,787	29,787	28		49,339	409	0	35,694	-13,646
29		51,000	409	80,787	29,787	29		49,339	409	0	35,694	-13,646
30		51,000	409	80,787	29,787	30		49,339	409	0	35,694	-13,646
31		51,000	409	80,787	29,787	31		49,339	409	0	35,694	-13,646
32		51,000	409	80,787	29,787	32		49,339	409	0	35,694	-13,646
33		51,000	409	80,787	29,787	33		49,339	409	0	35,694	-13,646
34		51,000	409	80,787	29,787	34		49,339	409	0	35,694	-13,646
35		51,000	409	80,787	29,787	35		49,339	409	0	35,694	-13,646
36		51,000	409	80,787	29,787	36		49,339	409	0	35,694	-13,646
37		51,000	409	80,787	29,787	37		49,339	409	0	35,694	-13,646
38		51,000	409	80,787	29,787	38		49,339	409	0	35,694	-13,646
39		51,000	409	80,787	29,787	39		49,339	409	0	35,694	-13,646
40		51,000	409	80,787	29,787	40		49,339	409	0	35,694	-13,646
41		51,000	409	80,787	29,787	41		49,339	409	656,134	35,694	642,488
42		51,000	409	80,787	29,787	42		49,339	409	0	35,694	-13,646
43		51,000	409	80,787	29,787	43		49,339	409	0	35,694	-13,646
44		51,000	409	80,787	29,787	44		49,339	409	0	35,694	-13,646
45		51,000	409	80,787	29,787	45		49,339	409	0	35,694	-13,646
46		51,000	409	80,787	29,787	46		49,339	409	0	35,694	-13,646
47		51,000	409	80,787	29,787	47		49,339	409	0	35,694	-13,646
48		51,000	409	80,787	29,787	48		49,339	409	0	35,694	-13,646
49		51,000	409	80,787	29,787	49		49,339	409	0	35,694	-13,646
50		51,000	409	80,787	29,787	50		49,339	409	0	35,694	-13,646



## Appendix 12-2-7 (11) Calculation of IRR

### Diesel Power Plant

Capacity	5000 kW	Plant factor	38.1%
kW cost	1,534 US\$/kW		
Tariff	0.1881 US\$/kWh	0.9403 SB\$/kWh	
Fuel +O&M	0.0912 US\$/kWh		

Capacity cost	1,531 US\$/kWh		
Willingness to pay	0.1958 US\$/kWh	0.9789 SB\$/kWh	
Fuel +O&M	0.0910 US\$/kWh		

FIRR =					17.01%
Cost	Fuel O&M Cost	Sold Energy MWh	Benefit	Net	
1	7,670,000	0	0	-7,670,000	
2	1,293,852	14,185	2,667,695	1,373,842	
3	1,293,852	14,185	2,667,695	1,373,842	
4	1,293,852	14,185	2,667,695	1,373,842	
5	1,293,852	14,185	2,667,695	1,373,842	
6	1,293,852	14,185	2,667,695	1,373,842	
7	1,293,852	14,185	2,667,695	1,373,842	
8	1,293,852	14,185	2,667,695	1,373,842	
9	1,293,852	14,185	2,667,695	1,373,842	
10	1,293,852	14,185	2,667,695	1,373,842	
11	1,293,852	14,185	2,667,695	1,373,842	
12	1,293,852	14,185	2,667,695	1,373,842	
13	1,293,852	14,185	2,667,695	1,373,842	
14	1,293,852	14,185	2,667,695	1,373,842	
15	1,293,852	14,185	2,667,695	1,373,842	
16	1,293,852	14,185	2,667,695	1,373,842	
17	1,293,852	14,185	2,667,695	1,373,842	
18	1,293,852	14,185	2,667,695	1,373,842	
19	1,293,852	14,185	2,667,695	1,373,842	
20	1,293,852	14,185	2,667,695	1,373,842	

EIRR =					18.67%
	Cost	Fuel O&M Cost	Sold Energy MWh	Benefit	Net
1	7,653,351	0	0	0	-7,653,351
2		1,291,044	14,185	2,777,099	1,486,055
3		1,291,044	14,185	2,777,099	1,486,055
4		1,291,044	14,185	2,777,099	1,486,055
5		1,291,044	14,185	2,777,099	1,486,055
6		1,291,044	14,185	2,777,099	1,486,055
7		1,291,044	14,185	2,777,099	1,486,055
8		1,291,044	14,185	2,777,099	1,486,055
9		1,291,044	14,185	2,777,099	1,486,055
10		1,291,044	14,185	2,777,099	1,486,055
11		1,291,044	14,185	2,777,099	1,486,055
12		1,291,044	14,185	2,777,099	1,486,055
13		1,291,044	14,185	2,777,099	1,486,055
14		1,291,044	14,185	2,777,099	1,486,055
15		1,291,044	14,185	2,777,099	1,486,055
16		1,291,044	14,185	2,777,099	1,486,055
17		1,291,044	14,185	2,777,099	1,486,055
18		1,291,044	14,185	2,777,099	1,486,055
19		1,291,044	14,185	2,777,099	1,486,055
20		1,291,044	14,185	2,777,099	1,486,055