

## Detailed Report for Tank: T-Karnaphuli


Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>			Roughness					
Geometric Summary									
X	858.91 m		Base Elevation		2.00				
Y	861.25 m		Zone		Zone-1				
Connecting Pipes									
P-KarIP1									
P-KarIP2									
Operating Range Summary									
Maximum Elevation	6.00 m		Maximum Level		4.00				
Initial Elevation	4.00 m		Initial Level		2.00				
Minimum Elevation	2.00 m		Minimum Level		0.00				
Storage Summary									
Type	Constant Area								
Cross Section	Non-Circular			Average Area		2,800.0			
Inactive Volume	0.00 m <sup>3</sup>			Total Active Volume		11,200.00			
Total Storage Capacity	11,200.00 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	4.00	2.00	19.56	50.0	5,600.00	N/A	31.83	Draining
1.00 hr	N/A	3.96	1.96	19.17	49.0	5,486.91	N/A	30.82	Draining
2.00 hr	N/A	3.92	1.92	18.79	48.0	5,377.38	N/A	29.85	Draining
3.00 hr	N/A	3.88	1.88	18.42	47.1	5,271.27	N/A	28.91	Draining
4.00 hr	N/A	3.85	1.85	18.06	46.1	5,168.55	N/A	28.00	Draining
5.00 hr	N/A	3.81	1.81	17.71	45.3	5,069.03	N/A	27.12	Draining
6.00 hr	N/A	3.78	1.78	17.37	44.4	4,972.66	N/A	26.26	Draining
7.00 hr	N/A	3.74	1.74	17.05	43.6	4,879.33	N/A	25.43	Draining
8.00 hr	N/A	3.71	1.71	16.73	42.8	4,789.02	N/A	24.63	Draining
9.00 hr	N/A	3.68	1.68	16.42	42.0	4,701.51	N/A	23.85	Draining
10.00 hr	N/A	3.65	1.65	16.13	41.2	4,616.77	N/A	23.10	Draining
11.00 hr	N/A	3.62	1.62	15.84	40.5	4,534.68	N/A	22.37	Draining
12.00 hr	N/A	3.59	1.59	15.56	39.8	4,455.22	N/A	21.66	Draining
13.00 hr	N/A	3.56	1.56	15.30	39.1	4,378.27	N/A	20.97	Draining
14.00 hr	N/A	3.54	1.54	15.04	38.4	4,303.73	N/A	20.31	Draining
15.00 hr	N/A	3.51	1.51	14.78	37.8	4,231.58	N/A	19.67	Draining
16.00 hr	N/A	3.49	1.49	14.54	37.2	4,161.73	N/A	19.04	Draining
17.00 hr	N/A	3.46	1.46	14.30	36.6	4,094.08	N/A	18.44	Draining
18.00 hr	N/A	3.44	1.44	14.07	36.0	4,028.55	N/A	17.86	Draining

## Detailed Report for Tank: T-Karnaphuli

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	3.42	1.42	13.85	35.4	3,965.10	N/A	17.29	Draining
20.00 hr	N/A	3.39	1.39	13.64	34.9	3,903.65	N/A	16.74	Draining
21.00 hr	N/A	3.37	1.37	13.43	34.3	3,844.16	N/A	16.21	Draining
22.00 hr	N/A	3.35	1.35	13.23	33.8	3,786.58	N/A	15.70	Draining
23.00 hr	N/A	3.33	1.33	13.03	33.3	3,730.78	N/A	15.20	Draining
24.00 hr	N/A	3.31	1.31	12.84	32.8	3,676.75	N/A	14.72	Draining
25.00 hr	N/A	3.29	1.29	12.66	32.4	3,624.44	N/A	14.25	Draining
26.00 hr	N/A	3.28	1.28	12.49	31.9	3,573.78	N/A	13.80	Draining
27.00 hr	N/A	3.26	1.26	12.31	31.5	3,524.74	N/A	13.36	Draining
28.00 hr	N/A	3.24	1.24	12.15	31.0	3,477.24	N/A	12.94	Draining
29.00 hr	N/A	3.23	1.23	11.99	30.6	3,431.26	N/A	12.53	Draining
30.00 hr	N/A	3.21	1.21	11.83	30.2	3,386.74	N/A	12.13	Draining
31.00 hr	N/A	3.19	1.19	11.68	29.9	3,343.66	N/A	11.75	Draining
32.00 hr	N/A	3.18	1.18	11.54	29.5	3,301.94	N/A	11.37	Draining
33.00 hr	N/A	3.16	1.16	11.39	29.1	3,261.52	N/A	11.01	Draining
34.00 hr	N/A	3.15	1.15	11.26	28.8	3,222.38	N/A	10.66	Draining
35.00 hr	N/A	3.14	1.14	11.13	28.4	3,184.49	N/A	10.32	Draining
36.00 hr	N/A	3.12	1.12	11.00	28.1	3,147.81	N/A	10.00	Draining
37.00 hr	N/A	3.11	1.11	10.87	27.8	3,112.29	N/A	9.68	Draining
38.00 hr	N/A	3.10	1.10	10.75	27.5	3,077.90	N/A	9.37	Draining
39.00 hr	N/A	3.09	1.09	10.64	27.2	3,044.61	N/A	9.07	Draining
40.00 hr	N/A	3.08	1.08	10.52	26.9	3,012.38	N/A	8.79	Draining
41.00 hr	N/A	3.06	1.06	10.41	26.6	2,981.15	N/A	8.51	Draining
42.00 hr	N/A	3.05	1.05	10.31	26.3	2,950.94	N/A	8.24	Draining
43.00 hr	N/A	3.04	1.04	10.21	26.1	2,921.68	N/A	7.97	Draining
44.00 hr	N/A	3.03	1.03	10.11	25.8	2,893.34	N/A	7.72	Draining
45.00 hr	N/A	3.02	1.02	10.01	25.6	2,865.92	N/A	7.48	Draining
46.00 hr	N/A	3.01	1.01	9.92	25.4	2,839.37	N/A	7.24	Draining
47.00 hr	N/A	3.00	1.00	9.83	25.1	2,813.65	N/A	7.01	Draining
48.00 hr	N/A	3.00	1.00	9.74	24.9	2,788.75	N/A	6.78	Draining
49.00 hr	N/A	2.99	0.99	9.66	24.7	2,764.64	N/A	6.57	Draining
50.00 hr	N/A	2.98	0.98	9.58	24.5	2,741.29	N/A	6.36	Draining
51.00 hr	N/A	2.97	0.97	9.50	24.3	2,718.69	N/A	6.16	Draining
52.00 hr	N/A	2.96	0.96	9.42	24.1	2,696.81	N/A	5.96	Draining
53.00 hr	N/A	2.96	0.96	9.35	23.9	2,675.62	N/A	5.77	Draining
54.00 hr	N/A	2.95	0.95	9.28	23.7	2,655.11	N/A	5.59	Draining
55.00 hr	N/A	2.94	0.94	9.21	23.5	2,635.26	N/A	5.41	Draining
56.00 hr	N/A	2.93	0.93	9.14	23.4	2,616.04	N/A	5.24	Draining
57.00 hr	N/A	2.93	0.93	9.07	23.2	2,597.43	N/A	5.07	Draining
58.00 hr	N/A	2.92	0.92	9.01	23.0	2,579.41	N/A	4.91	Draining
59.00 hr	N/A	2.91	0.91	8.95	22.9	2,561.96	N/A	4.75	Draining
60.00 hr	N/A	2.91	0.91	8.89	22.7	2,545.07	N/A	4.60	Draining
61.00 hr	N/A	2.90	0.90	8.83	22.6	2,528.71	N/A	4.46	Draining
62.00 hr	N/A	2.90	0.90	8.78	22.4	2,512.89	N/A	4.31	Draining
63.00 hr	N/A	2.89	0.89	8.73	22.3	2,497.56	N/A	4.18	Draining
64.00 hr	N/A	2.89	0.89	8.67	22.2	2,482.72	N/A	4.04	Draining
65.00 hr	N/A	2.88	0.88	8.62	22.0	2,468.36	N/A	3.92	Draining
66.00 hr	N/A	2.88	0.88	8.57	21.9	2,454.44	N/A	3.79	Draining
67.00 hr	N/A	2.87	0.87	8.53	21.8	2,440.98	N/A	3.67	Draining
68.00 hr	N/A	2.87	0.87	8.48	21.7	2,427.93	N/A	3.55	Draining
69.00 hr	N/A	2.86	0.86	8.44	21.6	2,415.31	N/A	3.44	Draining
70.00 hr	N/A	2.86	0.86	8.40	21.5	2,403.09	N/A	3.33	Draining
71.00 hr	N/A	2.85	0.85	8.35	21.4	2,391.26	N/A	3.22	Draining
72.00 hr	N/A	2.85	0.85	8.31	21.2	2,379.80	N/A	3.12	Draining

Tank: T-Karnaphuli  
Percent Full varying Time




## Detailed Report for Tank: T-Mad2-gr

Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>			Roughness					
Geometric Summary									
X	796.32 m		Base Elevation		2.00				
Y	835.48 m		Zone		Zone-1				
Connecting Pipes									
P-Mad2IP1									
P-Mad2IP2									
Operating Range Summary									
Maximum Elevation	7.00 m		Maximum Level		5.00				
Initial Elevation	3.50 m		Initial Level		1.50				
Minimum Elevation	2.00 m		Minimum Level		0.00				
Storage Summary									
Type	Constant Area								
Cross Section	Non-Circular		Average Area		2,000.0				
Inactive Volume	0.00 m <sup>3</sup>		Total Active Volume		10,000.00				
Total Storage Capacity	10,000.00 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	3.50	1.50	14.67	30.0	3,000.00	260.11	N/A	Filling
1.00 hr	N/A	3.97	1.97	19.23	39.3	3,932.22	257.30	N/A	Filling
2.00 hr	N/A	4.43	2.43	23.74	48.5	4,854.49	254.59	N/A	Filling
3.00 hr	N/A	4.88	2.88	28.21	57.7	5,767.24	251.98	N/A	Filling
4.00 hr	N/A	5.34	3.34	32.63	66.7	6,670.63	249.46	N/A	Filling
5.00 hr	N/A	5.78	3.78	37.00	75.7	7,565.17	247.02	N/A	Filling
6.00 hr	N/A	6.23	4.23	41.33	84.5	8,451.01	244.66	N/A	Filling
7.00 hr	N/A	6.66	4.66	45.63	93.3	9,328.47	242.37	N/A	Filling
8.00 hr	N/A	6.54	4.54	44.37	90.7	9,071.35	N/A	311.53	Draining
9.00 hr	N/A	5.98	3.98	38.95	79.6	7,963.92	N/A	301.95	Draining
10.00 hr	N/A	5.45	3.45	33.70	68.9	6,890.91	N/A	292.42	Draining
11.00 hr	N/A	4.93	2.93	28.62	58.5	5,851.84	N/A	282.96	Draining
12.00 hr	N/A	4.71	2.71	26.46	54.1	5,410.17	N/A	12.92	Draining
13.00 hr	N/A	4.68	2.68	26.24	53.6	5,364.10	N/A	12.62	Draining
14.00 hr	N/A	4.47	2.47	24.18	49.4	4,944.76	N/A	274.49	Draining
15.00 hr	N/A	4.10	2.10	20.50	41.9	4,191.14	N/A	4.94	Draining
16.00 hr	N/A	4.09	2.09	20.41	41.7	4,173.54	N/A	4.82	Draining
17.00 hr	N/A	4.08	2.08	20.33	41.6	4,156.36	N/A	4.71	Draining
18.00 hr	N/A	3.98	1.98	19.32	39.5	3,951.11	N/A	264.98	Draining

## Detailed Report for Tank: T-Mad2-gr

Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	3.51	1.51	14.73	30.1	3,010.74	N/A	255.74	Draining
20.00 hr	N/A	3.05	1.05	10.29	21.0	2,103.50	N/A	246.59	Draining
21.00 hr	N/A	2.79	0.79	7.73	15.8	1,579.52	13.06	N/A	Filling
22.00 hr	N/A	2.81	0.81	7.95	16.3	1,626.03	12.73	N/A	Filling
23.00 hr	N/A	3.28	1.28	12.54	25.6	2,564.65	261.44	N/A	Filling
24.00 hr	N/A	3.75	1.75	17.13	35.0	3,501.70	258.58	N/A	Filling
25.00 hr	N/A	4.21	2.21	21.66	44.3	4,428.59	255.83	N/A	Filling
26.00 hr	N/A	4.67	2.67	26.15	53.5	5,345.74	253.18	N/A	Filling
27.00 hr	N/A	5.13	3.13	30.59	62.5	6,253.40	250.62	N/A	Filling
28.00 hr	N/A	5.58	3.58	34.98	71.5	7,152.04	248.14	N/A	Filling
29.00 hr	N/A	6.02	4.02	39.33	80.4	8,041.88	245.75	N/A	Filling
30.00 hr	N/A	6.46	4.46	43.64	89.2	8,923.15	243.42	N/A	Filling
31.00 hr	N/A	6.80	4.80	46.91	95.9	9,591.04	N/A	38.56	Draining
32.00 hr	N/A	6.44	4.44	43.47	88.9	8,888.85	N/A	309.97	Draining
33.00 hr	N/A	5.89	3.89	38.08	77.9	7,786.77	N/A	300.39	Draining
34.00 hr	N/A	5.36	3.36	32.86	67.2	6,719.09	N/A	290.87	Draining
35.00 hr	N/A	4.84	2.84	27.81	56.9	5,685.57	N/A	281.42	Draining
36.00 hr	N/A	4.71	2.71	26.56	54.3	5,429.66	N/A	13.04	Draining
37.00 hr	N/A	4.69	2.69	26.33	53.8	5,383.15	N/A	12.74	Draining
38.00 hr	N/A	4.31	2.31	22.64	46.3	4,629.93	N/A	271.50	Draining
39.00 hr	N/A	4.09	2.09	20.42	41.8	4,175.55	N/A	4.83	Draining
40.00 hr	N/A	4.08	2.08	20.34	41.6	4,158.31	N/A	4.72	Draining
41.00 hr	N/A	4.07	2.07	20.26	41.4	4,141.49	N/A	4.61	Draining
42.00 hr	N/A	3.82	1.82	17.77	36.3	3,632.75	N/A	261.88	Draining
43.00 hr	N/A	3.35	1.35	13.22	27.0	2,703.60	N/A	252.67	Draining
44.00 hr	N/A	2.90	0.90	8.84	18.1	1,807.17	N/A	243.54	Draining
45.00 hr	N/A	2.78	0.78	7.66	15.7	1,565.29	13.16	N/A	Filling
46.00 hr	N/A	2.81	0.81	7.89	16.1	1,612.18	12.83	N/A	Filling
47.00 hr	N/A	3.22	1.22	11.94	24.4	2,441.73	261.82	N/A	Filling
48.00 hr	N/A	3.69	1.69	16.53	33.8	3,380.13	258.95	N/A	Filling
49.00 hr	N/A	4.15	2.15	21.07	43.1	4,308.34	256.19	N/A	Filling
50.00 hr	N/A	4.61	2.61	25.56	52.3	5,226.69	253.52	N/A	Filling
51.00 hr	N/A	5.07	3.07	30.01	61.4	6,135.64	250.95	N/A	Filling
52.00 hr	N/A	5.52	3.52	34.41	70.4	7,035.44	248.46	N/A	Filling
53.00 hr	N/A	5.96	3.96	38.77	79.3	7,926.41	246.05	N/A	Filling
54.00 hr	N/A	6.40	4.40	43.08	88.1	8,808.82	243.72	N/A	Filling
55.00 hr	N/A	6.84	4.84	47.36	96.8	9,682.42	N/A	39.09	Draining
56.00 hr	N/A	6.65	4.65	45.47	93.0	9,296.19	N/A	313.45	Draining
57.00 hr	N/A	6.09	4.09	40.02	81.8	8,181.77	N/A	303.85	Draining
58.00 hr	N/A	5.55	3.55	34.73	71.0	7,101.65	N/A	294.31	Draining
59.00 hr	N/A	5.03	3.03	29.62	60.6	6,055.79	N/A	284.84	Draining
60.00 hr	N/A	4.78	2.78	27.22	55.7	5,565.68	N/A	13.92	Draining
61.00 hr	N/A	4.76	2.76	26.98	55.2	5,516.04	N/A	13.60	Draining
62.00 hr	N/A	4.50	2.50	24.42	49.9	4,993.60	N/A	274.95	Draining
63.00 hr	N/A	4.15	2.15	21.06	43.1	4,306.69	N/A	5.71	Draining
64.00 hr	N/A	4.14	2.14	20.96	42.9	4,286.35	N/A	5.57	Draining
65.00 hr	N/A	4.13	2.13	20.87	42.7	4,266.49	N/A	5.44	Draining
66.00 hr	N/A	3.94	1.94	19.02	38.9	3,889.07	N/A	264.38	Draining
67.00 hr	N/A	3.48	1.48	14.43	29.5	2,950.96	N/A	255.14	Draining
68.00 hr	N/A	3.02	1.02	10.01	20.5	2,045.65	N/A	245.99	Draining
69.00 hr	N/A	2.80	0.80	7.79	15.9	1,592.37	12.97	N/A	Filling
70.00 hr	N/A	2.82	0.82	8.01	16.4	1,638.58	12.64	N/A	Filling
71.00 hr	N/A	3.10	1.10	10.72	21.9	2,192.06	262.60	N/A	Filling
72.00 hr	N/A	3.57	1.57	15.32	31.3	3,133.22	259.70	N/A	Filling



## Detailed Report for Tank: T-Mad2-el

### Scenario Summary

Label	Base
Demand Alternative	Base-Average Daily
Physical Alternative	Base-Physical
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Base-Fire Flow

### Calibration Summary

Demand	<none>	Roughness
--------	--------	-----------

### Geometric Summary

X	748.59 m	Base Elevation	5.00
Y	835.06 m	Zone	Zone-1

### Connecting Pipes

P-Mad2IP4  
P-3001

### Operating Range Summary

Maximum Elevation	36.00 m	Maximum Level	31.00
Initial Elevation	33.50 m	Initial Level	28.50
Minimum Elevation	30.00 m	Minimum Level	25.00

### Storage Summary

Type	Constant Area	Cross Section	Circular
Tank Diameter	18.00 m	Average Area	254.5
Inactive Volume	0.00 m <sup>3</sup>	Total Active Volume	1,526.81
Total Storage Capacity	1,526.81 m <sup>3</sup>		


### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	33.50	28.50	278.78	58.3	890.64	N/A	16.83	Draining
1.00 hr	N/A	33.40	28.40	277.78	56.6	864.60	2.86	N/A	Filling
2.00 hr	N/A	33.61	28.61	279.87	60.2	918.77	26.14	N/A	Filling
3.00 hr	N/A	34.12	29.12	284.87	68.7	1,049.00	45.65	N/A	Filling
4.00 hr	N/A	34.91	29.91	292.62	81.9	1,250.62	68.75	N/A	Filling
5.00 hr	N/A	35.62	30.62	299.57	93.7	1,431.37	21.05	N/A	Filling
6.00 hr	N/A	34.98	29.98	293.25	83.0	1,266.91	N/A	200.89	Draining
7.00 hr	N/A	31.93	26.93	263.46	32.2	491.92	N/A	341.63	Draining
8.00 hr	N/A	31.00	26.00	254.29	16.6	253.45	96.35	N/A	Filling
9.00 hr	N/A	32.28	27.28	266.81	37.9	579.07	41.55	N/A	Filling
10.00 hr	N/A	32.82	27.82	272.14	47.0	717.85	41.17	N/A	Filling
11.00 hr	N/A	33.56	28.56	279.36	59.3	905.60	71.29	N/A	Filling
12.00 hr	N/A	32.74	27.74	271.36	45.7	697.47	N/A	128.04	Draining
13.00 hr	N/A	31.19	26.19	256.18	19.8	302.57	N/A	87.69	Draining
14.00 hr	N/A	31.65	26.65	260.72	27.6	420.81	211.13	N/A	Filling
15.00 hr	N/A	33.87	28.87	282.38	64.5	984.27	N/A	35.74	Draining
16.00 hr	N/A	33.21	28.21	275.91	53.4	815.88	N/A	66.98	Draining
17.00 hr	N/A	31.81	26.81	262.26	30.2	460.83	N/A	142.05	Draining
18.00 hr	N/A	30.20	25.20	246.48	3.3	50.30	63.78	N/A	Filling

## Detailed Report for Tank: T-Mad2-el

Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	31.05	26.05	254.78	17.4	266.14	62.54	N/A	Filling
20.00 hr	N/A	32.49	27.49	268.89	41.5	633.16	140.47	N/A	Filling
21.00 hr	N/A	33.98	28.98	283.48	66.3	1,012.77	9.07	N/A	Filling
22.00 hr	N/A	34.98	29.98	293.28	83.0	1,267.83	127.09	N/A	Filling
23.00 hr	N/A	33.78	28.78	281.48	62.9	960.76	N/A	62.50	Draining
24.00 hr	N/A	33.20	28.20	275.81	53.3	813.19	N/A	21.12	Draining
25.00 hr	N/A	33.08	28.08	274.72	51.4	785.02	4.33	N/A	Filling
26.00 hr	N/A	33.32	28.32	276.97	55.3	843.58	27.57	N/A	Filling
27.00 hr	N/A	33.84	28.84	282.15	64.1	978.22	46.51	N/A	Filling
28.00 hr	N/A	34.66	29.66	290.11	77.6	1,185.29	69.58	N/A	Filling
29.00 hr	N/A	35.36	30.36	296.93	89.3	1,362.81	22.33	N/A	Filling
30.00 hr	N/A	34.17	29.17	285.36	69.5	1,061.73	N/A	199.65	Draining
31.00 hr	N/A	31.08	26.08	255.08	18.0	274.13	N/A	60.70	Draining
32.00 hr	N/A	31.52	26.52	259.45	25.4	387.63	94.93	N/A	Filling
33.00 hr	N/A	32.43	27.43	268.36	40.6	619.48	38.58	N/A	Filling
34.00 hr	N/A	32.99	27.99	273.78	49.8	760.45	39.62	N/A	Filling
35.00 hr	N/A	33.78	28.78	281.54	63.0	962.24	69.75	N/A	Filling
36.00 hr	N/A	32.30	27.30	267.05	38.3	585.37	N/A	127.91	Draining
37.00 hr	N/A	30.80	25.80	252.40	13.4	204.27	N/A	87.57	Draining
38.00 hr	N/A	32.62	27.62	270.19	43.7	667.18	208.14	N/A	Filling
39.00 hr	N/A	33.69	28.69	280.60	61.4	937.85	N/A	35.84	Draining
40.00 hr	N/A	32.97	27.97	273.62	49.5	756.23	N/A	67.09	Draining
41.00 hr	N/A	31.49	26.49	259.10	24.8	378.50	N/A	142.15	Draining
42.00 hr	N/A	31.07	26.07	255.02	17.8	272.47	59.71	N/A	Filling
43.00 hr	N/A	31.91	26.91	263.22	31.8	485.73	59.47	N/A	Filling
44.00 hr	N/A	33.31	28.31	276.95	55.2	843.00	137.42	N/A	Filling
45.00 hr	N/A	33.76	28.76	281.35	62.7	957.52	8.97	N/A	Filling
46.00 hr	N/A	34.76	29.76	291.14	79.4	1,212.20	127.00	N/A	Filling
47.00 hr	N/A	33.85	28.85	282.21	64.2	979.75	N/A	62.89	Draining
48.00 hr	N/A	33.26	28.26	276.48	54.4	830.84	N/A	21.49	Draining
49.00 hr	N/A	33.15	28.15	275.34	52.5	801.19	3.97	N/A	Filling
50.00 hr	N/A	33.37	28.37	277.55	56.2	858.54	27.75	N/A	Filling
51.00 hr	N/A	33.90	28.90	282.72	65.0	992.96	46.68	N/A	Filling
52.00 hr	N/A	34.72	29.72	290.76	78.7	1,202.28	69.75	N/A	Filling
53.00 hr	N/A	35.38	30.38	297.19	89.7	1,369.52	22.02	N/A	Filling
54.00 hr	N/A	34.48	29.48	288.39	74.7	1,140.63	N/A	199.95	Draining
55.00 hr	N/A	31.25	26.25	256.77	20.8	318.01	N/A	60.17	Draining
56.00 hr	N/A	30.87	25.87	253.05	14.5	221.18	98.17	N/A	Filling
57.00 hr	N/A	32.16	27.16	265.63	35.9	548.41	42.04	N/A	Filling
58.00 hr	N/A	32.84	27.84	272.31	47.3	722.33	43.06	N/A	Filling
59.00 hr	N/A	33.60	28.60	279.80	60.1	917.09	73.16	N/A	Filling
60.00 hr	N/A	32.87	27.87	272.65	47.9	731.08	N/A	127.04	Draining
61.00 hr	N/A	31.17	26.17	255.97	19.5	297.27	N/A	86.72	Draining
62.00 hr	N/A	31.97	26.97	263.78	32.8	500.30	211.58	N/A	Filling
63.00 hr	N/A	33.83	28.83	282.01	63.8	974.69	N/A	34.97	Draining
64.00 hr	N/A	33.12	28.12	275.07	52.0	794.11	N/A	66.24	Draining
65.00 hr	N/A	31.64	26.64	260.56	27.3	416.67	N/A	141.32	Draining
66.00 hr	N/A	30.88	25.88	253.13	14.6	223.17	64.06	N/A	Filling
67.00 hr	N/A	31.86	26.86	262.71	30.9	472.50	61.94	N/A	Filling
68.00 hr	N/A	33.06	28.06	274.50	51.0	779.19	139.87	N/A	Filling
69.00 hr	N/A	33.83	28.83	282.00	63.8	974.38	9.16	N/A	Filling
70.00 hr	N/A	34.32	29.32	286.76	71.9	1,098.18	127.18	N/A	Filling
71.00 hr	N/A	34.39	29.39	287.49	73.2	1,117.00	N/A	63.66	Draining
72.00 hr	N/A	33.59	28.59	279.64	59.8	912.93	N/A	22.23	Draining






## Detailed Report for Tank: T-Mohara

Scenario Summary											
Label	Base										
Demand Alternative	Base-Average Daily										
Physical Alternative	Base-Physical										
Initial Settings Alternative	Base-Initial Settings										
Operational Alternative	Base-Operational										
Age Alternative	Base-Age Alternative										
Constituent Alternative	Base-Constituent										
Trace Alternative	Base-Trace Alternative										
Fire Flow Alternative	Base-Fire Flow										
Calibration Summary											
Demand	<none>			Roughness							
Geometric Summary											
X	780.69 m			Base Elevation				2.00			
Y	797.98 m			Zone				Zone-1			
Connecting Pipes											
P-MohlP1											
P-MohlP2											
Operating Range Summary											
Maximum Elevation	5.33 m			Maximum Level				3.33			
Initial Elevation	4.00 m			Initial Level				2.00			
Minimum Elevation	2.45 m			Minimum Level				0.45			
Storage Summary											
Type	Constant Area			Cross Section				Circular			
Tank Diameter	3,498.00 m			Average Area				9,610,135.4			
Inactive Volume	0.00 m <sup>3</sup>			Total Active Volume				27,677,188.78			
Total Storage Capacity	27,677,188.78 m <sup>3</sup>										
Calculated Results Summary											
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status		
0.00 hr	N/A	4.00	2.00	19.56	53.8	14,895,709.53	155.85	N/A	Filling		
1.00 hr	N/A	4.00	2.00	19.57	53.8	14,897,720.83	600.00	N/A	Filling		
2.00 hr	N/A	4.00	2.00	19.57	53.8	14,899,947.23	635.90	N/A	Filling		
3.00 hr	N/A	4.00	2.00	19.57	53.8	14,902,290.96	663.72	N/A	Filling		
4.00 hr	N/A	4.00	2.00	19.57	53.9	14,904,735.25	698.72	N/A	Filling		
5.00 hr	N/A	4.00	2.00	19.58	53.9	14,907,129.25	613.47	N/A	Filling		
6.00 hr	N/A	4.00	2.00	19.58	53.9	14,908,919.87	232.06	N/A	Filling		
7.00 hr	N/A	4.00	2.00	19.58	53.9	14,909,662.93	N/A	11.14	Draining		
8.00 hr	N/A	4.00	2.00	19.58	53.9	14,909,567.95	N/A	89.24	Draining		
9.00 hr	N/A	4.00	2.00	19.58	53.9	14,909,241.12	N/A	104.77	Draining		
10.00 hr	N/A	4.00	2.00	19.58	53.9	14,908,864.00	N/A	103.28	Draining		
11.00 hr	N/A	4.00	2.00	19.58	53.9	14,908,503.64	N/A	96.91	Draining		
12.00 hr	N/A	4.00	2.00	19.58	53.9	14,908,174.01	N/A	83.36	Draining		
13.00 hr	N/A	4.00	2.00	19.58	53.9	14,907,886.28	N/A	73.79	Draining		
14.00 hr	N/A	4.00	2.00	19.58	53.9	14,907,634.87	N/A	63.75	Draining		
15.00 hr	N/A	4.00	2.00	19.58	53.9	14,907,422.57	N/A	53.24	Draining		
16.00 hr	N/A	4.00	2.00	19.58	53.9	14,907,215.85	N/A	60.61	Draining		
17.00 hr	N/A	4.00	2.00	19.58	53.9	14,906,972.82	N/A	76.57	Draining		
18.00 hr	N/A	4.00	2.00	19.57	53.9	14,906,676.71	N/A	89.20	Draining		

## Detailed Report for Tank: T-Mohara

Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	4.00	2.00	19.57	53.9	14,906,355.46	N/A	89.25	Draining
20.00 hr	N/A	4.00	2.00	19.57	53.9	14,906,070.53	N/A	70.93	Draining
21.00 hr	N/A	4.00	2.00	19.57	53.9	14,905,897.33	N/A	17.02	Draining
22.00 hr	N/A	4.00	2.00	19.57	53.9	14,906,391.77	395.39	N/A	Filling
23.00 hr	N/A	4.00	2.00	19.58	53.9	14,908,034.34	495.90	N/A	Filling
24.00 hr	N/A	4.00	2.00	19.58	53.9	14,909,945.07	561.41	N/A	Filling
25.00 hr	N/A	4.00	2.00	19.58	53.9	14,912,042.97	600.00	N/A	Filling
26.00 hr	N/A	4.00	2.00	19.58	53.9	14,914,269.37	635.90	N/A	Filling
27.00 hr	N/A	4.00	2.00	19.59	53.9	14,916,610.30	663.72	N/A	Filling
28.00 hr	N/A	4.00	2.00	19.59	53.9	14,919,060.18	698.72	N/A	Filling
29.00 hr	N/A	4.00	2.00	19.59	53.9	14,921,440.22	613.47	N/A	Filling
30.00 hr	N/A	4.00	2.00	19.59	53.9	14,922,996.18	232.06	N/A	Filling
31.00 hr	N/A	4.00	2.00	19.59	53.9	14,923,356.54	N/A	11.14	Draining
32.00 hr	N/A	4.00	2.00	19.59	53.9	14,923,102.33	N/A	89.27	Draining
33.00 hr	N/A	4.00	2.00	19.59	53.9	14,922,755.94	N/A	105.37	Draining
34.00 hr	N/A	4.00	2.00	19.59	53.9	14,922,378.82	N/A	103.84	Draining
35.00 hr	N/A	4.00	2.00	19.59	53.9	14,922,018.46	N/A	97.42	Draining
36.00 hr	N/A	4.00	2.00	19.59	53.9	14,921,694.42	N/A	83.73	Draining
37.00 hr	N/A	4.00	2.00	19.59	53.9	14,921,409.48	N/A	74.05	Draining
38.00 hr	N/A	4.00	2.00	19.59	53.9	14,921,160.87	N/A	63.92	Draining
39.00 hr	N/A	4.00	2.00	19.59	53.9	14,920,948.56	N/A	53.35	Draining
40.00 hr	N/A	4.00	2.00	19.59	53.9	14,920,744.64	N/A	60.83	Draining
41.00 hr	N/A	4.00	2.00	19.59	53.9	14,920,496.02	N/A	76.95	Draining
42.00 hr	N/A	4.00	2.00	19.59	53.9	14,920,199.91	N/A	89.58	Draining
43.00 hr	N/A	4.00	2.00	19.59	53.9	14,919,878.66	N/A	89.57	Draining
44.00 hr	N/A	4.00	2.00	19.59	53.9	14,919,582.56	N/A	71.23	Draining
45.00 hr	N/A	4.00	2.00	19.59	53.9	14,919,414.95	N/A	17.17	Draining
46.00 hr	N/A	4.00	2.00	19.59	53.9	14,919,878.66	395.39	N/A	Filling
47.00 hr	N/A	4.00	2.00	19.59	53.9	14,921,459.77	495.90	N/A	Filling
48.00 hr	N/A	4.00	2.00	19.59	53.9	14,923,367.71	561.41	N/A	Filling
49.00 hr	N/A	4.00	2.00	19.59	53.9	14,925,465.61	600.00	N/A	Filling
50.00 hr	N/A	4.00	2.00	19.60	53.9	14,927,692.01	635.90	N/A	Filling
51.00 hr	N/A	4.00	2.00	19.60	53.9	14,930,035.73	663.72	N/A	Filling
52.00 hr	N/A	4.00	2.00	19.60	54.0	14,932,488.40	698.72	N/A	Filling
53.00 hr	N/A	4.00	2.00	19.60	54.0	14,934,854.48	613.47	N/A	Filling
54.00 hr	N/A	4.00	2.00	19.61	54.0	14,936,530.56	232.06	N/A	Filling
55.00 hr	N/A	4.00	2.00	19.61	54.0	14,937,187.03	N/A	11.14	Draining
56.00 hr	N/A	4.00	2.00	19.61	54.0	14,937,119.98	N/A	89.34	Draining
57.00 hr	N/A	4.00	2.00	19.61	54.0	14,936,790.35	N/A	104.89	Draining
58.00 hr	N/A	4.00	2.00	19.61	54.0	14,936,421.61	N/A	103.23	Draining
59.00 hr	N/A	4.00	2.00	19.60	54.0	14,936,058.46	N/A	96.85	Draining
60.00 hr	N/A	4.00	2.00	19.60	54.0	14,935,723.25	N/A	83.51	Draining
61.00 hr	N/A	4.00	2.00	19.60	54.0	14,935,424.34	N/A	74.27	Draining
62.00 hr	N/A	4.00	2.00	19.60	54.0	14,935,170.14	N/A	64.37	Draining
63.00 hr	N/A	4.00	2.00	19.60	54.0	14,934,946.66	N/A	53.92	Draining
64.00 hr	N/A	4.00	2.00	19.60	54.0	14,934,734.36	N/A	61.50	Draining
65.00 hr	N/A	4.00	2.00	19.60	54.0	14,934,482.94	N/A	77.63	Draining
66.00 hr	N/A	4.00	2.00	19.60	54.0	14,934,198.01	N/A	89.89	Draining
67.00 hr	N/A	4.00	2.00	19.60	54.0	14,933,882.35	N/A	89.65	Draining
68.00 hr	N/A	4.00	2.00	19.60	54.0	14,933,575.06	N/A	71.77	Draining
69.00 hr	N/A	4.00	2.00	19.60	54.0	14,933,362.76	N/A	18.44	Draining
70.00 hr	N/A	4.00	2.00	19.60	54.0	14,933,376.73	66.99	N/A	Filling
71.00 hr	N/A	4.00	2.00	19.60	54.0	14,934,862.86	495.90	N/A	Filling
72.00 hr	N/A	4.00	2.00	19.61	54.0	14,936,681.41	561.41	N/A	Filling

Tank: T-Mohara  
Percent Full varying Time



## Detailed Report for Tank: T-New Mohara

Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>		Roughness						
Geometric Summary									
X	743.61 m	Base Elevation	2.00						
Y	778.27 m	Zone	Zone-1						
Connecting Pipes									
P-NMolP2									
P-NMolP1									
Operating Range Summary									
Maximum Elevation	5.33 m	Maximum Level	3.33						
Initial Elevation	4.50 m	Initial Level	2.50						
Minimum Elevation	2.45 m	Minimum Level	0.45						
Storage Summary									
Type	Constant Area								
Cross Section	Non-Circular	Average Area	1,166.0						
Inactive Volume	0.00 m <sup>3</sup>	Total Active Volume	3,358.08						
Total Storage Capacity	3,358.08 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	4.50	2.50	24.45	71.2	2,390.30	0.86	N/A	Filling
1.00 hr	N/A	4.50	2.50	24.48	71.3	2,393.38	0.84	N/A	Filling
2.00 hr	N/A	4.51	2.51	24.51	71.4	2,396.39	0.82	N/A	Filling
3.00 hr	N/A	4.51	2.51	24.53	71.4	2,399.33	0.81	N/A	Filling
4.00 hr	N/A	4.51	2.51	24.55	71.5	2,402.20	0.79	N/A	Filling
5.00 hr	N/A	4.51	2.51	24.58	71.6	2,405.01	0.77	N/A	Filling
6.00 hr	N/A	4.51	2.51	24.60	71.7	2,407.75	0.75	N/A	Filling
7.00 hr	N/A	4.52	2.52	24.62	71.8	2,410.43	0.73	N/A	Filling
8.00 hr	N/A	4.52	2.52	24.65	71.9	2,413.04	0.72	N/A	Filling
9.00 hr	N/A	4.52	2.52	24.67	71.9	2,415.60	0.70	N/A	Filling
10.00 hr	N/A	4.52	2.52	24.69	72.0	2,418.10	0.68	N/A	Filling
11.00 hr	N/A	4.53	2.53	24.71	72.1	2,420.54	0.67	N/A	Filling
12.00 hr	N/A	4.53	2.53	24.73	72.2	2,422.93	0.65	N/A	Filling
13.00 hr	N/A	4.53	2.53	24.75	72.2	2,425.26	0.64	N/A	Filling
14.00 hr	N/A	4.53	2.53	24.77	72.3	2,427.54	0.62	N/A	Filling
15.00 hr	N/A	4.53	2.53	24.79	72.4	2,429.77	0.61	N/A	Filling
16.00 hr	N/A	4.54	2.54	24.80	72.4	2,431.94	0.60	N/A	Filling
17.00 hr	N/A	4.54	2.54	24.82	72.5	2,434.07	0.58	N/A	Filling
18.00 hr	N/A	4.54	2.54	24.84	72.5	2,436.14	0.57	N/A	Filling

## Detailed Report for Tank: T-New Mohara

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	4.54	2.54	24.86	72.6	2,438.17	0.56	N/A	Filling
20.00 hr	N/A	4.54	2.54	24.87	72.7	2,440.16	0.54	N/A	Filling
21.00 hr	N/A	4.54	2.54	24.89	72.7	2,442.09	0.53	N/A	Filling
22.00 hr	N/A	4.55	2.55	24.91	72.8	2,443.99	0.52	N/A	Filling
23.00 hr	N/A	4.55	2.55	24.92	72.8	2,445.84	0.51	N/A	Filling
24.00 hr	N/A	4.55	2.55	24.94	72.9	2,447.65	0.50	N/A	Filling
25.00 hr	N/A	4.55	2.55	24.95	72.9	2,449.41	0.48	N/A	Filling
26.00 hr	N/A	4.55	2.55	24.97	73.0	2,451.14	0.47	N/A	Filling
27.00 hr	N/A	4.55	2.55	24.98	73.0	2,452.83	0.46	N/A	Filling
28.00 hr	N/A	4.56	2.56	24.99	73.1	2,454.47	0.45	N/A	Filling
29.00 hr	N/A	4.56	2.56	25.01	73.1	2,456.08	0.44	N/A	Filling
30.00 hr	N/A	4.56	2.56	25.02	73.2	2,457.66	0.43	N/A	Filling
31.00 hr	N/A	4.56	2.56	25.03	73.2	2,459.20	0.42	N/A	Filling
32.00 hr	N/A	4.56	2.56	25.05	73.3	2,460.70	0.41	N/A	Filling
33.00 hr	N/A	4.56	2.56	25.06	73.3	2,462.16	0.40	N/A	Filling
34.00 hr	N/A	4.56	2.56	25.07	73.4	2,463.60	0.39	N/A	Filling
35.00 hr	N/A	4.56	2.56	25.08	73.4	2,465.00	0.38	N/A	Filling
36.00 hr	N/A	4.57	2.57	25.09	73.4	2,466.37	0.38	N/A	Filling
37.00 hr	N/A	4.57	2.57	25.10	73.5	2,467.71	0.37	N/A	Filling
38.00 hr	N/A	4.57	2.57	25.12	73.5	2,469.02	0.36	N/A	Filling
39.00 hr	N/A	4.57	2.57	25.13	73.6	2,470.29	0.35	N/A	Filling
40.00 hr	N/A	4.57	2.57	25.14	73.6	2,471.54	0.34	N/A	Filling
41.00 hr	N/A	4.57	2.57	25.15	73.6	2,472.76	0.33	N/A	Filling
42.00 hr	N/A	4.57	2.57	25.16	73.7	2,473.95	0.33	N/A	Filling
43.00 hr	N/A	4.57	2.57	25.17	73.7	2,475.12	0.32	N/A	Filling
44.00 hr	N/A	4.57	2.57	25.18	73.7	2,476.26	0.31	N/A	Filling
45.00 hr	N/A	4.57	2.57	25.19	73.8	2,477.37	0.30	N/A	Filling
46.00 hr	N/A	4.58	2.58	25.19	73.8	2,478.45	0.30	N/A	Filling
47.00 hr	N/A	4.58	2.58	25.20	73.8	2,479.52	0.29	N/A	Filling
48.00 hr	N/A	4.58	2.58	25.21	73.9	2,480.55	0.28	N/A	Filling
49.00 hr	N/A	4.58	2.58	25.22	73.9	2,481.57	0.28	N/A	Filling
50.00 hr	N/A	4.58	2.58	25.23	73.9	2,482.56	0.27	N/A	Filling
51.00 hr	N/A	4.58	2.58	25.24	74.0	2,483.53	0.27	N/A	Filling
52.00 hr	N/A	4.58	2.58	25.24	74.0	2,484.47	0.26	N/A	Filling
53.00 hr	N/A	4.58	2.58	25.25	74.0	2,485.39	0.25	N/A	Filling
54.00 hr	N/A	4.58	2.58	25.26	74.0	2,486.30	0.25	N/A	Filling
55.00 hr	N/A	4.58	2.58	25.27	74.1	2,487.18	0.24	N/A	Filling
56.00 hr	N/A	4.58	2.58	25.27	74.1	2,488.04	0.24	N/A	Filling
57.00 hr	N/A	4.58	2.58	25.28	74.1	2,488.89	0.23	N/A	Filling
58.00 hr	N/A	4.59	2.59	25.29	74.1	2,489.71	0.23	N/A	Filling
59.00 hr	N/A	4.59	2.59	25.30	74.2	2,490.51	0.22	N/A	Filling
60.00 hr	N/A	4.59	2.59	25.30	74.2	2,491.30	0.22	N/A	Filling
61.00 hr	N/A	4.59	2.59	25.31	74.2	2,492.07	0.21	N/A	Filling
62.00 hr	N/A	4.59	2.59	25.31	74.2	2,492.82	0.21	N/A	Filling
63.00 hr	N/A	4.59	2.59	25.32	74.3	2,493.55	0.20	N/A	Filling
64.00 hr	N/A	4.59	2.59	25.33	74.3	2,494.27	0.20	N/A	Filling
65.00 hr	N/A	4.59	2.59	25.33	74.3	2,494.97	0.19	N/A	Filling
66.00 hr	N/A	4.59	2.59	25.34	74.3	2,495.65	0.19	N/A	Filling
67.00 hr	N/A	4.59	2.59	25.34	74.3	2,496.32	0.18	N/A	Filling
68.00 hr	N/A	4.59	2.59	25.35	74.4	2,496.97	0.18	N/A	Filling
69.00 hr	N/A	4.59	2.59	25.35	74.4	2,497.61	0.17	N/A	Filling
70.00 hr	N/A	4.59	2.59	25.36	74.4	2,498.23	0.17	N/A	Filling
71.00 hr	N/A	4.59	2.59	25.37	74.4	2,498.84	0.17	N/A	Filling
72.00 hr	N/A	4.59	2.59	25.37	74.4	2,499.44	0.16	N/A	Filling



## Detailed Report for Tank: T-Fatehabad

Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>	Roughness							
Geometric Summary									
X	314.56 m	Base Elevation	12.00						
Y	902.24 m	Zone	Zone-1						
Connecting Pipes									
P-FatIP1									
P-FatIP2									
Operating Range Summary									
Maximum Elevation	17.00 m	Maximum Level	5.00						
Initial Elevation	13.50 m	Initial Level	1.50						
Minimum Elevation	12.00 m	Minimum Level	0.00						
Storage Summary									
Type	Constant Area								
Cross Section	Non-Circular	Average Area	2,000.0						
Inactive Volume	0.00 m <sup>3</sup>	Total Active Volume	10,000.00						
Total Storage Capacity	10,000.00 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	13.50	1.50	14.67	30.0	3,000.00	260.08	N/A	Filling
1.00 hr	N/A	13.97	1.97	19.23	39.3	3,932.13	257.27	N/A	Filling
2.00 hr	N/A	14.43	2.43	23.74	48.5	4,854.31	254.57	N/A	Filling
3.00 hr	N/A	14.88	2.88	28.21	57.7	5,766.97	251.96	N/A	Filling
4.00 hr	N/A	15.34	3.34	32.62	66.7	6,670.28	249.44	N/A	Filling
5.00 hr	N/A	15.78	3.78	37.00	75.6	7,564.73	247.00	N/A	Filling
6.00 hr	N/A	16.23	4.23	41.33	84.5	8,450.49	244.64	N/A	Filling
7.00 hr	N/A	16.66	4.66	45.62	93.3	9,327.87	242.35	N/A	Filling
8.00 hr	N/A	16.57	4.57	44.67	91.3	9,133.66	N/A	315.23	Draining
9.00 hr	N/A	16.01	4.01	39.19	80.1	8,011.92	N/A	306.32	Draining
10.00 hr	N/A	15.46	3.46	33.86	69.2	6,922.26	N/A	297.41	Draining
11.00 hr	N/A	14.93	2.93	28.68	58.6	5,864.37	N/A	288.53	Draining
12.00 hr	N/A	14.56	2.56	25.01	51.1	5,113.81	N/A	16.21	Draining
13.00 hr	N/A	14.53	2.53	24.73	50.6	5,055.94	N/A	15.88	Draining
14.00 hr	N/A	14.50	2.50	24.45	50.0	4,999.26	N/A	15.55	Draining
15.00 hr	N/A	14.47	2.47	24.18	49.4	4,943.77	N/A	15.23	Draining
16.00 hr	N/A	14.40	2.40	23.46	48.0	4,795.82	N/A	279.30	Draining
17.00 hr	N/A	13.90	1.90	18.60	38.0	3,803.65	N/A	270.48	Draining
18.00 hr	N/A	13.47	1.47	14.39	29.4	2,941.71	N/A	3.29	Draining




## Detailed Report for Tank: T-Fatehabad

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	13.46	1.46	14.33	29.3	2,929.96	N/A	3.22	Draining
20.00 hr	N/A	13.16	1.16	11.38	23.3	2,326.70	N/A	256.86	Draining
21.00 hr	N/A	12.73	0.73	7.12	14.6	1,455.49	6.03	N/A	Filling
22.00 hr	N/A	12.83	0.83	8.10	16.6	1,655.17	264.27	N/A	Filling
23.00 hr	N/A	13.30	1.30	12.73	26.0	2,602.20	261.30	N/A	Filling
24.00 hr	N/A	13.77	1.77	17.31	35.4	3,538.75	258.45	N/A	Filling
25.00 hr	N/A	14.23	2.23	21.84	44.7	4,465.15	255.70	N/A	Filling
26.00 hr	N/A	14.69	2.69	26.32	53.8	5,381.83	253.05	N/A	Filling
27.00 hr	N/A	15.14	3.14	30.76	62.9	6,289.03	250.49	N/A	Filling
28.00 hr	N/A	15.59	3.59	35.15	71.9	7,187.23	248.02	N/A	Filling
29.00 hr	N/A	16.04	4.04	39.50	80.8	8,076.63	245.63	N/A	Filling
30.00 hr	N/A	16.48	4.48	43.81	89.6	8,957.49	243.31	N/A	Filling
31.00 hr	N/A	16.77	4.77	46.70	95.5	9,548.73	N/A	40.36	Draining
32.00 hr	N/A	16.48	4.48	43.84	89.6	8,964.39	N/A	313.90	Draining
33.00 hr	N/A	15.92	3.92	38.38	78.5	7,847.19	N/A	304.98	Draining
34.00 hr	N/A	15.38	3.38	33.07	67.6	6,762.07	N/A	296.08	Draining
35.00 hr	N/A	14.85	2.85	27.92	57.1	5,708.96	N/A	287.20	Draining
36.00 hr	N/A	14.56	2.56	25.01	51.1	5,113.62	N/A	16.21	Draining
37.00 hr	N/A	14.53	2.53	24.73	50.6	5,055.76	N/A	15.88	Draining
38.00 hr	N/A	14.50	2.50	24.45	50.0	4,999.09	N/A	15.55	Draining
39.00 hr	N/A	14.47	2.47	24.18	49.4	4,943.60	N/A	15.23	Draining
40.00 hr	N/A	14.21	2.21	21.67	44.3	4,429.71	N/A	276.07	Draining
41.00 hr	N/A	13.72	1.72	16.87	34.5	3,448.56	N/A	267.26	Draining
42.00 hr	N/A	13.66	1.66	16.22	33.2	3,315.79	N/A	5.58	Draining
43.00 hr	N/A	13.50	1.50	14.69	30.0	3,004.10	N/A	263.18	Draining
44.00 hr	N/A	13.03	1.03	10.12	20.7	2,069.26	N/A	254.43	Draining
45.00 hr	N/A	12.70	0.70	6.80	13.9	1,390.50	6.45	N/A	Filling
46.00 hr	N/A	12.82	0.82	8.03	16.4	1,641.10	264.31	N/A	Filling
47.00 hr	N/A	13.29	1.29	12.66	25.9	2,588.22	261.34	N/A	Filling
48.00 hr	N/A	13.76	1.76	17.24	35.2	3,524.91	258.49	N/A	Filling
49.00 hr	N/A	14.23	2.23	21.77	44.5	4,451.49	255.74	N/A	Filling
50.00 hr	N/A	14.68	2.68	26.26	53.7	5,368.27	253.09	N/A	Filling
51.00 hr	N/A	15.14	3.14	30.69	62.8	6,275.68	250.53	N/A	Filling
52.00 hr	N/A	15.59	3.59	35.09	71.7	7,174.01	248.06	N/A	Filling
53.00 hr	N/A	16.03	4.03	39.44	80.6	8,063.55	245.66	N/A	Filling
54.00 hr	N/A	16.47	4.47	43.75	89.4	8,944.57	243.34	N/A	Filling
55.00 hr	N/A	16.84	4.84	47.31	96.7	9,673.21	N/A	41.00	Draining
56.00 hr	N/A	16.68	4.68	45.74	93.5	9,352.22	N/A	316.94	Draining
57.00 hr	N/A	16.11	4.11	40.22	82.2	8,224.23	N/A	308.02	Draining
58.00 hr	N/A	15.56	3.56	34.86	71.3	7,128.18	N/A	299.11	Draining
59.00 hr	N/A	15.03	3.03	29.66	60.6	6,064.17	N/A	290.23	Draining
60.00 hr	N/A	14.67	2.67	26.12	53.4	5,340.46	N/A	17.51	Draining
61.00 hr	N/A	14.64	2.64	25.81	52.8	5,277.92	N/A	17.15	Draining
62.00 hr	N/A	14.61	2.61	25.51	52.2	5,216.70	N/A	16.80	Draining
63.00 hr	N/A	14.58	2.58	25.22	51.6	5,156.72	N/A	16.46	Draining
64.00 hr	N/A	14.20	2.20	21.56	44.1	4,407.44	N/A	275.87	Draining
65.00 hr	N/A	13.86	1.86	18.20	37.2	3,721.22	N/A	8.02	Draining
66.00 hr	N/A	13.85	1.85	18.06	36.9	3,692.59	N/A	7.85	Draining
67.00 hr	N/A	13.60	1.60	15.68	32.1	3,206.06	N/A	265.04	Draining
68.00 hr	N/A	13.13	1.13	11.08	22.6	2,264.55	N/A	256.28	Draining
69.00 hr	N/A	12.73	0.73	7.10	14.5	1,451.06	6.06	N/A	Filling
70.00 hr	N/A	12.74	0.74	7.20	14.7	1,472.68	5.92	N/A	Filling
71.00 hr	N/A	13.15	1.15	11.22	23.0	2,295.05	262.25	N/A	Filling
72.00 hr	N/A	13.62	1.62	15.82	32.3	3,234.97	259.36	N/A	Filling

Tank: T-Fatehabad  
Percent Full varying Time




## Detailed Report for Tank: T-Fat-el

Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>	Roughness							
Geometric Summary									
X	371.45 m	Base Elevation	15.00						
Y	902.27 m	Zone	Zone-1						
Connecting Pipes									
P-FatIP4									
P-1029									
P-3032									
Operating Range Summary									
Maximum Elevation	46.00 m	Maximum Level	31.00						
Initial Elevation	43.50 m	Initial Level	28.50						
Minimum Elevation	40.00 m	Minimum Level	25.00						
Storage Summary									
Type	Constant Area	Cross Section	Circular						
Tank Diameter	18.00 m	Average Area	254.5						
Inactive Volume	0.00 m <sup>3</sup>	Total Active Volume	1,526.81						
Total Storage Capacity	1,526.81 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	43.50	28.50	278.78	58.3	890.64	N/A	16.73	Draining
1.00 hr	N/A	43.40	28.40	277.80	56.7	864.97	2.96	N/A	Filling
2.00 hr	N/A	43.61	28.61	279.89	60.2	919.49	26.24	N/A	Filling
3.00 hr	N/A	44.13	29.13	284.91	68.8	1,050.05	45.74	N/A	Filling
4.00 hr	N/A	44.92	29.92	292.67	82.0	1,251.97	68.84	N/A	Filling
5.00 hr	N/A	45.63	30.63	299.63	93.9	1,433.04	21.15	N/A	Filling
6.00 hr	N/A	44.99	29.99	293.33	83.1	1,269.00	N/A	200.73	Draining
7.00 hr	N/A	41.94	26.94	263.56	32.4	494.60	N/A	341.43	Draining
8.00 hr	N/A	40.76	25.76	252.03	12.7	194.58	100.14	N/A	Filling
9.00 hr	N/A	42.10	27.10	265.12	35.1	535.18	46.05	N/A	Filling
10.00 hr	N/A	42.72	27.72	271.12	45.3	691.33	46.38	N/A	Filling
11.00 hr	N/A	43.53	28.53	279.09	58.9	898.68	77.07	N/A	Filling
12.00 hr	N/A	43.93	28.93	283.02	65.6	1,000.83	N/A	124.55	Draining
13.00 hr	N/A	42.43	27.43	268.32	40.5	618.39	N/A	84.26	Draining
14.00 hr	N/A	41.47	26.47	258.88	24.4	372.93	N/A	47.65	Draining
15.00 hr	N/A	40.94	25.94	253.71	15.6	238.27	N/A	25.29	Draining
16.00 hr	N/A	40.79	25.79	252.27	13.2	201.03	208.52	N/A	Filling
17.00 hr	N/A	43.23	28.23	276.17	53.9	822.71	123.91	N/A	Filling

## Detailed Report for Tank: T-Fat-el

Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
18.00 hr	N/A	44.20	29.20	285.66	70.0	1,069.42	N/A	198.67	Draining
19.00 hr	N/A	41.40	26.40	258.25	23.4	356.54	N/A	189.78	Draining
20.00 hr	N/A	41.65	26.65	260.70	27.5	420.32	150.93	N/A	Filling
21.00 hr	N/A	44.51	29.51	288.67	75.2	1,147.70	16.24	N/A	Filling
22.00 hr	N/A	44.91	29.91	292.60	81.9	1,250.05	N/A	124.33	Draining
23.00 hr	N/A	43.67	28.67	280.49	61.2	934.92	N/A	62.27	Draining
24.00 hr	N/A	43.10	28.10	274.84	51.6	788.17	N/A	20.90	Draining
25.00 hr	N/A	42.99	27.99	273.79	49.8	760.77	4.53	N/A	Filling
26.00 hr	N/A	43.22	28.22	276.07	53.7	820.06	27.76	N/A	Filling
27.00 hr	N/A	43.75	28.75	281.27	62.6	955.39	46.70	N/A	Filling
28.00 hr	N/A	44.57	29.57	289.26	76.2	1,163.13	69.76	N/A	Filling
29.00 hr	N/A	45.27	30.27	296.11	87.9	1,341.31	22.52	N/A	Filling
30.00 hr	N/A	44.09	29.09	284.56	68.2	1,041.02	N/A	199.40	Draining
31.00 hr	N/A	41.30	26.30	257.27	21.7	330.90	N/A	58.72	Draining
32.00 hr	N/A	41.28	26.28	257.12	21.4	326.96	98.94	N/A	Filling
33.00 hr	N/A	42.26	27.26	266.63	37.6	574.52	43.40	N/A	Filling
34.00 hr	N/A	42.88	27.88	272.75	48.1	733.64	45.05	N/A	Filling
35.00 hr	N/A	43.76	28.76	281.29	62.6	955.72	75.74	N/A	Filling
36.00 hr	N/A	43.61	28.61	279.87	60.2	918.99	N/A	124.55	Draining
37.00 hr	N/A	42.16	27.16	265.69	36.0	549.90	N/A	84.26	Draining
38.00 hr	N/A	41.24	26.24	256.67	20.6	315.27	N/A	47.65	Draining
39.00 hr	N/A	40.74	25.74	251.76	12.3	187.66	N/A	25.28	Draining
40.00 hr	N/A	41.98	26.98	263.95	33.1	504.72	204.43	N/A	Filling
41.00 hr	N/A	44.30	29.30	286.57	71.6	1,093.23	120.69	N/A	Filling
42.00 hr	N/A	42.40	27.40	268.01	40.0	610.37	N/A	196.39	Draining
43.00 hr	N/A	40.81	25.81	252.46	13.5	205.79	70.19	N/A	Filling
44.00 hr	N/A	42.37	27.37	267.69	39.4	602.09	148.49	N/A	Filling
45.00 hr	N/A	44.54	29.54	288.91	75.6	1,154.07	15.82	N/A	Filling
46.00 hr	N/A	44.74	29.74	290.88	78.9	1,205.41	N/A	124.38	Draining
47.00 hr	N/A	43.36	28.36	277.44	56.0	855.76	N/A	62.31	Draining
48.00 hr	N/A	42.79	27.79	271.80	46.4	708.86	N/A	20.94	Draining
49.00 hr	N/A	42.68	27.68	270.73	44.6	681.14	4.49	N/A	Filling
50.00 hr	N/A	42.91	27.91	273.01	48.5	740.33	28.25	N/A	Filling
51.00 hr	N/A	43.44	28.44	278.24	57.4	876.52	47.16	N/A	Filling
52.00 hr	N/A	44.27	29.27	286.35	71.2	1,087.54	70.22	N/A	Filling
53.00 hr	N/A	44.94	29.94	292.85	82.3	1,256.45	22.49	N/A	Filling
54.00 hr	N/A	44.04	29.04	284.11	67.4	1,029.30	N/A	199.44	Draining
55.00 hr	N/A	41.39	26.39	258.10	23.1	352.66	N/A	58.08	Draining
56.00 hr	N/A	40.75	25.75	251.91	12.6	191.64	101.75	N/A	Filling
57.00 hr	N/A	42.09	27.09	265.04	34.9	533.03	46.43	N/A	Filling
58.00 hr	N/A	42.84	27.84	272.36	47.4	723.58	48.08	N/A	Filling
59.00 hr	N/A	43.68	28.68	280.57	61.4	937.18	78.76	N/A	Filling
60.00 hr	N/A	43.87	28.87	282.43	64.5	985.51	N/A	123.25	Draining
61.00 hr	N/A	42.22	27.22	266.28	37.0	565.27	N/A	82.98	Draining
62.00 hr	N/A	41.21	26.21	256.36	20.1	307.20	N/A	46.40	Draining
63.00 hr	N/A	40.61	25.61	250.51	10.2	155.25	N/A	24.06	Draining
64.00 hr	N/A	42.77	27.77	271.68	46.2	705.73	204.23	N/A	Filling
65.00 hr	N/A	43.91	28.91	282.83	65.2	995.86	N/A	138.55	Draining
66.00 hr	N/A	41.78	26.78	262.00	29.7	453.90	N/A	194.08	Draining
67.00 hr	N/A	40.99	25.99	254.20	16.5	251.21	72.05	N/A	Filling
68.00 hr	N/A	42.34	27.34	267.41	39.0	594.81	150.34	N/A	Filling
69.00 hr	N/A	44.52	29.52	288.80	75.4	1,151.22	16.21	N/A	Filling
70.00 hr	N/A	45.11	30.11	294.52	85.2	1,300.09	134.01	N/A	Filling
71.00 hr	N/A	44.13	29.13	284.92	68.8	1,050.40	N/A	63.22	Draining
72.00 hr	N/A	43.33	28.33	277.14	55.5	847.88	N/A	21.82	Draining



## Detailed Report for Tank: T-Nas-gr

Scenario Summary										
Label	Base									
Demand Alternative	Base-Average Daily									
Physical Alternative	Base-Physical									
Initial Settings Alternative	Base-Initial Settings									
Operational Alternative	Base-Operational									
Age Alternative	Base-Age Alternative									
Constituent Alternative	Base-Constituent									
Trace Alternative	Base-Trace Alternative									
Fire Flow Alternative	Base-Fire Flow									
Calibration Summary										
Demand	<none>			Roughness						
Geometric Summary										
X	275.26 m			Base Elevation				23.00		
Y	582.30 m			Zone				Zone-1		
Connecting Pipes										
P-989										
P-991										
P-992										
P-993										
Operating Range Summary										
Maximum Elevation	28.00 m			Maximum Level				5.00		
Initial Elevation	24.50 m			Initial Level				1.50		
Minimum Elevation	23.00 m			Minimum Level				0.00		
Storage Summary										
Type	Constant Area									
Cross Section	Non-Circular			Average Area				5,500.0		
Inactive Volume	0.00 m <sup>3</sup>			Total Active Volume				27,500.00		
Total Storage Capacity	27,500.00 m <sup>3</sup>									
Calculated Results Summary										
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status	
0.00 hr	N/A	24.50	1.50	14.67	30.0	8,250.00	703.15	N/A	Filling	
1.00 hr	N/A	24.95	1.95	19.10	39.1	10,739.04	674.80	N/A	Filling	
2.00 hr	N/A	25.39	2.39	23.35	47.7	13,129.02	648.42	N/A	Filling	
3.00 hr	N/A	25.80	2.80	27.44	56.1	15,426.56	623.28	N/A	Filling	
4.00 hr	N/A	26.21	3.21	31.36	64.1	17,635.37	599.75	N/A	Filling	
5.00 hr	N/A	26.59	3.59	35.15	71.9	19,762.11	577.52	N/A	Filling	
6.00 hr	N/A	27.00	4.00	39.12	80.0	21,997.96	799.30	N/A	Filling	
7.00 hr	N/A	27.52	4.52	44.18	90.3	24,838.05	773.61	N/A	Filling	
8.00 hr	N/A	27.46	4.46	43.62	89.2	24,524.25	N/A	541.44	Draining	
9.00 hr	N/A	27.11	4.11	40.24	82.3	22,627.55	N/A	505.78	Draining	
10.00 hr	N/A	26.66	3.66	35.79	73.2	20,122.02	N/A	700.30	Draining	
11.00 hr	N/A	26.21	3.21	31.44	64.3	17,675.08	N/A	649.30	Draining	
12.00 hr	N/A	25.80	2.80	27.41	56.0	15,410.19	N/A	600.82	Draining	
13.00 hr	N/A	25.69	2.69	26.30	53.8	14,786.09	9.77	N/A	Filling	
14.00 hr	N/A	25.69	2.69	26.36	53.9	14,819.58	8.56	N/A	Filling	
15.00 hr	N/A	25.70	2.70	26.41	54.0	14,848.74	7.44	N/A	Filling	
16.00 hr	N/A	25.37	2.37	23.17	47.4	13,025.50	N/A	550.13	Draining	

## Detailed Report for Tank: T-Nas-gr


### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
17.00 hr	N/A	25.07	2.07	20.25	41.4	11,383.66	63.85	N/A	Filling
18.00 hr	N/A	25.11	2.11	20.64	42.2	11,606.97	59.54	N/A	Filling
19.00 hr	N/A	24.84	1.84	17.97	36.7	10,102.86	N/A	484.42	Draining
20.00 hr	N/A	24.53	1.53	14.97	30.6	8,417.61	N/A	444.80	Draining
21.00 hr	N/A	24.25	1.25	12.22	25.0	6,871.94	N/A	407.63	Draining
22.00 hr	N/A	24.22	1.22	11.96	24.5	6,725.95	142.63	N/A	Filling
23.00 hr	N/A	24.60	1.60	15.69	32.1	8,823.37	680.16	N/A	Filling
24.00 hr	N/A	25.04	2.04	19.98	40.8	11,232.89	653.36	N/A	Filling
25.00 hr	N/A	25.46	2.46	24.10	49.3	13,548.21	628.22	N/A	Filling
26.00 hr	N/A	25.87	2.87	28.06	57.4	15,775.41	604.65	N/A	Filling
27.00 hr	N/A	26.26	3.26	31.87	65.2	17,918.78	582.33	N/A	Filling
28.00 hr	N/A	26.63	3.63	35.54	72.7	19,984.24	561.21	N/A	Filling
29.00 hr	N/A	27.00	4.00	39.08	79.9	21,975.28	541.12	N/A	Filling
30.00 hr	N/A	27.34	4.34	42.50	86.9	23,895.37	522.11	N/A	Filling
31.00 hr	N/A	27.46	4.46	43.65	89.3	24,545.11	N/A	150.72	Draining
32.00 hr	N/A	27.09	4.09	39.99	81.8	22,483.45	N/A	760.64	Draining
33.00 hr	N/A	26.60	3.60	35.26	72.1	19,824.30	N/A	706.17	Draining
34.00 hr	N/A	26.16	3.16	30.87	63.1	17,357.74	N/A	654.19	Draining
35.00 hr	N/A	25.74	2.74	26.81	54.8	15,074.62	N/A	604.75	Draining
36.00 hr	N/A	25.36	2.36	23.06	47.2	12,967.42	N/A	557.92	Draining
37.00 hr	N/A	25.12	2.12	20.70	42.3	11,638.65	50.76	N/A	Filling
38.00 hr	N/A	25.15	2.15	21.02	43.0	11,816.49	47.45	N/A	Filling
39.00 hr	N/A	25.18	2.18	21.31	43.6	11,982.68	44.35	N/A	Filling
40.00 hr	N/A	24.99	1.99	19.46	39.8	10,943.67	N/A	512.62	Draining
41.00 hr	N/A	24.67	1.67	16.29	33.3	9,159.17	N/A	470.83	Draining
42.00 hr	N/A	24.37	1.37	13.38	27.4	7,524.04	N/A	431.62	Draining
43.00 hr	N/A	24.10	1.10	10.72	21.9	6,025.24	N/A	394.84	Draining
44.00 hr	N/A	23.85	0.85	8.28	16.9	4,654.06	N/A	360.45	Draining
45.00 hr	N/A	23.69	0.69	6.70	13.7	3,769.95	188.96	N/A	Filling
46.00 hr	N/A	23.81	0.81	7.88	16.1	4,431.12	176.31	N/A	Filling
47.00 hr	N/A	24.06	1.06	10.39	21.2	5,839.42	705.57	N/A	Filling
48.00 hr	N/A	24.52	1.52	14.83	30.3	8,337.93	677.13	N/A	Filling
49.00 hr	N/A	24.95	1.95	19.10	39.0	10,736.86	650.57	N/A	Filling
50.00 hr	N/A	25.37	2.37	23.20	47.4	13,042.20	625.67	N/A	Filling
51.00 hr	N/A	25.77	2.77	27.14	55.5	15,260.51	602.24	N/A	Filling
52.00 hr	N/A	26.16	3.16	30.94	63.3	17,396.41	580.14	N/A	Filling
53.00 hr	N/A	26.54	3.54	34.60	70.7	19,454.52	559.24	N/A	Filling
54.00 hr	N/A	26.90	3.90	38.13	78.0	21,438.97	539.43	N/A	Filling
55.00 hr	N/A	27.11	4.11	40.25	82.3	22,630.56	N/A	128.53	Draining
56.00 hr	N/A	26.85	3.85	37.67	77.0	21,181.04	N/A	740.12	Draining
57.00 hr	N/A	26.38	3.38	33.07	67.6	18,595.81	N/A	686.22	Draining
58.00 hr	N/A	25.95	2.95	28.81	58.9	16,200.10	N/A	634.87	Draining
59.00 hr	N/A	25.54	2.54	24.87	50.9	13,985.53	N/A	586.10	Draining
60.00 hr	N/A	25.17	2.17	21.25	43.4	11,945.61	N/A	539.98	Draining
61.00 hr	N/A	24.83	1.83	17.90	36.6	10,065.23	N/A	496.37	Draining
62.00 hr	N/A	24.67	1.67	16.29	33.3	9,161.10	88.00	N/A	Filling
63.00 hr	N/A	24.72	1.72	16.84	34.4	9,469.65	82.48	N/A	Filling
64.00 hr	N/A	24.77	1.77	17.36	35.5	9,758.89	77.32	N/A	Filling
65.00 hr	N/A	24.52	1.52	14.89	30.4	8,373.73	N/A	456.57	Draining
66.00 hr	N/A	24.23	1.23	12.07	24.7	6,786.88	N/A	417.94	Draining
67.00 hr	N/A	23.97	0.97	9.49	19.4	5,336.26	N/A	381.83	Draining
68.00 hr	N/A	23.73	0.73	7.13	14.6	4,010.95	N/A	348.10	Draining
69.00 hr	N/A	23.51	0.51	4.99	10.2	2,805.60	N/A	316.78	Draining
70.00 hr	N/A	23.36	0.36	3.53	7.2	1,983.07	219.02	N/A	Filling
71.00 hr	N/A	23.60	0.60	5.87	12.0	3,301.49	731.35	N/A	Filling

## Detailed Report for Tank: T-Nas-gr

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
72.00 hr	N/A	24.07	1.07	10.48	21.4	5,890.13	701.10	N/A	Filling






## Detailed Report for Tank: T-Nas-el

Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>				Roughness				
Geometric Summary									
X	335.79 m			Base Elevation		20.00			
Y	581.42 m			Zone		Zone-1			
Connecting Pipes									
P-NasIP3									
P-3045									
Operating Range Summary									
Maximum Elevation	53.00 m			Maximum Level		33.00			
Initial Elevation	51.00 m			Initial Level		31.00			
Minimum Elevation	45.00 m			Minimum Level		25.00			
Storage Summary									
Type	Constant Area			Cross Section		Circular			
Tank Diameter	24.00 m			Average Area		452.4			
Inactive Volume	0.00 m <sup>3</sup>			Total Active Volume		3,619.11			
Total Storage Capacity	3,619.11 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	51.00	31.00	303.24	75.0	2,714.34	N/A	100.40	Draining
1.00 hr	N/A	50.42	30.42	297.53	67.7	2,450.13	N/A	43.68	Draining
2.00 hr	N/A	50.33	30.33	296.65	66.6	2,409.69	19.08	N/A	Filling
3.00 hr	N/A	50.70	30.70	300.33	71.3	2,579.82	75.09	N/A	Filling
4.00 hr	N/A	51.52	31.52	308.31	81.5	2,949.09	137.45	N/A	Filling
5.00 hr	N/A	52.28	32.28	315.73	91.0	3,292.02	28.64	N/A	Filling
6.00 hr	N/A	51.24	31.24	305.62	78.0	2,824.54	N/A	499.40	Draining
7.00 hr	N/A	47.02	27.02	264.35	25.3	915.92	N/A	828.86	Draining
8.00 hr	N/A	46.55	26.55	259.73	19.4	702.12	210.29	N/A	Filling
9.00 hr	N/A	48.08	28.08	274.68	38.5	1,393.51	70.96	N/A	Filling
10.00 hr	N/A	48.53	28.53	279.10	44.1	1,597.77	51.43	N/A	Filling
11.00 hr	N/A	49.09	29.09	284.58	51.2	1,851.52	105.80	N/A	Filling
12.00 hr	N/A	50.41	30.41	297.51	67.7	2,449.53	236.99	N/A	Filling
13.00 hr	N/A	49.26	29.26	286.25	53.3	1,928.89	N/A	274.36	Draining
14.00 hr	N/A	47.39	27.39	267.95	29.9	1,082.20	N/A	184.98	Draining
15.00 hr	N/A	46.12	26.12	255.50	14.0	506.75	N/A	129.97	Draining
16.00 hr	N/A	49.00	29.00	283.66	50.0	1,808.98	364.45	N/A	Filling
17.00 hr	N/A	50.55	30.55	298.86	69.4	2,511.99	N/A	427.56	Draining
18.00 hr	N/A	46.69	26.69	261.11	21.2	765.90	N/A	558.54	Draining

## Detailed Report for Tank: T-Nas-el

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	46.09	26.09	255.16	13.6	490.98	14.18	N/A	Filling
20.00 hr	N/A	46.92	26.92	263.32	24.0	868.24	191.40	N/A	Filling
21.00 hr	N/A	49.61	29.61	289.64	57.6	2,085.22	469.62	N/A	Filling
22.00 hr	N/A	51.61	31.61	309.22	82.6	2,990.83	202.36	N/A	Filling
23.00 hr	N/A	50.37	30.37	297.07	67.1	2,429.22	N/A	203.42	Draining
24.00 hr	N/A	49.19	29.19	285.52	52.4	1,894.72	N/A	95.24	Draining
25.00 hr	N/A	48.71	28.71	280.81	46.3	1,677.28	N/A	26.35	Draining
26.00 hr	N/A	48.75	28.75	281.20	46.8	1,694.99	35.15	N/A	Filling
27.00 hr	N/A	49.24	29.24	286.04	53.0	1,918.94	87.07	N/A	Filling
28.00 hr	N/A	50.17	30.17	295.12	64.6	2,338.74	148.37	N/A	Filling
29.00 hr	N/A	50.98	30.98	303.08	74.8	2,706.90	40.73	N/A	Filling
30.00 hr	N/A	49.29	29.29	286.52	53.6	1,940.93	N/A	489.31	Draining
31.00 hr	N/A	46.63	26.63	260.44	20.3	735.19	N/A	163.51	Draining
32.00 hr	N/A	47.47	27.47	268.75	30.9	1,119.49	181.21	N/A	Filling
33.00 hr	N/A	48.25	28.25	276.30	40.6	1,468.29	21.09	N/A	Filling
34.00 hr	N/A	48.37	28.37	277.51	42.1	1,524.66	5.05	N/A	Filling
35.00 hr	N/A	48.68	28.68	280.50	45.9	1,662.91	60.75	N/A	Filling
36.00 hr	N/A	49.73	29.73	290.86	59.2	2,141.86	193.33	N/A	Filling
37.00 hr	N/A	50.22	30.22	295.61	65.2	2,361.46	N/A	312.52	Draining
38.00 hr	N/A	48.11	28.11	274.95	38.8	1,405.94	N/A	221.33	Draining
39.00 hr	N/A	46.59	26.59	260.09	19.9	718.92	N/A	164.66	Draining
40.00 hr	N/A	47.67	27.67	270.69	33.4	1,209.05	322.45	N/A	Filling
41.00 hr	N/A	49.42	29.42	287.74	55.2	1,997.51	107.94	N/A	Filling
42.00 hr	N/A	49.71	29.71	290.60	58.8	2,129.74	N/A	57.58	Draining
43.00 hr	N/A	49.22	29.22	285.80	52.7	1,907.97	N/A	66.16	Draining
44.00 hr	N/A	49.43	29.43	287.92	55.4	2,005.86	115.22	N/A	Filling
45.00 hr	N/A	50.81	30.81	301.38	72.6	2,628.51	N/A	122.07	Draining
46.00 hr	N/A	51.05	31.05	303.74	75.6	2,737.41	170.77	N/A	Filling
47.00 hr	N/A	51.18	31.18	305.01	77.3	2,796.08	N/A	223.35	Draining
48.00 hr	N/A	49.84	29.84	291.94	60.6	2,191.76	N/A	113.79	Draining
49.00 hr	N/A	49.22	29.22	285.82	52.7	1,908.66	N/A	43.70	Draining
50.00 hr	N/A	49.12	29.12	284.89	51.5	1,865.60	21.43	N/A	Filling
51.00 hr	N/A	49.50	29.50	288.56	56.2	2,035.30	74.12	N/A	Filling
52.00 hr	N/A	50.33	30.33	296.66	66.6	2,409.97	136.09	N/A	Filling
53.00 hr	N/A	50.98	30.98	303.05	74.8	2,705.56	26.93	N/A	Filling
54.00 hr	N/A	49.57	29.57	289.25	57.1	2,067.24	N/A	502.43	Draining
55.00 hr	N/A	46.64	26.64	260.61	20.5	742.95	N/A	183.71	Draining
56.00 hr	N/A	46.71	26.71	261.23	21.3	771.72	158.98	N/A	Filling
57.00 hr	N/A	47.75	27.75	271.45	34.4	1,244.42	0.61	N/A	Filling
58.00 hr	N/A	47.82	27.82	272.16	35.3	1,277.13	N/A	14.89	Draining
59.00 hr	N/A	47.87	27.87	272.61	35.9	1,297.65	41.38	N/A	Filling
60.00 hr	N/A	48.54	28.54	279.15	44.2	1,600.28	174.59	N/A	Filling
61.00 hr	N/A	49.95	29.95	292.98	61.9	2,240.12	237.19	N/A	Filling
62.00 hr	N/A	50.13	30.13	294.70	64.1	2,319.27	N/A	254.92	Draining
63.00 hr	N/A	48.19	28.19	275.79	39.9	1,444.75	N/A	196.28	Draining
64.00 hr	N/A	46.35	26.35	257.78	16.9	611.88	N/A	267.57	Draining
65.00 hr	N/A	47.19	27.19	265.94	27.3	989.36	92.66	N/A	Filling
66.00 hr	N/A	47.59	27.59	269.91	32.4	1,173.13	N/A	66.20	Draining
67.00 hr	N/A	47.13	27.13	265.40	26.6	964.21	N/A	80.32	Draining
68.00 hr	N/A	46.92	26.92	263.31	24.0	867.95	101.66	N/A	Filling
69.00 hr	N/A	48.30	28.30	276.86	41.3	1,494.19	384.70	N/A	Filling
70.00 hr	N/A	51.16	31.16	304.79	77.0	2,785.93	135.50	N/A	Filling
71.00 hr	N/A	51.42	31.42	307.31	80.2	2,902.74	N/A	241.18	Draining
72.00 hr	N/A	49.67	29.67	290.20	58.3	2,111.50	N/A	130.20	Draining



## Detailed Report for Tank: T-Salimpur


Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>				Roughness				
Geometric Summary									
X	26.41 m			Base Elevation			47.00		
Y	622.70 m			Zone			Zone-1		
Connecting Pipes									
P-SalPSV									
P-3114									
Operating Range Summary									
Maximum Elevation	55.00 m			Maximum Level			8.00		
Initial Elevation	50.00 m			Initial Level			3.00		
Minimum Elevation	47.00 m			Minimum Level			0.00		
Storage Summary									
Type	Constant Area								
Cross Section	Non-Circular			Average Area			1,400.0		
Inactive Volume	0.00 m <sup>3</sup>			Total Active Volume			11,200.00		
Total Storage Capacity	11,200.00 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	50.00	3.00	29.35	37.5	4,200.00	279.50	N/A	Filling
1.00 hr	N/A	50.75	3.75	36.67	46.9	5,247.87	303.45	N/A	Filling
2.00 hr	N/A	51.57	4.57	44.66	57.1	6,392.25	331.14	N/A	Filling
3.00 hr	N/A	52.45	5.45	53.30	68.1	7,627.94	354.87	N/A	Filling
4.00 hr	N/A	53.39	6.39	62.53	79.9	8,949.63	382.39	N/A	Filling
5.00 hr	N/A	54.32	7.32	71.62	91.5	10,251.05	328.63	N/A	Filling
6.00 hr	N/A	54.84	7.84	76.66	98.0	10,972.35	N/A	169.37	Draining
7.00 hr	N/A	54.36	7.36	71.99	92.0	10,302.77	N/A	331.08	Draining
8.00 hr	N/A	53.39	6.39	62.55	79.9	8,952.53	N/A	465.99	Draining
9.00 hr	N/A	52.19	5.19	50.79	64.9	7,269.47	N/A	519.04	Draining
10.00 hr	N/A	51.40	4.40	43.03	55.0	6,158.82	N/A	266.25	Draining
11.00 hr	N/A	50.75	3.75	36.72	46.9	5,255.07	N/A	225.15	Draining
12.00 hr	N/A	50.26	3.26	31.91	40.8	4,567.71	N/A	148.07	Draining
13.00 hr	N/A	49.93	2.93	28.70	36.7	4,107.69	N/A	102.58	Draining
14.00 hr	N/A	49.72	2.72	26.59	34.0	3,805.35	N/A	60.16	Draining
15.00 hr	N/A	49.59	2.59	25.37	32.4	3,631.67	N/A	34.09	Draining
16.00 hr	N/A	49.47	2.47	24.17	30.9	3,459.57	N/A	72.71	Draining
17.00 hr	N/A	49.19	2.19	21.39	27.3	3,061.26	N/A	161.98	Draining
18.00 hr	N/A	48.70	1.70	16.62	21.2	2,378.26	N/A	225.16	Draining

## Detailed Report for Tank: T-Salimpur

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	48.12	1.12	10.95	14.0	1,567.58	N/A	217.58	Draining
20.00 hr	N/A	47.68	0.68	6.69	8.5	957.56	N/A	120.83	Draining
21.00 hr	N/A	47.56	0.56	5.52	7.1	789.72	23.36	N/A	Filling
22.00 hr	N/A	47.80	0.80	7.87	10.1	1,126.41	158.05	N/A	Filling
23.00 hr	N/A	48.32	1.32	12.90	16.5	1,846.76	229.73	N/A	Filling
24.00 hr	N/A	48.97	1.97	19.31	24.7	2,764.09	278.32	N/A	Filling
25.00 hr	N/A	49.73	2.73	26.71	34.1	3,822.33	308.54	N/A	Filling
26.00 hr	N/A	50.56	3.56	34.82	44.5	4,983.60	335.95	N/A	Filling
27.00 hr	N/A	51.45	4.45	43.57	55.7	6,235.30	358.54	N/A	Filling
28.00 hr	N/A	52.41	5.41	52.91	67.6	7,573.02	385.80	N/A	Filling
29.00 hr	N/A	53.34	6.34	62.04	79.3	8,879.56	332.47	N/A	Filling
30.00 hr	N/A	53.89	6.89	67.35	86.1	9,639.88	78.56	N/A	Filling
31.00 hr	N/A	53.86	6.86	67.13	85.8	9,608.39	N/A	84.34	Draining
32.00 hr	N/A	53.45	6.45	63.13	80.7	9,035.00	N/A	221.87	Draining
33.00 hr	N/A	52.80	5.80	56.75	72.5	8,122.01	N/A	278.87	Draining
34.00 hr	N/A	52.09	5.09	49.81	63.7	7,128.93	N/A	271.10	Draining
35.00 hr	N/A	51.45	4.45	43.53	55.6	6,229.56	N/A	229.76	Draining
36.00 hr	N/A	50.96	3.96	38.75	49.5	5,545.44	N/A	152.45	Draining
37.00 hr	N/A	50.63	3.63	35.52	45.4	5,083.05	N/A	108.26	Draining
38.00 hr	N/A	50.41	3.41	33.35	42.6	4,773.05	N/A	65.57	Draining
39.00 hr	N/A	50.28	3.28	32.06	41.0	4,588.32	N/A	39.26	Draining
40.00 hr	N/A	50.13	3.13	30.65	39.2	4,386.17	N/A	76.85	Draining
41.00 hr	N/A	49.82	2.82	27.59	35.3	3,949.22	N/A	166.06	Draining
42.00 hr	N/A	49.32	2.32	22.68	29.0	3,246.29	N/A	232.63	Draining
43.00 hr	N/A	48.73	1.73	16.88	21.6	2,416.61	N/A	225.14	Draining
44.00 hr	N/A	48.27	1.27	12.44	15.9	1,780.49	N/A	127.86	Draining
45.00 hr	N/A	48.15	1.15	11.24	14.4	1,608.61	17.53	N/A	Filling
46.00 hr	N/A	48.38	1.38	13.47	17.2	1,928.02	153.74	N/A	Filling
47.00 hr	N/A	48.85	1.85	18.10	23.1	2,591.02	224.17	N/A	Filling
48.00 hr	N/A	49.49	2.49	24.38	31.1	3,488.68	273.01	N/A	Filling
49.00 hr	N/A	50.23	3.23	31.64	40.4	4,527.84	303.44	N/A	Filling
50.00 hr	N/A	51.05	4.05	39.62	50.6	5,671.11	331.84	N/A	Filling
51.00 hr	N/A	51.93	4.93	48.26	61.7	6,906.67	354.58	N/A	Filling
52.00 hr	N/A	52.88	5.88	57.52	73.5	8,231.70	381.97	N/A	Filling
53.00 hr	N/A	53.79	6.79	66.46	84.9	9,511.75	328.09	N/A	Filling
54.00 hr	N/A	54.39	7.39	72.25	92.3	10,340.53	74.34	N/A	Filling
55.00 hr	N/A	54.49	7.49	73.30	93.7	10,490.55	N/A	87.62	Draining
56.00 hr	N/A	54.16	7.16	70.07	89.5	10,028.63	N/A	224.26	Draining
57.00 hr	N/A	53.57	6.57	64.30	82.2	9,202.93	N/A	281.02	Draining
58.00 hr	N/A	52.88	5.88	57.47	73.4	8,225.78	N/A	273.15	Draining
59.00 hr	N/A	52.21	5.21	50.98	65.2	7,296.93	N/A	231.71	Draining
60.00 hr	N/A	51.68	4.68	45.81	58.5	6,555.95	N/A	154.30	Draining
61.00 hr	N/A	51.30	4.30	42.09	53.8	6,023.40	N/A	111.13	Draining
62.00 hr	N/A	51.05	4.05	39.59	50.6	5,666.36	N/A	70.43	Draining
63.00 hr	N/A	50.88	3.88	37.95	48.5	5,431.48	N/A	43.84	Draining
64.00 hr	N/A	50.72	3.72	36.42	46.5	5,211.86	N/A	79.02	Draining
65.00 hr	N/A	50.40	3.40	33.30	42.5	4,765.43	N/A	167.51	Draining
66.00 hr	N/A	49.93	2.93	28.71	36.7	4,108.80	N/A	233.43	Draining
67.00 hr	N/A	49.36	2.36	23.10	29.5	3,305.47	N/A	226.43	Draining
68.00 hr	N/A	48.86	1.86	18.15	23.2	2,597.76	N/A	129.08	Draining
69.00 hr	N/A	48.62	1.62	15.87	20.3	2,271.82	15.69	N/A	Filling
70.00 hr	N/A	48.73	1.73	16.97	21.7	2,428.76	149.08	N/A	Filling
71.00 hr	N/A	49.18	2.18	21.29	27.2	3,047.14	219.38	N/A	Filling
72.00 hr	N/A	49.76	2.76	27.03	34.5	3,867.98	268.45	N/A	Filling

Tank: T-Salimpur  
Percent Full varying Time




## Detailed Report for Tank: T-Khulshi-gr

Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>				Roughness				
Geometric Summary									
X	342.47 m			Base Elevation				28.00	
Y	360.07 m			Zone				Zone-1	
Connecting Pipes									
P-PSVKhu1									
P-KhulP1									
Operating Range Summary									
Maximum Elevation	35.00 m			Maximum Level				7.00	
Initial Elevation	29.60 m			Initial Level				1.60	
Minimum Elevation	28.00 m			Minimum Level				0.00	
Storage Summary									
Type	Constant Area								
Cross Section	Non-Circular			Average Area				2,800.0	
Inactive Volume	540.00 m <sup>3</sup>			Total Active Volume				19,600.00	
Total Storage Capacity	20,140.00 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	29.60	1.60	15.65	24.9	5,020.00	440.85	N/A	Filling
1.00 hr	N/A	30.18	2.18	21.31	33.0	6,640.68	458.72	N/A	Filling
2.00 hr	N/A	31.03	3.03	29.59	44.7	9,010.68	705.12	N/A	Filling
3.00 hr	N/A	31.95	3.95	38.61	57.6	11,593.22	728.28	N/A	Filling
4.00 hr	N/A	32.63	4.63	45.31	67.1	13,509.24	519.24	N/A	Filling
5.00 hr	N/A	33.26	5.26	51.47	75.8	15,271.68	443.36	N/A	Filling
6.00 hr	N/A	33.71	5.71	55.82	82.0	16,517.17	122.75	N/A	Filling
7.00 hr	N/A	33.84	5.84	57.08	83.8	16,878.73	N/A	80.48	Draining
8.00 hr	N/A	33.66	5.66	55.39	81.4	16,394.33	N/A	245.60	Draining
9.00 hr	N/A	33.30	5.30	51.85	76.4	15,381.16	N/A	546.73	Draining
10.00 hr	N/A	32.61	4.61	45.06	66.7	13,439.32	N/A	520.77	Draining
11.00 hr	N/A	31.97	3.97	38.83	57.9	11,655.25	N/A	454.24	Draining
12.00 hr	N/A	31.45	3.45	33.72	50.6	10,192.54	N/A	345.24	Draining
13.00 hr	N/A	31.04	3.04	29.75	45.0	9,054.68	N/A	280.53	Draining
14.00 hr	N/A	30.71	2.71	26.54	40.4	8,136.32	N/A	222.27	Draining
15.00 hr	N/A	30.70	2.70	26.38	40.2	8,090.34	28.62	N/A	Filling
16.00 hr	N/A	30.71	2.71	26.54	40.4	8,137.04	N/A	15.56	Draining
17.00 hr	N/A	30.50	2.50	24.48	37.5	7,547.57	N/A	336.19	Draining
18.00 hr	N/A	30.03	2.03	19.86	30.9	6,226.19	N/A	405.45	Draining

## Detailed Report for Tank: T-Khulshi-gr

Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	29.52	1.52	14.83	23.8	4,785.24	N/A	382.42	Draining
20.00 hr	N/A	29.11	1.11	10.83	18.1	3,641.38	N/A	250.75	Draining
21.00 hr	N/A	28.91	0.91	8.88	15.3	3,080.92	N/A	65.11	Draining
22.00 hr	N/A	28.97	0.97	9.50	16.2	3,258.71	301.21	N/A	Filling
23.00 hr	N/A	29.42	1.42	13.90	22.4	4,518.30	380.06	N/A	Filling
24.00 hr	N/A	29.94	1.94	19.02	29.7	5,983.34	429.27	N/A	Filling
25.00 hr	N/A	30.63	2.63	25.73	39.3	7,905.02	675.61	N/A	Filling
26.00 hr	N/A	31.52	3.52	34.42	51.6	10,393.11	705.47	N/A	Filling
27.00 hr	N/A	32.28	4.28	41.86	62.2	12,522.79	493.33	N/A	Filling
28.00 hr	N/A	32.93	4.93	48.21	71.2	14,340.68	517.19	N/A	Filling
29.00 hr	N/A	33.55	5.55	54.31	79.9	16,085.69	441.45	N/A	Filling
30.00 hr	N/A	34.23	6.23	60.95	89.3	17,986.37	369.61	N/A	Filling
31.00 hr	N/A	34.32	6.32	61.83	90.6	18,239.19	N/A	83.76	Draining
32.00 hr	N/A	33.80	5.80	56.73	83.3	16,777.76	N/A	490.64	Draining
33.00 hr	N/A	33.13	5.13	50.15	74.0	14,895.94	N/A	543.71	Draining
34.00 hr	N/A	32.44	4.44	43.44	64.4	12,974.85	N/A	517.78	Draining
35.00 hr	N/A	31.82	3.82	37.34	55.7	11,227.20	N/A	451.36	Draining
36.00 hr	N/A	31.31	3.31	32.35	48.7	9,798.71	N/A	342.48	Draining
37.00 hr	N/A	31.00	3.00	29.38	44.4	8,950.37	N/A	58.29	Draining
38.00 hr	N/A	30.96	2.96	28.99	43.9	8,839.03	N/A	5.68	Draining
39.00 hr	N/A	30.97	2.97	29.08	44.0	8,864.42	N/A	194.69	Draining
40.00 hr	N/A	30.70	2.70	26.40	40.2	8,096.59	N/A	233.67	Draining
41.00 hr	N/A	30.33	2.33	22.82	35.1	7,072.25	N/A	332.72	Draining
42.00 hr	N/A	29.87	1.87	18.25	28.6	5,762.89	N/A	401.93	Draining
43.00 hr	N/A	29.36	1.36	13.29	21.6	4,345.14	N/A	378.93	Draining
44.00 hr	N/A	28.95	0.95	9.34	16.0	3,213.47	N/A	247.23	Draining
45.00 hr	N/A	28.81	0.81	7.92	13.9	2,806.56	136.75	N/A	Filling
46.00 hr	N/A	29.10	1.10	10.72	17.9	3,608.68	300.09	N/A	Filling
47.00 hr	N/A	29.53	1.53	14.94	23.9	4,815.96	379.18	N/A	Filling
48.00 hr	N/A	30.05	2.05	20.05	31.2	6,277.87	428.45	N/A	Filling
49.00 hr	N/A	30.62	2.62	25.62	39.1	7,874.80	455.10	N/A	Filling
50.00 hr	N/A	31.35	3.35	32.72	49.2	9,906.03	705.68	N/A	Filling
51.00 hr	N/A	32.27	4.27	41.75	62.0	12,490.54	728.82	N/A	Filling
52.00 hr	N/A	33.10	5.10	49.90	73.6	14,822.75	516.03	N/A	Filling
53.00 hr	N/A	33.72	5.72	55.93	82.2	16,550.28	440.37	N/A	Filling
54.00 hr	N/A	34.12	6.12	59.91	87.8	17,689.97	120.12	N/A	Filling
55.00 hr	N/A	34.22	6.22	60.89	89.2	17,969.58	N/A	82.88	Draining
56.00 hr	N/A	34.06	6.06	59.23	86.9	17,494.25	N/A	248.06	Draining
57.00 hr	N/A	33.60	5.60	54.77	80.5	16,218.06	N/A	550.84	Draining
58.00 hr	N/A	32.91	4.91	48.07	71.0	14,299.71	N/A	525.25	Draining
59.00 hr	N/A	32.27	4.27	41.78	62.1	12,497.86	N/A	458.83	Draining
60.00 hr	N/A	31.73	3.73	36.48	54.5	10,982.03	N/A	349.70	Draining
61.00 hr	N/A	31.30	3.30	32.24	48.5	9,768.58	N/A	284.67	Draining
62.00 hr	N/A	31.00	3.00	29.31	44.3	8,930.11	N/A	5.82	Draining
63.00 hr	N/A	31.00	3.00	29.32	44.3	8,931.37	26.27	N/A	Filling
64.00 hr	N/A	31.00	3.00	29.38	44.4	8,948.64	N/A	17.82	Draining
65.00 hr	N/A	30.71	2.71	26.53	40.4	8,135.36	N/A	339.73	Draining
66.00 hr	N/A	30.26	2.26	22.09	34.1	6,862.99	N/A	409.49	Draining
67.00 hr	N/A	29.76	1.76	17.17	27.1	5,455.71	N/A	386.91	Draining
68.00 hr	N/A	29.31	1.31	12.84	20.9	4,213.94	N/A	254.70	Draining
69.00 hr	N/A	29.05	1.05	10.28	17.3	3,482.63	N/A	67.85	Draining
70.00 hr	N/A	29.05	1.05	10.25	17.2	3,473.73	300.73	N/A	Filling
71.00 hr	N/A	29.47	1.47	14.35	23.1	4,648.07	379.92	N/A	Filling
72.00 hr	N/A	29.96	1.96	19.21	30.0	6,038.41	429.41	N/A	Filling






## Detailed Report for Tank: T-Khulshi-el

Scenario Summary									
Label	Base								
Demand Alternative	Base-Average Daily								
Physical Alternative	Base-Physical								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Calibration Summary									
Demand	<none>			Roughness					
Geometric Summary									
X	381.62 m			Base Elevation				29.00	
Y	360.14 m			Zone				Zone-1	
Connecting Pipes									
P-KhulP4									
P-2031									
Operating Range Summary									
Maximum Elevation	52.00 m			Maximum Level				23.00	
Initial Elevation	51.00 m			Initial Level				22.00	
Minimum Elevation	45.00 m			Minimum Level				16.00	
Storage Summary									
Type	Constant Area			Cross Section				Circular	
Tank Diameter	18.00 m			Average Area				254.5	
Inactive Volume	0.00 m <sup>3</sup>			Total Active Volume				1,781.28	
Total Storage Capacity	1,781.28 m <sup>3</sup>								
Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	51.00	22.00	215.20	85.7	1,526.81	46.93	N/A	Filling
1.00 hr	N/A	51.77	22.77	222.70	96.7	1,721.84	62.46	N/A	Filling
2.00 hr	N/A	50.14	21.14	206.80	73.5	1,308.39	N/A	141.84	Draining
3.00 hr	N/A	48.21	19.21	187.87	45.8	815.83	N/A	132.36	Draining
4.00 hr	N/A	49.37	20.37	199.26	62.4	1,112.06	117.74	N/A	Filling
5.00 hr	N/A	50.90	21.90	214.27	84.4	1,502.63	93.68	N/A	Filling
6.00 hr	N/A	51.70	22.70	222.04	95.7	1,704.75	N/A	32.85	Draining
7.00 hr	N/A	51.12	22.12	216.36	87.4	1,556.98	N/A	114.75	Draining
8.00 hr	N/A	49.18	20.18	197.36	59.7	1,062.70	N/A	183.80	Draining
9.00 hr	N/A	47.08	18.08	176.88	29.8	529.96	29.48	N/A	Filling
10.00 hr	N/A	47.43	18.43	180.28	34.7	618.33	22.59	N/A	Filling
11.00 hr	N/A	47.81	18.81	184.00	40.1	715.02	34.99	N/A	Filling
12.00 hr	N/A	48.51	19.51	190.85	50.1	893.24	66.98	N/A	Filling
13.00 hr	N/A	49.57	20.57	201.19	65.3	1,162.35	83.30	N/A	Filling
14.00 hr	N/A	50.85	21.85	213.70	83.5	1,487.74	98.71	N/A	Filling
15.00 hr	N/A	49.57	20.57	201.23	65.3	1,163.37	N/A	106.93	Draining
16.00 hr	N/A	47.97	18.97	185.57	42.4	755.89	N/A	124.80	Draining
17.00 hr	N/A	47.42	18.42	180.18	34.6	615.75	46.43	N/A	Filling
18.00 hr	N/A	47.83	18.83	184.16	40.4	719.33	6.30	N/A	Filling

## Detailed Report for Tank: T-Khulshi-el

Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
19.00 hr	N/A	47.85	18.85	184.39	40.7	725.34	0.10	N/A	Filling
20.00 hr	N/A	48.15	19.15	187.35	45.0	802.19	42.04	N/A	Filling
21.00 hr	N/A	49.26	20.26	198.15	60.8	1,083.24	112.08	N/A	Filling
22.00 hr	N/A	50.96	21.96	214.82	85.2	1,516.98	N/A	19.59	Draining
23.00 hr	N/A	51.00	22.00	215.21	85.7	1,526.95	19.41	N/A	Filling
24.00 hr	N/A	51.47	22.47	219.79	92.4	1,646.24	47.02	N/A	Filling
25.00 hr	N/A	51.00	22.00	215.19	85.7	1,526.63	N/A	154.06	Draining
26.00 hr	N/A	48.91	19.91	194.75	55.9	994.90	N/A	141.84	Draining
27.00 hr	N/A	48.75	19.75	193.21	53.6	954.70	101.87	N/A	Filling
28.00 hr	N/A	50.31	21.31	208.46	75.9	1,351.54	119.05	N/A	Filling
29.00 hr	N/A	51.86	22.86	223.58	98.0	1,744.86	95.92	N/A	Filling
30.00 hr	N/A	48.98	19.98	195.42	56.8	1,012.11	N/A	279.39	Draining
31.00 hr	N/A	47.09	18.09	176.96	29.9	532.04	N/A	111.15	Draining
32.00 hr	N/A	48.28	19.28	188.62	46.9	835.22	63.00	N/A	Filling
33.00 hr	N/A	48.89	19.89	194.58	55.6	990.33	24.77	N/A	Filling
34.00 hr	N/A	49.22	20.22	197.78	60.3	1,073.58	19.89	N/A	Filling
35.00 hr	N/A	49.61	20.61	201.59	65.8	1,172.71	32.39	N/A	Filling
36.00 hr	N/A	50.31	21.31	208.47	75.9	1,351.66	64.50	N/A	Filling
37.00 hr	N/A	50.34	21.34	208.73	76.3	1,358.42	N/A	138.66	Draining
38.00 hr	N/A	48.53	19.53	191.05	50.4	898.62	N/A	117.62	Draining
39.00 hr	N/A	47.04	18.04	176.44	29.1	518.38	116.95	N/A	Filling
40.00 hr	N/A	48.54	19.54	191.17	50.6	901.70	93.55	N/A	Filling
41.00 hr	N/A	49.53	20.53	200.78	64.6	1,151.53	43.21	N/A	Filling
42.00 hr	N/A	49.89	20.89	204.35	69.9	1,244.58	1.96	N/A	Filling
43.00 hr	N/A	49.89	20.89	204.35	69.9	1,244.41	N/A	3.15	Draining
44.00 hr	N/A	50.15	21.15	206.90	73.6	1,310.77	38.76	N/A	Filling
45.00 hr	N/A	50.80	21.80	213.20	82.8	1,474.87	N/A	89.54	Draining
46.00 hr	N/A	50.05	21.05	205.91	72.1	1,284.98	N/A	18.25	Draining
47.00 hr	N/A	50.03	21.03	205.69	71.8	1,279.31	20.51	N/A	Filling
48.00 hr	N/A	50.51	21.51	210.42	78.7	1,402.48	48.05	N/A	Filling
49.00 hr	N/A	51.32	22.32	218.32	90.3	1,608.05	66.65	N/A	Filling
50.00 hr	N/A	51.03	22.03	215.47	86.1	1,533.91	N/A	141.84	Draining
51.00 hr	N/A	49.09	20.09	196.54	58.5	1,041.36	N/A	132.36	Draining
52.00 hr	N/A	48.66	19.66	192.32	52.3	931.69	121.48	N/A	Filling
53.00 hr	N/A	50.21	21.21	207.45	74.4	1,325.05	97.18	N/A	Filling
54.00 hr	N/A	50.89	21.89	214.17	84.2	1,499.89	N/A	29.72	Draining
55.00 hr	N/A	50.24	21.24	207.76	74.9	1,333.33	N/A	111.85	Draining
56.00 hr	N/A	48.37	19.37	189.44	48.1	856.62	N/A	180.88	Draining
57.00 hr	N/A	47.25	18.25	178.52	32.1	572.50	32.07	N/A	Filling
58.00 hr	N/A	47.73	18.73	183.21	39.0	694.50	27.53	N/A	Filling
59.00 hr	N/A	48.18	19.18	187.64	45.5	809.76	40.03	N/A	Filling
60.00 hr	N/A	48.89	19.89	194.56	55.6	989.80	71.88	N/A	Filling
61.00 hr	N/A	49.92	20.92	204.63	70.3	1,251.80	87.87	N/A	Filling
62.00 hr	N/A	50.75	21.75	212.79	82.2	1,464.11	N/A	117.32	Draining
63.00 hr	N/A	49.13	20.13	196.89	59.0	1,050.56	N/A	104.17	Draining
64.00 hr	N/A	47.53	18.53	181.27	36.2	644.21	N/A	122.16	Draining
65.00 hr	N/A	47.67	18.67	182.65	38.2	679.94	50.36	N/A	Filling
66.00 hr	N/A	48.24	19.24	188.22	46.3	824.96	11.67	N/A	Filling
67.00 hr	N/A	48.41	19.41	189.91	48.8	868.91	4.97	N/A	Filling
68.00 hr	N/A	48.65	19.65	192.22	52.1	928.85	46.36	N/A	Filling
69.00 hr	N/A	49.55	20.55	201.00	65.0	1,157.43	115.18	N/A	Filling
70.00 hr	N/A	50.96	21.96	214.82	85.2	1,516.80	N/A	18.77	Draining
71.00 hr	N/A	50.88	21.88	213.98	83.9	1,495.06	19.89	N/A	Filling
72.00 hr	N/A	51.23	22.23	217.47	89.0	1,585.72	47.21	N/A	Filling



## Detailed Report for Tank: T-Battali Hill

### Scenario Summary

Label	Base
Demand Alternative	Base-Average Daily
Physical Alternative	Base-Physical
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Base-Fire Flow

### Calibration Summary

Demand	<none>	Roughness
--------	--------	-----------

### Geometric Summary

X	376.50 m	Base Elevation	42.00
Y	299.46 m	Zone	Zone-1

### Connecting Pipes

P-MadunaghatTrans  
P-14T  
P-2077

### Operating Range Summary

Maximum Elevation	51.50 m	Maximum Level	9.50
Initial Elevation	46.50 m	Initial Level	4.50
Minimum Elevation	42.70 m	Minimum Level	0.70

### Storage Summary

Type	Constant Area		
Cross Section	Non-Circular	Average Area	1,550.0
Inactive Volume	151.00 m <sup>3</sup>	Total Active Volume	13,640.00
Total Storage Capacity	13,791.00 m <sup>3</sup>		

battali hill top tank

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	46.50	4.50	44.02	43.8	6,041.00	243.73	N/A	Filling
1.00 hr	N/A	47.09	5.09	49.75	50.4	6,948.77	260.59	N/A	Filling
2.00 hr	N/A	47.72	5.72	55.92	57.5	7,927.10	281.67	N/A	Filling
3.00 hr	N/A	48.39	6.39	62.52	65.1	8,972.21	298.00	N/A	Filling
4.00 hr	N/A	49.11	7.11	69.50	73.1	10,078.86	318.55	N/A	Filling
5.00 hr	N/A	49.80	7.80	76.30	80.9	11,155.46	268.50	N/A	Filling
6.00 hr	N/A	50.27	8.27	80.86	86.1	11,878.78	44.56	N/A	Filling
7.00 hr	N/A	50.33	8.33	81.53	86.9	11,984.17	N/A	98.24	Draining
8.00 hr	N/A	50.02	8.02	78.42	83.3	11,492.33	N/A	215.74	Draining
9.00 hr	N/A	49.51	7.51	73.51	77.7	10,713.59	N/A	260.53	Draining
10.00 hr	N/A	48.91	6.91	67.63	70.9	9,782.84	N/A	249.99	Draining
11.00 hr	N/A	48.37	6.37	62.29	64.8	8,935.97	N/A	210.47	Draining
12.00 hr	N/A	47.95	5.95	58.21	60.1	8,290.26	N/A	139.87	Draining
13.00 hr	N/A	47.67	5.67	55.45	56.9	7,853.06	N/A	99.29	Draining
14.00 hr	N/A	47.48	5.48	53.57	54.8	7,553.83	N/A	62.41	Draining
15.00 hr	N/A	47.36	5.36	52.38	53.4	7,366.46	N/A	39.75	Draining

## Detailed Report for Tank: T-Battali Hill


### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
16.00 hr	N/A	47.24	5.24	51.23	52.1	7,183.85	N/A	70.84	Draining
17.00 hr	N/A	47.00	5.00	48.91	49.4	6,815.30	N/A	145.66	Draining
18.00 hr	N/A	46.60	4.60	45.04	45.0	6,203.44	N/A	200.99	Draining
19.00 hr	N/A	46.14	4.14	40.49	39.8	5,482.32	N/A	192.03	Draining
20.00 hr	N/A	45.79	3.79	37.11	35.9	4,945.78	N/A	105.09	Draining
21.00 hr	N/A	45.70	3.70	36.21	34.8	4,803.43	22.95	N/A	Filling
22.00 hr	N/A	45.90	3.90	38.13	37.0	5,107.61	140.45	N/A	Filling
23.00 hr	N/A	46.31	4.31	42.13	41.6	5,741.64	199.47	N/A	Filling
24.00 hr	N/A	46.82	4.82	47.13	47.4	6,533.32	237.93	N/A	Filling
25.00 hr	N/A	47.40	5.40	52.81	53.9	7,434.04	260.59	N/A	Filling
26.00 hr	N/A	48.03	6.03	58.98	61.0	8,411.62	281.67	N/A	Filling
27.00 hr	N/A	48.70	6.70	65.57	68.6	9,456.04	298.00	N/A	Filling
28.00 hr	N/A	49.42	7.42	72.56	76.6	10,563.76	318.55	N/A	Filling
29.00 hr	N/A	50.11	8.11	79.31	84.4	11,633.15	268.50	N/A	Filling
30.00 hr	N/A	50.48	8.48	82.99	88.6	12,215.82	44.56	N/A	Filling
31.00 hr	N/A	50.41	8.41	82.25	87.7	12,099.60	N/A	98.24	Draining
32.00 hr	N/A	50.03	8.03	78.56	83.5	11,514.24	N/A	215.74	Draining
33.00 hr	N/A	49.47	7.47	73.08	77.2	10,645.76	N/A	260.53	Draining
34.00 hr	N/A	48.88	6.88	67.25	70.5	9,722.27	N/A	249.99	Draining
35.00 hr	N/A	48.34	6.34	62.02	64.5	8,893.61	N/A	210.47	Draining
36.00 hr	N/A	47.93	5.93	58.05	59.9	8,264.89	N/A	139.87	Draining
37.00 hr	N/A	47.66	5.66	55.38	56.9	7,841.03	N/A	99.29	Draining
38.00 hr	N/A	47.48	5.48	53.56	54.8	7,552.62	N/A	62.41	Draining
39.00 hr	N/A	47.36	5.36	52.42	53.5	7,372.27	N/A	39.75	Draining
40.00 hr	N/A	47.23	5.23	51.19	52.0	7,176.80	N/A	70.84	Draining
41.00 hr	N/A	46.98	4.98	48.72	49.2	6,785.96	N/A	145.66	Draining
42.00 hr	N/A	46.59	4.59	44.86	44.8	6,173.68	N/A	200.99	Draining
43.00 hr	N/A	46.13	4.13	40.35	39.6	5,459.99	N/A	192.03	Draining
44.00 hr	N/A	45.78	3.78	36.97	35.7	4,923.46	N/A	105.09	Draining
45.00 hr	N/A	45.70	3.70	36.18	34.8	4,799.39	22.95	N/A	Filling
46.00 hr	N/A	45.90	3.90	38.10	37.0	5,103.58	140.45	N/A	Filling
47.00 hr	N/A	46.28	4.28	41.89	41.4	5,703.21	199.47	N/A	Filling
48.00 hr	N/A	46.79	4.79	46.88	47.1	6,494.90	237.93	N/A	Filling
49.00 hr	N/A	47.37	5.37	52.57	53.6	7,395.46	260.59	N/A	Filling
50.00 hr	N/A	48.00	6.00	58.74	60.7	8,373.04	281.67	N/A	Filling
51.00 hr	N/A	48.68	6.68	65.33	68.3	9,418.16	298.00	N/A	Filling
52.00 hr	N/A	49.40	7.40	72.34	76.3	10,528.90	318.55	N/A	Filling
53.00 hr	N/A	50.08	8.08	79.03	84.0	11,588.81	268.50	N/A	Filling
54.00 hr	N/A	50.50	8.50	83.17	88.8	12,244.69	44.56	N/A	Filling
55.00 hr	N/A	50.54	8.54	83.51	89.2	12,298.71	N/A	98.24	Draining
56.00 hr	N/A	50.23	8.23	80.48	85.7	11,819.33	N/A	215.74	Draining
57.00 hr	N/A	49.72	7.72	75.53	80.0	11,033.94	N/A	260.53	Draining
58.00 hr	N/A	49.14	7.14	69.83	73.5	10,130.93	N/A	249.99	Draining
59.00 hr	N/A	48.59	6.59	64.48	67.3	9,282.92	N/A	210.47	Draining
60.00 hr	N/A	48.16	6.16	60.24	62.4	8,610.95	N/A	139.87	Draining
61.00 hr	N/A	47.85	5.85	57.21	59.0	8,131.32	N/A	99.29	Draining
62.00 hr	N/A	47.64	5.64	55.21	56.7	7,815.00	N/A	62.41	Draining
63.00 hr	N/A	47.51	5.51	53.89	55.2	7,605.88	N/A	39.75	Draining
64.00 hr	N/A	47.38	5.38	52.65	53.7	7,408.35	N/A	70.84	Draining
65.00 hr	N/A	47.13	5.13	50.16	50.9	7,014.78	N/A	145.66	Draining
66.00 hr	N/A	46.76	4.76	46.58	46.8	6,447.52	N/A	200.99	Draining
67.00 hr	N/A	46.32	4.32	42.25	41.8	5,761.01	N/A	192.03	Draining
68.00 hr	N/A	45.94	3.94	38.50	37.5	5,166.43	N/A	105.09	Draining
69.00 hr	N/A	45.77	3.77	36.89	35.6	4,911.88	22.95	N/A	Filling
70.00 hr	N/A	45.88	3.88	37.98	36.9	5,084.68	140.45	N/A	Filling

## Detailed Report for Tank: T-Battali Hill

**Calculated Results Summary**

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
71.00 hr	N/A	46.25	4.25	41.61	41.0	5,659.35	199.47	N/A	Filling
72.00 hr	N/A	46.73	4.73	46.27	46.4	6,398.31	237.93	N/A	Filling



## Detailed Report for Tank: T-ADC Hill

### Scenario Summary

Label	Base
Demand Alternative	Base-Average Daily
Physical Alternative	Base-Physical
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Base-Fire Flow

### Calibration Summary

Demand	<none>	Roughness
--------	--------	-----------

### Geometric Summary

X	519.65 m	Base Elevation	12.00
Y	221.50 m	Zone	Zone-1

### Connecting Pipes

P-ADCin  
P-2018  
P-ADCout

### Operating Range Summary

Maximum Elevation	38.10 m	Maximum Level	26.10
Initial Elevation	38.00 m	Initial Level	26.00
Minimum Elevation	33.50 m	Minimum Level	21.50

### Storage Summary

Type	Constant Area		
Cross Section	Non-Circular	Average Area	988.0
Inactive Volume	145.00 m <sup>3</sup>	Total Active Volume	4,544.80
Total Storage Capacity	4,689.80 m <sup>3</sup>		

adc hill top tank,

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	38.00	26.00	254.33	97.9	4,591.00	415.43	N/A	Filling
1.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
2.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
3.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
4.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.17e-3	N/A	Full
5.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
6.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.99e-4	N/A	Full
7.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.00	0.00	Full
8.00 hr	N/A	37.92	25.92	253.57	96.3	4,514.21	N/A	122.04	Draining
9.00 hr	N/A	37.48	25.48	249.25	86.9	4,077.71	N/A	182.78	Draining
10.00 hr	N/A	36.83	24.83	242.87	73.2	3,433.15	N/A	166.33	Draining
11.00 hr	N/A	36.30	24.30	237.73	62.1	2,913.98	N/A	105.39	Draining
12.00 hr	N/A	36.09	24.09	235.65	57.7	2,704.71	1.32	N/A	Filling
13.00 hr	N/A	36.20	24.20	236.68	59.9	2,808.11	60.85	N/A	Filling
14.00 hr	N/A	36.50	24.50	239.67	66.3	3,110.83	113.63	N/A	Filling
15.00 hr	N/A	36.97	24.97	244.21	76.1	3,569.18	141.71	N/A	Filling



## Detailed Report for Tank: T-ADC Hill


### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
16.00 hr	N/A	37.43	25.43	248.71	85.8	4,023.24	96.14	N/A	Filling
17.00 hr	N/A	37.60	25.60	250.46	89.6	4,200.28	N/A	15.34	Draining
18.00 hr	N/A	37.42	25.42	248.63	85.6	4,015.75	N/A	96.94	Draining
19.00 hr	N/A	37.07	25.07	245.24	78.3	3,673.22	N/A	81.63	Draining
20.00 hr	N/A	37.01	25.01	244.63	77.0	3,611.46	48.11	N/A	Filling
21.00 hr	N/A	37.51	25.51	249.51	87.5	4,104.29	212.28	N/A	Filling
22.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.13e-3	N/A	Full
23.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.15e-3	N/A	Full
24.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.15e-3	N/A	Full
25.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
26.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
27.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
28.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.17e-3	N/A	Full
29.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
30.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.99e-4	N/A	Full
31.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.00	0.00	Full
32.00 hr	N/A	37.92	25.92	253.53	96.2	4,509.87	N/A	122.00	Draining
33.00 hr	N/A	37.34	25.34	247.90	84.0	3,941.55	N/A	182.19	Draining
34.00 hr	N/A	36.70	24.70	241.63	70.5	3,308.36	N/A	165.77	Draining
35.00 hr	N/A	36.21	24.21	236.78	60.1	2,818.59	N/A	104.87	Draining
36.00 hr	N/A	36.02	24.02	234.98	56.2	2,636.34	1.69	N/A	Filling
37.00 hr	N/A	36.15	24.15	236.21	58.9	2,760.48	61.11	N/A	Filling
38.00 hr	N/A	36.47	24.47	239.37	65.7	3,079.89	113.80	N/A	Filling
39.00 hr	N/A	36.94	24.94	244.00	75.6	3,547.61	141.82	N/A	Filling
40.00 hr	N/A	37.39	25.39	248.33	85.0	3,984.89	96.35	N/A	Filling
41.00 hr	N/A	37.53	25.53	249.77	88.1	4,130.24	N/A	14.96	Draining
42.00 hr	N/A	37.35	25.35	247.94	84.1	3,946.00	N/A	96.56	Draining
43.00 hr	N/A	37.01	25.01	244.68	77.1	3,615.93	N/A	81.32	Draining
44.00 hr	N/A	36.95	24.95	244.08	75.8	3,555.36	48.42	N/A	Filling
45.00 hr	N/A	37.47	25.47	249.19	86.8	4,072.26	212.43	N/A	Filling
46.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.13e-3	N/A	Full
47.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.15e-3	N/A	Full
48.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.15e-3	N/A	Full
49.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
50.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
51.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
52.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.17e-3	N/A	Full
53.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.16e-3	N/A	Full
54.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.99e-4	N/A	Full
55.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.00	0.00	Full
56.00 hr	N/A	37.91	25.91	253.41	95.9	4,498.28	N/A	121.93	Draining
57.00 hr	N/A	37.46	25.46	249.01	86.4	4,053.43	N/A	182.67	Draining
58.00 hr	N/A	36.84	24.84	242.99	73.5	3,445.91	N/A	166.37	Draining
59.00 hr	N/A	36.32	24.32	237.87	62.4	2,928.14	N/A	105.45	Draining
60.00 hr	N/A	36.07	24.07	235.40	57.1	2,679.27	1.47	N/A	Filling
61.00 hr	N/A	36.11	24.11	235.81	58.0	2,720.18	61.33	N/A	Filling
62.00 hr	N/A	36.39	24.39	238.57	64.0	2,999.80	114.25	N/A	Filling
63.00 hr	N/A	36.82	24.82	242.81	73.1	3,427.16	142.39	N/A	Filling
64.00 hr	N/A	37.26	25.26	247.13	82.4	3,863.93	97.02	N/A	Filling
65.00 hr	N/A	37.41	25.41	248.55	85.4	4,007.10	N/A	14.29	Draining
66.00 hr	N/A	37.29	25.29	247.40	83.0	3,891.16	N/A	96.26	Draining
67.00 hr	N/A	37.00	25.00	244.54	76.8	3,602.29	N/A	81.24	Draining
68.00 hr	N/A	36.85	24.85	243.09	73.7	3,456.01	48.96	N/A	Filling
69.00 hr	N/A	37.19	25.19	246.44	80.9	3,794.51	213.71	N/A	Filling
70.00 hr	N/A	38.04	26.04	254.76	98.8	4,634.73	328.40	N/A	Filling

## Detailed Report for Tank: T-ADC Hill

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
71.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.15e-3	N/A	Full
72.00 hr	N/A	38.10	26.10	255.31	100.0	4,689.80	0.15e-3	N/A	Full



## Detailed Report for Tank: T-Patenga

### Scenario Summary

Label	Base
Demand Alternative	Base-Average Daily
Physical Alternative	Base-Physical
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Base-Fire Flow

### Calibration Summary

Demand	<none>	Roughness
--------	--------	-----------

### Geometric Summary

X	250.74 m	Base Elevation	1.00
Y	44.74 m	Zone	Zone-1

### Connecting Pipes

P-2060T2  
P-933  
P-PatIP

### Operating Range Summary

Maximum Elevation	7.00 m	Maximum Level	6.00
Initial Elevation	2.50 m	Initial Level	1.50
Minimum Elevation	1.00 m	Minimum Level	0.00

### Storage Summary


Type	Constant Area		
Cross Section	Non-Circular	Average Area	4,000.0
Inactive Volume	0.00 m <sup>3</sup>	Total Active Volume	24,000.00
Total Storage Capacity	24,000.00 m <sup>3</sup>		

### Calculated Results Summary

Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
0.00 hr	N/A	2.50	1.50	14.67	25.0	6,000.00	595.66	N/A	Filling
1.00 hr	N/A	3.06	2.06	20.13	34.3	8,230.18	644.51	N/A	Filling
2.00 hr	N/A	3.66	2.66	26.07	44.4	10,659.38	702.31	N/A	Filling
3.00 hr	N/A	4.32	3.32	32.47	55.3	13,277.12	750.54	N/A	Filling
4.00 hr	N/A	5.02	4.02	39.30	67.0	16,071.51	807.76	N/A	Filling
5.00 hr	N/A	5.70	4.70	46.01	78.4	18,812.45	688.45	N/A	Filling
6.00 hr	N/A	6.17	5.17	50.60	86.2	20,691.38	135.26	N/A	Filling
7.00 hr	N/A	6.26	5.26	51.48	87.7	21,051.87	N/A	213.76	Draining
8.00 hr	N/A	5.98	4.98	48.75	83.1	19,935.19	N/A	508.48	Draining
9.00 hr	N/A	5.52	4.52	44.24	75.4	18,089.36	N/A	625.54	Draining
10.00 hr	N/A	4.96	3.96	38.75	66.0	15,844.07	N/A	606.56	Draining
11.00 hr	N/A	4.45	3.45	33.71	57.4	13,783.58	N/A	514.38	Draining
12.00 hr	N/A	4.05	3.05	29.84	50.8	12,203.26	N/A	344.11	Draining
13.00 hr	N/A	3.78	2.78	27.21	46.4	11,127.16	N/A	243.76	Draining
14.00 hr	N/A	3.60	2.60	25.42	43.3	10,395.15	N/A	151.57	Draining
15.00 hr	N/A	3.49	2.49	24.31	41.4	9,942.71	N/A	94.92	Draining
16.00 hr	N/A	3.37	2.37	23.22	39.6	9,494.07	N/A	177.61	Draining
17.00 hr	N/A	3.14	2.14	20.94	35.7	8,562.45	N/A	368.67	Draining

## Detailed Report for Tank: T-Patenga

Calculated Results Summary									
Time	Constituent (mg/l)	Calculated Hydraulic Grade (m)	Tank Level (m)	Pressure (kPa)	Percent Full (%)	Current Storage Volume (m <sup>3</sup> )	Tank Inflow (l/s)	Tank Outflow (l/s)	Status
18.00 hr	N/A	2.75	1.75	17.16	29.2	7,017.73	N/A	506.27	Draining
19.00 hr	N/A	2.30	1.30	12.70	21.6	5,194.90	N/A	488.57	Draining
20.00 hr	N/A	1.95	0.95	9.33	15.9	3,815.93	N/A	276.03	Draining
21.00 hr	N/A	1.85	0.85	8.33	14.2	3,405.78	39.50	N/A	Filling
22.00 hr	N/A	2.02	1.02	10.03	17.1	4,099.92	333.12	N/A	Filling
23.00 hr	N/A	2.41	1.41	13.76	23.4	5,626.99	486.71	N/A	Filling
24.00 hr	N/A	2.89	1.89	18.52	31.5	7,571.43	589.27	N/A	Filling
25.00 hr	N/A	3.45	2.45	23.99	40.9	9,811.30	652.08	N/A	Filling
26.00 hr	N/A	4.07	3.07	29.99	51.1	12,265.13	709.51	N/A	Filling
27.00 hr	N/A	4.73	3.73	36.45	62.1	14,906.40	756.08	N/A	Filling
28.00 hr	N/A	5.43	4.43	43.35	73.9	17,725.89	812.94	N/A	Filling
29.00 hr	N/A	6.12	5.12	50.06	85.3	20,469.28	694.34	N/A	Filling
30.00 hr	N/A	6.50	5.50	53.84	91.7	22,017.08	140.28	N/A	Filling
31.00 hr	N/A	6.46	5.46	53.40	91.0	21,835.52	N/A	215.20	Draining
32.00 hr	N/A	6.12	5.12	50.07	85.3	20,474.76	N/A	513.35	Draining
33.00 hr	N/A	5.60	4.60	44.96	76.6	18,384.01	N/A	633.66	Draining
34.00 hr	N/A	5.03	4.03	39.45	67.2	16,130.20	N/A	613.89	Draining
35.00 hr	N/A	4.52	3.52	34.46	58.7	14,090.25	N/A	521.30	Draining
36.00 hr	N/A	4.13	3.13	30.64	52.2	12,528.01	N/A	350.63	Draining
37.00 hr	N/A	3.86	2.86	28.02	47.7	11,457.89	N/A	252.21	Draining
38.00 hr	N/A	3.68	2.68	26.22	44.7	10,722.99	N/A	159.63	Draining
39.00 hr	N/A	3.56	2.56	25.09	42.7	10,259.60	N/A	102.62	Draining
40.00 hr	N/A	3.44	2.44	23.86	40.7	9,756.97	N/A	183.71	Draining
41.00 hr	N/A	3.19	2.19	21.40	36.5	8,750.15	N/A	375.33	Draining
42.00 hr	N/A	2.79	1.79	17.54	29.9	7,173.41	N/A	517.88	Draining
43.00 hr	N/A	2.33	1.33	13.03	22.2	5,328.51	N/A	499.57	Draining
44.00 hr	N/A	1.98	0.98	9.57	16.3	3,911.64	N/A	286.20	Draining
45.00 hr	N/A	1.88	0.88	8.59	14.6	3,511.40	31.70	N/A	Filling
46.00 hr	N/A	2.05	1.05	10.23	17.4	4,181.35	326.88	N/A	Filling
47.00 hr	N/A	2.40	1.40	13.68	23.3	5,595.85	478.59	N/A	Filling
48.00 hr	N/A	2.88	1.88	18.37	31.3	7,511.46	581.43	N/A	Filling
49.00 hr	N/A	3.43	2.43	23.78	40.5	9,723.00	644.50	N/A	Filling
50.00 hr	N/A	4.04	3.04	29.71	50.6	12,149.96	703.35	N/A	Filling
51.00 hr	N/A	4.69	3.69	36.11	61.5	14,767.49	750.09	N/A	Filling
52.00 hr	N/A	5.39	4.39	42.97	73.2	17,570.04	807.12	N/A	Filling
53.00 hr	N/A	6.07	5.07	49.56	84.4	20,265.96	687.63	N/A	Filling
54.00 hr	N/A	6.49	5.49	53.73	91.6	21,972.54	133.77	N/A	Filling
55.00 hr	N/A	6.55	5.55	54.28	92.5	22,194.86	N/A	220.25	Draining
56.00 hr	N/A	6.27	5.27	51.56	87.8	21,083.60	N/A	517.01	Draining
57.00 hr	N/A	5.80	4.80	46.92	79.9	19,187.89	N/A	636.92	Draining
58.00 hr	N/A	5.24	4.24	41.51	70.7	16,973.74	N/A	616.97	Draining
59.00 hr	N/A	4.72	3.72	36.38	62.0	14,874.62	N/A	524.21	Draining
60.00 hr	N/A	4.30	3.30	32.26	55.0	13,193.70	N/A	353.37	Draining
61.00 hr	N/A	3.99	2.99	29.28	49.9	11,974.57	N/A	257.12	Draining
62.00 hr	N/A	3.79	2.79	27.26	46.4	11,146.47	N/A	166.80	Draining
63.00 hr	N/A	3.65	2.65	25.89	44.1	10,586.02	N/A	109.39	Draining
64.00 hr	N/A	3.51	2.51	24.60	41.9	10,057.40	N/A	186.23	Draining
65.00 hr	N/A	3.26	2.26	22.09	37.6	9,034.87	N/A	377.45	Draining
66.00 hr	N/A	2.89	1.89	18.49	31.5	7,562.68	N/A	519.04	Draining
67.00 hr	N/A	2.44	1.44	14.13	24.1	5,778.61	N/A	501.43	Draining
68.00 hr	N/A	2.05	1.05	10.29	17.5	4,209.73	N/A	287.95	Draining
69.00 hr	N/A	1.87	0.87	8.50	14.5	3,477.24	28.47	N/A	Filling
70.00 hr	N/A	1.95	0.95	9.29	15.8	3,800.76	320.20	N/A	Filling
71.00 hr	N/A	2.28	1.28	12.54	21.4	5,129.80	471.66	N/A	Filling
72.00 hr	N/A	2.72	1.72	16.85	28.7	6,890.15	574.77	N/A	Filling



**7.4-3-4 Relationship between Nodes and Wards (Basic Plan Phase 1, 2005)**

**7.4-3-5 Relationship between Nodes and Wards (Basic Plan Phase 2, 2010)**

Tables attached herewith show the relationship between Nodes and Wards. Based on these relationships, demand in each wards were distributed to each nodes for hydraulic analysis.






















### 7.4-4 Cross Section of Karnaphuli River at Proposed WTP Site

Source: Tidal Discharge Measurement Karnaphuli – Halda River System 13/3/1998 to 9/5/1998, July 1998, Sunflower Computers & Waterscape Consultant

#### Summary

In a bid to plan its resources development, Chittagong WASA planned a series of flow measurement on the Karnaphuli-Halda system. The river being tidal in the region of planned measurement, tidal discharge measurement procedure had to be adopted. Chittagong Hydrological Sub-Division under South Eastern Measurement Division BWDB implemented the survey as deposit work.

The sketch below shows the location of the discharge measurement sections on the Karnaphuli-Halda river system.




The following table explains the Station\_ID, StationName and Location\_ID

River	Station_ID	StationName	Location_ID
Karnaphuli	SW122B	Thermal Power Station	Karnaphuli_up
	SW122A	Chowdhuryhat	Karnaphuli_dn
Halda	SW121B	Satterghat	Halda_up
	SW121A	Madnaghhat	Halda_dn



C/S of Karnafuli\_dn1 at SW122A Chowdhuryhat  
Surveyed on 18/4/1998

7.4.4-2



## 7.4-5 Comparison Study on Natural Gas Engine Generator

### A. Conditions for Calculation

- (1) Total Capacity of Existing Facilities: 2,540 kW
- (2) Total Capacity of New Facilities: 2,500 kW
- (3) Requirement for Continuous Operation of All Facilities:  
 $(2,540+2,500) \times 95 \% = 4,800 \text{ kW}$
- (4) Power Generation per Gas Volume: 3.2 kWh/m<sup>3</sup> (based on manufacturer's data)
- (5) Unit Cost of Natural Gas: 2.22 Tk/m<sup>3</sup>
- (6) Penalty for Continuous Power Generation to be paid to PDB: 0.15 Tk/kWh
- (7) Operation Hours: Continuous Operation (24 hours, 365 days)  
Emergency Operation (15minutes/day, 365 days, based on past records)  
1% of a day
- (8) PDB Power Cost: 1.95 Tk/m<sup>3</sup>
- (9) Power Generation per Diesel Oil Volume: 3,000 kWh/m<sup>3</sup>
- (10) Unit Cost of Diesel Oil: 16 Tk/litter

### B. Operation Costs

- (1) Powered by PDB:  $4,800 \text{ kW} \times 1.95 \text{ Tk/kWh} \times 24 \text{ hours} \times 365 \text{ days} = 81.99 \text{ mil.Tk.}$   
 $= \underline{\text{US\$1,518,000 / year}}$
- (2) Powered by Gas Engine Generator (Continuous Generation):  
 $((4,800 \text{ kW} / 3.2 \text{ kWh/m}^3 \times 2.22 \text{ Tk/m}^3) + (4,800 \text{ kW} \times 0.15 \text{ Tk/kWh})) \times 24 \text{ hours} \times 365 \text{ days} = 35.48 \text{ mil.Tk.} = \underline{\text{US\$657,000 / year}}$
- (3) Powered by PDB and Gas Engine Generator in Emergency:  
 $((4,800 \text{ kW} \times 1.95 \text{ Tk/kWh} \times 0.99) + (4,800 \text{ kW} / 3.2 \text{ kWh/m}^3 \times 2.22 \text{ Tk/m}^3 \times 0.01)) \times 24 \text{ hours} \times 365 \text{ days} = 81.47 \text{ mil.Tk.} = \underline{\text{US\$1,509,000 / year}}$
- (4) Powered by Diesel Engine Generator (Continuous Generation):  
 $((4,800 \text{ kW} / 3,000 \text{ kWh/m}^3 \times 16,000 \text{ Tk/m}^3) + (4,800 \times 0.15 \text{ Tk/kWh})) \times 24 \text{ hours} \times 365 \text{ days} = 230.56 \text{ mil.Tk.} = \underline{\text{US\$4,270,000 / year}}$
- (5) Powered by PDB and Diesel Engine Generator in Emergency:  
 $((4,800 \text{ kW} \times 1.95 \text{ Tk/kWh} \times 0.99) + (4,800 \text{ kW} / 3,000 \text{ kWh/m}^3 \times 16,000 \text{ Tk/m}^3 \times 0.01)) \times 24 \text{ hours} \times 365 \text{ days} = 83.42 \text{ mil.Tk.} = \underline{\text{US\$1,545,000 / year}}$

### C. Equipment Cost (incl. mech. and elec. equipment)

3 units for continuous generation, 2 units for emergency generation

(1) Gas Engine Generator 2,500kW

For Continuous Generation:

US\$1,200,000 x 130% (customs, duty, charges, etc.) x 3 units = US\$4,680,000

Pipeline (100mm x 1,800m) Tk.13,558,871 = US\$251,000

Total US\$4,931,000

For Emergency Generation:

US\$1,200,000 x 130% (customs, duty, charges, etc.) x 2 units = US\$3,120,000

Pipeline (100mm x 1,800m) Tk.13,558,871 = US\$251,000

Total US\$3,371,000

(2) Diesel Engine Generator 2,500kW

For Continuous Generation:

US\$863,000 x 130% (customs, duty, charges, etc.) x 3 units = US\$3,366,000

For Emergency Generation:

US\$863,000 x 130% (customs, duty, charges, etc.) x 2 units = US\$2,244,000

D. Annual Maintenance Cost (incl. mech. and elec. equipment)

Life of generator: 15 years

Regular maintenance Cost: 3% of equipment cost per year

Overhaul maintenance Cost: 30% of equipment cost every 5 years for continuous generation

20% of equipment cost every 5 years for emergency generation

**Summary of Costs:**

Case	Equipment Cost (1000US\$)	Operation Cost (1000US\$/yr)	Maintenance Cost (1000US\$/yr)	Overhaul Cost (1000US\$/5yrs)	NPV (at 7.5%) for 15 years operation (1000US\$)	Ratio
PDB	-	1,518	-	-	12,465	1.00
Gas	4,931	657	148	1,479	12,823	1.03
PDB + Gas	3,371	1,509	101	674	17,097	1.37
Diesel	3,366	4,270	101	1,010	40,133	3.22
PDB + Diesel	2,244	1,545	67	449	15,818	1.27

**Conclusion:**

As shown in above table, the case with power supply only from PDB shows the least cost NPV, though it is not recommendable because of the least reliability. The option with continuous power generation by Gas Engine Generators is the second economical option. The least operation cost is beneficial for this evaluation though its initial cost is the highest.

For the adoption of Gas Engine Generator, the most important issue is availability of reliable operation & maintenance staff members and organization. Buck up support service is also requisite for reliable continuous operation. Provided those requirement are fulfilled and increase of initial cost is allowed, continuous power generation by Gas Engine Generators is recommendable from economical point of view.

Before final decision for application of Gas Engine Generators, reliability of gas supply system and availability of operation and maintenance services for both of normal operation and emergency situation, shall be verified in the beginning of the detailed design stage. In the feasibility study, however, the least capital cost option, i.e. emergency diesel engine power generation was tentatively applied for proposed plant.





Figure 7.4-6-1.

Flow Balance of Proposed Chittagong Water Supply System (Basic Plan Phase 1, 2005)



**Figure 7.4-6-2**

**Flow Balance of  
 Proposed Chittagong Water Supply System  
 (Basic Plan Phase 2, 2010)**

Table 7.5-1-1 Cost Estimates for Basic Plan Phase 1 Project

unit : US\$ 54Taka/\$

Facilities	Item	Local	Foreign	Total	Remarks	Priority Project		Phase I after Priority Project		Phase I	New Mohara Service Area		Others		Priority Project		Phase I after Priority Project		
						New Mohara	Others	New Mohara	Others		Total	Local	Foreign	Local	Foreign	Local	Foreign	Local	Foreign
						-a	-a	-b	-b										
<b>Direct Construction Cost</b>																			
-1	<b>Civil Work</b>																		
1	Intake Facilities	5,000	57,000	62,000	Priority	62,000				62,000	5,000	57,000			5,000	57,000	0	0	
2	Treatment Plant Facilities	5,530,000	313,000	5,843,000	Priority	5,843,000				5,843,000	5,530,000	313,000			5,530,000	313,000	0	0	
3	Transmission Facilities	1,049,000	4,224,000	5,273,000	Priority	5,273,000				5,273,000	1,049,000	4,224,000			1,049,000	4,224,000	0	0	
4	Khulshi Reservoir	19,600m <sup>3</sup>	2,229,000	362,000	2,591,000	Priority	2,591,000			2,591,000	2,229,000	362,000			2,229,000	362,000	0	0	
5	Khulshi Elevated Tank	18m x 7 mD x 16mH	802,000	72,000	874,000	Priority	874,000			874,000	802,000	72,000			802,000	72,000	0	0	
6	Kalurgat Reservoir	4,220m <sup>3</sup>	597,000	197,000	794,000	Priority		794,000		794,000			597,000	197,000	597,000	197,000	0	0	
7	Patenga Reservoir	12,000m <sup>3</sup>	1,381,000	332,000	1,713,000	Priority		1,713,000		1,713,000			1,381,000	332,000	1,381,000	332,000	0	0	
8	Distribution Line (1)	New Mohara Service Area	1,043,000	2,733,000	3,776,000	Priority	3,776,000			3,776,000	1,043,000	2,733,000			1,043,000	2,733,000	0	0	
9	Distribution Line (2)	Other Service Area	1,272,000	2,851,000	4,123,000	Priority		4,123,000		4,123,000			1,272,000	2,851,000	1,272,000	2,851,000	0	0	
10	Small Distribution Line (1)	Small Dia. Pipelines in New Mohara Service Area (Pr	1,199,000	1,727,000	2,926,000	Priority	2,926,000			2,926,000	1,199,000	1,727,000			1,199,000	1,727,000	0	0	
11	Small Distribution Line (2)	Small Dia. Pipelines in New Mohara Service Area	1,726,000	2,487,000	4,213,000	Priority		4,213,000		4,213,000					0	0	1,726,000	2,487,000	
12	Small Distribution Line (3)	Small Dia. Pipelines in Other Service Area (Priority)	787,000	1,134,000	1,921,000	Priority		1,921,000		1,921,000			787,000	1,134,000	787,000	1,134,000	0	0	
13	Small Distribution Line (4)	Small Dia. Pipelines in Other Service Area	2,166,000	3,121,000	5,287,000	Priority		5,287,000		5,287,000					0	0	2,166,000	3,121,000	
14	Rehabilitation Work (1)	Mohara WTP automaton of filter washing	355,000	0	355,000	Priority	355,000			355,000	355,000	0			355,000	0	0	0	
15	Rehabilitation Work (2)	Mohara WTP replace intake and transmission pump	0	0	0	Priority	0			0	0	0			0	0	0	0	
16	Rehabilitation Work (3)	Kalurgat IRP&BPS rehabilitation of filter	26,000	0	26,000	Priority	26,000			26,000	26,000	0			26,000	0	0	0	
17	Rehabilitation Work (4)	Kalurgat IRP&BPS installation of generator	20,000	0	20,000	Priority	20,000			20,000	20,000	0			20,000	0	0	0	
18	Zonal Offices	800 m2 x 5 offices	740,000	0	740,000	Priority	740,000			740,000	740,000	0			740,000	0	0	0	
19	Staff Quarters	100 m2 x 40 flats	740,000	0	740,000	Priority	740,000			740,000	740,000	0			740,000	0	0	0	
	Sub Total	21,667,000	19,610,000	41,277,000		23,226,000	8,551,000	4,213,000	5,287,000	41,277,000	13,738,000	9,488,000	4,037,000	4,514,000	17,775,000	14,002,000	3,892,000	5,608,000	
-2	<b>Mechanical and Electrical Work</b>																		
1	Intake Facilities	Intake pump 42.1m3/min x 15.2m x 2units	0	935,000	935,000	Priority	935,000			935,000	0	935,000	0	0	0	935,000	0	0	
2	Treatment Plant Facilities	Power receiving facilities, generator, chemical dosing	0	6,500,000	6,500,000	Priority	6,500,000			6,500,000	0	6,500,000	0	0	0	6,500,000	0	0	
3	Transmission Facilities	Transmission pump 15.8m3/min x 84m x 4units (+1)	0	1,828,000	1,828,000	Priority	1,828,000			1,828,000	0	1,828,000	0	0	0	1,828,000	0	0	
4	Kulshi Elevated Tank	Lift pump 13.1m3/min x 25m x 3units (+1)	0	1,717,000	1,717,000	Priority	1,717,000			1,717,000	0	1,717,000	0	0	0	1,717,000	0	0	
5	Patenga Reservoir	Distribution pump 19.2m3/min x 37m x 2units (+1)	0	1,999,000	1,999,000	Priority		1,999,000		1,999,000	0	0	1,999,000	0	0	1,999,000	0	0	
6	Rehabilitation Work (1)	Mohara WTP automated of filter washing	0	831,000	831,000	Priority	831,000			831,000	0	831,000	0	0	0	831,000	0	0	
7	Rehabilitation Work (2)	Mohara WTP replace intake and transmission pump	0	1,444,000	1,444,000	Priority	1,444,000			1,444,000	0	1,444,000	0	0	0	1,444,000	0	0	
8	Rehabilitation Work (3)	Kalurgat IRP&BPS rehabilitation of filter	0	85,000	85,000	Priority	85,000			85,000	0	85,000	0	0	0	85,000	0	0	
9	Rehabilitation Work (4)	Kalurgat IRP&BPS installation of generator	0	1,111,000	1,111,000	Priority	1,111,000			1,111,000	0	1,111,000	0	0	0	1,111,000	0	0	
	Sub Total	0	16,450,000	16,450,000		14,451,000	1,999,000	0	0	16,450,000	0	14,451,000	0	1,999,000	0	16,450,000	0	0	
<b>Total I</b>	<b>I</b>	21,667,000	36,060,000	57,727,000		37,677,000	10,550,000	4,213,000	5,287,000	57,727,000	13,738,000	23,939,000	4,037,000	6,513,000	17,775,000	30,452,000	3,892,000	5,608,000	
	<b>Overhead &amp; profit etc.</b>																		
	25% of Direct Cost for ICB (I-1 1-9, 14-17, 1-2)	0	10,475,000	10,475,000		8,318,000	2,157,000	0	0	10,475,000	0	8,318,000	0	2,157,000	0	10,475,000	0	0	
	12.5% of Direct Cost for LCB (I-1 10-13,18,19)	1,979,000	0	1,979,000		551,000	240,000	527,000	661,000	1,979,000	551,000	0	240,000	0	791,000	0	1,188,000	0	
	Sub Total	1,979,000	10,475,000	12,454,000		8,869,000	2,397,000	527,000	661,000	12,454,000	551,000	8,318,000	240,000	2,157,000	791,000	10,475,000	1,188,000	0	
<b>Total I + II</b>	<b>+</b>	23,646,000	46,535,000	70,181,000		46,546,000	12,947,000	4,740,000	5,948,000	70,181,000	14,289,000	32,257,000	4,277,000	8,670,000	18,566,000	40,927,000	5,080,000	5,608,000	
	<b>Others</b>																		
	Water meter	20-150mm x 25,000units	0	589,000	589,000		589,000			589,000		589,000			0	589,000	0	0	
	Vehicle	sedan x 2vehicles + jeep x 2vehicles	0	93,000	93,000		93,000			93,000		93,000			0	93,000	0	0	
	Computer	8 sets	0	22,000	22,000		22,000			22,000		22,000			0	22,000	0	0	
	Administration Cost		128,000	0	128,000		128,000			128,000		128,000			128,000	0	0	0	
	Land Acquisition Cost		3,370,000	0	3,370,000		3,370,000			3,370,000		3,370,000			3,370,000	0	0	0	
	Sub Total	3,498,000	704,000	4,202,000		4,202,000	0	0	0	4,202,000	3,498,000	704,000	0	0	3,498,000	704,000	0	0	
<b>Total I + II + III</b>	<b>+ +</b>	27,144,000	47,239,000	74,383,000		50,748,000	12,947,000	4,740,000	5,948,000	74,383,000	17,787,000	32,961,000	4,277,000	8,670,000	22,064,000	41,631,000	5,080,000	5,608,000	
	<b>Engineering Cost</b>																		
	Engineering Cost	8% of Total Cost ( + )	849,000	4,810,000	5,659,000		3,759,000	1,045,000	379,000	476,000	5,659,000	564,000	3,195,000	157,000	888,000	721,000	4,083,000	128,000	727,000
	VAT for Engineering Cost	5.25%	297,000	0	297,000		197,000	55,000	20,000	297,000	197,000	0	55,000	0	252,000	0	45,000	0	
	<b>Customs Duties, etc.</b>																		
	Customs Duties and Other Charges		12,595,000	0	12,595,000		7,399,000	2,508,000	1,192,000	1,496,000	12,595,000	7,399,000	0	2,508,000	0	9,907,000	0	2,688,000	
	VAT for Civil	4.5% of Civil and Mech & Elec Equip Installation Wo	1,518,000	0	1,518,000		1,058,000	263,000	87,000	110,000	1,518,000	1,058,000	0	263,000	0	1,321,000	0	197,000	
	VAT for Mech & Elec		6,010,000	0	6,010,000		3,674,000	1,168,000	518,000	650,000	6,010,000	3,674,000	0	1,168,000	0	4,842,000	0	1,168,000	
	Pre-shipment Inspection Fee		302,000	0	302,000		189,000	57,000	25,000	31,000	302,000	189,000	0	57,000	0	246,000	0	56,000	
	Sub Total	20,425,000	0	20,425,000		12,320,000	3,996,000	1,822,000	2,287,000	20,425,000	12,320,000	0	3,996,000	0	16,316,000	0	4,109,000	0	
<b>Total</b>		48,715,000	52,049,000	100,764,000		67,024,000	18,043,000	6,961,000	8,736,000	100,764,000	30,868,000	36,156,000	8,485,000	9,558,000	39,353,000	45,714,000	9,362,000	6,335,000	

7.5-1-1

	Priority Project Total	Phase I Total	Local ( (-a)+(-a) )	Foreign ( (-b)+(-b) )	Priority Project Total	Phase I Total	Rehabilitation - Mohara WTP	Rehabilitation - Kalurgat IRP	Total
Construction Cost	\$60,197,000	71%	\$70,885,000	70%	\$39,353,000	46%	\$48,715,000	48%	\$2,630,000 =Tk.142,020,000
Customs Duties & Taxes	\$16,568,000	19%	\$20,722,000	21%	\$45,714,000	54%	\$52,049,000	52%	\$3,872,000 =Tk.67,068,000
Land Cost	\$3,370,000	4%	\$3,370,000	3%	\$85,067,000	100%	\$100,764,000	100%	
Administration Cost	\$128,000	0%	\$128,000	0%					
Engineering Cost	\$4,804,000	6%	\$5,659,000	6%					(excl.VAT)

**Table 7.5-1-2 Details of Cost Estimates for Basic Plan Phase 1 Project (Civil Work)**

(54Taka/S) unit : USS

Equipment	Item	Cost (USS)	Priority Project		Phase 1 after Priority Pjet	
			New Mohara -a	Others -a	New Mohara -b	Others -b
<b>Civil Work</b>						
<b>I. Direct Cost</b>						
<b>-1 Intake Facilities</b>						
1 Intake Pump Installation	42.1m <sup>3</sup> /min×15.2m×2units	375,261	375,261			
2 Conveyance Pipe	DIP900mm×214m	4,886	4,886			
Sub-Total		380,147	380,147	0	0	0
<b>-2 Mohara WTP</b>						
1 Receiving Wel (Distribution Chamber)	W7.0m×L5.5m×ED4.0m×1Basin	59,837	59,837			
1 Desilting Basin	W23.0m×L76.0m×ED2.5m×4Basins	1,388,167	1,388,167			
3 Rapid Mixing Basin	W2.29m×L2.29m×ED1.91m×2Basins	6,889	6,889			
4 Clarifier	W7.62m×L7.62m×ED7.08m×24Basins	845,444	845,444			
5 Filter	W2.44m×L9.14m×2units×8Basins	1,182,667	1,182,667			
6 Clear Well (Include Chlorination Channel)	W31.5m×L(40.1+9.0)m×ED2.88m×2Basins	986,852	986,852			
7 Transmission Pump House	W15.24m×L41.66m	224,944	224,944			
8 Sludge Tank	W9.14m×L22.86m×ED4.30m×1Basins	132,519	132,519			
9 Chemical Building & Chlorination room	W9.04m×L76.58m	221,259	221,259			
10 Laboratory & Control room	W10.0m×L21.0×2sorries	87,852	87,852			
11 Inplant Piping	DIP1200-300mm×1,263m	217,777	217,777			
12 Road Work		146,778	146,778			
13 Lighting		28,815	28,815			
14 Mech & Elec Equipment Installation	WTP Equipment	2,177,074	2,177,074			
Sub-Total		7,706,874	7,706,874	0	0	0
<b>-3 Transmission Facilities</b>						
Transmission Pump	15.8m <sup>3</sup> /min×84m×5units	561,722	561,722			
Transmission Pipe	DIP900mm×15,045m	1,048,734	1,048,734			
Sub-Total		1,610,456	1,610,456	0	0	0
<b>-4 Khulshi Reservoir 1</b>						
Ground Reservoir	W17.7m×L44.4m×ED7.0m×4Basins	1,865,630	1,865,630			
Inplant Piping	DIP1000-200mm×1,210m	109,682	109,682			
Earth Work		168,796	168,796			
Road Work		75,222	75,222			
Lighting		9,852	9,852			
Sub-Total		2,229,182	2,229,182	0	0	0
<b>-5 Khulshi Reservoir 2</b>						
Elevated Tank	Dia 18m×ED7.0m×16mH	408,370	408,370			
Pump House	W10.0m×L24.0m	78,519	78,519			
Administration Building	W8.0m×L20.0m	32,944	32,944			
Inplant Piping	DIP700-300mm×460m	27,857	27,857			
Earth Work		168,796	168,796			
Road Work		75,204	75,204			
Lighting		9,852	9,852			
Mech & Elec Equipment Installation	Lift Pump, Power Receiving Facilities, Generator	605,044	605,044			
Sub-Total		1,406,586	1,406,586	0	0	0
<b>-6 Patenga BPS</b>						
Ground Reservoir	W16.6m×L33.8m×ED6.0m×4Basins	1,142,222		1,142,222		
Pump House	W12.0m×L28.0m	127,481		127,481		
Inplant Piping	DIP700-300mm×620m	36,885		36,885		
Road Work		58,852		58,852		
Lighting		15,426		15,426		
Mech & Elec Equipment Installation	Lift Pump, Power Receiving Facilities, Generator	720,097		720,097		
Sub-Total		2,100,963	0	2,100,963	0	0
<b>-7 Kalurghat Reservoir</b>						
Ground Reservoir	W16.8m×L47.6m×ED2.87m×2Basins	401,685		401,685		
Oxidation-Sedimentation Basin	W8.5m×L18.0m×ED2.5m×3Basins	138,796		138,796		
Inplant Piping	DIP600-200mm×600m	21,874		21,874		
Road Work		34,907		34,907		
Sub-Total		597,262	0	597,262	0	0
<b>-8 Distribution Pipe</b>						
New Mohara Service Area	(DIP1000-300mm, PVC250-200mm)× 20,985m	1,042,999	1,042,999			
Other Service Area	(DIP800-300mm, PVC250-200mm)×27,305m	1,271,744		1,271,744		
Small Pipeline in New Mohara Service Area (Priority)	PVC200-100mm×66 km	1,198,878	1,198,878			
Small Pipeline in New Mohara Service Area	PVC200-100mm×95 km	1,726,055			1,726,055	
Small Pipeline in Other Service Area (Priority)	PVC200-100mm×43 km	786,915		786,915		
Small Pipeline in Other Service Area	PVC200-100mm×119 km	2,166,104				2,166,104
Sub-Total		8,192,695	2,241,877	2,058,659	1,726,055	2,166,104
<b>-9 Rehabilitation of WTP Facilities</b>						
Rehabilitation of Mohara WTP Facilities(1)	Automatic Backwash system etc.	778,154	778,154			
Rehabilitation of Mohara WTP Facilities(2)	Change of Intake Pump & Spare Parts	735,455	735,455			
Rehabilitation of Kalurghat IRP&BPS Facilities(1)	Filter Rehabilitation etc.	69,299	69,299			
Rehabilitation of Kalurghat IRP&BPS Facilities(2)	Generator	586,105	586,105			
Sub-Total		2,169,013	2,169,013	0	0	0
<b>-10 Zonal Offices and Staff Quarters</b>						
Zonal Offices	800 m2 x 5 offices	740,000	740,000			
Staff Quarters	100 m2 x 40 Flats	740,000	740,000			
Sub-Total		1,480,000	1,480,000	0	0	0
Sub Total (I. Direct Cost)		27,873,178	19,224,135	4,756,884	1,726,055	2,166,104
<b>II. Overhead and Profit</b>						
for ICB (25% of Firect Cost) for all items except small dia.dist. pipe and staff quarters & zonal offices		4,943,807	3,951,314	992,492	0	0
for LCB (12.5% of Firect Cost) for small dia.dist. pipe and staff quarters & zonal offices		919,744	334,860	98,364	215,757	270,763
Sub Total (II. OH&P)		5,863,551	4,286,174	1,090,857	215,757	270,763
<b>III. VAT for Civil Work</b>						
	4.5% of I + II	1,518,153	1,057,964	263,148	87,382	109,659
Total		35,254,881	24,568,273	6,110,889	2,029,193	2,546,526



Table 7.5-1-3 Details of Cost Estimates for Basic Plan Phase 1 Project (Material-1)

(54Taka/US\$)

Equipment	Item	Material Cost (US\$)				C&F, VAT, and Customs Duties & Charges incl PSI (CD)						VAT				Customs Duties and Other Charges (excl PSI)				Pre-shipment Inspection Charge					
		Priority Project		Phase 1 after Priority Pjct.		B/P Phase 1 Total (CIF)	C&F		VAT*		CD		Total (C&F+VAT+CD)						(1% of C&F)						
		New Mohara	Others	New Mohara	Others		CIF/101%	%	C&F x %	3=4-1-2	%	C&F x %													
		-a	-a	-b	-b	1	2	3	4	-a	-a	-b	-b	-a	-a	-b	-b	-a	-a	-b	-b				
<b>-1 Pipe Material</b>																									
1	MWTP Conveyance Pipe	DIP900mm×214m	57,217			57,217	56,650	21.04	11,919	27,997	170.46	96,566	11,919					27,430			567				
2	MWTP Expanson Plant Transmission Pipe	DIP900mm×15,045m	4,223,744			4,223,744	4,181,925	21.04	879,877	2,066,707	170.46	7,128,509	879,877					2,024,888			41,819				
3	Mohara WTP In-plant Piping	DIP1200-300mm×1,263m	313,034			313,034	309,935	21.04	65,210	153,170	170.46	528,315	65,210					150,070			3,099				
4	Khulshi Reservoir In-plant Piping	DIP1000-200mm×1,210m	361,732			361,732	358,150	21.04	75,355	176,998	170.46	610,503	75,355					173,416			3,582				
5	Khulshi Elevated Tank In-plant Piping	DIP700-300mm×460m	71,780			71,780	71,069	21.04	14,953	35,122	170.46	121,145	14,953					34,412			711				
6	Kalurghat Reservoir In-plant Piping	DIP800-400mm×400m		196,867		196,867	194,918	21.04	41,011	96,328	170.46	332,257		41,011				94,379			1,949				
7	Patenga Reservoir In-plant Piping	DIP700-300mm×620m		331,967		331,967	328,680	21.04	69,154	162,434	170.46	560,268		69,154				159,147			3,287				
8	New Mohara Service Area - 1	DIP1000-300mm×14,080m	2,268,042			2,268,042	2,245,586	21.04	472,471	1,109,769	170.46	3,827,826	472,471					1,087,313			22,456				
9	New Mohara Service Area - 2	PVC250-200mm×6,905m	464,523			464,523	459,924	21.04	96,768	227,294	170.46	783,986	96,768					222,695			4,599				
10	Other Service Area - 2	DIP800-300mm×21,170m		2,427,431		2,427,431	2,403,397	21.04	505,675	1,187,759	170.46	4,096,831		505,675				1,163,725			24,034				
11	Other Service Area - 3	PVC250-200mm×6,135m		423,706		423,706	419,511	21.04	88,265	207,322	170.46	715,098		88,265				203,127			4,195				
12	Small Pipeline in New Mohara S.A. (Priority)	PVC200-100mm×66 km	1,727,381			1,727,381	1,710,278	21.04	359,843	845,219	170.46	2,915,340	359,843					828,117			17,103				
13	Small Pipeline in New Mohara Service Area	PVC200-100mm×95 km			2,486,954	2,486,954	2,462,331	21.04	518,074	1,216,884	170.46	4,197,289		518,074				1,192,261			24,623				
14	Small Pipeline in Other Service Area (Priority)	PVC200-100mm×43 km		1,133,812		1,133,812	1,122,586	21.04	236,192	554,782	170.46	1,913,560		236,192				543,556			11,226				
15	Small Pipeline in Other Service Area	PVC200-100mm×119 km			3,120,991	3,120,991	3,090,090	21.04	650,155	1,527,123	170.46	5,267,368			650,155			1,496,222			30,901				
	Sub-Total		9,487,453	4,513,783	2,486,954	3,120,991	19,609,181	19,415,031	4,084,922	9,594,908		33,094,861	1,976,396	940,297	518,074	650,155	4,548,341	2,163,934	1,192,261	1,496,222	93,935	44,691	24,623	30,901	
<b>-2 Mechanical Equipment</b>																									
1	Mohara WTP Intake Pump	42.1m3/min×15.2m×2units	559,720			559,720	554,178	18.20	100,878	166,123	148.18	821,179	100,878					160,581			5,542				
2	Mohara WTP Facilities	Mechanical Equip, Chemical Dosing Fac.	2,860,259			2,860,259	2,831,940	18.36	519,944	895,742	149.99	4,247,626	519,944					867,423			28,319				
3	Transmission Pump	15.8m3/min×84m×5units	1,266,167			1,266,167	1,253,631	18.09	226,835	360,058	146.82	1,840,523	226,835					347,521			12,536				
4	Khulshi Uplift Pump	13.1m3/min×25m×4units	843,981			843,981	835,625	18.09	151,200	240,001	146.82	1,226,826	151,200					231,645			8,356				
5	Patenga Distribution Pump	19.2m3/min×37m×3units		953,185		953,185	943,748	18.09	170,764	271,056	146.82	1,385,567		170,764				261,618			9,437				
6	Rehabilitation of Mohara WTP Facilities - 1	Automated Backwash system etc.	408,123			408,123	404,082	18.36	74,189	127,811	149.99	606,083	74,189					123,770			4,041				
7	Rehabilitation of Mohara WTP Facilities - 2	Change of Intake Pump, Dist. Pump & Spare Parts	708,989			708,989	701,969	18.20	127,781	210,425	148.18	1,040,176	127,781					203,405			7,020				
8	Rehabilitation of Kalurghat IRP&BPS Facilities - 1	Filter Rehabilitation etc.	41,812			41,812	41,398	18.36	7,601	13,094	149.99	62,093	7,601					12,680			414				
9	Rehabilitation of Kalurghat IRP&BPS Facilities - 2	Generator	545,376			545,376	539,976	16.07	86,774	88,178	132.40	714,929	86,774					82,778			5,400				
	Sub-Total		7,234,427	953,185	0	0	8,187,612	8,106,547	1,465,967	2,372,489		11,945,002	1,295,203	170,764	0	0	2,029,805	261,618	0	0	71,628	9,437	0	0	
<b>-3 Electrical Equipment</b>																									
1	Mohara WTP Facilities	Power receiving, Generator, Telemetering	1,462,444			1,462,444	1,447,964	17.60	254,842	383,276	144.07	2,086,082	254,842					368,797			14,480				
2	Khulshi Uplift Pump	Power receiving, Generator	268,419			268,419	265,761	17.60	46,774	70,347	144.07	382,882	46,774					67,689			2,658				
3	Patenga Distribution Pump	Power receiving, Generator		325,996		325,996	322,768	17.60	56,807	85,437	144.07	465,012		56,807				82,209			3,228				
	Sub-Total		1,730,863	325,996	0	0	2,056,859	2,036,494	358,423	539,060		2,933,977	301,616	56,807	0	0	436,486	82,209	0	0	17,137	3,228	0	0	
	<b>Total</b>		<b>18,452,743</b>	<b>5,792,964</b>	<b>2,486,954</b>	<b>3,120,991</b>	<b>29,853,652</b>	<b>29,558,071</b>	<b>5,909,312</b>	<b>12,506,457</b>		<b>47,973,840</b>	<b>3,573,215</b>	<b>1,167,868</b>	<b>518,074</b>	<b>650,155</b>	<b>7,014,632</b>	<b>2,507,762</b>	<b>1,192,261</b>	<b>1,496,222</b>	<b>182,700</b>	<b>57,356</b>	<b>24,623</b>	<b>30,901</b>	
<b>-4 Customs Duties, etc.</b>																									
	Customs Duties and Other Charges	(Average 41% of CIF)	7,014,632	2,507,762	1,192,261	1,496,222	12,210,876																		
	VAT	(Average 20% of CIF)	3,573,215	1,167,868	518,074	650,155	5,909,312																		
	Pre-shipment Inspection Fee	(Average 1% of CIF)	182,700	57,356	24,623	30,901	295,581																		
	<b>Sub-Total</b>	<b>(Average 62% of CIF)</b>	<b>10,770,547</b>	<b>3,732,986</b>	<b>1,734,958</b>	<b>2,177,277</b>	<b>18,415,769</b>																		
	<b>Total</b>		<b>29,223,290</b>	<b>9,525,950</b>	<b>4,221,912</b>	<b>5,298,268</b>	<b>48,269,421</b>																		

7.5-1-3

\*: VAT is charged as 15% of Assessment Value and Customs Duties.

**Table 7.5-1-4 Details of Cost Estimates for Basic Plan Phase 1 Project (Material-2)**

54Taka/\$

Equipment	Item	Material Cost (CIF) (US\$)	C&F, VAT, and Customs Duties & Charges incl PSI (CD)						VAT	Customs Duties and Other Charges (excl PSI)	Pre-shipment Inspection (1% of C&F)
			C&F	VAT		CD	Total (C&F+VAT+CD)				
			CIF/101%	%	C&F x %	3=4-1-2	%	C&F x %			
			1		2	3		4			
<b>-1 Material</b>											
1 Water Meter	20-150mm×25,000units	589,270	583,436	15.00	87,515	340,726	173.40	1,011,677	87,515	334,892	5,834
Sub-Total		589,270	583,436		87,515	340,726		1,011,677	87,515	334,892	5,834
2 Vehicle	sedan*2viecle+jeep*2viecle	92,593	91,676	15.00	13,751	50,844	170.46	156,271	13,751	49,927	917
Sub-Total		92,593	91,676		13,751	50,844		156,271	13,751	49,927	917
3 Computer	8 sets	22,222	22,002	0.00	0	0	100.00	22,002	0	0	0
Sub-Total		22,222	22,002		0	0		22,002	0	0	0
<b>TOTAL</b>		<b>704,085</b>	<b>697,114</b>		<b>101,267</b>	<b>391,792</b>		<b>1,189,951</b>	<b>101,268</b>	<b>384,820</b>	<b>6,751</b>
<b>-2 Customs Duties, etc.</b>											
Customs Duties and Other Charges	(Average 55% of CIF)	384,820									
VAT	(Average 14% of CIF)	101,268									
Pre-shipment Inspection Fee	(Average 1% of CIF)	6,751									
Sub-Total	(Average 70% of CIF)	<b>492,840</b>									
<b>GRAND TOTAL</b>		<b>1,196,925</b>									

7.5-1-4

**Table 7.5-1-5 Construction Cost Breakdown of Phase 1 - 1**

Unit : Taka

No.	Name of Facility	Item	Dimension	Unit	Unit Cost	Quantity	Price	Note	E&M	Civil (incl. materials)
1	Intake Pump Facilities									
1-1	In t ake Pump		42.1m <sup>3</sup> /min ×15.3m ×1 (+1)	set		1	50,489,000	Inverter Control 1 unit	50,489,000	
1-2	Conveyance Pipe		DIP900mmTP	m	15,671	214	3,353,594			3,353,594
	(Intake Pump Station ~ Receiving Well)									
	Sub Total						53,842,594		50,489,000	3,353,594
2	Treatment Plant Facilities									
2-1	Receiving Well	Civil Work		L.S.		1	3,231,209			3,231,209
	(Distribution Chamber)	Mechanical & Electrical Cost		L.S.		1	10,899,000		10,899,000	
2-2	Desilting Basin	Civil Work		L.S.		1	74,961,000			74,961,000
		Mechanical & Electrical Cost		L.S.		1	36,947,000		36,947,000	
2-3	Rapid Mixing Basin	Civil Work		L.S.		1	372,000			372,000
		Mechanical & Electrical Cost		L.S.		1	1,530,000		1,530,000	
2-4	Clarifier	Civil Work		L.S.		1	45,654,000			45,654,000
		Mechanical & Electrical Cost		L.S.		1	12,620,000		12,620,000	
2-5	Filter	Civil Work		L.S.		1	63,864,000			63,864,000
		Mechanical & Electrical Cost		L.S.		1	32,546,000		32,546,000	
2-6	Clear Well	Civil Work	6,716m <sup>3</sup>	L.S.		1	53,290,000			53,290,000
		Mechanical & Electrical Cost		L.S.		1	9,561,000		9,561,000	
2-7	Transmission Pump House	Civil Work		L.S.		1	12,147,000			12,147,000
2-8	Sludge Tank	Civil Work		L.S.		1	7,156,000			7,156,000
		Mechanical & Electrical Cost		L.S.		1	19,313,000		19,313,000	
2-9	Chemical Building & Chlorination room	Civil Work		L.S.		1	11,948,000			11,948,000
2-10	Laboratory & Control room	Civil Work		L.S.		1	4,744,000			4,744,000
		Mechanical & Electrical Cost		L.S.		1	74,536,000	Including Water analysis Equipment	74,536,000	
2-11	Alum Dosing Facilities	Mechanical & Electrical Cost		L.S.		1	5,124,000		5,124,000	
2-12	Lime Dosing Facilities	Mechanical & Electrical Cost		L.S.		1	8,987,000		8,987,000	
2-13	Chlorination Facilities	Mechanical & Electrical Cost		L.S.		1	21,033,000		21,033,000	
2-14	Power Receiving Facility	Mechanical & Electrical Cost	3500 KVA	L.S.		1	22,512,000		22,512,000	
2-15	Generator	Mechanical & Electrical Cost	1250 KVA ×2	L.S.		1	66,340,000		66,340,000	
2-16	TM Facilities	Mechanical & Electrical Cost		L.S.		1	29,040,000		29,040,000	
2-17	Inplant Piping			L.S.		1	28,663,759			28,663,759
2-18	Road Work			L.S.		1	7,926,000			7,926,000
2-19	Lighting			L.S.		1	1,556,000			1,556,000
	Sub Total						666,500,968		350,988,000	315,512,968
3	Transmission Facilities									
3-1	Transmission Pump	Mechanical & Electrical Cost	15.8m <sup>3</sup> /min ×84.m ×4 (+1)	L.S.		1	98,706,000		98,706,000	
3-2	Transmission Pipe		DIP900mmT	m	18,924	15,045	284,713,837			284,713,837
	Sub Total						383,419,837		98,706,000	284,713,837
4	Distribution Facilities									
4-1	Khulushi Reservoir	Ground Reservoir 4 Basin	19,600 m <sup>3</sup>	L.S.		1	100,744,000			100,744,000
		Inplant Piping		L.S.		1	25,456,000			25,456,000
		Earth Work		L.S.		1	9,115,000			9,115,000
		Road Work		L.S.		1	4,062,000			4,062,000
		Lighting		L.S.		1	532,000			532,000
	Sub Total						139,909,000		0	139,909,000
4-2	Distribution Pipe		DIP1000mmD	m	23,472	1,140	26,757,852			26,757,852
			DIP900mmD	m	19,825	910	18,041,023			18,041,023
			DIP800mmD	m	16,587	2,875	47,687,338			47,687,338
			DIP700mmD	m	13,651	200	2,730,200			2,730,200
			DIP600mmD	m	11,570	985	11,396,253			11,396,253
			DIP500mmD	m	9,085	3,515	31,933,424			31,933,424
			DIP450mmD	m	7,931	810	6,424,110			6,424,110
			DIP350mmD	m	6,076	420	2,552,088			2,552,088
			DIP300mmD	m	5,235	3,225	16,882,553			16,882,553
			PVC250mmD	m	6,477	4,065	26,328,192			26,328,192
			PVC200mmD	m	4,629	2,840	13,147,428			13,147,428
	Sub Total						203,880,460		0	203,880,460
5	Existing Treatment Plant Facilities Rehabilitation									
5-1	MWTP Filter Rehabilitation	Civil Work		L.S.		1	19,159,000			19,159,000
		Mechanical & Electrical Cost		L.S.		1	24,900,000		24,900,000	
		Others		L.S.		1	20,000,000	Reinforcement of Alum Dosing etc.	20,000,000	
	Sub Total	Rehabilitation 1 (Mohara WTP)					64,059,000		44,900,000	19,159,000
5-2	MWTP Replace of Intake pump etc.	Civil Work		L.S.		1	0			0
	Intake Pump	Mechanical & Electrical Cost	33.18m <sup>3</sup> /min ×14.3m ×1	L.S.		1	43,000,000	Inverter Control type	43,000,000	
	Distribution Pump	Mechanical & Electrical Cost	15.8m <sup>3</sup> /min ×87.m ×1	L.S.		1	25,000,000	Spare Parts	25,000,000	
		Others		L.S.		1	10,000,000		10,000,000	
	Sub Total	Rehabilitation 2 (Mohara WTP)					78,000,000		78,000,000	0
	<b>Total (Direct Construction Cost)</b>						<b>1,589,611,859</b>		<b>623,083,000</b>	<b>966,528,859</b>

**Table 7.5-1-6 Construction Cost Breakdown of Phase 1 - 2**

Unit : Taka

No.	Name of Facility	Item	Dimension	Unit	Unit Cost	Quantity	Price	Note	E&M	Civil (incl. materials)	
1	Distribution Facilities										
1-1	Khulshi Reservoir	Elevated Tank	dia18m ×7mD ×16mH	L.S.		1	22,052,000			22,052,000	
		Lift Pump	13.1m <sup>3</sup> /min ×25m ×3 (+1)	L.S.		1	65,794,000		65,794,000		
		Pump House		L.S.		1	4,240,000			4,240,000	
		Power Receiving Facility	500 KVA	L.S.		1	4,393,000		4,393,000		
		Generator	250 KVA ×2	L.S.		1	22,555,000		22,555,000		
		Administration Building		L.S.		1	1,779,000			1,779,000	
		Inplant Piping		L.S.		1	5,380,000			5,380,000	
		Earth Work		L.S.		1	9,115,000			9,115,000	
		Road Work		L.S.		1	4,061,000			4,061,000	
		Lighting		L.S.		1	532,000			532,000	
	Sub Total						139,901,000	¥370,737,650	92,742,000	47,159,000	
1-2	Patenga BPS										
		Ground Reservoir	12,000 m <sup>3</sup>	L.S.		1	61,680,000	Including Chlorination Facilities		61,680,000	
		Booster Pumps	19.2m <sup>3</sup> /min ×37m ×2 (+1)	L.S.		1	74,306,000		74,306,000		
		Pump House		L.S.		1	6,884,000			6,884,000	
		Power Receiving Facility	750 KVA	L.S.		1	6,589,000		6,589,000		
		Generator	300 KVA ×2	L.S.		1	27,066,000		27,066,000		
		Inplant Piping		L.S.		1	19,918,000			19,918,000	
		Road Work		L.S.		1	3,178,000			3,178,000	
		Lighting		L.S.		1	833,000			833,000	
	Sub Total						200,454,000	¥531,203,100	107,961,000	92,493,000	
1-3	Kalurghat IRP&BPS										
		Ground Reservoir	4,220 m <sup>3</sup>	L.S.		1	21,691,000			21,691,000	
		Oxidation-Sedimentation Basin		L.S.		1	7,495,000			7,495,000	
		Inplant Piping		L.S.		1	11,812,000			11,812,000	
		Road Work		L.S.		1	1,885,000			1,885,000	
	Sub Total						42,883,000	¥113,639,950	0	42,883,000	
1-4	Kalurghat IRP										
		Rehabilitation of Filter	Civil Work	L.S.		1	1,400,000	Trough, change of sand		1,400,000	
		Rehabilitation of Filter	Mechanical & Electrical Cost	L.S.		1	3,100,000	Air supply system	3,100,000		
		Others		L.S.		1	1,500,000	Generator etc.	1,500,000		
	Sub Total	Rehabilitation 1					6,000,000		4,600,000	1,400,000	
1-5	Kalurghat BPS										
		Generator Room	Civil Work	L.S.		1	1,100,000	Trough, change of sand		1,100,000	
		Generator 1,000KVA	Mechanical & Electrical Cost	L.S.		1	50,000,000	Air supply system	50,000,000		
		Others		L.S.		1	10,000,000	Oil Tank etc.	10,000,000		
	Sub Total	Rehabilitation 2					61,100,000		60,000,000	1,100,000	
1-6	Distribution Pipe	Stage 2									
			DIP800mmD	m	16,587	2,280	37,818,132			37,818,132	
			DIP700mmD	m	13,651	730	9,965,230			9,965,230	
			DIP600mmD	m	11,570	3,775	43,675,995			43,675,995	
			DIP500mmD	m	9,085	1,510	13,718,199			13,718,199	
			DIP450mmD	m	7,931	3,110	24,665,410			24,665,410	
			DIP400mmD	m	6,918	1,725	11,933,378			11,933,378	
			DIP350mmD	m	6,076	3,530	21,449,692			21,449,692	
			DIP300mmD	m	5,235	4,510	23,609,399			23,609,399	
			PVC250mmD	m	6,477	4,005	25,939,584			25,939,584	
			PVC200mmD	m	4,629	2,130	9,860,571			9,860,571	
	Sub Total					27,305	222,635,590	¥589,984,313	0	222,635,590	
2	Distribution Small Pipe (New Mohara WTP Area)										
2-1	Distribution Small Pipe	PVC200 ~ 100mm	Immediate	L.S.		1	64,739,422			64,739,422	
2-2	Distribution Small Pipe	PVC200 ~ 100mm	Non-immediate	L.S.		1	93,206,982			93,206,982	
	Sub Total						157,946,404	¥418,557,971		157,946,404	
3	Distribution Small Pipe (Other Area)										
3-1	Distribution Small Pipe	PVC200 ~ 100mm	Immediate	L.S.		1	42,493,408			42,493,408	
3-2	Distribution Small Pipe	PVC200 ~ 100mm	Non-immediate	L.S.		1	116,969,636			116,969,636	
	Sub Total						159,463,044	¥422,577,066	0	159,463,044	
	Total (Direct Construction Cost)							990,383,038	¥2,624,515,050	265,303,000	725,080,038

**Table 7.5-1-7 Other Costs**

Unit: US\$ (54Taka/\$)

Item	Cost	Customs Duties (w/out VAT&PSI)	VAT	Pre-shipment Inspection Cost	Total
1 Water Meter (25,000sets)	589,270	334,892	87,515	5,834	1,011,677
2 Vicle (Sedan2, Jeep2)	92,593	49,927	13,751	917	156,271
3 Computer (8sets)	22,222	0	0	0	22,222
4 Administration Cost	128,000	-	-	-	128,000
5 Land Acquisition	3,370,370	-	-	-	3,370,370
Total	4,202,455	384,819	101,267	6,751	4,688,541

**Table 7.5-1-8 Procurement of Water Meter**

(54Taka/\$)

	Diameter	Unit Cost (Taka)	Quantity	Cost (Taka)	Cost (US\$)
1	20mm	1,049	22,000	23,078,000	427,370
2	25mm	2,608	2,850	7,432,800	137,644
3	50mm	6,804	100	680,400	12,600
4	100mm	11,057	40	442,280	8,190
5	150mm	18,711	10	187,110	3,465
	Total		25,000	31,820,590	589,270

**Table 7.5-1-9 Land Acquisition Cost**

(54Taka/\$)

	Land	Area (m2)	Unit Cost (Taka/m2)	Land Acquisition Cost (Taka)	Remark
1	Mohara WTP	500	3,000	1,500,000	
2	Karnaphuri WTP	100,000	2,500	250,000,000	
3	Khulshi Reservoir	17,000	8,500	144,500,000	
4	Nashirabad Reservoir	26,000	5,600	145,600,000	
5	Patenga Reservoir	18,000	4,000	72,000,000	
6	Salimpur	13,000	3,000	39,000,000	US\$
	Total	174,500		652,600,000	12,085,185
	Total (1+3+5*(1/2)) for FS Project			182,000,000	3,370,370

**Table 7.5-1-10 Administration Cost**

(54Taka/\$)

	Man Power	Salary (Taka/month)	Detail Design Stage 1year			Construction Stage 3years		
			No.	MM	Cost	No.	MM	Cost
1	Project Director	22,000	1	12	264,000	1	36	792,000
2	Executive Engineer	20,000	1	12	240,000	1	36	720,000
3	Assistant Engineer	8,000	1	12	96,000	3	108	864,000
4	Chemist	8,000	0	0	0	1	3	24,000
5	Sub Assistant Engineer	6,000	0	0	0	5	180	1,080,000
6	Laboratory Assistant	5,000	0	0	0	2	6	30,000
7	Inspector	4,000	0	0	0	8	288	1,152,000
8	Upper Assistant Clerk	4,000	0	0	0	2	72	288,000
9	Lower Assistant Clerk	3,500	0	0	0	3	108	378,000
10	Driver	4,000	1	12	48,000	4	144	576,000
11	MLSS	3,000	1	12	36,000	3	108	324,000
	Sub Total				684,000			6,228,000
Total (Detail Design Stage & Construction Stage)							Taka	6,912,000
							US\$	128,000



7.5-1-12 Engineering Cost Details (Annual Summary)

	Priority Project Total			2002			2003			2004			2005			2006							
	Local	Foreign	Total	Local	Foreign	Total	Local	Foreign	Total	Local	Foreign	Total	Local	Foreign	Total	Local	Foreign	Total					
Expatriate (Per Diem + Remuneration)																							
PM	117,600	1,450,400	1,568,000	26,400	325,600	352,000	26,400	325,600	352,000	26,400	325,600	352,000	26,400	325,600	352,000	12,000	148,000	160,000					
WTP-Civil	26,400	281,600	308,000	26,400	281,600	308,000	0	0	0	0	0	0	0	0	0	0	0	0					
Civil2	21,600	203,400	225,000	21,600	203,400	225,000	0	0	0	0	0	0	0	0	0	0	0	0					
Pipe1	26,400	248,600	275,000	26,400	248,600	275,000	0	0	0	0	0	0	0	0	0	0	0	0					
Pipe2	9,600	90,400	100,000	9,600	90,400	100,000	0	0	0	0	0	0	0	0	0	0	0	0					
Mech1	15,600	166,400	182,000	9,600	102,400	112,000	1,200	12,800	14,000	1,200	12,800	14,000	2,400	25,600	28,000	1,200	12,800	14,000					
Elec1	15,600	166,400	182,000	9,600	102,400	112,000	1,200	12,800	14,000	1,200	12,800	14,000	2,400	25,600	28,000	1,200	12,800	14,000					
Arch1	14,400	153,600	168,000	9,600	102,400	112,000	0	0	0	1,200	12,800	14,000	2,400	25,600	28,000	1,200	12,800	14,000					
Structure 1	12,000	128,000	140,000	12,000	128,000	140,000	0	0	0	0	0	0	0	0	0	0	0	0					
Water Quality 1	12,000	113,000	125,000	2,400	22,600	25,000	0	0	0	0	0	0	4,800	45,200	50,000	4,800	45,200	50,000					
Spec1	12,000	113,000	125,000	9,600	90,400	100,000	2,400	22,600	25,000	0	0	0	0	0	0	0	0	0					
Inspector	76,800	723,200	800,000	0	0	0	14,400	135,600	150,000	26,400	248,600	275,000	26,400	248,600	275,000	9,600	90,400	100,000					
ST	360,000	3,838,000	4,198,000	163,200	1,697,800	1,861,000	45,600	509,400	555,000	56,400	612,600	669,000	64,800	696,200	761,000	30,000	322,000	352,000					
Local Engineer																							
Civil1	54,000	0	54,000	12,000	0	12,000	12,000	0	12,000	12,000	0	12,000	12,000	0	12,000	6,000	0	6,000					
Civil2	6,000	0	6,000	6,000	0	6,000	0	0	0	0	0	0	0	0	0	0	0	0					
Pipe1	6,000	0	6,000	6,000	0	6,000	0	0	0	0	0	0	0	0	0	0	0	0					
Pipe2	4,000	0	4,000	4,000	0	4,000	0	0	0	0	0	0	0	0	0	0	0	0					
Mech1	3,000	0	3,000	3,000	0	3,000	0	0	0	0	0	0	0	0	0	0	0	0					
Elec1	3,000	0	3,000	3,000	0	3,000	0	0	0	0	0	0	0	0	0	0	0	0					
Arch1	4,200	0	4,200	4,200	0	4,200	0	0	0	0	0	0	0	0	0	0	0	0					
Arch2	2,800	0	2,800	2,800	0	2,800	0	0	0	0	0	0	0	0	0	0	0	0					
Structure1	3,000	0	3,000	3,000	0	3,000	0	0	0	0	0	0	0	0	0	0	0	0					
Structure2	2,000	0	2,000	2,000	0	2,000	0	0	0	0	0	0	0	0	0	0	0	0					
Quantity Survey1	1,600	0	1,600	1,600	0	1,600	0	0	0	0	0	0	0	0	0	0	0	0					
Quantity Survey2	1,600	0	1,600	1,600	0	1,600	0	0	0	0	0	0	0	0	0	0	0	0					
Soil Survey	1,600	0	1,600	1,600	0	1,600	0	0	0	0	0	0	0	0	0	0	0	0					
Topo Survey	2,400	0	2,400	2,400	0	2,400	0	0	0	0	0	0	0	0	0	0	0	0					
Mohara Inspector1	14,400	0	14,400	0	0	0	2,400	0	2,400	4,800	0	4,800	4,800	0	4,800	2,400	0	2,400					
Kalurghat Inspector2	10,800	0	10,800	0	0	0	2,400	0	2,400	4,800	0	4,800	3,600	0	3,600	0	0	0					
Khulshi Inspector3	10,800	0	10,800	0	0	0	2,400	0	2,400	4,800	0	4,800	3,600	0	3,600	0	0	0					
Patenga Inspector4	10,800	0	10,800	0	0	0	2,400	0	2,400	4,800	0	4,800	3,600	0	3,600	0	0	0					
Pipeline Inspector5	14,400	0	14,400	0	0	0	2,400	0	2,400	4,800	0	4,800	4,800	0	4,800	2,400	0	2,400					
Pipeline Inspector6	10,800	0	10,800	0	0	0	2,400	0	2,400	4,800	0	4,800	3,600	0	3,600	0	0	0					
Pipeline Inspector7	10,800	0	10,800	0	0	0	2,400	0	2,400	4,800	0	4,800	3,600	0	3,600	0	0	0					
ST	178,000	0	178,000	53,200	0	53,200	28,800	0	28,800	45,600	0	45,600	39,600	0	39,600	10,800	0	10,800					
Admin Staff																							
Manager1	21,600	0	21,600	4,800	0	4,800	4,800	0	4,800	4,800	0	4,800	4,800	0	4,800	2,400	0	2,400					
Clark1	8,100	0	8,100	1,800	0	1,800	1,800	0	1,800	1,800	0	1,800	1,800	0	1,800	900	0	900					
Clark2	7,200	0	7,200	1,800	0	1,800	1,800	0	1,800	1,800	0	1,800	1,800	0	1,800	0	0	0					
Draughtsman1	8,100	0	8,100	1,800	0	1,800	1,800	0	1,800	1,800	0	1,800	1,800	0	1,800	900	0	900					
Draughtsman2	1,650	0	1,650	1,650	0	1,650	0	0	0	0	0	0	0	0	0	0	0	0					
Draughtsman3	1,200	0	1,200	1,200	0	1,200	0	0	0	0	0	0	0	0	0	0	0	0					
Draughtsman4	1,200	0	1,200	1,200	0	1,200	0	0	0	0	0	0	0	0	0	0	0	0					
Driver1	4,320	0	4,320	960	0	960	960	0	960	960	0	960	960	0	960	480	0	480					
Driver2	4,320	0	4,320	960	0	960	960	0	960	960	0	960	960	0	960	480	0	480					
Driver3	3,840	0	3,840	960	0	960	960	0	960	960	0	960	960	0	960	0	0	0					
Driver4	3,840	0	3,840	960	0	960	960	0	960	960	0	960	960	0	960	0	0	0					
Guard1	2,700	0	2,700	600	0	600	600	0	600	600	0	600	600	0	600	300	0	300					
Guard2	2,700	0	2,700	600	0	600	600	0	600	600	0	600	600	0	600	300	0	300					
Guard3	2,700	0	2,700	600	0	600	600	0	600	600	0	600	600	0	600	300	0	300					
Peon1	2,700	0	2,700	600	0	600	600	0	600	600	0	600	600	0	600	300	0	300					
ST	76,170	0	76,170	20,490	0	20,490	16,440	0	16,440	16,440	0	16,440	16,440	0	16,440	6,360	0	6,360					
Rem. + Per Diem Total	614,000	3,838,000	4,452,000	237,000	1,698,000	43%	1,935,000	91,000	509,000	13%	600,000	118,000	613,000	16%	731,000	121,000	696,000	18%	817,000	47,000	322,000	8%	369,000
Office Rental & Misc.	108,000	0	108,000	24,000	0	24,000	24,000	0	24,000	24,000	0	24,000	24,000	0	24,000	12,000	0	12,000					
Trip	0	164,000	164,000	0	64,000	64,000	0	20,000	20,000	0	20,000	20,000	0	36,000	36,000	0	24,000	24,000					
Topo. Survey	60,000	0	60,000	60,000	0	60,000	0	0	0	0	0	0	0	0	0	0	0	0					
Soil Investigation	0	20,000	20,000	0	20,000	20,000	0	0	0	0	0	0	0	0	0	0	0	0					
Grand Total	782,000	4,022,000	4,804,000	321,000	1,782,000	44%	2,103,000	115,000	529,000	13%	644,000	142,000	633,000	16%	775,000	145,000	732,000	18%	877,000	59,000	346,000	8%	405,000

7.5-1-9

<b>Table 7.5-1-13 Pipe Installation Cost</b>						
<b>Item</b>		<b>Dia</b>	<b>Installation Cost (per meter)</b>	<b>Pipe Material (per meter)</b>	<b>Total Cost (per meter)</b>	<b>Soil Cover (m)</b>
<b>Plant Area</b>	1	DIP200mmTP	TK1,267	TK1,831	TK3,098	2.00
<b>(excluding road Pavement</b>	2	DIP300mmTP	TK550	TK2,833	TK3,383	2.00
<b>by CDA)</b>	3	DIP400mmTP	TK623	TK4,122	TK4,745	2.00
	4	DIP450mmTP	TK661	TK4,903	TK5,564	2.00
	5	DIP600mmTP	TK873	TK7,764	TK8,637	2.00
	6	DIP700mmTP	TK974	TK9,398	TK10,372	2.00
	7	DIP900mmTP	TK1,233	TK14,438	TK15,671	2.00
	8	DIP1000mmTP	TK1,396	TK17,434	TK18,830	2.00
	9	DIP1200mmTP	TK1,747	TK24,063	TK25,810	2.00
	10	DIP1400mmTP	TK2,130	TK31,826	TK33,956	2.00
<b>Transmission Pipe</b>	10	DIP1400mmT	TK5,529	TK33,417	TK38,946	1.20
<b>(including road pavement</b>	11	DIP1200mmT	TK4,798	TK25,266	TK30,064	1.20
<b>by CDA)</b>	12	DIP1100mmT	TK3,645	TK21,690	TK25,335	1.20
	13	DIP1000mmT	TK4,099	TK18,306	TK22,405	1.20
	14	DIP900mmT	TK3,764	TK15,160	TK18,924	1.20
	15	DIP800mmT	TK3,486	TK12,347	TK15,833	1.20
	16	DIP700mmT	TK3,163	TK9,868	TK13,031	1.20
	17	DIP600mmT	TK2,892	TK8,152	TK11,044	1.20
	18	DIP500mmT	TK2,570	TK6,102	TK8,672	1.20
	19	DIP450mmT	TK2,423	TK5,148	TK7,571	1.20
	20	DIP400mmT	TK2,275	TK4,328	TK6,603	1.20
	21	DIP350mmT	TK2,148	TK3,652	TK5,800	1.20
	22	DIP300mmT	TK2,022	TK2,975	TK4,997	1.20
	23	PVC250mmT	TK2,123	TK4,059	TK6,182	1.20
	24	PVC200mmT	TK1,799	TK2,620	TK4,419	1.20
<b>Distribution Pipe</b>	25	DIP1400mmD	TK5,791	TK35,009	TK40,800	1.20
<b>(including road pavement</b>	26	DIP1200mmD	TK5,026	TK26,469	TK31,495	1.20
<b>by CDA)</b>	27	DIP1100mmD	TK3,819	TK22,723	TK26,542	1.20
	28	DIP1000mmD	TK4,295	TK19,177	TK23,472	1.20
	29	DIP900mmD	TK3,943	TK15,882	TK19,825	1.20
	30	DIP800mmD	TK3,652	TK12,935	TK16,587	1.20
	31	DIP700mmD	TK3,313	TK10,338	TK13,651	1.20
	32	DIP600mmD	TK3,030	TK8,540	TK11,570	1.20
	33	DIP500mmD	TK2,693	TK6,392	TK9,085	1.20
	34	DIP450mmD	TK2,538	TK5,393	TK7,931	1.20
	35	DIP400mmD	TK2,384	TK4,534	TK6,918	1.20
	36	DIP350mmD	TK2,250	TK3,826	TK6,076	1.20
	37	DIP300mmD	TK2,119	TK3,116	TK5,235	1.20
	38	PVC250mmD	TK2,224	TK4,253	TK6,477	1.20
	39	PVC200mmD	TK1,884	TK2,745	TK4,629	1.20
<b>Distribution Small Pipe</b>	40	PVC200mmD(S)	TK1,096	TK2,745	TK3,841	1.00
<b>(including road pavement</b>	41	PVC150mmD	TK1,017	TK1,693	TK2,710	1.00
<b>by CDA)</b>	42	PVC100mmD	TK930	TK880	TK1,810	1.00



**Table 7.5-1-14 Existing Small Diameter Distribution Pipeline Network Installation Cost (Taka)**

**Table 7.5-1-15 Breakdown of Existing Small Diameter Distribution Pipeline Network Installation Cost (Taka)**

Dia. (mm)	Length (m)	Installation Cost (Tk/m)	Installation Cost (Taka)	Existing Service Area (ha)	Unit Cost of Distribution Pipe Installation (Taka/ha)	Dia. (mm)	Installation Cost (per meter)		Pipe Material (per meter)		Total Cost (per meter)	Pipe Material Total	Installation Cost Total	Total Cost (Taka)
PVC200mmD(s)	83,980	3,841	322,539,986	-	-	PVC200mmD(s)	1,096	29%	2,745	71%	3,841	230,525,000	92,015,000	322,540,000
PVC150mmD	81,100	2,710	219,800,696	-	-	PVC150mmD	1,017	38%	1,693	62%	2,710	137,302,000	82,499,000	219,801,000
PVC100mmD	252,710	1,810	457,503,777	-	-	PVC100mmD	930	51%	880	49%	1,810	222,385,000	235,119,000	457,504,000
<b>Total</b>	<b>417,790</b>		<b>999,844,459</b>	<b>1,906</b>	<b>524,698</b>	<b>Total</b>						<b>590,212,000</b>	<b>409,633,000</b>	<b>999,845,000</b>
					<b>&gt;0.8= 420,000</b>							<b>59.0%</b>	<b>41.0%</b>	<b>100%</b>

**Table 7.5-1-16 Small Diameter Distribution Pipeline Network Length & Cost (Total of Priority Project, B/P Phase 1 and B/P Phase 2)**

Dia. (mm)	Unit Length (m/ha)	Length		Installation Cost (Taka)		Pipe Material Cost (Taka)		Total (Taka)
		New Mohara Area*	Others	New Mohara Area*	Others	New Mohara Area*	Others	
Area(ha)	1 ha	3,684 ha	4,514 ha					
PVC200mmD	35 m/ha	129,889 m	159,150 m					
PVC150mmD	34 m/ha	125,435 m	153,692 m					
PVC100mmD	106 m/ha	390,859 m	478,909 m					
<b>Total</b>	<b>175 m/ha</b>	<b>646,183 m</b>	<b>791,752 m</b>	<b>633,931,631</b>	<b>776,740,584</b>	<b>913,388,462</b>	<b>1,119,152,055</b>	<b>3,443,212,733</b>
			<b>1,437,935 m</b>			<b>1,547,320,093</b>	<b>1,895,892,639</b>	

\*: Based on boundaries of Service Blocks for B/P Phase 1.

**Table 7.5-1-17 Small Diameter Distribution Pipeline Network Length & Cost (Priority Project)**

Dia. (mm)	Unit Length (m/ha)	Length		Installation Cost (Taka)		Pipe Material Cost (Taka)		Total (Taka)
		New Mohara Area	Others	New Mohara Area	Others	New Mohara Area	Others	
Area(ha)	1 ha	376 ha	247 ha					
PVC200mmD	35 m/ha	13,265 m	8,707 m					
PVC150mmD	34 m/ha	12,810 m	8,408 m					
PVC100mmD	106 m/ha	39,916 m	26,200 m					
<b>Total</b>	<b>175 m/ha</b>	<b>65,991 m</b>	<b>43,315 m</b>	<b>64,739,422</b>	<b>42,493,408</b>	<b>93,278,578</b>	<b>61,225,827</b>	<b>261,737,235</b>
			<b>109,305 m</b>			<b>158,018,000</b>	<b>103,719,235</b>	

**Table 7.5-1-18 Small Diameter Distribution Pipeline Network Length & Cost (Basic Plan Phase 1 excluding Priority Project)**

Dia. (mm)	Unit Length (m/ha)	Length		Installation Cost (Taka)		Pipe Material Cost (Taka)		Total (Taka)
		New Mohara Area	Others	New Mohara Area	Others	New Mohara Area	Others	
Area(ha)	1 ha	542 ha	680 ha					
PVC200mmD	35 m/ha	19,098 m	23,966 m					
PVC150mmD	34 m/ha	18,443 m	23,145 m					
PVC100mmD	106 m/ha	57,468 m	72,119 m					
<b>Total</b>	<b>175 m/ha</b>	<b>95,008 m</b>	<b>119,230 m</b>	<b>93,206,982</b>	<b>116,969,636</b>	<b>134,295,526</b>	<b>168,533,499</b>	<b>513,005,643</b>
			<b>214,238 m</b>			<b>227,502,508</b>	<b>285,503,135</b>	

**Table 7.5-1-19 Small Diameter Distribution Pipeline Network Length & Cost (Basic Plan Phase 2)**


Dia. (mm)	Unit Length (m/ha)	Length		Installation Cost (Taka)		Pipe Material Cost (Taka)		Total (Taka)
		New Mohara Area*	Others	New Mohara Area*	Others	New Mohara Area*	Others	
Area(ha)	1 ha	2,766 ha	3,587 ha					
PVC200mmD	35 m/ha	97,527 m	126,477 m					
PVC150mmD	34 m/ha	94,182 m	122,140 m					
PVC100mmD	106 m/ha	293,475 m	380,590 m					
<b>Total</b>	<b>175 m/ha</b>	<b>485,184 m</b>	<b>629,207 m</b>	<b>475,985,227</b>	<b>617,277,540</b>	<b>685,814,358</b>	<b>889,392,729</b>	<b>2,668,469,855</b>
			<b>1,114,391 m</b>			<b>1,161,799,585</b>	<b>1,506,670,269</b>	

\*: Based on boundaries of Service Blocks for B/P Phase 1.



**Table 7.5-1-21 Dimensions of Excavation Plan for Pipe Installation**

Dia mm	D1 m	DP m	DC m	DS m	W m	Excavat ion m3	Sand Bed m3	Sand Cover m3	Back fill (soil) m3	Diposal soil m3	Remark
DIP 1400	1.50	3.50	2.00	1.70	2.00	7.000	0.200	1.861	3.100	3.900	
DIP 1200	1.30	3.30	2.00	1.70	1.80	5.940	0.180	1.570	2.790	3.150	
DIP 1000	1.10	3.10	2.00	1.70	1.60	4.960	0.160	1.295	2.480	2.480	
DIP 900	1.00	3.00	2.00	1.70	1.50	4.500	0.150	1.164	2.325	2.175	
DIP 700	0.80	2.80	2.00	1.70	1.30	3.640	0.130	0.915	2.015	1.625	
DIP 600	0.70	2.70	2.00	1.70	1.20	3.240	0.120	0.797	1.860	1.380	
DIP 450	0.55	2.55	2.00	1.70	1.05	2.678	0.105	0.629	1.628	1.050	
DIP 400	0.50	2.50	2.00	1.70	1.00	2.500	0.100	0.574	1.550	0.950	
DIP 300	0.40	2.40	2.00	1.70	0.90	2.160	0.090	0.469	1.395	0.765	
DIP 200	0.30	2.30	2.00	1.70	0.80	1.840	0.080	0.369	1.240	0.600	
DIP 1400	1.50	2.70	1.20	0.90	2.00	5.400	0.200	1.861	1.500	3.900	Pavement
DIP 1200	1.30	2.50	1.20	0.90	1.80	4.500	0.180	1.570	1.350	3.150	Pavement
DIP 1100	1.20	2.40	1.20	0.90	1.70	4.080	0.170	1.430	1.275	2.805	Pavement
DIP 1000	1.10	2.30	1.20	0.90	1.60	3.680	0.160	1.295	1.200	2.480	Pavement
DIP 900	1.00	2.20	1.20	0.90	1.50	3.300	0.150	1.164	1.125	2.175	Pavement
DIP 800	0.90	2.10	1.20	0.90	1.40	2.940	0.140	1.038	1.050	1.890	Pavement
DIP 700	0.80	2.00	1.20	0.90	1.30	2.600	0.130	0.915	0.975	1.625	Pavement
DIP 600	0.70	1.90	1.20	0.90	1.20	2.280	0.120	0.797	0.900	1.380	Pavement
DIP 500	0.60	1.80	1.20	0.90	1.10	1.980	0.110	0.684	0.825	1.155	Pavement
DIP 450	0.55	1.75	1.20	0.90	1.05	1.838	0.105	0.629	0.788	1.050	Pavement
DIP 400	0.50	1.70	1.20	0.90	1.00	1.700	0.100	0.574	0.750	0.950	Pavement
DIP 350	0.45	1.65	1.20	0.90	0.95	1.568	0.095	0.521	0.713	0.855	Pavement
DIP 300	0.40	1.60	1.20	0.90	0.90	1.440	0.090	0.469	0.675	0.765	Pavement
PVC 250	0.35	1.55	1.20	0.90	0.85	1.318	0.085	0.418	0.638	0.680	Pavement
PVC 200	0.30	1.50	1.20	0.90	0.80	1.200	0.080	0.369	0.600	0.600	Pavement
PVC 200	0.30	1.30	1.00	0.70	0.80	1.040	0.080	0.369	0.440	0.600	Pavement
PVC 150	0.25	1.25	1.00	0.70	0.75	0.938	0.075	0.320	0.413	0.525	Pavement
PVC 100	0.20	1.20	1.00	0.70	0.70	0.840	0.070	0.272	0.385	0.455	Pavement



**Table 7.5-1-22 Customs Duties by Commodity**

Description	H.S.Code	C&F	CIF	AV	CD	SD	VAT	AIT	IDSC	LPF	PSI	DF/VAT	Total	% to CIF
		1	2	3	4	5	6	7	8	9	10	11	12	13
		1	-	on 1	on 3	on 3+4	on 3+4	on 3	on 3	on 3	on 2	on 2	3-11	12/ 2
Ductile Iron Pipe	73.03	- 100.00	1.0% 101.00	2.0% 102.01	37.5% 38.25	0.0% 0.00	15.0% 21.04	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 170.52	168.8%
PVC Pipe	39.17	- 100.00	1.0% 101.00	2.0% 102.01	37.5% 38.25	0.0% 0.00	15.0% 21.04	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 170.52	168.8%
Valve	84.81	- 100.00	1.0% 101.00	2.0% 102.01	5.0% 5.10	5.0% 5.36	15.0% 16.87	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 138.56	137.2%
Motor	85.01	- 100.00	1.0% 101.00	2.0% 102.01	15.0% 15.30	5.0% 5.87	15.0% 18.48	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 150.87	149.4%
Pump	84.14	- 100.00	1.0% 101.00	2.0% 102.01	25.0% 25.50	0.0% 0.00	15.0% 19.13	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 155.86	154.3%
Power Generator	85.02	- 100.00	1.0% 101.00	2.0% 102.01	5.0% 5.10	0.0% 0.00	15.0% 16.07	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 132.40	131.1%
Watermeter	90.28	- 100.00	1.0% 101.00	2.0% 102.01	5.0% 5.10	0.0% 0.00	15.0% 16.07	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 132.40	131.1%
Watermeter (small dia, for Consumers)		- 100.00	1.0% 101.00	2.0% 102.01	40.0% 40.80	0.0% 0.00	15.0% 21.42	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 173.46	171.7%
Car of 1800cc	87.03.23	- 100.00	1.0% 101.00	2.0% 102.01	37.5% 38.25	0.0% 0.00	15.0% 21.04	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 170.52	168.8%
Car of 1800cc fabricated in Bangladesh	87.03.23	- 100.00	1.0% 101.00	2.0% 102.01	37.5% 38.25	0.0% 0.00	15.0% 21.04	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 170.52	168.8%
Jeep above 2500cc	87.03.90	- 100.00	1.0% 101.00	2.0% 102.01	37.5% 38.25	0.0% 0.00	15.0% 21.04	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 170.52	168.8%
Transformer	85.04	- 100.00	1.0% 101.00	2.0% 102.01	25.0% 25.50	0.0% 0.00	15.0% 19.13	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 155.86	154.3%
Electric Control Panel	85.37	- 100.00	1.0% 101.00	2.0% 102.01	15.0% 15.30	0.0% 0.00	15.0% 17.60	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 144.13	142.7%
Instrumentation Equip.	85.38	- 100.00	1.0% 101.00	2.0% 102.01	15.0% 15.30	0.0% 0.00	15.0% 17.60	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 144.13	142.7%
Wired Communication Equip	85.17	- 100.00	1.0% 101.00	2.0% 102.01	15.0% 15.30	0.0% 0.00	15.0% 17.60	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 144.13	142.7%
Laboratory Analysis Equip.	90.27	- 100.00	1.0% 101.00	2.0% 102.01	5.0% 5.10	0.0% 0.00	15.0% 16.07	3.0% 3.06	2.5% 2.55	2.5% 2.55	1.0% 1.01	0.05% 0.05	incl. PSI 132.40	131.1%

AV: Assessable Value  
 CD: Customs Duty  
 SD: Supplementary Duty  
 VAT: Value Added Tax

AIT: Advance Income Tax  
 IDSC: Infrastructure Development Surcharge  
 LPF: LCA/Permit Fee  
 PSI: Pre-shipment Inspection Fee

DF/VAT: Documentation Fee for Value Added Tax

Table 7.5-2-1 Cost Estimates for Basic Plan Phase 2 Project

54Taka/\$

Facilities	Item	Construction Cost (\$)			Construction Cost (Taka)			
		Local	Foreign	Total	Local	Foreign	Total	
<b>Direct Construction Cost</b>								
<b>-1 Civil Work</b>								
1	Mohara Water Treatment Plant Expansion System	from Ground Reservoir DIP600-300mm, PVC250-200mm×5.715m	279,000	649,000	928,000	15,053,000	35,035,000	50,088,000
2	Mohara Water Treatment Plant Expansion System	from Elevated Tank DIP600-300mm, PVC250-200mm×2.165m	88,000	152,000	240,000	4,727,000	8,234,000	12,961,000
3	Mohara Water Treatment Plant Existing System	Distribution Pipe DIP600-300mm, PVC250-200mm×1.170m	49,000	86,000	136,000	2,666,000	4,663,000	7,329,000
4	Kalurgat IRP&BPS	Ground Reservoir 1,690m <sup>3</sup>	243,000	125,000	368,000	13,126,000	6,728,000	19,854,000
5	Kalurgat IRP&BPS Distribution Pipe	Distribution Pipe DIP600-300mm, PVC250-200mm×3.910m	165,000	287,000	452,000	8,900,000	15,496,000	24,396,000
6	Madunaghat Phase1	Distribution Pipe DIP450mm×1.170m	55,000	117,000	172,000	2,969,000	6,310,000	9,279,000
7	Karnaphuli WTP System	Patenga BPS Ground Reservoir 12,000m <sup>3</sup>	1,813,000	215,000	2,028,000	97,915,000	11,629,000	109,544,000
8	Karnaphuli WTP System	Distribution Pipe DIP900-300mm, PVC250-200mm×15.465m	825,000	2,258,000	3,083,000	44,553,000	121,920,000	166,473,000
9	Fatehabad System	Fatehabad Ground Reservoir 10,000m <sup>3</sup> , Elevated Tank	1,992,000	197,000	2,189,000	107,551,000	10,616,000	118,167,000
10	Fatehabad System	Distribution Pipe DIP900-300mm, PVC250-200mm×10.495m	552,000	1,432,000	1,984,000	29,828,000	77,340,000	107,168,000
11	Madunaghat WTP System Phase2	Intake Facilities, Conveyance Pipe	1,188,000	78,000	1,266,000	64,152,000	4,229,000	68,381,000
12	Madunaghat WTP System Phase2	WTP, Reservoir, Elevated Tank	4,664,000	0	4,664,000	251,856,000	0	251,856,000
13	Madunaghat WTP System Phase2	Distribution Pipe DIP900-300mm, PVC250-200mm×15.475m	802,000	2,240,000	3,042,000	43,298,000	120,941,000	164,239,000
14	Karnaphuli WTP System	Intake Facilities, Conveyance Pipe	2,625,000	348,000	2,973,000	141,738,000	18,796,000	160,534,000
15	Karnaphuli WTP System	WTP	15,093,000	0	15,093,000	815,047,000	0	815,047,000
16	Karnaphuli WTP System	Transmission Pipe DIP1,200mm×52,000m	9,250,000	24,330,000	33,580,000	499,475,000	1,313,832,000	1,813,307,000
17	Karnaphuli WTP System (Nasirabad)	Ground Reservoir 27,500m <sup>3</sup> , Elevated Tank	4,109,000	326,000	4,435,000	221,883,000	17,604,000	239,487,000
18	Karnaphuli WTP System (Nasirabad)	Transmission Pipe to Patenga BPS	1,373,000	3,605,000	4,978,000	74,116,000	194,655,000	268,771,000
19	Karnaphuli WTP System (Nasirabad)	Transmission Pipe to Salimpur	858,000	939,000	1,797,000	46,338,000	50,707,000	97,045,000
20	Karnaphuli WTP System (Nasirabad)	Distribution Pipe DIP1,400-300mm, PVC250-200mm×12.725m	944,000	4,241,000	5,185,000	50,959,000	229,029,000	279,988,000
21	Karnaphuli WTP System (Salimpur reservoir)	Ground Reservoir 11,200m <sup>3</sup>	1,238,000	242,000	1,480,000	66,857,000	13,091,000	79,948,000
22	Karnaphuli WTP System (Salimpur reservoir)	Distribution Pipe DIP900-300mm, PVC250-200mm×10.120m	511,000	1,324,000	1,835,000	27,597,000	71,483,000	99,080,000
23	Distribution Small Pipe	Distribution Pipe PVC200-100mm×m	20,246,000	29,171,000	49,417,000	1,093,262,768	1,575,207,087	2,668,469,855
24	Zonal Offices	800 m <sup>2</sup> x 5 offices	740,000	0	740,000	39,960,000	0	39,960,000
25	Staff Quarters	100 m <sup>2</sup> x 40 flats	740,000	0	740,000	39,960,000	0	39,960,000
	Sub Total		70,442,000	72,362,000	142,805,000	3,803,786,768	3,907,545,087	7,711,331,855
<b>-2 Mechanical and Electrical Work</b>								
1	Karnaphuli WTP System	Lift Pump, Power Receiving Facilities, Generator	0	2,084,000	2,084,000	0	112,519,000	112,519,000
2	Fatehabad System	Lift Pump, Power Receiving Facilities, Generator	0	1,683,000	1,683,000	0	90,866,000	90,866,000
3	Madunaghat WTP System Phase2	Intake Pump	0	674,000	674,000	0	36,395,000	36,395,000
4	Madunaghat WTP System Phase2	WTP	0	4,236,000	4,236,000	0	228,722,000	228,722,000
5	Karnaphuli WTP System	Intake Pump	0	2,211,000	2,211,000	0	119,394,000	119,394,000
6	Karnaphuli WTP System	WTP, Transmission Pump	0	19,155,000	19,155,000	0	1,034,372,000	1,034,372,000
7	Karnaphuli WTP System (Nasirabad)	Lift Pump, Power Receiving Facilities, Generator	0	2,794,000	2,794,000	0	150,881,000	150,881,000
8	Karnaphuli WTP System (Nasirabad)	Transmission to Patenga BPS, Pump	0	1,652,000	1,652,000	0	89,193,000	89,193,000
9	Karnaphuli WTP System (Nasirabad)	Transmission to Salimpur, Pump	0	1,891,000	1,891,000	0	102,133,000	102,133,000
	Sub Total		0	36,380,000	36,380,000	0	1,964,475,000	1,964,475,000
	<b>Total I</b>		70,442,000	108,742,000	179,184,000	3,803,786,768	5,872,020,087	9,675,806,855
<b>Overhead &amp; profit etc.</b>								
		25% of Direct Cost for ICB (I-1 I-22, I-2)	0	32,071,000	32,071,000	0	1,731,854,000	1,731,854,000
		12.5% of Direct Cost for LCB (I-1 23-25)	6,362,000	0	6,362,000	343,549,000	0	343,549,000
	Sub Total		6,362,000	32,071,000	38,433,000	343,549,000	1,731,854,000	2,075,403,000
	<b>Total I + II</b>		76,804,000	140,813,000	217,617,000	4,147,335,768	7,603,874,087	11,751,209,855
<b>Others</b>								
	Water meter	20-150mm×25,000units	0	589,000	589,000	0	31,806,000	31,806,000
	Vehicle	sedan×2+jeep×2+tricycles	0	93,000	93,000	0	5,022,000	5,022,000
	Computer	8 sets	0	22,000	22,000	0	1,188,000	1,188,000
	Administration Cost		128,000	0	128,000	6,912,000	0	6,912,000
	Land Acquisition Cost		8,715,000	0	8,715,000	470,610,000	0	470,610,000
	Sub Total		8,843,000	704,000	9,547,000	477,522,000	38,016,000	515,538,000
	<b>Total I + II + III</b>		85,647,000	141,517,000	227,164,000	4,624,857,768	7,641,890,087	12,266,747,855
<b>Engineering Cost</b>								
	Engineering Cost	8 % of Total Cost ( + )	2,611,000	14,798,000	17,409,000	141,015,000	799,082,000	940,097,000
	VAT for Engineering Cost	5.25%	914,000	0	914,000	49,355,000	0	49,355,000
	Sub Total		3,525,000	14,798,000	18,323,000	190,370,000	799,082,000	989,452,000
<b>Customs Duties, etc.</b>								
	Customs Duties and Other Charges		37,724,000	0	37,724,000	2,037,070,000	0	2,037,070,000
	VAT for Civil	4.5% of Civil and Mech & Elec Equip Installation Work	4,607,000	0	4,607,000	248,786,000	0	248,786,000
	VAT for Mech & Elec		18,437,000	0	18,437,000	995,577,000	0	995,577,000
	Pre-shipment Inspection Fee		936,000	0	936,000	50,538,000	0	50,538,000
	Sub Total		61,704,000	0	61,704,000	3,331,971,000	0	3,331,971,000
	<b>Total</b>		150,876,000	156,315,000	307,191,000	8,147,198,768	8,440,972,087	16,588,170,855

7.5-2-1

**Table 7.5-2-2 Details of Cost Estimates for Basic Plan Phase 2 Project**

(unit: Tk.)

No.	Name of Facility	Item	Dimension	Unit	Unit Cost	Quantity	Price	Equipment	Civil Materials	Civil & Equip Installation Cost
<b>1 Mohara Water Treatment Plant Expansion System</b>										
1-1	Distribution Pipe (Khulshi Reservoir Service Area)		DIP600mmD	m	11,570	2,400	27,767,520		20,496,000	7,271,520
	(from Khulshi ground reservoir)		DIP500mmD	m	9,085	0	0		0	0
			DIP450mmD	m	7,931	420	3,331,020		2,265,060	1,065,960
			DIP400mmD	m	6,918	1,930	13,351,547		8,750,620	4,600,927
			DIP350mmD	m	6,076	335	2,035,594		1,281,710	753,884
			DIP300mmD	m	5,235	385	2,015,437		1,199,660	815,777
			PVC250mmD	m	6,477	245	1,586,816		1,041,985	544,831
			PVC200mmD	m	4,629	0	0		0	0
	Sub Total					5,715	50,087,934	0	35,035,035	15,052,899
1-2	Distribution Pipe (Khulshi Reservoir Service Area)		DIP600mmD	m	11,570	0	0		0	0
	(from Khulshi elevated tank)		DIP500mmD	m	9,085	0	0		0	0
			DIP450mmD	m	7,931	0	0		0	0
			DIP400mmD	m	6,918	690	4,773,351		3,128,460	1,644,891
			DIP350mmD	m	6,076	0	0		0	0
			DIP300mmD	m	5,235	430	2,251,007		1,339,880	911,127
			PVC250mmD	m	6,477	595	3,853,696		2,530,535	1,323,161
			PVC200mmD	m	4,629	450	2,083,219		1,235,250	847,969
	Sub Total					2,165	12,961,273	0	8,234,125	4,727,148
	<b>Total of 1</b>						<b>63,049,207</b>	<b>0</b>	<b>43,269,160</b>	<b>19,780,047</b>
<b>2 Mohara Water Treatment Plant Existing System</b>										
2-1	Distribution Pipe		DIP600mmD	m	11,570	30	347,094		256,200	90,894
			DIP500mmD	m	9,085	0	0		0	0
			DIP450mmD	m	7,931	0	0		0	0
			DIP400mmD	m	6,918	455	3,147,645		2,062,970	1,084,675
			DIP350mmD	m	6,076	295	1,792,538		1,128,670	663,868
			DIP300mmD	m	5,235	390	2,041,611		1,215,240	826,371
			PVC250mmD	m	6,477	0	0		0	0
			PVC200mmD	m	4,629	0	0		0	0
	Sub Total					1,170	7,328,888	0	4,663,080	2,665,808
	<b>Total of 2</b>						<b>7,328,888</b>	<b>0</b>	<b>4,663,080</b>	<b>2,665,808</b>
<b>3 Kalurghat IRP&amp;BPS</b>										
3-1	Kalurghat Reservoir	Ground Reservoir	1,690 m <sup>3</sup>	L.S.		1	8,687,000		0	8,687,000
		Oxidation-Sedimentation Basin		L.S.		1	2,498,000		0	2,498,000
		In-plant Piping		L.S.		1	7,475,000		6,727,500	747,500
		Road Work		L.S.		1	1,193,000		0	1,193,000
	Sub Total						19,853,000	0	6,727,500	13,125,500
3-2	Distribution Pipe		DIP600mmD	m	11,570	0	0		0	0
			DIP500mmD	m	9,085	0	0		0	0
			DIP450mmD	m	7,931	625	4,956,875		3,370,625	1,586,250
			DIP400mmD	m	6,918	1,180	8,163,122		5,350,120	2,813,002
			DIP350mmD	m	6,076	305	1,853,302		1,166,930	686,372
			DIP300mmD	m	5,235	1,800	9,422,820		5,608,800	3,814,020
			PVC250mmD	m	6,477	0	0		0	0
			PVC200mmD	m	4,629	0	0		0	0
	Sub Total					3,910	24,396,119	0	15,496,475	8,899,644
	<b>Total of 3</b>						<b>44,249,119</b>	<b>0</b>	<b>22,223,975</b>	<b>22,025,144</b>
<b>4 Madunaghat Phase 1</b>										
4-1	Distribution Pipe		DIP600mmD	m	11,570	0	0		0	0
			DIP500mmD	m	9,085	0	0		0	0
			DIP450mmD	m	7,931	1,170	9,279,270		6,309,810	2,969,460
			DIP400mmD	m	6,918	0	0		0	0
			DIP350mmD	m	6,076	0	0		0	0
			DIP300mmD	m	5,235	0	0		0	0
			PVC250mmD	m	6,477	0	0		0	0
			PVC200mmD	m	4,629	0	0		0	0
	Sub Total					1,170	9,279,270	0	6,309,810	2,969,460
	<b>Total of 4</b>						<b>9,279,270</b>	<b>0</b>	<b>6,309,810</b>	<b>2,969,460</b>
<b>5 Karnaphuli WTP System</b>										
5-1	Distribution Facilities (Patenga BPS)									
	Ground Reservoir		12,000 m <sup>3</sup>	L.S.		1	61,680,000		0	61,680,000
	Lift Pump	Mechanical & Electrical Cost	27.6m <sup>3</sup> /min ×37m ×2 (+1)	L.S.		1	77,737,000	66,469,000		11,268,000
	Pump House			L.S.		1	8,253,000		0	8,253,000
	Power Receiving Facility	Mechanical & Electrical Cost	1000 kVA	L.S.		1	8,785,000	6,893,000		1,892,000
	Generator	Mechanical & Electrical Cost	500 kVA ×2	L.S.		1	45,110,000	39,157,000		5,953,000
	In-plant Piping			L.S.		1	12,921,000		11,628,900	1,292,100
	Earth Work			L.S.		1	3,566,000		0	3,566,000
	Road Work			L.S.		1	3,178,000		0	3,178,000
	Lighting			L.S.		1	833,000		0	833,000
	Sub Total						222,063,000	112,519,000	11,628,900	97,915,100
5-2	Distribution Pipe		DIP900mmD	m	19,825	1,430	28,350,179		22,711,260	5,638,919

No.	Name of Facility	Item	Dimension	Unit	Unit Cost	Quantity	Price	Equipment	Civil Materials	Civil & Equip
			DIP800mmD	m	16,587	400	6,634,760		5,174,000	1,460,760
			DIP700mmD	m	13,651	0	0		0	0
			DIP600mmD	m	11,570	6,735	77,922,603		57,516,900	20,405,703
			DIP500mmD	m	9,085	3,325	30,207,293		21,253,400	8,953,893
			DIP450mmD	m	7,931	0	0		0	0
			DIP400mmD	m	6,918	830	5,741,857		3,763,220	1,978,637
			DIP350mmD	m	6,076	405	2,460,942		1,549,530	911,412
			DIP300mmD	m	5,235	0	0		0	0
			PVC250mmD	m	6,477	2,340	15,155,712		9,952,020	5,203,692
			PVC200mmD	m	4,629	0	0		0	0
		Sub Total				15,465	166,473,346	0	121,920,330	44,553,016
		<b>Total of 5</b>					<b>388,536,346</b>	<b>112,519,000</b>	<b>133,549,230</b>	<b>142,468,116</b>
<b>6 Fatehabad system</b>										
6-1	Nasirabad Distribution Facilities									
	Ground Reservoir		10,000 m3	L.S.		1	51,400,000		0	51,400,000
	Lift Pump	Mechanical & Electrical Cost	15.6m3/min ×35m ×3 (+1)	L.S.		1	74,762,000	63,925,000		10,837,000
	Elevated Tank		dia18m ×6mD ×25mH	L.S.		1	22,052,000		0	22,052,000
	Pump House			L.S.		1	6,969,000		0	6,969,000
	Power Receiving Facility	Mechanical & Electrical Cost	1000 kVA	L.S.		1	8,786,000	6,893,000		1,893,000
	Generator	Mechanical & Electrical Cost	400 kVA ×2	L.S.		1	23,096,000	20,048,000		3,048,000
	In-plant Piping			L.S.		1	11,795,000		10,615,500	1,179,500
	Earth Work			L.S.		1	6,511,000		0	6,511,000
	Road Work			L.S.		1	2,901,000		0	2,901,000
	Lighting			L.S.		1	760,000		0	760,000
	Sub Total						209,032,000	90,866,000	10,615,500	107,550,500
6-2	Distribution Pipe		DIP900mmD	m	19,825	0	0		0	0
			DIP800mmD	m	16,587	0	0		0	0
			DIP700mmD	m	13,651	1,600	21,841,600		16,540,800	5,300,800
			DIP600mmD	m	11,570	3,850	44,543,730		32,879,000	11,664,730
			DIP500mmD	m	9,085	2,535	23,030,222		16,203,720	6,826,502
			DIP450mmD	m	7,931	1,525	12,094,775		8,224,325	3,870,450
			DIP400mmD	m	6,918	0	0		0	0
			DIP350mmD	m	6,076	595	3,615,458		2,276,470	1,338,988
			DIP300mmD	m	5,235	390	2,041,611		1,215,240	826,371
			PVC250mmD	m	6,477	0	0		0	0
			PVC200mmD	m	4,629	0	0		0	0
	Sub Total					10,495	107,167,396	0	77,339,555	29,827,841
	<b>Total of 6</b>						<b>316,199,396</b>	<b>90,866,000</b>	<b>87,955,055</b>	<b>137,378,341</b>
<b>7 Madunaghat WTP system (Stage 2)</b>										
7-1	Intake Pump Facilities									
	Intake Mouth			L.S.		1	25,000,000		0	25,000,000
	Conveyance Pipe 1		DIP700mmTP	m	10,372	150	1,555,800		1,409,700	146,100
		(Intake Mouth - Intake Pump House)								
	Intake Pump House			L.S.		1	31,823,000		0	31,823,000
	Intake Pump		17.4m3/min ×20m ×2 (+1)	L.S.		1	43,286,000	36,395,000		6,891,000
	Conveyance Pipe 2		DIP700mmTP	m	10,372	300	3,111,600		2,819,400	292,200
		(Intake Pump Station - Receiving Well)								
	Sub Total						104,776,400	36,395,000	4,229,100	64,152,300
7-2	Treatment Plant Facilities									
	Treatment Plant Facilities		10 MGD	L.S.		1	321,927,000	176,935,000		144,992,000
	Ground Reservoir		10,000 m3	L.S.		1	51,400,000		0	51,400,000
	Lift Pump		15.6m3/min ×35m ×3 (+1)	L.S.		1	74,762,000	51,787,000		22,975,000
	Elevated Tank		dia18m ×6mD ×25mH	L.S.		1	25,520,000		0	25,520,000
	Pump House			L.S.		1	6,969,000		0	6,969,000
	Sub Total						480,578,000	228,722,000	0	251,856,000
7-3	Distribution Pipe		DIP900mmD	m	19,825	3,100	61,458,430		49,234,200	12,224,230
			DIP800mmD	m	16,587	1,750	29,027,075		22,636,250	6,390,825
			DIP700mmD	m	13,651	0	0		0	0
			DIP600mmD	m	11,570	1,045	12,090,441		8,924,300	3,166,141
			DIP500mmD	m	9,085	990	8,994,051		6,328,080	2,665,971
			DIP450mmD	m	7,931	950	7,534,450		5,123,350	2,411,100
			DIP400mmD	m	6,918	880	6,087,752		3,989,920	2,097,832
			DIP350mmD	m	6,076	230	1,397,572		879,980	517,592
			DIP300mmD	m	5,235	1,270	6,648,323		3,957,320	2,691,003
			PVC250mmD	m	6,477	3,600	23,316,480		15,310,800	8,005,680
			PVC200mmD	m	4,629	1,660	7,684,764		4,556,700	3,128,064
	Sub Total					15,475	164,239,338	0	120,940,900	43,298,438
	<b>Total of 7</b>						<b>749,593,738</b>	<b>265,117,000</b>	<b>125,170,000</b>	<b>359,306,738</b>
<b>8 Karnaphuli WTP system</b>										
8-1	Intake Pump Facilities									
	Intake Mouth			L.S.		1	70,000,000		0	70,000,000
	Conveyance Pipe 1		DIP1000mmTP	m	18,830	250	4,707,500		4,358,500	349,000
		(Intake Mouth - Intake Pump House)								
	Intake Pump House			L.S.		1	47,735,000		0	47,735,000
	Intake Pump		52.1m3/min ×20m ×4 (+1)	L.S.		1	142,000,000	119,394,000		22,606,000

No.	Name of Facility	Item	Dimension	Unit	Unit Cost	Quantity	Price	Equipment	Civil Materials	Civil & Equip
	Conveyance Pipe 2		DIP1200mmTP	m	25,810	600	15,486,000		14,437,800	1,048,200
	(Intake Pump Station – Receiving Well)									
	Sub Total						279,928,500	119,394,000	18,796,300	141,738,200
8-2	Treatment Plant Facilities									
	Treatment Plant Facilities		60 MGD	L.S.		1	1,724,250,000	947,668,000		776,582,000
	Transmission Pump		71.5m3/min ×48m ×4 (+1)	L.S.		1	125,169,000	86,704,000		38,465,000
	(Karnaphuli WTP – Nasirabad)									
	Sub Total						1,849,419,000	1,034,372,000	0	815,047,000
8-3	Transmission Facilities									
	Transmission Pipe		DIP1200mmT	m	30,064	52,000	1,563,307,200		1,313,832,000	249,475,200
	Aqueduct		DIP1200mm*2*250m	L.S.		1	250,000,000		0	250,000,000
	Sub Total						1,813,307,200	0	1,313,832,000	499,475,200
	<b>Total of 8</b>						<b>3,942,654,700</b>	<b>1,153,766,000</b>	<b>1,332,628,300</b>	<b>1,456,260,400</b>
<b>9</b>	<b>Karnaphuli WTP system (Nasirabad)</b>									
9-1	Nasirabad Distribution Facilities									
	Ground Reservoir		27,500 m3	L.S.		1	141,350,000		0	141,350,000
	Lift Pump	Mechanical & Electrical Cost	38.4m3/min ×29m ×3 (+1)	L.S.		1	88,956,000	76,062,000		12,894,000
	Elevated Tank		dia24m ×8mD ×25mH	L.S.		1	25,463,000		0	25,463,000
	Pump House			L.S.		1	9,866,000		0	9,866,000
	Power Receiving Facility	Mechanical & Electrical Cost	2500 kVA	L.S.		1	21,965,000	17,234,000		4,731,000
	Generator	Mechanical & Electrical Cost	1250 kVA ×2	L.S.		1	66,340,000	57,585,000		8,755,000
	In-plant Piping			L.S.		1	19,560,000		17,604,000	1,956,000
	Earth Work			L.S.		1	10,797,000		0	10,797,000
	Road Work			L.S.		1	4,811,000		0	4,811,000
	Lighting			L.S.		1	1,260,000		0	1,260,000
	Sub Total						390,368,000	150,881,000	17,604,000	221,883,000
9-2	Transmission Line to Patenga BPS									
	Lift Pump	Mechanical & Electrical Cost	38.7m3/min ×23m ×2 (+1)	L.S.		1	74,701,000	63,873,000		10,828,000
	Pump House			L.S.		1	7,621,000		0	7,621,000
	Power Receiving Facility	Mechanical & Electrical Cost	1000 kVA	L.S.		1	8,786,000	6,893,000		1,893,000
	Generator	Mechanical & Electrical Cost	400 kVA ×2	L.S.		1	21,229,000	18,427,000		2,802,000
	In-plant Piping			L.S.		1	12,921,000		11,628,900	1,292,100
	Earth Work			L.S.		1	3,566,000		0	3,566,000
	Road Work			L.S.		1	3,178,000		0	3,178,000
	Lighting			L.S.		1	833,000		0	833,000
	Transmission Pipe		DIP1000mmT	m	22,405	8,955	200,635,880		163,930,230	36,705,650
			DIP800mmT	m	15,833	1,540	24,382,743		19,014,380	5,368,363
			DIP600mmT	m	11,044	10	110,439		81,520	28,919
	Sub Total					10,505	357,964,062	89,193,000	194,655,030	74,116,032
9-3	Transmission Line to Salimpur Reservoir									
	Lift Pump	Mechanical & Electrical Cost	18.m3/min ×49m ×2 (+1)	L.S.		1	74,749,000	63,914,000		10,835,000
	Pump House			L.S.		1	7,631,000		0	7,631,000
	Power Receiving Facility	Mechanical & Electrical Cost	1000 kVA	L.S.		1	8,785,000	6,893,000		1,892,000
	Generator	Mechanical & Electrical Cost	400 kVA ×2	L.S.		1	36,088,000	31,326,000		4,762,000
	In-plant Piping			L.S.		1	12,483,000		11,234,700	1,248,300
	Earth Work			L.S.		1	3,445,000		0	3,445,000
	Road Work			L.S.		1	3,071,000		0	3,071,000
	Lighting			L.S.		1	804,000		0	804,000
	Transmission Pipe		DIP700mmT	m	13,031	4,000	52,122,000		39,472,000	12,650,000
	Sub Total					4,000	199,178,000	102,133,000	50,706,700	46,338,300
9-4	Distribution Pipe									
			DIP1400mmD	m	40,800	400	16,320,040		14,003,600	2,316,440
			DIP1200mmD	m	31,495	4,910	154,641,432		129,962,790	24,678,642
			DIP1100mmD	m	26,542	895	23,755,001		20,337,085	3,417,916
			DIP1000mmD	m	23,472	1,170	27,462,006		22,437,090	5,024,916
			DIP900mmD	m	19,825	340	6,740,602		5,399,880	1,340,722
			DIP800mmD	m	16,587	705	11,693,765		9,119,175	2,574,590
			DIP700mmD	m	13,651	705	9,623,955		7,288,290	2,335,665
			DIP600mmD	m	11,570	545	6,305,541		4,654,300	1,651,241
			DIP500mmD	m	9,085	520	4,724,148		3,323,840	1,400,308
			DIP450mmD	m	7,931	2,000	15,862,000		10,786,000	5,076,000
			DIP400mmD	m	6,918	35	242,127		158,690	83,437
			DIP350mmD	m	6,076	0	0		0	0
			DIP300mmD	m	5,235	500	2,617,450		1,558,000	1,059,450
			PVC250mmD	m	6,477	0	0		0	0
			PVC200mmD	m	4,629	0	0		0	0
	Sub Total					12,725	279,988,066	0	229,028,740	50,959,326
	<b>Total of 9</b>						<b>1,227,498,127</b>	<b>342,207,000</b>	<b>491,994,470</b>	<b>393,296,657</b>
<b>10</b>	<b>Karnaphuli WTP system (Salimpur reservoir)</b>									
10-1	Salimpur Reservoir	Ground Reservoir 4 Basin	11,200 m3	L.S.		1	57,568,000		0	57,568,000
		In-plant Piping		L.S.		1	14,546,000		13,091,400	1,454,600
		Earth Work		L.S.		1	5,209,000		0	5,209,000
		Road Work		L.S.		1	2,321,000		0	2,321,000
		Lighting		L.S.		1	304,000		0	304,000
	Sub Total						79,948,000	0	13,091,400	66,856,600



No.	Name of Facility	Item	Dimension	Unit	Unit Cost	Quantity	Price	Equipment	Civil Materials	Civil & Equip
10-2	Distribution Pipe		DIP900mmD	m	19,825	1,000	19,825,300		15,882,000	3,943,300
			DIP800mmD	m	16,587	0	0		0	0
			DIP700mmD	m	13,651	2,950	40,270,450		30,497,100	9,773,350
			DIP600mmD	m	11,570	0	0		0	0
			DIP500mmD	m	9,085	320	2,907,168		2,045,440	861,728
			DIP450mmD	m	7,931	850	6,741,350		4,584,050	2,157,300
			DIP400mmD	m	6,918	1,000	6,917,900		4,534,000	2,383,900
			DIP350mmD	m	6,076	1,000	6,076,400		3,826,000	2,250,400
			DIP300mmD	m	5,235	1,000	5,234,900		3,116,000	2,118,900
			PVC250mmD	m	6,477	1,000	6,476,800		4,253,000	2,223,800
			PVC200mmD	m	4,629	1,000	4,629,376		2,745,000	1,884,376
	Sub Total					10,120	99,079,644	0	71,482,590	27,597,054
	<b>Total 10</b>						<b>179,027,644</b>	<b>0</b>	<b>84,573,990</b>	<b>94,453,654</b>
<b>11</b>	<b>Distribution Small Pipe and Others</b>									
11-1	Distribution Small Pipe	PVC200 ~ 100mm	2010	L.S.		1	2,668,470,000		756,990,632	1,911,479,368
11-2	Zonal Offices (expansion) & Staff Quarters			L.S.		1	79,920,000		0	79,920,000
	Sub Total						2,748,390,000	0	756,990,632	1,991,399,368
	<b>Total of 11</b>						<b>2,748,390,000</b>	<b>0</b>	<b>756,990,632</b>	<b>1,991,399,368</b>
	<b>Total (Direct Construction Cost)</b>						<b>9,675,806,434</b>	<b>1,964,475,000</b>	<b>3,089,327,702</b>	<b>4,622,003,732</b>
	<b>Overhead for ICB (25%)</b>						<b>1,731,854,108</b>	<b>491,118,750</b>	<b>583,084,268</b>	<b>657,651,091</b>
	<b>Overhead for LCB (12.5%)</b>						<b>343,548,750</b>	<b>0</b>	<b>94,623,829</b>	<b>248,924,921</b>
	<b>Total</b>						<b>11,751,209,292</b>	<b>2,455,593,750</b>	<b>3,767,035,799</b>	<b>5,528,579,744</b>

## **CHAPTER 8**

### **FEASIBILITY STUDY ON PRIORITY PROJECT**

### 8.3-1 Comparison of Water Treatment Method

Existing Mohara WTP adopted the treatment process with high rate sludge blanket type clarifier and self-backwashing filter. Desilting basins are also provided upstream of rapid mixing chamber.

#### (1) Characteristics of Existing Facilities and Conditions for Planning of Proposed Facilities

- a) Existing sludge blanket type clarifiers are operated in good condition and treatment result is satisfactory.
- b) Existing rapid sand filters is self-backwashing type with surface washing equipment. Treatment result is satisfactory.
- c) Existing desilting basins provided at upstream of rapid mixing chamber is effective for reduction of turbidity more than 20% without chemical dosing.
- d) Water level loss in the plant is low comparing with a plant with paddle flocculator. Difference of water levels between desilting basin and clearwater reservoir HWL is 2.74 m.
- e) Moving mechanical equipment in the plant is flush mixers only, except several pumps. Therefore, daily maintenance work is easy and its frequency is few.
- f) Elevation of premises is set at 20 ft. or 6.1 m to avoid inundation. This elevation is much higher than the surrounding area at 9 ft. or 2.74m.
- g) The highest turbidity in last 2 years from May 1998 was 850 NTU, which is the highest record during WTP operation. The lowest was 20 NTU, while 159 NTU in average. These turbidity conditions satisfy the conditions for adoption of high rate sludge blanket type clarifier.
- h) Presently, filtration continues 24 hours in shortest and 72 hours in average. Turbidity of treated water id about 1 NTU and less than 3 NTU in highest. Existing clarifiers and filters are functioning satisfactory.
- i) Existing intake facility consisting of intake mouths, intake pump house, and connecting pipeline, was constructed with room for future expansion. The proposed project will utilize those facilities.
- j) In the proposed project, a receiving well cum distribution chamber will be provided to equalize the flow to existing and expansion plants. An interconnection pipe will be installed between clearwater wells of both plants for emergency case.
- k) Because of above-mentioned conditions, water head loss in expansion plant shall be designed as same as existing plant.

#### (2) Comparison of Treatment Method

Major types of sedimentation basin applied in worldwide are High Rate Clarifier (HRC) and Conventional Horizontal Flow Type (CHF). Characteristics of both types are presented in Table 8.3-1-1. The CHF type is effective for high turbidity, rapid fluctuation of turbidity and water temperature comparing with the HRC type. Therefore, pretreatment facility such as desilting basin is not necessary for CHF. Mechanical chemical mixing device shall be introduced for the expansion plant to secure low water head loss as same as the existing plant. Baffling type flocculation basin shall be avoided because of its large head loss. The CHF sedimentation basin needs mechanical sludge removal device or consideration on structure for sludge removal, which usually adopt conical hopper on bottom of basin at inlet part, drain pipe, control valve, and drain pump.

In the proposed project, HRC was recommended for the treatment method of the Mohara WTP expansion plant as same as existing plant because of ease of operation and maintenance, limitation of reserved area for the plant. This comparison study was conducted to verify the result of treatment method selection from economical point of view.

Cost comparison of both type are summarized in Table 8.3-1-2. Costs include civil work and mechanical work consisting of flocculator, sludge collector, and sludge drain pipe. Operation and maintenance cost is also estimated as power cost and maintenance cost (1% of mechanical equipment cost). As a result, costs for CHF is higher than that for HRC in both of construction and O&M costs. CHF with mechanical sludge remover requires 1.36 times of HRC construction cost and 18 times of HRC O&M cost. CHF with hopper requires 1.1 times and 10 times of respective cost. As shown in the table, it may be judged that HRC type, which is adopted in the proposed project, is more economical than CRF type.

With regard to filter type, proposed project employ the self-backwashing type filter as same as existing filter. This type can make constant rate filtration without any control device at outlet. Automatic washing system will be introduced to both of existing and expansion plants.

**Table 8.3-1-1 Characteristics of Sedimentation Basin Type**

Item	HRC (Sludge Blanket Type)	CHF (Horizontal Flow Sedimentation)
General	Existing Clarifier is Sludge Blanket Type. Sludge Drainage is conducted with pipe and valve. Because any mechanical equipment such as sludge collector is not used, maintenance work is easy.	1) With Sludge Collector Structure is simple. Mechanical sludge collector collect sludge to hoppers at inlet of basin.  2) Hopper Hoppers are provided at inlet of basin or entire bottom and drain pipe is connected. Sludge drainage is

		insufficient so that annual cleaning work after drying is needed.
Design Criteria Detention Time Surface Load Average Velocity	1.2hours (1.0-2.0hours) 50mm/min (40-60mm/min)	3hours (about 3hours) 22mm/min (less than 15-30mm/min) 0.33m/min (less than 0.4m/min)
Facilities	Main Structure Sludge Drain Pipe	Main Structure (incl. Flocculation Basin) Flocculator Sludge Collector Sludge Drain Pipe
Specific Requirements for Proposed Project	The same type of clarifier shall be introduced to equalize water levels of facilities with existing plant to enable interconnection of clearwater reservoirs of both plants.	To equalize head loss with existing plant, mechanical flocculator shall be provided. Baffling wall type flocculator cannot be adopted because of high head loss.
Measure against High Turbidity	Desilting Basin shall be provided at upstream of rapid mixing chamber to decrease turbidity, and stabilize rapid change of turbidity.	Detention time is long as 3 hours.
Ease of Maintenance	Easy maintenance because of no mechanical equipment in clarifiers.	maintenance work on sludge collector is needed.

**Table 8.3-1-2 Cost Comparison**

Item	HRC ( Sludge Blanket Type )	CHF	
		Mech. Corrector Type	Hopper Type
Desilting Basin Construction Cost	Civil 1,995,000 <u>Mech.(Drain) 1,283,000</u> Total \$3,278,000	None	None
Clarifier & Sedimentation Basin Construction Cost	Civil 1,215,000 <u>Mech.(pipe etc.) 439,000</u> Total \$1,654,000	Civil 2,500,000 Mech. (floccurator) 1,900,000 (sludge corrector) <u>2,300,000</u> Total \$6,700,000	2,700,000  1,900,000 <u>(Pipe) 1,000,000</u> \$5,600,000
Total Construction Cost	\$4,932,000	\$6,700,000	\$5,600,000
O&M Cost per Year	Power Cost \$3,000 Maintenance Cost 0 Total \$3,000  Drain pump in desilting basin 1.5 x 4 = 6.0 kW	\$13,000 \$42,000 \$55,000  floccurator, sludge corrector, drain pump (2.2+1.5+0.75+0.75) x 4+ 0.75 x 4 + 1.5 x 2 = 26.8 kW	\$13,000 \$19,000 \$30,000  floccurator, drain pump (2.2+1.5+0.75+ 0.75) x 4+1.5 x 2 = 23.8 kW

Note: Power Supply Cost is 2.95 Taka/kW.

### **8.3-2 Examination on Production Loss at Water Treatment Plant**

In order to identify intake amount, examination on production loss was conducted. For projection of production loss, following conditions of the treatment plant were considered:

- a) Raw water turbidity is high.

Refer to Supporting Report 4.1-1, annual average; 159NTU, highest; 830 NTU, average in 50days of high turbidity period; 458 NTU

- b) High rate clarifier and rapid sand filter will be applied.

Refer to Supporting Report 8.3-1

- c) Desilting Basin will be provided before rapid mixing chamber to decrease turbidity.

Refer to Supporting Report 4.1-4

- d) Sludge suction pumps will be installed on traveling bridge over desilting basin together with drain pipe.

- e) Filtration cycle is assumed to be 24 hours.

Refer to Supporting Report 4.1-6

Major production losses in WTP are; sludge drainage from desilting basin, sludge drainage from clarifiers, and washing wastewater from filters. Other minor losses are; water for chemical solution, water for chlorine solution, cleaning water, and consumption in administration use. Influence by cleaning water can be ignorable because cleaning work is carried out during dry season, in which raw water turbidity is low and therefore sludge drainage from clarifiers is less.

#### **(1) Status of Raw Water Turbidity**

In recent years, raw water turbidity tends to increase because of cultivation in upstream basin of Halda River. The highest record is 830 NTU on 13<sup>th</sup> August 1999 with a daily average of 755 NTU. In this examination following turbidities were considered based on records from May 1998 to April 2000:

Highest; 755 NTU (daily average in the day the highest record was measured)

Average 159 NTU

High Turbidity Continuing Period; 50 days (Highest 645 NTU, Average 458 NTU, Lowest 285 NTU)

#### **(2) Sludge Drainage from Desilting Basins**

Existing plant has a piping for alum dosing before desilting basins. However, alum dosing before desilting basin means conversion of desilting basins to horizontal flow sedimentation basins.

Purposes of provision of desilting basin is are to stabilize rapid change of turbidity and water temperature, and to reduce raw water turbidity without chemicals. For that purposes, it is operated without dosing chemicals usually. As presented in Table 4.1-4-1, turbidity reduction ratio was about 23% in case of no chemical dosing against raw water with a turbidity of 100 to 150 NTU. In this examination, reduction ration is assumed to be 20% without chemical dosing.

Existing desilting basins have drain pipes at bottom for sludge drain purpose. They are operated once a day for 1 to 2 minutes. Drained sludge volume is calculated at 0.242 m<sup>3</sup>/sec as presented in Table 8.3-4-7 WTP Hydraulic Calculation. Therefore, it will be about 300 m<sup>3</sup> a day as follows:

$$0.243 \text{ m}^3/\text{s} \times 2 \text{ minutes} \times 60 \text{ seconds} \times 4 \text{ pipes} \times 2 \text{ basins} = 232 \text{ m}^3/\text{day} \text{ say } 300 \text{ m}^3/\text{day}$$

Sludge in proposed desilting basins will be drained by sand pumps installed on the traveling bridge usually. At the time of cleaning of basins, drain pipe will be operated for drain water in the basins. Assuming sand pumps are operated for 8 hours a day, sludge drain volume will be about 600 m<sup>3</sup>/day as follows;

$$0.3 \text{ m}^3/\text{min}/\text{unit} \times 60 \text{ minutes} \times 8 \text{ hours} \times 4 \text{ basins} = 576 \text{ m}^3/\text{day} \text{ say } 600 \text{ m}^3/\text{day}$$

### (3) Sludge drainage from Clarifiers

In order to keep proper operation of clarifier, control of sludge concentration and thickness of sludge blanket zone is indispensable. For that purpose, frequent sludge drainage from sludge pockets and bottom is necessary. Sludge concentration, therefore, is less than that of conventional horizontal flow sedimentation basin. Concentration of sludge drained from bottom of existing clarifier was 0.5 % during the period of low raw water turbidity at 70 to 150 NTU as presented in Table 4.1-5-1.

According to Table 8.3-3 Capacity Calculation, sludge drainage volume will be 3,117 m<sup>3</sup>/day or 3.4 % of production volume, 20 MGD (90,912 m<sup>3</sup>/day) against raw water turbidity at 130 NTU (expected turbidity at clarifier inlet against 159 NTU raw water).

In the day of highest record at 830 NTU, 13<sup>th</sup> August 1999, daily average turbidity was 755 NTU. According to Table 8.3-2-2, turbidity of inflow to clarifier at that time is supposed to be about 600 NTU. Assuming the sludge concentration is 2 %, sludge drainage volume is 3,640 m<sup>3</sup>/day or 4 % of production volume, as presented in Table 8.3-3.

**Table 8.3-2-1 Sludge Concentration and Sludge Volume**

Case	Inflow Water Turbidity	Sludge Concentration	Sludge Drain Volume	Ratio to Production Volume (%)
Average Turbidity	130	0.5%	3,117 m <sup>3</sup> /d	3.4
Highest Turbidity	600	2.0%	3,640 m <sup>3</sup> /d	4.0
Continuing High Turbidity	370	1.5%	2,983 m <sup>3</sup> /d	3.3

(4) Washing wastewater from Filters

As presented in Supporting Report 4.1-6, filtration run time was 72 hours in average for last 2 years. However, it is not constant through a year. From December to March, it decreases 24 hours continuously. As presented in Table 4.1-6-3, cases, in which such situation continues more than 3 days, are counted at 31 times, and total of such days is 115 days or 2 % of filtration days. Consequently, washing wastewater from Filters is calculated presuming 24-hour filtration run time. Wastewater will not be returned to receiving well and discharged to river directly.

Though backwashing of filters is operated for 8 minutes presently, its effect is not sufficient. After the proposed project, it is assumed to be 10 minutes. Volume of wastewater during said backwashing will be 471 m<sup>3</sup>/unit including backwashing and surface washing water. Total wastewater volume will be 2,353 m<sup>3</sup>/day or 2.4 % of production volume.

(5) Production Loss in WTP

Calculation results of production losses at average turbidity, continuous high turbidity, and highest turbidity are presented in Table 8.3-2-3. Based on this calculation, production loss will be equivalent to 9 to 9.5 % of production volume.

Actual record at existing plant shown in Table 8.3-2-4 indicated an average value of 9.4 %. This value is almost equal to the calculation result.

As a result, production loss to be adopted in the capacity calculation was decided as 10 %.



Table 8.3-2-2 Sludge Removal Amount of Desilting Basin and Clarifier

No.	Turbidity (daily Average)		Desilting Basin		Clarifier		
			Ratio	Turbidity	Ratio	Turbidity	Adopted
1	Average	159	20%	32	80%	127	130
2	Highest Turbidity	755	20%	151	80%	604	600
3	Continuous high Turbidity period	458	20%	92	80%	366	370

- Note: 1. Turbidity data is adopted the data from May 1998 to April 2000 see Table4.1-1-1  
 2. Highest Turbidity is the data at 13 August 1999.  
 3. Continuous high turbidity period is during 50 days from 20 May to 8 July.

Table 8.3-2-3 Water Loss in Mohara Water Treatment Plant

No.	Items	Average Turbidity Period			High Turbidity Period (370NTU)			Highest Turbidity (600NTU)		
		Existing	Expansion	Total	Existing	Expansion	Total	Existing	Expansion	Total
1	Desilting Basin	300	600	900	300	600	900	300	600	900
2	Clarifier	3,117	3,117	6,234	2,983	2,983	5,966	3640	3640	7,280
3	Filter	3,765	4,235	8,000	3,765	4,235	8,000	3,765	4,235	8,000
4	Others									
4-1	Alum Dosing	66	66	132	66	66	132	66	66	132
4-2	Lime Dosing	109	109	218	109	109	218	109	109	218
4-3	Chlorine Dosing	400	400	800	400	400	800	400	400	800
4-4	Service Water	50	50	100	50	50	100	50	50	100
4-5	Wash Water	150	150	300	150	150	300	0	0	0
	Others Total	775	775	1,550	775	775	1,550	625	625	1,250
	Total	7,957	8,727	16,684	7,823	8,593	16,416	8,330	9,100	17,430
	Loss Ratio(%)	8.75	9.60	9.18	8.61	9.45	9.03	9.16	10.01	9.59
	Adopted Ratio (%)	10.0								

Notes :

1. Desilting Basin  
 Drain Pipe of Existing Basin  
 $0.242 \text{ m}^3/\text{s} \times 2 \text{ min} \times 60 \text{ sec} \times 4 \text{ sets} \times 2 \text{ basin} = 232 \text{ m}^3/\text{day} \rightarrow 300 \text{ m}^3/\text{day}$   
 Drain Pump of Proposed Basin  
 $0.3 \text{ m}^3/\text{min} \times 4 \text{ units} \times (8\text{H}/24\text{H}) = 0.4 \text{ m}^3/\text{min} = 576 \text{ m}^3/\text{day} \rightarrow 600 \text{ m}^3/\text{day}$
2. Clarifier (Water Contents : 0.5% at low Turbidity, 1.5% at high turbidity, 2.0% at highest turbidity)
3. Wash water of Filter  
 Surface Wash  $0.15 \text{ m}^3/\text{min}/\text{m}^2 \times 44.60 \text{ m}^2/\text{unit} = 33.5 \text{ m}^3/\text{unit}$   
 Back Wash  $0.98 \text{ m}^3/\text{min}/\text{m}^2 \times 44.60 \text{ m}^2/\text{unit} = 437.1 \text{ m}^3/\text{unit}$   
 $\rightarrow 470.6 \text{ m}^3/\text{unit}$   
 Back Wash cycle = 24 hours  
 $470.6 \text{ m}^3/\text{units} \times 8 \text{ units} = 3,765 \text{ m}^3/\text{day}$   
 $470.6 \text{ m}^3/\text{units} \times 9 \text{ units} = 4,235 \text{ m}^3/\text{day}$
4. Others is assumed as follows
  - 4-1 Alum and Lime Dosing Water Volume is equal to solution tank volume.  
 Alum dosing  
 Existing  $10.93 \text{ m}^3/\text{tank} \times 2 \text{ tanks} = 22 \text{ m}^3/\text{day}$   
 Expansion  $10.93 \text{ m}^3/\text{tank} \times 6 \text{ tanks} = 66 \text{ m}^3/\text{day}$   
 Lime Dosing  
 Existing  $27.32 \text{ m}^3/\text{tank} \times 2 \text{ tanks} = 55 \text{ m}^3/\text{day}$   
 Expansion  $27.32 \text{ m}^3/\text{tank} \times 4 \text{ tanks} = 109 \text{ m}^3/\text{day}$
  - 4-2 Chlorine Dosing  
 $260 \text{ L}/\text{min} = 374 \text{ m}^3/\text{day} \rightarrow 400 \text{ m}^3/\text{day}$
  - 4-3 Service Water in WTP  
 Laboratory  $50 \text{ L}/\text{min} = 72 \text{ m}^3/\text{day}$   
 Person  $100 \text{ L}/\text{day} \times 200 \text{ person} = 20 \text{ m}^3/\text{day}$   
 Total  $92 \text{ m}^3/\text{day} \rightarrow 100 \text{ m}^3/\text{day}$
  - 4-4 Wash water (for each Existing and Proposed facilities)  
 $0.2 \text{ m}^3/\text{min} \times 2 \text{ pieces} \times (5 \text{ hours}/24 \text{ hours}) = 144 \text{ m}^3/\text{day} \rightarrow 150 \text{ m}^3/\text{day}$

Table 8.3-2-4 Mohara WTP Water Loss Existing Data

Date		Production	Plant Loss
		MGD	%
1	Mar.88	18.41	6
2	Mar.88	17.85	10
3	Mar.88	18.65	9
4	Mar.88	18.52	12
6	Mar.88	18.84	6
7	Mar.88	19.25	2
8	Mar.88	18.30	8
12	Mar.88	18.29	8
13	Mar.88	18.63	8
14	Mar.88	19.17	9
17	Mar.88	18.70	11
18	Mar.88	18.45	12
20	Mar.88	18.60	12
21	Mar.88	18.98	9
22	Mar.88	18.68	10
30	Mar.88	19.70	8
8	Apr.88	19.45	10
9	Apr.88	18.68	14
10	Aug.88	19.52	13
20	Aug.88	19.41	11
25	Aug.88	19.83	10
10	Sep.88	20.06	9
Average		18.91	9.4

**8.3-3 Mohara WTP Capacity Calculation**  
**Table 8.3-3-1 Bangladesh - Chittagong Water Supply Project**  
**Capacity Calculation for Mohara Water Treatment Plant**  
**Expansion Capacity 20MGD( 90,912 cu m/day)**

Item	Total System			
Production Flow	Q=	90,912 cu m/day		
Plant Capacity (Intake to Clarifier)	Q=	100,003 cu m/day	(Loss 10 %)	
	=	4,167 cu m/hour		
	=	69.4 cu m/min		
	=	1.157 cu m/sec		
Plant Capacity (Filter)	Q=	95,458 cu m/day	(Loss 5 %)	
	=	3,977 cu m/hour		
	=	66.3 cu m/min		
	=	1.105 cu m/sec		
Plant Capacity (Clear Well)	Q=	90,912 cu m/day	(Loss 0 %)	
	=	3,788 cu m/hour		
	=	63.1 cu m/min		
	=	1.052 cu m/sec		
<b>(1) Receiving Well (Existing System)</b>				
Criteria	Retention Time	T =	1.5 min	
	Recirculation	a =	0.0 %	
Dimension	Rectangular	1 units		
	W m x L	m x D m	x units	
	5.0	5.5	4.0	1
	V=	110.0 cu m		
	T=	1.6 min		
<b>(2) Receiving Well (Expansion System)</b>				
Criteria	Retention Time	T =	1.5 min	
	Recirculation	a =	0.0 %	
Dimension	Rectangular	1 units		
	W m x L	m x D m	x units	
	7.0	5.5	4.0	1
	V=	154.0 cu m		
	T=	2.2 min		
<b>(3) Desilting Basin (Existing Facility)</b>				
Criteria	Surface loading	V <sub>0</sub> =	5-10 mm/min	
	Average flow Velocity	V =	0.3 m/min	
Dimension	Rectangular	2 units		
	W m x L	m x D m	x units	
Upper	25.29	134.11	1.98	2
Lower	13.40	116.31		
	V=	9591.9 cu m		
	T=	138.1 min		
	V <sub>0</sub> =	10.2 mm/min		
	V =	0.7 m/min		
<b>(4) Desilting Basin (Proposed Facility)</b>				
Criteria	Surface loading	V <sub>0</sub> =	5-10 mm/min	
	Average flow Velocity	V =	0.3 m/min	
Dimension	Rectangular	4 units		
	W m x L	m x D m	x units	
	23.0	76.0	2.5	4
	V=	17480.0 cu m		
	T=	4.20 hours		
	V <sub>0</sub> =	9.93 mm/min		
	V =	0.30 m/min		
Unit Flow	q =	1,042 cu m/hr/basin		
	L m x N troughs/basin	2.0 x 14		
	Total L =	56.0 m		
	Load =	446 m <sup>3</sup> /m/day		

Item	Total System				
(5) Rapid Mixing Chamber (for Lime)	Criteria	Retention Time	T =	0.15 min	
		Recirculation	a =	same as Existing Chamber 0.0 %	
	Dimension	Rectangular		1 units	
		L m x W	m x D m	x units	
		2.286	2.286	1.91	1
	Unit Volume	UV =	9.98 cu m/unit		
Total Volume	V =	9.98 cu m			
Retention Time	t =	0.14 min			
Mixing	Flash mixer				
(6) Mixing Chamber (for Alum)	Criteria	Retention Time	T =	0.11 min	
		Recirculation	a =	same as Existing Chamber 0.0 %	
	Dimension	Rectangular		1 units	
		L m x W	m x D m	x units	
		2.286	2.286	1.45	1
	Unit Volume	UV =	7.58 cu m/unit		
Total Volume	V =	7.58 cu m			
Retention Time	t =	0.11 min			
Mixing	Flash mixer				
(7) Clarifier	Criteria	Recirculation	a =	0 %	
		Retention Time	T =	60 - 120 min	
		Required Volume	V =	4,167 cu.m to 8,334 cu.m	
		Surface Load	a =	40 - 60 mm/min	
	Unit Flow	q =	2.89 cu m/min/basin		
	Dimension		24 units		
		Dimension Width m	x Length m (Top)		
			7.62	7.62	
		Width m	x Length m (Bottom)		
			0.91	0.91	
		Depth H1 =	1.29 m		
		Depth H2 =	5.79 m		
	Volume		4847 cu m (Retention Time		1.16 hours)
	Surface Load	a =	50 mm/min		
	Sludge Removal	Sludge Blanket Type Clarifier			
	Sludge Amount	So = Q * (K*(T1-T2)+B*156/666)*10^-6			
	Solid Amount (ton-DS)	where So: Sludge dry weight(ton)			
		Q : Treated water amount(m3/d)			
		K : Coefficient converting turbidity to SS (0.8-1.5 ->1.2)			
		T1 : Turbidity in raw water (ave= 130			
		T1 : Turbidity in raw water (max(peak)= 600			
		T1 : Turbidity in raw water (max(1 month)= 370			
	(see Table 8.3-2-2)				
	T2 : Turbidity after Sedimentation (ave = 5)				
	B : Alum dosage rate (ave.= 25				
	B = 4 + 2 * ( T1 ) ^ 0.5 = 26.8				
	B : Alum dosage rate (max.(peak)= 60				
	B = 4 + 2 * ( T1 ) ^ 0.5 = 53.0				
	B : Alum dosage rate (max.(1 month)= 40				
	B = 4 + 2 * ( T1 ) ^ 0.5 = 42.5				
	So = 15.59 ton-DS/day (ave)				
	So = 72.81 ton-DS/day (max(peak))				
	So = 44.74 ton-DS/day (max(1 month))				
	Water Contents of Drained Sludge (with wash-out water)				
	w =	99.5 % (Ave)			
	w =	98.0 % (Max(peak))			
	w =	98.5 % (Max(1 month))			
Sludge Volume	Total (ave)	v =	3,117 cu.m/day	(3.4 %)	
		So =	16 ton-DS/day		
	Total (max(peak))	v =	3,640 cu.m/day	(4.0 %)	
		So =	73 ton-DS/day		
	Total (max(1 month))	v =	2,983 cu.m/day	(3.3 %)	
		So =	45 ton-DS/day		

Item	Total System		
(8) Rapid Sand Filter	Down Flow, Single Media		
Type	Down Flow, Single Media		
No.	9 units (wash (Stand by	1 unit)	1 unit)
Unit Flow	q =	10,606 cu m/day/unit	
Criteria	Filtration Rate	Fr <=	300 m/day = 12.5 m/hour
	Maximum Filter Area per Ur	A <	150 sq m
Dimension	W m x L m	x N units	
	4.88	9.14	9 (9 filters/group)
	A =	44.60 sq m/unit	
Filtration Rate	Fr =	238 m/day	(All units are operated)
Filtration Rate during washing	Fr' =	268 m/day	(One unit is washing)
Filtration Rate during washing	Fr'' =	306 m/day	(1 unit stand by, 1 unit is washing)
Filters for Backwashing		5.3 filters/group	
Filter Washing Washing Cycle		2days for each filter	
Rate	Surface Washing	rate =	0.15 m3/m2/min
		duration =	5 min
	Backwashing	rate =	0.98 m3/m2/min
		duration =	10 min
Water Amount for washing	Surface Washing	Vs =	33.5 cu m/unit
	Backwashing	Vb =	437.1 cu m/unit
		Vs + Vb =	470.6 cu m/unit
for Total Units	Total Amount for Washing (9units/day)		4,235 cu m/day ②
	Percentage for Planned Flow		4.7 %
Solid Amount in Wastewater (ton-DS)	So = Q*K*(T1-T2)*10^-6		
	where So:Sludge dry weight(ton)		
	Q :Treated water amount(m3/d)		100,003
	K :Coefficient converting turbidity to SS (0.8-1.5 ->>1.2)		1.2
	T1 :Turbidity before filter(ave=		5
	T2 :Turbidity after filter(ave =		0
	So =	0.60 ton-DS/day	
SS Contents	s =	142 mg/l	
(9) Chlorination Channel	at the Inlet of the Clear Water Reservoir		
Location	at the Inlet of the Clear Water Reservoir		
Criteria	Contact Time	T >	10 minutes
Required Volume	V =	694 cu m	
Dimension	No.	2 units	
	L m x W m	x D m	m x N units basin
	31.5	3.0	2.88 3
Total Volume	v =	816 cu m	
Retention Time	t =	11.8 min	
(10) Clear Water Reservoir	Retention Time T > 1.0 hours		
Criteria	Retention Time	T >	1.0 hours
Required Volume	V =	3,788 cu m	
Dimension	No.	2 units	
	L m x W m	x D m	m x N units
	40.1	31.5	2.88 2
Total Volume	V =	7,276 cu m	
Retention Time	T =	1.92 hours	

Item	Total System	
(11) Alum Dissolving Tank		
Coagulant	Solid Aluminum Sulphate (Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> ) containing 15% Al <sub>2</sub> O <sub>3</sub>	
Criteria	Dosage Rate :	10-80 mg-solid alum/l
	Average	25 mg/l
	Max	65 mg/l
	Coagulant Solution :	10 % sg = 1.0525
	Retention Time	24 hours
	Dissolving Time	2 hours
	Average (Max)	
Dosage Amount	Wt =	2,500 ( 6,500 ) kg-Alum/day
Coagulant Solution	V =	23.8 ( 61.8 ) cu m/day
Solution Tank	Square	6 units
Dimension	L m x W	m x D m x units
	2.13	2.13 2.40 6
Total Volume	V =	65.3 cu m
	Average (Max)	
Retention Time	T =	66.0 ( 25.4 ) hours
Storage	Period	30 days
	Bulk s. g.	0.60
Storage Area	A =	63 m <sup>2</sup> at 2.0 m height
(12) Lime Dissolving Tank (Dosing to Rapid Mixing Chamber)		
pH Control	Hydrated Lime (Ca(OH) <sub>2</sub> ) containing 72% CaO	
Criteria	Dosage Rate :	10-40 mg-solid Lime/l
	Requirement	8.7 mg/l
	Average	5 mg/l
	Max	10 mg/l
	Lime Solution	10 % sg = 1.0607
	Retention Time	24 hours
	Dissolving Time	2 hours
	Average (Max)	
Dosage Amount	Wt =	500 ( 1,000 ) kg-Lime/day
Coagulant Solution	V =	4.7 ( 9.4 ) cu m/day
Solution Tank	Square	2 units
Dimension	L m x W	m x D m x units
	3.35	3.35 2.43 2
Total Volume	V =	54.5 cu m
	Average (Max)	
Retention Time	T =	277.7 138.8 hours
Storage	Period	30 days
	Bulk s. g.	0.40
Storage Area	A =	19 m <sup>2</sup> at 2.0 m height
(Dosing to Clearwell)		
pH Control	Hydrated Lime (Ca(OH) <sub>2</sub> ) containing 72% CaO	
Criteria	Dosage Rate :	10-40 mg-solid Lime/l
	Requirement	3.5 mg/l
	Average	1 mg/l
	Max	2 mg/l
	Lime Solution	1 % sg = 1.0308
	Retention Time	24 hours
	Dissolving Time	2 hours
	Average (Max)	
Dosage Amount	Wt =	100 ( 200 ) kg-Lime/day
Coagulant Solution	V =	9.7 ( 19.4 ) cu m/day
Solution Tank	Square	2 units
Dimension	L m x W	m x D m x units
	3.35	3.35 2.43 2
Total Volume	V =	54.5 cu m
	Average (Max)	
Retention Time	T =	134.9 ( 67.5 ) hours
Storage	Period	30 days
	Bulk s. g.	0.40
Storage Area	A =	4 m <sup>2</sup> at 2.0 m height

Item	Total System		
<b>(13) Chlorination Equipment</b>			
Injection Point	at the Filtered water Channel and at the Rapid Mixing Chamber and inlet of Desilting Basin		
Type	Liquid Chlorine (900 kg-cylinder)		
Criteria	Dosage Rate :	7.0 mg-Cl/l	
	Average	3.0 mg/l	
Dosage Amount	Wt =	300 kg- Cl gas/day	
	or	12.5 kg- Cl gas/hour	
Chlorinator	Vacuum Type		
No. of unit	2 units (excl. 1 unit stand-by)		
Rate	6.25 kg/hour/unit		
Operation Rate	60 percent		
Capacity	10 kg/hour/unit		
Storage	Period	30 days	
Storage Area	A =	21 m <sup>2</sup> as	2.0 m <sup>2</sup> /container
<b>(14) Sludge Storage Tank</b> (Clarifier drain water + Backwash wastewater) including Existing facilities			
Backwash Water	V <sub>s</sub> + V <sub>b</sub> = 471 cu.m/filter unit		
Required Volume	17 filter washing / day	8,000 cu.m/3 hours	= 1000 cu m/hour
Clarifier sludge Water	(ave)	3,117 cu.m/day	= 130 cu m/hour
	(max(peak))	3,640 cu.m/day	= 152 cu m/hour
	(max(1month))	2,983 cu.m/day	= 124 cu m/hour
Total Sludge Water	(ave)	1,130 cu.m/hour	
	(max(peak))	1,152 cu.m/hour	
	(max(1month))	1,124 cu.m/hour	
No.	N =	1 units	
Dimension	L m x W m	x D m	m x N units
	22.86	9.14	3.81 2
			1 Existing 1 Expansion
Total Volume	v =	1,592 cu m	> 1130 cu m 1152 cu m 1124 cu m
Sludge Pump	10.14	cu.m/min x	6 m x 22.4 kw x 3 (+1) Existing
Total pump Capacity	30.42	cu.m/min =	1,825 cu.m/hour
			> 1130 cu.m/hour
			> 1152 cu.m/hour
			> 1124 cu.m/hour

Note : Small pumps such as utility water pumps are not shown in this calculation.



### 8.3-4-1 Study of Proposed Intake Pump Capacity

Intake Pump Mouth ~ Proposed Receiving Well		Existing Pipe	900 mm,	Proposed Pipe	900 mm
(Calculation for Proposed Pump)					
1 Proposed Pump + 3 Existing Pump					
1. River Water Level					
Min.L.W.L.	-4.00 ft	-1.22 m			
2. Inlet Water Level at Intake Pump					
W.L. +	-5.51 ft	-1.68 m	>	-2.35 m(-7.7ft)	OK
3. Receiving Well Water Level					
W.L. +	+31.81 ft	+9.70 m			
4. Actual Pump Head					
	+35.81 ft	+10.92 m			
5. Total Pump Head Loss					
	50 ft	15.24 m	>	15.202 m	OK
6. Intake Flow & Velocity					
Q1= (Existing Pump)	7100 GPM=	32.27 m <sup>3</sup> /min=	46468.8 m <sup>3</sup> /day=	10.22	MGD/2units
Q2= (Proposed Pump)	9260 GPM=	42.09 m <sup>3</sup> /min=	60609.6 m <sup>3</sup> /day=	13.33	MGD/2units
Q3=	16360 GPM=	74.37 m <sup>3</sup> /min=	107092.8 m <sup>3</sup> /day=	23.56	MGD/2units
Q4=	30560 GPM=	138.91 m <sup>3</sup> /min=	200030.4 m <sup>3</sup> /day=	44.01	MGD/4units
Q4-A(900mm)=	15280 GPM=	69.46 m <sup>3</sup> /min=	100022.4 m <sup>3</sup> /day=	22.00	MGD/4units
7. Water Level Loss					
7.1. Bar Screen Loss	B= 1.83 m ( 37.5 *44= 1.650 m)	H= 1.31 m ( V= 0.325 m/s)	b= 37.5 mm ( H= 0.003 m)	t= 12.5 mm	θ= 75 °
7.2. Suction Pipe Loss	C= 100				
7.2.1. Inlet Loss	(Diameter 600 mm), f=	0.5	V= 2.48 m/s	h= 0.157 m	
7.2.2. Valve	(Diameter 600 mm), f=	0	V= 2.48 m/s	h= 0.000 m	
7.2.3. Gradually Expanded Pipe	(Diameter 900 600 mm), f=	0.534	θ= 24.1 °	h= 0.052 m	
7.2.4. Gradually Reduced Pipe	(Diameter 900 600 mm), f=	0.015	θ= 24.1 °	h= 0.005 m	
7.2.5. Valve Loss	(Diameter 600 mm), f=	0	V= 2.48 m/s	h= 0.000 m	
7.2.6. Valve Loss	(Diameter 600 mm), f=	0	V= 2.48 m/s	h= 0.000 m	
7.2.7. 90°Bend Loss	(Diameter 600 mm), f=	0.1	V= 2.48 m/s	h= 0.031 m	
7.2.8. Pipe Friction Loss	(Diameter 600 mm), I=	0.01329	L= 10.00 m	h= 0.133 m	
7.2.9. Pipe Friction Loss	(Diameter 900 mm), I=	0.00184	L= 45.00 m	h= 0.083 m	
Sub Total				H2= 0.461 m	1.513 ft
7.3. Pipe Loss (Intake Pump (Proposed Pump) → Connection Point)					
7.3.1. Check Valve Loss	(Diameter 500 mm), f=	1	V= 3.57 m/s	h= 0.650 m	
7.3.2. Strainer Loss	(Diameter 500 mm), f=	1	V= 3.57 m/s	h= 0.650 m	
7.3.3. Valve Loss	(Diameter 500 mm), f=	0	V= 3.57 m/s	h= 0.000 m	
7.3.4. Tee Loss	(Diameter 1050 500 mm), f=	0.60	V= 1.43 m/s	h= 0.063 m	
7.3.5. Tee Loss	(Diameter 1050 500 mm), f=	0.60	V= 1.43 m/s	h= 0.063 m	
7.3.6. Tee Loss	(Diameter 1050 500 mm), f=	0.45	V= 1.43 m/s	h= 0.047 m	
7.3.7. Tee Loss	(Diameter 1050 500 mm), f=	0.38	V= 1.43 m/s	h= 0.040 m	
7.3.8. Pipe Friction Loss	(Diameter 500 mm), I=	0.0323	L= 15.00 m	h= 0.485 m	
Sub Total				H3= 1.998 m	
7.4. Pipe Loss (Connection Point → Receiving Well)					
7.4.1. Gradually Reduced Pipe	(Diameter 1050 900 mm), f=	0.014	θ= 10.7 °	h= 0.001 m	
7.4.2. 90°Bend Loss	(Diameter 900 mm), f=	0.21	V= 1.82 m/s	h= 0.035 m	
7.4.3. Valve Loss	(Diameter 900 mm), f=	0	V= 1.82 m/s	h= 0.000 m	
7.4.4. 22.5°Bend Loss	(Diameter 900 mm), f=	0.04	V= 1.82 m/s	h= 0.007 m	
7.4.5. Bentley Meter Loss	(Diameter 900 mm), f=	2.0	V= 1.82 m/s	h= 0.338 m	
7.4.6. Valve Loss	(Diameter 900 mm), f=	0	V= 1.82 m/s	h= 0.000 m	
7.4.7. 45°Bend Loss	(Diameter 900 mm), f=	0.1	V= 1.82 m/s	h= 0.017 m	
7.4.8. 45°Bend Loss	(Diameter 900 mm), f=	0.1	V= 1.82 m/s	h= 0.017 m	
7.4.9. 90°Bend Loss	(Diameter 900 mm), f=	0.21	V= 1.82 m/s	h= 0.035 m	
7.4.10. Pipe Friction Loss	(Diameter 1050 mm), I=	0.00793	L= 11.00 m	h= 0.087 m	
7.4.11. Pipe Friction Loss	(Diameter 1166.4 mm), I=	0.00475	L= 214.00 m	h= 1.017 m	
7.4.12. Outlet Loss	(Diameter 900 mm), f=	1	V= 1.82 m/s	h= 0.169 m	
Sub Total				H4= 1.723 m	
8. Total Pipe Loss				H5= 4.282 m	
9. Total Pump Head (Actual Pump Head + Total Pipe Loss)				H6= 15.202 m	49.875 ft

### 8.3-4-2 Study of Existing Intake Pump Capacity

Intake Pump Mouth ~ Proposed Receiving Well Existing Pipe 900 mm, Proposed Pipe 900 mm  
(Calculation for Existing Pump)

1 Proposed Pump + 3 Existing Pump

#### 1. River Water Level

Min.L.W.L. -4.00 ft -1.22 m

#### 2. Inlet Water Level at Intake Pump

W.L.+ -4.91 ft -1.50 m > Inlet Pipe Level -2.35 m(-7.7ft) OK

#### 3. Receiving Well Water Level

W.L.+ +31.81 ft +9.70 m

#### 4. Actual Pump Head

+35.81 ft +10.92 m

#### 5. Total Pump Head Loss

47 ft 14.33 m > Actual Loss 14.295 m OK

#### 6. Intake Flow & Velocity

Q1= (Existing Pump)	7100 GPM=	32.27 m3/min=	46468.8 m3/day=	10.22	MGD/2units
Q2= (Proposed Pump)	9260 GPM=	42.09 m3/min=	60609.6 m3/day=	13.33	MGD/2units
Q3=	16360 GPM=	74.37 m3/min=	107093 m3/day=	23.56	MGD/2units
Q4=	30560 GPM=	138.91 m3/min=	200030 m3/day=	44.01	MGD/4units
Q4-A(900mm)=	15280 GPM=	69.46 m3/min=	100022 m3/day=	22.00	MGD/4units

#### 7. Water Level Loss

7.1. Bar Screen Loss B= 1.83 m ( 37.5 \*44= 1.650 m) H1= 0.100 m  
H= 1.31 m ( V= 0.249 m/s)  
b= 37.5 mm ( H= 0.002 m)  
t= 12.5 mm  
θ= 75 °

#### 7.2. Suction Pipe Loss C= 100 (Proposed Pump)

7.2.1. Inlet Loss	(Diameter 600 mm), f=	0.5	V= 1.90 m/s	h= 0.092 m
7.2.2. Valve	(Diameter 600 mm), f=	0	V= 1.90 m/s	h= 0.000 m
7.2.3. Gradually Expanded Pipe	(Diameter 900 600 mm), f=	0.534	θ= 24.1 °	h= 0.030 m
7.2.4. Gradually Reduced Pipe	(Diameter 900 600 mm), f=	0.015	θ= 24.1 °	h= 0.004 m
7.2.5. Valve Loss	(Diameter 600 mm), f=	0	V= 1.90 m/s	h= 0.000 m
7.2.6. Valve Loss	(Diameter 600 mm), f=	0	V= 1.90 m/s	h= 0.000 m
7.2.7. 90°Bend Loss	(Diameter 600 mm), f=	0.1	V= 1.90 m/s	h= 0.018 m
7.2.8. Pipe Friction Loss	(Diameter 600 mm), I=	0.00813	L= 10.00 m	h= 0.081 m
7.2.9. Pipe Friction Loss	(Diameter 900 mm), I=	0.00113	L= 45.00 m	h= 0.051 m
Sub Total				H2= 0.277 m 0.907 ft

#### 7.3. Pipe Loss (Intake Pump (Proposed Pump) → Connection Point)

7.3.1. Check Valve Loss	(Diameter 500 mm), f=	1	V= 2.74 m/s	h= 0.383 m
7.3.2. Strainer Loss	(Diameter 500 mm), f=	1	V= 2.74 m/s	h= 0.383 m
7.3.3. Valve Loss	(Diameter 500 mm), f=	0	V= 2.74 m/s	h= 0.000 m
7.3.4. Tee Loss	(Diameter 1050 500 mm), f=	0.60	V= 1.43 m/s	h= 0.063 m
7.3.5. Tee Loss	(Diameter 1050 500 mm), f=	0.60	V= 1.43 m/s	h= 0.063 m
7.3.6. Tee Loss	(Diameter 1050 500 mm), f=	0.45	V= 1.43 m/s	h= 0.047 m
7.3.7. Tee Loss	(Diameter 1050 500 mm), f=	0.38	V= 1.43 m/s	h= 0.040 m
7.3.8. Pipe Friction Loss	(Diameter 500 mm), I=	0.01976	L= 45.00 m	h= 0.296 m
Sub Total				H3= 1.275 m

#### 7.4. Pipe Loss (Connection Point → Receiving Well)

7.4.1. Gradually Reduced Pipe	(Diameter 1050 900 mm), f=	0.014	θ= 10.7 °	h= 0.001 m
7.4.2. 90°Bend Loss	(Diameter 900 mm), f=	0.21	V= 1.82 m/s	h= 0.035 m
7.4.3. Valve Loss	(Diameter 900 mm), f=	0	V= 1.82 m/s	h= 0.000 m
7.4.4. 22.5°Bend Loss	(Diameter 900 mm), f=	0.04	V= 1.82 m/s	h= 0.007 m
7.4.5. Bently Meter Loss	(Diameter 900 mm), f=	2.0	V= 1.82 m/s	h= 0.338 m
7.4.6. Valve Loss	(Diameter 900 mm), f=	0	V= 1.82 m/s	h= 0.000 m
7.4.7. 45°Bend Loss	(Diameter 900 mm), f=	0.1	V= 1.82 m/s	h= 0.017 m
7.4.8. 45°Bend Loss	(Diameter 900 mm), f=	0.1	V= 1.82 m/s	h= 0.017 m
7.4.9. 90°Bend Loss	(Diameter 900 mm), f=	0.21	V= 1.82 m/s	h= 0.035 m
7.4.10. Pipe Friction Loss	(Diameter 1050 mm), I=	0.00793	L= 11.00 m	h= 0.087 m
7.4.11. Pipe Friction Loss	(Diameter 1166.4 mm), I=	0.00475	L= 214.00 m	h= 1.017 m
7.4.12. Outlet Loss	(Diameter 900 mm), f=	1	V= 1.82 m/s	h= 0.169 m
Sub Total				H4= 1.723 m

#### 8. Total Pipe Loss

H5= 3.375 m

#### 9. Total Pump Head (Actual Pump Head + Total Pipe Loss)

H6= 14.295 m  
46.900 ft

### 8.3-4-3 Connection Pipe (1)

Proposed Reseiving Well ~ Proposed Desilting Basin No.5 Pipe loss Calculation

1. Receiving Well Inflow Water Level			
W.L.+	+31.82 ft	+9.70 m	
2. Receiving Well Outflow Water Level			
W.L.+	+29.92 ft	+9.12 m	
3. Desilting Basin Water Level			
W.L.+	+28.44 ft	+8.67 m	
4. Total of Water Level Loss			
	+1.48 ft	+0.45 m	Actual Loss > +0.437 m OK
5. Intake Flow & Verosity			
Q1=	5.5 MGD=	25000.8 m <sup>3</sup> /d=	0.289 m <sup>3</sup> /s
Q2=	2.75 MGD=	12500.4 m <sup>3</sup> /d=	0.145 m <sup>3</sup> /s
6. Water Level Loss			

Pipe Loss (Reseiving Well → Desilting Basin No.5)		C=	100				
6.1. Inlet Loss	(Diameter 700 mm), f=	0.5	V=	0.75 m/s	h=	0.014 m	
6.2. 45° Bend Loss (Vertical)	(Diameter 700 mm), f=	0.1	V=	0.75 m/s	h=	0.003 m	
6.3. 45° Bend Loss (Vertical)	(Diameter 700 mm), f=	0.1	V=	0.75 m/s	h=	0.003 m	
6.4. 45° Bend Loss (Horizontal)	(Diameter 700 mm), f=	0.1	V=	0.75 m/s	h=	0.003 m	
6.5. 45° Bend Loss (Horizontal)	(Diameter 700 mm), f=	0.1	V=	0.75 m/s	h=	0.003 m	
6.6. 90° Bend Loss	(Diameter 700 mm), f=	0.20	V=	0.75 m/s	h=	0.006 m	
6.7. Tee Loss	(Diameter 700 mm), f=	0.05	V=	0.75 m/s	h=	0.001 m	
6.8. Gradually Reduced Pipe	(Diameter 700 mm), f=	0.016	θ=	20.6 °	h=	0.004 m	
6.9. 90° Bend Loss	(Diameter 450 mm), f=	0.17	V=	0.91 m/s	h=	0.007 m	
6.10. Valve Loss	(Diameter 450 mm), f=	0	V=	0.91 m/s	h=	0.000 m	
6.11. Inlet Loss	(Diameter 450 mm), f=	1	V=	0.91 m/s	h=	0.042 m	
6.12. Pipe Friction Loss	(Diameter 700 mm), I=	0.00122	L=	240 m	h=	0.293 m	
6.13. Pipe Friction Loss	(Diameter 450 mm), I=	0.00292	L=	20 m	h=	0.058 m	
Total Pipe Loss					H=	0.437 m	

### 8.3-4-4 Connection Pipe (2)

Proposed Desilting Basin No.4 ~ Proposed Rapid Mix Chamber

1 Desilting Basin Inflow Water Level			
W.L..+	+28.44 ft	+8.67 m	
2 Desilting Basin Outflow Water Level			
W.L..+	+27.29 ft	+8.32 m	
3 Rapid Mixing Basin Inflow Water Level			
W.L..+	+26.27 ft	+8.01 m	
4 Total of Water Level Loss			
	1.02 ft	0.31 m	> 0.300 m OK
5 Intake Flow & Verosity			
Q1=	5.5 MGD=	25000.8 m3/d=	0.289 m3/s
Q2=	11 MGD=	50001.6 m3/d=	0.579 m3/s
Q3=	22 MGD=	100003 m3/d=	1.157 m3/s

#### 6 Water Level Loss

Pipe Loss ( Desilting Basin No.4 → Rapid Mix Chamber)				C=	100			
6.1. Inlet Loss	(Diameter	600	mm), f=	0.5	V=	1.02 m/s	h=	0.027 m
6.2. Tee Loss	(Diameter	1000	600 mm), f=	0.55	V=	0.74 m/s	h=	0.015 m
6.3. Tee Loss	(Diameter	1000	1000 mm), f=	0.55	V=	0.74 m/s	h=	0.015 m
6.4. Reducer Loss	(Diameter	1200	1000 mm), f=	0.285	θ=	14.4 °	h=	0.001 m
6.5. Tee Loss	(Diameter	1200	600 mm), f=	0.39	V=	1.03 m/s	h=	0.021 m
6.6. Tee Loss	(Diameter	1200	600 mm), f=	0.39	V=	1.03 m/s	h=	0.021 m
6.7. Tee Loss	(Diameter	1200	1200 mm), f=	1.0	V=	1.03 m/s	h=	0.054 m
6.8. Inlet Loss	(Diameter	1200	mm), f=	1.0	V=	1.02 m/s	h=	0.053 m
6.9. Pipe Friction Loss	(Diameter	600	mm), I=	0.00258	L=	6 m	h=	0.015 m
6.10. Pipe Friction Loss	(Diameter	1000	mm), I=	0.00077	L=	84 m	h=	0.065 m
6.11. Pipe Friction Loss	(Diameter	1200	mm), I=	0.00115	L=	11 m	h=	0.013 m
Total Pipe Loss							H=	0.300 m

### 8.3-4-5 Connection Pipe (3)

Proposed Receiving Well ~ Existing Desilting Basin No.2 Pipe loss Calculation

1 Receiving Well Outflow Water Level

W.L.+ +29.92 ft +9.12 m

2 Existing Desilting Basin No.2 Inflow Water Level

W.L.+ +26.5 ft +8.08 m

3 Total of Water Level Loss

+3.42 ft +1.04 m < 0.935 m OK

4 Intake Flow & Velocity

Q1= 11.0 MGD= 50001.6 m3/d= 0.579 m3/s  
 3.67 MGD= 16667.2 m3/d= 0.193 m3/s

5 Water Level Loss

Pipe Loss ( Proposed receiving Well → Existing Desilting Basin		C=	100					
5.1. Inlet Loss	(Diameter 800 mm), f=	0.5	V=	1.15 m/s	h=	0.034 m		
5.2. 45°Bend Loss (Vertical)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m		
5.3. 45°Bend Loss (Vertical)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m		
5.4. Valve Loss	(Diameter 800 mm), f=	0	V=	1.15 m/s	h=	0.000 m		
5.5. 45°Bend Loss (Horizontal)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m		
5.6. 45°Bend Loss (Horizontal)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m		
5.7. 45°Bend Loss (Horizontal)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m		
5.8. 45°Bend Loss (Horizontal)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m		
5.9. Gradually Reduced Pipe	(Diameter 900 800 mm), f=	0.143	θ=	8.2 °	h=	0.006 m		
5.10. Tee Loss	(Diameter 900 900 mm), f=	0	V=	0.91 m/s	h=	0.000 m		
5.11. 90°Bend Loss (Horizontal)	(Diameter 900 mm), f=	0.21	V=	0.30 m/s	h=	0.001 m		
5.12. Tee Loss	(Diameter 900 900 mm), f=	0.99	V=	0.91 m/s	h=	0.042 m		
5.13. Tee Loss	(Diameter 900 350 mm), f=	0.01	V=	0.91 m/s	h=	0.000 m		
5.14. Tee Loss	(Diameter 900 350 mm), f=	0.05	V=	0.61 m/s	h=	0.001 m		
5.15. Tee Loss	(Diameter 900 350 mm), f=	0.99	V=	0.30 m/s	h=	0.005 m		
5.16. 90°Bend Loss (Vertical)	(Diameter 350 mm), f=	0.16	V=	2.01 m/s	h=	0.034 m		
5.17. Inlet Loss	(Diameter 350 mm), f=	1	V=	2.01 m/s	h=	0.206 m		
5.18. Pipe Friction Loss	(Diameter 800 mm), I=	0.0023	L=	36 m	h=	0.083 m		
5.19. Pipe Friction Loss	(Diameter 900 mm), I=	0.00129	L=	72 m	h=	0.093 m		
5.20. Pipe Friction Loss	(Diameter 350 mm), I=	0.01685	L=	23 m	h=	0.388 m		
Total Pipe Loss					H=	0.935 m		
						3.069 ft		

### 8.3-4-6 Connection Pipe (4)

Proposed Receiving Well ~ Existing Rapid Mixing Chamber

#### 1 Receiving Well Outflow Water Level

W.L.+ +29.92 ft +9.12 m

#### 2 Existing Desilting Basin No.2 Inflow Water Level

W.L.+ +26.27 ft +8.01 m

#### 3 Total of Water Level Loss

+3.65 ft +1.11 m < 0.612 m OK

#### 4 Intake Flow & Velocity

Q1= 11.0 MGD= 50002 m<sup>3</sup>/d= 0.579 m<sup>3</sup>/s  
 22.00 MGD= 100003 m<sup>3</sup>/d= 1.157 m<sup>3</sup>/s

#### 5 Water Level Loss

Pipe Loss ( Proposed Receiving Well → Existing Rapid Mix		C=	100				
5.1. Inlet Loss	(Diameter 800 mm), f=	0.5	V=	1.15 m/s	h=	0.034 m	
5.2. 45°Bend Loss (Vertical)	(Diameter 800 mm), f=	0.10	V=	1.15 m/s	h=	0.007 m	
5.3. 45°Bend Loss (Vertical)	(Diameter 800 mm), f=	0.10	V=	1.15 m/s	h=	0.007 m	
5.4. Valve Loss	(Diameter 800 mm), f=	0	V=	1.15 m/s	h=	0.000 m	
5.5. 45°Bend Loss (Horizontal)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m	
5.6. 45°Bend Loss (Horizontal)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m	
5.7. 45°Bend Loss (Horizontal)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m	
5.8. 45°Bend Loss (Horizontal)	(Diameter 800 mm), f=	0.1	V=	1.15 m/s	h=	0.007 m	
5.9. Gradually Reduced Pipe	(Diameter 900 800 mm), f=	0.143	θ=	8.2 °	h=	0.006 m	
5.10. Tee Loss	(Diameter 900 900 mm), f=	0.99	V=	0.91 m/s	h=	0.042 m	
5.11. Tee Loss	(Diameter 900 800 mm), f=	0.3	V=	0.91 m/s	h=	0.013 m	
5.12. 22.5°Bend Loss (Vertical)	(Diameter 900 mm), f=	0.07	V=	0.91 m/s	h=	0.003 m	
5.13. 22.5°Bend Loss (Vertical)	(Diameter 900 mm), f=	0.07	V=	0.91 m/s	h=	0.003 m	
5.14. 90°Bend Loss (Horizontal)	(Diameter 900 mm), f=	0.21	V=	1.82 m/s	h=	0.036 m	
5.15. Gradually Reduced Pipe	(Diameter 1200 900 mm), f=	0.467	θ=	21.6 °	h=	0.023 m	
5.16. Tee Loss	(Diameter 1200 1200 mm), f=	0.01	V=	1.02 m/s	h=	0.001 m	
5.17. Inlet Loss	(Diameter 1200 mm), f=	1	V=	1.02 m/s	h=	0.053 m	
5.18. Pipe Friction Loss	(Diameter 800 mm), I=	0.0023	L=	36 m	h=	0.083 m	
5.19. Pipe Friction Loss	(Diameter 900 mm), I=	0.00129	L=	193 m	h=	0.249 m	
5.20. Pipe Friction Loss	(Diameter 1200 mm), I=	0.00115	L=	20 m	h=	0.023 m	
Total Pipe Loss					H=	0.612 m	
						2.007 ft	

### 8.3-4-7 Connection Pipe (5).

#### Existing Desilting Basin Drain Pipe Water flow Calculation

##### 1 Existing Desilting Basin Water Level

W.L.+ 126.5 ft +8.08 m

##### 1 Drain Channel Water Level

W.L.+ +16.72 ft +5.1 m ( 15.22 + 1.50 = 16.72 ft )

##### 3 Total of Water Level Loss

+9.78 ft +2.98 m < 2.943 m OK

##### 4 Intake Flow & Verosity

Q1= 4.60 MGD= 20910 m3/d= 0.242 m3/s

##### 5 Water Level Loss

Pipe Loss ( Desilting Basin No.4 → Rapid Mix Chamber)		C=	100			
5.1. Inlet Loss	(Diameter 300 mm), f=	0.5	V=	3.43 m/s	h=	0.300 m
5.11. 90°Bend Loss (Vertical)	(Diameter 300 mm), f=	0.15	V=	3.43 m/s	h=	0.090 m
5.4. Valve Loss	(Diameter 300 mm), f=	0	V=	3.43 m/s	h=	0.000 m
5.17. Outlet Loss	(Diameter 300 mm), f=	1	V=	3.43 m/s	h=	0.600 m
5.18. Pipe Friction Loss	(Diameter 300 mm), I=	0.05426	L=	36 m	h=	1.953 m
Total Pipe Loss					H=	2.943 m 9.656 ft

### 8.3-4-8 Connection Pipe (6)

#### Existing Clarifier Drain Pipe Water flow Calculation

##### 1 Existing Clarifier Water Level

W.L.+ 25.24 ft +7.69 m

##### 1 Drain Channel Water Level in Clarifier

W.L.+ 13.5 ft +4.11 m

Floor

( 12.00 + 1.50 = 13.50 ft )

##### 3 Total of Water Level Loss

+11.74 ft +3.58 m < 3.249 m OK

##### 4 Intake Flow & Verosity

Q1= 0.35 MGD= 1591 m3/d= 0.018 m3/s

##### 5 Water Level Loss

Pipe Loss ( Desilting Basin No.4 → Rapid Mix Chamber) C= 100

5.1. Inlet Loss	(Diameter 100 mm), f=	0.5	V= 2.29 m/s	h= 0.134 m
5.2. Tee Loss	(Diameter 100 mm), f=	100	V= 2.29 m/s	h= 0.268 m
5.3. 90°Bend Loss (Vertical)	(Diameter 100 mm), f=	0.14	V= 2.29 m/s	h= 0.037 m
5.4. Ball Valve Loss	(Diameter 100 mm), f=	7.0	V= 2.29 m/s	h= 1.873 m
5.5. 45°Bend Loss (Vertical)	(Diameter 100 mm), f=	0.09	V= 2.29 m/s	h= 0.025 m
5.6. Outlet Loss	(Diameter 100 mm), f=	1	V= 2.29 m/s	h= 0.268 m
5.7. Pipe Friction Loss	(Diameter 100 mm), I=	0.09338	L= 6.9 m	h= 0.644 m

Total Pipe Loss

H= 3.249 m  
10.659 ft



8.3-5-1





FIGURE 8.3-5-1 LAYOUT PLAN OF PROPOSED FACILITIES OF MOHARA WATER TREATMENT PLANT







**Intake Pump**  
Scale 1 : 100

Proposed Equipment


FIGURE 8.3-5-3 PROPOSED INTAKE PUMP



**Plan**  
Scale 1 : 200



**Section A-A**  
Scale 1 : 200



**Top Slab Detail**  
Scale 1 : 100


**FIGURE 8.3-5-4 PROPOSED RECEIVING WELL (DISTRIBUTION BASIN)**





8.3-5-7


FIGURE 8.3-5-7 PLAN OF PROPOSED CLARIFIERS




Plan of Clarifiers

Scale 1 : 300

FIGURE 8.3-5-8 SECTION OF PROPOSED CLARIFIERS



Section B-B  
Scale 1 : 300



Section A-A  
Scale 1 : 300








FIGURE 8.3-5-9 PROPOSED CLARIFIER






**Plan**  
Scale 1:150




**Section A-A**  
Scale 1:150

**FIGURE 8.3-5-11 PROPOSED FILTER**



**Plan**  
Scale 1 : 400



**Section A-A**  
Scale 1 : 400

**FIGURE 8.3-5-12 PROPOSED CLEAR WATER RESERVOIR**








FIGURE 8.3-5-13 LAYOUT PLAN & SECTION OF TRANSMISSION PUMP HOUSE



**Plan**  
Scale 1 : 200



**Section A-A**  
Scale 1 : 200

**FIGURE 8.3-5-14 PROPOSED SLUDGE TANK**




FIGURE 8.3-6-1 PROPOSED FACILITIES OF KALURGHAT B.P.ST.




FIGURE 8.3-7-1 PROPOSED PATENGA RESERVOIR & BPS (2005 and 2010)