



SECTION A - A
SCALE 1:100



DETAIL "A"



SECTION B - B - INLET STRUCTURE
SCALE 1:50



SECTION C - C - INLET CHANNEL
SCALE 1:50

DO NOT SCALE

| | | | |
|-----------------------|----------------|---|--------------|
| SUB PROJECT: | | TITLE: | |
| ELLIE HOUSE RESERVOIR | | GENERAL ARRANGEMENT NEW RESERVOIR SECTIONAL DETAILS | |
| DATE: | DATE: | DESIGNER: | DATE: |
| 14 JUL 2011 | 14 JUL 2011 | EH / GR / C-05 | 14 JUL 2011 |
| CHECKER: | CHECKER: | SCALE: | SCALE: |
| 14 JUL 2011 | 14 JUL 2011 | 1:50 | 1:50 |
| DESIGNER: | DESIGNER: | PROJECT NO.: | PROJECT NO.: |
| EH / GR / C-05 | EH / GR / C-05 | 14 JUL 2011 | 14 JUL 2011 |
| SCALE: | SCALE: | SCALE: | SCALE: |
| 1:50 | 1:50 | 1:50 | 1:50 |

NATIONAL WATER SUPPLY AND DRAINAGE BOARD
THE PROJECT FOR THE REDUCTION OF NON-RESIDENTIAL WATER IN THE GREATER COLOMBO AREA

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
STUDY TEAM
NIHON SUICO CONSULTANTS CO. LTD.,
TOKYO, JAPAN

CHAPTER 3

3 WATER SUPPLY ENHANCEMENT IN KOTIKAWATTE AND MULLERIYAWA AREA

3.1 BACKGROUND

The scope of JBIC loan for this project component was determined based on the improvement plan proposed by World Bank Report 1994. The report proposed as follows:

- Water required for the improvement be taken from the Ambatale-Jubilee transmission main by branching off a new transmission main.
- A new ground reservoir, a pumping station and a water tower be constructed at the Mulleriyawa Mental Hospital area in two phases to improve water supply in the Mulleriyawa area whereas the existing Gothatuwa water tower be utilized to supply part of the Gothatuwa town.

This plan was not implemented except for some distribution reinforcements in 1995 and ad-hoc additions of distribution mains.

The following facilities have been included in the scope of JBIC loan based on the World Bank proposal.

- Transmission Main (length: 2,400 m, diameter 500 mm)
- Distribution Mains (length: 4,710 m, diameter 75 to 150 mm)
- Mulleriyawa ground reservoir (2,000 m³)
- Mulleriyawa water tower (1,500 m³)
- Gothatuwa pump station (1.5 m³/min. x 27 m)
- Mulleriyawa pump station (9 m³/min. x 40 m)

In 1999, NWSDB prepared a revised improvement plan to directly pump water from Ambatale WTP to the Mulleriyawa area while utilising the existing Gothatuwa Tower to supply part of the Gothatuwa Town as recommended by World Bank.

The scope of JBIC loan was clarified during the visit of JICA S/W mission in June 1999 in that NWSDB explained that review of the World Bank proposal was necessary to conform best water supply enhancement plan.

3.2 REVIEW OF WATER SUPPLY ENHANCEMENT PLAN

In March 2000, the study team conducted an assessment of the existing Ambatale-Jubilee

transmission main and concluded that it had no adequate capacity to cater for additional water demand in the Kotikawatte and Mulleriyawa area. Based on the assessment, water for improvement was decided to be taken directly from the Ambatale WTP by pumping.

NWSDB indicated the study team that it had a plan to construct a new ground reservoir at Kolonnawa to supply mainly CMC, including housing developments at Sahaspura (20,000 housing units) and Minikelanipura (6,000 housing units). NWSDB requested to consider pumping to the Kotikawatte-Mulleriyawa area and to the proposed Kolonnawa ground reservoir from a common pumping station and through a common transmission main thereby reducing the number of pumping stations at Ambatale and the number of transmission mains originating from the plant. NWSDB has provided the following details of the plan.

| | | |
|--|---|------------------------------------|
| Rate of water transmission (design demand) | - | 29,575 m ³ /d (6.5 mgd) |
| Diameter of transmission main | - | 600 mm |
| TWL of Reservoir | - | 25.2 m MSL |
| BWL of Reservoir | - | 15.75 m MSL |
| Reservoir capacity | - | 11,250 m ³ |

Making provisions for this NWSDB plan was agreed in the amended scope of work agreed between NWSDB, JICA and JBIC on August 4, 2000. The amended scope of work also increased the total length of distribution mains to be installed under the project from 4,710 m to 40,360 m.

3.2.1 Water Demand

Water demand estimated by the SAPROF study was updated by the study team by reflecting the increase in population, existing water supply and expected time when the improvements under this project actually benefit the customers. The water demand estimate prepared by NWSDB in 1998 based on streetwise surveys was also reviewed and compared with the updated SAPROF estimate. These two estimates were discussed with NWSDB and agreed that the following water demands be used for preparation of the water enhancement plan.

| | | |
|--|---|--------------------------|
| Existing consumption (year 2000) | - | 11,628 m ³ /d |
| Existing supply (year 2000) | - | 17,900 m ³ /d |
| Average daily water demand (year 2020) | - | 28,100 m ³ /d |
| Maximum daily water demand (year 2020) | - | 30,900 m ³ /d |

3.2.2 Land Availability

During the Stage II work in Sri Lanka, 3 sites were investigated as the possible sites for construction of ground reservoir, pumping station and water tower. They are “Gothatuwa site”, “Mulleriyawa site” and “Fever Hospital site”. However, at the “Mulleriyawa site”, where proposed facilities had originally been planned to be sited within the Angoda Mental (Teaching) Hospital premises under the World Bank proposal, new hospital wards have already been constructed and no sufficient space is available for construction of proposed facilities. “Fever Hospital site” was eliminated due to the poor accessibility to the site and health concerns.

Finally, “Gothatuwa site” was selected as the site for construction of proposed facilities. The existing Gothatuwa Tower site has vacant land on southwest, south and west sides, which are currently owned by the Fever Hospital. The site is around 24 m above MSL, enabling the new water tower at this site to supply the entire Kotikawatte and Mulleriyawa area.

NWSDB indicated that the proposed pumping facility for Kotikawatte and Mulleriyawa area could be constructed at a plot of land immediately adjacent to the new Ambatale-Ellie House transmission pumping station. This pumping station had already been under construction when this Study started in January 2000 and has almost been completed to date.

3.2.3 Proposed System

Based on the estimated water demand, locations of the proposed facilities, and the results of hydraulic simulation analyses, the following facilities have been proposed. Drawing KMU/PS/G-02 shows the outline of the proposed system.

- Gothatuwa-Kolonnawa Pump House (At Ambatale WTP)
- Gothatuwa Transmission Main (From Ambatale WTP to Gothatuwa Ground Reservoir)
- Gothatuwa Ground Reservoir and Pump House (At Gothatuwa site)
- Gothatuwa New Water Tower (At Gothatuwa site)
- Distribution mains (Throughout Kotikawatte and Mulleriyawa area)

3.3 GOTHATUWA-KOLONNAWA PUMP HOUSE

The pump house is designed to transmit treated water from Ambatale treatment plant to service reservoirs at Gothatuwa (this project) and at Kolonnawa (in future). Operating characteristics are as follows:

Volume of sump : 100 m³

| | | |
|------------------------|---|--------------|
| High water level | : | +12.38 m MSL |
| Low Water Level | : | + 9.28 m MSL |
| Floor level sump | : | + 7.30 m MSL |
| Floor level pump house | : | + 8.0 m MSL |
| Ground elevation | : | + 7.5 m MSL |

The ultimate number of pumps units is 3 x 14 m³/min plus 1 stand-by. Initially (year 2005) three pumps will be installed (2 duty + 1 standby). The pumps are double suction type with horizontal split casing and will have trimmed impellers to give 11.85 m³/min each thereby matching the range in flow from 2005 to 2010. By 2010 it will be necessary to install one additional pump (3 duty pumps) to meet maximum day flows bringing the total number of pumps to 4. Timing for the installation of a fourth pump will depend on growth and trends in water use. Between the year 2010 and 2015 it will be necessary to change the impellers to 14 m³/min in all pumps to obtain maximum day flows.

Pump motors are rated 165 kW, 3 phase 415 volts. Power supply is provided from an existing substation located in the neighboring Ellie House Pump house.

The site plan for Gothatuwa-Kolonnawa Pump House is presented in drawing KMU/PS/C-01. The general layout plan for the pump house is presented in drawing KMU/PS/C-04 with a sectional view presented in drawing KMU/PS/C-08. The upper level (+11.25 m MSL) consists of a staging area at the entrance for removing pumps and a floor area for electrical switchgear and motor controls. The pumps are located at the lower floor level (+ 8.0 m MSL).

Two 15 m³ surge tanks are provided to attenuate the effects of pressure transients in the transmission main. The tanks are physically quite large and have been located outdoors to simplify access for maintenance.

Flow control at the transmission end (Ambatale) is not possible since the transmission main branches into two sections with different operating requirements and head loss characteristics. Therefore flow control is placed at each reservoir to control the amount of water received.

Pump building is designed to be similar in appearance to the existing pump house next to it. The building is reinforced concrete frame. The proposed pump house has overall dimension of 15 m x 15 m.

3.4 GOTHATUWA TRANSMISSION MAIN

Gothatuwa Transmission main is to pump water from Gothatuwa-Kolonnawa Pump House

located within Ambatale Water Treatment Plant premises to the Gothatuwa Ground Reservoir to be constructed next to the existing Gothatuwa water tower along the Fever Hospital Road.

The transmission main (800 mm DI) will exit through the gate of New Ambatale Plant taking an anti-clockwise route around the new treatment plant facilities. It will be laid along the same route as existing Dehiwela main (1,000 mm CI) and existing Kolonnawa main (600 mm DI) for approximately 0.6 km and thereafter up to Petiagoda Lane with the existing Kolonnawa main. At the Hospital Junction (junction of Himbutana Road and Angoda Road), it will branch to Gothatuwa Ground Reservoir site (500 mm DI) and to New Kolonnawa Reservoir site (600 mm DI). A blank-flanged tee with valve will be provided at this junction for future laying of pipeline to New Kolonnawa Reservoir site by NWSDB.

Major lengths are as follows:

| | |
|--|-----------|
| Length of 800 mm transmission main, from Gothatuwa-Kolonnawa Pump house to Hospital Junction | = 2,541 m |
| Length of 500 mm transmission main, from Hospital Junction to Gothatuwa Ground Reservoir | = 1,821 m |
| Length of 600 mm transmission main, from Hospital Junction to Kolonnawa New reservoir | = 6,207 m |

Ductile iron pipe with cement-mortar lining will be used which is the economical material for this range of diameters.

3.5 GOTHATUWA GROUND RESERVOIR AND PUMP HOUSE

The reservoir receives treated water from Ambatale treatment plant. The pump house is designed to lift water from the service reservoir to the elevated water tower. The reservoir and tower combine to provide storage to balance the fluctuation in demands in the Kotikawatte-Mulleriyawa distribution area. Operating characteristics of the reservoir are as follows:

| | | |
|---------------------------|---|----------------------|
| Volume | : | 4,400 m ³ |
| High water level | : | +26.25 m MSL |
| Low Water Level | : | + 21.0 m MSL |
| Floor level sump | : | + 19.15 m MSL |
| Floor level pump house | : | + 20.0 m MSL |
| Ground elevation variable | : | + 23.0 to 25.0 m MSL |

The reservoir provides 3.4 hours of storage at maximum day demand in the year 2020.

The ultimate number of pumps units is 2 x 18 m³/min plus 1 stand-by. The pumps are double suction type with horizontal split casing. Pump motors are rated 130 kW, 3 phase 415 volts. Power supply is provided by LECO from a 400 kVA pole mounted transformer located on site. Initially (year 2005) two pumps will be installed (1 duty + 1 standby). By 2010 it will be necessary to install one additional pump (2 duty pumps) to meet maximum day flows bringing the total number of pumps to 3. Timing for the installation of a third pump will depend on growth and trends in water use.

The site plan for Gothatuwa Pump House and ground reservoir is presented in drawing KMU/GR/G-02. The site is near the existing water tower in Gothatuwa adjoining the Fever Hospital Boundary. The site is small and physically constrains the maximum plan dimensions of the reservoir.

The reservoir is rectangular and has a plan dimension of 26.6 m x 32.6 m with a water height of 5.25 m. The pump house is built attached to the reservoir and has a plan dimension of 10.7 m x 19.5 m. The upper level (+ 26.25 m MSL) consists of a staging area at the entrance for removing pumps and a floor area for electrical switchgear and motor controls. The pumps are located at the lower floor level (+ 19.5 m MSL). The reservoir is divided into two equal cells. A sump common to both cells is provided for pump intakes. Sluice gates are provided between each cell and the common sump to isolate one half of the reservoir for maintenance. Internal baffle walls are provided to improve circulation within the reservoir.

A 375 kVA diesel generator is provided to operate 1 duty pumps in the event of a power failure and miscellaneous station loads. The diesel generator is oversized to meet the inrush current when the pump starts. The diesel generator starts automatically and has a fuel supply of 8 hours.

Pumping from Ambatale needs to be a continuous operation with as few stop start cycles as possible. For this reason, a motor operated flow control valve on the inlet side will be modulated by a flow meter to keep flow into the reservoir constant and match demand as closely as possible

3.6 GOTHATUWA NEW WATER TOWER

The water towers provided as additional storage and to maintain pressures in the distribution

lines.

Hydraulic characteristics of the new water tower are as follows:

| | | |
|----------------------|---|---------------------|
| Volume of clear well | : | 1500 m ³ |
| High water level | : | +47.5 m MSL |
| Low water level | : | + 41.5 m MSL |

Note: low water level is set to match the bottom of the existing 227 m³ tower.

The tower will provide 1.15 hours of storage at maximum day demand in the year 2020. The existing 227 m³ water tower increase storage to 1.34 hours.

The 1,500 m³ water tower will be reinforced concrete of the same Intz-type design adopted by NWSDB in other locations. Ground elevations at the site vary from +24.38 m MSL to +23.38 m MSL. The foundation level is set at +22.25 m MSL at same elevation as the existing water tower. The cylindrical water tank has a conical bottom that will be supported on a circular reinforced concrete shaft bearing onto a raft foundation. The inlet and outlet piping will be accommodated within the circular shaft. A thin walled shaft will be provided in the center of the tank for service access.

The tower will be provided with internal lighting, lightning protection and aircraft obstruction warning light.


3.7 DISTRIBUTION MAINS

Pipeline routes required to meet water demand in year 2020 are determined based on hydraulic network analyses. The new pipelines will be connected to existing pipelines through interconnections to improve the existing system pressure.

Approximately 40 km of priority pipeline routes have been selected for construction under this project as shown below. Drawing KMU/DM/G-02 shows the locations of these priority distribution mains.

| Diameter and Material | Required Length, m |
|-----------------------|--------------------|
| 500 mm DI | 2,124 |
| 400 mm DI | 1,764 |
| 300 mm DI | 12,290 |
| 250 mm DI | 213 |

| | |
|------------|--------|
| Sub-total | 16,391 |
| 225 mm PVC | 9,904 |
| 160 mm PVC | 3,932 |
| 110 mm PVC | 9,486 |
| Sub-total | 23,322 |
| Total | 39,713 |




SECTIONAL ELEVATION 1

SCALE: 1:100

SECTIONAL ELEVATION 2


SCALE: 1:100





SECTIONAL ELEVATION 3

SCALE: 1:100

DO NOT SCALE

| | | | |
|---|---|--|---------------------------|
|  | | NATIONAL WATER SUPPLY AND DRAINAGE BOARD THE PROJECT FOR THE REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA | |
| REL. 0008/PM | SUB PROJECT: KOTIKAWATTE MULLERYAWA | TITLE: GOHATULWA - KOLOMVAWA PUMP HOUSE SECTIONAL ELEVATIONS & DETAILS | DATE: JAN. 2001 |
| OWNER: JICA | DESIGNER: NIHOON SUDO CONSULTANTS CO. LTD., TOKYO, JAPAN | CONTRACTOR: NRW / CW | DATE: JAN. 2001 |
| PROJECT LEADER: KNU/PS/C/08 | DESIGNER: NIHOON SUDO CONSULTANTS CO. LTD., TOKYO, JAPAN | CONTRACTOR: NRW / CW | DATE: JAN. 2001 |




LONGITUDINAL SECTION

| | | | |
|------|-------------|---|---|
| | | NATIONAL WATER SUPPLY AND DRAINAGE BOARD THE PROJECT FOR THE REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA | |
| REV. | DESCRIPTION | SUBJECT: | TRANSMISSION MAIN (WITH DISTRIBUTION MAIN) FROM AMBATALE WATER TREATMENT PLANT TO GOATHUWA GROUND RESERVOIR |
| | | DATE: | JAN. 2017 |
| | | CONTRACTOR: | NRW/CW |
| | | DESIGNER: | KMU/TM/C-4 |
| | | DATE: | JAN. 2017 |
| | | CONTRACTOR: | NRW/CW |
| | | DESIGNER: | KMU/TM/C-4 |

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
 STUDY TEAM
 NIKON SUDICO CONSULTANTS CO. LTD.,
 TOKYO, JAPAN

DO NOT SCALE


JUNCTION DETAIL AT 2,285 CH.
 GOATHUWA TRANSMISSION MAIN




| | | |
|--------------|------------|---------------------------------------|
| REV. | | DESCRIPTION |
| SUB PROJECT: | KOTAWATTE | GOTHAWA GROUND RESERVOIR & PUMP HOUSE |
| CLIENT: | MULLERAWA | SITE GRADING & LANDSCAPING |
| OWNER: | DMN | KEWA |
| DATE: | | JAN. 2001 |
| DESIGNER: | NIHON SUDO | NIHON SUDO CONSULTANTS CO., LTD. |
| PROJECT NO.: | | NIJUGO-02 |
| SCALE: | | 1:50 |
| DATE: | | JAN. 2001 |
| DESIGNER: | | NIHON SUDO |
| PROJECT NO.: | | NIJUGO-02 |
| SCALE: | | 1:50 |
| DATE: | | JAN. 2001 |

NATIONAL WATER SUPPLY AND DRAINAGE BOARD
THE PROJECT FOR THE REDUCTION OF NON-REVENUE WATER
IN THE GREATER COLOMBO AREA

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
STUDY TEAM
NIHON SUDO CONSULTANTS CO., LTD.
TOKYO, JAPAN




PUMP HOUSE ROOF PLAN
SCALE: 1:200



RESERVOIR ROOF PLAN AT 26.80m MSL
SCALE: 1:50

DO NOT SCALE

| | | | |
|--|---|--|-------------------------------------|
|  | | NATIONAL WATER SUPPLY AND DRAINAGE BOARD THE PROJECT FOR THE REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA | |
| JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) STUDY TEAM NHON SUDO CONSULTANTS CO. LTD. TOKYO, JAPAN | SUB PROJECT: KOTIKAWATTE MULLERIYAWA | TITLE: GOTTHATHWA GROUND RESERVOIR & PUMP HOUSE ROOF PLAN OF RESERVOIR & PUMP HOUSE | DATE: JAN. 2011 |
| DESIGNER: NHON SUDO CONSULTANTS CO. LTD. | CLIENT: NWS&DB | CONTRACT NO.: AS/100/000000 | CONTRACT DATE: NRW / CW |
| SCALE: AS PER DRAWING | PROJECT NO.: AS/100/000000 | DATE: NRW / CW | PROJECT NO.: KMLJ/GR/C-03 |

