

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

**NATIONAL WATER SUPPLY AND DRAINAGE BOARD
MINISTRY OF URBAN DEVELOPMENT, CONSTRUCTION
AND PUBLIC UTILITIES
DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA**

**THE DETAILED DESIGN STUDY
ON
THE PROJECT FOR REDUCTION
OF NON-REVENUE WATER
IN THE GREATER COLOMBO AREA
IN
THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA**

FINAL REPORT

APPENDICES TO MAIN REPORT

MARCH 2001

JICA LIBRARY



J1163357(5)

NIHON SUIDO CONSULTANTS CO., LTD.

SSS



01-24

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

**NATIONAL WATER SUPPLY AND DRAINAGE BOARD
MINISTRY OF URBAN DEVELOPMENT, CONSTRUCTION
AND PUBLIC UTILITIES
DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA**

**THE DETAILED DESIGN STUDY
ON
THE PROJECT FOR REDUCTION
OF NON-REVENUE WATER
IN THE GREATER COLOMBO AREA
IN
THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA**

FINAL REPORT

APPENDICES TO MAIN REPORT

MARCH 2001

NIHON SUIDO CONSULTANTS CO., LTD.



1163357(5)

CURRENCY EQUIVALENTS

(As of August, 2000)

Currency Unit = Sri Lankan Rupee (Rs.)

US\$1.00 = 79.47 Rs.

US\$1.00 = 109.288 Yen (Japanese Yen)

1.0 Rs. = 1.37522 Yen (Japanese Yen)

1.0 Yen (Japanese Yen) = 0.727 Rs.

マイクロ
フィルム作成

LIST OF APPENDICES TO MAIN REPORT

CHAPTER 2

- Appendix 2A Langelier Saturation Index
- Appendix 2B Inspection of Maligakanda Roof Structure Jan.29, 2000
- Appendix 2C Inspection of Ellie House Roof Structure Jan.27, 2000

CHAPTER 3

- Appendix 3A WATER DEMAND
- Appendix 3A-1 SAPROF Water Demand Estimate for Kotikawatte-Mulleriyawa Area
- Appendix 3A-2 Revised SAPROF Water Demand Estimate for Kotikawatte-Mulleriyawa Area
- Appendix 3A-3 NWSDB Estimate for Kotikawatte-Mulleriyawa Water Supply Improvement
- Appendix 3B Diameters of Transmission Main
- Appendix 3C Distribution Pipe Network Analysis
- Appendix 3D Power Supply for Gothatuwa-Kolonnawa Pump House and Gothatuwa Pump House

CHAPTER 4

- Appendix 4A PILOT PROJECT FOR REDUCTION OF NON-REVENUE WATER
- Appendix 4A-1 List of Tenement Gardens in NRW Reduction Pilot Project Area
- Appendix 4A-2 NWSDB Billing Records of Registered Customers (May to August 2000)
- Appendix 4A-3 Records of Meter Reading on Registered Customers
- Appendix 4A-4 Details of Standposts
- Appendix 4A-5 Records of Meter Reading on Standposts
- Appendix 4A-6 List of Illegal Connections
- Appendix 4A-7 Details of Detected Leaks
- Appendix 4B PILOT PROJECTS IN LOW INCOME SETTLEMENTS
- Appendix 4B-1 NGO report on The Pilot Project for Implementation of NRW Improvement in Three Low-income Settlements (Dec.2000)
- Appendix 4B-2 Report on Pilot Projects in Low Income Settlements in CMC and Implementation Manual for Environmental Improvements (Jan. 2001)

Appendix 4C	WATER AWARENESS MASS MEDIA CAMPAIGN
Appendix 4C-1	NGO report on The Survey in Colombo City for A Water Awareness Mass Media Campaign (Final Report on the Questionnaire Survey – Nov. 2000)
Appendix 4C-2	Report on Water Awareness Mass Media Campaign (Dec. 2000)
Appendix 4D	NRW REDUCTION MANAGEMENT SYSTEM
Appendix 4D-1	Meter Repair Workshop
Appendix 4D-2	Meter Reading, Billing and Collection System
Appendix 4D-3	Inventory Management System
Appendix 4E	NRW MONITORING SYSTEM FOR CB1
Appendix 4E-1	Methodologies Proposed for Monitoring by NWSDB
Appendix 4E-2	Results of Examination and Recommendations
Appendix 4E-3	Results of Flow Measurement

CHAPTER 5

Appendix 5A	Manuals for Leakage Survey and Pipe Assessment
Appendix 5B	Results of Leakage Survey
Appendix 5C	Results of Pipe Assessment
Appendix 5D	Results of Valve Assessment
Appendix 5E	Evaluation of Reinforcement Options

CHAPTER 8

Appendix 8A	Cost Related Information
-------------	--------------------------

CHAPTER 10

Appendix 10A	Financial Evaluation
--------------	----------------------

CHAPTER 2

APPENDIX 2A

LANGELIER SATURATION INDEX

Appendix 2A - Langelier Saturation Index

Source of NWSDB data: Treatment Plant Laboratory at Mulleriyawa

Location	Date	Total Dissolved Solids mg/l	Temperature °C	Calcium Hardness as CaCO ₃ mg/l *	Total Alkalinity as CaCO ₃ mg/l	A	B	C	D	pH _s	pH	LI	RI	Test Carried out by
Maligakanda														
Inlet	13-Jan-00	32	28	20	22	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
109/7 Gothami Rd Co 8	13-Jan-00	28	28	20	22	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	21-Jan-00	41	28	20	22.9	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
109/7 Gothami Rd Co 8	21-Jan-00	38	28	20	22.9	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	10-Feb-00	19	29	24	20	0.1	1.9	1	1.3	9	6.9	-2.1	11.1	NWSDB
109/7 Gothami Rd Co 8	10-Feb-00	21	29	24	20	0.1	1.9	1	1.3	9	6.9	-2.1	11.1	NWSDB
Inlet	17-Feb-00	54	29	20	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
109/7 Gothami Rd Co 8	17-Feb-00	49	29	20	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	25-Feb-00	26	29	18	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
109/7 Gothami Rd Co 8	25-Feb-00	30	29	18	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	02-Mar-00	59	29	20	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
109/7 Gothami Rd Co 8	02-Mar-00	54	29	20	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	09-Mar-00	23	29	18	24	0.1	1.9	0.9	1.4	9	6.8	-2.2	11.2	NWSDB
109/7 Gothami Rd Co 8	09-Mar-00	21	29	18	24	0.1	1.9	0.9	1.4	9	6.6	-2.4	11.4	NWSDB
Inlet	16-Mar-00	34	29	30	14	0.1	1.9	1.1	1.2	9	6.8	-2.2	11.2	NWSDB
109/7 Gothami Rd Co 8	16-Mar-00	28	29	24	14	0.1	1.9	1	1.2	9.1	6.8	-2.3	11.4	NWSDB
Inlet	23-Mar-00	18	29	20	18	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
109/7 Gothami Rd Co 8	23-Mar-00	24	29	20	18	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	06-Apr-00	12	30	20	28	0.1	1.9	0.9	1.4	9	7	-2.0	11	NWSDB
109/7 Gothami Rd Co 8	06-Apr-00	18	30	20	26	0.1	1.9	0.9	1.4	9	7	-2.0	11	NWSDB
Inlet	20-Apr-00	54	30	18	30	0.1	1.9	0.9	1.5	8.9	6.8	-2.1	11	NWSDB
109/7 Gothami Rd Co 8	20-Apr-00	46	30	18	28	0.1	1.9	0.9	1.5	8.9	6.8	-2.1	11	NWSDB
Inlet	27-Apr-00	43	30	20	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
109/7 Gothami Rd Co 8	27-Apr-00	28	30	18	18	0.1	1.9	0.9	1.3	9.1	6.7	-2.4	11.5	NWSDB
Inlet	04-May-00	51	30	20	22	0.1	1.9	0.9	1.3	9.1	7	-2.1	11.2	NWSDB
109/7 Gothami Rd Co 8	04-May-00	48	30	20	24	0.1	1.9	0.9	1.4	9	7	-2.0	11	NWSDB
Inlet	11-May-00	61	30	18	16	0.1	1.9	0.9	1.2	9.2	7	-2.2	11.4	NWSDB
109/7 Gothami Rd Co 8	11-May-00	51	30	18	16	0.1	1.9	0.9	1.2	9.2	7	-2.2	11.4	NWSDB
Inlet	19-May-00	36	30	14	24	0.1	1.9	0.8	1.4	9.1	6.6	-2.5	11.6	NWSDB
109/7 Gothami Rd Co 8	19-May-00	32	30	14	24	0.1	1.9	0.8	1.4	9.1	6.6	-2.5	11.6	NWSDB
Inlet	25-May-00	19	30	20	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
109/7 Gothami Rd Co 8	25-May-00	41	30	20	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	01-Jun-00	52	28	16	24	0.1	1.9	0.8	1.4	9.1	6.8	-2.3	11.4	NWSDB
109/7 Gothami Rd Co 8	01-Jun-00	48	28	16	24	0.1	1.9	0.8	1.4	9.1	6.8	-2.3	11.4	NWSDB
Inlet	08-Jun-00	32	28	16	24	0.1	1.9	0.8	1.4	9.1	6.9	-2.2	11.3	NWSDB
109/7 Gothami Rd Co 8	08-Jun-00	36	28	16	24	0.1	1.9	0.8	1.4	9.1	6.9	-2.2	11.3	NWSDB
Inlet	29-Jun-00	40	28	14	22	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
109/7 Gothami Rd Co 8	29-Jun-00	42	28	14	22	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
Inlet	13-Jul-00	57	28	16	20	0.1	1.9	0.8	1.3	9.2	6.9	-2.3	11.5	NWSDB
109/7 Gothami Rd Co 8	13-Jul-00	48	28	16	20	0.1	1.9	0.8	1.3	9.2	6.9	-2.3	11.5	NWSDB
Inlet	20-Jul-00	58	28	16	24	0.1	1.9	0.8	1.4	9.1	6.8	-2.3	11.4	NWSDB
109/7 Gothami Rd Co 8	20-Jul-00	55	28	20	27	0.1	1.9	0.9	1.4	9	6.8	-2.2	11.2	NWSDB
Inlet	27-Jul-00	63	28	18	18	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
109/7 Gothami Rd Co 8	27-Jul-00	58	28	18	18	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	03-Aug-00	29	28	22	22	0.1	1.9	0.9	1.3	9.1	6.7	-2.4	11.5	NWSDB
109/7 Gothami Rd Co 8	03-Aug-00	36	28	22	22	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	09-Aug-00	48	28	18	14	0.1	1.9	0.9	1.2	9.2	6.8	-2.4	11.6	NWSDB
109/7 Gothami Rd Co 8	09-Aug-00	51	28	18	14	0.1	1.9	0.9	1.2	9.2	6.8	-2.4	11.6	NWSDB
Inlet	16-Aug-00	46	28	20	24	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
109/7 Gothami Rd Co 8	16-Aug-00	52	28	20	24	0.1	1.9	0.9	1.4	9	6.8	-2.2	11.2	NWSDB
Inlet	23-Aug-00	30	28	24	20	0.1	1.9	1	1.3	9	6.8	-2.2	11.2	NWSDB
109/7 Gothami Rd Co 8	23-Aug-00	26	28	24	20	0.1	1.9	1	1.3	9	6.8	-2.2	11.2	NWSDB
Inlet	31-Aug-00	28	28	22	23	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
109/7 Gothami Rd Co 8	31-Aug-00	26	28	22	23	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
Inlet	06-Sep-00	48	28	22	32	0.1	1.9	0.9	1.5	8.9	6.9	-2.0	10.9	NWSDB
109/7 Gothami Rd Co 8	06-Sep-00	44	28	22	32	0.1	1.9	0.9	1.5	8.9	6.9	-2.0	10.9	NWSDB
109/7 Gothami Rd Co 8	14-Sep-00	48	28	32	29	0.1	1.9	1.1	1.5	8.7	6.6	-2.1	10.8	NWSDB
Inlet	20-Sep-00	41	28	16	9	0.1	1.9	0.8	1	9.5	6.4	-3.1	12.6	NWSDB
109/7 Gothami Rd Co 8	20-Sep-00	38	28	16	10	0.1	1.9	0.8	1	9.5	6.4	-3.1	12.6	NWSDB
Inlet	27-Sep-00	21	28	23	24	0.1	1.9	1	1.4	8.9	6.4	-2.5	11.4	NWSDB
109/7 Gothami Rd Co 8	27-Sep-00	28	28	22	24	0.1	1.9	0.9	1.4	9	6.4	-2.6	11.6	NWSDB
Inlet	04-Oct-00	54	29	16	20	0.1	1.9	0.8	1.3	9.2	6.9	-2.3	11.5	NWSDB
109/7 Gothami Rd Co 8	04-Oct-00	42	29	16	20	0.1	1.9	0.8	1.3	9.2	6.9	-2.3	11.5	NWSDB
Inlet	18-Oct-00	58	29	18	22	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
109/7 Gothami Rd Co 8	18-Oct-00	48	29	16	22	0.1	1.9	0.8	1.3	9.2	6.6	-2.6	11.8	NWSDB
Inlet	25-Oct-00	55	29	20	26	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
109/7 Gothami Rd Co 8	25-Oct-00	44	29	20	26	0.1	1.9	0.9	1.4	9	6.6	-2.4	11.4	NWSDB
Inlet	01-Nov-00	25	29	30	32	0.1	1.9	1.1	1.5	8.7	7.2	-1.5	10.2	NWSDB
109/7 Gothami Rd Co 8	01-Nov-00	21	29	29	31	0.1	1.9	1.1	1.5	8.7	7.2	-1.5	10.2	NWSDB

Appendix 2A - Langelier Saturation Index

Source of NWSDB data: Treatment Plant Laboratory at Mulleriyawa

Location	Date	Total Dissolved Solids mg/l	Temperature °C	Calcium Hardness as CaCO ₃ mg/l *	Total Alkalinity as CaCO ₃ mg/l	A	B	C	D	pH _s	pH	LI	Ri	Test Carried out by
Inlet	08-Nov-00	36	29	16	22	0.1	1.9	0.8	1.3	9.2	7	-2.2	11.4	NWSDB
109/7 Gothami Rd Co 8	08-Nov-00	42	29	16	22	0.1	1.9	0.8	1.3	9.2	7	-2.2	11.4	NWSDB
Inlet	15-Nov-00	54	29	24	26	0.1	1.9	1	1.4	8.9	7	-1.9	10.8	NWSDB
109/7 Gothami Rd Co 8	15-Nov-00	51	29	28	28	0.1	1.9	1.1	1.5	8.7	6.9	-1.8	10.5	NWSDB
Inlet	22-Nov-00	29	29	16	24	0.1	1.9	0.8	1.4	9.1	7	-2.1	11.2	NWSDB
Inlet	29-Nov-00	29	29	20	29	0.1	1.9	0.9	1.5	8.9	6.8	-2.1	11	NWSDB
109/7 Gothami Rd Co 8	29-Nov-00	29	29	20	28	0.1	1.9	0.9	1.5	8.9	6.8	-2.1	11	NWSDB
Average		39.3	28.8	19.7	22.2	0.1	1.9	0.9	1.3	9.1	6.8	-2.2	11.3	
Maligakanda														
Inlet	13-Nov-00	42	27	18	16	0.1	1.9	0.9	1.2	9.2	9.1	-0.1	9.3	ITI
Inside Reservoir	13-Nov-00	39	29	17	12	0.1	1.9	0.8	1.1	9.4	8.5	-0.9	10.3	ITI
Ellie House														
Inlet	13-Jan-00	32	28	18	19	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
104 College St Kotahena	13-Jan-00	30	28	18	19	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	21-Jan-00	22	28	16	20	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
104 College St Kotahena	21-Jan-00	24	28	16	20	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
Inlet	10-Feb-00	54	29	20	20	0.1	1.9	0.9	1.3	9.1	6.6	-2.5	11.6	NWSDB
104 College St Kotahena	10-Feb-00	48	29	20	20	0.1	1.9	0.9	1.3	9.1	6.6	-2.5	11.6	NWSDB
Inlet	17-Feb-00	51	29	20	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
104 College St Kotahena	17-Feb-00	44	29	20	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	25-Feb-00	34	29	18	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
104 College St Kotahena	25-Feb-00	32	29	18	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	02-Mar-00	57	29	18	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
104 College St Kotahena	02-Mar-00	52	29	18	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	09-Mar-00	21	29	20	28	0.1	1.9	0.9	1.5	8.9	6.8	-2.1	11	NWSDB
104 College St Kotahena	09-Mar-00	18	29	20	28	0.1	1.9	0.9	1.5	8.9	6.6	-2.3	11.2	NWSDB
Inlet	16-Mar-00	32	29	30	14	0.1	1.9	1.1	1.2	9	6.8	-2.2	11.2	NWSDB
104 College St Kotahena	16-Mar-00	28	29	30	14	0.1	1.9	1.1	1.2	9	6.8	-2.2	11.2	NWSDB
Inlet	23-Mar-00	24	29	22	18	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
104 College St Kotahena	23-Mar-00	28	29	20	18	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	06-Apr-00	18	30	20	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
104 College St Kotahena	06-Apr-00	21	30	20	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	27-Apr-00	32	30	20	24	0.1	1.9	0.9	1.4	9	6.6	-2.4	11.4	NWSDB
104 College St Kotahena	27-Apr-00	30	30	20	24	0.1	1.9	0.9	1.4	9	6.6	-2.4	11.4	NWSDB
Inlet	04-May-00	49	30	20	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
104 College St Kotahena	04-May-00	48	30	20	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	11-May-00	52	30	20	20	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
104 College St Kotahena	11-May-00	28	30	14	24	0.1	1.9	0.8	1.4	9.1	6.6	-2.5	11.6	NWSDB
Inlet	19-May-00	22	30	14	22	0.1	1.9	0.8	1.3	9.2	6.6	-2.6	11.8	NWSDB
104 College St Kotahena	19-May-00	28	30	20	24	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
Inlet	25-May-00	27	30	20	24	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
104 College St Kotahena	25-May-00	53	28	26	24	0.1	1.9	1	1.4	8.9	6.8	-2.1	11	NWSDB
Inlet	01-Jun-00	48	28	26	24	0.1	1.9	1	1.4	8.9	6.8	-2.1	11	NWSDB
104 College St Kotahena	01-Jun-00	46	28	16	20	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
Inlet	29-Jun-00	39	28	16	20	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
104 College St Kotahena	29-Jun-00	44	28	16	18	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
Inlet	13-Jul-00	41	28	16	18	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
104 College St Kotahena	13-Jul-00	41	28	22	33	0.1	1.9	0.9	1.5	8.9	6.8	-2.1	11	NWSDB
Inlet	20-Jul-00	46	28	22	33	0.1	1.9	0.9	1.5	8.9	6.8	-2.1	11	NWSDB
104 College St Kotahena	20-Jul-00	32	28	16	20	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
Inlet	27-Jul-00	28	28	16	20	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
104 College St Kotahena	27-Jul-00	52	28	22	22	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	03-Aug-00	32	28	22	22	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
104 College St Kotahena	03-Aug-00	48	28	16	19	0.1	1.9	0.8	1.3	9.2	6.9	-2.3	11.5	NWSDB
Inlet	09-Aug-00	46	28	16	19	0.1	1.9	0.8	1.3	9.2	6.9	-2.3	11.5	NWSDB
104 College St Kotahena	09-Aug-00	46	28	14	22	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
Inlet	16-Aug-00	48	28	14	22	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
104 College St Kotahena	16-Aug-00	32	28	20	22	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
Inlet	23-Aug-00	28	28	20	22	0.1	1.9	0.9	1.3	9.1	6.8	-2.3	11.4	NWSDB
104 College St Kotahena	23-Aug-00	48	28	16	24	0.1	1.9	0.8	1.4	9.1	6.9	-2.2	11.3	NWSDB
Inlet	31-Aug-00	32	28	16	24	0.1	1.9	0.8	1.4	9.1	6.9	-2.2	11.3	NWSDB
104 College St Kotahena	31-Aug-00	26	28	20	32	0.1	1.9	0.9	1.5	8.9	6.9	-2.0	10.9	NWSDB
Inlet	06-Sep-00	22	28	20	32	0.1	1.9	0.9	1.5	8.9	6.9	-2.0	10.9	NWSDB
104 College St Kotahena	06-Sep-00	40	29	14	18	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
Inlet	04-Oct-00	50	29	14	18	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
104 College St Kotahena	04-Oct-00	21	29	18	22	0.1	1.9	0.9	1.3	9.1	6.6	-2.5	11.6	NWSDB
Inlet	18-Oct-00	21	29	18	22	0.1	1.9	0.9	1.3	9.1	6.6	-2.5	11.6	NWSDB
104 College St Kotahena	18-Oct-00	49	29	18	24	0.1	1.9	0.9	1.4	9	7	-2.0	11	NWSDB
Inlet	25-Oct-00	52	29	18	24	0.1	1.9	0.9	1.4	9	7	-2.0	11	NWSDB
104 College St Kotahena	25-Oct-00	48	29	24	40	0.1	1.9	1	1.6	8.7	7.2	-1.5	10.2	NWSDB
Inlet	01-Nov-00	48	29	24	40	0.1	1.9	1	1.6	8.7	7.2	-1.5	10.2	NWSDB
108 Blumendal Rd Kotaha	01-Nov-00	52	29	24	40	0.1	1.9	1	1.6	8.7	7.2	-1.5	10.2	NWSDB

Appendix 2A - Langelier Saturation Index

Source of NWSDB data: Treatment Plant Laboratory at Mulleriyawa

Location	Date	Total Dissolved Solids mg/l	Temperature °C	Calcium Hardness as CaCO ₃ mg/l *	Total Alkalinity as CaCO ₃ mg/l	A	B	C	D	pH _s	pH	LI	RI	Test Carried out by
Inlet	08-Nov-00	48	29	16	18	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
108 Blumendal Rd Kotahe	08-Nov-00	35	29	16	20	0.1	1.9	0.8	1.3	9.2	6.8	-2.4	11.6	NWSDB
Inlet	15-Nov-00	53	29	22	27	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
108 Blumendal Rd Kotahe	15-Nov-00	48	29	22	27	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
Inlet	22-Nov-00	30	29	18	20	0.1	1.9	0.9	1.3	9.1	6.9	-2.2	11.3	NWSDB
Inlet	29-Nov-00	35	29	22	26	0.1	1.9	0.9	1.4	9	6.9	-2.1	11.1	NWSDB
108 Blumendal Rd Kotahe	29-Nov-00	35	29	24	29	0.1	1.9	1	1.5	8.8	6.9	-1.9	10.7	NWSDB
Average		37.6	28.8	19.2	22.5	0.1	1.9	0.9	1.3	9.07	6.82	-2.3	11.3	
Ellie House														
Inlet	13-Nov-00	54	27	20	15	0.1	1.9	0.9	1.2	9.2	9	-0.2	9.4	ITI
Inside Reservoir	13-Nov-00	52	28	17	12	0.1	1.9	0.8	1.1	9.4	8.1	-1.3	10.7	ITI
Ambathale WTP	20-Oct-00	32	29	16	24	0.1	1.9	0.8	1.4	9.1	7.2	-1.9	11	NWSDB

Notes

LI = pH - pH_s and pH_s = (9.3+A+B)-(C+D)

* NWSDB Test Total Hardness (for this calculation purpose it assumed to be equal to Calcium Hardness)



INDUSTRIAL TECHNOLOGY INSTITUTE (ITI)

P.O. Box, 787, 363, Baudhaloka Mawatha, Colombo 7, Sri Lanka.
Telephone: 693807-9, 698621/3 Fax: 686567

successor to the Ceylon Institute of Scientific & Industrial Research (CISIR)

TEST REPORT No: SS 29455

Issue Date: 20th November, 2000

Ceywater Consultants (Pvt) Ltd.

397, Nawala Road

RAJAGIRIYA



Laboratory Services Group
Chemical and Environmental Technology Division

1 of 4 pages

J

THE REPORT IS ISSUED SUBJECT TO CONDITIONS MENTIONED OVERLEAF

"PLEASE ADDRESS ALL COVERS TO THE DIRECTOR"



TEST REPORT No. SS 29455

CLIENT : Ceywater Consultants (Pvt) Ltd.
397, Nawala Road
RAJAGIRIYA.

SAMPLES : WATER

Collection Points : Sp.01. Inlet of the Maligakanda Reservoir at Colombo 10.
Sp.02. Inside the Maligakanda Reservoir at Colombo 10.
Sp.03. Inlet (south) of the Ellie House Reservoir at Colombo 15.
Sp.04. Inside the Ellie House Reservoir at Colombo 15

Sampling Method: Grab sampling

Description : Clear water

Sampling carried out by : Mr. M.N.A. Mubarak of III

Witness : Mr. Kugaprasatham, Engineer of Ceywater Consultants Pvt) Ltd.

Date & Time of sampling : 13th November, 2000 from 10.30 a.m. - 12.20 p.m.

Temperature of samples at collection : Sample 01 and 03 - 27°C
Sample 02 - 29°C
Sample 04 - 28°C

Date & time of reception of samples at III : 13th November, 2000 at 1.20 p.m.

Temperature samples at reception : 28°C

Condition of samples at reception : Satisfactory

TESTED FOR : Parameters given in SLS 614 : 1983 Specification for Potable water Part 1 Tables 1&2.

- reference client's letter of 10th November, 2000

Date of analysis- 13th - 17th November, 2000

TEST METHODS & PRINCIPLES : See Table 1




SS 29455


RESULTS

TEST	TEST VALUE			
	Sample 01	Sample 02	Sample 03	Sample 04
Langelier Index	- 0.2 at 27°C	- 0.91 at 29°C	- 0.35 at 27°C	- 1.34 at 28°C
* Temperature	27°C	29°C	27°C	28°C
* Total residual chlorine (as Cl ₂), mg/l	0.6	0.4	0.6	0.3
* Free residual chlorine (as Cl ₂), mg/l	0.4	0.3	0.4	0.2
*# pH	9.1 at 27°C	8.5 at 29°C	9.0 at 29°C	8.1 at 28°C
# Total Alkalinity (as CaCO ₃), mg/l	16	12	15	12
Phenolphthalin Alkalinity (as CaCO ₃), mg/l	Nil	Nil	Nil	Nil
Manganese (as Mn), mg/l	0.1	Less than 0.05	0.07	0.0
Calcium (as Ca), mg/l	6.8	6	6.8	5.8
# Total Dissolved Solids at 180°C, mg/l	42	39	54	52
# Total Hardness (as CaCO ₃), mg/l	18	17	20	17
Total Iron (as Fe), mg/l	Less than 0.1	Less than 0.1	Less than 0.1	Less than 0.1
Ferrous (as Fe ²⁺), mg/l	Less than 0.1	Less than 0.1	Less than 0.1	Less than 0.1

* Measured on site.

Accredited test.


 Mr. M.N.A. Mubarak
TECHNICAL OFFICER


 Ms. M.S.L. de Costa
SENIOR RESEARCH OFFICER
CHEMICAL & ENVIRONMENTAL
TECHNOLOGY DIVISION



SS 29455

Table 1- Test Methods and Principles

Parameter	Test Method	Principle
Langlier index	IS 8188	Calculated
Temperature	APHA 2550 B	Mercury Thermometer
Total Residual chlorine	APHA 4500 Cl G	Colorimetry
Free Residual chlorine	APHA 4500 Cl G	Colorimetry
pH	APHA 4500 - H ⁺ B	Glass electrode
Total Alkalinity	APHA 2320 B	Titrimetry
Phenolphtheline Alkalinity	APHA 2320 B	Calculated
Manganese	CETD 9	Colorimetry
Calcium	APHA 3500 Ca D	Titrimetry
Total Dissolved Solids at 180°C	APHA 2540 C	Gravimetry
Total Iron	APHA 3500-Fe D	Colorimetry
Ferrous	APHA 3500 Fe D	Colorimetry
Total Hardness	APHA 2340 C	Titrimetry

APHA – Standard Methods for the examination of water and waste water APHA, AWWA, WEF 1992, 18th edition

IS - Indian Standard

CETD – Chemical & Environmental Technology Division

3 of 4 pages

J

APPENDIX 2B

INSPECTION OF MALIGAKANDA ROOF
STRUCTURE JAN.29, 2000


APPENDIX 2B

Inspection of Maligakanda Roof Structure Jan. 29, 2000

1 of 5



Photograph M1 – Wall Tie Beam Grid and Roof Columns



Photograph M2 – Wall Tie Beams and Roof Columns

JICA

Detailed Design Study for the Project on the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka

APPENDIX 2B

Inspection of Maligakanda Roof Structure Jan. 29, 2000

2 of 5



Photograph M3 – Roof Beams, Cracked Concrete Roof Arches and Corroded Ties



Photograph M4 – Cracked Concrete Roof Arches and Missing Ties

JICA

Detailed Design Study for the Project on the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka

APPENDIX 2B

Inspection of Maligakanda Roof Structure Jan. 29, 2000

3 of 5



Photographs M5 – New 30” Inlet, Tie Beam Connection at Wall, and Missing Roof Ties



Photograph M6 – New 30” Inlet and Roof Connection at Wall

JICA

Detailed Design Study for the Project on the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka


APPENDIX 2B

Inspection of Maligakanda Roof Structure Jan. 29, 2000

4 of 5



Photograph M7 – Reinforcement of Wall at North East Corner



Photograph M8 – Connection of Main Roof Beam at Wall and Corroded Tie Rod Connections

JICA

Detailed Design Study for the Project on the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka


APPENDIX 2B

Inspection of Maligakanda Roof Structure Jan. 29, 2000

5 of 5



Photograph M9 -- Cracked Concrete Arches on Roof Top



Photograph M10 -- Earth Embankment

JICA

Detailed Design Study for the Project on the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka


APPENDIX 2C

INSPECTION OF ELLIE HOUSE ROOF
STRUCTURE JAN.27, 2000


APPENDIX 2C

Inspection of Ellie House Roof Structure Jan. 27, 2000

1 of 4



Photograph E1 – Main Beam and Wall Connection



Photograph E2 - Main Beam and Wall Connection


JICA

Detailed Design Study on the Project for the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka

APPENDIX 2C

Inspection of Ellie House Roof Structure Jan. 27, 2000

2 of 4



Photograph E3 – Main Beam Column Connection



Photograph E4 – Badly Corroded Main Beam


JICA

Detailed Design Study on the Project for the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka


APPENDIX 2C

Inspection of Ellie House Roof Structure Jan. 27, 2000

3 of 4



Photographs E5 – Wall, Roof and Secondary Beam Connection



Photograph E6 – Secondary Beam Corroded Reinforcing Steel and Roof Leakage

JICA

Detailed Design Study on the Project for the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka


APPENDIX 2C

Inspection of Ellie House Roof Structure Jan. 27, 2000

4 of 4



Photograph E7 – Secondary Beams and Corrugated Sheeting Detached from Roof Arch



Photograph E8 – Secondary Beams Connection to Main Beam

JICA

Detailed Design Study on the Project for the Reduction of Non-Revenue Water
in the Greater Colombo Area in the
Democratic Socialist Republic of Sri Lanka

CHAPTER 3

APPENDIX 3A

WATER DEMAND

APPENDIX 3A-1

SAPROF WATER DEMAND ESTIMATE FOR KOTIKAWATTE-MULLERIYAWA AREA

Appendix 3A-1 SAPROF Water Demand Estimate for Kotikawatte and Mulleriyawa Area

 District
 Division

 Colombo
 Kottikawatte-Mulleriyawa PS

		Year					
		1995	2000	2005	2010	2015	2020
A	Projected Population	92,400	98,500	101,500	104,500	107,400	110,300
	Total Land Use, ha	1,483	1,515	1,531	1,546	1,552	1,557
	Net Population density, person/ha	62	65	66	68	69	71
B	Percentage of Population Served, %	67	100	100	100	100	100
C	Total Service Population	61,908	98,500	101,500	104,500	107,400	110,300
D	Direct Connection	49.3	55.5	61.6	67.7	73.9	80
	Connected Population	30,521	54,668	62,524	70,747	79,369	88,240
	Per Capita Water Consumption, lpcd	155	168	174	178	179	180
	Water Consumption(Direct), m3/d	4,731	9,184	10,879	12,593	14,207	15,883
E	Community Tap (Stand Posts & Garden Taps)						
	Percentage of Served Population	47.3	39.84	32.38	24.92	17.46	10
	Population	29,282	39,242	32,866	26,041	18,752	11,030
	Per Capita Water Consumption, lpcd	53	53	53	53	53	53
	Water Consumption(Community Tap), m3/d	1,552	2,080	1,742	1,380	994	585
F	Direct Connection (without in-house plumbing)						
	Percentage of Served Population	3.3	4.64	5.98	7.32	8.66	10
	Population	2,043	4,570	6,070	7,649	9,301	11,030
	Per Capita Water Consumption, lpcd	75	75	75	75	75	75
	Water Consumption(Direct/low cons), m3/d	153	343	455	574	698	827
G	Total of Percentage	100	100	100	100	100	100
H	Total Served Population	61,846	98,480	101,459	104,437	107,421	110,300
	Total Domestic Water Consumption, m3/d	6,436	11,607	13,076	14,547	15,898	17,295
I	Industrial Water Use						
	Industrial Area, ha	133	136	138	140	132	124
	Unit Industrial Water Use, L/(ha d)	13,078	13,078	13,078	13,078	13,078	13,078
	Industrial Water Consumption, m3/d	1,739	1,779	1,805	1,831	1,726	1,622
J	Commercial Water Use						
	Commercial Area, ha	108	112	114	116	118	120
	Unit commercial Water Use, L/(ha d)	686	686	686	686	686	686
	Commercial Water Consumption, m3/d	74	77	78	80	81	82
K	Institutional Water Use						
	Institutional Area, ha	94	96	98	100	102	104
	Unit Institutional Water Use, L/(ha d)	49,968	49,968	49,968	49,968	49,968	49,968
	Institutional Water Consumption, m3/d	4,697	4,797	4,897	4,997	5,097	5,197
L	Total Net Water Consumption, m3/d	12,946	18,259	19,856	21,454	22,802	24,196
M	Water Loss						
	Water Loss Ratio, %	25	23	21	20	19	18
	Water Loss, m3/d	4,315	5,454	5,278	5,364	5,349	5,311
N	Total Water Supply Required, m3/d	17,262	23,713	25,134	26,818	28,151	29,507
	domestic	8,581	15,074	16,552	18,183	19,628	21,092
	non-domestic	8,681	8,639	8,582	8,634	8,523	8,415

APPENDIX 3A-2

REVISED SAPROF WATER DEMAND
ESTIMATE FOR KOTIKAWATTE-
MULLERIYAWA AREA

Appendix 3A-2 Revised SAPROF Water Demand Estimate for Kotikawatte and Mulleriyawa Area

District Division		Colombo Kottikawatte-Mulleriyawa PS					
		Year					
		1995	2000	2005	2010	2015	2020
A	Projected Population	92,400	<u>110,500</u>	<u>113,900</u>	<u>117,300</u>	<u>120,600</u>	<u>123,900</u>
	Total Land Use, ha	1,483	1,515	1,531	1,546	1,552	1,557
	Net Population density, person/ha	62	65	66	68	69	71
B	Percentage of Population Served, %	67	<u>72</u>	<u>81</u>	<u>91</u>	<u>100</u>	100
C	Total Service Population	61,908	<u>79,600</u>	<u>92,666</u>	<u>106,366</u>	<u>120,600</u>	<u>123,900</u>
D	Direct Connection	49.3	<u>59.2</u>	<u>69.1</u>	<u>72.7</u>	<u>76.4</u>	80
	Connected Population	30,521	<u>47,107</u>	<u>63,994</u>	<u>77,334</u>	<u>92,081</u>	<u>99,120</u>
	Per Capita Water Consumption, lpcd	155	155	174	178	179	180
	Water Consumption(Direct), m3/d	4,731	<u>7,302</u>	<u>11,135</u>	<u>13,765</u>	<u>16,483</u>	<u>17,842</u>
E	Community Tap (Stand Posts & Garden Taps)						
	Percentage of Served Population	47.3	<u>36.2</u>	<u>29.6</u>	<u>23.1</u>	<u>16.6</u>	10
	Population	29,282	<u>28,800</u>	<u>27,429</u>	<u>24,571</u>	<u>20,020</u>	<u>12,390</u>
	Per Capita Water Consumption, lpcd	53	53	53	53	53	53
	Water Consumption(Community Tap), m3/d	1,552	<u>1,526</u>	<u>1,454</u>	<u>1,302</u>	<u>1,061</u>	<u>657</u>
F	Direct Connection (without in-house plumbing)						
	Percentage of Served Population	3.3	4.64	5.98	7.32	8.66	10
	Population	2,043	<u>3,693</u>	<u>5,541</u>	<u>7,786</u>	<u>10,444</u>	<u>12,390</u>
	Per Capita Water Consumption, lpcd	75	75	75	75	75	75
	Water Consumption(Direct/low cons.), m3/d	153	<u>277</u>	<u>416</u>	<u>584</u>	<u>783</u>	<u>929</u>
G	Total of Percentage	100	100	100	100	100	100
H	Total Served Population	61,846	<u>79,600</u>	<u>96,964</u>	<u>109,691</u>	<u>122,545</u>	<u>123,900</u>
	Total Domestic Water Consumption, m3/d	6,436	<u>9,105</u>	<u>13,004</u>	<u>15,652</u>	<u>18,327</u>	<u>19,428</u>
I	Industrial Water Use						
	Industrial Area, ha	133	136	138	140	132	124
	Unit Industrial Water Use, L/(ha.d)	13,078	13,078	13,078	13,078	13,078	13,078
	Industrial Water Consumption, m3/d	1,739	1,779	1,805	1,831	1,726	1,622
J	Commercial Water Use						
	Commercial Area, ha	108	112	114	116	118	120
	Unit commercial Water Use, L/(ha.d)	686	686	686	686	686	686
	Commercial Water Consumption, m3/d	74	77	78	80	81	82
K	Institutional Water Use						
	Institutional Area, ha	94	96	98	100	102	104
	Unit Institutional Water Use, L/(ha.d)	49,968	49,968	49,968	49,968	49,968	49,968
	Institutional Water Consumption, m3/d	4,697	4,797	4,897	4,997	5,097	5,197
L	Total Net Water Consumption, m3/d	12,946	15,757	19,784	22,559	25,231	26,328
M	Water Loss						
	Water Loss Ratio, %	25	23	21	20	19	18
	Water Loss, m3/d	4,315	4,707	5,278	5,364	5,349	5,311
N	Total Water Supply Required, m3/d	17,262	20,464	25,043	28,199	31,149	32,108

- Note: 1. Revised values are shown in underlined italic letters.
 2. Population of year 2000 is revised.
 3. Served population in year 2000 is revised based on data of number of connections.
 4. Full coverage of population is assumed in the year 2015.

APPENDIX 3A-3

NWSDB ESTIMATE FOR KOTIKAWATTE-
MULLERIYAWA WATER SUPPLY
IMPROVEMENT

APPENDIX 3B

DIAMETERS OF TRANSMISSION MAIN

APPENDIX 3B DIAMETERS FOR TRANSMISSION MAIN

3B.1 OUTLINE

To determine the economical transmission system to pump water from Ambatale Water Treatment Plant to Gothatuwa Ground Reservoir and Kolonnawa New Ground Reservoir, analysis was carried out comparing present worth of capital and operation costs for the following.

- Separate pump houses and separate transmission mains to Gothatuwa and Kolonnawa
- Common pump house, common transmission main with branches to Gothatuwa and Kolonnawa

Three cases were developed for analysis.

Case 1 Separate Transmission system to Gothtuwa Ground Reservoir and Kolonnawa New Ground Reservoir

Case 1-1 Pumping to Gothatuwa Ground Reservoir Only

Case 1-2 Pumping to Kolonnawa New Ground Reservoir Only

Case 2 Pumping to Gothatuwa and Kolonnawa – 800/500/600

Case 3 Pumping to Gothatuwa and Kolonnawa – 700/500/600

Table 3B-1 shows the hydraulic calculations for transmission main alternatives. Figures 3B-1 show the schematic of transmission system for each of the above case. Head loss around pump is accounted for by adding 2 m head and approximating to the nearest whole number.

Hazen-William coefficient C is assumed at 110 accounting for the losses in fittings, curves etc. along the pipeline.

3B.2 Basic Assumptions

Main components of transmission system for comparison are as follows.

- Capital cost of transmission mains
- Energy cost (power) for pumping

Construction cost of pump house at Ambatale is excluded as the difference between that for a common pump house and that for separate pump houses are negligible for the purpose of this analysis. Capital cost of pumps are also excluded as their costs are similar for Case 2 and Case 3. For Case 1, including the cost of pumps will increase the cost.


3B.3 Results

Table 3B-2 shows the comparison for discount rate at 10%, 5% and 15%. Table B-3 shows the summary of comparison for discount rate of 10%.


Table 3B-3 Summary of Transmission Alternatives

Item	Case 1-1	Case 1-2	Case 1	Case 2	Case 3
Cost of Transmission mains, SLRs.	104,160,198	208,893,492	313,053,690	269,009,331	265,167,339
Energy Cost, SLRs.	27,638,047	26,043,488	53,681,535	61,801,319	71,643,141
Net Present Value, SLRs. (nearest thousand)	131,798,000	234,937,000	366,735,000	330,811,000	336,810,000

Based on the above results, Case 2 is the most economical transmission system. As evident from Figure 3B-1, pumping through a common will result in excess energy that need to be dissipated in Case 2 and in Case 3. However, combining the transmission main for Gothatuwa and for Kolonnawa far outweigh individual pumping in Case 1 and therefore excess energy dissipation in Case 2 or Case 3 is inevitable.




CASE 1-1




CASE 1-2

FIG. 3B-1	Schematic of Transmission System Alternatives
SCALE	Not to scale
JICA STUDY TEAM	
THE DETAILED DESIGN STUDY ON THE PROJECT FOR REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA IN THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA	



CASE 2



CASE 3

FIG. 3B-2	Schematic of Transmission System Alternatives
SCALE	Not to scale
JICA STUDY TEAM	
THE DETAILED DESIGN STUDY ON THE PROJECT FOR REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA IN THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA	

Table 3B- 1 Hydraulic Calculation of Transmission Alternatives

CASE 1-1 Pumping to Gothatuwa Ground Reservoir Only

NODE									
NO	Type	Q l/sec	WL m	GL m	EH m				
1	1	-357.800	9.15		7.00	2.15			
2	0	0.000	40.24		11.00	29.24			
3	0	0.000	32.09		18.00	14.09			
4	0	357.800	26.25		26.25	0.00			
1.000									
PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	600	50		110	31.25	357.80	1.27	3.21
2	3	600	2541		110		357.80	1.27	3.21
3	4	600	1821		110		357.80	1.27	3.21

End

CASE 1-2 Pumping to Kolonnawa New Ground Reservoir Only

NODE									
NO	Type	Q l/sec	WL m	GL m	EH m				
1	1	-342.300	9.15		7.00	2.15			
2	0	0.000	51.09		11.00	40.09			
3	0	0.000	43.58		18.00	25.58			
5	0	342.300	25.25		25.25	0.00			
1.000									
PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	600	50		110	42.09	342.30	1.21	2.95
2	3	600	2541		110		342.30	1.21	2.95
3	5	600	6207		110		342.30	1.21	2.95

End

CASE 2 Pumping to Gothatuwa and Kolonnawa 800/500/600

NODE									
NO	Type	Q l/sec	WL m	GL m	EH m				
1	1	-700.100	9.15		7.00	2.15			
2	0	0.000	50.53		11.00	39.53			
3	0	0.000	43.59		18.00	25.59			
4	0	357.800	29.40		26.25	3.15			
5	0	342.300	25.25		25.25	0.00			
1.000									
PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	600	50		110	41.94	700.10	2.48	11.10
2	3	800	2541		110		700.10	1.38	2.73
3	4	500	1821		110		357.80	1.82	7.79
3	5	600	6207		110		342.30	1.21	2.95

End

CASE 3 Pumping to Gothatuwa and Kolonnawa 700/500/600

NODE									
NO	Type	Q l/sec	WL m	GL m	EH m				
1	1	-700.100	9.15		7.00	2.15			
2	0	0.000	56.90		11.00	45.90			
3	0	0.000	43.59		18.00	25.59			
4	0	357.800	29.40		26.25	3.15			
5	0	342.300	25.25		25.25	0.00			
1.000									
PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	600	50		110	48.31	700.10	2.48	11.10
2	3	700	2541		110		700.10	1.82	5.24
3	4	500	1821		110		357.80	1.82	7.79
3	5	600	6207		110		342.30	1.21	2.95

End

Note: Q Flowrate
 C Hazen-William Coefficient
 WL Water Level
 GL Ground Level
 EH Effective Head
 dH Pumping Head
 V Velocity
 I Friction Gradient

Table B-2 Comparison of Transmission Alternatives

Item		Case 1-1	Case 1-2	Case 1	Case 2	Case-3
		Q=30,910 m ³ /d	Q=29,575 m ³ /d	Q=30,910+29,575 m ³ /d	Q=60,485 m ³ /d	Q=60,485 m ³ /d
		φ 600 mm	φ 600 mm		φ 800/500/600 mm	φ 700/500/600 mm
		Pumping to Gothatuwa GR only	Pumping to Kolonnawa New GR Only		Pumping to Gothatuwa GR and New Kolonnawa GR	Pumping to Gothatuwa GR and New Kolonnawa GR
Cost of pipe (Ambatale-Hospital Junction), m	2,541	60,676,539	60,676,539	121,353,078	88,912,131	85,070,139
Cost of Pipe (Hospital Junction - Gothatuwa), m	1,821	43,483,659		43,483,659	31,880,247	31,880,247
Cost of Pipe (Hospital Junction - Kolonnawa), m	6,207		148,216,953	148,216,953	148,216,953	148,216,953
Total Cost of Pipe		104,160,198	208,893,492	313,053,690	269,009,331	265,167,339
Pump Head, m		34	44		44	51
Overall power efficiency		0.7	0.7		0.7	0.7
KVA rating required		155	192		392	455
Unit demand charge (SLRs./kVA)		240	240		240	240
Total Fixed Power Demand Charge (present value)		3,980,218	4,930,335	8,910,553	10,066,101	11,683,867
Unit power cost, (SLRs./kWh)		4.25	4.25		4.25	4.25
Total Power Consumption Cost (present value)		43,046,252	40,986,497	84,032,748	96,693,411	112,076,453
Total Cost of Energy, SLRs. (present value)		47,026,470	45,916,832	92,943,302	106,759,511	123,760,320
Total Present Value, SLRs. (year 2000)		151,187,000	254,810,000	405,997,000	375,769,000	388,928,000
				30,228,000	0	13,159,000

Annual power consumption cost (present value)						
year 2005		3,222,136	2,086,547	5,309,683	6,256,371	7,251,702
year 2006		3,151,175	2,210,097	5,361,273	6,288,089	7,288,467
year 2007		3,079,666	2,317,150	5,396,815	6,302,599	7,305,286
year 2008		3,007,821	2,408,995	5,416,816	6,301,469	7,303,976
year 2009		2,935,836	2,486,839	5,422,674	6,286,155	7,286,225
year 2010		2,863,885	2,551,806	5,415,691	6,258,011	7,253,603
year 2011		2,792,130	2,604,947	5,397,077	6,218,292	7,207,566
year 2012		2,720,715	2,647,241	5,367,956	6,166,166	7,149,465
year 2013		2,649,770	2,679,599	5,329,369	6,108,713	7,080,554
year 2014		2,579,412	2,702,873	5,282,265	6,040,936	7,001,994
year 2015		2,509,746	2,717,855	5,227,601	5,965,761	6,914,860
year 2016		2,440,866	2,725,280	5,166,146	5,884,048	6,820,147
year 2017		2,372,855	2,725,836	5,098,691	5,796,589	6,718,774
year 2018		2,305,787	2,720,159	5,025,945	5,704,118	6,611,591
year 2019		2,239,725	2,708,841	4,948,566	5,607,308	6,499,380
year 2020		2,174,726	2,692,433	4,867,159	5,506,785	6,382,864
Present value		43,046,252	40,986,497	84,032,748	96,693,411	112,076,453

Annual fixed power cost (present value)						
year 2005		349,766	433,259	783,025	884,570	1,026,733
year 2006		333,111	412,627	745,738	842,447	977,841
year 2007		317,248	392,978	710,226	802,331	931,277
year 2008		302,141	374,265	676,406	764,125	886,930
year 2009		287,753	356,443	644,196	727,738	844,696
year 2010		274,051	339,469	613,520	693,084	804,472
year 2011		261,001	323,304	584,305	660,080	766,164
year 2012		248,572	307,909	556,481	628,647	729,680
year 2013		236,735	293,246	529,982	598,712	694,933
year 2014		225,462	279,282	504,745	570,202	661,841
year 2015		214,726	265,983	480,709	543,049	630,325
year 2016		204,501	253,317	457,818	517,190	600,309
year 2017		194,763	241,255	436,017	492,562	571,723
year 2018		185,488	229,766	415,255	469,106	544,498
year 2019		176,656	218,825	395,481	446,768	518,570
year 2020		168,243	208,405	376,648	425,493	493,876
Present value		3,980,218	4,930,335	8,910,553	10,066,101	11,683,867

Discount rate	5%	1.05	1.05	1.05	1.05
Cost of pipe					
		400 DI			15,684
		500 DI			17,507
		600 DI			23,879
		700 DI			33,479
		800 DI			34,991

Table B-2 Comparison of Transmission Alternatives

Item	Case 1-1		Case 1-2	Case 1	Case 2	Case-3
	Q=30,910 m ³ /d		Q=29,575 m ³ /d	Q=30,910+29,575 m ³ /d	Q=60,485 m ³ /d	Q=60,485 m ³ /d
	φ 600 mm	φ 600 mm	φ 600 mm		φ 800/500/600 mm	φ 700/500/600 mm
		Pumping to Gothatuwa GR only	Pumping to Kolonnawa New GR Only		Pumping to Gothatuwa GR and New Kolonnawa GR	Pumping to Gothatuwa GR and New Kolonnawa GR
Cost of pipe (Ambatale-Hospital Junction), m	2,541	60,676,539	60,676,539	121,353,078	88,912,131	85,070,139
Cost of Pipe (Hospital Junction - Gothatuwa), m	1,821	43,483,659		43,483,659	31,880,247	31,880,247
Cost of Pipe (Hospital Junction - Kolonnawa), m	6,207		148,216,953	148,216,953	148,216,953	148,216,953
Total Cost of Pipe		104,160,198	208,893,492	313,053,690	269,009,331	265,167,339
Pump Head, m		34	44		44	51
Overall power efficiency		0.7	0.7		0.7	0.7
KVA rating required		155	192		392	455
Unit demand charge (SLRs./KVA)		240	240		240	240
Total Fixed Power Demand Charge (present value)		1,519,703	1,882,471	3,402,174	3,843,378	4,461,064
Unit power cost, (SLRs./KWh)		4.25	4.25		4.25	4.25
Total Power Consumption Cost (present value)		15,787,977	13,898,660	29,686,637	34,330,160	39,791,776
Total Cost of Energy, SLRs. (present value)		17,307,680	15,781,131	33,088,811	38,173,538	44,252,840
Total Present Value, SLRs. (year 2000)		121,468,000	224,675,000	345,143,000	307,183,000	309,420,000
				38,960,000	0	2,237,000

Annual power consumption cost (present value)						
year 2005		2,044,566	1,323,992	3,369,559	3,669,902	4,601,477
year 2006		1,825,666	1,280,443	3,106,109	3,643,069	4,222,648
year 2007		1,629,085	1,225,728	2,854,814	3,333,956	3,864,359
year 2008		1,452,726	1,163,503	2,616,229	3,043,501	3,527,695
year 2009		1,294,657	1,096,657	2,391,314	2,772,096	3,213,111
year 2010		1,153,109	1,027,454	2,180,562	2,519,712	2,920,575
year 2011		1,026,459	957,646	1,984,105	2,286,005	2,649,688
year 2012		913,231	888,569	1,801,799	2,070,397	2,399,778
year 2013		812,077	821,219	1,633,295	1,872,142	2,169,982
year 2014		721,774	756,321	1,478,095	1,690,381	1,959,305
year 2015		641,212	694,381	1,335,593	1,524,185	1,766,669
year 2016		569,387	635,733	1,205,119	1,372,586	1,590,952
year 2017		505,389	580,570	1,085,959	1,234,603	1,431,017
year 2018		448,400	528,981	977,381	1,109,264	1,285,737
year 2019		397,679	480,974	878,652	995,617	1,154,010
year 2020		352,561	436,490	789,050	892,745	1,034,772
Present value		15,787,977	13,898,660	29,686,637	34,330,160	39,791,776
Annual fixed power cost (present value)						
year 2005		221,940	274,919	496,859	561,293	651,500
year 2006		192,991	239,060	432,051	488,081	566,522
year 2007		167,818	207,878	375,696	424,418	492,628
year 2008		145,929	180,764	326,693	369,059	428,372
year 2009		126,895	157,186	284,080	320,921	372,497
year 2010		110,343	136,683	247,027	279,062	323,911
year 2011		95,951	118,855	214,806	242,662	281,662
year 2012		83,435	103,352	186,788	211,011	244,923
year 2013		72,552	89,871	162,424	183,488	212,977
year 2014		63,088	78,149	141,238	159,554	185,197
year 2015		54,860	67,956	122,816	138,743	161,041
year 2016		47,704	59,032	106,796	120,646	140,036
year 2017		41,482	51,384	92,866	104,910	121,770
year 2018		36,071	44,682	80,753	91,226	105,887
year 2019		31,365	38,854	70,220	79,327	92,076
year 2020		27,275	33,786	61,061	68,980	80,066
Present value		1,519,703	1,882,471	3,402,174	3,843,378	4,461,064

Discount rate	15%	1.15	1.15	1.15	1.15
Cost of pipe					
		400 DI			15,684
		500 DI			17,507
		600 DI			23,879
		700 DI			33,479
		800 DI			34,991

Table B-2 Comparison of Transmission Alternatives

Item		Case 1-1	Case 1-2	Case 1	Case 2	Case-3
		Q=30,910 m ³ /d	Q=29,575 m ³ /d	Q=30,910+29,575 m ³ /d	Q=60,485 m ³ /d	Q=60,485 m ³ /d
		φ 600 mm	φ 600 mm		φ 800/500/600 mm	φ 700/500/600 mm
		Pumping to Gothatuwa GR only	Pumping to Kolonnawa New GR Only		Pumping to Gothatuwa GR and New Kolonnawa GR	Pumping to Gothatuwa GR and New Kolonnawa GR
Cost of pipe (Ambatale-Hospital Junction), m	2,541	60,676,539	60,676,539	121,353,078	88,912,131	85,070,139
Cost of Pipe (Hospital Junction - Gothatuwa), m	1,821	43,483,659		43,483,659	31,880,247	31,880,247
Cost of Pipe (Hospital Junction - Kolonnawa), m	6,207		148,216,953	148,216,953	148,216,953	148,216,953
Total Cost of Pipe		104,160,198	208,893,492	313,053,690	269,009,331	265,167,339
Pump Head, m		34	44		44	51
Overall power efficiency		0.7	0.7		0.7	0.7
kVA rating required		155	192		392	455
Unit demand charge (SLRs./kVA)		240	240		240	240
Total Fixed Power Demand Charge (present value)		2,385,427	2,954,851	5,340,278	6,032,822	7,002,382
Unit power cost, (SLRs./kWh)		4.25	4.25		4.25	4.25
Total Power Consumption Cost (present value)		25,252,620	23,088,637	48,341,257	55,768,498	64,640,759
Total Cost of Energy, SLRs. (present value)		27,638,047	26,043,488	53,681,535	61,801,319	71,643,141
Total Present Value, SLRs. (year 2000)		131,798,000	234,937,000	366,735,000	330,811,000	336,810,000
				35,924,000	0	5,999,000

Annual power consumption cost (present value)						
year 2005		2,553,448	1,653,527	4,206,975	4,957,989	5,746,760
year 2006		2,383,703	1,671,826	4,055,530	4,756,619	5,513,354
year 2007		2,223,719	1,673,133	3,896,851	4,550,886	5,274,891
year 2008		2,073,122	1,660,385	3,733,507	4,343,248	5,034,221
year 2009		1,931,529	1,636,127	3,567,657	4,135,753	4,793,714
year 2010		1,798,547	1,602,558	3,401,105	3,930,089	4,555,331
year 2011		1,673,780	1,561,571	3,235,351	3,727,639	4,320,673
year 2012		1,556,834	1,514,791	3,071,626	3,529,518	4,091,032
year 2013		1,447,319	1,463,612	2,910,930	3,336,612	3,867,437
year 2014		1,344,848	1,409,218	2,754,067	3,149,610	3,650,685
year 2015		1,249,048	1,352,619	2,601,666	2,969,033	3,441,380
year 2016		1,159,551	1,294,664	2,454,215	2,795,259	3,239,959
year 2017		1,076,003	1,236,067	2,312,071	2,628,542	3,046,720
year 2018		998,063	1,177,425	2,175,488	2,469,037	2,861,838
year 2019		925,402	1,119,230	2,044,631	2,316,808	2,685,391
year 2020		857,703	1,061,884	1,919,587	2,171,853	2,517,375
Present value		25,252,620	23,088,637	48,341,257	55,768,498	64,640,759

Annual fixed power cost (present value)						
year 2005		277,179	343,345	620,524	700,995	813,655
year 2006		251,981	312,132	564,113	637,268	739,687
year 2007		229,074	283,756	512,830	579,335	672,442
year 2008		208,249	257,960	466,209	526,668	611,311
year 2009		189,317	234,509	423,826	478,789	555,738
year 2010		172,107	213,190	385,297	435,263	505,216
year 2011		156,460	193,809	350,270	395,694	459,287
year 2012		142,237	176,190	318,427	359,721	417,534
year 2013		129,306	160,173	289,479	327,019	379,576
year 2014		117,551	145,612	263,163	297,290	345,069
year 2015		106,865	132,374	239,239	270,264	313,699
year 2016		97,150	120,340	217,490	245,695	285,181
year 2017		88,318	109,400	197,718	223,359	259,256
year 2018		80,289	99,455	179,744	203,053	235,687
year 2019		72,990	90,413	163,403	184,594	214,261
year 2020		66,355	82,194	148,548	167,813	194,783
Present value		2,385,427	2,954,851	5,340,278	6,032,822	7,002,382

Discount rate	10%	1.1	1.1	1.1	1.1
Cost of pipe					
		400 DI			15,684
		500 DI			17,507
		600 DI			23,879
		700 DI			33,479
		800 DI			34,991

APPENDIX 3C

DISTRIBUTION
ANALYSIS

PIPE

NETWORK

APPENDIX 3C DISTRIBUTION NETWORK ANALYSIS

3C.1 BASIS OF NETWORK ANALYSIS

Preliminary network analysis was carried out to determine the requirement of pipeline strengthening for the year 2020 demand. Approximately 40 km of priority pipeline was selected for strengthening under this project. Route and leveling surveys were carried out along the priority pipeline routes. Network analysis was refined with the information obtained from route and leveling survey and information from the NWSDB field staff. Following were used in the analysis.

- Preliminary analysis was based on length and ground elevation from 1:10000 scale map (blue print) provided by NWSDB. Length and ground elevation along priority pipeline routes are from the survey results. Difference in pipe lengths are negligible for this purpose.
- Hazen-Williams equation is used with C values as follows

For all PVC mains above 100 mm or 4"	- 130
DI pipes with cement mortar lining (250 mm and above)	- 120
All existing pipes less than 4" or 110 mm PVC	- 90
- Internal diameter used for the network calculations are as follows:

Table 3C-1 Internal Diameters Used for Network Calculations

Nominal Diameter	Internal Diameter used for computation, mm
1"	25
1 1/2"	38
2"	50
2 1/2"	63
3"	75
4"	100
6"	150
90 mm PVC	75
110 mm PVC	100
225 mm PVC	200
250 mm DI	250
300 mm DI	300
400 mm DI	400
500 mm DI	500

- All existing tappings from transmission mains are considered to be closed and the single distribution source will be the New Gothatuwa Water Tower whose minimum water level is 41.5 m above MSL. (Node number of the source is N1500.) Pipes for strengthening are added to the network starting from pipe number P2100 until P2307 connected at

interconnections to the existing network.

- Demand is allocated to the same nodes as NWSDB with a factor to account for the increased demand. Nodes where demand is allocated are shown in italics in the worksheet. Other dummy nodes are used with zero demand to account for the shape of the pipe route since pipe length is calculated automatically from the scanned map. Zero demand is assigned to these dummy nodes.
- Hourly maximum demand is 49,500 m³/d (hourly peak factor of 1.6) and day maximum demand is 30,910 m³/d in the year 2020.
- New pipelines along Avissawella Road was avoided as there are four large size transmission mains (two 30" and two 20") and a 4" distribution main existing on that road in addition to telephone cables. Laying another main will be extremely difficult unless road is widened. Larger main could be laid when road widening is carried out. Network analysis is made considering only the existing distribution main in that road.
- Minimum allowable residual pressure head is 10 m of water during maximum hourly flow condition. However, exceptions are allowed for interior nodes where residual pressure head is close to 10 m.
- Network analysis was carried out by VIPNES (Visual Pipeline Network Simulator) Program.
- Changes/modifications were made on the routes and diameters following the preliminary analysis and survey results.

- Shanthi Mawatha - revised route following survey
- Pethiagoda Road - revised route following survey
- Malpura Road - revised route following survey
- Salalihini Mawatha - eliminated (no connecting road between Siri Sumana Mawatha and Ranabiru Mawatha)

Nagahawela Road / Abeysiri Perera Mawatha

- small part eliminated and connection to Low level Road through Nagahawela Road is added

Between Halgahasdeniya Road and Koswatta Road


- additional route to reduce the diameter along Bandaranayakepura Road (400 mm to 300 mm) and increase network reliability

- Diameters were reduced to reduce residual pressures along low-lying areas, especially along Old Avissawella Road (Sedawatta Road)
- Diameter along Udumulla Road was increased to improve residual pressures along Udumulla Road

3C.2 RESULTS OF NETWORK ANALYSIS


Figure 3C-1 shows the pipeline network for the year 2020 showing priority pipelines to be strengthened as thick lines. Table 3C-2 shows the residual pressures at the nodes for the hourly maximum flow condition.

Network was checked for fire demand at average flow condition for not developing negative water pressures in the network.



1	3
2	4

FIG. 3C-1	Distribution Pipe Network for Kotikawatte-Mulleriyawa Area - Year 2020 (1/4)
SCALE	Not to scale
JICA STUDY TEAM THE DETAILED DESIGN STUDY ON THE PROJECT FOR REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA IN THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA	



1	3
2	4

FIG. 3C-1	Distribution Pipe Network for Kotikawatte-Mulleriyawa Area - Year 2020 (2/4)
SCALE	Not to scale
JICA STUDY TEAM	
THE DETAILED DESIGN STUDY ON THE PROJECT FOR REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA IN THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA	




FIG. 3C-1	Distribution Pipe Network for Kotikawatte-Mulleriyawa Area - Year 2020 (4/4)
SCALE	Not to scale
JICA STUDY TEAM	
THE DETAILED DESIGN STUDY ON THE PROJECT FOR REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA IN THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA	