

DAYANANDA ASSOCIATES CONSULTING ENGINEERS	PROJECT		JOB REF
	CALCULATIONS BY	CHECKED BY	CALC SHEET
	PART OF STRUCTURE		DATE

MEMBER REF	CALCULATIONS	OUT PUT
------------	--------------	---------

$M = 66 \text{ kNm}$, RB1 - 300 x 450

$$\frac{M}{f_c b d^2} = \frac{66 \times 10^6}{25 \times 250 \times 397.5^2} = 0.067$$

$$z = 0.908 \times 397.5 = 360.93$$

$$A_{st} = \frac{66 \times 10^6}{0.87 \times 450 \times 361} = 467 - 2720 (628)$$


$$v_u = \frac{94 \times 10^3}{250 \times 397.5} = 0.95$$

$$\frac{100 A_s}{b d} = \frac{100 \times 628}{250 \times 397.5} = 0.63$$

$$v_c = 0.57$$


$$b(v - v_c) = 250(0.95 - 0.57) = 95$$

110 @ 300 c/c




RB3 beam - 250 x 250


$$\text{nominal } r/f = 0.0013 \times 250 \times 250 = 81.25 - 2712 (226)$$



DAYANANDA ASSOCIATES		PROJECT	JOB REF
CONSULTING ENGINEERS		CALCULATIONS BY	CHECKED BY
MEMBER REF	CALCULATIONS	DATE	
	<p>column C₂ - 300 x 300</p> <p>N = 99 M = 66 kNm.</p> <p>$l_{ox} = 3.0 - 0.45 = 2.55$</p> <p>$l_{ex} = 1.2 \times 2.55$</p> <p>$\frac{l_{ex}}{h} = \frac{1.2 \times 2.55}{0.3} = 10.2$</p> <p>$\frac{N}{bhfc_u} = \frac{99 \times 10^3}{300^2 \times 25} = 0.044$] Nominal OK</p> <p>$\frac{M}{bh^2fc_u} = \frac{66 \times 10^6}{300 \times 300^2 \times 25} = 0.098$]</p> <p>provide 1% = 900 - 4Y16</p> <p>beam RB1 - 250 x 450</p> <p>case 1</p> <p>B.M.D.</p> <p>S.D.</p> <p>case 2</p> <p>B.M.D.</p> <p>M = 192 kNm.</p> <p>$\frac{M}{fc_u b d^2} = \frac{192 \times 10^6}{25 \times 250 \times 397^2} = 0.195$</p> <p>$z = 0.777 \times 397.5 = 308.86$</p> <p>Asc = $\frac{(0.195 - 0.156) \times 25 \times 250 \times 397^2}{0.87 \times 450 \times (397 - 50)} = 283 - 2Y16$ (402)</p> <p>92 Ast = $\frac{0.156 \times 25 \times 250 \times 397^2}{0.87 \times 450 \times 309} + 283 = 1553 - 2Y25 + 2Y20$ (1609)</p>		


DAYANANDA ASSOCIATES		PROJECT	JOB REF.
CONSULTING ENGINEERS		CALCULATIONS BY	CHECKED BY
		PART OF STRUCTURE	DATE
MEMBER REF	CALCULATIONS		OUTPUT
	<p>column - c₁ - 300x300</p> <p>$N = 303 \text{ kN}$</p> <p>$l_{ox} = 3200 - 450 = 2750$</p> <p>$\frac{l_{ox}}{h} = \frac{2750}{300} = 9.17$</p> <p>$M_{min} = 0.05 \times 0.3 \times 303 = 4.55$</p> <p>$\frac{N}{bh f_{cu}} = \frac{303 \times 10^3}{300^2 \times 25} = 0.135$</p> <p>$\frac{M}{bh^2 f_{cu}} = \frac{10 \times 10^6}{300 \times 300^2 \times 25} = 0.015$</p> <p>1% $x/f = 900$</p>		
	<p>RB6 - 250x250</p> <p>$\omega_d = 1.34 \times (2.3 + 2.6)/2 + 0.25 \times 0.45 \times 24 = 6.12$</p> <p>$\omega_s = 0.75 \times \text{''} = 1.91$</p> <p>4.02 1.572</p> <p>$n = 1.4 \times 6.12 + 1.6 \times 1.91 = 11.62 \text{ kN/m}$</p> <p>$M_{span} = \frac{\omega l^2}{8} = 11.62 \times \frac{4.02^2}{8} = 23.47$</p> <p>$M_{support} = \frac{\omega l^2}{12} = 11.62 \times \frac{4.02^2}{12} = 15.65 \text{ kNm}$</p> <p>$\frac{M}{f_{cu} b d^2} = \frac{24 \times 10^6}{25 \times 250 \times 200^2} = 0.096$</p> <p>$z = 0.861 \times 200 = 172.2$</p> <p>$A_{st} = \frac{24 \times 10^6}{0.87 \times 450 \times 172} = 356 - 2416 \text{ (402)}$</p>		
	<p>$V_{max} = 11.62 \times (\frac{4.02}{2} + 1.572) = 41.62 \text{ kN}$</p>		

DAYANANDA ASSOCIATES		PROJECT	JOB REF
CONSULTING ENGINEERS		CALCULATIONS BY	CHECKED BY
		CALC SHEET	
		PART OF STRUCTURE	DATE
MEMBER REF	CALCULATIONS		OUT PUT
RBG	$V_u = \frac{42 \times 10^3}{250 \times 200} = 0.84$ $\frac{100AS}{bd} = \frac{100 \times 402}{250 \times 200} = 0.804$ $V_c = 0.695$ $b(V_u - V_c) = 250(0.84 - 0.69) = 37.5$ <p>provide $0.4 \times 250 = 100 - 410 @ 150 c/c$</p> $M = 16 \text{ kNm}$ $\frac{M}{f_c b d^2} = \frac{16 \times 10^6}{25 \times 250 \times 200^2} = 0.064$ $z = 0.912 \times 200 = 182.4$ $A_{st} = \frac{16 \times 10^6}{0.87 \times 450 \times 182} = 225 - 2412$ <p>RBS - 250 x 450</p> $3.78 = 0.25 \times 0.45 \times 24 \times 1.4$ $P = 15 \times 1.5 \times 1.2 + 2 \times 11.62 \times \frac{4.62}{2} = 73.71 \text{ kN}$ $M_{span} = 74 \times \frac{5.823}{4} + \frac{4 \times 5.823^2}{8}$ $= 124.68 \text{ kNm}$ $\frac{M}{f_c b d^2} = \frac{125 \times 10^6}{25 \times 250 \times 397.5^2} = 0.127$ $z = 0.803 \times 397.5 = 319$ $A_{st} = \frac{125 \times 10^6}{0.87 \times 450 \times 319} = 1001 - 2425 + 1412 (1094)$ $V = \frac{74}{2} + \frac{4 \times 5.823}{2} = 48.65 \text{ kN}$		

DAYANANDA ASSOCIATES		PROJECT	JOB REF
CONSULTING ENGINEERS		CALCULATIONS BY	CALC SHEET
		PART OF STRUCTURE	DATE
MEMBER REF	CALCULATIONS		OUTPUT
RBS	$V_u = \frac{49 \times 10^3}{250 \times 397.5} = 0.493$ $\frac{100 A_S}{b d} = \frac{100 \times 1094}{250 \times 397.5} = 1.1$ $V_c = 0.65$ <p>provide $0.4 \times 250 = 100$ $\phi 10 @ 300 c/c$</p> 		


**ROOF REHABILITATION OF EXISTING
MALIGAKANDA RESERVOIR**



PROJECT	Reduction of non-revenue water in the Greater Colombo Area										
PART OF STRUCTURE	Maligakanda -Rehabilitation of Existing reservoir										
REF	CALCULATIONS	OUTPUT									
	<p>Since the existing columns are on a grid of 4.83 x 4.83 metres a similar grid was selected to support a rc flat slab type roof.</p> <p>4.83m x 4.83 m grid</p> <p>Loading -roof slab</p> <p>Dead load</p> <table border="0"> <tr> <td>Slab</td> <td>=</td> <td>0.25*24 = 6 kN/m²</td> </tr> <tr> <td>Pebbles</td> <td>=</td> <td>0.25 * 20 = 5 kN/m²</td> </tr> <tr> <td>Mortar</td> <td>=</td> <td>0.25*22 = 5.5 kN/m²</td> </tr> </table> <p>Imposed load</p> <p>For 4.83 m width,</p> <p>Case 1</p> <p>SLS total dead load (wd) = 4.83*16.5 = 79.69 kN\m</p> <p>total super load (ws) = 2.5*4.83 = 12.08 kN\m</p> <p>Case 2</p> <p>ULS total dead load (wd) = 4.83*16.5*1.4 = 111.57 kN\m</p> <p>total super load (ws) = 2.5*4.83*1.6 = 19.32 kN\m</p> <p>Refer to computer analysis output sheets</p>  <p>width of the column strip = $4.83/2$ = 2.415 m</p>	Slab	=	0.25*24 = 6 kN/m ²	Pebbles	=	0.25 * 20 = 5 kN/m ²	Mortar	=	0.25*22 = 5.5 kN/m ²	<p>16.5kN/m²</p> <p>2.5kN/m²</p>
Slab	=	0.25*24 = 6 kN/m ²									
Pebbles	=	0.25 * 20 = 5 kN/m ²									
Mortar	=	0.25*22 = 5.5 kN/m ²									


PROJECT	Reduction of non-revenue water in the Greater Colombo Area		
PART OF STRUCTURE	Maligakanda -Rehabilitation of Existing reservoir		
REF	CALCULATIONS		OUTPUT
SLS			
	Col strip	Mid strip	
Near centre of 1st span,	$0.55 \cdot 182 / (4.83/2)$ =41.51kNm	$0.45 \cdot 182 / (4.83/2)$ =34kNm	
1st interior support,	$-0.75 \cdot 233 / (4.83/2)$ =72.4 kNm	$-0.25 \cdot 233 / (4.83/2)$ =24.1 kNm	
ULS			
	Col strip	Mid strip	
Near centre of 1st span,	$0.55 \cdot 273 / (4.83/2)$ =62.17 kNm	$0.45 \cdot 273 / (4.83/2)$ =50.87kNm	
1st interior support,	$-0.75 \cdot 330 / (4.83/2)$ =102.5 kNm	$-0.25 \cdot 330 / (4.83/2)$ =34.2 kNm	
R/f for thermal & shrinkage crack control in immature concrete			
area of steel	(A_{st})	= $112.5 \cdot 10^3 \cdot 2 \cdot 12 \cdot 10^{-6} (25+14) \emptyset / (6 \cdot 0.2 \cdot 2)$	
	A_{st}	= 44 \emptyset	
selected bar dia.		= 10 mm	
	A_{st}	= 786 mm ² /m	y10@100mm
R/f for flexure			
overall depth of slab (h)		= 250 mm	
cover to main r/f in botom face		= 50 mm	
cover to main r/f in botom face		= 40 mm	
Effective depth (d)		= 250-40-10 = 200 mm	

PROJECT		Reduction of non-revenue water in the Greater Colombo Area		
PART OF STRUCTURE		Maligakanda - Rehabilitation of Existing reservoir		
REF		CALCULATIONS		OUT PUT
	SLS	Near centre of 1st span,	1st interior support	
	Moment (M_{s1s})	41.5 kNm/m	72.4 kNm/m	
	$K=M/bd^2f_{cu}$	0.03 <.156	0.056 <.156	
		no compression steel required	no compression steel required	
	$z=d\{.5+[0.25-(k/0.9)]^{1/2}\}$	180.5 mm	177.41 mm	
	$A_s=M/0.87f_yz$	532 mm ² /m	991 mm ² /m	
		Y12-100c/c	Y16-100c/c + Y10-100c/c	Crackwidth 0.172 mm
	ULS			
	col strip,			
	(-ve) M_{ult}	=	102.5 kNm	
	$2/3^{rd}$ of an half col strip	=	4.83/4	= 1.21 m
		=	$2/3*(102.5)*4.83/2$	
		=	165./1.21 kNm/m	
		=	136.4 kNm/m	
	A_s	=	1921 mm ² /m	
		Y16-100c/c		
		+		
		Y10-100c/c	provided and is ok	

PROJECT	Reduction of non-revenue water in the Greater Colombo Area	
PART OF STRUCTURE	Maligakanda -Rehabilitation of Existing reservoir	
REF	CALCULATIONS	OUT PUT
	<p>Column head and 600mm dia. Column</p> <p>Shear @ column head = $(16.5 \times 1.4 + 2.5 \times 1.6) \times 4.83^2$ kN = 27.1×4.83^2 (V_u) = 632.21 kN</p> <div style="text-align: center;">  </div> <p>$h_c < 0.25 \times 4830$ = 1207 mm</p> <p>$V_u = \frac{[632.21 - p \times 1.6^2 \times 27.1/4] \times 1.15 \times 10^3}{[p \times 1600 \times 200]}$ = 0.66 N/mm²</p> <p>$A_{st} = Y16-100c/c$ + Y10-100c/c = 2796 mm²/m</p> <p>$v_c = 0.94 \text{ N/mm}^2 > V_u$</p> <p>$V_u / \text{m width} = \frac{659.48}{[(22/7) \times 1.6]}$ = 131.2 kN/m</p> <p>Typ column head, $N_u = 632.21 \text{ KN}$</p> <p>since $V_u < v_c$ -nominal R/F is required in the column heads</p> <p>nominal R/F = $(0.0035/2) \times 250 \times 10^3$ Y 16 -400 c/c is ok Provide 14 numbers of Y 16 bars to be in line with column reinforcement</p> <p>4.83m simply supported span,</p> <p>$M_{sls} = (16.5 + 2.5) \times 4.83^2 / 8$ = 55.41 kNm</p> <p>$M_{ult} = (16.5 \times 1.4 + 2.5 \times 1.6) \times 4.83^2 / 8$ = 79 kNm</p>	

PROJECT	Reduction of non-revenue water in the Greater Colombo Area	
PART OF STRUCTURE	Maligakanda -Rehabilitation of Existing reservoir	
REF	CALCULATIONS	OUT PUT

600 mm dia column to support the flat slab

	clear height	(l ₀)	=	13 m	(say)	
		l ₀	<=	60*500*10 ⁻³ m		o.k
		N	=	(451.477+38.72) + π*6.6 ² *24*1.0*13/4		
			=	578.4 kN		
		l/r	=	1.3*13*10 ³ /600		
			=	28		slender column
		β	=	0.39		
		M _{add}	=	578.4*0.39*0.6	kNm	
			=	135.35	kNm	
From computer analysis		M _{sls}	=	23.88	kNm	
		(M _x) _{sls}	=	159.23	kNm	
	Bi-Axial Bending					
		M _x /h'	=	M _y /b'		
		N/(A _c *f _{cu})	=	578.4*10 ³ /(π/4)*600 ² *35		
			=	0.06		
		β	=	0.93		
				uniaxial bending to be considered		
	Therefore,					
	Enhanced bending moment		=	159.23*1.93		
		M _{sls}	=	307.29 kNm		
		M	=	307.3 kNm		
		N	=	578.4 kN		
		R	=	30 cm		
		R _s	=	23.4 cm		
						
Design charts		A _s	=	112.59 cm ²	(4% A _c)	14Y32
		f _c	=	117.3 N/mm ²		



PROJECT	Reduction of non-revenue water in the Greater Colombo Area	
PART OF STRUCTURE	Maligakanda -Rehabilitation of Existing reservoir	
REF	CALCULATIONS	DATE
Roof Beams	<p>Typical frames considered in the analysis</p> <p>frame F₁</p> <p>Frame F₂</p> <p>Frame F₃</p> <p>Loading</p> <p>due to slab,</p> <p>$w_d = 16.5 \text{ kN/m}^2$</p> <p>$w_s = 2.5 \text{ kN/m}^2$</p> <p>Loads on frame</p> <p>File name M-NRF1</p> <p>F₁ -u.d.l</p> <p>$w_d = 16.5 \times 4.83 + 0.45 \times 0.5 \times 24$ $= 79.69 + 5.40$ $= 85 \text{ kN/m}$</p> <p>$w_s = 2.5 \times 4.83$ $= 12.08 \text{ kN/m}$</p>	

PROJECT		Reduction of non-revenue water in the Greater Colombo Area		
PART OF STRUCTURE		Maligakanda -Rehabilitation of Existing reservoir		
REF		CALCULATIONS		OUT PUT
	Load P			
	Point load P _d	= 16.5*4.83 ² /2 + 5.4*4.83/2		
		= 205.5 kN		
	Point load P _s	= 2.5*4.83 ² /2		
		= 29.16 kN		
M-NRF2	F ₂			
	w _d	= 85 kN/m		
	w _s	= 12.08 kN/m		
M-NRF3	F ₃			
	w _d	= 85 kN/m		
	w _s	= 12.08 kN/m		
	Typical Forces			
	F ₁			450x750
	Span moments			
	M _{sls}	= 152 kNm	provide 4Y20	
	M _{ult}	= 232 kNm		
	Support moments			
	M _{sls}	= 271 kNm		
	M _{ult}	= 384 kNm	provide 4Y20 +	
	v _u	= 405 kN	5Y25	
	A _{st} - min for } 750 face	= (750*250)*2*12*10 ⁻⁶ *32φ/(6*0.2*2)		
		= 60 φ		
	φ	A _{st}		
	16	960mm ²	5Y16	
	20	1200mm ²	4Y20	
	A _{st} - min for } 450 face	= (450/750)*60φ		
	φ	A _{st}		
	16	576mm ²	3Y16	
	20	720mm ²	3Y20	
	v _c -4Y20	= 0.53 N/mm ²	Y10-150c/c	
	End support,			
	v _u	= 274 kN		
	v _c -4Y20	= 0.53 N/mm ²	Y10-250c/c	o.k



PROJECT		Reduction of non-revenue water in the Greater Colombo Area	
PART OF STRUCTURE		Maligakanda -Rehabilitation of Existing reservoir	
		CALCULATIONS	
	F_2 & F_3		
	Span moments		
	M_{sls}	= 182 kNm	4Y20
	M_{ult}	= 273 kNm	
	Support moments		
	M_{sls}	= 235 kNm	
	M_{ult}	= 332 kNm	provide 4Y20 +
	v_u	= 401 kN	4Y16
	v_c - 4Y20	= 0.53 N/mm ²	Y10-150c/c
	End support,		
	v_u	= 286 kN	
	v_c - 4Y20	= 0.53 N/mm ²	Y10-250c/c
			o.k

PROJECT		Reduction of non-revenue water in the Greater Colombo Area		
PART OF STRUCTURE		Maligakanda -Rehabilitation of Existing reservoir		
		CALCULATIONS		
Base Slab	From comp analysis			
	M_{ult}	=	63.1 kNm	
	M_{slz}	=	63.1 / 1.4	Y12-100 c/c is ok for MsIs
		=	45.07 kNm	with enhancement of 25%
			56.34	
	h	=	300	d=300-50-12
	d	=	300-50-12 = 238 mm	=238
	A_{st} for M_{ult}	=	712 mm ²	
	v_u	=	(27.1x4.83 ² +PIx0.6 ² x24x13x1.4/4)1.15	
		=	869.07 kN/m	
		=	869.07*10 ³ / (PI*1290*230)	
		=	0.93 N/mm ²	
	v_c ($A_s=4273$ mm ² /m)		0.99 N/mm ²	Y12-100c/c (1130)+ Y20-100c/c (3141) provided ok
	Thermal & Shrinkage crack control steel,			
T_1	=	30 °c		
T_2	=	14 °c		
Steel ratio (r)	=	12*10 ⁻⁶ *44f/(3*0.2*2)		
A_s	=	4.4*150*10 ³ *f*10 ⁻⁴		
	=	66f		
f	A_{st}			
12	792		Y 12 -100 c/c is ok	
16	1056			


M-NRFS
BUILDING-SUB FRAME-M-NRFS



NEW ROOF-M-NRF2U



Maligakanda reservoir rehab- base slab				
	1st layer	2nd layer		
Dia of Bar mm	12	0	fy N/mm^2	450
Spacing mm	100	125	fcuN/mm^2	35
Bredth of Sect mm	1000			
Depth of sect mm	300	space-mm		
Clear cover mm	50	50		
Service M (kNM)	60.00			
			wcr(8007)	0.209 mm
			max 0.2mm	
Ast-mm^2	1131	1131	0	
Effect Depth mm			244	
fst N/mm^2	242.66			
fst All'ble	360.00			
fcu N/mm^2	7.19			
fcu all'ble	15.75			
		M-kanda		
Maligakanda reservoir rehab- base slab				
	1st layer	2nd layer		
Dia of Bar mm	12	20	fy N/mm^2	450
Spacing mm	100	100	fcuN/mm^2	35
Bredth of Sect mm	1000			
Depth of sect mm	300	space-mm		
Clear cover mm	50	50		
Service M (kNM)	150			
			wcr(8007)	0.199 mm
			max 0.2mm	
Ast-mm^2	4274	1131	3142.86	
Effective Depth			195	
fst N/mm^2	219.85			
fst All'ble	360.00			
fcu N/mm^2	17.48			
fcu all'ble	15.75			




MN/ELEM
STDR LOAD= 1

MX CONTOUR

- A -8.9
- B 5.5
- C 19.9
- D 34.3
- E 48.7
- F 63.1
- G 77.5
- H 91.9
- I 106.3
- J 120.7
- K 135.1
- L 149.5
- M 163.91
- N 178.31
- O 192.71
- 207.11

STRUCTURE DATA
 TYPE = SPACE
 NJ = 484
 NM = 0
 NE = 441
 NS = 0
 NRJ = 484
 NL = 3
 XMAX = 19.9
 YMAX = .0
 ZMAX = 19.9



J=484, E=441

UNIT MET KNS

S T A A D P O S T - P L O T (REV: 22.3a)

DATE: NOV 22, 2000

TITLE: "M-BASE2.STD" MALIGAKANGA OLD RESERVOIR

1. STAAD SPACE "M-BASEL.STD" MALIGANANGA OLD RESERVOIR BASE
 2. "MALIGANANGA RESERVOIR BASE SLAB"
 3. "BASE FOR THE OLD RESERVOIR"
 4. "BASE THICKNESS CHANGED 1.4 TO 1.3"
 ELEMENT FORCES FORCE, LENGTH UNITS= MM, METER
 FORCE OR STRESS FORCE/WIDTH/THICK, MOMENT = FORCE-LENGTH WIDTH

ELEMENT	LOAD	QX VONT	QY VONB	MX FM	MY FY	MXY FMY
22	1	-3.40	-28.38	-1.03	1.39	-6.94
		881.78	881.78	.00	.00	.00
23	1	13.09	10.80	3.94	1.61	-11.26
		1820.73	1820.73	.00	.00	.00
24	1	-15.70	57.84	14.89	-1.59	-9.81
		1827.64	1827.64	.01	.01	.06
25	1	-15.81	87.71	18.99	-2.32	-1.44
		1492.41	1492.41	.00	.00	.00
26	1	-13.96	65.65	7.80	-1.51	6.79
		973.15	973.15	.00	.00	.00
27	1	-24.57	-19.65	-12.07	.79	5.12
		1009.90	1009.90	.00	.00	.00
28	1	24.13	-20.51	-12.33	.85	-5.26
		1049.31	1049.31	.00	.00	.00
29	1	10.85	51.90	6.11	-1.40	-7.45
		976.81	976.81	.00	.00	.00
30	1	.89	80.48	18.93	-2.47	.06
		1219.39	1219.39	.00	.00	.00
31	1	-9.09	51.86	6.81	-1.31	7.94
		996.36	996.36	.00	.00	.00
ELEMENT	LOAD	QX VONT	QY VONB	MX FM	MY FY	MXY FMY
32	1	-23.18	-20.63	-11.64	1.13	5.27
		1013.07	1013.07	.00	.00	.00
33	1	13.24	-20.63	-11.63	1.14	-5.27
		1012.47	1012.47	.00	.00	.00
34	1	9.38	51.82	6.64	-1.33	-7.55
		997.19	997.19	.01	.00	.00
35	1	-1.77	80.47	18.97	-2.45	-1.07
		1121.49	1121.49	.00	.00	.00
36	1	-17.88	51.78	6.15	-1.38	7.41
		973.47	973.47	.00	.01	.00
37	1	-24.81	-20.89	-12.15	1.00	5.15
		1049.21	1049.21	.00	.00	.00
38	1	24.65	-20.60	-12.09	.99	-5.36
		1041.36	1041.36	.00	.00	.00
39	1	14.35	53.97	7.47	-1.33	-7.31
		1006.10	1006.10	.00	.00	.00
40	1	13.04	80.47	18.96	-2.46	.00
		1417.91	1417.91	.00	.00	.00
41	1	12.81	63.65	14.34	-1.11	7.45
		1369.27	1369.27	.01	.01	.01
ELEMENT	LOAD	QX VONT	QY VONB	MX FM	MY FY	MXY FMY
42	1	-3.09	-20.80	1.07	3.70	8.99
		1059.97	1059.97	.00	.00	.00
43	1	.54	-22.41	-11.82	7.19	-6.07
		881.11	881.11	.01	.00	.00
44	1	87.44	-12.88	1.43	11.71	-17.73
		1441.27	1441.27	.01	.01	.01
45	1	62.01	170.79	34.12	19.18	-1.04
		1134.51	1134.51	.01	.01	.00
46	1	-4.60	319.11	11.71	17.34	-1.86
		2177.49	2177.49	.00	.00	.00

47	1	-197.11	149.89	19.19	17.41	-7.48
		1708.37	1708.37	.00	.00	.00
48	1	-35.81	-35.81	-19.87	8.57	5.11
		1748.10	1748.10	.00	.00	.00
49	1	81.69	-35.81	-19.87	8.57	-5.11
		1748.10	1748.10	.00	.00	.00
50	1	168.96	134.47	19.87	16.77	-1.63
		1618.90	1618.90	.00	.00	.00
51	1	.01	331.63	19.87	37.34	-1.66
		1166.50	1166.50	.00	.00	.00

ELEMENT LOAD QX QY MX MY MXX
VONT VONS FX FY FXX

52	1	-163.86	133.63	19.87	16.77	-1.63
		1618.90	1618.90	.00	.00	.00
53	1	-35.81	-35.81	-19.87	8.57	5.11
		1748.10	1748.10	.00	.00	.00
54	1	81.69	-35.81	-19.87	8.57	-5.11
		1748.10	1748.10	.00	.00	.00
55	1	163.86	133.63	19.87	16.77	-1.63
		1618.90	1618.90	.00	.00	.00
56	1	.01	331.63	19.87	37.34	-1.66
		1166.50	1166.50	.00	.00	.00
57	1	-166.47	134.47	19.87	16.77	-1.63
		1618.90	1618.90	.00	.00	.00
58	1	-35.81	-35.81	-19.87	8.57	5.11
		1748.10	1748.10	.00	.00	.00
59	1	81.69	-35.81	-19.87	8.57	-5.11
		1748.10	1748.10	.00	.00	.00
60	1	168.96	134.47	19.87	16.77	-1.63
		1618.90	1618.90	.00	.00	.00
61	1	.01	331.63	19.87	37.34	-1.66
		1166.50	1166.50	.00	.00	.00

ELEMENT FORCES FORCE/LENGTH UNITS= KNS METRS
FORCE OR STRESS = FORCE/WIDTH/THICK, MOMENT = FORCE-LENGTH/WIDTH

ELEMENT	LOAD	QX VONT	QY VONS	MX FX	MY FY	MXX FXX
62	1	-131.66	149.89	19.41	19.82	1.80
		1989.11	1989.11	.00	.00	.00
63	1	-19.47	-49.83	.91	11.74	9.83
		1317.05	1317.05	.00	.00	.00
64	1	-19.79	-49.83	-1.97	8.34	-3.39
		650.60	650.60	.00	.00	.00
65	1	97.79	-1.69	1.17	16.83	-3.17
		1159.32	1159.32	.00	.00	.00
66	1	359.05	8.59	48.41	11.27	-1.44
		1619.97	1619.97	.00	.00	.00
67	1	-1.61	-1.64	116.69	163.81	-9.83
		19.44	19.44	.00	.00	.00
68	1	-471.11	-11.19	39.31	17.82	-1.71
		1762.11	1762.11	.00	.00	.00
69	1	-7.79	-7.79	-11.41	13.13	-1.19
		1074.99	1074.99	.00	.00	.00
70	1	94.65	-9.95	-13.11	12.92	.00
		1107.47	1107.47	.00	.00	.00
71	1	380.81	-8.16	16.97	17.24	.13
		1681.97	1681.97	.00	.00	.00

ELEMENT LOAD QX QY MX MY MXX
VONT VONS FX FY FXX

72	1	.05	-1.41	197.07	197.67	.59
		17.61	17.61	.00	.00	.00
73	1	-378.55	-6.77	18.98	17.35	-1.09
		1571.80	1571.80	.00	.00	.00
74	1	-94.69	-9.68	-11.51	13.15	.07

		2091.79	2091.79	.00	.00	.00
73	1	94.88	-9.88	-10.49	13.13	-1.08
		2091.89	2091.89	.00	.00	.00
78	1	178.88	-8.88	18.87	17.38	.09
		1873.39	1873.39	.00	.00	.00
77	1	-1.06	-1.41	149.19	147.79	-1.81
		17.61	17.61	.00	.00	.00
79	1	-381.79	-1.41	18.47	17.13	-1.18
		1851.81	1851.81	.00	.00	.00
79	1	-98.43	-9.14	-13.13	11.91	-1.11
		2114.86	2114.86	.00	.00	.00
80	1	89.83	-9.79	-11.74	13.09	-1.07
		2093.32	2093.32	.00	.00	.00
81	1	399.95	-8.34	19.89	17.92	.42
		1720.99	1720.99	.00	.00	.00

ELEMENT	LOAD	QX YOUT	QY VONE	MX FX	MY FY	MXY FXY
81	1	1.19	-1.97	204.53	148.87	8.11
		19.42	19.42	.00	.00	.00
83	1	-348.84	16.13	38.18	14.31	1.71
		2270.18	2270.18	.00	.00	.00
84	1	-38.87	-23.71	.94	19.55	3.01
		1256.01	1256.01	.00	.00	.00
85	1	8.66	-13.71	-1.98	6.55	.22
		407.83	407.83	.00	.00	.00
86	1	70.78	19.86	3.54	10.36	5.01
		939.93	939.93	.00	.00	.00
87	1	144.38	-248.38	38.42	15.39	-1.79
		1119.31	1119.31	.00	.00	.00
88	1	-21.30	-311.77	11.39	31.84	-1.14
		1820.48	1820.48	.00	.00	.00
89	1	-139.10	-100.15	-11.55	11.83	-1.19
		1808.89	1808.89	.00	.00	.00
90	1	-87.18	32.43	-18.19	7.99	-3.02
		1854.32	1854.32	.00	.00	.00
91	1	80.31	32.18	-19.10	8.00	4.91
		1704.93	1704.93	.00	.00	.00

FORCE OR STRESS = FORCE/WIDTH/THICK, MOMENT = FORCE-LENGTH/WIDTH

ELEMENT	LOAD	QX YOUT	QY VONE	MX FX	MY FY	MXY FXY
92	1	233.29	-202.73	19.96	23.74	.90
		1410.59	1410.59	.00	.00	.00
93	1	1.13	-331.89	17.74	31.69	.09
		1779.15	1779.15	.00	.00	.00
94	1	-132.96	-203.55	19.34	22.84	-1.69
		1422.78	1422.78	.00	.00	.00
95	1	-51.89	31.05	-18.70	8.07	-4.82
		1684.50	1684.50	.00	.00	.00
96	1	53.11	31.05	-19.70	8.07	4.82
		1686.89	1686.89	.00	.00	.00
97	1	132.94	-203.91	19.35	23.84	.70
		1422.84	1422.84	.00	.00	.00
98	1	-1.33	-331.19	17.73	31.69	-1.10
		1779.19	1779.19	.00	.00	.00
99	1	-233.61	-102.87	19.89	-11.73	-1.85
		1408.92	1408.92	.00	.00	.00
100	1	-81.78	31.83	-19.31	8.00	-5.00
		1721.21	1721.21	.00	.00	.00
101	1	86.86	32.87	-19.82	8.07	4.84
		1676.54	1676.54	.00	.00	.00

FORCE OR STRESS = FORCE/WIDTH/THICK, MOMENT = FORCE-LENGTH/WIDTH


ELEMENT	LOAD	QX	QY	MX	MY	MXY
---------	------	----	----	----	----	-----

		VONT	VONE	FX	FY	EXY
102	1	240.00	-200.75	21.93	22.94	.95
		1497.63	1497.63	.00	.00	.00
103	1	21.69	-311.96	21.12	31.14	1.04
		1939.35	1939.35	.00	.00	.00
104	1	-212.90	-209.74	32.31	24.96	0.06
		1969.70	1969.70	.00	.00	.00
105	1	-34.63	0.99	0.97	10.59	-3.27
		736.45	736.45	.00	.00	.00
106	1	-.52	-11.91	1.33	-.99	.92
		171.24	171.24	.00	.00	.00

MN/ELEM
DFOR LOAD= 1

STRUCTURE DATA

TYPE = SPACE
 NJ = 484
 NM = 0
 NE = 441
 NS = 0
 NRJ = 484
 NL = 1
 XMAX = 19.9
 YMAX = .0
 ZMAX = 19.9



Max Displ = .002
 J=484, E=441

UNIT MET KNS

STA O P O S T - P L O T (REV: 22.3a)
 TITLE: "M-BASE2.STD" MALIGAKANGA OLD RESERVOIR
 DATE: OCT 14, 2000

Maligakanda reservoir rehab- Roof slab -free span				
	1st layer		2nd layer	
Dia of Bar mm	10		16	fy N/mm ² 450
Spacing mm	150		150	fcuN/mm ² 35
Bredth of Sect mm	1000			
Depth of sect mm	250		space-mm	
Clear cover mm	50		0	
Service M (kNM)	59.33			
			wcr(8007)	0.122 mm
			max 0.2mm	
Ast-mm ²	1865	524	1341	
Effect Depth mm			186	
fst N/mm ²	199.47			
fst All'ble	360.00			
fcB N/mm ²	9.48			
fcB all'ble	15.75			
			M-kanda	
Maligakanda reservoir rehab- Roof				
	1st layer		2nd layer	
Dia of Bar mm	16		0	fy N/mm ² 450
Spacing mm	75		150	fcuN/mm ² 35
Bredth of Sect mm	1000			
Depth of sect mm	250		space-mm	
Clear cover mm	50		0	
Service M (kNM)	59.33			
			wcr(8007)	0.148 mm
			max 0.2mm	
Ast-mm ²	2682	<u>2682</u>	0.00	
Effective Depth			192	
fst N/mm ²	136.90			
fst All'ble	360.00			
fcB N/mm ²	8.05			
fcB all'ble	15.75			


ref. mod.

Maligakanda reservoir rehab- Roof slab -5.0 m avg. free span					
	1st layer	2nd layer			
Dia of Bar mm	10	12	fy N/mm ²	450	
Spacing mm	150	150	fcuN/mm ²	35	
Bredth of Sect mm	1000	space-mm			
Depth of sect mm	250	space-mm			
Clear cover mm	40	0			
Service M (kNM)	59.33				
			wcr(8007)	0.170	mm
			max 0.2mm		
Ast-mm ²	1278	524	754		
Effect Depth mm		199			
M-kanda					
Maligakanda reservoir rehab- Roof					
	1st layer	2nd layer			
Dia of Bar mm	10	12	fy N/mm ²	450	
Spacing mm	150	150	fcuN/mm ²	35	
Bredth of Sect mm	1000	space-mm			
Depth of sect mm	250	space-mm			
Clear cover mm	40	0			
Service M (kNM)	59.33				
			wcr(8007)	0.170	mm
			max 0.2mm		
Ast-mm ²	1278	524	754.29		
Effective Depth		199			
fst N/mm ²	265.43				
fst All'ble	360.00		gamma St	1.28	
fcB N/mm ²	9.58				
fcB all'ble	15.75				

Used

ELLIE HOUSE RESERVOIR





NOTE:
1. REFER TO STANDARD SPEC. FOR GENERAL NOTION AND TYPICAL DETAILS.


SECTION
(SCALE - 1:100)

BASE PLAN
(SCALE - 1:500)

SUB PROJECT ELLIE HOUSE		TITLE ELLIE HOUSE - GENERAL ARRANGEMENT	
NO.	DATE	REVISIONS	BY
NATIONAL WATER SUPPLY AND DRAINAGE BOARD THE PROJECT FOR THE RECONSTRUCTION OF WATER SUPPLY IN THE GREAT EAST COAST AREA			
JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) STUDY TEAM NHKON SUIDO CONSULTANTS CO. LTD. TOKYO, JAPAN			
DRAWING NO. EH/GR/ST-01		SHEET NO. OF 02	

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	NRW	JOB NO.
	CALCULATIONS BY		SHEET..... OF.....
	SCHEME COMPONENT	ELLIE - HOUSE - RESERVOIR EXT - WALL.	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------



$k_a = 0.376$
 $\phi = 27^\circ$
 5.9 m earth fill - no burm.

part.	weight	L. Arm about A	Moment about A
		horiz	vert
1	$15(0.9 + 0.374) = 19.11$	5.887	-
	$0.9 \times 5.9 \times 20 = 106.2$	5.7	-
2	$0.5 \times 0.374 \times 5.9 \times 20 = 22.06$	5.125	-
3	$0.5 \times 0.45 \times 7.1 \times 24 = 38.34$	4.95	-
4	$0.3 \times 7.1 \times 24 = 51.12$	4.65	-
5	$0.75 \times 6.15 \times 24 = 110.7$	3.075	-
6	$1.0 \times 0.75 \times 24 = 18.0$	4.875	-
	$\Sigma W = 365.53$		$M_y = 1686.54$
7	$15 \times 0.376 \times 6.65 = 37.5$	3.325	124.69
8	$50 \times 6.65 \times 0.5 = 166.25$	2.22	369.09
	$\Sigma F_a = 203.75$		$M_o = 493.77$

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET..... OF.....
	SCHEME COMPONENT	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------


$$F/s \text{ overturning} = \frac{1686.54}{493.77} = 3.42 \text{ o.k.}$$

$$\bar{x} = \frac{1686.54 - 493.77}{365.53} = 3.263$$

$$\bar{e} = 6.15/2 - 3.263 = -0.188$$

$$f = \frac{365.53}{6.15} \pm \frac{365.53 \times 0.188}{\frac{1}{6} \times 1 \times 6.15^2}$$

$$= 59.44 \pm 10.9$$



Applied horizontal force $F_H = 203.75 \text{ kN}$

μ came to soil = 0.58

$$\text{horizontal resistance force} =$$

$$365.53 \times 0.58 + 2.65 \times 20 \times 1 \times \frac{1}{2} \times 1 + 20 \times 1 \times 4.5 = 328.51 \text{ kN}$$

$$F/s \text{ sliding} = \frac{328.51}{203.75} = 1.61 > 1.5 \text{ o.k.}$$

ext. wall with water pressure? 7.1m height!

$$\Sigma W = 365.53 + 71 \times 4.5 = 685 \text{ kN}$$

$$M_{Y-A} = 1686.54 + 71 \times 4.5 \times 2.25 = 2405 \text{ kNm}$$


$$M_{G-A} = 493.77 - (71 \times 7.1/2) (7.1/3 + 0.75)$$

$$= -291.79 \text{ kNm}$$



CEY WATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	NRW	JOB NO.
	CALCULATIONS BY		SHEET.....OF.....
	SCHEME COMPONENT	Ext. WALL	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------



ext. wall
outer face at 7.1m height

$$\overline{MA} = 44.37 \times \frac{5.9^2}{6} + 5.64 \times \frac{2.9^2}{2} = 355.58 \text{ kNm/m SLS}$$

$$V = (44.37 \times \frac{5.9}{2}) + (5.64 \times 2.9) \times 1.4 = 229.83 \text{ kN ULT}$$

provide $\gamma 25 - 125 \text{ c/c}$.

INNER face.

$$\overline{MA} = 71.0 \times \frac{7.1^2}{2} = 896.5 \text{ kNm SLS}$$

$$V = 71 \times \frac{7.1}{2} \times 1.4 = 832.87 \text{ kN ULT}$$

provide $\gamma 25 - 125 \text{ c/c}$ 1st layer + $\gamma 20 - 125 \text{ c/c}$ 2nd layer.

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET.....OF.....
	SCHEME COMPONENT	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

outer face @ 4.1 m height.

$$M_c = 21.8 \times \frac{2.9^2}{6} + 5.64 \times \frac{2.9^2}{2} = 54.27 \text{ kNm SLS}$$

$$V = (21.8 \times \frac{2.9}{2} + 5.64 \times 2.9) \times 1.4 = 111.4 \text{ kN ULT}$$

provide Y16 - 125 c/c

Inner face -

$$M_c = 41 \times \frac{4.1^2}{6} = 114.9 \text{ kNm SLS}$$

$$V = 41 \times \frac{4.1}{2} \times 1.4 = 117.67 \text{ kN ULT}$$

provide Y16 - 125 c/c

Ellie House -Ext wall at 7.1 m height-outer face				• T1 and T2 resp	
	1st layer	2nd layer		deg C	
Dia of Bar mm	25	0 fy N/mm ²	450	15	
Spacing mm	125	125 fcuN/mm ²	35	49.26	
Bredth of Sect mm	1000				
Depth of sect mm	750	space-mm			
Clear cover mm	66	75			
Service M (kNm)	355.58				

wcr(8007) 0.155 mm
max 0.2mm

Ast-mm ²	3929	3929	0
Effect Depth mm			672

% of R/F 0.59

fst N/mm ²	152.23		gamma St	2.15
fst All'ble	360.00		Vu -kN	229.83
fcB N/mm ²	5.18		vu -n/mm ²	0.342
fcB all'ble	15.75		vc -n/mm ²	0.591
			Shear design	OK
			Ast temp -dia	16
		0	Ast temp -mm	2570
			spacing mm c/c	78

Ellie House -Ext wall at 7.1 m height-inner face

	1st layer	2nd layer	
Dia of Bar mm	25	20 fy N/mm ²	450
Spacing mm	125	125 fcuN/mm ²	35
Bredth of Sect mm	1000		
Depth of sect mm	750	space-mm	
Clear cover mm	66	75	
Service M (kNm)	596.5		

wcr(8007) 0.187 mm
max 0.2mm

Ast-mm ²	6443	3929	2514.29
Effective Depth			633

fst N/mm ²	170.24		gamma St	1.62
fst All'ble	360.00		Vu -kN	352.87
fcB N/mm ²	8.16		vu -n/mm ²	0.557
fcB all'ble	15.75		vc -n/mm ²	0.711
			Shear design	ok

Ellie House -Ext wall at 4.1 m height-outer face				. T1 and T2 resp	
	1st layer	2nd layer		deg C	
Dia of Bar mm		16	0 fy N/mm ²	450	15
Spacing mm		125	125 fcuN/mm ²	35	42.26
Bredth of Sect mm		1000			
Depth of sect mm		560	space-mm		
Clear cover mm		66	75		
Service M (kNm)		54.27			

wcr(8007)
max 0.2mm

-0.018 mm

Ast-mm ²	1609	1609	0
Effect Depth mm			486

fst N/mm ²	76.32		% of R/F	0.33
fst All'ble	360.00		gamma St	3.51
fcB N/mm ²	1.86		Vu -kN	111.40
fcB all'ble	15.75		vu -n/mm ²	0.229

vc -n/mm ²	0.489
Shear design	OK
Ast temp -dia	16
Ast temp -mm	2290
spacing mm c/c	88

Ellie House -Ext wall at 4.1 m height-inner face


	1st layer	2nd layer		
Dia of Bar mm		16	0 fy N/mm ²	450
Spacing mm		125	150 fcuN/mm ²	35
Bredth of Sect mm		1000		
Depth of sect mm		560	space-mm	
Clear cover mm		66	75	
Service M (kNm)		114.9		
Ast-mm ²	1609	1609	0.00	
Effective Depth			486	

wcr(8007)
max 0.2mm

0.106 mm

fst N/mm ²	161.59		gamma St	2.45
fst All'ble	360.00		Vu -kN	117.67
fcB N/mm ²	3.93		vu -n/mm ²	0.242
fcB all'ble	15.75		vc -n/mm ²	0.489
			Shear design	ok

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	NRW	JOB NO.
	CALCULATIONS BY		SHEET.....OF.....
	SCHEME COMPONENT	ELLIE - HOUSE CENTRE WALL	DATE
ITEM	CALCULATIONS		OUT PUT



PV

①	$3.5 \times 7.1 \times 10$	=	248.5	lh.	6.0	MY.	1491
②	$0.225/2 \times 7.1 \times 10$	=	7.99		4.175		33.36
③	$0.525 \times 7.1 \times 24$	=	89.46		3.875		346.66
④	$7.75 \times 0.75 \times 24$	=	139.5		3.875		540.56
⑤	$0.75 \times 1.0 \times 24$	=	$\frac{18.0}{503.45}$		3.875		$\frac{69.75}{2481.33}$

lv

Mo.

⑥	$7.1 \times \frac{7.1}{2}$	=	252.05	Ph.	3.117		785.64
---	----------------------------	---	--------	-----	-------	--	--------

$$F/s \text{ overturning} = \frac{2481.33}{785.64} = 3.16 \text{ o.k.}$$

$$\rightarrow \text{Applied} = 252.05 \text{ kN}$$

$$\leftarrow \text{Resistance} = 503.45 \times 0.58 + \frac{2.663 \times 20}{2} + 20 \times 3.5 = 388.63 \text{ kN.}$$

$$F/s \text{ sliding} = \frac{388.63}{252.05} = 1.54 > 1.5 \text{ o.k.}$$

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET.....OF.....
	SCHEME COMPONENT	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------


$$\bar{x} = \frac{2481.33 - 785.64}{503.45} = 3.37$$

$$\bar{e} = 7.75/2 - 3.37 = 0.505$$

$$f = \frac{503.45}{7.75 \times 1} \pm \frac{503.45 \times 0.505}{\frac{1}{6} \times 7.75^2}$$


$$= 64.96 \pm 25.39$$

$$= 90.35 \text{ OR } 39.57 \text{ kN/m}^2$$



CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET.....OF.....
	SCHEME EILIE HOUSE RESERVOIR COMPONENT CENTER WALL.	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------



@ 7.1 m height.

$$\rightarrow \overline{MA} = 71.0 \times \frac{7.1^2}{2} = 596.5 \text{ kNm/m.} \quad \text{SLS}$$

$$\rightarrow V = 71.0 \times \frac{7.1}{2} \times 1.4 = 352.87 \text{ kN} \quad \text{ULT}$$

→ Provide $\gamma_{25} - 125 \text{ c/c}$

$$d = 663$$

$$1.5d =$$

$$\gamma_u = \frac{61.66 \times 5.106}{2} \times 1.4 = 260.96$$

@ 4.1 m height

$$\rightarrow \overline{MA} = 41.0 \times \frac{4.1^2}{2} = 114.9 \text{ kNm}$$

$$V = 41 \times \frac{4.1}{2} \times 1.4 = 117.67 \text{ kN}$$

Provide $\gamma_{16} - 125 \text{ c/c}$

Ellie House -Center wall-@ 7.1m height

	1st layer	2nd layer	• T1 and T2 resp deg C	
Dia of Bar mm	25	20 fy N/mm ²	450	15
Spacing mm	125	125 fcuN/mm ²	35	49.26
Bredth of Sect mm	1000			
Depth of sect mm	750	space-mm		
Clear cover mm	66	75		
Service M (kNm)	596.50			
		wcr(8007) max 0.2mm	0.187 mm	
Ast-mm ²	6443	3929	2514	
Effect Depth mm			633	

			% of R/F	1.02
fst N/mm ²	170.24			
fst All'ble	360.00		gamma St	1.62
fcB N/mm ²	8.16		Vu -kN	352.87
fcB all'ble	15.75		vu -n/mm ²	0.557
			vc -n/mm ²	0.711
			Shear design	OK
			Ast temp -dia	16
		0	Ast temp -mm	2570
			spacing mm c/c	78

Ellie House -Center wall-@ 4.1m height

	1st layer	2nd layer		
Dia of Bar mm	16	0 fy N/mm ²	450	
Spacing mm	125	150 fcuN/mm ²	35	
Bredth of Sect mm	1000			
Depth of sect mm	560	space-mm		
Clear cover mm	66	75		
Service M (kNm)	114.9			
		wcr(8007) max 0.2mm	0.106 mm	
Ast-mm ²	1609	1609	0.00	
Effective Depth			486	

fst N/mm ²	161.59		gamma St	2.45
fst All'ble	360.00		Vu -kN	117.67
fcB N/mm ²	3.93		vu -n/mm ²	0.242
fcB all'ble	15.75		vc -n/mm ²	0.489
			Shear design	ok

DAYANANDA ASSOCIATES CONSULTING ENGINEERS	PROJECT	NRW	JOB REF
	CALCULATIONS BY		CHECKED BY
	PART OF STRUCTURE	Ellie house Reservoir	DATE

MEMBER REF	CALCULATIONS	OUT PUT
------------	--------------	---------

Base slab

$$\text{Applied uoL} = 10 \times 6.1 + 0.5 \times 24 = 73.0 \text{ kN/m}^2$$

$$h = 400 \text{ mm}$$

$$\text{Column load} = 844 + \frac{\pi}{4} \times (0.5)^2 \times 6.55 \times 24 \text{ kN} = 875 \text{ kN}$$

From computer output,

$$M_x\text{-SLS} = 115 \times 1.25 = 143.75 \text{ kNm with enhancement of 25\%}$$

$$M_x\text{-ULT} = 143.75 \times 1.4 = 201.25 \text{ kNm}$$

R/F to control thermal & shrinkage cracking,

$$A_{st} = \frac{\alpha (T_1 + T_2) b h \phi}{3 \times \omega_{max} \times 2} = \frac{12 \times 10^{-6} \times (34.5 + 15) \times 10^3 \times 200 \phi}{3 \times 0.2 \times 2} = 99 \phi$$

ϕ	A_{st}
16	1584
20	1980
25	2475

provide 100 @ 125 c/c (2513)

$M_x\text{-SLS}$ o.k.

$$M_x\text{-ULT} = 201 \text{ kNm}$$

$$\frac{M}{f_c b d^2} = \frac{201 \times 10^6}{35 \times 10^3 \times 330^2} = 0.053$$

$$A_{st} = \frac{201 \times 10^6}{0.87 \times 450 \times 0.928 \times 330} = 1676 \text{ mm}^2/\text{m}$$

$$d_{avg} = 400 - 50 - 20 = 330$$

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET.....OF.....
	SCHEME COMPONENT	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

Typical column 500 ϕ .


$$\text{Average pressure} = \frac{875}{6.35 \times 6.2} = 22.23 \text{ kN/m}^2$$

$$V_u = \frac{875 - \left(22 \times \pi \times \frac{1.76^2}{4}\right) \times 1.4 \times 1.15 \times 10^3}{\pi \times 1760 \times 330} = 0.72 \text{ N/mm}^2$$

$$\frac{100AS}{bd} = \frac{100 \times 5020}{10^3 \times 330} = 1.52$$

$$V_c = 0.77 \text{ N/mm}^2$$

provide $\gamma_{20-125 \text{ c/c}} + \gamma_{20-125 \text{ c/c}}$ over support.



Ellie House -base slab					T1 and T2 resp
	1st layer	2nd layer			deg C
Dia of Bar mm	20		fy N/mm ²	450	15
Spacing mm	125	125	fcuN/mm ²	35	34.5
Bredth of Sect mm	1000				
Depth of sect mm	400	space-mm			
Clear cover mm	50	-10			
Service M (kNm)	144.00				
			wcr(8007)	0.193 mm	
			max 0.2mm		
Ast-mm ²	2514	2514	0		
Effect Depth mm			340		
				% of R/F	0.74
fst N/mm ²	192.63				
fst All'ble	360.00			gamma St	1.65
fcu N/mm ²	7.56			Vu -kN	192.00
fcu all'ble	15.75			vu -n/mm ²	0.565
				vc -n/mm ²	0.666
				Shear design	OK
				Ast temp -dia	20
			0	Ast temp -mm	1980
				spacing mm c/c	159

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET.....OF.....
	SCHEME COMPONENT	DATE


ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

Roof slab & beams.
6.35 x 6.2 m grid. 200mm slab

loading

		SLS		ULT
slab	0.2 x 24 =	4.8	} x 1.4	21.42
benching	0.25 x 22 =	5.5		
pebbles	0.23 x 20 =	5.0		
super	2.5	= $\frac{2.5}{17.8}$	x 1.6	$\frac{4.0}{25.42}$ kN/m ²

$$\frac{l_y}{l_x} = 1.024$$



M_x'	=	$17.8 \times 6.2^2 \times 0.049$	=	33.52 kNm	SLS
M_x	=	"	x 0.037	= 25.32	"
M_x'	=	$25.42 \times 6.2^2 \times 0.049$	=	47.88	ULT
M_x	=	"	x 0.037	= 36.15	"
M_y'	=	$17.8 \times 6.2^2 \times 0.045$	=	30.79	SLS
M_y	=	"	x 0.034	= 23.26	"
M_y'	=		=	43.97	ULT
M_y	=		=	33.22	"

R/F to control thermal & shrinkage cracking

$$A_{st-min} = \frac{12 \times 10^{-6} \times (28.75 + 13) \times 200 \times 10^2 \times 6}{3 \times 0.002} = 875 \text{ mm}^2 \text{ - on both faces}$$

∅	A_{st}	→	4/10 - 1500/c	- (533 x 2)
10	875	→	4/12 - 2000/c	- (565 x 2)
12	1050	→	4/12 - 2000/c	- (565 x 2)

Ellie House -roof slab -top over support -short span

	1st layer	2nd layer	T1 and T2 resp deg C	
Dia of Bar mm	12	10	fy N/mm ²	450
Spacing mm	125	125	fcuN/mm ²	35
Bredth of Sect mm	1000			15
Depth of sect mm	200	space-mm		28.75
Clear cover mm	50	-10		
Service M (kNm)	34.00		wcr(8007)	0.181 mm
			max 0.2mm	
Ast-mm ²	1534	905		
Effect Depth mm				



fst N/mm ²	180.36		% of R/F	1.07
fst All'ble	360.00			
fcu N/mm ²	8.92			
fcu all'ble	15.75			



Ellie House -roof slab -bottom r/f -short span

	1st layer	2nd layer		
Dia of Bar mm	12	10	fy N/mm ²	450
Spacing mm	100	150	fcuN/mm ²	35
Bredth of Sect mm	1000			
Depth of sect mm	200	space-mm		
Clear cover mm	50	75		
Service M (kNm)	25.32		wcr(8007)	0.182 mm
			max 0.2mm	
Ast-mm ²	1131	1131		
Effective Depth				

fst N/mm ²	178.32		gamma St	1.72
fst All'ble	360.00		Vu -kN	50.00
fcu N/mm ²	7.27		vu -n/mm ²	0.347
fcu all'ble	15.75		vc -n/mm ²	0.652
			Shear design	ok

RBI. (R-RIS)






		Location	Ellie house reservoir-Roof beam-Rb1-1st span		
Dist bet two layers	25				
Bar Dia layers 1 & 2	20		25	fy N/mm ²	450
Number of bars	4		2	fcuN/mm ²	35
Breadth of sect mm	450				
Depth of sect mm	750		Space bet bars		90.00
Clear cover mm	50				
Service M (kNm)	251.00		Ult M (kNm)		378
Es (kN/mm ²)	200		Depth to Asc		75
Ec (kN/mm ²)	28			Ast- Mult	Asc-Mult
			Ast2	982	
Total Ast mm ²	2239		Ast1	1257	1541
Effective Depth mm	669.17				0
fst N/mm ²	190.84		Defln		1.411
fst Allowable	360.00		Coeiff:		
fcB N/mm ²	7.74				
fcB allowable	15.75				
			Wcr 8007		0.19
			mm 0.2		
		Location	Ellie house reservoir-Roof beam-Rb1-1st support		
Dist bet two layers	25				
Bar Dia layers 1 & 2	25		20	fy N/mm ²	450
Number of bars	4		2	fcuN/mm ²	35
Breadth of sect mm	450				
Depth of sect mm	750		Space bet bars		83.33
Clear cover mm	50				
Service M (kNm)	297.00		Ult M (kNm)		424
Es (kN/mm ²)	200		Depth to Asc		75
Ec (kN/mm ²)	28			Ast- Mult	Asc-Mult
			Ast2	629	
Total Ast mm ²	2593		Ast1	1964	1723
Effective Depth mm	675.98				0
fst N/mm ²	194.51		Defln		1.318
fst Allowable	360.00		Coeiff:		
fcB N/mm ²	8.58				
fcB allowable	15.75				
			Wcr 8007		0.20
			mm 0.2		

		Location	Ellie house reservoir-Roof beam-Rb1-2nd span		
Dist bet two layers		25			
Bar Dia layers 1 & 2		20	0	f_y N/mm ²	450
Number of bars		4	2	f_{cu} N/mm ²	35
Breadth of sect mm		450			
Depth of sect mm		750	Space bet bars		90.00
Clear cover mm		50			
Service M (kNm)		116.00	Ult M (kNm)		213
E_s (kN/mm ²)		200	Depth to Asc		75
E_c (kN/mm ²)		28		Ast- Mult	Asc-Mult
			Ast2	0	
Total Ast mm ²		1257	Ast1	1257	815
Effective Depth mm		690.00			0
f_{st} N/mm ²		147.88	Defln		2.152
f_{st} Allowable		360.00	Coeff:		
f_{cb} N/mm ²		4.17			
f_{cb} allowable		15.75			
			Wcr 8007		0.09
			mm 0.2		
		Location	Ellie house reservoir-Roof beam-Rb1-2nd support		
Dist bet two layers		25			
Bar Dia layers 1 & 2		25	20	f_y N/mm ²	450
Number of bars		4	2	f_{cu} N/mm ²	35
Breadth of sect mm		450			
Depth of sect mm		750	Space bet bars		83.33
Clear cover mm		50			
Service M (kNm)		297.00	Ult M (kNm)		424
E_s (kN/mm ²)		200	Depth to Asc		75
E_c (kN/mm ²)		28		Ast- Mult	Asc-Mult
			Ast2	629	
Total Ast mm ²		2593	Ast1	1964	1723
Effective Depth mm		675.98			0
f_{st} N/mm ²		194.51	Defln		1.318
f_{st} Allowable		360.00	Coeff:		
f_{cb} N/mm ²		8.58			
f_{cb} allowable		15.75			
			Wcr 8007		0.20
			mm 0.2		



11/1/2008

BEAM DESIGN (BS:8110)		Ellie house reservoir roof beam				
=====						
Project	NRW					
Beam	Roof beam -RB1					
fcu (N/mm ²) =	35	35	35	35	35	
fy (N/mm ²) =	450	450	450	450	450	
bw (mm) =	450					
h (mm) =	750					
d (mm) =	676					
d' (mm) =	75					
bf (mm) =	450					
hf (mm) =	200					
m (kNm) =	378	424	213			0
redist % =	0	0	0	0		0
DESIGN FOR BENDI						
k' =	0.156	0.156	0.156	0.156	0.156	
k (M/bd ² fcu) =	0.053	0.059	0.030	0.000	0.000	
z (mm) =	634	628	642	642	642	
x (mm) =	93	106	75	75	75	
fsc (N/mm ²) =	138	204	1	1	1	
=====						
As (mm ²) =	1523	1723	847	0	0	
As' (mm ²) =	0	0	0	0	0	
=====						
DESIGN FOR SHEAR						
V (kN) =	213	338	270			
As (mm ²) =	1256	2591	2591			
bv (mm) =	450	450	450	450	450	
d (mm) =	676	676	676	676	676	
v (N/mm ²) =	0.70	1.11	0.89	0.00	0.00	
100As/bd =	0.41	0.85	0.85	0.00	0.00	
vc (N/mm ²) =	0.53	0.67	0.67	0.00	0.00	
b(v-vc) =	78	198	98	0	0	
b*0.4 =	180	180	180	180	180	
=====						
Links R6 2legs	68	62	68	68	68	
Links Y10 2legs	311	282	311	311	311	
Links, Max spaci	507	507	507	507	507	
=====						

RBT. (R-B25)



430 x 130 RA (R-B-U)





BEAM DESIGN (BS:8110)		Ellie house reservoir roof beam				
=====						
Project	NRW					
Beam	Roof beam -RB2 (RBT)					
f_{cu} (N/mm ²) =	35	35	35	35	35	
f_y (N/mm ²) =	450	450	450	450	450	
b_w (mm) =	450					
h (mm) =	750					
d (mm) =	669					
d' (mm) =	75					
b_f (mm) =	450					
h_f (mm) =	200					
m (kNm) =	396	461	260	319	0	
redist % =	0	0	0	0	0	
DESIGN FOR BENDI						
k' =	0.156	0.156	0.156	0.156	0.156	
k (M/bd ² f _{cu}) =	0.056	0.065	0.037	0.045	0.000	
z (mm) =	624	616	636	633	636	
x (mm) =	99	117	74	79	74	
f_{sc} (N/mm ²) =	172	252	-6	35	-6	
=====						
A_s (mm ²) =	1620	1911	1045	1286	0	
A_s' (mm ²) =	0	0	0	0	0	
=====						
DESIGN FOR SHEAR						
V (kN) =	219	358	305	150	265	
A_s (mm ²) =	1963	3221	3221	1256	1256	
b_v (mm) =	450	450	450	450	450	
d (mm) =	669	669	669	669	669	
v (N/mm ²) =	0.73	1.19	1.01	0.50	0.88	
$100A_s/bd$ =	0.65	1.07	1.07	0.42	0.42	
v_c (N/mm ²) =	0.61	0.72	0.72	0.53	0.53	
$b(v-v_c)$ =	51	210	131	-14	158	
$b*0.4$ =	180	180	180	180	180	
=====						
Links R6 2legs	68	59	68	68	68	
Links Y10 2legs	311	267	311	311	311	
Links, Max spaci	502	502	502	502	502	
=====						


		Location	Ellie house reservoir-Roof beam-Rb2-1st span		
Dist bet two layers	25				
Bar Dia layers 1 & 2	25	20	fy N/mm ²	450	
Number of bars	4	2	fcuN/mm ²	35	
Breadth of sect mm	450				
Depth of sect mm	750	Space bet bars		83.33	
Clear cover mm	50				
Service M (kNm)	262.00	Ult M (kNm)		396	
Es (kN/mm ²)	200	Depth to Asc		75	
Ec (kN/mm ²)	28			Ast- Mult	Asc-Mult
		Ast2	629		
Total Ast mm ²	2593	Ast1	1964	1601	0
Effective Depth mm	675.98				
fst N/mm ²	171.59	Defln		1.455	
fst Allowable	360.00	Coeff.			
fcB N/mm ²	7.57				
fcB allowable	15.75				
			Wcr 8007	0.17	
			mm 0.2		
		Location	Ellie house reservoir-Roof beam-Rb2-1st support		
Dist bet two layers	25				
Bar Dia layers 1 & 2	25	20	fy N/mm ²	450	
Number of bars	4	4	fcuN/mm ²	35	
Breadth of sect mm	450				
Depth of sect mm	750	Space bet bars		83.33	
Clear cover mm	50				
Service M (kNm)	336.00	Ult M (kNm)		461	
Es (kN/mm ²)	200	Depth to Asc		75	
Ec (kN/mm ²)	28			Ast- Mult	Asc-Mult
		Ast2	1257		
Total Ast mm ²	3221	Ast1	1964	1911	0
Effective Depth mm	668.96				
fst N/mm ²	181.35	Defln		1.274	
fst Allowable	360.00	Coeff.			
fcB N/mm ²	9.22				
fcB allowable	15.75				
			Wcr 8007	0.19	
			mm 0.2		

	Location	Ellie house reservoir-Roof beam-Rb2-2nd span			
Dist bet two layers	25				
Bar Dia layers 1 & 2	25	0	fy N/mm ²	450	
Number of bars	4	2	fcuN/mm ²	35	
Breadth of sect mm	450				
Depth of sect mm	750	Space bet bars		83.33	
Clear cover mm	50				
Service M (kNm)	152.00	Ult M (kNm)		260	
Es (kN/mm ²)	200	Depth to Asc		75	
Ec (kN/mm ²)	28		Ast- Mult	Asc-Mult	
		Ast2	0		
Total Ast mm ²	1964	Ast1	1964	1007	0
Effective Depth mm	687.50				
fst N/mm ²	127.17	Defln		2.028	
fst Allowable	360.00	Coeff:			
fcf N/mm ²	4.68				
fcf allowable	15.75				
		Wcr 8007		0.10	
		mm 0.2			
	Location	Ellie house reservoir-Roof beam-Rb2-2nd support			
Dist bet two layers	25				
Bar Dia layers 1 & 2	20	20	fy N/mm ²	450	
Number of bars	4	2	fcuN/mm ²	35	
Breadth of sect mm	450				
Depth of sect mm	750	Space bet bars		90.00	
Clear cover mm	50				
Service M (kNm)	224.00	Ult M (kNm)		319	
Es (kN/mm ²)	200	Depth to Asc		75	
Ec (kN/mm ²)	28		Ast- Mult	Asc-Mult	
		Ast2	629		
Total Ast mm ²	1886	Ast1	1257	1273	0
Effective Depth mm	675.00				
fst N/mm ²	198.60	Defln		1.464	
fst Allowable	360.00	Coeff:			
fcf N/mm ²	7.22				
fcf allowable	15.75				
		Wcr 8007		0.19	
		mm 0.2			

R86 (R - 834)

EH-26





		Location	Ellie house reservoir-Roof beam-Rb3-1st span		
Dist bet two layers	25				
Bar Dia layers 1 & 2	20	20	fy N/mm ²	450	
Number of bars	4	4	fcuN/mm ²	35	
Breadth of sect mm	450				
Depth of sect mm	750	Space bet bars		90.00	
Clear cover mm	50				
Service M (kNm)	269.00	Ult M (kNm)		405	
Es (kN/mm ²)	200	Depth to Asc		75	
Ec (kN/mm ²)	28		Ast- Mult	Asc-Mult	
		Ast2	1257		
Total Ast mm ²	2514	Ast1	1257	1664	0
Effective Depth mm	667.50				
fst N/mm ²	183.80	Defln		1.389	
fst Allowable	360.00	Coeff:			
fcu N/mm ²	8.02				
fcu allowable	15.75				
		Wcr 8007		0.19	
		mm 0.2			
		Location	Ellie house reservoir-Roof beam-Rb3-1st support		
Dist bet two layers	25				
Bar Dia layers 1 & 2	25	20	fy N/mm ²	450	
Number of bars	4	4	fcuN/mm ²	35	
Breadth of sect mm	450				
Depth of sect mm	750	Space bet bars		83.33	
Clear cover mm	50				
Service M (kNm)	319.00	Ult M (kNm)		454	
Es (kN/mm ²)	200	Depth to Asc		75	
Ec (kN/mm ²)	28		Ast- Mult	Asc-Mult	
		Ast2	1257		
Total Ast mm ²	3221	Ast1	1964	1879	0
Effective Depth mm	668.96				
fst N/mm ²	172.18	Defln		1.325	
fst Allowable	360.00	Coeff:			
fcu N/mm ²	8.76				
fcu allowable	15.75				
		Wcr 8007		0.18	
		mm 0.2			


		Location	Ellie house reservoir-Roof beam-Rb3-2nd span		
Dist bet two layers	25				
Bar Dia layers 1 & 2	20		fy N/mm ²	450	
Number of bars	4		4 fcuN/mm ²	35	
Breadth of sect mm	450				
Depth of sect mm	750		Space bet bars	90.00	
Clear cover mm	50				
Service M (kNm)	125.00		Ult M (kNm)	228	
Es (kN/mm ²)	200		Depth to Asc	75	
Ec (kN/mm ²)	28			Ast- Mult	Asc-Mult
			Ast2	0	
Total Ast mm ²	1257		Ast1	1257	875
Effective Depth mm	690.00				0
fst N/mm ²	159.36		Defln	2.041	
fst Allowable	360.00		Coeff.		
fcu N/mm ²	4.49				
fcu allowable	15.75				
			Wcr 8007	0.11	
			mm 0.2		
		Location	Ellie house reservoir-Roof beam-Rb3-2nd support		
Dist bet two layers	25				
Bar Dia layers 1 & 2	25		20 fy N/mm ²	450	
Number of bars	4		4 fcuN/mm ²	35	
Breadth of sect mm	450				
Depth of sect mm	750		Space bet bars	83.33	
Clear cover mm	50				
Service M (kNm)	319.00		Ult M (kNm)	454	
Es (kN/mm ²)	200		Depth to Asc	75	
Ec (kN/mm ²)	28			Ast- Mult	Asc-Mult
			Ast2	1257	
Total Ast mm ²	3221		Ast1	1964	1879
Effective Depth mm	668.96				0
fst N/mm ²	172.18		Defln	1.325	
fst Allowable	360.00		Coeff.		
fcu N/mm ²	8.76				
fcu allowable	15.75				
			Wcr 8007	0.18	
			mm 0.2		

BEAM DESIGN (BS:8110)		Ellie house reservoir roof beam				
=====						
Project	NRW					
Beam	Roof beam -RB3 (RB6)					
fcu (N/mm ²) =	35	35	35	35	35	35
fy (N/mm ²) =	450	450	450	450	450	450
bw (mm) =	450					
h (mm) =	750					
d (mm) =	676					
d' (mm) =	75					
bf (mm) =	450					
hf (mm) =	200					
m (kNm) =	405	454	228			0
redist % =	0	0	0	0	0	0
DESIGN FOR BENDI						
k' =	0.156	0.156	0.156	0.156	0.156	0.156
k (M/bd ² fcu) =	0.056	0.063	0.032	0.000	0.000	0.000
z (mm) =	631	625	642	642	642	642
x (mm) =	101	114	75	75	75	75
fsc (N/mm ²) =	178	239	1	1	1	1
=====						
As (mm ²) =	1640	1856	907	0	0	0
As' (mm ²) =	0	0	0	0	0	0
=====						
DESIGN FOR SHEAR						
V (kN) =	223	354	283	100		
As (mm ²) =	1256	3221	3221	1256		
bv (mm) =	450	450	450	450	450	450
d (mm) =	676	676	676	676	676	676
v (N/mm ²) =	0.73	1.16	0.93	0.33	0.00	0.00
100As/bd =	0.41	1.06	1.06	0.41	0.00	0.00
vc (N/mm ²) =	0.53	0.72	0.72	0.53	0.00	0.00
b(v-vc) =	93	199	94	-89	0	0
b*0.4 =	180	180	180	180	180	180
=====						
Links R6 2legs	68	62	68	68	68	68
Links Y10 2legs	311	281	311	311	311	311
Links, Max spac	507	507	507	507	507	507
=====						

CEY WATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET NO. OF
	SCHEME COMPONENT	DATE

ITEM	CALCULATIONS	OUTPUT
------	--------------	--------

Continuous corbel off beam



$$P_u \text{ Max} = \left[15.3 \times \frac{6.35}{2} \times 1.4 + 2.5 \times \frac{6.35}{2} \times 1.5 \right] = 20.71 \text{ kN/m}$$

$$M_x = 20.71 \times 0.2 \text{ kNm}$$

$$d = 530 - 2 \times 50 = 480$$

$$A_{st} = \frac{0.13 \times 10^3 \times (530 - 255)}{110 - 150} = 279.5 \text{ mm}^2/\text{m} \quad \text{--- [110-150 c/c]}$$

- considering effective depth as 255 - 25 = 230

X [

$$A_{st} - \text{min} = 279.5 \text{ mm}^2/\text{m} \quad \text{--- [110-225 (349) OK]}$$

$$V_u = \frac{20.71 \times 10^3}{10^3 \times 480}$$

$$= 0.19 \text{ N/mm}^2$$

$$V_c = 0.38 \text{ N/mm}^2$$

Main beam with

- Mahgalkanda Reaction $P = 206.2 \text{ kN}$ wt.

- E/Wai House reaction

$$P_u = 220.70 < \checkmark$$

Hence repeat beam with for Mahgalkanda

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET OF
	SCHEME COMPONENT	DATE

ITEM	CALCULATIONS	OUTPUT
------	--------------	--------

502 of column

$$N_{SC} = 843 \times \frac{P}{F} \times 0.5^2 \times 24 \times 6.75 \text{ KN}$$

$$= 875.0 \text{ KN}$$

$$M_{SC} = 21.03$$

$$\frac{1}{r} = \frac{1.3 \times 6.75 \times 10^3}{500}$$

$$= 17.55$$

$$M_{add} = 875 \times 0.15 \times 0.5$$



$$= 65.61 \text{ KNM}$$

$$\frac{M_x}{h'} = \frac{M_y}{b'}$$

$$\frac{N}{A_c f_{cu}} = \frac{875 \times 10^3}{\frac{\pi}{4} \times 500^2 \times 85} = 0.13$$

$$\beta = 0.85$$

$$M_{add} \text{ (windward)} = (21.03 + 65.61) \times 1.85 = 160.28$$



$$R = 250 \text{ mm}$$

$$R_{steel} = 250 - 50 - 15$$

$$= 175 \text{ mm}$$

$M_{SC} = 16.02 \text{ TM}$
$N = 87.5 \text{ T}$


----Ellie house Reservoir circular column----

M = 16.02 (T.M)
 N = 87.5 (T)
 R = 25 (CM)
 RS = 17.5 (CM)
 AS = 72.38 (CM²)

 NP = .55272
 RS/R = .7
 E/R = .7323428
 M! = 37.895 (T.M)
 M!/R3 = 242.528 (KG/CM2)
 C = .5322453
 S = .2382605

Stress in concrete Sig-C = 129.0844 (KG/CM2)
 Stress in steel Sig-S = 866.7726 (KG/CM2)

12492 (4.92%)





$$\frac{86.68}{x} = \frac{12.708}{425 - x} \quad ; \quad x = 131.4 \text{ mm}$$

$$\epsilon = \frac{131.4 + 425}{131.4} \times \frac{86.68}{200000} = 6.21 \times 10^{-3}$$

$\text{Ccr} < 7200 \times 6.21 \times 10^{-3} = 44.71 \text{ MPa}$
 $\text{Ccr} = 49 \text{ MPa}$
 $= 0.05 < 0.2 \text{ OK}$

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	NRW	JOB NO.
	CALCULATIONS BY		SHEET..... OF.....
	SCHEME COMPONENT	INLET CHANNEL - ELLIE HOUSE - RESERVOIR	DATE 01/19

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------



loading

Dead $0.25 \times 24 = 6.0$
 finishes $= 1.0$
 $\frac{7.0}{7.0} \text{ kn/m}^2$

super water $10 \times 1.115 = 11.15$
 surcharge $15 = 15$
 $\} = 26.13 \text{ kn/m}^2$
 Total super

top slab loading
 $u_{d1} = 7.0 \text{ kn/m}^2$
 $u_{s1} = 15.0 \text{ kn/m}^2$

bottom slab loading
 $u_{d2} = 7.0 \text{ kn/m}^2$
 $u_{s2} = 11.15$

load on B1
 $w_d = 14 \times 2.75/2 + 0.25 \times 24 \times 1.115 + \text{self}$
 $83.69 + \text{self, kn/m}$
 $w_s = 26.13 \times 2.75/2 = 35.93 \text{ kn/m}$

PROJECT

JOB REF 07


CALCULATIONS BY

CHECKED BY

CALC SHEET

PART OF STRUCTURE


DATE

MEMBER REF	CALCULATIONS	OUT PUT
	<p>wall load on foundation = SLS</p> <p>$14 \times (5.625/2 + 1.5) = 60.38$</p> <p>$- 26.13 \times (\quad) = 112.69$</p> <p>$0.45 \times 0.75 \times 4.313 \times 2 \times 24 = 69.87$</p> <p>$0.3 \times 3.05 \times 5.2 \times 24 = 114.19$</p> <p>$1.0 \times 3.75 \times 0.25 \times 24 = 22.5$</p> <p>$0.25 \times 1.15 \times 4.313 \times 2 \times 24 = 57.7$</p> <p style="text-align: right;"><u>437.33</u></p>	<p>ULT</p> <p>84.53</p> <p>180.29</p> <p>97.82</p> <p>159.87</p> <p>31.50</p> <p><u>80.79</u></p> <p>634.80</p>
	<p>bearing pressure = $\frac{438}{1.0 \times 3.75} = 117 \text{ kN/m}^2$ SLS.</p> <p style="text-align: right;">169 kN/m² ULT</p>	
	 <p>$M_{x-x} = 170 \times \left(\frac{1.0 - 0.3}{2} \right)^2 \times \frac{1}{2}$</p> <p>$= 10.41 \text{ kNm}$</p> <p>$A_{st} = 152$</p> <p>$V = 100 \times 0.35 = 35 \text{ kN}$</p> <p>$V_u = 0.18 \text{ N/mm}^2$</p> <p>$V_c = 0.53 \text{ N/mm}^2$</p> <p>$A_{st \text{ min (temp)}} = 110 - 150 \text{ c/c (523)}$</p>	<p>$d = 250 - 50$</p> <p>$= 190$</p>

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	JOB NO.
	CALCULATIONS BY	SHEET.....OF.....
	SCHEME COMPONENT	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

TOP SLAB & BOTTOM SLAB.



$$\begin{aligned}
 n &= 7.0 + 15 = 22 \text{ kN/m}^2 \\
 n &= 1.4 \times 7.0 + 1.6 \times 15 = 33.8 \text{ kN/m}^2 \\
 M_x &= 0.086 \times 33.8 \times 2.75^2 = 21.98 \text{ kNm} \\
 M_x &= 0.086 \times 22 \times 2.75^2 = 14.31 \text{ kNm} \\
 \frac{M}{f_c b d^2} &= \frac{22 \times 10}{35 \times 10^3 \times 194} = 0.017 \\
 z &= 0.95 d \\
 A_{st} &= 305 - \text{Y10} - 150 \text{ c/c } (523) \\
 f_s &= \frac{5}{8} \times 450 \times \frac{305}{523} = 164 \\
 \frac{M}{b d^2} &= 0.58 \\
 \gamma_{st} &= 0.55 + \frac{(477 - 164)}{120(0.9 + 0.58)} = 2.31 \\
 d &= \frac{2.75 \times 10^3}{20 \times 2} = 68.75 < d \text{ o.k.}
 \end{aligned}$$



SLS
ULT
ULT
 $d = \frac{250 - 50 - 12}{2} = 194$


Ast min = Y10 - 140 c/c.
(temp)
Provide Y10 - 125 c/c.

Y10 - 125 c/c
both dir
top & bot

Ellie House -Inlet roof slab

	1st layer	2nd layer		T1 and T2 resp deg C
Dia of Bar mm		10	f_y N/mm ²	450
Spacing mm		125	f_{cu} N/mm ²	35
Bredth of Sect mm		1000		28.75
Depth of sect mm		250	space-mm	
Clear cover mm		50		
Service M (kNm)	15.00			
			wcr(8007) max 0.2mm	0.038 mm
A_{st} -mm ²	629	629	0	
Effect Depth mm			195	
				% of R/F 0.32
f_{st} N/mm ²		134.44		
f_{st} All'ble		360.00		gamma St 2.76
f_{cb} N/mm ²		3.22		V_u -kN 47.00
f_{cb} all'ble		15.75		v_u -n/mm ² 0.241
				v_c -n/mm ² 0.580
				Shear design OK
				A_{st} temp -dia 10
			0	A_{st} temp -mm 547
				spacing mm c/c 144





12/27/00

BEAM DESIGN (BS:8110)		Ellie house reservoir inlet floor beam				
=====						
Project	NRW					
Beam	Inlet beam - INL-B1					
fcu (N/mm ²) =	35	35	35	35	35	
fy (N/mm ²) =	450	450	450	450	450	
bw (mm) =	450					
h (mm) =	750					
d (mm) =	676					
d' (mm) =	75					
bf (mm) =	450					
hf (mm) =	250					
m (kNm) =	210	634				0
redist % =	0	0	0	0	0	0
DESIGN FOR BENDING						
k' =	0.156	0.156	0.156	0.156	0.156	
k (M/bd ² fcu)=	0.029	0.088	0.000	0.000	0.000	
z (mm)=	642	602	642	642	642	642
x (mm)=	75	165	75	75	75	75
fsc (N/mm ²)=	1	382	1	1	1	1
=====						
As (mm ²)=	835	2692	0	0	0	0
As'(mm ²)=	0	0	0	0	0	0
=====						
DESIGN FOR SHEAR						
V (kN) =	280	524	200			
As (mm ²)=	1257	1257	1257			
bv (mm)=	450	450	450	450	450	450
d (mm)=	676	676	676	676	676	676
v (N/mm ²)=	0.92	1.72	0.66	0.00	0.00	
100As/bd =	0.41	0.41	0.41	0.00	0.00	
vc (N/mm ²)=	0.53	0.53	0.53	0.00	0.00	
b(v-vc) =	177	538	59	0	0	
b*0.4 =	180	180	180	180	180	
=====						
Links R6 2legs @	68	23	68	68	68	68
Links Y10 2legs @	311	104	311	311	311	311
Links, Max spacing	507	507	507	507	507	507
=====						

		Location	Ellie house reservoir-Inlet floor beam-INL-B1-1st span			
Dist bet two layers		25				
Bar Dia layers 1 & 2		25	25	fy N/mm ²	450	
Number of bars		5	2	fcuN/mm ²	35	
Breadth of sect mm		450				
Depth of sect mm		750	Space bet bars		56.25	
Clear cover mm		50				
Service M (kNm)		403.00	Ult M (kNm)		634	
Es (kN/mm ²)		200	Depth to Asc		75	
Ec (kN/mm ²)		28			Ast- Mult	Asc-Mult
			Ast2	982		
Total Ast mm ²		3438	Ast1	2455	2706	0
Effective Depth mm		673.21				
fst N/mm ²		203.27		Defln	1.140	
fst Allowable		360.00		Coeff:		
fcf N/mm ²		10.73				
fcf allowable		15.75				
				Wcr 8007	0.20	
				mm 0.2		
		Location	Ellie house reservoir-Inlet floor beam-INL-B1-1st support			
Dist bet two layers		25				
Bar Dia layers 1 & 2		20	0	fy N/mm ²	450	
Number of bars		4	2	fcuN/mm ²	35	
Breadth of sect mm		450				
Depth of sect mm		750	Space bet bars		90.00	
Clear cover mm		50				
Service M (kNm)		144.00	Ult M (kNm)		210	
Es (kN/mm ²)		200	Depth to Asc		75	
Ec (kN/mm ²)		28			Ast- Mult	Asc-Mult
			Ast2	0		
Total Ast mm ²		1257	Ast1	1257	803	0
Effective Depth mm		690.00				
fst N/mm ²		183.58		Defln	1.831	
fst Allowable		360.00		Coeff:		
fcf N/mm ²		5.18				
fcf allowable		15.75				
				Wcr 8007	0.13	
				mm 0.2		

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	NRW	JOB NO.
	CALCULATIONS BY		SHEET OF
	SCHEME COMPONENT	ELLIE HOUSE VALVE HOUSE	DATE

ITEM	CALCULATIONS	OUTPUT
------	--------------	--------

load at 29.3 level.			
dead		SLS	ULT
slab	$0.2 \times 24 = 4.8$		
part B	$0.17 \times 22 = 3.74$		
	<u>6.23</u>	6.23	8.72
super	10.0	<u>10.0</u>	16
		16.23	24.72 ton/m^2
blk.	$4.95 \times 30 = 14.85$	14.85	20.79 kn/m
load at roof level.			
dead	= 1.34	1.34	1.87
super	= 0.75	<u>0.75</u>	1.2
		2.09	3.07 kn/m^2

Total load at base		SLS	ULT
=	$10.24 \times 4.733 \times 6.75$	= 518.5	789.75
	$2.09 \times 4.733 \times 6.75$	= 66.77	98.08
	$16.23 \times 4.733 \times 1.75$	= 134.43	204.75
	$7.8 \times 24 \times 4.733 \times 2$	= 1063.22	1488.51
	$0.6 \times 3.6 \times 4.733 \times 24$	= 382	534.8
	$10 \times 4.733 \times 6.4$	= 208.23	333.2
	$14.85 \times (4.733 \times 3 + 6.75)$	= 311.09	435.53
	$0.3 \times 0.75 \times 24 \times 10.15$	= 76.57	107.2
		<u>2766.83</u>	<u>3991.82</u>


bearing pressure	=	$\frac{2766.83}{4.733 \times 6.2}$	$\frac{3991.82}{4.733 \times 6.2}$
		94.29	136.0 kn


CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY	SHEET.....OF.....
	SCHEME COMPONENT Ellie house Reservoir Valve house	DATE

ITEM	CALCULATIONS	OUTPUT
------	--------------	--------

wall.


15 kN/m^2
 0.6
 5
 7.8
 7.8 m
 0.6
 0.3 5.6 0.3
 $7.8 = 10 \times 7.8$
 $26 = (20-15) \times 7.8$
 $\frac{15}{3} = 5$
 Tot = 109





Bending moments for Load Case 2


ULT



F5 Zm in F6 Zm out W Zm wndw P Plt all F Plt file Ctrl+M ▲ ▼ Esc

Shear forces for Load Case 2

ULT



F5 Zn in F6 Zn out W Zn wndw P Plt all E Plt file Ctrl+ [Left Arrow] [Right Arrow] [Up Arrow] [Down Arrow] Esc

Ellie House -valve house wall at 7.8 m height <i>depth</i>				T1 and T2 resp	
	1st layer	2nd layer		deg C	
Dia of Bar mm	25	12 fy N/mm ²	450	15	
Spacing mm	125	125 fcuN/mm ²	35	44.28	
Bredth of Sect mm	1000				
Depth of sect mm	600 space-mm				
Clear cover mm	66	75			
Service M (kNm)	317.00		wcr(8007)	0.175 mm	
			max 0.2mm		
Ast-mm ²	4834	3929	905		
Effect Depth mm			504		
			% of R/F	0.96	
fst N/mm ²	151.03		gamma St	1.81	
fst All'ble	360.00		Vu -kN	328.00	
fcu N/mm ²	6.97		vu -n/mm ²	0.651	
fcu all'ble	15.75		vc -n/mm ²	0.697	
			Shear design	OK	
			Ast temp -dia	16	
			Ast temp -mm	2371	
			spacing mm c/c	85	
Ellie House -valve house wall at 4.0 m height <i>depth</i>					
	1st layer	2nd layer			
Dia of Bar mm	25	0 fy N/mm ²	450		
Spacing mm	125	150 fcuN/mm ²	35		
Bredth of Sect mm	1000				
Depth of sect mm	600 space-mm				
Clear cover mm	66	75			
Service M (kNm)	266		wcr(8007)	0.169 mm	
			max 0.2mm		
Ast-mm ²	3929	3929	0.00		
Effective Depth			522		
			gamma St	2.01	
fst N/mm ²	148.63		Vu -kN	0.00	
fst All'ble	360.00		vu -n/mm ²	0.000	
fcu N/mm ²	5.90		vc -n/mm ²	0.643	
fcu all'ble	15.75		Shear design	ok	

DAYANANDA ASSOCIATES

CONSULTING ENGINEERS

PROJECT

JOB REF

CALCULATIONS BY

CHECKED BY

CALC SHEET

PART OF STRUCTURE

DATE

MEMBER REF	CALCULATIONS	OUTPUT
	<p>Valve house wall at 7.5 m depth</p> <p>MULT = 468 kNm</p> <p>$\frac{M}{fcu b d^2} = 0.049$</p> <p>$z = 0.935 d$</p> <p>Ast = 2439 - y25 - 1230/c (3929)</p> <p>V = 404 kN</p> <p>Vu = 0.99</p> <p>$\frac{100 A_s}{b d} = 0.76$</p> <p>Vc = 0.65 > Vu. o.k.</p> <p>at 4.0 m depth</p> <p>MULT = 367 kNm</p> <p>$\frac{M}{fcu b d^2} = 0.039$</p> <p>$z = 0.949$</p> <p>Ast = 1900 - y20 - 1230/c</p>	<p>$\lambda = 600$</p> <p>$d = 600 - 50$</p> <p>$- 25 =$</p> <p>$= 521.5$</p>

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	NRW	JOB NO.
	CALCULATIONS BY		SHEET.....OF.....
	SCHEME COMPONENT	ELLIE VALVE House FLOOR slab r/f	DATE

ITEM	CALCULATIONS	OUTPUT
------	--------------	--------

5.45 slab at 29.3

$\frac{ly}{lx} = \frac{3.55}{3.55} = 1.54$

$d = \frac{200 - 25 - 10}{2} = 170$

$M_x = 0.052 \times 24.72 \times 3.55^2 = 16.2 - 256 - 110 - 225$
 $M_x' = 0.069 \times \dots = 21.5 - 340 - 110 - 200$
 $M_y = 0.023 \times \dots = 7.2 - 114 - 110 - 300$
 $M_y' = 0.037 \times \dots = 11.5 - 182 - 110 - 300$

$M_x = 16.2$
 $\delta_{st} = 2.0$
 $d = 89 < 170$ o.k.

0.56
206

3.6

$\frac{ly}{lx} = 1.4$

$M_x = 0.06 \times 24.72 \times 3.6^2 = 19.22 - 304 - 110 - 200$
 $M_x' = 0.05 \times \dots = 25.63 - 405 - 110 - 150$
 $M_y = 0.043 \times \dots = 13.78 - 218 - 110 - 250$

Ast

5.4

$M_x = 0.086 \times 24.72 \times 1.6^2 = 5.44 - 86 - 110 - 300$
 $M_y = 0.086 \times \dots = \dots$

Ast

DAYANANDA ASSOCIATES

CONSULTING ENGINEERS

PROJECT

JOB REF




CALCULATIONS BY

CHECKED BY

CALC SHEET

PART OF STRUCTURE

DATE

MEMBER REF	CALCULATIONS	OUT PUT
0.45 181	<p>5.4</p>  $\frac{I_y}{I_x} = \frac{5.4}{2.85} = 1.89$ <p style="text-align: right;">Ast</p> <p> $M_x = 0.064 \times 24.72 \times 2.85^2 = 12.85 - 203 - Y10-250 (3)$ $M_{x'} = 0.054 \times \quad \quad \quad = 16.87 - 267 - Y10-225 (3)$ $M_y = 0.028 \times \quad \quad \quad = 5.60 - 89 - Y10-300$ $M_{y'} = 0.037 \times \quad \quad \quad = 7.43 - 118 - Y10-300$ </p> <p> $M_x = 12.85$ $r_{st} = 2.34$ $d = 71 < 170 \text{ O.K.}$ </p>	
0.34 167	<p>5.4</p>  $\frac{I_y}{I_x} =$ <p style="text-align: right;">Ast</p> <p> $M_x = 0.086 \times 24.72 \times 2.15^2 = 9.82 - 155 - Y10-300 (2E)$ $r_{st} = 2.0$ $d = 54 < 170 \text{ O.K.}$ </p>	
S.O	<p>4.05</p>  $\frac{I_y}{I_x} = 1.23$ <p style="text-align: right;">Ast (3)</p> <p> $M_x = 0.046 \times 24.72 \times 4.05^2 = 18.65 - 295 - Y10-250$ $M_{x'} = 0.062 \times \quad \quad \quad = 25.14 - 398 - Y10-150$ $M_y = 0.035 \times \quad \quad \quad = 14.19 - 224 - Y10-250$ $M_{y'} = 0.047 \times \quad \quad \quad = 19.06 - 301 - Y10-250$ </p>	

DAYANANDA ASSOCIATES

CONSULTING ENGINEERS

PROJECT

JOB REF

CALCULATIONS BY

CHECKED BY

CALC SHEET

PART OF STRUCTURE


DATE

MEMBER REF

CALCULATIONS

OUT PUT

slab case



load:

waist $0.2 \times 24 \times 1.28 = 6.14 \text{ kN/m}^2$

steps $0.2/2 \times 24 = 2.4$

finishes $0.065 \times 22 \times 1.28 = 1.83$

$\frac{1.83}{10.37}$

super = 5.0

$n = 1.4 \times 10.37 + 1.6 \times 5 = 22.52 \text{ kN/m}^2$

span $0.95 + 2.45 + 1.0 = 4.4$

$M = 22.52 \times \frac{4.4^2}{8} = 54.49 \text{ kNm}$

$A_{st} = 889 \text{ - } \gamma_{12-100} (1130)$

$\gamma_{st} = 1.34$

$d = 164 < 174 \text{ o.k.}$

nominal $1/f = 260 \text{ - } \gamma_{10} @ 250 \text{ c/c.}$

$d = 200 - 20 = 174$

DAYANANDA ASSOCIATES

CONSULTING ENGINEERS

PROJECT

JOB REF


CALCULATIONS BY

CHECKED BY



CALC SHEET

PART OF STRUCTURE

DATE

MEMBER REF	CALCULATIONS	OUT PUT
	<p>column C1 - 300x300</p> <p>Total column load.</p> $N = (6.23 \times 1.75/2 + 0.3 \times 0.75 \times 24) \times 2.647 \times 1.4$ $+ 0.3 \times 0.3 \times 24 \times 2.25 \times 1.4 +$ $10.0 \times 1.75/2 \times 2.647 \times 1.6$ $= 84 \text{ kN.}$ <p>Provide nominal x/f.</p> <p>Asc = 1% = 900 - 4y15</p> <p>links y10 - 200 c/c</p>	 <p>300</p> <p>300</p> <p>4y15</p> <p>1%</p> <p>y10</p> <p>200</p> <p>200</p>

V = bH



BEAM DESIGN (BS:8110)		Ellie house valve house floor beam				
=====						
Project	NRW					
Beam	Floor-B4					
fcu (N/mm ²) =	25	25	25	25	25	
fy (N/mm ²) =	450	450	450	450	450	
bw (mm) =	300					
h (mm) =	750					
d (mm) =	690					
d' (mm) =	60					
bf (mm) =	300					
hf (mm) =	200					
m (kNm) =	361	613				0
redist % =	0	0	0	0	0	0
DESIGN FOR BENDI						
k' =	0.156	0.156	0.156	0.156	0.156	
k (M/bd ² fcu) =	0.101	0.172	0.000	0.000	0.000	
z (mm) =	601	536	656	656	656	
x (mm) =	198	342	77	77	77	
fsc (N/mm ²) =	392	392	152	152	152	
=====						
As (mm ²) =	1534	2881	0	0	0	
As' (mm ²) =	0	227	0	0	0	
=====						
DESIGN FOR SHEAR						
V (kN) =	257	276	408	293		
As (mm ²) =	1472	1472	2945	1472		
bv (mm) =	300	300	300	300	300	
d (mm) =	690	690	690	690	690	
v (N/mm ²) =	1.24	1.33	1.97	1.42	0.00	
100As/bd =	0.71	0.71	1.42	0.71	0.00	
vc (N/mm ²) =	0.56	0.56	0.71	0.56	0.00	
b(v-vc) =	203	231	378	255	0	
b*0.4 =	120	120	120	120	120	
=====						
Links R6 2legs	61	53	33	48	102	
Links Y10 2legs	276	243	148	219	467	
Links, Max spaci	518	518	518	518	518	
=====						

GOTHATUWA -KOLONNAWA PUMP HOUSE

CEY WATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFI	SHEET 01 OF
	SCHEME COMPONENT KMO - PUMP HOUSE & RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

1. DATA:

A) DEAD LOADS:

PUMP HOUSE STAGING AREA SLAB = 4.8 kN/m²
200 mm THICK.

SCREED & TERRAZZO = 1.8 kN/m²

200mm THICK PEBBLE LAYER ON ROOF = 4.0 kN/m²

ZINC ALUMINUM ROOFING WITH PURLINS, BOLTS etc. = 0.5 kN/m²

100mm BENCHING CONCRETE = 2.4 kN/m²

200mm BLOCK WALL (inc. plaster) = 3.3 kN/m²

CONCRETE DENSITY = 24.0 kN/m³

DENSITY OF WATER = 10.0 kN/m³

B) LIVE LOADS:

ON ROOF (INACCESSIBLE) = 1.0 kN/m²

ON STAGING AREA SLAB = 10.0 kN/m²

ON RESERVOIR ROOF = 2.5 kN/m²

C) WIND FORCES

BASIC WIND SPEED = 34.0 m/s

CHARACTERISTIC WIND PRESSURE

$$W_k = 0.613 \frac{V_s^2}{V_b^2} \text{ N/m}^2$$

$$\text{where } V_s = S_1 S_2 S_3 \cdot V$$

$$S_1 = 1.0, S_3 = 1.0 \quad \text{and } S_2 = 0.83$$

for H = 5.0m &
Topogr. factor = 1.

D) ALLOWABLE SOIL BEARING

PRESSURE = 250 kN/m²

CONCRETE f_w = 35.0 N/mm²

REINFORCEMENT f_y = 460.0 N/mm²

MILD STEEL = 250.0 N/mm²

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT <u>NRW</u>	JOB NO.
	CALCULATIONS BY <u>MOMO. LUTHFY.</u>	SHEET <u>02</u> OF
	SCHEME COMPONENT <u>KMU - PUMP HOUSE & RESERVOIR.</u>	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

2.

CALCULATION OF WIND FORCES.

$$W_k = 0.613 V_3^2$$

$$= 0.613 \times (1.0 \times 0.83 \times 1.0 \times 34)^2$$

$$= 0.488 \text{ KN/m}^2$$

$W_k = 0.488$
KN/m²

BUILDING DIMENSIONS:

$$l = 21.0 \text{ m}, \quad b = 10.0 \text{ m}, \quad h = 5.0 \text{ m}.$$

$$h > \frac{1}{2} b.$$

$$\text{ROOF SLOPE} = 15^\circ.$$

WIND AT RIGHT ANGLE TO BUILDING.

$$\therefore C_{pe} = -0.8 \quad \& \quad -0.4$$

WIND PARALLEL TO BUILDING.

$$C_{pe} = -0.8 \quad \& \quad -0.6.$$

\(\therefore\) TOTAL WIND FORCE F PER FRAME

$$F = W_k \cdot A (C_{pe1} - C_{pe2})$$

$$= 0.488 \times 4.125 \times h (-0.8 - (-0.4))$$

$$= -0.81h \text{ KN.} \quad \text{- MAX}^n \text{ SUCTION}$$

$$h = \text{height.}$$

WIND FORCE ON ROOF FRAME

$$= -0.81 \text{ KN/m.}$$

WIND FORCE
 $IF = -0.81$
KN/m

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY.	SHEET 03 OF
	SCHEME COMPONENT KIU - PUMP HOUSE & RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
B.	<p>DESIGN OF STAGING AREA SLAB.</p> <p>MAX^m. SPAN = 4.25m - ONE WAY SINGLE SPAN.</p> <p>ULS. DESIGN LOAD = 1.4GK + 1.6QK.</p> <p>SECTION 3.5. BS 8110 Part 1: 1985.</p> <p>∴ DES. LOAD = $1.4 \times (2.8 + 1.2) + 1.6 \times 100$</p> <p>$n = 25.24 \text{ KN/m}^2$</p> <p>∴ SINGLE SPAN MOMENT: BM</p> $= \frac{wl^2}{8}$ $= \frac{25.24 \times 4.25^2}{8}$ $= 57.00 \text{ KNm/m}$ <p>REINFORCEMENT</p> <p>BS 8110: Part 1: 1985 clause 3.5.4 - slabs & clause 3.4.4 for beams.</p> <p>SLAB THICKNESS = 200 mm.</p> <p>EFFECTIVE DEPTH = $200 - 40 - \frac{10}{2}$</p> $d = 155 \text{ mm}$ <p>$\frac{M}{bd^2} = \frac{57.0 \times 10^6}{1000 \times 155^2} = 2.37$</p> <p>USING CHARTS OF BS 8110: Part 3: 1985 chart 2. for $f_{cu} = 25.0 \text{ N/mm}^2$</p> $\frac{100A_s}{bd} = 0.64$ <p>∴ $A_s = \frac{0.64 \times 1000 \times 155}{100}$</p> $= 992.0 \text{ mm}^2$ <p>MAIN BARS PROVIDE T12 @ 100 c/c → $A_s = 1130.0 \text{ mm}^2$</p>	<p>$n = 25.24 \text{ KN/m}^2$</p> <p>Ult. Des. BM = 57.00 KNm/m</p> <p>$d = 155 \text{ mm}$</p> <p>1000 Bars T12 @ 100.</p>

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	N R W	JOB NO.	
	CALCULATIONS BY		M O H D . L U T H F Y .	SHEET 04 OF
	SCHEME COMPONENT	K M U - P U M P H O U S E & R E S E R V O I R .	DATE	

ITEM	CALCULATIONS	OUT PUT
3.1	<p>SECONDARY REINFORCEMENT.</p> <p>BS 8110: Part 1: 1985 clause 3.12.5.3.</p> <p>DIST. BARS = $0.13 bh$.</p> <p>$= 0.13 \times 1000 \times 200$</p> <p>$= 260.0 \text{ mm}^2$.</p> <p>PROVIDE T10 @ 300 c/c.</p> <p>$A_s = 261.0 \text{ mm}^2$.</p> <p>AT SUPPORT: BS 8110: Part 1: 1985 clause 3.12.10.3.2</p> <p>$A_s = \frac{1}{2} \times 643.5 = 321.8 \text{ mm}^2$.</p> <p>MINIMUM REQUIRED</p> <p>$= 0.12 bh = 240.0 \text{ mm}^2$.</p> <p>$\therefore$ PROVIDE T10 @ 200 c/c.</p> <p>$A_s = 392.0 \text{ mm}^2$.</p>	<p>DIST. BARS</p> <p><u>T10 @ 300 c/c</u></p> <p>AT SUPPORT</p> <p><u>T10 @ 200 c/c</u></p>
3.2	<p>DEFLECTION:</p> <p>BS 8110: Part 1: 1985, clause 3.5.7 & Table 3.10 & 3.11.</p> <p>BASIC $\frac{l_y}{d} = 20$ S/S. CONDITION.</p> <p>MODIFICATION FACTOR FOR TENSION RFT</p> $i_s = \frac{5 f_y A_{s, req}}{8 A_{s, prov}} \cdot \frac{1}{\beta_b}, \quad \beta_b = 1.0$ $= \frac{5 \times 460 \times 992.0}{8 \times 1130.0} = 252.4 \text{ N/mm}^2$ <p>\therefore MOD. FACTOR = $0.55 + \frac{(477 - 252.4)}{120(0.9 + 2.37)}$</p> <p>$= 1.122$</p> <p>CONSIDERING T12 @ 100 c/c TOP BARS.</p> <p>$A_s = 1130.0 \text{ mm}^2$</p>	

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY.	SHEET 05 OF
	SCHEME KNU - PUMP HOUSE & RESERVOIR COMPONENT RESERVOIR	DATE

ITEM	CALCULATIONS	OUT PUT
	<p>MOD. FACTOR FOR COMPRESSION AREA REINFORCEMENT</p> $= 1 + \frac{100 \times 1130.0}{1000 \times 154} \left/ \left(3 + \frac{100 \times 1130.0}{1000 \times 154} \right) \right.$ $= 1.197.$ <p>ALLOWABLE SPAN</p> $= 20 \times 1.122 \times 1.197 \times 154$ $= 4136.5 \text{ mm} < 4250 \text{ mm.}$ <p>CHANGE BOTTOM BARS TO T16 @ 150 $\rightarrow A_s = 1340.0 \text{ mm}^2$</p> <p>MOD. FACTOR</p> $i_s = \frac{5}{8} d_y \times \frac{A_{s \text{ req}}}{A_{s \text{ provided}}} \times \frac{1}{f_{c2}}$ $= \frac{5}{8} \times 460 \times \frac{982}{1340} \times 1$ $= 212.8 \text{ mm.}$ <p>MOD. FACTOR = 0.155 $\left(\frac{477 - 212.8}{100 (0.8 + 2.37)} \right)$</p> $= 1.245.$ <p>\therefore ALLOWABLE SPAN = $20 \times 1.245 \times 1.197 \times 154$</p> $= 4590.0 > 4250.$ <p>\therefore ok.</p>	<p>\therefore SLAB TOP BARS T12 @ 100 & BOTTOM BARS T16 @ 150.</p> <p>DEFLECTION OK.</p>

DESIGN OF CRACK

BS 8007 : 1987

Pump House Staging Slab

DESIGN SURFACE CRACK WIDTH $\omega = \frac{3acr.E_m}{1+2\left(\frac{acr - C_{min}}{h-x}\right)}$

$$\epsilon_m = \frac{\epsilon_1 - b\alpha(h-x)(a'-x)}{3E_s.A_s(d-x)}$$

SERVICE MOMENT M = 37.5 KNM/M

h (mm) = 200 Cmin = 40 (mm) ϕ = 16.00 mm
 d = h - Cmin - ϕ/2 d = 152.00 mm

CONCRETE f_{cu} = 35 N/mm²
 f_y = 460 N/mm²

REINFORCEMENT PROVIDED BAR DIAMETER ϕ = 16 mm
 BAR SPACING S = 150 mm

Asp = 1340.41 mm²

E_c = 28 KN/mm²
 E_s = 200 KN/mm²

α_e = E_s / 12E_c = 14.29

ρ = 0.00882

α_{e,ρ} = 0.126

THEREFORE $\frac{x}{d} = \frac{-\alpha_e(\rho + \rho') + \sqrt{\alpha_e^2(\rho + \rho')^2 + 2\alpha_e(\rho + d'\rho')}}{d} = 0.392$

CONSIDERING ρ' = 0

THEREFORE x = 59.51 mm

z = d - 1/3 x = 132.16 mm

f_s = $\frac{M}{Asp.z}$ = 211.68 N/mm²

ε_s = $\frac{f_s}{E_s \times 1000}$ = 0.0010584

$$\epsilon_1 = \frac{(h-x) * \epsilon_s}{(d-x)} = 0.001608$$

$$\epsilon_m = 0.0013424$$

1) CRACK UNDER THE BAR DIRECTLY

$$a_{cr} = C_{min} = 40 \text{ mm}$$

$$\omega = 3.a_{cr}.\epsilon_m = 0.161 \text{ mm}$$

$$< 0.2\text{mm} \quad \text{O.K}$$

2) CRACK AT MIDWAY BETWEEN TWO BARS

$$a_{cr} + \phi/2 = \sqrt{(S/2)^2 + (\phi/2 + C_{min})^2} = 89.04$$

$$a_{cr} = 81.04 \text{ mm}$$

$$\omega = 0.206 \text{ mm}$$

$$\sim 0.2\text{mm} \quad \text{O.K}$$

THEREFORE REINFORCEMENT T16 @ 150 C/C O.K

CHECK FOR THERMAL CRACK

Staging area Slab
BS 8007, APPENDIX A.3

$$\text{CRACK SPACING } S_{\text{max}} = \frac{f_{ct} \times \phi}{f_b \times 2\rho}$$

FROM TABLE A.1 $\frac{f_{ct}}{f_b} = 0.67$

FOR R/F PROVIDED BAR DIAMETER $\phi = 16 \text{ mm}$

BAR SPACING $S = 150 \text{ mm}$

$A_{sp} = 1340.95 \text{ mm}^2$

USING SURFACE ZONES AS PER FIG A.2 BS 8007 $h = 100 \text{ mm}$

$\rho = \frac{A_{sp}}{1000 \times h} = 0.0134095$

$S_{\text{max}} = 399.72 \text{ mm}$

MAXIMUM CRACK WIDTH DUE TO CHANGE IN TEMPERATURE

T1 & T2

BS 8007 - APPENDIX A.3 $\omega_{\text{max}} = S_{\text{max}} \cdot \frac{\alpha(T1+T2)}{2}$

$\alpha = 0.00001 \text{ /}^\circ\text{C}$

T1= 25°C FOR WALL OF 200mm THICK

THEREFORE

T1 = 25 °C

T2 = 15 °C

$\omega_{\text{max}} = 0.0799432 \text{ mm} < 0.2\text{mm}$

THERMAL CRACK OK

CHECK FOR THERMAL CRACK

Staging area Slab

BS 8007, APPENDIX A.3

$$CRACK SPACING S_{max} = \frac{f_{ct} \times \phi}{f_b \times 2\rho}$$

FROM TABLE A.1 $\frac{f_{ct}}{f_b} = 0.67$

FOR R/F PROVIDED BAR DIAMETER $\phi = 12 \text{ mm}$

BAR SPACING $S = 100 \text{ mm}$

$A_{sp} = 1131.43 \text{ mm}^2$

USING SURFACE ZONES AS PER FIG A.2 BS 8007 $h = 100 \text{ mm}$

$\rho = \frac{A_{sp}}{1000 \times h} = 0.0113143$

$S_{max} = 355.30 \text{ mm}$

MAXIMUM CRACK WIDTH DUE TO CHANGE IN TEMPERATURE

T1 & T2

BS 8007 - APPENDIX A.3

$$\omega_{max} = S_{max} \cdot \frac{\alpha(T1+T2)}{2}$$

$\alpha = 0.00001 / ^\circ\text{C}$

T1= 25°C FOR WALL OF 200mm THICK

THEREFORE

T1 = 25 °C

T2 = 15 °C

$\omega_{max} = 0.0710606 \text{ mm} < 0.2\text{mm}$

THERMAL CRACK OK

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHERY	SHEET 10 OF
	SCHEME COMPONENT KMTU - PUMP HOUSE & RESERVOIR	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

4.

DESIGN OF RESERVOIR ROOF SLAB

SPAN = 4.5m. S/S. ONEWAY.

BS 8110: Part 1: 1985 clause 3.5

ULT. DESIGN LOAD $n = 1.4G_R + 1.6Q_R$

$$= 1.4(4.8 + 4.0 + 2.4) + 1.6 \times 2.5$$

$$= 19.68 \text{ kN/m}^2$$

Ult. Des. Load
 $n = 19.68 \text{ kN/m}^2$

BENDING MOMENT.

Max^m SINGLE SPAN $BM = \frac{wl^2}{8}$

$$= \frac{19.68 \times 4.5^2}{8}$$

$$= 49.82 \text{ kNm. /m}$$

Ult. Des. BM = 49.82

REINFORCEMENT

BS 8110: Part 1: 1985 clause 3.5.4 for SLABS & clause 3.4.4 for BEAMS.

SLAB THICKNESS = 200 mm.

$$d = 200 - 40 - \frac{10}{2} = 155 \text{ mm.}$$

$$\frac{M}{bd^2} = \frac{49.82 \times 10^6}{1000 \times 155^2} = 2.07$$


BS 8110: Part 3: 1985, chart 2 for $f_{cu} = 25.0 \text{ N/mm}^2$

$$\frac{100A_s}{bd} = 0.56$$

$$\therefore A_s = \frac{0.56 \times 1000 \times 155}{100} = 868.0 \text{ mm}^2$$

MAIN BARS PROVIDE T12 @ 125 c/c.

$$\Rightarrow A_s = 904.0 \text{ mm}^2$$



Main Bars
T12 @ 125 c/c

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT	NRW	JOB NO.
	CALCULATIONS BY		MOHD LUTHFY.
	SCHEME COMPONENT		KMU - PUMP HOUSE & RESERVOIR.
			SHEET // OF
			DATE

ITEM	CALCULATIONS	OUT PUT
4.1	<p>SECONDARY REINFORCEMENT.</p> <p>SIMILAR TO ITEM 3.1</p> <p>T10 @ 300 c/c OK</p>	<p>DIST. BARS</p> <p>T10 @ 300 c/c.</p>
4.2	<p>DEFLECTION:</p> <p>SIMILAR TO ITEM 3.2</p> <p>PROVIDE T16 @ 150 c/c BOTTOM BARS</p> <p>& T12 @ 100 c/c TOP BARS.</p> <p>DEFLECTION OK.</p>	

DESIGN OF CRACK.

BS 8007 : 1987

Reservoir Roof Slab

$$\text{DESIGN SURFACE CRACK WIDTH } \omega = \frac{3\alpha_{cr} E_m}{1 + 2 \frac{\alpha_{cr} - C_{min}}{h - x}}$$

$$E_m = \frac{\varepsilon_1 - b_t (h - x)(a' - x)}{3E_s A_s (d - x)}$$

$$\text{SERVICE MOMENT } M = 34.7 \text{ KNM/M}$$

$$h \text{ (mm)} = 200 \quad C_{min} = 40 \text{ (mm)} \quad \phi = 16.00 \text{ mm}$$

$$d = h - C_{min} - \phi/2 \quad d = 152.00 \text{ mm}$$

$$\text{CONCRETE } f_{cu} = 35 \text{ N/mm}^2$$

$$f_y = 460 \text{ N/mm}^2$$

$$\text{REINFORCEMENT PROVIDED BAR DIAMETER } \phi = 16 \text{ mm}$$

$$\text{BAR SPACING } S = 150 \text{ mm}$$

$$A_{sp} = 1340.41 \text{ mm}^2$$

$$E_c = 28 \text{ KN/mm}^2$$

$$E_s = 200 \text{ KN/mm}^2$$

$$\alpha_e = E_s / 12E_c = 14.29$$

$$\rho = 0.00882$$

$$\alpha_e \rho = 0.126$$

$$\text{THEREFORE } \frac{x}{d} = \frac{-\alpha_e (\rho + \rho') + \sqrt{\alpha_e^2 (\rho + \rho')^2 + 2\alpha_e (\rho + d' \rho')}}{d} = 0.392$$

CONSIDERING $\rho' = 0$

$$\text{THEREFORE } x = 59.51 \text{ mm}$$

$$z = d - 1/3 x = 132.16 \text{ mm}$$

$$f_s = \frac{M}{A_{sp} z} = 195.88 \text{ N/mm}^2$$

$$\varepsilon_s = \frac{f_s}{E_s \times 1000} = 0.0009794$$

$$\varepsilon_1 = \frac{(h-x) \cdot \varepsilon_s}{(d-x)} = 0.001488$$

$$\varepsilon_m = 0.0012224$$

1) CRACK UNDER THE BAR DIRECTLY

$$a_{cr} = C_{min} = 40 \text{ mm}$$

$$\omega = 3 \cdot a_{cr} \cdot \varepsilon_m = 0.147 \text{ mm}$$
$$< 0.2 \text{ mm}$$

O.K

2) CRACK AT MIDWAY BETWEEN TWO BARS

$$a_{cr} + \phi/2 = \sqrt{(S/2)^2 + (\phi/2 + C_{min})^2} = 89.04$$

$$a_{cr} = 81.04 \text{ mm}$$

$$\omega = 0.188 \text{ mm}$$

$$< 0.2 \text{ mm}$$

O.K


THEREFORE REINFORCEMENT T16 @ 150 C/C O.K

KEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY	SHEET...14...OF.....
	SCHEME COMPONENT KMW - PUMP HOUSE 2 RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

5. DESIGN OF RESERVOIR WALLS & BASE SLAB.

THIS PART OF DESIGN IS MADE IN ACCORDANCE WITH BS 8007:1987 Δ BS 8110: Parts 1, 2 & 3 : 1985




HWL
 = 12.38 MSL
 GL = 11.0 MSL

$K_a = 0.333$
 $K_p = 3.0$
 $\theta = 30^\circ$

5.1. DESIGN OF OUTER WALL.

5.1.1 CASE OF EMPTY RESERVOIR



ACTIVE EARTH PRESSURE

$$\begin{aligned}
 q_2 &= k_2 \gamma h \\
 &= 0.333 \times 20 \times 3.7 \\
 &= 24.64 \text{ KN/m}^2
 \end{aligned}$$

$$\begin{aligned}
 \therefore H_a &= \frac{1}{2} \times 24.64 \times 3.7 \\
 &= 45.6 \text{ KN/m run.}
 \end{aligned}$$

$$\therefore \text{BM at X (SERVICE)} = 45.6 \times \frac{3.7}{3} = 56.2 \text{ KNm}$$

$$\text{SHEAR AT X (SERVICE)} = 45.6 \text{ KN/m run.}$$

$$\therefore \text{ULT. BM} = 1.4 \times 56.2 = 78.7 \text{ KNm. /m.}$$

$$\text{" SF} = 1.4 \times 45.6 = 63.8 \text{ KN /m.}$$

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFI	SHEET 15 OF
	SCHEME COMPONENT KNU - PUMP HOUSE & RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
	<p><u>REINFORCEMENT:</u> BS 8110: Part 1: 1985 & BS 8007: 1987 clause 3.2.1 & 3.2.2</p> <p>WALL THICKNESS = 500 mm.</p> <p>EFFECTIVE DEPTH $d = 500 - 50 - \frac{20}{2}$ $= 440 \text{ mm.}$</p> <p>$\frac{m}{bd^2} = \frac{78.7 \times 10^6}{1000 \times 440^2} = 0.41 < 0.5$</p> <p>PROVIDE NOMINAL REINFORCEMENT.</p> <p>BS 8007 APPENDIX 'A' TABLE A1. MIN. REINFORCEMENT $\frac{D}{\sqrt{cyl}} = 0.0035$</p> <p>$\therefore A_s = 0.0035 \times 1000 \times 500$ $= 1750.0 \text{ mm}^2$</p> <p>PROVIDE $\phi 10 @ 150 \text{ c/c} \rightarrow A_s = 2094.0$ MINIMAL REIN. mm^2</p>	<p>500</p> <p>0</p> <p>0</p> <p>$\leftarrow d \rightarrow + 50$</p> <p>$d = 440 \text{ mm.}$</p> <p>WALL VERTICAL REIN. $\phi 10 @ 150 \text{ c/c}$</p>

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY,	SHEET 16 OF
	SCHEME COMPONENT KMU - PUMP HOUSE & RESERVOIR.	DATE


ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

S.1.2

CASE OF RESERVOIR FULL.

HWL = 12.38 MSL.

POSSIBILITY OF HWL RISING TO 14.25 MSL AS THE RESERVOIR HAS NO OVERFLOW SYSTEM.



FROM 5.1.1

$$q_z = 24.64 \text{ KN/m}^2$$

$$H_a = 45.6 \text{ KN/m run}$$

$$q_w = 6.95 \times 10 = 69.5 \text{ KN/m}^2$$

$$H_w = \frac{1}{2} \times 69.5 \times 6.95 = 241.50 \text{ KN/m}$$

CONSIDERING VERTICAL WALL WITH THE ROOF SLAB AS PROPPED CANTILEVER.

$$\begin{aligned} \text{BM AT THE BOTTOM OF WALL X} \\ (\text{SERVICE}) &= \frac{2 \text{ WL}}{15} = \frac{2 \times 241.5 \times 6.95}{15} \\ &= \underline{223.8} \text{ KNm/m} \end{aligned}$$

$$\begin{aligned} \text{MAX}^{\text{ve}} \text{ BM (SERVICE)} &= 0.0596 \text{ WL} \\ &= 0.0596 \times 241.5 \times 6.95 \\ &= 100.0 \text{ KNm/m} \end{aligned}$$

$$\begin{aligned} \text{LOCATION OF MAX}^{\text{ve}} \text{ BM} &= 0.447L \\ \text{FROM THE TOP OF WALL} \\ &= 0.447 \times 6.95 \\ &= \underline{3.107} \text{ m} \end{aligned}$$

$$\text{SHEAR AT X} = \frac{4 \times 241.5}{5} = 193.2 \text{ KN/m}$$

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY	SHEET. 17 OF
	SCHEME COMPONENT KMU - PUMP HOUSE & RESERVOIR	DATE

ITEM	CALCULATIONS	OUT PUT
	$\text{BM AT } Y \text{ (SERVICE)} = \frac{1}{2} \times 32.5 \times 3.25 \times \frac{3.25}{3}$ $= \underline{57.2} \text{ kNm/m.}$ $\text{SHEAR AT } Y = \frac{1}{2} \times 32.5 \times 3.25$ $= \underline{52.8} \text{ kN/m.}$ <p>∴ <u>ULTIMATE</u> BM^s & SF^s.</p> <p>AT X BM = 1.4 × 223.8 = <u>313.3</u> kNm/m</p> <p> SF = 1.4 × 193.2 = <u>270.5</u> kN/m</p> <p>AT Y BM = 1.4 × 57.2 = <u>80.1</u> kNm/m</p> <p> SF = 1.4 × 52.8 = <u>73.9</u> kN/m.</p> <p><u>REINFORCEMENT.</u></p> <p>BS 8110 : PART 3 : 1985 3 BS 8007 : 1987, CLAUSE 3.2.1.5 3.2.2</p> <p><u>ULTIMATE LIMIT STATE.</u></p> <p>WALL THICKNESS = 500 mm.</p> <p>EFFECTIVE DEPTH = 500 - 50 - $\frac{20}{2}$</p> <p> = <u>440</u> mm</p> $\frac{M}{bd^2} = \frac{313.3 \times 10^6}{1000 \times 440^2} = 1.62$ <p>USING BS 8110, PART 3, CHARTS CHART 2 FOR $f_{cu} = 35.0 \text{ N/mm}^2$</p> $\frac{100 A_s}{bd} = 0.45$ <p>∴ $A_s = 0.45 \times 1000 \times 440 / 100$</p> $= \underline{1980.0} \text{ mm}^2$	

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFI.	SHEET 18 OF
	SCHEME COMPONENT KNU - PUMP HOUSE & RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
	<p>BS 8007, APPENDIX 'A' TABLE A.1 MINIMUM REINFORCEMENT</p> $\rho_{\text{min}} = 0.0035$ $\therefore A_s = 0.0035 \times 1000 \times 500$ $= 1750.0 \text{ mm}^2 < 1980 \text{ mm}^2$ <p>\therefore ADOPT T20 @ 150 c/c</p> $A_s = 2094.0 \text{ mm}^2$ <p>CHECK FOR SHEAR.</p> $v = \frac{270.5 \times 10^3}{1000 \times 440} = 0.615 \text{ N/mm}^2$ $\frac{100 A_s}{bd} = \frac{100 \times 2094}{1000 \times 440} = 0.48\%$ $\therefore v_c = 0.55 \text{ N/mm}^2 < 0.615 \text{ N/mm}^2$ <p>ADOPT T25 @ 150 c/c.</p> $A_s = 3272.0 \text{ mm}^2$ $\therefore \frac{100 A_s}{bd} = \frac{100 \times 3272}{1000 \times 440} = 0.744\%$ $\therefore v_c = 0.636 \text{ N/mm}^2 > 0.615 \text{ N/mm}^2$ <p>\therefore NO SHEAR REINFORCEMENT NECESSARY.</p>	<p>VERTICAL BARS T25@150. c/c</p> <p>SHEAR OK.</p>

DESIGN OF CRACK

BS 8007 : 1987

Reservoir Outer Wall

DESIGN SURFACE CRACK WIDTH $\omega = \frac{3a_{cr}.E_m}{1+2(\frac{a_{cr} - C_{min}}{h-x})}$

$$E_m = \frac{\epsilon_1 - b t (h-x)(a' - x)}{3E_s . A_s (d-x)}$$

	SERVICE MOMENT M	=	223.8 KNM/M
h (mm) = 500	Cmin = 50 (mm)	$\phi =$	25.00 mm
d = h - Cmin - $\phi/2$		d =	437.50 mm
	CONCRETE f _{cu}	=	35 N/mm ²
	f _y	=	460 N/mm ²
REINFORCEMENT PROVIDED	BAR DIAMETER ϕ	=	25 mm
	BAR SPACING S	=	150 mm
	Asp	=	3272.49 mm ²

E _c	=	28 KN/mm ²
E _s	=	200 KN/mm ²

$\alpha_e = E_s / 1/2 E_c = 14.29$

$\rho = 0.00748$

$\alpha_e . \rho = 0.107$

THEREFORE $x = \frac{-\alpha_e (\rho + \rho') + \sqrt{\alpha_e^2 (\rho + \rho')^2 + 2\alpha_e (\rho + d' \rho')}}{d} = 0.368$

CONSIDERING $\rho' = 0$

THEREFORE x = 160.84 mm

z = d - 1/3 x = 383.89 mm

$f_s = \frac{M}{Asp.z} = 178.15 \text{ N/mm}^2$

$\epsilon_s = \frac{f_s}{E_s \times 1000} = 0.0008907$

$$\epsilon_1 = \frac{(h-x)}{(d-x)} * \epsilon_s = 0.001092$$

$$\epsilon_m = 0.0008802$$

1) CRACK UNDER THE BAR DIRECTLY

$$a_{cr} = C_{min} = 50 \text{ mm}$$

$$\omega = 3.a_{cr}.\epsilon_m = 0.132 \text{ mm}$$

$$< 0.2\text{mm} \quad \text{O.K}$$

2) CRACK AT MIDWAY BETWEEN TWO BARS

$$a_{cr} + \phi/2 = \sqrt{(S/2)^2 + (\phi/2 + C_{min})^2} = 97.63$$

$$a_{cr} = 85.13 \text{ mm}$$

$$\omega = 0.186 \text{ mm}$$


$$< 0.2\text{mm} \quad \text{O.K}$$

THEREFORE REINFORCEMENT T25 @ 150 C/C O.K

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY M.O.M.D. LUTHFI Y.	SHEET. 21 OF
	SCHEME COMPONENT KIMU - PUMP HOUSE & RESERVOIR	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

5.2 DESIGN OF INNER WALL.



HWL = 12.38 MSL.

POSSIBILITY OF HWL RISING TO 14.25 MSL AS THE RESERVOIR HAS NO OVERFLOW SYSTEM.

CONSIDER THE PORTION OF THE WALL ABOVE THE POINT B.

WATER PRESSURE AT B.

$$q_2 = (6.95 - 0.7) \times 10 = 62.5 \text{ KN/m}^2$$

$$\therefore H_w = \frac{1}{2} \times 62.5 \times 6.25 = 190.3 \text{ KN}$$

CONSIDERING VERTICAL WALL WITH THE ROOF SLAB AS PROPPED CANTILEVER

$$\begin{aligned} \text{BM AT B SERVICE} &= \frac{2}{15} WL = \frac{2}{15} \times 190.3 \times 6.25 \\ &= 162.8 \text{ KNM/m.} \end{aligned}$$

MAX^y. SERVICE BM ABOVE B

$$\begin{aligned} &= 0.0596 WL \\ &= 0.0596 \times 190.3 \times 6.25 \\ &= 70.9 \text{ KNM/m.} \end{aligned}$$

$$\begin{aligned} \text{LOCATION OF MAX}^y \text{ BM FROM TOP OF WALL} &= 0.447 L = 0.447 \times 6.25 \\ &= 2.794 \text{ m.} \end{aligned}$$

$$\begin{aligned} \text{SHEAR AT B} &= \frac{4}{5} \times 190.3 \\ &= 152.2 \text{ KN/m.} \end{aligned}$$

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW.	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY.	SHEET 22 OF
	SCHEME COMPONENT KMU - PUMP HOUSE & RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
	<p>ULTIMATE BM^s & SF^s.</p> <p>$BM = 1.4 \times 162.8 = 227.92 \text{ KN/m}$</p> <p>$SF = 1.4 \times 152.2 = 213.1 \text{ KN/m}$</p> <p>CONSIDERING THE FIGURES USED IN SECTION 5.1.2.</p> <p>$BM = 227.92 < 313.3$</p> <p>$SF = 213.1 < 270.5$</p> <p>∴ USING 500 mm THICK WALL & T25 @ 150 c/c REINFORCEMENT SATISFY ALL CONDITIONS.</p>	<p>VERTICAL BARS: T25 @ 150 c/c</p>

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY.	SHEET 23 OF
	SCHEME COMPONENT KMU - PUMP HOUSE & RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
6.0	<p>CHECK THERMAL CRACK.</p> <p>BS 8007, APPENDIX A.3.</p> <p>CRACK SPACING $S_{max} = \frac{f_{ct}}{f_b} \times \frac{\phi}{2\rho}$</p> <p>TABLE A.1 $\rightarrow \frac{f_{ct}}{f_b} = 0.67$</p> <p>FOR BASE SLAB USING $\phi = 20$ mm.</p> <p>ρ FOR T20 @ 150 $A_s = 2034.0$ mm².</p> <p>USING SURFACE ZONES, FIGURE 2.10 BS 8007. $\rho = \frac{2034}{1000 \times 250} = 0.008136$.</p> <p>$\therefore S_{max} = 0.67 \times \frac{20}{2 \times 0.008136}$ $= 799.9$ mm ≤ 800 mm.</p> <p>MAXIMUM CRACK WIDTH DUE TO TEMPERATURE CHANGES T_1 & T_2. BS 8007 - APPENDIX A.3.</p> <p>$w_{max} = \epsilon_{max} \cdot \frac{\alpha}{2} (T_1 + T_2)$</p> <p>USING BS 8110, PART 2: 1985, TABLE 7.3 $\alpha = 10 \times 10^{-6} / ^\circ C$.</p> <p>$T_1 = 35^\circ$ & $T_2 = 15^\circ$</p> <p>$w_{max} = 800 \times \frac{10 \times 10^{-6}}{2} (35 + 15)$ $= 0.12$ mm ≤ 0.2 mm - OK.</p> <p>\therefore T20 @ 150 c/c SATISFACTORY.</p> <p>FOR WALLS T25 @ 150 c/c ADOPTED</p> <p>\therefore THERMAL CRACKS SATISFACTORY.</p>	

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW CALCULATIONS BY MOHD. LUTHFY. SCHEME KMU - PUMP HOUSE & COMPONENT RESERVOIR.	JOB NO. SHEET 24 OF DATE
ITEM	CALCULATIONS	OUT PUT
7.0	<p>CHECK FOR FLOTATION</p> <p>CALCULATION OF DEAD WEIGHT OF THE STRUCTURE.</p> <p>ROOF STRUCTURE = $0.5 \times 22.5 \times 11.5 = 129.4 \text{ kN}$</p> <p>RC ROOF FRAMES = $6 \times 12 \times 0.3 \times 0.4 \times 24 = 207.4 \text{ kN}$</p> <p>RC COLUMNS = $\left(\begin{matrix} 6 \times 0.3 \times 0.5 \times 5.2 \\ + 6 \times 0.3 \times 0.5 \times 1.9 \end{matrix} \right) \times 24 = 153.4 \text{ kN}$</p> <p>RC CORBELS = $\left[0.9 \times 0.4 + \frac{1}{2}(0.9 + 0.4) \times 0.4 \right] \times 2 \times 20 \times 24 = 595.2 \text{ kN}$</p> <p>FLOOR SLAB AT 11.25 MSL = $(4.25 \times 10 + 16.25 \times 4) \times 0.2 \times 24 = 516.0 \text{ kN}$</p> <p>RC WALLS</p> <p>WALLS 1, 4 & 5 = $(21 + 9 + 9) \times 0.5 \times 24 = 468.0 \text{ kN}$</p> <p>WALL 2 = $21 \times 7.2 \times 0.5 \times 24 = 1814.0 \text{ kN}$</p> <p>WALL 3 = $\left(\begin{matrix} 16 \times 7.2 \times 0.5 \times 24 \\ + 4.5 \times 3.25 \times 24 \times 0.5 \end{matrix} \right) = 1557.9 \text{ kN}$</p> <p>WALL 6 & PART OF 4 = $(6.5 + 6.5) \times 0.5 \times 3.25 \times 24 = 507.0 \text{ kN}$</p> <p>WALL 7 = $15 \times 1.5 \times 0.2 \times 24 = 108.0 \text{ kN}$</p> <p>BLOCK WALLS = $\left(\begin{matrix} 20 \times 5.2 + 20 \times 1.9 \\ + 10 \times 5.2 \times 2 + \frac{10}{2} \times 1.0 \times 2 \end{matrix} \right) \times 3.3 = 844.8 \text{ kN}$</p> <p>RC ROOF OF SUMP = $16 \times 5 \times 0.2 \times 24 = 384.0 \text{ kN}$</p> <p>SCREENED & PEBBLES ON ROOF = $\left(\begin{matrix} 0.15 \times 24 \\ + 0.2 \times 20 \end{matrix} \right) \times 16 \times 5.0 = 608.0 \text{ kN}$</p> <p>RC BASE SLAB WITH 1.0M EXT. ALL AROUND = $\left(\begin{matrix} 17.5 \times 23.5 \\ + 2.0 \times 7.5 \end{matrix} \right) \times 0.5 \times 24 = 5115.0 \text{ kN}$</p>	


CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW.	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY.	SHEET 25 OF
	SCHEME COMPONENT KMU - PUMP HOUSE & RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
	TOTAL DEAD WEIGHT = 13008.1 KN.	
	A) RECORDED MAX ^m . FLOOD LEVEL 8.0MSL.	
	$\begin{aligned} \text{UPLIFT} &= (23.5 \times 11.0) \times (8 - 7.5) \times 10 \\ &+ 17.0 \times 5.5 \times (8 - 6.8) \times 10 \\ &+ 6 \times 6.5 \times (8 - 7.5) \times 10 \\ &= 2609.5 \text{ KN} \end{aligned}$	
	$\begin{aligned} \text{FOS} &= \frac{13008.1}{2609.5} \\ &= 4.985 > 1.1 \end{aligned}$	
	B) FLOOD LEVEL REACHING 10.0 MSL.	
	$\begin{aligned} \text{UPLIFT} &= \left[\begin{aligned} &(23.5 \times 11.0 + 6 \times 6.5) \times (10 - 7.5) \\ &(- 23.5 \times 1.0 - 17.0 \times 1.0) \\ &(- 6 \times 1.0 - 6.5 \times 1.0) \end{aligned} \right] \times 10 \\ &\quad \times (10 - 8.9) \times 10 \\ &+ (17.0 \times 5.5) \times (10 - 6.8) \times 10 \\ &\quad (- 5.5 \times 1.0 - 17 \times 1.0) \times (10 - 7.3) \times 10 \end{aligned}$	
	$= 8788.0 \text{ KN.}$	
	$\text{FOS} = \frac{13008.1}{8788.0} = 1.48 > 1.1$	
	C) FLOOD LEVEL REACHING 11.25 MSL.	
	$\begin{aligned} \text{UPLIFT} &= \left[\begin{aligned} &(23.5 \times 11.0 + 6 \times 6.5) \times (11.25 - 7.5) \\ &- (23.5 + 11 + 6 + 6.5) \times (11.25 - 8) \end{aligned} \right] \times 10 \\ &+ (17.0 \times 5.5) \times (11.25 - 6.8) \times 10 \\ &- (5.5 + 17) \times 1.0 \times (11.25 - 7.3) \times 10 \end{aligned}$	
	$= 12900.8 \text{ KN.}$	
	$\text{FOS} = \frac{13008.1}{12900.8} = 1.01 < 1.1$	FOS AGAINST FLOATAION
	WHEN CONSIDERING EXTRA WEIGHTS OF THRUST BLOCKS, PUMPS ETC., FOS > 1.1. ∴ SATISFACTORY	OK.

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHEY.	SHEET 26 OF
	SCHEME COMPONENT KMU - PUMP HOUSE & RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

8.0 ANALYSIS OF PUMP HOUSE RC FRAME.



NO. OF NODES = 11
 NO. OF ELEMENTS = 10
 NO. OF MATERIALS = 3.

MATERIAL	AREA (M ²)	I (M ⁴)	ELEMENTS
1 - 300 X 500	0.15	3.125E-3	1/4
2 - 300 X 400	0.12	1.6E-3	5/8
3 - 300 X 800	0.24	1.28E-2	9 10

LOADS: DL = 0.5 x 4 + 0.12 x 24 = 4.88 kN/m.

LL = 1.0 x 4.0 = 4.0 "

WL = 0.81 \downarrow = \downarrow 0.78 & \rightarrow 0.20

DL = -4.88 kN/m ELEM. 5/8 & -92.0 ^{kN/m} EL. 9/10

LL = -4.0 " " 5/8

WL = -0.78 \downarrow , +0.21 \rightarrow 5/6, +0.78 \uparrow , \rightarrow +0.21 \rightarrow 7/8

CRANE: Node 5 - 32.0 \downarrow & Node 7, - 8.0 \downarrow
 Node 5 - 8.0 \downarrow & Node 7, - 32.0 \downarrow .

```

=====
MICROFEAP-PI                DATE: 11-05-2000                <DATA> P.1
PROJECT : AMBATALE PUMP HOUSE ROOF FRAME                FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH                ENGINEER: MOHD. LUTHFY
=====

```

```

*****
*
*  STRUCTURE DATA  *
*
*****

```

*COORDINATE DATA (m)**			**BOUNDARY DATA**		
NODE	1-COOR	2-COOR	1-B	2-B	3-B
1	0.00	5.19			
2	0.75	0.00	L	L	F
3	0.75	4.00			
4	0.75	5.40			
5	1.35	4.00			
6	5.50	6.60			
7	9.65	4.00			
8	10.25	2.80	L	L	F
9	10.25	4.00			
10	10.25	5.40			
11	11.00	5.19			

*ELEMENT DATA**				
ELEM	1-NODE	2-NODE	HINGE	MATERIAL
1	2	3		1
2	3	4		1
3	8	9		1
4	9	10		1
5	1	4		2
6	4	6		2
7	6	10		2
8	10	11		2
9	3	5		3
10	7	9		3

MATERIAL DATA			
MATE	E-MODULUS (KN/m ²)	AXIAL-AREA (m ²)	INERTIA (m ⁴)
1	2.100D+07	1.500D-01	3.125D-03
2	2.100D+07	1.200D-01	1.600D-03
3	2.100D+07	2.400D-01	1.280D-02

```

LOAD CASE #1 : DEAD LOAD
**UNIFORM LOAD DATA**
ELEM  1-UNIFORM  2-UNIFORM
      (KN/m)     (KN/m)
-----

```

```

=====
MICROFEAP - P1                DATE: 11-05-2000                <DATA> P.2
PROJECT : AMBATALE PUMP HOUSE ROOF FRAME                FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH                ENGINEER: MOHD. LUTHFY
=====

```

LOAD CASE #1 : DEAD LOAD

UNIFORM LOAD DATA

ELEM	1-UNIFORM (KN/m)	2-UNIFORM (KN/m)
5	0.000D+00	-4.880D+00
6	0.000D+00	-4.880D+00
7	0.000D+00	-4.880D+00
8	0.000D+00	-4.880D+00
9	0.000D+00	-9.200D+01
10	0.000D+00	-9.200D+01

LOAD CASE #2 : LIVE LOAD

UNIFORM LOAD DATA

ELEM	1-UNIFORM (KN/m)	2-UNIFORM (KN/m)
5	0.000D+00	-4.000D+00
6	0.000D+00	-4.000D+00
7	0.000D+00	-4.000D+00
8	0.000D+00	-4.000D+00

LOAD CASE #3 : WIND LOAD

UNIFORM LOAD DATA

ELEM	1-UNIFORM (KN/m)	2-UNIFORM (KN/m)
5	2.100D-01	-7.800D-01
6	2.100D-01	-7.800D-01
7	2.100D-01	7.800D-01
8	2.100D-01	7.800D-01

LOAD CASE #4 : CRANE LOAD

NODAL FORCE DATA

NODE	1-FORC (KN)	2-FORC (KN)	3-FORC (KN-m)
5	0.000D+00	-3.200D+01	0.000D+00
7	0.000D+00	-8.000D+00	0.000D+00

LOAD CASE #5 : CRANE LOAD 2

NODAL FORCE DATA

NODE	1-FORC (KN)	2-FORC (KN)	3-FORC (KN-m)
5	0.000D+00	-8.000D+00	0.000D+00
7	0.000D+00	-3.200D+01	0.000D+00

```

=====
MICROFEAP - P1                DATE: 11-05-2000                <COMB> P.1
PROJECT : AMBATALE PUMP HOUSE ROOF FRAME                FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH                ENGINEER: MOHD. LUTHFY
=====

```

```

*****
*
* COMBINATION *
*
*****

```

DISPLACEMENT COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1.4/1.6/0/1.6/0

MODE	1-DISP (m)	2-DISP (m)	3-DISP (Rad)
1	-1.3015D-02	1.6101D-04	-6.0427D-04
2	0.0000D+00	0.0000D+00	4.2475D-03
3	-1.2578D-02	-2.6264D-04	9.3861D-04
4	-1.2887D-02	-2.9747D-04	-6.3302D-04
5	-1.2578D-02	2.7904D-04	8.8707D-04
6	-1.0113D-02	-1.1558D-02	-6.2155D-04
7	-3.1331D-03	-1.7568D-03	2.8353D-03
8	0.0000D+00	0.0000D+00	2.5117D-03
9	-3.1331D-03	-5.9917D-05	2.8095D-03
10	-7.2810D-03	-8.9784D-05	3.2512D-03
11	-6.6024D-03	2.3323D-03	3.2225D-03

STRESS COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1.4/1.6/0/1.6/0

ELEM	MA HINGE	SECTION (m)	AXIAL F. (KN)	SHEAR (KN)	MOMENT (KN-m)
1	1	0.00	-2.0683D+02	-2.7143D+01	3.8147D-06
		4.00	-2.0683D+02	-2.7143D+01	-1.0857D+02
2	1	0.00	-7.8351D+01	-2.7143D+01	-5.4670D+01
		1.40	-7.8351D+01	-2.7143D+01	-9.2670D+01
3	1	0.00	-1.5728D+02	2.7143D+01	-3.0518D-05
		1.20	-1.5728D+02	2.7143D+01	3.2572D+01
4	1	0.00	-6.7201D+01	2.7143D+01	1.7065D+00
		1.40	-6.7201D+01	2.7143D+01	3.9707D+01
5	2	0.00	-1.2341D-03	-7.7486D-05	-3.1590D-06
		0.19	6.6772D-01	-2.3892D+00	-2.3260D-01
		0.39	1.3367D+00	-4.7783D+00	-9.3038D-01
		0.58	2.0056D+00	-7.1674D+00	-2.0933D+00
		0.78	2.6746D+00	-9.5565D+00	-3.7215D+00

```

=====
MICROFEAP-P1                DATE: 11-05-2000                <COMB> P.2
OBJECT : AMBATALE PUMP HOUSE ROOF FRAME                FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH                ENGINEER: MOHD. LUTHFY
=====

```

STRESS COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1.4/1.6/0/1.6/0

MEMBER	MEMBER NO	SECTION	AXIAL F. (KN)	SHEAR (KN)	MOMENT (KN-m)
6	2	0.00	-4.3077D+01	5.9694D+01	-9.6392D+01
		1.22	-3.9228D+01	4.4460D+01	-3.2607D+01
		2.45	-3.5380D+01	2.9226D+01	1.2518D+01
		3.67	-3.1531D+01	1.3991D+01	3.8984D+01
		4.90	-2.7682D+01	-1.2431D+00	4.6791D+01
7	2	0.00	-2.4951D+01	1.2054D+01	4.6791D+01
		1.22	-2.8799D+01	-3.1807D+00	5.2225D+01
		2.45	-3.2648D+01	-1.8415D+01	3.9000D+01
		3.67	-3.6497D+01	-3.3649D+01	7.1152D+00
		4.90	-4.0345D+01	-4.8884D+01	-4.3429D+01
8	2	0.00	2.6756D+00	9.5565D+00	-3.7216D+00
		0.19	2.0066D+00	7.1674D+00	-2.0934D+00
		0.39	1.3376D+00	4.7783D+00	-9.3038D-01
		0.58	6.6869D-01	2.3892D+00	-2.3254D-01
		0.78	-2.5755D-04	9.2745D-05	1.1128D-04
9	3	0.00	0.0000D+00	1.2848D+02	-5.3903D+01
		0.60	0.0000D+00	5.1200D+01	1.3542D-04
10	3	0.00	0.0000D+00	-1.2800D+01	2.5320D-04
		0.60	0.0000D+00	-9.0080D+01	-3.0865D+01

SUPPORT REACTIONS <2D-FRAME SYSTEM>

LOAD FACTOR : 1.4/1.6/0/1.6/0

NODE	1-REACTION (KN)	2-REACTION (KN)	3-REACTION (KN-m)
2	2.7143D+01	2.0683D+02	0.0000D+00
8	-2.7143D+01	1.5728D+02	0.0000D+00

```

=====
MICROFEAP - P1                DATE: 11-05-2000                <COMB> P.1
PROJECT : AMBATALE PUMP HOUSE ROOF FRAME                FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH                ENGINEER: MOHD. LUTHFY
=====

```

```

*****
*                               *
* COMBINATION                   *
*                               *
*****

```

DISPLACEMENT COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1.4/1.6/0/0/1.6

NODE	1-DISP (m)	2-DISP (m)	3-DISP (Rad)
1	-1.8251D-02	-2.9230D-04	5.4494D-05
2	0.0000D+00	0.0000D+00	5.2607D-03
3	-1.6731D-02	-2.1981D-04	2.0270D-03
4	-1.8261D-02	-2.5671D-04	2.5739D-05
5	-1.6731D-02	9.8523D-04	2.0012D-03
6	-1.5222D-02	-1.2568D-02	-1.1658D-03
7	-5.5421D-03	-2.9817D-03	4.8640D-03
8	0.0000D+00	0.0000D+00	4.5214D-03
9	-5.5421D-03	-7.2767D-05	4.8124D-03
10	-1.2135D-02	-1.0056D-04	4.7376D-03
11	-1.1144D-02	3.4364D-03	4.7089D-03

STRESS COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1.4/1.6/0/0/1.6

ELEM	MA	HINGE SECTION (m)	AXIAL F. (KN)	SHEAR (KN)	MOMENT (KN-m)
1	1	0.00	-1.7310D+02	-2.6526D+01	-2.2888D-05
		4.00	-1.7310D+02	-2.6526D+01	-1.0611D+02
2	1	0.00	-8.3020D+01	-2.6527D+01	-7.5242D+01
		1.40	-8.3020D+01	-2.6527D+01	-1.1238D+02
3	1	0.00	-1.9101D+02	2.6526D+01	-1.2207D-04
		1.20	-1.9101D+02	2.6526D+01	3.1831D+01
4	1	0.00	-6.2532D+01	2.6526D+01	-2.2075D+01
		1.40	-6.2532D+01	2.6526D+01	1.5062D+01
5	2	0.00	4.9013D-04	-4.9424D-04	8.9586D-05
		0.19	6.6944D-01	-2.3896D+00	-2.3255D-01
		0.39	1.3384D+00	-4.7787D+00	-9.3037D-01
		0.58	2.0073D+00	-7.1678D+00	-2.0934D+00
		0.78	2.6763D+00	-9.5569D+00	-3.7216D+00


```

=====
MICROFEAP - P1                DATE: 11-05-2000                <COMB> P.2
PROJECT : AMBATALE PUMP HOUSE ROOF FRAME                FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH                ENGINEER: MOHD. LUTHFY
=====

```

RESS COMBINATION <2D-FRAME SYSTEM>

AD FACTOR : 1.4/1.6/0/0/1.6

EM	MA	HINGE SECTION (m)	AXIAL F. (KN)	SHEAR (KN)	MOMENT (KN-m)
6	2	0.00	-4.3622D+01	6.4372D+01	-1.1610D+02 ←
		1.22	-3.9773D+01	4.9138D+01	-4.6587D+01
		2.45	-3.5924D+01	3.3903D+01	4.2676D+00
		3.67	-3.2076D+01	1.8669D+01	3.6463D+01
		4.90	-2.8227D+01	3.4347D+00	5.0000D+01
7	2	0.00	-2.3209D+01	1.6429D+01	5.0000D+01
		1.22	-2.7058D+01	1.1948D+00	6.0793D+01
		2.45	-3.0907D+01	-1.4040D+01	5.2926D+01
		3.67	-3.4755D+01	-2.9274D+01	2.6401D+01
		4.90	-3.8604D+01	-4.4508D+01	-1.8783D+01
8	2	0.00	2.6748D+00	9.5562D+00	-3.7215D+00
		0.19	2.0059D+00	7.1671D+00	-2.0934D+00
		0.39	1.3369D+00	4.7780D+00	-9.3041D-01
		0.58	6.6796D-01	2.3888D+00	-2.3265D-01
		0.78	-9.8997D-04	-2.7347D-04	-7.1824D-05
9	3	0.00	0.0000D+00	9.0081D+01	-3.0862D+01
		0.60	0.0000D+00	1.2801D+01	1.3351D-05
10	3	0.00	0.0000D+00	-5.1198D+01	7.4148D-04
		0.60	0.0000D+00	-1.2848D+02	-5.3906D+01

SUPPORT REACTIONS <2D-FRAME SYSTEM>

AD FACTOR : 1.4/1.6/0/0/1.6

NODE	1-REACTION (KN)	2-REACTION (KN)	3-REACTION (KN-m)
2	2.6526D+01	1.7310D+02	0.0000D+00
8	-2.6526D+01	1.9101D+02	0.0000D+00

```

=====
MICROFEAP~P1          DATE: 11-05-2000          <COMB> P.1
OBJECT : AMBATALE PUMP HOUSE ROOF FRAME          FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH          ENGINEER: MOHD. LUTHFY
=====

```

```

*****
*
* COMBINATION *
*
*****

```

DISPLACEMENT COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1.2/1.2/1.2/1.2/0

NODE	1-DISP (m)	2-DISP (m)	3-DISP (Rad)
1	-9.9292D-03	1.9219D-04	-5.7796D-04
2	0.0000D+00	0.0000D+00	3.3052D-03
3	-9.6918D-03	-2.1661D-04	6.5839D-04
4	-9.8061D-03	-2.4591D-04	-6.0319D-04
5	-9.6918D-03	1.6149D-04	6.1790D-04
6	-7.6053D-03	-9.1841D-03	-3.6385D-04
7	-2.2854D-03	-1.2987D-03	2.0897D-03
8	0.0000D+00	0.0000D+00	1.8225D-03
9	-2.2854D-03	-4.8426D-05	2.0685D-03
10	-5.3565D-03	-7.1216D-05	2.4305D-03
11	-4.8491D-03	1.7397D-03	2.4094D-03

STRESS COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1.2/1.2/1.2/1.2/0

ELEM	MEMBER	HINGE SECTION (m)	AXIAL F. (KN)	SHEAR (KN)	MOMENT (KN-m)
1	1	0.00	-1.7058D+02	-2.1712D+01	-5.7220D-06
		4.00	-1.7058D+02	-2.1712D+01	-8.6850D+01
2	1	0.00	-6.5938D+01	-2.1712D+01	-4.3938D+01
		1.40	-6.5938D+01	-2.1712D+01	-7.4336D+01
3	1	0.00	-1.2712D+02	2.2423D+01	-3.0518D-05
		1.20	-1.2712D+02	2.2423D+01	2.6908D+01
4	1	0.00	-5.1278D+01	2.2423D+01	1.2747D+00
		1.40	-5.1278D+01	2.2423D+01	3.2667D+01
5	2	0.00	1.1035D-03	5.4628D-05	-3.5398D-05
		0.19	5.7440D-01	-2.0965D+00	-2.0413D-01
		0.39	1.1477D+00	-4.1931D+00	-8.1646D-01
		0.58	1.7210D+00	-6.2897D+00	-1.8370D+00
		0.78	2.2943D+00	-8.3862D+00	-3.2658D+00

```

=====
MICROFEAP-P1                      DATE: 11-05-2000                   <COMB> P.2
OBJECT : AMBATALE PUMP HOUSE ROOF FRAME  FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH   ENGINEER: MOHD. LUTHFY
=====

```

STRESS COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1.2/1.2/1.2/1.2/0

MEM	MA	HINGE SECTION (m)	AXIAL F. (KN)	SHEAR (KN)	MOMENT (KN-m)
6	2	0.00	-3.5124D+01	5.0169D+01	-7.7602D+01
		1.22	-3.1825D+01	3.6804D+01	-2.4339D+01
		2.45	-2.8527D+01	2.3439D+01	1.2554D+01
		3.67	-2.5229D+01	1.0075D+01	3.3078D+01
		4.90	-2.1930D+01	-3.2901D+00	3.7233D+01
7	2	0.00	-2.0861D+01	7.5203D+00	3.7233D+01
		1.22	-2.3762D+01	-3.6520D+00	3.9602D+01
		2.45	-2.6662D+01	-1.4824D+01	2.8287D+01
		3.67	-2.9563D+01	-2.5997D+01	3.2880D+00
		4.90	-3.2463D+01	-3.7169D+01	-3.5395D+01
8	2	0.00	2.0172D+00	7.0055D+00	-2.7282D+00
		0.19	1.5131D+00	5.2541D+00	-1.5346D+00
		0.39	1.0089D+00	3.5026D+00	-6.8207D-01
		0.58	5.0477D-01	1.7512D+00	-1.7055D-01
		0.78	6.2974D-04	-2.4530D-04	-4.8079D-05
9	3	0.00	0.0000D+00	1.0464D+02	-4.2911D+01
		0.60	0.0000D+00	3.8400D+01	-1.1086D-04
10	3	0.00	0.0000D+00	-9.5997D+00	-3.5858D-04
		0.60	0.0000D+00	-7.5840D+01	-2.5633D+01

SUPPORT REACTIONS <2D-FRAME SYSTEM>

LOAD FACTOR : 1.2/1.2/1.2/1.2/0

NODE	1-REACTION (KN)	2-REACTION (KN)	3-REACTION (KN-m)
2	2.1712D+01	1.7058D+02	0.0000D+00
8	-2.2423D+01	1.2712D+02	0.0000D+00

```

=====
MICROFEAP~P1          DATE: 11-05-2000          <COMB> P.1
PROJECT : AMBATALE PUMP HOUSE ROOF FRAME        FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH         ENGINEER: MOHD. LUTHFY
=====

```

```

*****
*
* COMBINATION *
*
*****

```

DISPLACEMENT COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1/0/1.4/0/0

NODE	1-DISP (m)	2-DISP (m)	3-DISP (Rad)
1	-5.0215D-03	4.4515D-05	-2.2497D-04
2	0.0000D+00	0.0000D+00	1.6085D-03
3	-4.8245D-03	-1.1196D-04	4.0147D-04
4	-4.9734D-03	-1.2661D-04	-2.3800D-04
5	-4.8245D-03	1.2338D-04	3.8915D-04
6	-3.9485D-03	-4.2892D-03	-1.5667D-04
7	-1.2783D-03	-7.2072D-04	1.1561D-03
8	0.0000D+00	0.0000D+00	1.0260D-03
9	-1.2783D-03	-2.8920D-05	1.1438D-03
10	-2.8993D-03	-3.8126D-05	1.2254D-03
11	-2.6432D-03	8.7628D-04	1.2172D-03

STRESS COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1/0/1.4/0/0

ELEM	MEMBER	HINGE SECTION (m)	AXIAL F. (KN)	SHEAR (KN)	MOMENT (KN-m)
1	1	0.00	-8.8165D+01	-9.9010D+00	8.5831D-06
		4.00	-8.8165D+01	-9.9010D+00	-3.9604D+01
2	1	0.00	-3.2965D+01	-9.9010D+00	-2.3044D+01
		1.40	-3.2965D+01	-9.9010D+00	-3.6906D+01
3	1	0.00	-7.5915D+01	1.0730D+01	7.6294D-06
		1.20	-7.5915D+01	1.0730D+01	1.2876D+01
4	1	0.00	-2.0715D+01	1.0730D+01	-3.6844D+00
		1.40	-2.0715D+01	1.0730D+01	1.1338D+01
5	2	0.00	7.7285D-04	7.8976D-05	-2.5470D-05
		0.19	2.8783D-01	-1.0824D+00	-1.0540D-01
		0.39	5.7488D-01	-2.1648D+00	-4.2153D-01
		0.58	8.6194D-01	-3.2472D+00	-9.4843D-01
		0.78	1.1490D+00	-4.3297D+00	-1.6861D+00

```

=====
MICROFEAP-P1          DATE: 11-05-2000          <COMB> P.2
OBJECT : AMBATALE PUMP HOUSE ROOF FRAME          FILENAME: AMBRFRM
AUTHORITY: KANDIAH SRIBALASKANDARAJAH          ENGINEER: MOHD. LUTHFY
=====

```

RESS COMBINATION <2D-FRAME SYSTEM>

LOAD FACTOR : 1/0/1.4/0/0

MEMBER	MEMBER NO	HINGE SECTION (m)	AXIAL F. (KN)	SHEAR (KN)	MOMENT (KN-m)
6	2	0.00	-1.6637D+01	2.5178D+01	-3.8592D+01
		1.22	-1.4985D+01	1.8281D+01	-1.1977D+01
		2.45	-1.3334D+01	1.1384D+01	6.1897D+00
		3.67	-1.1682D+01	4.4864D+00	1.5909D+01
		4.90	-1.0031D+01	-2.4110D+00	1.7180D+01
7	2	0.00	-9.9721D+00	2.6424D+00	1.7180D+01
		1.22	-1.1159D+01	-1.6973D+00	1.7758D+01
		2.45	-1.2347D+01	-6.0369D+00	1.3022D+01
		3.67	-1.3534D+01	-1.0377D+01	2.9703D+00
		4.90	-1.4721D+01	-1.4716D+01	-1.2397D+01
8	2	0.00	8.2558D-01	2.7191D+00	-1.0589D+00
		0.19	6.1921D-01	2.0393D+00	-5.9562D-01
		0.39	4.1284D-01	1.3595D+00	-2.6473D-01
		0.58	2.0647D-01	6.7974D-01	-6.6208D-02
		0.78	1.0566D-04	-3.9518D-05	-4.4715D-05
9	3	0.00	0.0000D+00	5.5200D+01	-1.6560D+01
		0.60	0.0000D+00	9.7275D-05	-1.1253D-04
10	3	0.00	0.0000D+00	-5.6839D-04	1.2851D-04
		0.60	0.0000D+00	-5.5201D+01	-1.6561D+01

SUPPORT REACTIONS <2D-FRAME SYSTEM>

LOAD FACTOR : 1/0/1.4/0/0

NODE	1-REACTION (KN)	2-REACTION (KN)	3-REACTION (KN-m)
2	9.9010D+00	8.8165D+01	0.0000D+00
8	-1.0730D+01	7.5915D+01	0.0000D+00

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW CALCULATIONS BY MOHD. LUTHFI SCHEME COMPONENT KMU - PUMP HOUSE & RESERVOIR.	JOB NO. SHEET 37 OF DATE
ITEM	CALCULATIONS	OUT PUT
8.1	<p>DESIGN OF REINFORCEMENT</p> <p>ELEMENTS 5, 6, 7 & 8.</p> <p>MAX^m: BM = 116.1 kNm.</p> <p>Maxⁿ: SF = 64.4 kN.</p> <p>BEAM SECTION 300 x 400.</p> <p>USING BS 8110; PART II: 1985 DESIGN CHARTS FOR $f_{cu} = 35.0$</p> $\frac{M}{bd^2} = \frac{116.1 \times 10^6}{300 \times 352^2} = 3.12$ <p>$\therefore \frac{100A_s}{bd} = 0.89$</p> $\therefore A_s = 0.89 \times 300 \times 352 / 100 = 940.0 \text{ mm}^2$ <p>PROVIDE <u>3T20</u> $\rightarrow A_s = 942.5 \text{ mm}^2$</p> <p><u>SHEAR:</u></p> $V = \frac{64.4 \times 10^3}{300 \times 352} = 0.61 \text{ N/mm}^2$ $V_c = 0.675 \text{ N/mm}^2$ <p>$0.5V_c < V < V_c + 0.4$</p> <p>NOMINAL SHEAR LINKS.</p> $\Rightarrow \frac{A_{sv}}{S_v} \geq \frac{0.4bv}{0.87f_{yv}}$ $\geq \frac{0.4 \times 300}{0.87 \times 460}$ <p>$\therefore S_v \leq 3.335 A_{sv}$</p> <p>USING T8 BARS 2 Legs. $A_{sv} = 100.5 \text{ mm}^2$</p> <p>$\therefore S_v \leq 333.2 \text{ mm}$</p> <p>T8@300 c/c LINKS OK.</p>	<p>MAIN BARS 3T20</p> <p>LINKS T8@300</p>

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY.	SHEET <u>38</u> OF
	SCHEME KIU - PUMP HOUSE & COMPONENT RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
------	--------------	---------

DESIGN OF BASE SLAB:


TOTAL DEAD LOAD = 13008.1 KN
 LIVE LOAD ON ROOF = 1.0 KN/m²
 LIVE LOAD ON STAGING AREA = 10.0 KN/m²
 LIVE LOAD ON PUMP FLOOR = 10.0 "
 WATER LOAD = 69.5 KN/m².

∴ TOTAL SERVICE PRESSURE ON THE
 GROUND = $\frac{13008.1}{23.5 \times 17.5} + 1.0 + 10 + 10 + 69.5$
 = 31.6 + 90.5
 = 122.1 KN/m² < 250.0 KN/m²
 ∴ OK.

ULTIMATE DESIGN PRESSURE
 IN SUMP BASE
 = $(31.6 + 69.5) \times 1.4 + 2.5 \times 1.6$
 = 145.5 KN/m²

ULTIMATE DESIGN PRESSURE IN
 PUMP HOUSE BASE
 = $1.4 \times 31.6 + 1.6 \times 21.0$
 = 77.84 KN/m².

PUMP HOUSE BASE SLAB ANALYSED AS
 INVERTED FLOOR SLAB FRAMING WITH
 RC WALLS & COLUMN. (4000mm WIDE
 SLAB)



TITLE PUMP HOUSE BASE SLAB

F.O.S FOR DL= 1 ***F.O.S. FOR IMPL= 1
STRUCTURE INFORMATION NO.OF SPANS= 2

SPAN NO	SPAN LTH-m	Iz- mm^4
1	3.05	4.167E+10
2	6.45	4.167E+10

COLUMN ROW	LENGTH(m)	2ND MOMENT OF AREA(mm^4)		
1.00	0.00	0.00	ABOVE	
1.00	3.00	%41670000000.00		BELOW
2.00	0.00	0.00	ABOVE	
2.00	3.00	%21330000000.00		BELOW
3.00	0.00	0.00	ABOVE	
3.00	3.00	%41670000000.00		BELOW

*****LOADING INFORMATION*****

SP.NO	LOAD-kN	ST.DIST-m	COV.DIST-m	DD/IMP
1	949.60	0.00	3.05	D
2	2008.30	0.00	6.45	D

CANT.CHR.D.MT LHS= 0 kNm CANT.CHR.IMP.MT.LHS = 0 kNm
CANT.CHR.D.MT RHS= 0 kNm CANT.CHR.IMP.MT.RHS = 0 kNm

MAX.SHEARS AND MOMENTS. SF-kN BM-kNm

SPAN NO.	SHEAR	HOG.MT	SAG.MT
1	158.33	0.00	53.89
	-791.27	-911.35	0.00

MAX.SPAN MNT= 93.73001 kNm AT A DISTANCE= .45 m

2	1019.41	-947.59	0.00
	-988.89	-849.17	0.00

MAX.SPAN MNT= 720.8 kNm AT A DISTANCE= 3.22 m

COLUMN MOMENTS, kN.m

COLUMN ROW	COLUMN MOMENTS	
	ABOVE	BELOW
1.00	0.00	-53.89
2.00	0.00	36.25
3.00	0.00	-849.17

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW.	JOB NO.
	CALCULATIONS BY MOHD. LUTHFY.	SHEET...40...OF.....
	SCHEME KNU - PUMP HOUSE & COMPONENT RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
	<p>MAX^M. (-)VE BM AT SUPPORT. = 947.6 kNm.</p> <p>COLUMN STRIP 75% = 710.7 kNm.</p> <p>MIDDLE STRIP 25% = 236.9 kNm.</p> <p>MAX^M. +VE BM AT MID SPAN = 720.8 kNm.</p> <p>COLUMN STRIP 55% = 396.4 kNm.</p> <p>MIDDLE STRIP 45% = 324.4 kNm.</p> <p>WIDTH OF COLUMN STRIP = 2000 mm.</p> <p>WIDTH OF MIDDLE STRIP = 2000 mm.</p> <p>REINFORCEMENT:</p> <p>AT SUPPORT - BOTTOM BAR.</p> <p>$M = 720.8 \text{ kNm.}$ $b = 2000 \text{ mm.}$ $d = 500 - 50 - \frac{20}{2}$ $= 440 \text{ mm.}$</p> <p>$\frac{M}{bd^2} = \frac{720.8 \times 10^6}{2000 \times 440^2} = 1.86$</p> <p>$\frac{100A_s}{bd} = 0.51 \rightarrow A_s = \frac{0.51 \times 2000 \times 440}{100}$ $= 4488.0 \text{ mm}^2$ $= 2244 \text{ mm}^2/\text{m.}$</p> <p>PROVIDE T20 @ 125 c/c $\rightarrow A_s = 2593.0 \text{ mm}^2$</p> <p>MIDDLE STRIP - BOTTOM BAR</p> <p>$M = 236.9 \text{ kNm.}$ $b = 2000 \text{ mm.}$ $d = 440 \text{ mm.}$</p> <p>$\frac{M}{bd^2} = \frac{236.9 \times 10^6}{2000 \times 440^2} = 0.61$</p> <p>$\frac{100A_s}{bd} = 0.17 \rightarrow A_s = \frac{0.17 \times 2000 \times 440}{100}$ $= 1496.0 \text{ mm}^2$ $= 748.0 \text{ mm}^2/\text{m.}$</p> <p>NOMINAL $\rightarrow 0.35\% \rightarrow A_s = 1750.0 \text{ mm}^2/\text{m.}$ PROVIDE T20 @ 150 $\rightarrow A_s = 2094.0 \text{ mm}^2$</p>	<p>PROVIDE BOTTOM BAR AT SUPPORT T20 @ 125 c/c</p> <p>MIDDLE STRIP BOTTOM BAR T20 @ 150</p>

CEYWATER CONSULTANT (PVT) LTD. INFRASTRUCTURE & ENVIRONMENTAL ENGINEERS AND PLANNERS	PROJECT NRW	JOB NO.
	CALCULATIONS BY MOHD. LUTHAFY	SHEET 41 OF
	SCHEME KNU - PUMP HOUSE & COMPONENT RESERVOIR.	DATE

ITEM	CALCULATIONS	OUT PUT
	<p>COLUMN STRIP TOP BAR</p> <p>$M = 396.4 \text{ kNm.}$ $b = 2000 \text{ mm}$ $d = 440 \text{ mm.}$ $\frac{M}{bd^2} = \frac{396.4 \times 10^6}{2000 \times 440^2} = 1.02.$ $\frac{100A_s}{bd} = 0.28 \rightarrow A_s = 0.28 \times 2000 \times 440 / 100$ $= 2464.0 \text{ mm}^2$ $= 1232.0 \text{ mm}^2/\text{m.}$ NOMINAL $\rightarrow 0.35\% \rightarrow A_s = 1750 \text{ mm}^2/\text{m.}$ PROVIDE T20 @ 150 c/c.</p> <p>PUNCHING SHEAR. SHEAR NOMINAL. NO SHEAR REINFORCEMENT NECESSARY.</p>	<p>TOP BAR T20 @ 150 c/c.</p>

DESIGN OF CRACK

BS 8007 : 1987

Pump House Base Slab

DESIGN SURFACE CRACK WIDTH $\omega = \frac{3acr.E_m}{1+2\left(\frac{acr - C_{min}}{h-x}\right)}$

$$\epsilon_m = \frac{\epsilon_1 - bt(h-x)(a' - x)}{3E_s.A_s(d-x)}$$

SERVICE MOMENT M = 253.8 KNM/M

h (mm) = 500 Cmin = 50 (mm) $\phi = 20.00$ mm
 d = h - Cmin - $\phi/2$ d = 440.00 mm

CONCRETE f_{cu} = 35 N/mm²
 fy = 460 N/mm²

REINFORCEMENT PROVIDED BAR DIAMETER $\phi = 20$ mm
 BAR SPACING S = 100 mm

Asp = 3141.59 mm²

Ec = 28 KN/mm²
 Es = 200 KN/mm²

$\alpha_e = E_s / 1/2 E_c = 14.29$

$\rho = 0.00714$

$\alpha_e \rho = 0.102$

THEREFORE $\frac{x}{d} = -\alpha_e(\rho + \rho') + \sqrt{\alpha_e^2(\rho + \rho')^2 + 2\alpha_e(\rho + d'\rho')}$ = 0.361
 CONSIDERING $\rho' = 0$

THEREFORE x = 158.86 mm

z = d - 1/3 x = 387.05 mm

$f_s = \frac{M}{Asp.z} = 208.73$ N/mm²

$\epsilon_s = \frac{f_s}{E_s \times 1000} = 0.0010436$

$$\varepsilon_1 = \frac{(h-x) * \varepsilon_s}{(d-x)} = 0.001266$$

$$\varepsilon_m = 0.0010468$$

1) CRACK UNDER THE BAR DIRECTLY

$$a_{cr} = C_{min} = 50 \text{ mm}$$

$$\omega = 3.a_{cr}.\varepsilon_m = 0.157 \text{ mm}$$

$$< 0.2 \text{ mm} \quad \text{O.K}$$

2) CRACK AT MIDWAY BETWEEN TWO BARS

$$a_{cr} + \phi/2 = \sqrt{(S/2)^2 + (\phi/2 + C_{min})^2} = 78.10$$

$$a_{cr} = 68.10 \text{ mm}$$

$$\omega = 0.193 \text{ mm}$$

$$< 0.2 \text{ mm} \quad \text{O.K}$$

THEREFORE REINFORCEMENT T20 @ 100 C/C O.K

