

PART II

DESIGN CALCULATIONS – HYDRAULIC

**MALIGAKANDA RESERVOIR SITE –
GRAVITY DRAIN FOR OVERFLOW / WASHOUT**

Maligakanda Reservoir Site

Design of Gravity Drain for Overflow / Washout

R2 - Existing Circular Reservoir

R3 - New Maligakanda Reservoir

Scenario 1 - R2 and R3 Reservoirs Overflowing

Design Flow : MH1 - MH2 = 74,000 m³/day = .856 m³/s

: EMH - MH3 - MH4 - MH2 = 22,000 m³/day = .255 m³/s

: MH2 - Outfall = 96,000 m³/day = 1.111 m³/s

Manning N for RCC Hume Pipes : 0.012

Segment No.	From MH	To MH	Length m	Flow m ³ /s	H/L	Dia m (")	d m	Full Cap. m ³ /s	Q max m ³ /s	% full	V m/s
1	MH1	MH2	40	0.856	0.025	.6 (24")	0.41	1.05	1.13	68.79	4.15
2	EMH	MH3	6	0.255	0.038	.375 (15")	0.23	0.36	0.38	63.31	3.62
3	MH3	MH4	32	0.255	0.038	.375 (15")	0.23	0.36	0.38	63.31	3.62
4	MH4	MH2	32	0.255	0.038	.375 (15")	0.23	0.36	0.38	63.31	3.62
5	MH2	MH5	14	1.111	0.025	.6 (24")	0.53	1.05	1.13	88.27	4.20
6	MH5	MH6	31	1.111	0.025	.6 (24")	0.53	1.05	1.13	88.27	4.20
7	MH6	MH7	30	1.111	0.050	.6 (24")	0.39	1.49	1.60	64.42	5.77
8	MH7	MH8	23	1.111	0.050	.6 (24")	0.39	1.49	1.60	64.42	5.77
9	MH8	MH9	52	1.111	0.050	.6 (24")	0.39	1.49	1.60	64.42	5.77
10	MH9	MH10	52	1.111	0.050	.6 (24")	0.39	1.49	1.60	64.42	5.77
11	MH10	MH11	47	1.111	0.050	.6 (24")	0.39	1.49	1.60	64.42	5.77
12	MH11	Outfall	116	1.111	0.019	.75 (30")	0.45	1.65	1.78	59.99	4.81

Scenario 2 - R3 Reservoir Overflowing

Design Flow : MH1 - MH2 = 74,000 m³/day = .856 m³/s

: EMH - MH3 - MH4 - MH2 = No Flow

: MH2 - Outfall = 74,000 m³/day = 0.856 m³/s

Manning N for RCC Hume Pipes : 0.012

Segment No.	From MH	To MH	Length m	Flow m ³ /s	H/L	Dia m (")	d m	Full Cap. m ³ /s	Q max m ³ /s	% full	V m/s
1	MH1	MH2	40	0.856	0.025	.6 (24")	0.41	1.05	1.13	68.55	4.15
2	EMH	MH3	6		0.038	.375 (15")					
3	MH3	MH4	32		0.038	.375 (15")					
4	MH4	MH2	32		0.038	.375 (15")					
5	MH2	MH5	14	0.856	0.025	.6 (24")	0.41	1.05	1.13	68.55	4.15
6	MH5	MH6	31	0.856	0.025	.6 (24")	0.41	1.05	1.13	68.55	4.15
7	MH6	MH7	30	0.856	0.050	.6 (24")	0.33	1.49	1.60	54.58	5.45
8	MH7	MH8	23	0.856	0.050	.6 (24")	0.33	1.49	1.60	54.58	5.45
9	MH8	MH9	52	0.856	0.050	.6 (24")	0.33	1.49	1.60	54.58	5.45
10	MH9	MH10	52	0.856	0.050	.6 (24")	0.33	1.49	1.60	54.58	5.45
11	MH10	MH11	47	0.856	0.050	.6 (24")	0.33	1.49	1.60	54.58	5.45
12	MH11	Outfall	116	0.856	0.019	.75 (30")	0.46	0.91	0.98	77.31	3.67

Scenario 3 - R2 Reservoir Overflowing

Design Flow : MH1 - MH2 = No Flow

: EMH - MH3 - MH4 - MH2 = 22,000 m³/day = .255 m³/s

: MH2 - Outfall = 22,000 m³/day = .255 m³/s


Manning N for RCC Hume Pipes : 0.012

Segment No.	From MH	To MH	Length m	Flow m ³ /s	H/L	Dia m(")	d m	Full Cap. m ³ /s	Q max m ³ /s	% full	V m/s
1	MH1	MH2	40		0.025	.6 (24")					
2	EMH	MH3	6	0.255	0.038	.375 (15")	0.23	0.36	0.38	63.31	3.62
3	MH3	MH4	32	0.255	0.038	.375 (15")	0.23	0.36	0.38	63.31	3.62
4	MH4	MH2	32	0.255	0.038	.375 (15")	0.23	0.36	0.38	63.31	3.62
5	MH2	MH5	14	0.255	0.025	.6 (24")	0.20	1.05	1.13	33.54	3.07
6	MH5	MH6	31	0.255	0.025	.6 (24")	0.20	1.05	1.13	33.54	3.07
7	MH6	MH7	30	0.255	0.050	.6 (24")	0.17	1.49	1.60	27.74	3.91
8	MH7	MH8	23	0.255	0.050	.6 (24")	0.17	1.49	1.60	27.74	3.91
9	MH8	MH9	52	0.255	0.050	.6 (24")	0.17	1.49	1.60	27.74	3.91
10	MH9	MH10	52	0.255	0.050	.6 (24")	0.17	1.49	1.60	27.74	3.91
11	MH10	MH11	47	0.255	0.050	.6 (24")	0.17	1.49	1.60	27.74	3.91
12	MH11	Outfall	116	0.255	0.019	.75 (30")	0.20	1.65	1.78	26.29	2.70

Summary of Pipe Lengths

- .275 (15") = 70 m
- .6 (24") = 289 m
- .75 (30") = 116 m
- Total = 475 m

**MALIGAKANDA RESERVOIR SITE –
INLET / OUTLET SIZING**



⊕	butterfly valve, open	
⊗	butterfly valve, closed	to be abandoned
⊠	gate valve, open	----- existing main
⊡	gate valve, closed	————— new main
○	flow meter	m005 meter number

Figure 2-7 Maligakanda Reservoir - piping schematic for single tank option
 overflow and washout drains not shown for clarity

note: two circular reservoirs in operation and old rectangular reservoir closed

NODE						
NO	Type	Q l/sec	WL m	GL m	EH m	
3	0		29.37		17.00	12.37
4	0		29.37		17.00	12.37
5	0		29.37		17.00	12.37
6	0		29.38		17.00	12.38
7	0		29.38		17.00	12.38
8	1	-1571.891	29.90			29.90
9	1	-468.109	29.90			29.90
10	0		29.83	19.00		10.83
11	0		29.38	17.00		12.38
12	0		29.38	17.00		12.38
13	0	71.000	28.89	19.00		9.89
14	0		29.38	17.00		12.38
15	0	372.000	29.33	19.00		10.33
16	0	230.000	25.09	17.00		8.09
17	0	364.000	29.03	17.00		12.03
18	0	336.000	29.08	17.00		12.08
19	0	667.000	29.15	17.00		12.15

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
3	4	1000	2		120	-230.00	-0.29	-0.10	
4	5	1000	2		120	-594.00	-0.76	-0.58	
5	6	1000	2		120	-930.00	-1.18	-1.33	
6	7	1000	1		120	-1597.00	-2.03	-3.61	
7	8	800	50		120	-1571.89	-3.13	-10.40	
9	10	760	50		120	468.11	1.03	1.42	
7	11	1000	2		120	-25.11	-0.03	0.00	
10	11	600	100		120	468.11	1.66	4.49	
11	12	1000	2		120	443.00	0.56	0.34	
12	13	250	50		120	71.00	1.45	9.74	
12	14	1000	2		120	372.00	0.47	0.24	
14	15	760	50		120	372.00	0.82	0.93	
3	16	250	50		120	230.00	4.69	85.65	
4	17	500	50		120	364.00	1.85	6.85	
5	18	500	50		120	336.00	1.71	5.91	
6	19	685	50		120	667.00	1.81	4.53	

End

8 4,550 36,400 0.421 1.1 0.463

Note: 3 reservoirs in operation

NODE					
NO	Type	Q l/sec	WL m	GL m	EH m
1	1	-1232.423	29.90		29.90
2	0		29.81	17.00	12.81
3	0		29.81	17.00	12.81
4	0		29.81	17.00	12.81
5	0		29.80	17.00	12.80
6	0		29.80	17.00	12.80
7	0		29.81	17.00	12.81
8	1	-622.062	29.90		29.90
9	1	-185.515	29.90		29.90
10	0		29.89	19.00	10.89
11	0		29.81	17.00	12.81
12	0		29.81	17.00	12.81
13	0	71.000	29.32	19.00	10.32
14	0		29.81	17.00	12.81
15	0	372.000	29.76	19.00	10.76
16	0	230.000	25.53	17.00	8.53
17	0	364.000	29.46	17.00	12.46
18	0	336.000	29.51	17.00	12.51
19	0	667.000	29.58	17.00	12.58

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	1000	40		120	1232.42	1.57	2.24	
2	3	1000	1		120	1232.42	1.57	2.24	
3	4	1000	2		120	1002.42	1.28	1.53	
3	16	250	50		120	230.00	4.69	85.65	
4	5	1000	2		120	638.42	0.81	0.66	
4	17	500	50		120	364.00	1.85	6.85	
5	6	1000	2		120	302.42	0.39	0.17	
5	18	500	50		120	336.00	1.71	5.91	
6	7	600	1		120	-364.58	-1.29	-2.83	
6	19	685	50		120	667.00	1.81	4.53	
7	8	800	50		120	-622.06	-1.24	-1.87	
7	11	1000	2		120	257.49	0.33	0.12	
9	10	760	50		120	185.51	0.41	0.26	
10	11	600	100		120	185.51	0.66	0.81	
11	12	1000	2		120	443.00	0.56	0.34	
12	13	250	50		120	71.00	1.45	9.74	
12	14	1000	2		120	372.00	0.47	0.24	
14	15	760	50		120	372.00	0.82	0.93	

End

8

4,550

36,400

0.421

1.1

0.463

Flows used in the hydraulic model for Maligakanda

A	maximum day supply (ultimate)	1275 l/s
B	maximum day demand (supply x 1.6)	2040 l/s

Node no.	D Measured Flow liter/s	(B/C x D) Estimated future flow liter/s
13 10" to mount mary	55	71
15 30" to Borella	289	372
16 10" to Dematagoda	179	230
17 20" to Fort	283	364
18 20" to Kirulapone	261	336
19 27" to San Sebastien	518	667
C	total	1585
		2040

**ELLIE HOUSE RESERVOIR SITE –
GRAVITY DRAIN FOR OVERFLOW / WASHOUT**

Design of Overflow / washout pipe for Ellie House Reservoir

For overflowing Rate

A. From Manhole 1 to Manhole 2

Elevation at overflow vier	=	27.85
Elevation at First manhole	=	21.61
Distance	=	42 m
Hydraulic Gradient	=	$\frac{27.85 - 21.61}{42} = \frac{6.24}{42} = 1.486$

Rate of flow = $\frac{2}{3} \times 110,000 \text{ m}^3/\text{d} = 73,333 \text{ m}^3/\text{d} = 0.849 \text{ m}^3/\text{s}$

D= 500 mm n = 0.012

Solve for Actual Depth

D = 0.50 m S = 0.1486 n = 0.012 q = 0.849

D = 0.26 m Velocity = 8.18 m/s % Full = 52.38%
 Full capacity = 1.58 cum/s QMax = 1.70 cum/s

B. From Manhole 2 to Existing washout

Elevation at overflow view	=	27.85
Elevation at connection to existing overflow / washout	=	21.00
Distance	=	137 m

Hydraulic gradient = $\frac{27.85 - 21.00}{137} = 0.185$

Rate of flow = $110,000 \text{ m}^3/\text{d} = 1.273 \text{ m}^3/\text{s}$

Valve for actual Depth

D = 0.60 S = 0.185 n = 0.012 Q = 1.273 m³/s

d = 0.31 V = 9.76 m/s % full = 62.96 %
 Full capacity = 1.76 m³/s Q max = 1.89 m³/s

2. Washout Rates Through Overflow / Washout System

C. From Manhole 1 to Manhole 2

Elevation of pipe at MH 1	=	22.10
Elevation of pipe at MH 2	=	21.61
Drop	=	0.49
Distance	=	42 m
S	=	0.01167

Solve for Full Flow capacity

$$d = 0.5 \text{ m} \quad S = .01167 \quad N = .012 \quad Q = 0.44 \text{ cum/s}$$

$$Q_{\text{max}} = 0.48 \text{ cum/s} = 41,472 \text{ m}^3/\text{d}$$

D. From manhole 2 to Existing Washout

$$\text{Elevation at MH 2} = 21.61$$

$$\text{Elevation at MH 3} = 19.84$$

$$\text{Drop} = 1.77$$

$$\text{Distance} = 137$$

$$S = 0.0129$$

Solve for Full Flow capacity


$$D = 0.6 \text{ m} \quad S = .0129 \quad N = 0.12 \quad Q = 0.76 \text{ cum/s}$$

$$Q_{\text{Max}} = 0.81 \text{ cum/s} = 69,984 \text{ m}^3/\text{d}$$

Therefore the designed overflow/ washout system can safely discharge the maximum designed overflow rate of 110,000 m³/d.

The system can also safely discharge a washout rate of 41,472 m³/d.

**ELLIE HOUSE RESERVOIR SITE –
INLET / OUTLET SIZING**



New Elie House Reservoir Schematic Diagram - Stage 8 inlet channels restored
 overflow and washout drains not shown for clarity

note: three cells in parallel operation

NODE						
NO	Type	Q l/sec	WL m	GL m		EH m
1	1	-114.472	28.45		22.50	5.95
2	0		28.45		22.50	5.95
3	1	-187.847	28.45		22.50	5.95
4	0		28.45		22.50	5.95
5	1	-1737.681	28.45		22.50	5.95
6	0		28.44		22.50	5.94
7	0		28.07		22.50	5.57
8	0		28.05		22.50	5.55
9	0		28.04		22.50	5.54
10	0		28.03		22.50	5.53
11	0		28.02		22.50	5.52
12	0		28.02		22.50	5.52
13	0		28.02		22.50	5.52
14	0	330.000	27.49		20.00	7.49
15	0	330.000	27.48		20.00	7.48
16	0	180.000	24.83		20.00	4.83
17	0	400.000	27.54		20.00	7.54
18	0	600.000	27.96		20.00	7.96
19	0	200.000	26.42		20.00	6.42

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	1000	2	110		114.47	0.15	0.03	
3	4	1000	2	110		187.85	0.24	0.08	
5	6	1000	2	110		1737.68	2.21	4.96	
2	4	1000	3	110		114.47	0.15	0.03	
4	6	1000	50	110		302.32	0.38	0.20	
6	7	1000	55	110		2040.00	2.60	6.67	
7	8	1000	3	110		2040.00	2.60	6.67	
8	9	1000	3	110		1710.00	2.18	4.81	
9	10	1000	3	110		1380.00	1.76	3.24	
10	11	1000	3	110		1200.00	1.53	2.50	
11	12	1000	3	110		800.00	1.02	1.18	
12	13	1000	3	110		600.00	0.76	0.69	
8	14	450	50	110		330.00	2.07	11.21	
9	15	450	50	110		330.00	2.07	11.21	
10	16	250	50	110		180.00	3.67	63.93	
11	17	500	50	110		400.00	2.04	9.58	
12	19	300	50	110		200.00	2.83	31.97	
13	18	900	50	110		600.00	0.94	1.16	


End

8 4.550 36,400 0.421 1.1 0.463

Flows used in the hydraulic model for Ellie House			
A	maximum day supply (ultimate)		1275 l/s
B	maximum day demand (ultimate supply x 1.6)		2040 l/s
		D (B/C x D)	
Node		Measured	Estimated future flow
no.		liter/s	liter/s
15	18" to Fort	232	330
16	18" to Walls lane	233	330
17	10" to Kotahena	82	180
18	20" to Mattakulliya	-	400
19	36" to Walls lane	74	600
20	12" to Mutawal	73	200
C	total	694	2,040

**GOTHATUWA – KOLONNAWA PUMP HOUSE
- CLEAR WELL OPERATING LEVELS**

SUMP LEVELS YEAR 2020 (Peak Flow Condition)



Total losses 1-3-7 = 1.173 m
 Minimum operating water level = 10.8-1.203 = 9.627 m

Top water level is set as same level as the Clear Water Reservoir of Ambatale New Water Treatment Plant at 13.9 m MSL, to cater for the condition when clear water reservoir is full and the outflow is zero (stopping of all pumps). An allowance of 350 mm is included to cater for changes in fittings etc. and the Low water level is set at 9.28 m MSL. Similarly, maximum operating level in year 2020 is 12.38 m MSL

Pipe	Node (u)	Node (d)	Losses	Loss Coefficient k	Number	Flow m ³ /s	Velocity m/s	Head Loss kV ² /2g
200	1	2	1000 mm ND 45° bend	neglect 0.4	2	2.54	3.24	0.428
300	2	3	1200 mm ND 45° bend	0.4	2	2.54	2.25	0.260 0.206
700	3	7	1200 mm ND T for Qa/Q = 0.7/3.43 Butterfly valve 45° bend	neglect 0.25 0.4	1 1 2	0.7 0.7 0.7	2.25 0.62 0.62	0.26 0.005 0.016

NODE

NO	Type	Q l/sec	WL m	GL m	EH m
1	1	-2543.000	10.80	11.00	-0.20
2	0	0.000	10.76	11.00	-0.24
3	0	0.000	10.59	11.00	-0.41
4	0	0.000	10.55	11.00	-0.45
5	0	1423.000	10.51	11.00	-0.49
6	0	420.000	10.55	9.00	1.55
7	0	700.000	10.59	7.50	3.09

1.000

PIPE

	NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo
200	1	2	1000	6	130	0.00	2543.00	3.24	7.36
300	2	3	1200	55	130		2543.00	2.25	3.03
	3	4	1200	21	130		1843.00	1.63	1.67
700	3	7	1200	10	130		700.00	0.62	0.28
	4	6	1200	10	130		420.00	0.37	0.11
	4	5	1200	40	130		1423.00	1.26	1.04

End

**GOTHATUWA TRANSMISSION MAIN –
HYDRAULIC ANALYSIS DURING NORMAL
OPERATION**

Pumping to Gothatuwa and Kolonnawa Ground Reservoirs

NODE Year 2020

NO	Type	Q l/sec	WL m	GL m	EH m
1	1	-700.100	9.28		2.28
2	0	0.000	50.49		39.49
3	0	0.000	43.54		25.54
4	0	357.800	29.35		3.10
5	0	342.300	25.20		0.00

R1 6.95 m Hospital Junction
R2 18.34 m Kolonnawa GR
R3 14.19 m Gothatuwa GR

PIPE

NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	41.24	700.10	1.39	2.73
2	3	800	2541		110		700.10	1.39	2.73
3	4	500	1821		110		357.80	1.82	7.79
3	5	600	6207		110		342.30	1.21	2.95

End

NODE Year 2015

NO	Type	Q l/sec	WL m	GL m	EH m
1	1	-662.300	9.28		2.28
2	0	0.000	50.49		39.49
3	0	0.000	44.22		26.22
4	0	320.000	32.68		6.43
5	0	342.300	25.88		0.68

R1 6.27 m Hospital Junction
R2 18.34 m Kolonnawa GR
R3 11.54 m Gothatuwa GR

PIPE

NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	41.24	662.30	1.32	2.47
2	3	800	2541		110		662.30	1.32	2.47
3	4	500	1821		110		320.00	1.63	6.34
3	5	600	6207		110		342.30	1.21	2.95

End

NODE Year 2010

NO	Type	Q l/sec	WL m	GL m	EH m
1	1	-501.500	9.28		2.28
2	0	0.000	39.34		28.34
3	0	0.000	35.60		17.60
4	0	285.500	26.25		0.00
5	0	216.000	27.77		2.57

R1 3.75 m Hospital Junction
R2 7.82 m Kolonnawa GR
R3 9.35 m Gothatuwa GR

PIPE

NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	30.08	501.50	1.00	1.48
2	3	800	2541		110		501.50	1.00	1.48
3	4	500	1821		110		285.50	1.45	5.13
3	5	600	6207		110		216.00	0.76	1.26

End

NODE Year 2005

NO	Type	Q l/sec	WL m	GL m	EH m
1	1	-371.000	9.28		2.28
2	0	0.000	35.98		24.98
3	0	0.000	33.83		15.83
4	0	255.000	26.25		0.00
5	0	116.000	31.36		6.16

R1 2.15 m Hospital Junction
R2 2.48 m Kolonnawa GR
R3 7.58 m Gothatuwa GR

PIPE

NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	26.71	371.00	0.74	0.84
2	3	800	2541		110		371.00	0.74	0.84
3	4	500	1821		110		255.00	1.30	4.16
3	5	600	6207		110		116.00	0.41	0.40

End

Note:

Q Flowrate
C Hazen-William Coefficient
WL Water Level
GL Ground Level

EH Effective Head
dH Pumping Head
V Velocity
I Friction Gradient

R1, R2 and R3 are friction losses in common main (800 mm), branch to Kolonnawa Ground Reservoir (600 mm) and branch to Gothatuwa Ground Reservoir (500 mm).

Pumping to Kolonnawa Ground Reservoir Only

NODE		Year 2020		Kolonnawa Only			
NO	Type	Q l/sec	WL m	GL m	EH m		
1	1	-342.300	9.28		7.00		2.28
2	0	0.000	50.51		11.00		39.51
3	0	0.000	48.66		18.00		30.66
4	0	342.300	30.32		25.20		5.12

R1 1.85 m Hospital Junction
R2 18.34 m Kolonnawa GR

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	41.24	342.30	0.68	0.73
2	3	800	2541		110		342.30	0.68	0.73
3	4	600	6207		110		342.30	1.21	2.95

End

NODE		Year 2015		Kolonnawa Only			
NO	Type	Q l/sec	WL m	GL m	EH m		
1	1	-342.300	9.28		7.00		2.28
2	0	0.000	50.51		11.00		39.51
3	0	0.000	48.66		18.00		30.66
4	0	342.300	30.32		25.20		5.12

R1 1.85 Hospital Junction
R2 18.34 Kolonnawa GR

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	41.24	342.30	0.68	0.73
2	3	800	2541		110		342.30	0.68	0.73
3	4	600	6207		110		342.30	1.21	2.95

End

NODE		Year 2010		Kolonnawa Only			
NO	Type	Q l/sec	WL m	GL m	EH m		
1	1	-216.000	9.28		7.00		2.28
2	0	0.000	39.36		11.00		28.36
3	0	0.000	38.57		18.00		20.57
4	0	216.000	30.74		25.20		5.54

R1 0.79 Hospital Junction
R2 7.82 Kolonnawa GR

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	30.08	216.00	0.43	0.31
2	3	800	2541		110		216.00	0.43	0.31
3	4	600	6207		110		216.00	0.76	1.26

End

NODE		Year 2005		Kolonnawa Only			
NO	Type	Q l/sec	WL m	GL m	EH m		
1	1	-116.000	9.28		7.00		2.28
2	0	0.000	39.36		11.00		28.36
3	0	0.000	39.11		18.00		21.11
4	0	116.000	36.63		25.20		11.43

R1 0.25 Hospital Junction
R2 2.48 Kolonnawa GR

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	30.08	116.00	0.23	0.10
2	3	800	2541		110		116.00	0.23	0.10
3	4	600	6207		110		116.00	0.41	0.40

End

Note: Q Flowrate EH Effective Head
C Hazen-William Coefficient dH Pumping Head
WL Water Level V Velocity
GL Ground Level I Friction Gradient
R1, R2 and R3 are friction losses in common main (800 mm), branch to Kolonnawa Ground Reservoir (600 mm) and branch to Gothatuwa Ground Reservoir (500 mm).

Pumping to Gothatuwa Ground Reservoir Only

NODE		Year 2020		Pumping to Gothatuwa only			
NO	Type	Q l/sec	WL m	GL m		EH m	
1	1	-357.800	9.28			7.00	2.28
2	0	0.000	50.51			11.00	39.51
3	0	0.000	48.50			18.00	30.50
4	0	357.800	34.31			26.25	8.06

R1 2.01 Hospital Junction
R3 14.19 Gothatuwa GR

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	41.24	357.80	0.71	0.79
2	3	800	2541		110		357.80	0.71	0.79
3	4	500	1821		110		357.80	1.82	7.79

End

NODE		Year 2015		Pumping to Gothatuwa only			
NO	Type	Q l/sec	WL m	GL m		EH m	
1	1	-320.000	9.28			7.00	2.28
2	0	0.000	50.51			11.00	39.51
3	0	0.000	48.88			18.00	30.88
4	0	320.000	37.34			26.25	11.09

R1 1.63 Hospital Junction
R3 11.54 Gothatuwa GR

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	41.24	320.00	0.64	0.64
2	3	800	2541		110		320.00	0.64	0.64
3	4	500	1821		110		320.00	1.63	6.34

End

NODE		Year 2010		Pumping to Gothatuwa only			
NO	Type	Q l/sec	WL m	GL m		EH m	
1	1	-285.500	9.28			7.00	2.28
2	0	0.000	39.35			11.00	28.35
3	0	0.000	38.03			18.00	20.03
4	0	285.500	28.69			26.25	2.44

R1 1.32 Hospital Junction
R3 9.35 Gothatuwa GR

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	30.08	285.50	0.57	0.52
2	3	800	2541		110		285.50	0.57	0.52
3	4	500	1821		110		285.50	1.45	5.13

End

NODE		Year 2005		Pumping to Gothatuwa only			
NO	Type	Q l/sec	WL m	GL m		EH m	
1	1	-255.000	9.28			7.00	2.28
2	0	0.000	39.36			11.00	28.36
3	0	0.000	38.28			18.00	20.28
4	0	255.000	30.70			26.25	4.45


R1 1.07 Hospital Junction
R3 7.58 Gothatuwa GR

PIPE									
NO(u)	NO(d)	Dia mm	Length m	C	dH m	Q l/sec	V m/sec	I o/oo	
1	2	800	11		110	30.08	255.00	0.51	0.42
2	3	800	2541		110		255.00	0.51	0.42
3	4	500	1821		110		255.00	1.30	4.16

End

Note: Q Flowrate
C Hazen-William Coefficient
WL Water Level
GL Ground Level
EH Effective Head
dH Pumping Head
V Velocity
I Friction Gradient
R1, R2 and R3 are friction losses in common main (800 mm), branch to Kolonnawa Ground Reservoir (600 mm) and branch to Gothatuwa Ground Reservoir (500 mm).

System Head Curves



Pumping to Gothatuwa and Kolonnawa

Item	Unit	2005	2010	2015	2020
Quantity of water transmission					
Flow required at Gothatuwa	L/s	255.0	285.5	320.0	357.8
Flow required at Kolonnawa	L/s	118.0	216.0	342.3	342.3
Total flow required	L/s	371.0	501.5	662.3	700.1
Friction loss in pipeline					
Gothatuwa-Kolonnawa Pump House - Hospital Junction R1	m	2.15	3.75	6.27	6.95
Hospital Junction - Kolonnawa GR	m	2.48	7.62	18.34	18.34
Hospital Junction - Gothatuwa GR	m	7.58	9.35	11.54	14.19
Effective friction loss	m	9.73	13.10	24.61	25.29
Static Head					
Gothatuwa-Kolonnawa Pump House Sump	m	9.28	9.28	9.28	9.28
Gothatuwa GR	m	12.38	12.38	12.38	12.38
New Kolonnawa GR	m	26.25	26.25	26.25	26.25
Maximum Static Head	m	23.75	23.75	23.75	23.75
Gothatuwa-Kolonnawa Pump House Sump - Gothatuwa GR	m	25.20	25.20	25.20	25.20
Gothatuwa-Kolonnawa Pump House Sump - New Kolonnawa GR	m	23.75	23.75	23.75	23.75
Minimum Static Head	m	16.97	16.97	16.97	16.97
Gothatuwa-Kolonnawa Pump House Sump - Gothatuwa GR	m	15.92	15.92	15.92	15.92
Gothatuwa-Kolonnawa Pump House Sump - New Kolonnawa GR	m	11.37	11.37	11.37	11.37
Effective static head	m	11.37	11.37	11.37	11.37
Other Losses					
Around the pump	m	2.0	2.0	2.0	2.0
Effective friction loss	m	9.73	13.10	24.61	25.29
System Head Characteristics					
Total pumping head required	m	28.70	32.07	43.58	44.28
Total flow	m³/min	23.60	26.97	38.48	39.16
Flow to Gothatuwa GR	m³/min	22.26	30.09	39.74	42.01
Flow to New Kolonnawa GR	m³/min	15.30	17.13	19.20	21.47
Total Head Loss from Ambattele to Gothatuwa GR	m	28.70	32.07	36.78	40.11
Total Head Loss from Ambattele to Kolonnawa GR	m	6.96	12.96	20.54	20.54

Pumping to Gothatuwa only


System Head Characteristics	Unit	2005	2010	2015	2020
Total pumping head required	m	27.62	29.64	32.14	35.17
Total flow	m³/min	22.02	24.04	26.54	29.57


Pumping to Kolonnawa only

System Head Characteristics	Unit	2005	2010	2015	2020
Total pumping head required	m	20.65	26.54	38.11	38.11
Total flow	m³/min	16.60	22.49	34.06	34.06

Note: Pumping head requirements are governed by Kolonnawa facilities which are at planning stage and are based on the data provided by NWSDB.

FIG. 3-10 System Head Curves for Pumping to Gothatuwa and Kolonnawa
SCALE: Not to scale
JICA STUDY TEAM
THE DETAILED DESIGN STUDY ON THE PROJECT FOR REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA IN THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA




	A	B	C	D	E	F	G	H	I	J
1	 CEYWATER	PROJECT:- Gotathuwa Kolonnawa							Job No	
2		Water Supply							Des. By	AP
3		COMPONENT:- Detailed Design of the							Checked	
4		Transmission System							Date	Sep-00

Design Flows

As per water demand projections for Gotathuwa and Kolonnawa, the required pumping rates in l/s are as follows:


		2005	2010	2015	2020
12	Gotathuwa	255.0	285.5	320.0	357.8
13	Kolonnawa	116.0	216.0	342.3	342.3
14	Total	371.0	501.5	662.3	700.1


The increase of demand with time is graphically represented in the following chart.




As extrapolated from the above curves projected yearly design flows(l/s) are tabulated as follows:

		<u>2005</u>	<u>2006</u>	<u>2007</u>	<u>2008</u>	<u>2009</u>	<u>2010</u>	<u>2011</u>	<u>2012</u>	<u>2013</u>
45	Gotathuwa	255	260	265	275	280	286	295	300	305
46	Kolonnawa	116	135	155	175	195	216	240	275	300
47	Total	371	395	420	450	475	502	535	575	605
49		<u>2014</u>	<u>2015</u>	<u>2016</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>	<u>2020</u>		
50	Gotathuwa	315	320	325	335	340	350	358		
51	Kolonnawa	322	342	342	342	342	342	342		
52	Total	637	662	667	677	682	692	700		

	A	B	C	D	E	F	G	H	I	J
1		CEYWATER	PROJECT:- Gotathuwa Kolonnawa						Job No	
2			Water Supply						Des. By	AP
3			COMPONENT:- Detailed Design of the						Checked	
4			Transmission System						Date	Sep-00
57	Design Approach									
58										
59	An economic analysis, taking into account such factors as estimated pumping head, energy consumption									
60	capital and O & M costs for varying pipeline sizes were performed using "Present Worth" technique.									
61	The result of this analysis revealed the following sizing for the proposed transmission system:									
62										
63	From Ambatale WTP up to the hospital junction :-						800 mm dia DI with L=	2510		
64	From the hospital junction up to Gotathuwa reservoir site :-						500 mm Dia DI with L=	1765		
65	From the hospital junction up to Kolonnawa reservoir site :-						600 mm Dia DI with L=	6151		
66										
67	Based on this result, a transmission model was developed indicating the geometric and hydraulic									
68	properties of the system including node numbers, pipe numbers, node elevations, minor loss coefficient									
69	for each of the pipes and reservoir data. A basic data file was then set up to suit the KYPIPE computer									
70	program for hydraulic analysis of pipe networks developed by the University of Kentucky, USA.									
71	Flow control devices are introduced at inlets of both Gotathuwa and Kolonnawa reservoirs.									
72	Frictional head losses are calculated using Hazen William equation by adopting a C value of 110. The									
73	minor loss coefficient of specials in respect of each pipe is assumed to be included within the overall									
74	frictional head loss of the pipeline.									
75										
76	Because of the fact that Gotathuwa and Kolonnawa pipeline routes widely differ in length, it is rather									
77	difficult to achieve perfect hydraulic balance. Hence, it is inevitable that flows to Gotathuwa and									
78	Kolonnawa need precise control in order to receive the correct quantity of water under all conditions.									
79										
80	Based on this concept two system curves were developed using the KYPIPE program, one for the									
81	maximum static head and the other for the minimum static head. The results are summarised as follows:									
82										
83	<u>Year</u>	<u>2005</u>	<u>2010</u>	<u>2015</u>	<u>2020</u>					
84	Flow to G	255.0	285.5	320.0	357.8	l/s				
85	Flow to K	116.0	216.0	342.3	342.3	l/s				
86	Total flow	371.0	501.5	662.3	700.1	l/s				
87	TDH(max)	24.35	30.3	43.35	45.71	m				
88	TDH(min)	22.89	28.87	41.48	43.73	m				
89										
90	Eight (8) computer runs were executed in developing the system curves.									
91										
92	The system curves are graphically depicted below.									
93										
94										
95										
96										
97										
98										
99										
100										
101										
102										
103										
104										
105										
106										
107										
108										

	A	B	C	D	E	F	G	H	I	J
1	 CEYWATER			PROJECT:- Gotathuwa Kolonnawa Water Supply					Job No	
2									COMPONENT:- Detailed Design of the Transmission System	
3				Checked						
4				Date	Sep-00					



CASE 1 : 2010 to 2020


The details of the pump that would best fit into the above system curves are as given below:


139	Make	: Weir
140	Type	: Horizontal split casing
141	Model	: SDB 250/300B
142	Speed	: 1480 rpm
143	Max WP	: 12 bar
144	Motor	: 165 kW

For the ultimate demand during the year 2020, 3 pumps (in parallel operation) will be required.

The pump characteristics (as extracted from manufacturer's catalogue) superimposed with the system curves are indicated below:

Flow l/s	Pump Curves			Eff. %	TDH	
	1 pump	2 pump	3 pumps		max	min
0	61					
100	57			68		
200	49	57		88		
300	38.5	53	57	74	21	20
400		49	55	53	25.5	24
500		44	52		30	29
600		38.5	49		38	36.5
700		33	45.71		45.71	43.73
800						

1	 CEYWATER	PROJECT:- Gotathuwa Kolonnawa Water Supply						Job No	
2		COMPONENT:- Detailed Design of the Transmission System						Des. By	AP
3								Checked	
4								Date	Sep-00




186 It is seen from the above curves that the most desirable operating range of the pump lies between
187 $Q = 150$ l/s and 250 l/s which corresponds with H values of 44 m and 54 m respectively.


188 This operating range corresponds with maximum efficiency varying between 75% and 88% .


190 Computer printout of the results output file relating to 2020 flow condition is annexed together with a
191 schematic of the transmission model.

193 A number of computer runs were executed to determine the pump duty points when pumping water to
194 any single location under 2020, 2015 and 2010 flow conditions. The results are summarised as follows:

196	Design	Point of	Nr of duty	Q l/s per	H m	Q (Got)	Q (Kol)	Q (Total)	Hf (Got)	Hf (Kol)
197	Horizon	Supply	Pumps	pump						
198	2020	G & K	3	233.37	45.74	357.8	342.3	700.11	5.44	1.44
199		G only	3	119.22	55.6	357.8	-	357.66	21.98	
200		G only	2	178.9	50.89	357.8	-	357.8	17.15	
201		K only	3	114.1	55.96		342.3	342.3		19.46
202		K only	2	171.15	51.56		342.3	342.3		14.95
203	2015	G & K	3	220.77	47	320	342.3	662.31	10.25	4.53
204		G only	3	106.67	56.46	320		320.01	25.96	
205		G only	2	160	52.49	320		320	21.9	
206		K only	3	114.1	55.96		342.3	342.3		19.46
207		K only	2	171.51	51.56		342.3	343.02		14.95
208	2010	G & K	2	250.75	43.95	285.5		501.5	12.56	15.1
209		G only	2	142.75	53.87	285.5		285.5	25.88	
210		G only	1	285.5	40.16	285.5		285.5	11.76	
211		K only	2	108	56.37		216	216		31.65
212		K only	1	216	47.46		216	216		22.18

	A	B	C	D	E	F	G	H	I	J
1		CEYWATER	PROJECT:- Gotathuwa Kolonnawa						Job No	
2			Water Supply						Des. By	AP
3			COMPONENT:- Detailed Design of the						Checked	
4			Transmission System						Date	Sep-00
213										
214	The highlighted rows represent the recommended operating modes. It is important to maintain precise									
215	flow control at both Gotathuwa and Kolonnawa. The estimated headloss at each flow control device									
216	is indicated in m water head.									
217										
218	As evident from the above results it is important to maintain a pump discharge head between 44 m and									
219	54 m when operating the pumps under various flow conditions. This could be achieved either by using									
220	variable speed pumps or by changing the number of pumps working in parallel. For example, when three									
221	pumps are working in parallel, if suddenly the manometric head increases beyond 52 m, the operator									
222	should immediately switch off one pump in order to keep the pressure below 52 m limit.									
223										
224	Motor Horse Power:-									
225	Required horse power of the motor is given by:									
226	$P = (Q \times H \times g) / (n \times 1000)$									
227	where	P = Horse Power in kW								
228		Q = Flow in l/s								
229		H = Manometric Head in m								
230		n1 = pump efficiency								
231		n2 = motor excess								
232										
233	Considering the 2020 situation with 3 pumps in parallel, the required total power is computed as follows:									
234										
235		Q =	700.1							
236		H =	45.71							
237		g =	9.797							
238		n1 =	0.8							
239		n2 =	1.25							
240										
241	Therefore	P =	489.874							
242										
243	Hence, required horse power of the motor = 163.2913 kW									
244										
245	Provide a motor of capacity = 165 kW									
246										
247	CASE 2 : 2010 to 2020									
248										
249	The results of the computer runs reveal the following system curves.									
250										
251	Year	2005	2006	2007	2008	2009	2010			
252	Flow to G	255.0	260.0	265.0	275.0	280	286			
253	Flow to K	116.0	135.0	155.0	175.0	195	216			
254	Total flow	371.0	395.0	420.0	450.0	475	502			
255	TDH(max)	24.35	25.41	26.18	27.79	29.33	31.02			
256	TDH(min)	22.89	23.95	24.72	26.33	27.87	28.87			
257										
258										
259										
260										
261										
262										
263										
264										

1	 CEYWATER	PROJECT:- Gotathuwa Kolonnawa Water Supply						Job No	
2								Des. By	AP
3		COMPONENT:- Detailed Design of the Transmission System						Checked	
4								Date	Sep-00




291 The same pump with a trimmed down impeller will be used during the period from 2005 to 2010.


293 For the ultimate demand during the year 2010, 2 pumps (in parallel operation) will be required.

294 The pump characteristics (as extracted from manufacturer's catalogue) superimposed with the system curves are indicated below:

Flow l/s	Head m			TDH m	
	1 pump	2 pump	Eff. %	max	min
0	47.53				
100	43.53		68		
200	35.53	43.53	88		
300	24.53	39.53	74	23	21
400		35.53	53	25.5	24
500		31.02		31.02	28.87
600		24.53		37.5	36

	A	B	C	D	E	F	G	H	I	J
1	 CEYWATER	PROJECT:- Gotathuwa Kolonnawa Water Supply							Job No	
2		COMPONENT:- Detailed Design of the Transmission System							Des. By	AP
3									Checked	
4									Date	Sep-00

317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343



344 Motor Horse Power:-

345 Required horse power of the motor is given by:

346 $P = (Q \times H \times g) / (n \times 1000)$

- 347 where P = Horse Power in kW
 348 Q = Flow in l/s
 349 H = Manometric Head in m
 350 n1 = pump efficiency
 351 n2 = motor excess

353 Considering the 2010 situation with 2 pumps in pallel, the required total power is computed as follows:

- 354
 355 Q = 502.0
 356 H = 30.5
 357 g = 9.797
 358 n1 = 0.88
 359 n2 = 1.4

360
 361 Therefore P = 238.6393

363 Hence, required horse power of the motor = 119.3197 kW

365 Although motor capacity required for the pump with trimmed impeller is only 120 kW, it is
 366 recommended to provide a motor of 165 kW so that it could continue serving after upgrading
 367 the pumps before the year 2010.

368

GOTATHUWA KOLONNAWA TRANSMISSION SYSTEM

Hydraulic Analysis

Year 2020 Situation - Three duty pumps in parallel and with flow control devices installed
At Gotathuwa and Kolonnawa Reservoirs

```

***** K Y P I P E 2 *****
* University of Kentucky Hydraulic Analysis Program *
* Distribution of Pressure and Flows in Piping Networks *
* 1000 PIPE VERSION - 1.10 (08/25/92) *
*****
    
```

DATE: 10/17/2000
TIME: 9: 8:55

INPUT DATA FILENAME ----- c:\anselm\kyp2\GKT_REV1.DAT
TABULATED OUTPUT FILENAME ----- c:\anselm\kyp2\GKT_REV1.OUT
POSTPROCESSOR RESULTS FILENAME --- c:\anselm\kyp2\GKT_REV1.RES

SUMMARY OF ORIGINAL DATA

U N I T S S P E C I F I E D

FLOWRATE = liters/second
HEAD (HGL) = meters
PRESSURE = kpa

R E G U L A T I N G V A L V E D A T A

VALVE TYPE	POSITION JUNCTION	CONTROLLED PIPE	VALVE SETTING (m or l/s)
FCV-1	12	15	357.80
FCV-1	18	22	342.30

P I P E L I N E D A T A

STATUS CODE: XX -CLOSED PIPE FG -FIXED GRADE NODE PU -PUMP LINE
CV -CHECK VALVE RV -REGULATING VALVE

PIPE NUMBER	NODE NOS. #1	NODE NOS. #2	LENGTH (m)	DIAMETER (cm)	ROUGHNESS COEFF.	MINOR LOSS COEFF.	FGN-HGL (m)
1-FG	0	1	5.0	50.0	110.00	1.79	9.28
2-PU	1	2	6.0	50.0	110.00	4.64	
3-PU	1	2	6.0	50.0	110.00	4.64	
4-PU	1	2	6.0	50.0	110.00	4.64	
5	2	3	31.0	60.0	110.00	1.65	
6	3	4	225.0	80.0	110.00	.00	
7	4	5	100.0	80.0	110.00	.00	
8	5	6	725.0	80.0	110.00	.00	
9	6	7	275.0	80.0	110.00	.00	
10	7	8	850.0	80.0	110.00	.00	
11	8	9	335.0	80.0	110.00	.00	
12	9	10	40.0	50.0	110.00	.00	
13	10	11	925.0	50.0	110.00	.00	
14	11	12	800.0	50.0	110.00	.00	
15-RV	12	20	6.0	40.0	110.00	.00	
16	9	13	927.0	60.0	110.00	.00	
17	13	14	804.0	60.0	110.00	.00	
18	14	15	2572.0	60.0	110.00	.00	
19	15	16	558.0	60.0	110.00	.00	
20	16	17	1080.0	60.0	110.00	.00	
21	17	18	210.0	60.0	110.00	.00	
22-RV	18	19	6.0	50.0	110.00	.00	
23-FG	19	0	50.0	60.0	110.00	.00	25.20
24-FG	20	0	50.0	50.0	110.00	.00	26.25

GOTATHUWA KOLONNAWA TRANSMISSION SYSTEM

Hydraulic Analysis

Year 2020 Situation - Three duty pumps in parallel and with flow control devices installed
At Gotathuwa and Kolonnawa Reservoirs

P U M P D A T A

THERE IS A PUMP IN LINE 2 DESCRIBED BY THE FOLLOWING DATA:

HEAD (m)	FLOWRATE (l/s)
61.00	.00
45.74	233.70
38.50	300.00

THERE IS A PUMP IN LINE 3 DESCRIBED BY THE FOLLOWING DATA:

HEAD (m)	FLOWRATE (l/s)
61.00	.00
45.74	233.70
38.50	300.00

THERE IS A PUMP IN LINE 4 DESCRIBED BY THE FOLLOWING DATA:

HEAD (m)	FLOWRATE (l/s)
61.00	.00
45.74	233.70
38.50	300.00

J U N C T I O N N O D E D A T A

JUNCTION NUMBER	JUNCTION TITLE	EXTERNAL DEMAND (l/s)	JUNCTION ELEVATION (m)	CONNECTING PIPES			
1		.00	8.55	1	2	3	4
2		.00	8.55	2	3	4	5
3		.00	8.55	5	6		
4		.00	16.24	6	7		
5		.00	21.48	7	8		
6		.00	5.52	8	9		
7		.00	15.95	9	10		
8		.00	6.74	10	11		
9		.00	12.83	11	12	16	
10		.00	13.70	12	13		
11		.00	1.97	13	14		
12		.00	21.73	14	15		
13		.00	18.20	16	17		
14		.00	1.40	17	18		
15		.00	11.17	18	19		
16		.00	-.22	19	20		
17		.00	22.44	20	21		
18		.00	18.63	21	22		
19		.00	18.63	22	23		
20		.00	21.73	15	24		

O U T P U T O P T I O N D A T A

OUTPUT SELECTION: ALL RESULTS ARE INCLUDED IN THE TABULATED OUTPUT

S Y S T E M C O N F I G U R A T I O N

NUMBER OF PIPES(p) = 24
 NUMBER OF JUNCTION NODES(j) = 20
 NUMBER OF PRIMARY LOOPS(l) = 2
 NUMBER OF FIXED GRADE NODES(f) = 3
 NUMBER OF SUPPLY ZONES(z) = 1

Hydraulic Analysis

Year 2020 Situation - Three duty pumps in parallel and with flow control devices installed
At Gotathuwa and Kolonnawa Reservoirs

S I M U L A T I O N R E S U L T S

THE RESULTS ARE OBTAINED AFTER 2 TRIALS WITH AN ACCURACY = .00000

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE FG -FIXED GRADE NODE PU -PUMP LINE
 CV -CHECK VALVE RV -REGULATING VALVE TK -STORAGE TANK

PIPE NUMBER	NODE NOS.		FLOWRATE (l/s)	HEAD LOSS (m)	PUMP HEAD (m)	MINOR LOSS (m)	LINE VELO. (m/s)	HL/ 1000 (m/m)
	#1	#2						
1-FG	0	1	700.10	.13	.00	1.16	3.57	26.77
2-PU	1	2	233.37	.02	45.77	.33	1.19	3.50
3-PU	1	2	233.37	.02	45.77	.33	1.19	3.50
4-PU	1	2	233.37	.02	45.77	.33	1.19	3.50
5	2	3	700.10	.34	.00	.52	2.48	11.01
6	3	4	700.10	.61	.00	.00	1.39	2.71
7	4	5	700.10	.27	.00	.00	1.39	2.71
8	5	6	700.10	1.97	.00	.00	1.39	2.71
9	6	7	700.10	.75	.00	.00	1.39	2.71
10	7	8	700.10	2.31	.00	.00	1.39	2.71
11	8	9	700.10	.91	.00	.00	1.39	2.71
12	9	10	357.80	.31	.00	.00	1.82	7.72
13	10	11	357.80	7.14	.00	.00	1.82	7.72
14	11	12	357.80	6.18	.00	.00	1.82	7.72
15-RV	12	20						
16	9	13	342.30	2.71	.00	.00	1.21	2.93
17	13	14	342.30	2.35	.00	.00	1.21	2.93
18	14	15	342.30	7.53	.00	.00	1.21	2.93
19	15	16	342.30	1.63	.00	.00	1.21	2.93
20	16	17	342.30	3.16	.00	.00	1.21	2.93
21	17	18	342.30	.61	.00	.00	1.21	2.93
22-RV	18	19						
23-FG	19	0	342.30	.15	.00	.00	1.21	2.93
24-FG	20	0	357.80	.39	.00	.00	1.82	7.72

J U N C T I O N N O D E R E S U L T S

JUNCTION NUMBER	JUNCTION TITLE	EXTERNAL DEMAND (l/s)	HYDRAULIC GRADE (m)	JUNCTION ELEVATION (m)	PRESSURE HEAD (m)	JUNCTION PRESSURE (kpa)
1		.00	7.99	8.55	-.56	-5.53
2		.00	53.40	8.55	44.85	439.88
3		.00	52.55	8.55	44.00	431.47
4		.00	51.94	16.24	35.70	350.07
5		.00	51.67	21.48	30.19	296.02
6		.00	49.70	5.52	44.18	433.24
7		.00	48.95	15.95	33.00	323.64
8		.00	46.65	6.74	39.91	391.35
9		.00	45.74	12.83	32.91	322.71
10		.00	45.43	13.70	31.73	311.15
11		.00	38.29	1.97	36.32	356.14
12		.00	32.11	21.73	10.38	101.79
13		.00	43.02	18.20	24.82	243.44
14		.00	40.67	1.40	39.27	385.11
15		.00	33.14	11.17	21.97	215.47
16		.00	31.51	-.22	31.73	311.15
17		.00	28.35	22.44	5.91	57.93
18		.00	27.73	18.63	9.10	89.26
19		.00	25.35	18.63	6.72	65.87
20		.00	26.64	21.73	4.91	48.11

GOTATHUWA KOLONNAWA TRANSMISSION SYSTEM

Hydraulic Analysis

Year 2020 Situation - Three duty pumps in parallel and with flow control devices installed
At Gotathuwa and Kolonnawa Reservoirs

R E G U L A T I N G V A L V E R E P O R T

VALVE TYPE	POSITION NODE	CONTROLLED PIPE	VALVE SETTING (m or l/s)	VALVE STATUS	UPSTREAM GRADE (m)	DOWNSTREAM GRADE (m)	THROUGH FLOW (l/s)
FCV-1	12	15	357.80	THROTTLED	32.11	26.64	357.80
FCV-1	18	22	342.30	THROTTLED	27.73	25.35	342.30

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM FIXED GRADE NODES
(-) OUTFLOWS FROM THE SYSTEM INTO FIXED GRADE NODES

PIPE NUMBER	FLOWRATE (l/s)
1	700.10
23	-342.30
24	-357.80
NET SYSTEM INFLOW =	700.10
NET SYSTEM OUTFLOW =	-700.10
NET SYSTEM DEMAND =	.00


**** KYPIPE SIMULATION COMPLETED ****

DATE: 10/17/2000
TIME: 9: 8:55

GOTHATUWA - KOLONNAWA TRANSMISSION MODEL

DESIGN FLOWS, L/s

AREA	2005	2010	2015	2020
GOTHATUWA	255.0	285.5	320.0	357.8
KOLONNAWA	116.0	216.0	342.3	342.3
TOTAL	371.0	501.5	662.3	700.1



GOTHATUWA GROUND RESERVOIR


26.25
 ∇ 23.75
 ∇ 20.0


KOLONNAWA NEW RESERVOIR


∇ 25.2
 ∇ 23.75
 ∇ 15.7


**GOTHATUWA TRANSMISSION MAIN
– SURGE ANALYSIS**





	A	B	C	D	E	F	G	H	I	J
1	 CEYWATER	PROJECT:- Greater Colombo NRW Reduction							Job No	
2									Des. By	AP
3		COMPONENT:- G'thuwa K'nawa Pumping Main							Checked	
4		Surge Analysis							Date	25-7-00
5										
6	1. Design Flow Condition									
7	The surge control system is designed to cater for the year 2020 flow condition ie								700.1 l/s	
8										
9	2. Design of Surge Control System									
10										
11	Introduction									
12										
13	In the event of power failure or a rapid pump shutdown, the pump rapidly decelerates from steady									
14	speed to zero speed, causing abrupt decrease of discharge into the pumping main, while the water									
15	body in the pipeline still moves forward. At this time a negative pressure wave is created just upstream									
16	of the pump and this wave rapidly travels from pump station end of the force main to its discharge end.									
17	This negative pressure wave decelerates the flow in the pumping main and when it reaches the discharge									
18	end it is reflected back in the direction of pumping station as a positive wave which further reduces the									
19	flow in the pumping main. When this positive wave reaches the pump station the cycle of wave travel is									
20	completed. When the pump comes to a stand still the check valve closes and isolates the pump from									
21	the force main.									
22	However, pressure wave cycle is repeated until all the energy has been dissipated by friction in the pipe.									
23	The round trip travel time of the pressure wave is termed the critical period. The magnitude of the pressure									
24	build up at the pump is dependent on whether the flow is stopped in a time interval equal to or less than									
25	or greater than the critical period.									
26										
27	Surge Analysis									
28										
29	The critical period T (in secs) is given by									
30	$T = 2 \cdot L / a$									
31	where L = Length of the pumping main between pump station and point of discharge in m									
32										
33	From Ambatale WTP up to the hospital junction :-							800 mm dia DI with L=	2510	
34	From the hospital junction up to Gotathuwa reservoir site :-							500 mm Dia DI with L=	1818	
35	From the hospital junction up to Kolonnawa reservoir site :-							600 mm Dia DI with L=	6151	
36								Maximum L =	8661	
37										
38	Hs =		Static Head		=		15.92 m			
39	a =		Velocity of pressure wave in m/s							
40										
41	Pressure wave velocity in m/s is given by									
42	$a = 1440 / (1 + C1 \cdot (K \cdot d / E \cdot e))^{0.5}$									
43	where C1 = 1, for pipe with expansion joints throughout;									
44	1-u ² , for pipes anchored against axial movement throughout (ex. buried pipes)									
45	5/4-u, for pipes without expansion joints and anchored at the upstream end;									
46	u = Poisson's Ratio									
47	K = Bulk Modulus of Water taken as		2.2E+09		N/sq m					
48	d = Pipe diameter, m									
49	E = Modulus of elasticity of pipe material in MN/sq m									
50	e = Pipe wall thickness in m									
51										
52	For	0.5	0.60	0.80 m dia. Class K9 DI pipe,						
53	u =	0.28								
54	E =	1.7E+11								
55	e =	0.0140	0.0150	0.0175						
56	C1 =	0.92 for buried pipeline								
57	a =	1200	1179	1152	Average a		= 1177.28 m/s			

	A	B	C	D	E	F	G	H	I	J
1	 CEYWATER	PROJECT:- Greater Colombo NRW Reduction							Job No	
2									Des. By	AP
3		COMPONENT:- G'thuwa K'nawa Pumping Main							Checked	
4	Surge Analysis							Date	25-7-00	
58	Therefore critical period T			=	13.87431	secs	for Kolonnawa branch			
59				=	4.260303	secs	for Gotathuwa branch			
60										
61	The magnitude of the maximum water hammer pressure Ps (in m) at pump discharge is given by									
62										
63	$P_s = a \cdot v / g$									
64	where	a =	Pressure wave velocity in m/s							
65		v =	Steady flow velocity in m/s				=	1.47	average	
66		g =	Gravity constant in m/s ²							
67										
68	In the case of a pump trip this pressure is negative. For this to happen, pump speed must reach zero									
69	within a time period less than the critical time.									
70	When pressure in the pipeline reaches sub atmospheric conditions, vapor bubbles start									
71	developing and gives rise to sudden implosion into the inter space between water and pipe.									
72	This phenomenon is called "cavitation" and it can cause damage to pipes and equipment.									
73	Hence, it is very important that pipeline and equipment is adequately protected against									
74	cavitaion.									
75	When pressure wave approaches the pump after reflecting back at the reservoir end, the reverse velocity									
76	causes a positive surge and the cycle repeats until all energy has been dissipated.									
77										
78	Analysis of Pressure/Flow Transients									
79										
80	<u>Introduction</u>									
81	The computer program "SURGE 4" which is a separate module of KYPIPE2 has been used to analyze									
82	and determine the type and magnitude of surge control equipment required for this application.									
83	This program provides for analyzing the hydraulics of the system at a number of time intervals measured									
84	from the time of pump stoppage. Time period for the analysis is predetermined, which in this case we									
85	have used 100 seconds and 200 seconds.									
86										
87	The steps of analysis is briefly described as follows:									
88	1 Develop a geometric layout of the basic system (without provision for surge control devices)									
89	indicating all parameters viz. pipe lengths, diameters, nodal elevations pump curves etc.									
90	Refer Figure 1									
91	2 Create a data (DAT) file using KYPIPE2.									
92	3 Execute a snap shot run for steady state analysis.									
93	4 Convert KYPIPE DAT file into Steady state Initial Condition (SIC) using C-SIC data conversion									
94	program.									
95	5 Run C-SIC program and create the Initial Condition File (ICF) required for the Surge Analysis.									
96	6 Open the already created ICF file within SURGE4 Program and, edit and modify data as									
97	required by the SURGE4 program to simulate pump trip.									
98	7 Run the program and compile results of flows and pressures from Pump Station end of the									
99	pipeline up to the delivery end at the reservoir.									
100	8 Modify the geometric model to include side discharge orifices (SDOs) for modeling surge									
101	control facilities such as surge tanks and air valves (Refer Figure 2).									
102	9 Input additional data for surge tank and air valves.									
103	10 Repeat steps 1 to 7 and compile results including variation of gas volume within the surge									
104	tank.									
105	11 Execute number of trial runs and determine the most economical size for the surge tank									
106	12 Design layout, piping and air compressor for the surge tank.									
107										
108										
109										
110										
111										

	A	B	C	D	E	F	G	H	I	J	
1	 CEYWATER			PROJECT:- Greater Colombo NRW Reduction					Job No		
2									Des. By	AP	
3				COMPONENT:- G'thuwa K'nawa Pumping Main					Checked		
4	Surge Analysis					Date	25-7-00				
112	Computer Runs										
113											
114	The following computer runs were executed for the simulation of "pump trip" under different operational										
115	scenarios:										
116											
117	Run 1 The system with no surge control device and with one pump in operation delivering the										
118	ultimate design output of 700.1 l/s to Gotathuwa and Kolonnawa										
119	Run 2 The system with no surge control device and with one pump in operation delivering										
120	the ultimate design output to Gotathuwa only										
121	Run 3 The system with no surge control device and with one pump in operation delivering										
122	the ultimate design output to Kolonnawa only										
123	Run 4 The system with surge control device in place and with one pump in operation delivering										
124	the ultimate design output to Gotathuwa and Kolonnawa.										
125											
126	Program assumptions:-										
127											
128	<ul style="list-style-type: none"> ■ Within the program, each of the pipelines is divided into line segments as indicated in network diagrams. Each line segment is defined by the program by assigning two numbers one at the starting point and the other at the end point. 										
129											
130											
131	<ul style="list-style-type: none"> ■ The basic parameters calculated by the program for each of the line segment are: 										
132	<ul style="list-style-type: none"> • Number of wave travel increments in terms of time increment provided, which in this case .01 seconds was allocated. 										
133											
134	<ul style="list-style-type: none"> • Factor c/gA which is (wave speed)/(gravity constant*cross sectional area of pipe) 										
135	Initial flowrate										
136	<ul style="list-style-type: none"> • Segment Resistance 										
137	<ul style="list-style-type: none"> • Pump Curves are defined by quadratic curves with A, B and C as constants: 										
138	<ul style="list-style-type: none"> ■ The wave speed is assumed to remain constant in all pipe branches 										
139	<ul style="list-style-type: none"> ■ Simulation time is taken as 100 seconds for the runs 1, 2 and 3 and 200 secs for the run 4. 										
140	<ul style="list-style-type: none"> ■ Multiple pumps have been simplified, to be represented by one equivalent pump 										
141	<ul style="list-style-type: none"> ■ Duration of 1 second is allowed for the pump to come to a complete stop from the time of sudden stoppage 										
142											
143	<ul style="list-style-type: none"> ■ The gas volume within the surge tank is assumed to follow adiabatic compression and expansion with gas constant = 1.1 										
144											
145											
146	Presentation of Results:-										
147											
148	Computer printouts of SIC and Surge Analysis programs for each of the Runs mentioned above are										
149	enclosed in the Appendix. The results are summarized as follows:										
150											
151	Run 1										
152	Computer File Organization:-										
153	Steady State Initial Condition Input Data File					:	gk_ic1.SIC				
154	Steady State Initial Condition Output Data File					:	gk_ic1.TIC				
155	Surge Analysis										
156	Input Data File					:	gk_ic1.DAT				
157											
158	Results Interpretation:-										
159	Maximum Pressure occurs at the position 3 and is equal to 318.3 m.										
160	During the surge sub atmospheric pressure will develop along the pipeline. Along the pipeline										
161	sub-atmospheric pressure will reach cavitation range i e -10.1 m.										
162	The maximum pressure of 318.3 m as well as the sub atmospheric pressure condition is not acceptable										
163	since this phenomenon would result in cavitation and possible damage to the pipeline.										
164	to the system.										
165	The results are graphically represented in the attached Charts 1 and 2.										


	A	B	C	D	E	F	G	H	I	J
1	 CEYWATER	PROJECT:- Greater Colombo NRW Reduction							Job No	
2									Des. By	AP
3		COMPONENT:- G'thuwa K'nawa Pumping Main							Checked	
4	Surge Analysis							Date	25-7-00	
166										
167	Run 2									
168										
169	Computer File Organization:-									
170	Steady State Initial Condition Input Data File					:	gk_ic2.SIC			
171	Steady State Initial Condition Output Data File					:	gk_ic2.TIC			
172	Surge Analysis									
173	Input Data File					:	gk_ic2.DAT			
174	Output File					:	gk_ic2.OUT			
175										
176	<u>Results Interpretation:-</u>									
177										
178	The positive surge is not so severe as in the case of Run 1 and the maximum pressure of 115.1 m occurs									
179	at position 4. However, negative surge will reach cavitation pressure soon after the pump.									
180										
181	The results are graphically represented in the attached Charts 2 and 3.									
182										
183	Run 3									
184										
185	Computer File Organization:-									
186	Steady State Initial Condition Input Data File					:	gk_ic3.SIC			
187	Steady State Initial Condition Output Data File					:	gk_ic3.TIC			
188	Surge Analysis									
189	Input Data File					:	gk_ic3.DAT			
190	Output File					:	gk_ic3.OUT			
191										
192	<u>Results Interpretation:-</u>									
193										
194	The positive surge is not so severe as in the case of Runs 1 & 2 and the max. pressure of 108.6 m occurs									
195	at position 5. However, negative surge will reach cavitation pressure along the pipeline.									
196										
197	The results are graphically represented in the attached Charts 5 and 6.									
198										
199	Run 4									
200	Run 4 simulates "pump trip" with the surge tank in place and for the operational scenario defined under									
201	Run 1.									
202										
203	Computer File Organization:-									
204	Steady State Initial Condition Input Data File					:	gk_ic4.SIC			
205	Steady State Initial Condition Output Data File					:	gk_ic4.TIC			
206	Surge Analysis									
207	Input Data File					:	gk_ic4.DAT			
208	Output File					:	gk_ic4.OUT			
209										
210	With the surge tank in place, a maximum pressure of 83.3 m occurs at position 3. The pipeline will not									
211	be subjected to sub atmospheric pressure up to -10.1 m. Hence the system is not at risk.									
212	The sub-atmospheric pressure indicated for positions 1, 2 and 3 can be disregarded since water in the									
213	clear water tank will flow into the negative pressure region and nullifies the vacuum.									
214	Pressure wave energy is absorbed by the volume of gas in the surge tank. The gas volume increases									
215	from 7 cum to a maximum of 19.6 cum and gradually decreases to 17.6 cum at the end of 200 secs.									
216	The initial gas head is estimated at							41.6 m		
217										
218	The surge tank must be so sized that adequate water level is maintained within the tank at all times									
219	without allowing the tank to go empty. Sizing of the tank is indicated later in this calculation.									

	A	B	C	D	E	F	G	H	I	J
1		CEYWATER	PROJECT:- Greater Colombo NRW Reduction						Job No	
2									Des. By	AP
3			COMPONENT:- G'thuwa K'nawa Pumping Main						Checked	
4	Surge Analysis						Date	25-7-00		
220										
221	The results are graphically represented in the attached Charts 7, 8 and 9 representing:									
222										
223	Variation of Head and Flow Vs. Time at Position 22									
224	Gas Volume Vs. Time									
225										
226										
227	Sizing of the surge vessel:-									
228										
229	The proposed surge vessel is designed to cater for the ultimate operating condition of 700.1 l/s and									
230	should be able to withstand a pressure of 10 bar.									
231										
232	As per above analysis, maximum gas volume = 19.6 cu m									
233	To avoid gas escaping into the pipeline, a 50.00 % buffer capacity is usually allowed.									
234	Hence the required capacity of the vessel = 29.4 cu m									
235	Say 30 cu m									
236										
237										
238										
239										
240	Replaceable bladder type hydropneumatic tank (2 in number) is selected with the following dimensions:									
241	Diameter of the vessel						=	2 m		
242	Overall Height of the vessel						=	5.97 m		
243										
244										
245	Design of Air Compressor:-									
246										
247	Initial gas volume						=	7 cu m		
248	Initial gas head (gage)						=	41.6 m		
249	Atmospheric Pressure						=	10.34 m		
250	Therefore, Initial gas head (absolute)						=	51.94 m		
251	Applying Boyle's Law PV = constant, equivalent volume of free air						=	35.1625 cu m		
252							=	35162.5 liters		
253	Provide a compressor conforming to following:									
254										
255	Capacity in terms of Free Air Delivery (FAD)						=	26.66 l/s		
256	Operating Pressure						=	10 bar		
257							=	101.97 m		
258	Absolute Operating Pressure						=	112.31 m		
259	Time taken to pressurize the vessel						=	1318.92 secs		
260							=	21.982 mins		
261							OK			
262										
263	Theoretical Air Power for the compressor in kW is given by:-									
264										
265	$((P1 \cdot FAD) / 10) \cdot \ln(P2 / P1)$									
266										
267	Where P is the absolute pressure in bar at initial and final conditions									
268										
269	Therefore, theoretical air power						=	6.44824 kW		
270										
271	Required Horse Power of the motor is generally						2 times the theoretical horse power.			
272	Therefore, required motor horse power						=	12.8965 kW		
273	Provide a motor of capacity						=	15 kW		

	A	B	C	D	E	F	G	H	I	J
1	 CEYWATER	PROJECT:- Greater Colombo NRW Reduction							Job No	
2									Des. By	AP
3		COMPONENT:- G'thuwa K'nawa Pumping Main							Checked	
4		Surge Analysis							Date	25-7-00
274										
275	Computation of size of the air receiver:-									
276										
277	Required volume of the receiver is given by:									
278										
279	Vr = $60 \cdot C \cdot B / P$ for constant demand									
280	Vr = $180 \cdot C \cdot B / P$ for variable demand									
281	Where C = Output of the compressor in FAD l/s									
282	B = Atmospheric Pressure in bar absolute									
283	P = Working Pressure in bar absolute									
284	B = 1.01 bar									
285	P = 10 bar									
286	Vr for constant demand = 161.56 liters									
287	Vr for variable demand = 484.679 liters									
288										
289	Therefore, provide a air receiver with volume not less than 480 liters									

GOTATHUWA - KOLONNAWA TRANSMISSION SYSTEM MODEL FOR SURGE ANALYSIS (WITHOUT SURGE CONTROL FACILITIES)

FIGURE 1



LEGEND

- NODE Nr.
- NODE ELEVATION m.
- PIPE Nr.
PIPE DIA mm.
PIPE LENGTH m.
MINOR LOSS COEF.
- POSITION Nr.
- PUMP
- NON-RETURN VALVE
- FLOW CONTROL DEVICE
- FIXED GRADE NODE (FGW)
- SURGE VESSEL
- AIR VALVE

NOTE:
'C' VALUE IS GLOBALLY TAKEN AS 110

Reduced Drawing
Do Not Scale

FIG. 1	Gothatuwa - Kolonnawa Transmission Model for Surge Analysis		
SCALE		DRG. No.	
JICA STUDY TEAM			
THE DETAILED DESIGN STUDY ON THE PROJECT FOR REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA IN THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA			

GOTATHUWA - KOLONNAWA TRANSMISSION SYSTEM MODEL FOR SURGE ANALYSIS (WITH SURGE TANK AND AIR VALVES IN PLACE)

FIGURE 2




FIG. 2	Gothatuwa - Kolonnawa Transmission Main for Surge Analysis (with surge control facilities)		
SCALE		DRG. No.	
JICA STUDY TEAM THE DETAILED DESIGN STUDY ON THE PROJECT FOR REDUCTION OF NON-REVENUE WATER IN THE GREATER COLOMBO AREA IN THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA			

Reduced Drawing
Do Not Scale